

# 2010 FACILITIES ASSESSMENT EAST HIGH




<b>Project Data</b>	
<b>Location Code:</b>	127
<b>Address:</b>	3206 Poplar Avenue
<b>Year Built:</b>	1948
<b>Grade Configuration:</b>	9-12
<b>Student Capacity:</b>	1550
<b>Ideal Capacity:</b>	1,286
<b>ADA Student Enrollment:</b>	0
<b>Size:</b>	32.76 acres
<b>Portables:</b>	0
<b>Building &amp; Addition</b>	201,0543 s. f.




## 2010 FACILITIES ASSESSMENT EAST HIGH

<p><b>Description:</b></p> <p>Replace chillers and pumps</p>	<p><b>No Picture available</b></p>
<p><b>Timeline:</b></p> <p><b>2010-11</b></p>	<p><b>Cost</b></p> <p><b>\$612,000</b></p>

<p><b>Description:</b></p> <p>Replace major components and parts to bring elevator up to ADA compliance</p>	<p><b>No picture available</b></p>
<p><b>Timeline:</b></p> <p><b>2010-11</b></p>	<p><b>Cost</b></p> <p><b>\$71,400</b></p>

<p><b>Description:</b></p> <p>Replace gymnasium lighting</p>	
<p><b>Timeline:</b></p> <p><b>2010-11</b></p>	<p><b>Cost</b></p> <p><b>\$35,700</b></p>

# 2010 FACILITIES ASSESSMENT EAST HIGH

<p><b>Description:</b></p> <p>Intercom System</p> <p>Rauland MCZ3000</p> <p>Installation Date: 2001</p>	
<p><b>Timeline:</b></p> <p><b>2010-11</b></p>	<p><b>Cost</b></p> <p><b>\$90,000</b></p>
<p><b>Description:</b></p> <p>Reconstruction of 3,800 sq yd of asphalt parking lot</p>	
<p><b>Timeline:</b></p> <p><b>2010-11</b></p>	<p><b>Cost</b></p> <p><b>\$57,500</b></p>
<p><b>Description:</b></p> <p>PVC Single Ply roof: 7 years-fair</p>	
<p><b>Timeline:</b></p> <p><b>TBD</b></p>	<p><b>Cost</b></p> <p><b>\$730,000</b></p>