



# 2010 FACILITIES ASSESSMENT MITCHELL HIGH




Project Data	
<b>Location Code:</b>	167
<b>Address:</b>	658 Mitchell
<b>Year Built:</b>	2002
<b>Grade Configuration:</b>	9-12
<b>Student Capacity:</b>	1175
<b>Ideal Capacity:</b>	1,041
<b>ADA Student Enrollment:</b>	2
<b>Size:</b>	20 acres
<b>Portables:</b>	0
<b>Building &amp; Addition</b>	117,630 s. f


# 2010 FACILITIES ASSESSMENT MITCHELL HIGH


<b>Description:</b> Fencing in NW corner of school property is damaged	
<b>Timeline:</b>  <b>TBD</b>	<b>Cost:</b>  <b>\$1,000</b>

<b>Description:</b> Dumpsters (2) need enclosures	
<b>Timeline:</b>  <b>TBD</b>	<b>Cost:</b>  <b>\$10,000</b>

<b>Description:</b> Replace gymnasium lighting	
<b>Timeline:</b>  <b>2010-11</b>	<b>Cost:</b>  <b>\$36,000</b>

# 2010 FACILITIES ASSESSMENT MITCHELL HIGH

<p><b>Description:</b></p> <p>EDPM Single ply roof: 10 years-poor</p> <p>Built up modified roof: 6 years-fair</p> <p>Metal roof- 10 years-fair</p>	
<p><b>Timeline:</b></p> <p><b>TBD</b></p>	<p><b>Cost:</b></p> <p><b>\$648,500</b></p>

<p><b>Description:</b></p> <p>Intercom System:</p> <p>Bogen MCP35A</p> <p>Installation Date: 2000</p>	
<p><b>Timeline:</b></p> <p><b>TBD</b></p>	<p><b>Costs:</b></p> <p><b>\$90,000</b></p>