




2010 FACILITIES ASSESSMENT
SHEFFIELD CTC





Project Data	
Location Code:	248
Address:	4350 Chuck Street
Year Built:	N/A
Grade Configuration:	N/A
Student Capacity:	N/A
Ideal Capacity:	N/A
ADA Student Enrollment:	N/A
Size:	N/A
Portables:	0
Building & Additions:	

2010 FACILITIES ASSESSMENT SHEFFIELD CTC

<p>Description:</p> <p>Interior paint is in poor condition.</p>	
<p>Timeline:</p> <p>TBD</p>	<p>Cost:</p> <p>\$63,000</p>
<p>Description:</p> <p>Second floor classrooms do not have finished ceilings and HVAC duct needs painting.</p>	
<p>Timeline:</p> <p>TBD</p>	<p>Cost:</p> <p>\$11,000</p>
<p>Description:</p> <p>Exterior brick is cracked mortar is loose or missing.</p>	
<p>Timeline:</p> <p>TBD</p>	<p>Cost:</p> <p>\$6,500</p>

2010 FACILITIES ASSESSMENT SHEFFIELD CTC

Description: PVC Single Ply roof: 9 years-good	
Timeline: TBD	Cost: \$238,000

Description: Intercom System: Bogen MCP35A Installation Date: 2000	
Timeline: TBD	Cost: \$70,000