

| Count of Craft | Craft | | | | | | | | | |
|----------------------------|----------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabiling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Administration Bldg (8550) | 1 | 14 | 32 | 89 | 41 | 15 | 46 | 3 | 7 | 248 |
| Grand Total | 1 | 14 | 32 | 89 | 41 | 15 | 46 | 3 | 7 | 248 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-------------------------------|--|----------------|------------------|--------------------|----------|
| Administration Bldg (8550) 2A | floor tiles are loose in Auditorium by stage and by section A storeroom door | 3/20/14 | Auditorium | COE Auditorium | Asbestos |
| Administration Bldg (8550) 2A | Access DNSI - (Service call) assist NCE department in Network Cabling needed for Admin Room 115 Project Management and IT Dept CIO Room located in legacy SCS area of Admin. | 3/21/14 | | | Cabling |
| Administration Bldg (8550) 2A | Project Management for Access DNSI to provide Network Cabling needed for Admin (Barnes area) Room designated for IT Dept CIO - the Room is located in legacy SCS area of Admin- Project | 3/26/14 | | | Cabling |
| Administration Bldg (8550) 2A | Provide support for service call at Barnes SCS legacy part of the Administration building. We request one data tech to work with Charles White 601-6420 and SCS Elite construction crew . This | 6/9/14 | | | Cabling |
| Administration Bldg (8550) 2A | Please facilitate Service call for Access to troubleshoot problems with drops in the admin building front desk | 5/30/14 | | | Cabling |
| Administration Bldg (8550) 2A | Access is requested to perform a service call of installing a drop for EMS system. This request was submitted by Mike friar and approved by Eddie Miller budget 2922 | 4/25/14 | | | Cabling |
| Administration Bldg (8550) 2A | port needs to be opened in Gail Lynns office #256 all ports are closed now two offices port next to it #is 256-6v IDF1 256-D-48 in back office (Request Network Cabling Installation Support) | 7/19/13 | 2nd Floor | rm#256 Gail Lynn | Cabling |
| Administration Bldg (8550) 2A | admin blgd. WO-- 371704-- add ethernet cable extension to phone line so it will go behind desk along wall and not stretched across the desk -138 Ramones office (Request Network Cabling | 8/6/13 | 1st Floor | 138 Ramones office | Cabling |

| | | | | | | |
|-------------------------------|--|----------|---------------------|-----------------|--|-----------|
| Administration Bldg (8550) 2A | Access data is needed to install three data drops throughout Administration office for EMS.(Request Network Cabling Project Management). | 8/15/13 | | | | Cabling |
| Administration Bldg (8550) 2A | Need technician to hang projector screen in auditorium. | 8/29/13 | | | | Cabling |
| Administration Bldg (8550) 2A | Provide project management for the creation of a exercise room at admin building | 9/12/13 | | | | Cabling |
| Administration Bldg (8550) 2A | meeting at administration Bldg.at 5-30-6.00. | 9/18/13 | | | | Cabling |
| Administration Bldg (8550) 2A | Repair Fiber Optic Cable in the Legacy SCS Data Center. This cable connects the Legacy MCS Data Center to the SCS Data Center. | 10/29/13 | | | | Cabling |
| Administration Bldg (8550) 2A | Install data cabling to room B5 at the SCS Administration Building | 11/10/14 | | | | Cabling |
| Administration Bldg (8550) 2A | Renovations to the commissioner desks in the admin auditorium (Request Network Cabling Installation Support). | 7/29/13 | | | | Cabling |
| Administration Bldg (8550) 2A | FRONT DOOR HANDLE HAS BROKEN PLANT MGR- BLACK/416.5300 | 3/20/14 | | | | Carpentry |
| Administration Bldg (8550) 2A | Replace front door closer not checking and slamming shut,hitting people waiting to go through metal detector. | 3/20/14 | Administration Area | front exit door | | Carpentry |

| | | | | | |
|-------------------------------|--|---------|------------|-------------------------|-----------|
| Administration Bldg (8550) 2A | Install three white boards in three offices in room 115, white boards are on site. | 4/3/14 | 1st Floor | rm115 IT | Carpentry |
| Administration Bldg (8550) 2A | Install white board in middle office with glass wall, white board is on site | 4/3/14 | 2nd Floor | rm205 IT legacy SCS | Carpentry |
| Administration Bldg (8550) 2A | Tape off area in the hallway. | 4/4/14 | | | Carpentry |
| Administration Bldg (8550) 2A | Repair door | 4/9/14 | | | Carpentry |
| Administration Bldg (8550) 2A | Mount a 4 X 8 bulletin board and coat hook in the DOM'S office. | 4/14/14 | | | Carpentry |
| Administration Bldg (8550) 2A | Repair tailor for paint shop. | 2/20/14 | | | Carpentry |
| Administration Bldg (8550) 2A | floor tiles in front of auditorium are loose in two sections in section A | 2/26/14 | Auditorium | auditorium section A | Carpentry |
| Administration Bldg (8550) 2A | install white board in Jessica Lotz office in room 256 board is on site. | 6/3/14 | 2nd Floor | 256 Jessica Lotz office | Carpentry |
| Administration Bldg (8550) 2A | Repairs at the shop. | 6/5/14 | | | Carpentry |

| | | | | | |
|-------------------------------|--|---------|------------|---------------------------------|-----------|
| Administration Bldg (8550) 2A | hang white board in this office white board on site | 6/19/14 | 2nd Floor | Chief of staff asst. rm210 | Carpentry |
| Administration Bldg (8550) 2A | FRONT ENTRY EXIT DR ON LEDGACY SHELBY SIDE LATCH WON'T LOCK - PM/REDDICK 416-9357 | 4/23/14 | | | Carpentry |
| Administration Bldg (8550) 2A | replace cove base on hallway wall across from room 126 | 5/27/14 | 1st Floor | hallway wall across from 126 | Carpentry |
| Administration Bldg (8550) 2A | Request floor be repaired. | 5/29/14 | | | Carpentry |
| Administration Bldg (8550) 2A | Renovations in Rm. 164 - HR and PACE | 5/2/14 | | | Carpentry |
| Administration Bldg (8550) 2A | FRONT ENTRANCE DOOR PARK SERVICES AREA-NOT LOCKING, WON'T BE ABLE TO SECURE BLDG-PLANT MGR REDDICK 416-5397 KLR | 5/6/14 | | | Carpentry |
| Administration Bldg (8550) 2A | replace missing cove base in cafeteria | 5/21/14 | Cafeteria | behind vending machines | Carpentry |
| Administration Bldg (8550) 2A | place two white boards on wall in Chief Of Innovations office wall see him or Linda Millhouse for location on wall | 7/19/13 | 2nd Floor | SCS BLDG 206 | Carpentry |
| Administration Bldg (8550) 2A | rehang hall of fame pictures that were removed for project work completions | 7/31/13 | Auditorium | auditorium | Carpentry |

| | | | | | |
|-------------------------------|---|----------|---------------------|-------------------------------------|-----------|
| Administration Bldg (8550) 2A | DOOR KNOB HAS COME COMPLETELY OFF DOOR TO RM 115 LEGAL OFC- DOOR IS CLOSED NOW AND ITS THE ONLY ACCESS TO OFC PER SBE-SBE REDDICK 416-5397 KLR | 8/8/13 | | | Carpentry |
| Administration Bldg (8550) 2A | Install bulletin board on wall in Laura Links office she has the bulletin board on site | 8/13/13 | 2nd Floor | office 256 Laura Link | Carpentry |
| Administration Bldg (8550) 2A | place new parking signs on building in designated spots marked on building see Plant Mngr. or Officer Pete in security for correct placement, signs are on site. | 8/30/13 | Parking Lot | superintendent and security parking | Carpentry |
| Administration Bldg (8550) 2A | repair front entrance doors so that lock will contact properly for doors to lock on exit side when visitors leave. The doors are not locking when exited so that no one can enter without ID's not electronic on exit side but a contact spring lock. | 9/11/13 | Administration Area | leagacy SCS B building entrance | Carpentry |
| Administration Bldg (8550) 2A | Shop work. | 10/15/13 | | | Carpentry |
| Administration Bldg (8550) 2A | CRASH BAR FRONT ENTRANCE DOOR- DAMAGED, NOT ABLE TO ENTER-PLANT MGR REDDICK 416-5397 KLR | 10/22/13 | | | Carpentry |
| Administration Bldg (8550) 2A | (Special General Services Project) LEGAL SERVICES - Renovations to SCS Administration Building – Rooms 218, and 220 (Legal Counsel) | 10/23/13 | | | Carpentry |
| Administration Bldg (8550) 2A | Project Director(s): repair entry door to Human Resource door frame is moving preventing electronic access from from unlatching door all the way | 11/13/13 | 1st Floor | 164 HR | Carpentry |
| Administration Bldg (8550) 2A | place caulking around three pipes leading from boiler room to outside above entrance door to prevent rodents from entering basement | 12/19/13 | Mechanical Room | basement boiler rm. | Carpentry |

| | | | | | | |
|-------------------------------|---|---------|------------|----------------------|--|------------|
| Administration Bldg (8550) 2A | Mount lift on the back of truck. | 1/16/14 | | | | Carpentry |
| Administration Bldg (8550) 2A | replace missing floor tile on elevator #2 by rm 116 | 1/24/14 | Elevator | #2 by rm116 | | Carpentry |
| Administration Bldg (8550) 2A | repair loose floor tiles in auditorium. Several tiles are loose at the front of the auditorium in section A, and slipping when walked on. | 1/24/14 | Auditorium | auditorium | | Carpentry |
| Administration Bldg (8550) 2A | bad ballast in three light fixtures in this office | 3/24/14 | 1st Floor | rm 148b stars office | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in Ray Hopskins office in security no lights in his office | 3/26/14 | 1st Floor | rm 140 security | | Electrical |
| Administration Bldg (8550) 2A | Prepare for Art Fests. Get all the materials together for the activity. | 3/31/14 | | | | Electrical |
| Administration Bldg (8550) 2A | ballast bad on 2nd floor hallway in front of 214 (superintendent office) | 4/4/14 | 2nd Floor | hallway | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in star's office rm 148-a | 4/15/14 | 1st Floor | 148-A | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in Mrs. Cathy's office in 312 | 1/31/14 | 3rd Floor | office 312 | | Electrical |

| | | | | | |
|-------------------------------|---|---------|-------------|--------------------------------|------------|
| Administration Bldg (8550) 2A | need twelve t5 28w 3500k bulbs to replace burned out cubicle lights. | 2/3/14 | Custodial | plant manager office | Electrical |
| Administration Bldg (8550) 2A | hang art fest banner (when ground is dry) Richard Powell knows about this-os Art fest is April 4th & 5th- more w/o's to come as we get closer to date | 2/14/14 | | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast on stairway by rm 115 | 2/24/14 | Stairway | first floor by rm 115 | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast on second floor landing in stairway by rm#206 | 2/24/14 | Stairway | second floor landing by rm 206 | Electrical |
| Administration Bldg (8550) 2A | LED light out in this office over receptionist desk | 3/17/14 | 2nd Floor | legal office 216 | Electrical |
| Administration Bldg (8550) 2A | reset time clock for front lights going off to early in the morning | 3/19/14 | Parking Lot | front entrance | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in Mildred Davis office | 3/20/14 | 2nd Floor | rm 226 Mildred Davis Office | Electrical |
| Administration Bldg (8550) 2A | three lights out at gas pumps covering | 3/20/14 | Parking Lot | Gas pumps | Electrical |
| Administration Bldg (8550) 2A | replace outside lights at entrance to Barnes bldg. Legacy SCS | 3/20/14 | Parking Lot | Front entrance Legacy SCS | Electrical |

| | | | | | |
|-------------------------------|---|---------|---------------------|----------------------|------------|
| Administration Bldg (8550) 2A | need 12 spiral 40w 4100k 120v 60hz 680mA 2600 lumens bulbs | 6/4/14 | Administration Area | plant manager office | Electrical |
| Administration Bldg (8550) 2A | need 20 60w bulbs | 6/4/14 | Administration Area | plant manager office | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in three light fixtures in this office | 6/10/14 | 3rd Floor | office 304 | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in rm 304 at front entrance | 6/19/14 | 3rd Floor | room 304 | Electrical |
| Administration Bldg (8550) 2A | Need 20 bulbs f30t8/cw for cubicle desk lights | 1/28/14 | Custodial | Plant manager office | Electrical |
| Administration Bldg (8550) 2A | AHU ENTIRE 3RD FLR-BELT BROKE PER SBE, NOT COMING ON-PLANT MGR REDDICK 416-5397 KLR | 1/29/14 | | | Electrical |
| Administration Bldg (8550) 2A | WIRING EXPOSED IN HUMAN RESOURCES CONFERENC RM-IT'S SHOCKING PEOPLE PER SBE-PLANT MGR REDDICK 416-5397 KLR | 1/29/14 | | | Electrical |
| Administration Bldg (8550) 2A | repair electrical outlet in cafeteria serving area by warmer. the outlet shot spark when warmer was plugged in. | 1/30/14 | Cafeteria | kitchen serving area | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in second office in auditing | 1/30/14 | 3rd Floor | Off. 312 auditing | Electrical |

| | | | | | |
|-------------------------------|---|---------|-----------------|----------------------|------------|
| Administration Bldg (8550) 2A | bad ballast in light fixture at front desk in finance office | 5/2/14 | 2nd Floor | rm 226 | Electrical |
| Administration Bldg (8550) 2A | Alarm going in the building. | 5/20/14 | | | Electrical |
| Administration Bldg (8550) 2A | VENTING HOOD HAVE NO POWER (071) IN KITCHEN. SBE-BLACK/416-5300 | 7/2/13 | | | Electrical |
| Administration Bldg (8550) 2A | check recepticles in room 206 (old scs side) see Linda Milhouse-os | 7/11/13 | | | Electrical |
| Administration Bldg (8550) 2A | AHU#9 NOT COMING ON IN RM-158,164 LOBBY (036). SBE-REDDICK/416-5300 | 7/15/13 | | | Electrical |
| Administration Bldg (8550) 2A | line trace for trane technician to shut power to control panel | 7/16/13 | Mechanical Room | basement | Electrical |
| Administration Bldg (8550) 2A | remove tombstone from floor behind desk place circuit on wall by desk | 7/19/13 | 2nd Floor | SCS BLDG 206 | Electrical |
| Administration Bldg (8550) 2A | Inspect security system at COW and COE. | 7/23/13 | | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in four light fixtures in this office | 7/31/13 | 2nd Floor | accounts payable 250 | Electrical |

| | | | | | |
|-------------------------------|---|---------|------------------|------------------------------------|------------|
| Administration Bldg (8550) 2A | bad ballast in Dr. Eddie Jones office in 106 legacy scs | 8/6/13 | 1st Floor | 106 legacy scs side | Electrical |
| Administration Bldg (8550) 2A | bad ballast in fixture in basement by plant mangr. office legacy scs side. | 8/6/13 | Hallway/Corridor | basement legacy scs | Electrical |
| Administration Bldg (8550) 2A | bad ballast in three light fixtures in hallway by Labor Relations Office | 8/8/13 | 1st Floor | hallway between rm#132 and rm#138 | Electrical |
| Administration Bldg (8550) 2A | UNIT #9 NOT COMING ON IN RM-158, FRONT LOBBY. PLANT MGR- REDDICK/416.5300 | 8/12/13 | | | Electrical |
| Administration Bldg (8550) 2A | check for bad ballast in managers office bulbs were replaced but lights are blinking on and off | 8/13/13 | Kitchen | cafe mangr. office | Electrical |
| Administration Bldg (8550) 2A | remove tomstones from floor and place circuts on the wall see Joanne Norman in rm#208. There are two tombstones located on the floor. | 8/15/13 | 2nd Floor | 208 Communication Directors Office | Electrical |
| Administration Bldg (8550) 2A | repair light fixture that has fallen from ceiling and is hanging by conduit in isle.will need a lift. | 8/21/13 | 1st Floor | Mail room warehouse | Electrical |
| Administration Bldg (8550) 2A | replace burned out bulbs in mail room will need a lift | 8/21/13 | 1st Floor | mail room warehouse | Electrical |
| Administration Bldg (8550) 2A | AHU PKG SERVES OFCS 138 - 151 PER SBE-NOT COMING ON-PLANT MGR REDDICK 416-5397 KLR | 9/3/13 | | | Electrical |

| | | | | | |
|-------------------------------|--|---------|-----------|--------------------------|------------|
| Administration Bldg (8550) 2A | Plant Mngr. needs (72) T8 Ultramax ECO XI lamps - 46807-requisition number | 9/9/13 | Custodial | basement | Electrical |
| Administration Bldg (8550) 2A | bad ballast in two fixtures in labor relations office | 9/9/13 | 1st Floor | 138 labor relation | Electrical |
| Administration Bldg (8550) 2A | bad ballast in four fixtures in this office | 9/9/13 | 2nd Floor | 208 communications | Electrical |
| Administration Bldg (8550) 2A | three ballast out in park services on first floor two in hallway and one in Mr. Johnson's office | 9/19/13 | 1st Floor | park commission | Electrical |
| Administration Bldg (8550) 2A | bad ballast in park services on second floor two in hall and one in Mrs. Holman's office | 9/19/13 | 2nd Floor | park services | Electrical |
| Administration Bldg (8550) 2A | five bad ballast in 110a,106,164 and two in 128 Terri Jones office | 9/19/13 | 1st Floor | rm# 110a,106,164,and 128 | Electrical |
| Administration Bldg (8550) 2A | four bad ballast in 226 open area and Mildred Davis office,220 and 218 | 9/19/13 | 2nd Floor | rm#226,220 and 218 | Electrical |
| Administration Bldg (8550) 2A | bad ballast in rm 208 conference room | 9/20/13 | 2nd Floor | 208 conference room | Electrical |
| Administration Bldg (8550) 2A | need f32 t8/tl 741 bulbs stock #46807 ,four cases (100)bulbs | 9/20/13 | Custodial | basement | Electrical |

| | | | | | |
|-------------------------------|---|----------|-----------------|----------------------|------------|
| Administration Bldg (8550) 2A | VENT-A-HOOD KITCHEN AREA-NOT COMING ON-WILL NEED-PLANT MGR REDDICK 416-5397 KLR | 9/23/13 | | | Electrical |
| Administration Bldg (8550) 2A | need 100(four cases) t8 Ultramax ECO XL lamps stock#46807 | 9/26/13 | Custodial | plant manager | Electrical |
| Administration Bldg (8550) 2A | need 20 compact florescent light 60w stock# 46820 | 9/27/13 | | | Electrical |
| Administration Bldg (8550) 2A | remove tombstone from floor in room 126 from under receptionist desk | 10/2/13 | 1st Floor | procurement 126 | Electrical |
| Administration Bldg (8550) 2A | replace burned out inset lights in auditorium over board seating area on stage | 10/3/13 | Auditorium | auditorium | Electrical |
| Administration Bldg (8550) 2A | need 30 fbo32/741/6/eco 32 watt bulbs. 30 per case | 10/10/13 | Mechanical Room | Plant Manager Office | Electrical |
| Administration Bldg (8550) 2A | need 30 F30t8/cw 30 watt bulbs | 10/10/13 | Mechanical Room | Plant Manager Office | Electrical |
| Administration Bldg (8550) 2A | bad ballast in office next to Mrs. Niccarrato's office in benefits rm#120 | 10/10/13 | 1st Floor | 120 center office | Electrical |
| Administration Bldg (8550) 2A | need t8 f017/741/eco 17watt bulbs, 30 bulbs | 10/10/13 | Mechanical Room | plant manager office | Electrical |

| | | | | | |
|-------------------------------|--|----------|------------------|------------------------|------------|
| Administration Bldg (8550) 2A | Wire shortage in the basement. | 10/21/13 | | | Electrical |
| Administration Bldg (8550) 2A | install light fixture over womens restroom entrance in first floor hallway per Zeno Williams | 10/25/13 | Hallway/Corridor | park services | Electrical |
| Administration Bldg (8550) 2A | install wall socket in 126 for copier by IDF plug see J Sanders | 10/25/13 | 1st Floor | office 126 procurement | Electrical |
| Administration Bldg (8550) 2A | NO POWER TO LIGHTS ON ELEVATOR (TECH IS ALREADY ON SITE). PLANT MGR- REDDICK/416.5300 | 10/28/13 | | | Electrical |
| Administration Bldg (8550) 2A | Replace cover plates near vending machines per B.Shipp | 10/29/13 | | | Electrical |
| Administration Bldg (8550) 2A | Disconnect printer from power sources. | 10/29/13 | | | Electrical |
| Administration Bldg (8550) 2A | install wall socket covers on light switches and wall sockets in lobby area of park services | 10/30/13 | 1st Floor | park services lobby | Electrical |
| Administration Bldg (8550) 2A | bad ballast in office 114 Jake Allens office | 11/1/13 | 1st Floor | rm 114 | Electrical |
| Administration Bldg (8550) 2A | set parkinglot lights for time change | 11/6/13 | Parking Lot | parking lot | Electrical |

| | | | | | |
|-------------------------------|---|----------|---------------------|-------------------------------|------------|
| Administration Bldg (8550) 2A | LIGHTS HAVE NO POWER IN RM-250 (AP DEPT). PLANT MGR- BLACK/416.5300 | 11/6/13 | | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in two light fixtures in park services office on first floor. | 11/6/13 | 1st Floor | park services | Electrical |
| Administration Bldg (8550) 2A | SWITCH FAILURE.HAS A SHORTEN FOR RM-126. PLANT MGR- BLACK/416.5300 | 11/11/13 | | | Electrical |
| Administration Bldg (8550) 2A | LIGHTS HAVE NO POWER IN RM-126. PLANT MGR- BOBBY/416.5300 | 11/13/13 | | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in rm 318 light fixture in front area behind front desk | 11/15/13 | 3rd Floor | 318 | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in light fixture in lobby hall entrance | 11/26/13 | Administration Area | front lobby by courtyard door | Electrical |
| Administration Bldg (8550) 2A | remove tombstone from floor in this office in room 208 see Joanne Norman | 12/9/13 | 2nd Floor | 208 Christian Ross Office | Electrical |
| Administration Bldg (8550) 2A | generator making loud beeping noise, sounds like a truck backing up | 12/9/13 | Courtyard | outside rear of Barnes bldg | Electrical |
| Administration Bldg (8550) 2A | need 12 compact flr. bulbs to replace burned out bulbs in dinning room | 12/11/13 | Cafeteria | dinning area | Electrical |

| | | | | | |
|-------------------------------|---|----------|---------------------|----------------------------------|------------|
| Administration Bldg (8550) 2A | outside lights out or popping off and on in the rear of Admin. Bldg. by cafe., security, and mail room areas. | 12/23/13 | Parking Lot | rear dock areas | Electrical |
| Administration Bldg (8550) 2A | AHU BASEMENT AREA-NOT COMING ON-CTRLS LEGACY SHELBY COUNTY-PLANT MGR REDDICK 416-5397 KLR | 1/6/14 | | | Electrical |
| Administration Bldg (8550) 2A | need light bulbs 3 cases f34cw-rs-wm-eco | 1/15/14 | Administration Area | plant manager office | Electrical |
| Administration Bldg (8550) 2A | AHU ENTIRE 3RD FLR-NOT COMING ON-PLANT MGR REDDICK 416-5397 KLR | 1/17/14 | | | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in hall light fixture | 1/17/14 | 2nd Floor | hallway by front stairs by rm204 | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in 256 conference room | 1/17/14 | 2nd Floor | rm 256 conference room | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast over Bob Labonia's desk in 208 | 1/17/14 | 2nd Floor | room208 | Electrical |
| Administration Bldg (8550) 2A | replace burned out outside lights over gas pumps | 1/17/14 | Parking Lot | over gas pumps | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in park services, Mr Stigall's office | 1/22/14 | 1st Floor | park services Stigall's office | Electrical |

| | | | | | |
|-------------------------------|--|---------|---------------------|------------------------|---------------------------------------|
| Administration Bldg (8550) 2A | need 100 t8 ultramax ECO XI lamps stock #46807 | 1/22/14 | Administration Area | plant manager office | Electrical |
| Administration Bldg (8550) 2A | replace bad ballast in payroll office over front desk in corner | 1/22/14 | 1st Floor | 130 payroll office | Electrical |
| Administration Bldg (8550) 2A | coils need cleaning on ahu-14 unit in kitchen ID#155-029 unit is blowing dust particles onto food prep arear health department hazard. | 4/24/14 | Kitchen | kitchen | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | CHILLER IS NOT COMING ON - PM/REDDICK 416-9357 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | PACKAGE UNIT - IN SECURITY -RM 152 & 152A - BLOWING NOT COOLING SHOWING 80 DEGREES - PM/REDDICK 416-5397 | 5/30/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Good morning, the air conditioner in the west wing is not working. Thank you. Have a great day. | 6/24/14 | 2nd Floor | Graves Creek-West Wing | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | A/C - RM152 & 152A - BLOWING NOT COOLING - PM/REDDICK 416-5397 | 6/30/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | replace discharge sensors on 3rd floor | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------|---|---------|--|--|---------------------------------------|
| Administration Bldg (8550) 2A | Monthly - ADMIN BLDG LVL 2 WATER TREATMENT - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | AHU NOT HEATING, BELT HAS BROKE IN PARK SERVICE 1ST FLR PLANT MGR- BLACK/416.5300 | 2/6/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | the health clinic on flicker street has no heat per Brian Shipp | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Monthly - Oil Lube & Belt- Administration Bldg - Refer to PM schedule details. | 3/14/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Repair chiller | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Repair units on flicker | 6/11/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | AHU NOT COOLING IN DINING AREA (007). SBE-BLACK/416-5300 | 7/2/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Air handler running, but not cooling, ID#155-007 in the Dining area per Bob Reddick, Plant Mgr at 901.416.5397. | 7/5/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Repair AHU for cafe and chilled water pump | 7/10/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------|--|---------|--|-----|---------------------------------------|
| Administration Bldg (8550) 2A | Repair chiller | 7/17/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | UNIT IN RM 150 NOT COOLING. SBE REDDRICK 416-5397 | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | CO west chiller down per EMS 7.19.13 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | AHU#6 IS OVER COOLING IN RM-102 THRU 110. PLANT MGR- REDDICK/416.5300 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Monthly - Oil Lube & Belt- Administration Bldg - Refer to PM schedule details. | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | THE EMS WAS OFF LINE | 9/6/13 | | EMS | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Chiller down per EMS 9-16-13 | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | repair leak on chem feed at co west | 9/27/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Repair pump | 10/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------|--|----------|--|----------------|---------------------------------------|
| Administration Bldg (8550) 2A | replace andover board | 10/18/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Replace A/C master | 10/31/13 | | Admin building | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | purchase seal for york chiller | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | purchase oil and oil filter for chiller | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | replace seal in york chiller - not to exceed \$5000.00 | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | replace broken shaft and rebuild pump #3 - not to exceed \$5000.00 | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | BOILER IS OVERHEATING ENTIRE 3RD -4TH FLRS ADMIN ASSIST-B LEAKS/416-5300 | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | AC-12 CAFE DINING AREA- NOT HEATING-PLANT MGR REDDICK 416-5397 KLR | 1/17/14 | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | EMS PANEL IS OFF LINE | 1/21/14 | | EMS PANEL | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-------------------------------|--|---------|---------|-----------------|--|---------------------------------------|
| Administration Bldg (8550) 2A | replace VFD on AHU #8 | 1/23/14 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Monthly - Filter-Administration Building - Refer to PM schedule details. | 9/23/13 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Yearly - Oil Samples-Admin Building - Refer to PM schedule details. | 9/1/13 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Monthly - Filter-Administration Building - Refer to PM schedule details. | 1/27/14 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Monthly - Filter-Administration Building - Refer to PM schedule details. | 5/26/14 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Daily - Admin Building Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | Yearly - Cooling Towers-Admin Building - Refer to PM schedule details. | 3/1/14 | | | | Heating/Ventilation /Air Conditioning |
| Administration Bldg (8550) 2A | repair crumbling plaster and pilling paint around kitchen windows. Hazard problem in food prep area. | 2/7/14 | Kitchen | kitchen windows | | Painting |
| Administration Bldg (8550) 2A | PAINT WALLS IN OLD ADMN. BLDG, ALSO CEILING GRID | 2/18/14 | | | | Painting |

| | | | | | |
|-------------------------------|---|---------|--|--|----------|
| Administration Bldg (8550) 2A | paint emergency cut off sign | 2/26/14 | | | Painting |
| Administration Bldg (8550) 2A | paint walls in exercise rm | 6/3/14 | | | Painting |
| Administration Bldg (8550) 2A | water blast scs sign | 7/17/13 | | | Painting |
| Administration Bldg (8550) 2A | paint walls in aud | 8/22/13 | | | Painting |
| Administration Bldg (8550) 2A | paint walls in rm.261 | 9/27/13 | | | Painting |
| Administration Bldg (8550) 2A | mud and paint walls prucement serv. | 10/1/13 | | | Painting |
| Administration Bldg (8550) 2A | paint walls in auditorium closets and storerooms | 10/1/13 | | | Painting |
| Administration Bldg (8550) 2A | paint bracketts for sound baffels in aud. | 10/3/13 | | | Painting |
| Administration Bldg (8550) 2A | paint ceiling grid in rm. 218 | 11/8/13 | | | Painting |

| | | | | | | |
|-------------------------------|---|----------|------------------|-----------------------------------|--|----------|
| Administration Bldg (8550) 2A | mud tape and paint sheetrock | 1/7/14 | | | | Painting |
| Administration Bldg (8550) 2A | PAINT DOORS FOR ROOM | 1/8/14 | | | | Painting |
| Administration Bldg (8550) 2A | PAINT HANDICAPPED LINES ON PARKING LOT | 1/14/14 | | | | Painting |
| Administration Bldg (8550) 2A | paint walls in room in basemen@ old shelby county admn. bldg | 10/15/13 | | | | Painting |
| Administration Bldg (8550) 2A | NO HOT WATER IN KITCHEN PLANT MGR-BLACK/416.5300 | 3/24/14 | | | | Plumbing |
| Administration Bldg (8550) 2A | commode backed up in mens restroom on first floor in legacy scs | 4/2/14 | Restroom (Boys) | first in legacy scs by front hall | | Plumbing |
| Administration Bldg (8550) 2A | commode backed up ladies restroom on second floor in legacy scs | 4/2/14 | Restroom (Girls) | second floor | | Plumbing |
| Administration Bldg (8550) 2A | AC unit leaking. | 4/7/14 | | | | Plumbing |
| Administration Bldg (8550) 2A | Repair wench on sewer machine. | 2/6/14 | | | | Plumbing |

| | | | | | |
|-------------------------------|--|---------|------------------|-------------|----------|
| Administration Bldg (8550) 2A | hand sinks clogged up in men and women restrooms on second floor by rm 218 | 3/5/14 | Restroom (Girls) | by rm 218 | Plumbing |
| Administration Bldg (8550) 2A | Clean sewer area. | 6/6/14 | | | Plumbing |
| Administration Bldg (8550) 2A | Flush sewer lines | 6/9/14 | | | Plumbing |
| Administration Bldg (8550) 2A | Sink stopped up in the clinic. | 6/9/14 | | | Plumbing |
| Administration Bldg (8550) 2A | urinal not flushing on first floor by rm 158 dead battery | 6/18/14 | Restroom (Boys) | by room 158 | Plumbing |
| Administration Bldg (8550) 2A | Sewer stopped-up | 1/27/14 | | | Plumbing |
| Administration Bldg (8550) 2A | AHU -14 unit has water running from a pipe connection that is rusting out the drain pan because of continuous water flow | 4/24/14 | Kitchen | kitchen | Plumbing |
| Administration Bldg (8550) 2A | men toilet by room 308,(REA) does not work. | 5/7/14 | 3rd Floor | | Plumbing |
| Administration Bldg (8550) 2A | FLOOR DRAIN ELEVATOR RM BASEMENT AREA-BACKING UP-PLANT MGR REDDICK 416-5397 KLR | 5/12/14 | | | Plumbing |

| | | | | | |
|-------------------------------|--|---------|------------------|------------------------------|----------|
| Administration Bldg (8550) 2A | flush valve handle broken on the toilet in the men r/r on the 1st floor back hallway of the Park Commission. | 5/14/14 | 1st Floor | Park Commission | Plumbing |
| Administration Bldg (8550) 2A | Faucet leaking, commode and water fountain not working properly. | 5/16/14 | | | Plumbing |
| Administration Bldg (8550) 2A | brown water runs from the hot water faucet when turned on. 1st floor women restroom near 158. | 5/19/14 | 1st Floor | female rest room | Plumbing |
| Administration Bldg (8550) 2A | Clean area drains | 5/20/14 | | | Plumbing |
| Administration Bldg (8550) 2A | the toilet seat is broken in the women restroom on the 2nd floor by 206 | 6/25/14 | 2nd Floor | restroom | Plumbing |
| Administration Bldg (8550) 2A | Flush sewer lines | 6/26/14 | | | Plumbing |
| Administration Bldg (8550) 2A | water cooler not working properly will not shut off and is backed up ID#155-061. | 7/5/13 | 2nd Floor | park services | Plumbing |
| Administration Bldg (8550) 2A | water cooler backed up ID#155-062 park services second floor across from elevator. | 7/5/13 | 2nd Floor | park services | Plumbing |
| Administration Bldg (8550) 2A | mop sink in basement water will not stop running when shut off. | 7/5/13 | Custodial Closet | basement by service elevator | Plumbing |

| | | | | | |
|-------------------------------|--|---------|-----------------|----------------------------------|----------|
| Administration Bldg (8550) 2A | Back flow test. | 8/8/13 | | | Plumbing |
| Administration Bldg (8550) 2A | hand sink in kitchen coming off of wall needs bracing and caulking. | 8/13/13 | Kitchen | kitchen | Plumbing |
| Administration Bldg (8550) 2A | hot water in mop sink will not cut off in this closet | 8/13/13 | Mechanical Room | second floor by service elevator | Plumbing |
| Administration Bldg (8550) 2A | Back flow test | 8/22/13 | | | Plumbing |
| Administration Bldg (8550) 2A | Back flow test (Central Office EAST) | 8/22/13 | | | Plumbing |
| Administration Bldg (8550) 2A | repair two commodes in this portable mens commode will not stop running and womens is over filling the tank and leaking onto floor | 8/30/13 | Portables | port.320 E.M.S. | Plumbing |
| Administration Bldg (8550) 2A | two three compartment sinks in kitchen leaking leaking appears to be at elbow on drain pipe on both sinks | 9/3/13 | Kitchen | cafeteria east wall | Plumbing |
| Administration Bldg (8550) 2A | Calibrated back flow kit. | 9/6/13 | | | Plumbing |
| Administration Bldg (8550) 2A | water cooler stopped up in park services ID#155-063 | 9/20/13 | 1st Floor | park services lobby | Plumbing |

| | | | | | |
|-------------------------------|--|----------|------------------|-----------------------------------|----------|
| Administration Bldg (8550) 2A | water is leaking from hand sink onto floor in ladies restroom by elevator on first floor | 9/26/13 | Restroom (Girls) | by room 116 | Plumbing |
| Administration Bldg (8550) 2A | PARTS FOR GAS PUMP- REQUESTED BY M TRIPLETT KLR | 10/2/13 | | | Plumbing |
| Administration Bldg (8550) 2A | Garbage disposal not working. | 10/14/13 | | | Plumbing |
| Administration Bldg (8550) 2A | Inspect grease trap | 10/28/13 | | | Plumbing |
| Administration Bldg (8550) 2A | Clean out vehicle #353 for turn-in | 11/1/13 | | | Plumbing |
| Administration Bldg (8550) 2A | auto flush on both urinals in this restroom not working and they want flush manually | 11/8/13 | Restroom (Boys) | second floor by 204 | Plumbing |
| Administration Bldg (8550) 2A | flush valve on urinal leaking when flushed in this restroom | 11/8/13 | Restroom (Boys) | second floor by 256 and breezeway | Plumbing |
| Administration Bldg (8550) 2A | FLR DRAIN IS BACKING UP IN KITCHEN. PLANT MGR- BOBBY/416.5300 | 11/13/13 | | | Plumbing |
| Administration Bldg (8550) 2A | commode in womens restroom on third floor will not shut off,flush valve stuck. Plant Mngr. shut water off to it. | 11/19/13 | Restroom (Girls) | third floor across from rm 304 | Plumbing |

| | | | | | | |
|-------------------------------|---|----------|-----------------|-------------------------|--|-------------|
| Administration Bldg (8550) 2A | BUSTED WTR LINE IN SERVING LINE AREA - PM/REDDICK 416-5397 | 11/25/13 | | | | Plumbing |
| Administration Bldg (8550) 2A | REPLACEMENT PARTS FOR GAS PUMPS-REQUESTED BY M TRIPLETT KLR | 12/11/13 | | | | Plumbing |
| Administration Bldg (8550) 2A | commode bolts broken at floor and commode is moving around when sat on | 12/13/13 | Restroom (Boys) | across service elevator | | Plumbing |
| Administration Bldg (8550) 2A | COMMODE- 3RD FLR MEN'S RR - BY ELEVATOR - FLUSH VALVE IS STUCK, CAN'T SHUT OFF - PM/REDDICK 416-5397 | 12/16/13 | | | | Plumbing |
| Administration Bldg (8550) 2A | FLOOR DRAIN BASEMENT MECH RM-STOPPED UP AND WATER BACKING UP THRU MOP SINK-PLANT MGR REDDICK 416-5397 KLR | 1/17/14 | | | | Plumbing |
| Administration Bldg (8550) 2A | repair roof leak in room 232 | 3/6/14 | | | | Roof |
| Administration Bldg (8550) 2A | ROOF IS LEAKING WATER ON CARPET IN RM-B8 SBE-REDDICK/416-5300 | 7/22/13 | | | | Roof |
| Administration Bldg (8550) 2A | water leaking into IT room from rooftop unit | 11/20/13 | Data Closet | IT room 239 | | Roof |
| Administration Bldg (8550) 2A | repair holes in HVAC drain pan hanging from kitchen ceiling,it has two small holes that are leaking on kitchen floor all day and night or replace pan | 4/3/14 | Kitchen | kitchen by dock door | | Sheet Metal |

| | | | | | |
|-------------------------------|--|----------|-----------|---------------------|-------------|
| Administration Bldg (8550) 2A | Sheet metal to cover transom windows | 4/9/14 | 2nd Floor | Emily Owen's Office | Sheet Metal |
| Administration Bldg (8550) 2A | Request metal covers be painted beige. | 4/15/14 | | | Sheet Metal |
| Administration Bldg (8550) 2A | check duct in kitchen vent hood for proper operation or blockage the motor was replaced and air flow is not removing smoke from kitchen | 9/26/13 | Kitchen | kitchen | Sheet Metal |
| Administration Bldg (8550) 2A | We need 50 brackets for sound baffles for the Admin. bldg. The brackets needed are the same size brackets we made for the training room where we have our safety meetings. | 9/30/13 | | | Sheet Metal |
| Administration Bldg (8550) 2A | Move ductwork in Room 218 per. Charles White. | 11/5/13 | | | Sheet Metal |
| Administration Bldg (8550) 2A | Request supply grill be painted for room #218. | 11/20/13 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|---------------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| American Way MS (2023) 2B | 2 | 2 | 30 | 57 | 33 | 6 | 35 | 16 | 6 | 187 |
| Grand Total | 2 | 2 | 30 | 57 | 33 | 6 | 35 | 16 | 6 | 187 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|---------------------------|--|----------------|------------------|--------------------|-----------|
| American Way MS (2023) 2B | Reinsulate make up line going to cooling tower. | 3/10/14 | | | Asbestos |
| American Way MS (2023) 2B | The gym floor need to be refinish. urgent. | 12/17/13 | 1st Floor | Gym floor | Asbestos |
| American Way MS (2023) 2B | Green Hallway Internet drop not working | 9/25/13 | 1st Floor | Room#C-204 | Cabling |
| American Way MS (2023) 2B | Wall jacks for computers are damaged and could cause potential damage to student if something is inserted. Needs to be replaced. | 9/26/13 | Classroom | A210 | Cabling |
| American Way MS (2023) 2B | The class room door is hard to open. urgent. | 2/3/14 | 1st Floor | D 204 | Carpentry |
| American Way MS (2023) 2B | Stall door has been pull down in side the girls rest room . urgent. | 2/5/14 | 1st Floor | Seventh grade hall | Carpentry |
| American Way MS (2023) 2B | Door handle on storge room door is broken need to be replaced. urgent. | 2/12/14 | 1st Floor | By the gym | Carpentry |
| American Way MS (2023) 2B | 4 gym doors need new door stoper in stall. urgent. | 10/15/13 | Gym | 1st floor | Carpentry |

| | | | | | |
|---------------------------|--|---------|-----------|-----------------|-----------|
| American Way MS (2023) 2B | The fram to the ceiling title has been pull down need to be replaced. urgent. | 4/24/14 | 1st Floor | Boy locker room | Carpentry |
| American Way MS (2023) 2B | Door closure on class room door is broken need to be replaced. urgent. | 5/8/14 | 1st Floor | Room 207 b | Carpentry |
| American Way MS (2023) 2B | The office door is hard to open. urgent. | 5/8/14 | 1st Floor | main office | Carpentry |
| American Way MS (2023) 2B | The fire door will not closed. the fire door is by sbe office. the doors are blue. urgent. | 5/8/14 | 1st Floor | Fire door | Carpentry |
| American Way MS (2023) 2B | The fire door will not lock when the door closed. the fire door is on the green hallway. urgent. | 5/8/14 | 1st Floor | Fire door | Carpentry |
| American Way MS (2023) 2B | Door closure on the office door is broken, the door closure is leaking oil. urgent. | 3/20/14 | 1st Floor | Main office | Carpentry |
| American Way MS (2023) 2B | Door closure on the office door is broken, need to be replaced. urgent. | 3/20/14 | 1st Floor | Guidance office | Carpentry |
| American Way MS (2023) 2B | Stall door is broken need to be repaired. the girls rest room is on the seventh grade hallway. urgent. | 4/8/14 | 1st Floor | Girls rest room | Carpentry |
| American Way MS (2023) 2B | Need to removed window seal and the cabinet from the wall for termites. urgent. | 4/10/14 | 1st Floor | Room c 208 | Carpentry |

| | | | | | |
|---------------------------|--|----------|-----------|----------------|-----------|
| American Way MS (2023) 2B | Door closure on class room door is broken need to be replaced. urgent. | 4/10/14 | 1st Floor | Room c 205 | Carpentry |
| American Way MS (2023) 2B | Door handle on class room door is broken need to be replaced. urgent. | 10/30/13 | 1st Floor | Band room | Carpentry |
| American Way MS (2023) 2B | There are two steps on the gym beaches that is broken need to be repaired. urgent. | 11/1/13 | 1st Floor | Gym | Carpentry |
| American Way MS (2023) 2B | The office in side the gym the door to the office is hard to open. urgent. | 11/6/13 | 1st Floor | Gym | Carpentry |
| American Way MS (2023) 2B | The stall wall is about to fall in side the boys rest room on the eighth grade hallway. urgent. | 11/15/13 | 1st Floor | Boys rest room | Carpentry |
| American Way MS (2023) 2B | Classroom door is difficult to open. Door has to be pushed and pulled hard because of a tight fit. | 12/13/13 | Classroom | D211 | Carpentry |
| American Way MS (2023) 2B | Ceiling tile need to be change out, from water leaking from the roof. | 8/8/13 | 1st Floor | Cafeteria | Carpentry |
| American Way MS (2023) 2B | The stall wall in side boy rest room by the cafeteria is falling down, need to be repaired.urgent. | 8/9/13 | 1st Floor | Boy rest room | Carpentry |
| American Way MS (2023) 2B | AUDIT DOOR, CANT SECURE PLANT MGR- JACKSON/416.1250 | 8/19/13 | | | Carpentry |

| | | | | | |
|---------------------------|---|---------|-----------|------------------|------------|
| American Way MS (2023) 2B | Weld drain grate | 8/21/13 | | | Carpentry |
| American Way MS (2023) 2B | The handle on the out side door is broken need to be repaired. and the lock on the door is broken. urgent. | 9/12/13 | 1st Floor | By the cafeteria | Carpentry |
| American Way MS (2023) 2B | Need 4 signs put up on the wall in the gym. urgent. | 9/19/13 | 1st Floor | Gym | Carpentry |
| American Way MS (2023) 2B | DOOR - MAIN FRONT ENTRANCE - WON'T LOCK - PM/MCFARLAND 416-5012 | 9/26/13 | | | Carpentry |
| American Way MS (2023) 2B | Door handle on out side door on the east side of the building is broken. urgent. | 10/1/13 | 1st Floor | Out side door | Carpentry |
| American Way MS (2023) 2B | Door handle to out side door on the east side of the building is broken. urgent. | 1/10/14 | 1st Floor | Main Lobby | Carpentry |
| American Way MS (2023) 2B | The stall door in side girls rest room on the seventh grade hallway is broken need to be replaced. Urgent. | 5/20/14 | 1st Floor | Girls rest room | Carpentry |
| American Way MS (2023) 2B | LOCKERS - 6 GRADE HALLWAY HAS BEEN PULLED FROM WALL - ABOUT TO FALL - HAZARDOUS TO STUDENTS - PM/JACKSON 416-1250 | 5/22/14 | | | Carpentry |
| American Way MS (2023) 2B | Light in the ceiling by room 209 c has a bad balance, the light is on the seventh grade hallway. urgent. | 1/15/14 | 1st Floor | Green hallway | Electrical |

| | | | | | |
|---------------------------|---|----------|-----------|---------------------|------------|
| American Way MS (2023) 2B | Light in the ceiling has a bad balance. urgent. | 1/16/14 | 1st Floor | By the main office | Electrical |
| American Way MS (2023) 2B | Partial power outage. | 1/16/14 | | | Electrical |
| American Way MS (2023) 2B | UNIT in the CAFETERIA is NOT COMING ON per Mr. Jackson, Plant Mgr. 416.1250 | 2/7/14 | | | Electrical |
| American Way MS (2023) 2B | The light on the exploratory hallway has a bad blance. urgent. | 2/19/14 | | Exploratory hallway | Electrical |
| American Way MS (2023) 2B | BALLAST/LIGHT FIXTURE LIBRARY AREA-HAS A BURNING SMELL-PLANT MGR JACKSON 416-1250 KLR | 2/20/14 | | | Electrical |
| American Way MS (2023) 2B | Light in side rest room has a bad blance. urgent. | 10/16/13 | 1st Floor | main office | Electrical |
| American Way MS (2023) 2B | fan coil unit not working in room 201D per Mr. Jackson 416-5012 | 10/16/13 | | | Electrical |
| American Way MS (2023) 2B | Their are two rec in side room C206 that has no power I can not fine the braker. urgent | 10/17/13 | 1st Floor | Room C206 | Electrical |
| American Way MS (2023) 2B | Light switch on the seventh grade hallway is bad, need to be replaced. urgent. | 10/21/13 | 1st Floor | 7 grade hallway | Electrical |

| | | | | | |
|---------------------------|---|----------|------------------|-----------------------|------------|
| American Way MS (2023) 2B | 10 cases of flourescent light bulbs for classrooms | 10/22/13 | Hallway/Corridor | throughout building | Electrical |
| American Way MS (2023) 2B | 7 lights out in gym. Need lift. | 10/22/13 | Gym | sw of school | Electrical |
| American Way MS (2023) 2B | Several lights out in auditorium. Very dim and cannot use. Need a lift. | 10/22/13 | Auditorium | | Electrical |
| American Way MS (2023) 2B | Electrical outlet is burned out and needs repairing. Cannot utilize internet. | 10/22/13 | Classroom | A210 | Electrical |
| American Way MS (2023) 2B | All the lights on the poles and around the building are not working need to be fix. urgent. | 10/29/13 | Parking Lot | West side of building | Electrical |
| American Way MS (2023) 2B | Their are ten light out in the cafeteria. the lights. are to high for me sbe to reach. urgent. | 4/22/14 | 1st Floor | cafeteria | Electrical |
| American Way MS (2023) 2B | Need 20 cases of lamp for the class rooms the number is 821746. the lamp for american way middle and south park elem. urgent. | 4/22/14 | 1st Floor | sbe office | Electrical |
| American Way MS (2023) 2B | UNIT NOT COMING ON IN AUDIT. PLANT MGR- JACKSON/416.1250 | 4/24/14 | | | Electrical |
| American Way MS (2023) 2B | The light has a bad balance. urgent. | 4/29/14 | 1st Floor | Yellow locker area | Electrical |

| | | | | | |
|---------------------------|---|---------|-----------|---------------------|------------|
| American Way MS (2023) 2B | Exit light is not working need to be repaired. urgent. | 5/8/14 | 1st Floor | Yellow locker ar | Electrical |
| American Way MS (2023) 2B | RECEPTACLE HAS NO POWER FOR MILK BOX KITCHEN. PLANT MGR- MCFARLAND/416.1250 | 5/12/14 | | | Electrical |
| American Way MS (2023) 2B | Repair heat trace on make up line going to cooling tower. | 3/12/14 | | | Electrical |
| American Way MS (2023) 2B | The light in side of office 101g has a bad balance. urgent. | 3/17/14 | Grounds | Guidance office | Electrical |
| American Way MS (2023) 2B | The light were the six grade lockers are has a bad balance. urgent. | 3/17/14 | 1st Floor | Six grade hall | Electrical |
| American Way MS (2023) 2B | The light on the exploratory hallway has a bad balance. urgent. | 3/17/14 | 1st Floor | Exploratory hallway | Electrical |
| American Way MS (2023) 2B | There are five rec out by the sbe office, it is not the breaker. urgent. | 3/24/14 | 1st Floor | By sbe office | Electrical |
| American Way MS (2023) 2B | There are five light in side the girls locker room that is out they all have bad balance. urgent. | 3/24/14 | 1st Floor | Girls locker room | Electrical |
| American Way MS (2023) 2B | VENTING HOOD NOT COMING ON IN KITCHEN PLANT MGR- JACKSON/416.1250 | 4/9/14 | | | Electrical |

| | | | | | |
|---------------------------|---|----------|-----------|----------------|------------|
| American Way MS (2023) 2B | Round light by room A205 is bad need to be fix or replaced. urgent. | 10/31/13 | 1st Floor | By room A205 | Electrical |
| American Way MS (2023) 2B | I need two casees of general electric biax D eco 18w 4 pin 4 broches and 4 clavijas. urgent. | 11/6/13 | 1st Floor | Lights | Electrical |
| American Way MS (2023) 2B | per Mr. Jackson 416-1250 cannot get the air handler unit on in the cafeteria | 12/13/13 | | | Electrical |
| American Way MS (2023) 2B | Need a len cover for a light fixture in side room A 210 art room. urgent. | 12/16/13 | 1st Floor | Room A 210 | Electrical |
| American Way MS (2023) 2B | Their is a bad rec in the teacher lounge on the seventh grade hallway, need to be replaced. urgent. | 12/19/13 | 1st Floor | Teacher lounge | Electrical |
| American Way MS (2023) 2B | Need 5 cases of fluoescent lights for the class rooms. urgent. | 8/7/13 | 1st Floor | sbe office | Electrical |
| American Way MS (2023) 2B | Rec is bad in the cafe kitchen. urgent. | 8/8/13 | 1st Floor | Cafe kitchen | Electrical |
| American Way MS (2023) 2B | Repair cooling tower | 8/9/13 | | | Electrical |
| American Way MS (2023) 2B | Bells need to be seat. urgent. | 8/12/13 | 1st Floor | Main office | Electrical |

| | | | | | |
|---------------------------|--|---------|-----------|----------------------|------------|
| American Way MS (2023) 2B | Need two exit signs installed in side of boys locker room. URGENT. | 8/16/13 | 1st Floor | Boy locker room | Electrical |
| American Way MS (2023) 2B | FCU-4 RM 101 GUIDANCE OFC-NOT COMING ON-SBE JACKSON 416-1250 KLR | 8/19/13 | | | Electrical |
| American Way MS (2023) 2B | FCU RM 206F-NOT COMING ON-PLANT MGR 416-1250 KLR | 8/21/13 | | | Electrical |
| American Way MS (2023) 2B | Rec on the front line in the cafe is bad. urgent. | 8/22/13 | 1st Floor | cafe | Electrical |
| American Way MS (2023) 2B | AHU MECH RM SERVES CHOIR RM-NOT COMING ON-PLANT MGR JACKSON 416-1250 KLR | 8/23/13 | | | Electrical |
| American Way MS (2023) 2B | There are about 8 lights out in the front plaza in the back plaza has about 5 out. we have about 4 lights out on the yellow hallway in the back. the lights are over 12 feet high. | 8/23/13 | 1st Floor | Front plaze and back | Electrical |
| American Way MS (2023) 2B | Two lights has bad blance in side boys rest that is in side the boys locker room. urgent. | 8/29/13 | 1st Floor | Boys locker room | Electrical |
| American Way MS (2023) 2B | 5 Lights are out the lights are over 12 feet high need to be replaced. urgent. | 8/29/13 | 1st Floor | Six grade hallway | Electrical |
| American Way MS (2023) 2B | There are 5 lights out, all 5 lights has bad blance. urgent. | 8/30/13 | 1st Floor | Library | Electrical |

| | | | | | |
|---------------------------|--|---------|-----------|-----------------|------------|
| American Way MS (2023) 2B | There is an 8 ft lens cover falling out of ceiling by main office in hallway per Jackson 416-1250 | 9/4/13 | | | Electrical |
| American Way MS (2023) 2B | The light in the main hallway by the band room has a bad balance need to be replaced. urgent. | 9/5/13 | 1st Floor | Main hallway | Electrical |
| American Way MS (2023) 2B | refrigerator no power and vent hood 1 & 2 not working | 9/23/13 | 1st Floor | Rm# A-206 | Electrical |
| American Way MS (2023) 2B | needs some light switch keys | 9/25/13 | 1st Floor | Plant Manager | Electrical |
| American Way MS (2023) 2B | Air Handler Units are NOT COMING ON in the Band and Music Room and on the 8th Hallway per Mr. Jackson, Plant Mgr. 416.1250 | 1/8/14 | | | Electrical |
| American Way MS (2023) 2B | AHU CAFE AREA-NOT COMING ON-THEY ARE HAVING A PROGRAM IN AREA-PLANT MGR HURSE 416-1250 KLR | 6/19/14 | | | Electrical |
| American Way MS (2023) 2B | A/C UNIT is NOT COMING ON in the AUDITORIUM per Randy Hersh 416.1628 | 6/19/14 | | | Electrical |
| American Way MS (2023) 2B | Braker tripped in the air handle room. urgent. | 6/13/14 | 1st Floor | Air handle room | Electrical |
| American Way MS (2023) 2B | Need 3 cases of lamps for the class rooms the number is 821746. urgent | 6/2/14 | 1st Floor | Sbe office | Electrical |

| | | | | | |
|---------------------------|--|---------|----------------|------------------|---------------------------------------|
| American Way MS (2023) 2B | Replace parking lot lighting with LED fixtures. | 2/27/14 | | | Electrical |
| American Way MS (2023) 2B | Electrical power need to be ran to the foot ball score board. urgent. | 8/29/13 | Athletic Field | West of building | Electrical |
| American Way MS (2023) 2B | CHILLER MECH RM-IN ALARM-PLANT MGR HURSE 416-1250 KLR | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | CHILLER is in ALARM per Randy Hirsch, Plant Mgr. 416.1240 | 6/30/14 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Monthly - AMERICAN WAY MID LVL 2 WATER TREATMENT - Refer to PM schedule details. | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Monthly - Filter-American Way Middle - Refer to PM schedule details. | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Monthly - Filter-American Way Middle - Refer to PM schedule details. | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | BOILER#2 NOT COMING ON PLANT MGR- JACKSON/416.1250 | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | 2-FCU NOT COMING ON IN RM-200B,215B. PLANT MGR- JACKSON/416.1250 | 1/21/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|---------------------------|---|----------|-----------|----------------|--|---------------------------------------|
| American Way MS (2023) 2B | main office and attendance office are blowing cold air per Mr. Jackson 416-1250 | 1/23/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | per mr jackson 416-1250 boiler #2 won't come on | 1/29/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Monthly - Oil Lube & Belt- American Way Elementary - Refer to PM schedule details. | 1/31/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | UNIT NOT HEATING IN ASSIST PRIN OFFICE & FRONT ENTRY BREEZEWAY. PLANT MGR- JACKSON/416.5024 | 2/10/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Classrooms are hot. Air is not coming on. B201 thermostat reads 80 degrees. | 10/22/13 | Classroom | All Classrooms | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | HEAT RM C210-NOT HEATING-PLANT MGR JACKSON 416-1250 KLR | 3/19/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | UNIT NOT HEATING IN RM- A212 PLANT MGR- JACKSON/416.1250 | 3/21/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | chiller down per mr. jackson 416-5012 | 10/30/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Yearly - Air Handler Cleaning- American Way Middle - Refer to PM schedule details. | 11/1/13 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------|---|----------|--|--|---------------------------------------|
| American Way MS (2023) 2B | boiler will not come on per Mr. Jackson 416-1250 | 11/7/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | RTU NOT HEATING IN MAIN OFFICE. PLANT MGR- JACKSON/416.1250 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | room A203 is blowing cold air and room B206 is too hot (78 degrees0) per Mr. Jackson 416-1250 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | 2-BOILERS NOT COMING ON PLANT MGR- JACKSON/416.1250 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | 2-BOILERS NOT COMING ON PLANT MGR- JACKSON/416.1250 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | CHILLER#2 THAT CONTROLS THE MAIN BLDG IS NOT COMING ON. SBE JACKSON 416-1250 | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | chiller in alarm | 7/23/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | CHILLER IS NOT COMING ON . SBE JACKSON 416-2370 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | PUMP#2 & 4 TO THE CHILLER IS NOT COMING ON. SBE JACKSON 416-1250 | 8/6/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|---------------------------|---|----------|-----------|---------------------|--|---------------------------------------|
| American Way MS (2023) 2B | Chiller is down per Mr. Jackson 416-1250 | 8/26/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | AHU KITCHEN AREA-NOT COOLING-PLANT MGR JACKSON 416-1250 KLR | 8/26/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Yearly - Oil Samples- American Way Middle - Refer to PM schedule details. | 8/30/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Monthly - Filter-American Way Middle - Refer to PM schedule details. | 9/17/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | UNIT NOT COOLING IN GUIDANCE OFFICE PLANT MGR- MCFARLAND/416.1250 | 9/23/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | A/C MAIN OFC AREA-NOT COOLING-PLANT MGR McFARLAND 416-1250 KLR | 9/24/13 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | CHILLER-1 MECH RM-IN ALARM-PLANT MGR HURSE 416-1250 KLR | 6/20/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Yearly - Cooling Towers- American Way Middle - Refer to PM schedule details. | 3/3/14 | | | | Heating/Ventilation /Air Conditioning |
| American Way MS (2023) 2B | Boys and girls rest rooms on the exploratory hallway the stall walls needs to be painted. urgent. | 10/29/13 | 1st Floor | Exploratory hallway | | Painting |

| | | | | | |
|---------------------------|--|----------|----------------|--------------------|----------|
| American Way MS (2023) 2B | The cafeteria needs to be painted. urgent. | 10/29/13 | 1st Floor | Cafeteria | Painting |
| American Way MS (2023) 2B | The cafeteria needs to be painted. urgent. | 4/15/14 | 1st Floor | cafeteria | Painting |
| American Way MS (2023) 2B | paint lines on football field | 6/4/14 | | | Painting |
| American Way MS (2023) 2B | Please paint window seal. | 4/29/14 | | | Painting |
| American Way MS (2023) 2B | Need for lines to be put down on the foot ball field. request by the prinipical. urgent. | 9/12/13 | Athletic Field | TO Eddle Mmiller | Painting |
| American Way MS (2023) 2B | The urinal in side boys rest room by the cafeteria is leaking water. | 1/15/14 | 1st Floor | Boys rest room | Plumbing |
| American Way MS (2023) 2B | per jackson 416-1250 there is a gas smell in the kitchen | 1/31/14 | | | Plumbing |
| American Way MS (2023) 2B | FLR DRAIN IS STOPPED IN B/LOCKER GYM PLANT MGR- JACKSON/416.1250 | 2/5/14 | | | Plumbing |
| American Way MS (2023) 2B | The pipe on top of the urinal is leaking water. urgent. | 2/12/14 | 1st Floor | Seventh grade hall | Plumbing |

| | | | | | |
|---------------------------|--|----------|-----------|-------------------|----------|
| American Way MS (2023) 2B | The faucet on the sink in side the conference room 101 c is broken need to be replaced. urgent. | 2/19/14 | 1st Floor | Guidance office | Plumbing |
| American Way MS (2023) 2B | Water fountain is leaking water by the seventh grade hallway. ID number 178 119. urgent. | 10/1/13 | 1st Floor | Front lobby | Plumbing |
| American Way MS (2023) 2B | We have three commde stop up on the six grade hallway two in side the girls rest room and one in the boys rest room. urgent. | 10/14/13 | 1st Floor | Boys and girls rm | Plumbing |
| American Way MS (2023) 2B | Commode is stop up. urgent. | 4/22/14 | 1st Floor | Attendance office | Plumbing |
| American Way MS (2023) 2B | Commode is stop up. urgent. | 4/24/14 | 1st Floor | Boy locker room | Plumbing |
| American Way MS (2023) 2B | The urinal and the commode on the yellow hallway is stop up. urgent. | 4/29/14 | 1st Floor | Boy rest room | Plumbing |
| American Way MS (2023) 2B | HAND SINK IS HANGING FROM CAFE WALL PLANT MGR- JACKSON/416.1250 | 5/6/14 | | | Plumbing |
| American Way MS (2023) 2B | BUSTED PIPE ON COOLING TOWER PLANT MGR- JACKSON/416.1250 | 3/5/14 | | | Plumbing |
| American Way MS (2023) 2B | PIPE IN CEILING OF CAFE RR-LEAKING. CAN'T CONTAIN-PLANT MGR JACKSON 416-1250 KLR | 3/28/14 | | | Plumbing |

| | | | | | |
|---------------------------|---|----------|-----------|-----------------|----------|
| American Way MS (2023) 2B | Commode is stop up in the boys rest room on the seventh grade hallway. and a urinal that keeps on running will not cut off. urgent. | 4/8/14 | 1st Floor | Boys rest room | Plumbing |
| American Way MS (2023) 2B | Hand sink in side the laundry room the pipe is leaking water. urgent. | 11/1/13 | 1st Floor | Wash room | Plumbing |
| American Way MS (2023) 2B | The girls rest room on the exploratory hallway the flush vaule on the commode is broken need to be replaced. urgent. | 11/14/13 | 1st Floor | Girls rest room | Plumbing |
| American Way MS (2023) 2B | The boys rest room on the eighth grade hallway the flush vaule on the commode is broken need to be replaced. urgent. | 11/15/13 | 1st Floor | Boys rest room | Plumbing |
| American Way MS (2023) 2B | FLR DRAIN IS BACKING UP IN B/LOCKER RM PLANT MGR- JACKSON/416.5024 | 11/19/13 | | | Plumbing |
| American Way MS (2023) 2B | floor drain in boys locker room coming back up per Mr. Jackson 416-1250 | 12/2/13 | | | Plumbing |
| American Way MS (2023) 2B | Drains are STOPPED UP in the Boy's Washroom per Leonard Jackson, Plant Mgr. 416.1250 | 12/3/13 | | | Plumbing |
| American Way MS (2023) 2B | Girls rest room on the yellow hallway the pipe on the commode is leaking water. urgent. | 12/12/13 | 1st Floor | Girls rest room | Plumbing |
| American Way MS (2023) 2B | Water fountain by seventh grade hallway, the pipe is leaking water. ID 178 119. urgent. | 12/16/13 | 1st Floor | Front lobby | Plumbing |

| | | | | | |
|---------------------------|---|---------|-----------|------------------|----------|
| American Way MS (2023) 2B | Handle on the water fountain is broken. ID number 178 076. urgent. | 8/16/13 | 1st Floor | By sbe office | Plumbing |
| American Way MS (2023) 2B | There are two sinks in side of room A210 the hot side does not work need to be replared. urgent. | 8/16/13 | 1st Floor | A 210 | Plumbing |
| American Way MS (2023) 2B | Cooling tower overflowing. | 9/18/13 | | | Plumbing |
| American Way MS (2023) 2B | Boys restroom urinal make a loud noise | 9/25/13 | 1st Floor | Green Hall | Plumbing |
| American Way MS (2023) 2B | Boy restroom two toilet stop-up | 9/25/13 | 1st Floor | Red Hall | Plumbing |
| American Way MS (2023) 2B | 1st stall stop-up & four stall stop-up | 9/27/13 | 1st Floor | Red Hallway | Plumbing |
| American Way MS (2023) 2B | Toilet not working in boys locker room. | 9/27/13 | Gym | boys locker room | Plumbing |
| American Way MS (2023) 2B | The pipe on the coolin tower is broken need to be replaced water ran all over the ground. urgent. | 1/9/14 | 1st Floor | Coolin tower | Plumbing |
| American Way MS (2023) 2B | per jackson 416-1250 gas smell in band room | 2/28/14 | | | Plumbing |

| | | | | | | |
|---------------------------|--|----------|-----------|-------------------|--|----------|
| American Way MS (2023) 2B | COOLING TOWER IS OVERFLOWING WITH WATER PLANT MGR- JACKSON/416.1250 | 2/27/14 | | | | Plumbing |
| American Way MS (2023) 2B | SINK - RM D203 - LEAKING FROM PIPE - PM/MCFARLAND 416-1215 | 5/16/14 | | | | Plumbing |
| American Way MS (2023) 2B | Water fountain is leaking water from the pipe. the water fountain is cut off. Urgent. | 5/20/14 | 1st Floor | By room E 200 | | Plumbing |
| American Way MS (2023) 2B | The urinal in side the boys rest room on the seventh grade hallway will not flush. Urgent. | 5/20/14 | 1st Floor | Boys rest room | | Plumbing |
| American Way MS (2023) 2B | In side the teacher lounge women rest room water is leaking from the roof.urgent. | 2/5/14 | 1st Floor | Sventh grade hall | | Roof |
| American Way MS (2023) 2B | Water is leaking from the roof. this room has been work on 3 time and it has not been fix yet. urgent. | 2/5/14 | 1st Floor | Music room F 206 | | Roof |
| American Way MS (2023) 2B | Water is leaking all the way down the hallway from the roof. urgent. | 2/5/14 | 1st Floor | Hallway by F204 | | Roof |
| American Way MS (2023) 2B | Water is leaking from the roof. urgent. | 2/5/14 | 1st Floor | Room B201 | | Roof |
| American Way MS (2023) 2B | Water is leaking from ceiling. urgent. | 10/16/13 | 1st Floor | Music room F206 | | Roof |

| | | | | | |
|---------------------------|--|----------|-----------|---------------------|------|
| American Way MS (2023) 2B | Water is leaking from the ceiling. urgent. | 10/16/13 | 1st Floor | Main entrance | Roof |
| American Way MS (2023) 2B | Water is leaking from the roof all over the cafeteria. urgent. | 4/22/14 | 1st Floor | Cafeteria | Roof |
| American Way MS (2023) 2B | Water is leaking from the ceiling in the hallway. urgent. | 4/30/14 | 1st Floor | By room 200 E | Roof |
| American Way MS (2023) 2B | Water is leaking from the ceiling. urgent. | 4/30/14 | 1st Floor | Room 204 A | Roof |
| American Way MS (2023) 2B | Water is leaking from the ceiling. urgent. | 4/30/14 | 1st Floor | By room 204 F | Roof |
| American Way MS (2023) 2B | Water is leaking from the ceiling. urgent. | 4/30/14 | 1st Floor | Room 206 F | Roof |
| American Way MS (2023) 2B | Water is leaking from the ceiling by the back out side doors by the gym. urgent. | 4/30/14 | 1st Floor | Back out side doors | Roof |
| American Way MS (2023) 2B | Water is leaking from the roof in to the class rooms. urgent. | 10/31/13 | 1st Floor | Rooms F206 B201 | Roof |
| American Way MS (2023) 2B | Water is leaking from the roof in to the light in side the class room. urgent. | 10/31/13 | 1st Floor | Room D202 | Roof |

| | | | | | |
|---------------------------|--|----------|-----------|--------------|-------------|
| American Way MS (2023) 2B | Water is leaking in the hallway from the roof by room E 202. urgent. | 10/31/13 | 1st Floor | By room E202 | Roof |
| American Way MS (2023) 2B | Water is leaking from the roof. urgent. | 1/9/14 | 1st Floor | B201 F206 | Roof |
| American Way MS (2023) 2B | The metal door to the concessions stand is broken need to be replaced. urgent. | 10/1/13 | 1st Floor | By the cafe | Sheet Metal |
| American Way MS (2023) 2B | Fabricate new strainer basket for catch basin in laundry room. | 12/5/13 | | | Sheet Metal |
| American Way MS (2023) 2B | Dryer in CTE classroom needs a dryer vent kit connected. | 12/5/13 | Classroom | A206 | Sheet Metal |
| American Way MS (2023) 2B | Make 30 covers for light fixtures. | 8/1/13 | | | Sheet Metal |
| American Way MS (2023) 2B | Repair lockers at school. | 9/5/13 | | | Sheet Metal |
| American Way MS (2023) 2B | There are two metal gates to the serving line that will not let up. urgent. | 1/7/14 | 1st Floor | Cafeteria | Sheet Metal |

| Count of Craft | Craft | | | | | | | |
|----------------|---------|-----------|------------|------|----------|------|-------------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Plumbing | Roof | Sheet Metal | Grand Total |
| Avon (2025) 2A | 1 | 13 | 13 | 14 | 36 | 7 | 1 | 85 |
| Grand Total | 1 | 13 | 13 | 14 | 36 | 7 | 1 | 85 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|----------------|--|---------------|---------------------|--|-----------|
| Avon (2025) 2A | Avon - WO385589-- In room 208 the data jack was damaged in the ceiling and needs to be replaced because its not working needs attention. | 9/23/13 | Classroom | Rm 208 | Cabling |
| Avon (2025) 2A | There is a leake coming in under the door in the kitchen part by the chiller.needs attention. | 4/28/14 | Cafeteria | side door by chiller | Carpentry |
| Avon (2025) 2A | Need swinging door repair very loose don't won't anybody to get hurt needs attention. | 5/2/14 | Administration Area | Main office | Carpentry |
| Avon (2025) 2A | The doors to the cafeteria are loose and missing screws on both sides needs attention . | 10/14/13 | Cafeteria | outside doors leading to hallway | Carpentry |
| Avon (2025) 2A | There are crews loose and falling out the doors needs attention. | 10/23/13 | Cafeteria | doors of cafeteria leading to hallway. | Carpentry |
| Avon (2025) 2A | The screws have come out of the panic bar at the top of the door and it is causing the door not to close properly. | 10/30/13 | Classroom | Rm 115 | Carpentry |
| Avon (2025) 2A | The second set of double doors are coming of the door molding and needs attention. | 8/27/13 | 1st Floor | cafeteriaecond set of doors | Carpentry |

| | | | | | |
|----------------|---|----------|-------------|------------------------------------|------------|
| Avon (2025) 2A | Spring has buckled alose from door it keeps door from slamming needs attention. | 2/5/14 | Cafeteria | door leading to hallway right side | Carpentry |
| Avon (2025) 2A | I need some ceiling tile for Avon so I can change out old ones. | 2/26/14 | Classroom | | Carpentry |
| Avon (2025) 2A | There is a big hole in the sheet rock on the elevator shaft that lets the kids up and down on the stage. | 4/4/14 | Cafetorium | next to stage | Carpentry |
| Avon (2025) 2A | The emergency window won't lock or close needs serious attention. | 4/15/14 | Library | Upstairs | Carpentry |
| Avon (2025) 2A | There is a tile behind the teachers desk and it has a hole in two places needs attention. | 4/22/14 | Classroom | 112 | Carpentry |
| Avon (2025) 2A | Mod and paint Sheetrock in Cafeteria. | 4/23/14 | | | Carpentry |
| Avon (2025) 2A | There was a crosswalk sign up on the poles outside the school delivery driver for company bump it by accident and broke the pole need pole replaced. | 6/12/14 | Grounds | by the crosswalk | Carpentry |
| Avon (2025) 2A | Principal would like for a light to be installed out were the buses are dropping off because it is really dark in the mornings and is a safety issue. | 10/30/13 | Parking Lot | were the buses come in | Electrical |

| | | | | | |
|----------------|---|----------|---------------------|------------------------------------|------------|
| Avon (2025) 2A | Need main clock set for daylight saving times. | 11/4/13 | Administration Area | main office | Electrical |
| Avon (2025) 2A | BURNING SMELL in the Data Room per Christopher Harper, Plant Mgr. 416.2124 | 12/11/13 | | | Electrical |
| Avon (2025) 2A | Emergency lights do not work also on the on the southside of the building the exit sign needs attention it does not light when testing. | 7/31/13 | 1st Floor | Front Entrance | Electrical |
| Avon (2025) 2A | There were some prongs broke off in socket and they are still in there socket needs attention .recptacle. | 8/13/13 | Administration Area | Main office | Electrical |
| Avon (2025) 2A | I need light bulbs to replace some of the old ones that are blown they are the skinny tubes for the T8 ballast | 8/13/13 | Mechanical Room | Out the backdoor to the parkinglot | Electrical |
| Avon (2025) 2A | Need light bulbs so I can replace some old ones in different areas they are the skinny tubes for the T8 ballast.needs attention. | 8/13/13 | Classroom | all over | Electrical |
| Avon (2025) 2A | The receptacle has gone out in this room and I have checked all the breakers and there is none tripped .needs attention. | 8/15/13 | Classroom | 115 1st floor | Electrical |
| Avon (2025) 2A | There is aballast blown inthe light fixture in the hallway on the second floor. | 1/8/14 | 2nd Floor | hallway | Electrical |

| | | | | | |
|----------------|---|----------|---------------------|-------------|---------------------------------------|
| Avon (2025) 2A | All the bulbs have blown and need replacing needs attention per principal. | 1/30/14 | Classroom | Elevator | Electrical |
| Avon (2025) 2A | The main clock in the office needs setting for daylight saving time. | 3/17/14 | Administration Area | main office | Electrical |
| Avon (2025) 2A | HEATING UNIT RM 217- HAS A BURNING SMELL AND NOT COMING ON- PLANT MGR HARPER 416-2124 KLR | 4/2/14 | | | Electrical |
| Avon (2025) 2A | A/C UNIT is NOT COMING ON in ROOM 212 per Christopher Harper, Plant Mgr. 416.2124 | 6/6/14 | | | Electrical |
| Avon (2025) 2A | CHILLER MECH RM-NOT COOLING-AFFECTS ENTIRE BLDG-PLANT MGR HARPER 416-2124 KLR | 4/25/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | AHU NOT HEATING THRU ENTIRE BLDG. PLANT MGR- HARPER/416.2124 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | BOILER is NOT COMING ON per Christopher Harper, Plant Mgr. 416.2124 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | UNIT NOT COOLING IN ASSIS PRIN OFFICE (NO ID) . SBE-CLAY/416-8880 | 7/15/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------|--|---------|--|--|--|
| Avon (2025) 2A | Chiller down per EMS 7.11.13 | 7/20/13 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | Chiller down per EMS 7.18.13 | 7/20/13 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | Monthly - Oil Lube & Belt- Avon Middle - Refer to PM schedule details. | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | BOILER NOT COMING ON- AFFECTS ENTIRE BLDG- PLANT MGR HARPER 416- 2132 KLR | 2/21/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | Monthly - Oil Lube & Belt- Avon Middle - Refer to PM schedule details. | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | CHILLER OUTSIDE BLDG- NOT COMING ON, HAS NO POWER-PLANT MGR HARPER 416-2124 KLR | 6/9/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | Monthly - Filter-Avon Middle - Refer to PM schedule details. | 9/8/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------|--|----------|-----------------|----------|--|
| Avon (2025) 2A | Monthly - Filter-Avon Middle - Refer to PM schedule details. | 1/5/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | Monthly - Filter-Avon Middle - Refer to PM schedule details. | 5/11/14 | | | Heating/Ventilation /Air Conditioning |
| Avon (2025) 2A | A/C RM 112-LEAKING- PLANT MGR HARPER 416- 2124 KLR | 4/28/14 | | | Plumbing |
| Avon (2025) 2A | Flush sewer main | 5/5/14 | | | Plumbing |
| Avon (2025) 2A | There is a toilet that leaks needs attention. | 9/19/13 | Restroom (Boys) | upstairs | Plumbing |
| Avon (2025) 2A | FOUNTAIN CONTINUES TO RUN WATER IN CAFE. PLANT MGR- HARPER/834.2397 | 10/28/13 | | | Plumbing |
| Avon (2025) 2A | Pipe LEAKING in ceiling above the entrance door by the parking lot per Christopher Harper, Plant Mgr. 416.2124 | 11/6/13 | | | Plumbing |
| Avon (2025) 2A | Preform back flow test. | 12/23/13 | | | Plumbing |

| | | | | | |
|----------------|--|---------|------------------|-----------|----------|
| Avon (2025) 2A | UNIT IN MAIN OFFICE & PRINC. OFFICE LEAKING. SBE HARPER 416-2124 | 8/6/13 | | | Plumbing |
| Avon (2025) 2A | A/C IN MAIN OFC & PRIN'S OFC-BOTH ARE LEAKING-SBE HARPER 416-2124 KLR | 8/7/13 | | | Plumbing |
| Avon (2025) 2A | There are two water fountains without numbers that need attention one of the kids pull the two water fountains from the wall .also there is a sink that has a stream of water running non stop | 8/8/13 | Restroom (Boys) | 2nd floor | Plumbing |
| Avon (2025) 2A | The toilet and has a sign on it it won't do anything needs attention. | 8/8/13 | Restroom (Girls) | 2nd floor | Plumbing |
| Avon (2025) 2A | UNIT IS LEAKING WATER IN CUST. RM . PLANT MGR- HARPER/416.2124 | 8/8/13 | | | Plumbing |
| Avon (2025) 2A | RTU IN MAIN OFC - LEAKING - PM/HARPER 416-2124 | 8/14/13 | | | Plumbing |
| Avon (2025) 2A | The water fountain on the second floor was rip off needs attention. | 8/16/13 | Restroom (Boys) | 2nd floor | Plumbing |
| Avon (2025) 2A | A/C IN RMS 217 & 218- BOTH ARE LEAKING- PLANT MGR HARPER 416-2124 KLR | 8/20/13 | | | Plumbing |

| | | | | | |
|----------------|---|---------|-----------|-------------|----------|
| Avon (2025) 2A | UV IS LEAKING WATER IN RM-21,217 PLANT MGR- HARPER/416.2124 | 8/22/13 | | | Plumbing |
| Avon (2025) 2A | WATER is coming from UP from the SEWER in the KITCHEN per Christopher Harper, Plant Mgr. 416.2124 | 1/17/14 | | | Plumbing |
| Avon (2025) 2A | Sewer stopped-up | 1/27/14 | | | Plumbing |
| Avon (2025) 2A | FLOOR DRAIN KITCHEN AREA-BACKING UP SEWAGE-PLANT MGR HARPER 416-2124 KLR | 2/3/14 | | | Plumbing |
| Avon (2025) 2A | There is a waterfountain thats hanging of the wall needs attention. | 2/4/14 | Cafeteria | on the wall | Plumbing |
| Avon (2025) 2A | sewer backing up in kitchen per mr harper 416-2124 | 2/10/14 | | | Plumbing |
| Avon (2025) 2A | Unstop Main Sewer | 2/12/14 | | | Plumbing |
| Avon (2025) 2A | Unstop Sewer | 2/12/14 | | | Plumbing |

| | | | | | |
|----------------|---|---------|-----------------|----------|----------|
| Avon (2025) 2A | Unstop sewer | 2/21/14 | | | Plumbing |
| Avon (2025) 2A | Request camera be used to explore sewer drain. | 2/21/14 | | | Plumbing |
| Avon (2025) 2A | The toilet seat was broken off the toilet in 2 pieces need new toilet seat.needs attention. | 2/24/14 | Restroom (Boys) | upstairs | Plumbing |
| Avon (2025) 2A | video sewer drains | 2/26/14 | | | Plumbing |
| Avon (2025) 2A | per mr harper 416-2132 water is sitting in kitchen floor drain (backing up) | 3/25/14 | | | Plumbing |
| Avon (2025) 2A | Flush sanitary Sewer | 3/31/14 | | | Plumbing |
| Avon (2025) 2A | FLOOR DRAIN KITCHEN AREA-BACKING UP SEWAGE-PLANT MGR HARPER 416-2124 KLR | 4/2/14 | | | Plumbing |
| Avon (2025) 2A | ENTIRE COVER TO WATER FOUNTAIN 2ND FLR B RR-HAS BEEN TORN OFF BY A STUDENT EVERYTHING EXPOSE- PLANT MGR HARPER 416-2124 KLR | 4/3/14 | | | Plumbing |

| | | | | | |
|----------------|---|----------|------------------|--|----------|
| Avon (2025) 2A | Request sewer drain be washed out. | 4/14/14 | | | Plumbing |
| Avon (2025) 2A | Unstop sewer in front of school | 4/17/14 | | | Plumbing |
| Avon (2025) 2A | NO HOT WATER IN KITCHEN PLANT MGR- HARPER/834.2397 | 5/12/14 | | | Plumbing |
| Avon (2025) 2A | There is a pipe leaking in the ceiling by the parking lot door needs attention. | 5/30/14 | 1st Floor | by the parkinglot door | Plumbing |
| Avon (2025) 2A | Request installation for pipe that is leaking on the north end of the hallway. | 6/4/14 | | | Plumbing |
| Avon (2025) 2A | A/C PRIN'S OFC-LEAKING- PLANT MGR HARPER 416- 2124 KLR | 6/5/14 | | | Plumbing |
| Avon (2025) 2A | There are several leakes in the cafeteria and also in the ceiling in the mainhall door by the parkinglot needs attention. | 4/28/14 | Cafeteria | In the back and in the mainhall by door facing par | Roof |
| Avon (2025) 2A | There is a leak in the ceiling and every time the tile is changed it comes back needs attention. | 10/17/13 | Hallway/Corridor | mainhallway by parkinglot door | Roof |

| | | | | | |
|----------------|--|---------|------------------|----------------------------------|-------------|
| Avon (2025) 2A | There is a leake in the custodian breakroom over the desk that sits in there needs attention. | 8/5/13 | Custodial | Custodian break area | Roof |
| Avon (2025) 2A | There is a leake in the hallway on the south end of the building by the door that leads to the parking lot. | 8/5/13 | Hallway/Corridor | on the south end of the building | Roof |
| Avon (2025) 2A | There is a leak in the light fixture and in the ceiling in the cafeteria needs attention. | 1/8/14 | Cafeteria | in the ceiling | Roof |
| Avon (2025) 2A | There is a leake in the back of the cafeteria needs attention. | 2/5/14 | Cafeteria | in back of cafeteria | Roof |
| Avon (2025) 2A | There is a leake in this spot and it is still leaking. | 3/18/14 | Cafeteria | in the back by the doors | Roof |
| Avon (2025) 2A | The gutter over the door has came a loose and needs attention it is causing it to allow water to come in the side door by the chiller. | 5/5/14 | Cafeteria | outside by door by chiller | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|-----------------------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Berclair ES (2045) 2A | 5 | 36 | 57 | 50 | 3 | 51 | 7 | 1 | 210 |
| Grand Total | 5 | 36 | 57 | 50 | 3 | 51 | 7 | 1 | 210 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|-----------------------|---|---------------|---------------|-----------------------------------|-----------|
| Berclair ES (2045) 2A | Mr. Leonard Myers and the Capital Improvement department is requesting that our NCE staff provide project management for these 4 relocated portables to have network cabling installed in them for the purpose of computers internet connection and phones and until which time they are removed. Capital Improvements through Mr. Leonard Myers will provide any funding | 5/22/14 | | | Cabling |
| Berclair ES (2045) 2A | We need assistance from Support for Cabling and Electrical Wiring. We are to create a Computer Lab in room # 18. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 2/12/14 | Classroom | # 18 | Cabling |
| Berclair ES (2045) 2A | We need to have an estimate on wiring this classroom , # 18 . It will be turn into a computer lab. Please see " Facilitator or Computer Lab Tech. concerning any other information. | 2/24/14 | Classroom | # 18 | Cabling |
| Berclair ES (2045) 2A | network down in annex- fiber pulled from idf fiber tray- no phones or internet | 8/27/13 | Annex | | Cabling |
| Berclair ES (2045) 2A | Retermenate fibers that are broken due to improper terminations. | 9/12/13 | | | Cabling |
| Berclair ES (2045) 2A | per Ms. Davis 416-8800 portable 149 the door closure is not closing all the way and security is an issue | 10/3/13 | | | Carpentry |
| Berclair ES (2045) 2A | One of the door facing, on one the the doors leading into the Cafetoriumn is damage from termites. Please fix . | 10/17/13 | Cafetorium | Door Entering / Serving Line Area | Carpentry |
| Berclair ES (2045) 2A | We are having another problem with this floor. It has start during the same thing it did before . It is the 3rd time this has happen.It is very weak in 3 areas of the room. This is a safety hazard. Please fix A. S. A. P..... | 10/23/13 | Portables | # 309 B | Carpentry |
| Berclair ES (2045) 2A | The Enclosure on the Porch is broke . Please fix A. S. A. P. This is a safety hazard. | 11/6/13 | Portables | # 88 B | Carpentry |
| Berclair ES (2045) 2A | This is another portable which the siding is missing off of the porch . Please fix A. S. A. P. Portable # 89. | 11/15/13 | Portables | # 89 | Carpentry |

| | | | | | | |
|-----------------------|---|----------|---------------------|-----------------------|--|-----------|
| Berclair ES (2045) 2A | RAMP PORT 88-HAS A HOLE IN IT-PLANT MGR DAVIS 416-8800 KLR | 12/9/13 | | | | Carpentry |
| Berclair ES (2045) 2A | RAMP PORT 89-ON ONE SIDE HAS COLLASPED-HAZARDOUS-PLANT MGR DAVIS 416-8800 KLR | 12/17/13 | | | | Carpentry |
| Berclair ES (2045) 2A | LARGE HOLE ON CAFE STAGE FLR PLANT MGR-DAVIS/416.8800 | 12/20/13 | | | | Carpentry |
| Berclair ES (2045) 2A | Request door trim be painted. | 1/10/14 | | | | Carpentry |
| Berclair ES (2045) 2A | window leaking on to tile floor,tile floor renewing (waxing) | 6/10/14 | 1st Floor | rm.16 | | Carpentry |
| Berclair ES (2045) 2A | repair floor tile,damage | 6/27/14 | Portables | 237 | | Carpentry |
| Berclair ES (2045) 2A | repair floor tile,damage | 6/27/14 | Annex | rm.22 | | Carpentry |
| Berclair ES (2045) 2A | WOOD PORCH is VERY WEAK outside door on PORTABLE #88 per Geraldine Davis, Plant Mgr. 416.8800 | 5/14/14 | | | | Carpentry |
| Berclair ES (2045) 2A | PORT 149 - RAMP - WOOD IS COMING UP IN A TRIPPING STAGE - HAZARDOUS TO THE STUDENTS & ADULTS - PM/DAVIS 416-8800 | 4/23/14 | | | | Carpentry |
| Berclair ES (2045) 2A | Install a window in the door. | 4/25/14 | | | | Carpentry |
| Berclair ES (2045) 2A | At the Principal request, we need 2 small wndows cut out in these 2 doors. This is the asst. principal office. They will store the T - Cap tests in here. This office need too be monitor just like all of the classroom. | 4/25/14 | Administration Area | Located in Cafetorium | | Carpentry |

| | | | | | | |
|-----------------------|--|---------|---------------------|-------------------------|--|-----------|
| Berclair ES (2045) 2A | portable 149 front door the closure is broken per ms davis 416-8800 | 4/15/14 | | | | Carpentry |
| Berclair ES (2045) 2A | This room is being use as the office of the Afterschool Director. She need a small bullentin board install in there. | 4/17/14 | Administration Area | Server Room | | Carpentry |
| Berclair ES (2045) 2A | The ramp on this portable is coming up in some area. Please fix A. S. A. P. | 4/22/14 | Portables | # 149 | | Carpentry |
| Berclair ES (2045) 2A | We have another area in this portable where the floor is giving out. It is very weak. | 2/10/14 | Portables | # 309 A | | Carpentry |
| Berclair ES (2045) 2A | install two locks in office area, per principal-os | 2/11/14 | | | | Carpentry |
| Berclair ES (2045) 2A | The Teacher was walking up the ramp and her foot went thru the ramp. Big hole there. | 7/29/13 | Portables | # 89 | | Carpentry |
| Berclair ES (2045) 2A | PORTABLE# 89 RAMP HAS A HOLE IN IT. SBE DAVIS 416-880 | 7/30/13 | | | | Carpentry |
| Berclair ES (2045) 2A | We need a Dry Erase Board install in this room .This is a classroom now.. | 8/1/13 | Library | ESL Room (Storage Room) | | Carpentry |
| Berclair ES (2045) 2A | Repair ramp on the portable. | 8/2/13 | | | | Carpentry |
| Berclair ES (2045) 2A | The door in the lounge restroom will lock and you cannot get out sometimes. | 8/6/13 | | | | Carpentry |
| Berclair ES (2045) 2A | GUTTER TO PORTABLE#301 IS HANGING. SBE DAVIS 416-8800 | 8/7/13 | | | | Carpentry |

| | | | | | | |
|-----------------------|--|----------|---------------------|--------------------|--|------------|
| Berclair ES (2045) 2A | DOOR will NOT CLOSE N. End of Hall near Classroom #1 per Geraldine Davis, Plant Mgr. 416.8800 | 3/6/14 | | | | Carpentry |
| Berclair ES (2045) 2A | Someone cut the whole window screen out. Please fix A. S. A. P. | 8/12/13 | Kitchen | Cafetorium Manager | | Carpentry |
| Berclair ES (2045) 2A | The Principal has several signs which need to be posted. The Poles are in the ground. The signs need to be attach. Please see Principal for further info. | 8/13/13 | Grounds | Grounds | | Carpentry |
| Berclair ES (2045) 2A | The Cafeteria Manager is having a problem with one of the Cafeteria Doors (near water fountain) trying to get it open. It was stuck this morning. | 8/15/13 | Cafetorium | Serving Line Area | | Carpentry |
| Berclair ES (2045) 2A | BACK CAFE WINDOW DOOR IS COMPLETELY OUT, CANT SECURE, & PANTRY DOOR HAS BEEN KICKED IN KITCHEN. PLANT MGR-DAVIS/416.5952 | 8/20/13 | | | | Carpentry |
| Berclair ES (2045) 2A | At the Principal request , we have 3 doors in the main office which need the locks fix where they are automatically lock from the outside when you close the door. This is for safety in case we have a 911 situation in the main office. This was submitted to the wrong dept. 2nd request. | 8/20/13 | Administration Area | Main Office | | Carpentry |
| Berclair ES (2045) 2A | We have a restroom door which will not close good .Its stuck. | 8/21/13 | Restroom (Boys) | 1st floor | | Carpentry |
| Berclair ES (2045) 2A | One of the plywood in certain area of the ramp is coming up from the ramp It is a tripping habit. | 9/9/13 | Portables | # 149 | | Carpentry |
| Berclair ES (2045) 2A | All three steps are rotten as you enter Portable no. 88A per Geraldine Davis 901.416.8800. | 9/10/13 | | | | Carpentry |
| Berclair ES (2045) 2A | ICE MAKER PLUG HEAD IS STUCK IN RECEPTACLE KITCHEN. PLANT MGR-DAVIS/416.8800 | 10/15/13 | | | | Electrical |
| Berclair ES (2045) 2A | We need about 3 boxes of flr. Lamp Start 25 here at Grahamwood El. | 10/16/13 | Custodial | Boiler Room | | Electrical |

| | | | | | |
|-----------------------|--|----------|---------------------|-------------------------------------|------------|
| Berclair ES (2045) 2A | We need about 3 boxes of Fir. Lamp Rapid Start 25 for our school. | 10/16/13 | Custodial | Boiler Room | Electrical |
| Berclair ES (2045) 2A | This classroom has 2 sets of lights out. The bulbs has been changed and the lights will not come on. | 10/29/13 | Annex | # 25 | Electrical |
| Berclair ES (2045) 2A | We need our clock set for Daylight Saving Time. | 11/4/13 | Administration Area | Main Office | Electrical |
| Berclair ES (2045) 2A | This classroom has 3 sets of lights out . The bulbs has been changed in all of them. Please fix A. S. A. P. | 11/4/13 | Annex | # 24 | Electrical |
| Berclair ES (2045) 2A | BELL SYSTEM MAIN OFC AREA-HAS NO POWER AT ALL-PLANT MGR DAVIS 416-8800 KLR | 11/14/13 | | | Electrical |
| Berclair ES (2045) 2A | UV NOT COMING ON IN RM-15 PLANT MGR-DAVIS/416.8800 | 11/25/13 | | | Electrical |
| Berclair ES (2045) 2A | room 16 one unit won't come on at all room 15 one unit won't come on at all per ms davis 416-8800 | 11/26/13 | | | Electrical |
| Berclair ES (2045) 2A | We have 2 set of lights in this portable which do not work. The bulbs has been change. Also there is a hallway light in the Annex building not working. The bulbs has been change and it is not working. | 11/27/13 | Portables | 237 A & Hallway in Annex (Northend) | Electrical |
| Berclair ES (2045) 2A | ALL outlets in the KITCHEN are NOT WORKING per Geraldine Davis, Plant Mgr. 416.8800 | 12/5/13 | | | Electrical |
| Berclair ES (2045) 2A | 4-UV NOT COMING ON IN RM-3,8,10,14 PLANT MGR-DAVIS/416.8800 | 12/9/13 | | | Electrical |
| Berclair ES (2045) 2A | UV NOT COMING ON & BURNING SMELL IN RM-8 PLANT MGR-DAVIS/416-8800 | 12/17/13 | | | Electrical |

| | | | | | | |
|-----------------------|--|---------|---------------------|------------------------------|--|------------|
| Berclair ES (2045) 2A | HEAVY WIRING DOWN ON GROUND COMING FROM ANNEX BLDG LEADING TO A PORT 89-PLANT MGR DAVIS 416-8800 KLR | 1/2/14 | | | | Electrical |
| Berclair ES (2045) 2A | RECEPTACLE KITCHEN AREA FOR ICE MACHINE- HAS NO POWER, WILL NEED-PLANT MGR DAVIS 416-8800 KLR | 1/6/14 | | | | Electrical |
| Berclair ES (2045) 2A | We need some light bulbs for our double portables. The size we need are T- 12 (2 boxes). Also we need 2 boxes of the regular light bulbs. | 1/6/14 | Custodial | Boiler Room | | Electrical |
| Berclair ES (2045) 2A | We have a set of lights out in the Lounge. The bulbs has been change . | 1/16/14 | Administration Area | Teacher Lounge | | Electrical |
| Berclair ES (2045) 2A | This classroom has an outlet not working . The circuit box has been checked. Please fix A. S. A. P. | 1/21/14 | Classroom | # 15 | | Electrical |
| Berclair ES (2045) 2A | We are having an Electrical problem in this portable . | 1/21/14 | Portables | # 248 | | Electrical |
| Berclair ES (2045) 2A | We need about 10 flood watt light bulbs for the stage. | 1/22/14 | Cafetorium | | | Electrical |
| Berclair ES (2045) 2A | WINDOW unit in PORTABLE #87 is NOT HEATING per Geraldine Davis, Plant Mgr. 416.8800. | 1/24/14 | | | | Electrical |
| Berclair ES (2045) 2A | The Fire Marshall was here on 3 - 26- 2014 & he found several fire code violations with the Emergency lights thru - out the school. Please see Plant Manager or check into Main Office for further instructions. | 3/27/14 | Hallway/Corridor | Thru - Out School & Hallways | | Electrical |
| Berclair ES (2045) 2A | We need a box of Light Bulbs for the light fixture. | 8/7/13 | Custodial | Boiler Room | | Electrical |
| Berclair ES (2045) 2A | A/C UNIT is NOT COMING ON in the TEACHER'S LOUNGE per Horace Jefferson, Plant Mgr. 416.8800 | 6/4/14 | | | | Electrical |

| | | | | | | |
|-----------------------|---|---------|------------|---------------------|--|------------|
| Berclair ES (2045) 2A | RECEPTACLE B RR IN HALL TO PARKING LOT-HAS NO POWER-PLANT MGR JEFFERSON 416-8800 KLR | 6/12/14 | | | | Electrical |
| Berclair ES (2045) 2A | A/C RM 5 & ONE UNIT IN RM 7-BOTH NOT COMING ON-PLANT MGR JEFFERSON 416-8800 KLR | 6/17/14 | | | | Electrical |
| Berclair ES (2045) 2A | The light where the receptionist sit is out. The bulbs has been change and the light is still out. It is very difficult for her to work in that area. | 5/12/14 | Portables | # 149 | | Electrical |
| Berclair ES (2045) 2A | per ms davis 416-8800 in the main office the printing area is completely dark, lights will not come on | 4/30/14 | | | | Electrical |
| Berclair ES (2045) 2A | The Vent Hood in the Kitchen has a fan which will not come on. Please fix A. S. A. P. | 4/28/14 | Kitchen | Kitchen | | Electrical |
| Berclair ES (2045) 2A | HAS A COMPLETE POWER OUTAGE-PLANT MGR DAVIS 416-8800 KLR | 4/2/14 | | | | Electrical |
| Berclair ES (2045) 2A | We have a light out in the hallway . The bulb has been change. | 4/8/14 | Annex | Northend of Hallway | | Electrical |
| Berclair ES (2045) 2A | Please fix light in computer lab. | 4/8/14 | Classroom | Computer Lab | | Electrical |
| Berclair ES (2045) 2A | We have about 4 exit lights out in the Cafetoriumn. Please fix A. S. A. P. | 1/28/14 | Cafetorium | Cafetoriumn Area | | Electrical |
| Berclair ES (2045) 2A | per ms davis 416-8800 the assistant principal's office which is in the cafetorium heat is not coming on at all | 1/28/14 | | | | Electrical |
| Berclair ES (2045) 2A | ROW OF LIGHTS IN LIBRARY THAT LEADS TO ESL CLASSRM-NOT WORKING MAKING IT VERY DARK IN RM PER RM-PLANT MGR DAVIS 416-8800 KLR | 1/29/14 | | | | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|----------------|------------|
| Berclair ES (2045) 2A | Power outage | 2/3/14 | | | Electrical |
| Berclair ES (2045) 2A | There is a problem with a light fixture in this classroom. I was putting a bulb in the fixture and there was a little smoke coming from the fixture. Please see the teacher or Plant Manager. | 2/5/14 | Annex | Classroom # 27 | Electrical |
| Berclair ES (2045) 2A | per ms davis 416-8800 due to power outage the bells are not ringing | 2/7/14 | | | Electrical |
| Berclair ES (2045) 2A | We need a box of regular flourescent light bulbs here at Berclair Elementary. | 2/17/14 | Custodial | Boiler Room | Electrical |
| Berclair ES (2045) 2A | HEAVY WIRING PORT 149-HANGING REAL LOW-PLANT MGR DAVIS 416-8800 KLR | 2/21/14 | | | Electrical |
| Berclair ES (2045) 2A | LIGHTS ARE BLINKING OFF AND ON THRU BLDG, FIRE ALARM IS SHOWING TROUBLE. PLANT MGR-DAVIS/489.4842 | 2/26/14 | | | Electrical |
| Berclair ES (2045) 2A | We need our clock change for Daylight Saving Time..... | 2/28/14 | Administration Area | Main Office | Electrical |
| Berclair ES (2045) 2A | UV IS MAKING NOISE IN LIBRARY (033). SBE-DAVIS/416-8800 | 7/3/13 | | | Electrical |
| Berclair ES (2045) 2A | UNIT IN THE CAFETORIUM IS NOT COMING ON. SBE DAVIS 416-8840 | 7/30/13 | Cafetorium | | Electrical |
| Berclair ES (2045) 2A | We have a light fixture where the bulb is very hard too come out . Please fix A. S. A. P. | 3/17/14 | Kitchen | Kitchen | Electrical |
| Berclair ES (2045) 2A | Pick-up compressor and return it to the shop. | 3/18/14 | | | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|-------------------|------------|
| Berclair ES (2045) 2A | We are having the school bell ringing 4 times a day. We only need the bell too ring 1 time a day which is at 3:00 p. m. | 3/21/14 | Administration Area | Main Office | Electrical |
| Berclair ES (2045) 2A | UV NOT COMING ON IN RM-16(036). PLANT MGR-DAVIS/ | 8/12/13 | | | Electrical |
| Berclair ES (2045) 2A | UV-35 RM 15 EAST-NOT COMING ON-SBE DAVIS 416-8800 KLR | 8/13/13 | | | Electrical |
| Berclair ES (2045) 2A | The Clock need too be set for tardy bell and dismissal bell. | 8/13/13 | Administration Area | Main Office | Electrical |
| Berclair ES (2045) 2A | UV RM 15-NOT COMING ON-PLANT MGR DAVIS 416-8800 KLR | 8/20/13 | | | Electrical |
| Berclair ES (2045) 2A | LIGHT IN PANTRY NOT COMING ON-SBE SAYS SHE CHANGED BULB, STILL NOT COMING ON-PLANT MGR DAVIS 416-8800 KLR | 8/21/13 | | | Electrical |
| Berclair ES (2045) 2A | The flag is stuck up on the flagpole. | 8/26/13 | Grounds | Front of building | Electrical |
| Berclair ES (2045) 2A | The ice maker is not working because of electrical problem per Ms. Davis 416-8800 | 9/3/13 | | | Electrical |
| Berclair ES (2045) 2A | This portable is having a problem with a couple of lights out. The bulb has been changed. | 9/10/13 | Portables | 87 | Electrical |
| Berclair ES (2045) 2A | We need the bulb changed on these pole lights behind these portables for security reasons. It is very dark out there . | 9/13/13 | Portables | # 88, 89, 237 | Electrical |
| Berclair ES (2045) 2A | room #16 UV will not come on per Ms. Davis 416-8800 | 9/30/13 | | | Electrical |

| | | | | | |
|-----------------------|---|----------|--|--|---------------------------------------|
| Berclair ES (2045) 2A | unit in room 5 not cooling per Ms. Davis 416-8800 | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | 4-UV NOT HEATING IN RM-15,13,8,COMPUTER LAB PLANT MGR-DAVIS/416.8800 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | room 15 one of the units is blowing cold air room 16 one of the units is blowing cold air per Ms. Davis 416-8800 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | 3-UV NOT HEATING IN RM-10,9,2, PORT-149, & BOILER NOT COMING ON PLANT MGR-DAVIS/416.8800 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | HEAT PORT 89 & FCU ASST PRIN'S OFC-BOTH NOT HEATING-PLANT MGR DAVIS 416-8800 KLR | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UV NOT HEATING IN TEACHERS' LOUNGE PLANT MGR-DAVIS/416-8800 | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | HEAT PORT 149-NOT HEATING-PLANT MGR DAVIS 416-8800 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | (3) UV'S LIBRARY-NOT HEATING-PLANT MGR DAVIS 416-8800 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | BOILER-1 MECH RM-NOT COMING ON-PLANT MGR DAVIS 416-8800 KLR | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Monthly - Filter-Berclair Elementary - Refer to PM schedule details. | 1/20/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | HEAT PORT 89 & TEACHER'S LOUNGE-BOTH NOT HEATING-PLANT MGR DAVIS 416-8800 KLR | 1/22/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|--|--|---------------------------------------|
| Berclair ES (2045) 2A | Yearly - #1 Boiler 053 - Berclair El-Boiler Rm S - Refer to PM schedule details. | 3/1/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Yearly - #2 Boiler 054 - Berclair El-Boiler Rm N - Refer to PM schedule details. | 3/2/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Monthly - Filter-Berclair Elementary - Refer to PM schedule details. | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | 7-UNITS NOT COOLING IN RM-8,10,11,12,13,14,15 . PLANT MGR-DAVIS/416.8800 | 4/24/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UNIT IS MAKING NOISE NOT COOLING IN MAIN OFFICE PLANT MGR-DAVIS/416.8800 | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | per ms davis 416-8800 teachers lounge blowing hot | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UNIT NOT COOLING IN LIBRARY, TEACHER LOUNGE ,COMPUTER LAB PLANT MGR-DAVIS/416.8800 | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C PORT 149-MAKING LOUD NOISES & NOT COOLING-PLANT MGR DAVIS 416-8800 KLR | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | OTHER ONE RM 7-NOT COOLNG ON-PLANT MGR JEFFERSON 416-8800 KLR | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C RM 2-NOT COOLING-PLANT MGR JEFFERSON 416-88800 KLR | 6/24/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C UNIT is NOT COOLING in the LIBRARY per Horace Jefferson, Plant Mgr. 901.644.1319 | 5/28/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Berclair ES (2045) 2A | FCU - COMPUTER LAB BLOWING NOT COOLING - PM/JEFFERSON | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | TWO (2) A/C UNITS are LEAKING in ROOM 2 and the CAFETERIA per Horace Jefferson, Plant Mgr. 416.8800 | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C UNITS are NOT COOLING in ROOM 9 and PORTABLE 149 per Horace Jefferson, Plant Mgr. 416.8800 | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C UNIT is MAKING A LOUD NOISE in the MAIN OFFICE per Horace Jefferson, Plant Mgr. 416.8800 | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UNIT NOT COOLING IN RM-6 PLANT MGR-JEFFERSON/644.1319 | 6/9/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C UNIT is LEAKING in ROOM 2 (on First Floor) per Mr. Jefferson, Plant Mgr. 416.8800 | 6/13/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | replace unit on port#1 | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | replace unit port#2 | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | replace unit port#3 | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | replace unit port#4 | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UV RM 2-LEAKING, CAN'T CONTAIN-PLANT MGR DAVIS 416-8800 KLR NOTE: PLUMBER RESPONDED, COILS HAVE BURST SWITCHED TO HVAC KLR | 5/9/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|---|---------|------------|-------|--|---------------------------------------|
| Berclair ES (2045) 2A | Monthly - Filter-Berclair Elementary - Refer to PM schedule details. | 5/19/14 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Monthly - Oil Lube & Belt-Berclair Elementary - Refer to PM schedule details. | 5/4/14 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | per ms davis 416-8800 portable 89 is blowing cold air no heat and teachers lounge is blowing cold | 2/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | 2-UV NOT COOLING IN LIBRARY (131,030). SBE-EVANS/416-7780 | 7/3/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UNITS ARE NOT COOLING IN 2 & THE TEACHER LOUNGE. SBE DAVIS 416-8840 | 7/30/13 | Cafetorium | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Portable 88 a/c core is froze up low on freon per Ms. Davis 416-8800 | 8/12/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UNIT NOT COOLING IN PORT-88. PLANT MGR-DAVIS/416.8800 | 8/12/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | A/C IN PORT 88-NOT COOLING-SBE DAVIS 416-8800 KLR | 8/13/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UV-26 RM 6 SOUTH & PORT 309A-BOTH NOT COOLING-SBE DAVIS 416-8800 KLR | 8/19/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | The thermostat in this class room need too be replace' | 8/21/13 | Classroom | # 109 | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|---|---------|---------------------|----------------------------|--|---------------------------------------|
| Berclair ES (2045) 2A | PORT 89-A/C NOT COOLING-PLANT MGR DAVIS 416-8800 KLR | 8/26/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Unit is freeze and has to be turned off at times in Portable 309 per Geraldine Davis, Plant Mgr. 416.8800. | 9/11/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | UV NOT COOLING IN RM-6 PLANT MGR-DAVIS/416.8800 | 9/17/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | At the Principal request , this classroom has had problems with both of the unit ventilators in this classroom. We are requesting those 2 units be removed and be replace with the unit that the Principal has in his office. One of the unit ventilator floods the classroom all the time , and the other unit ventilator just blows hot air all the time. | 9/17/13 | Classroom | # 6 | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | Monthly - Oil Lube & Belt-Berclair Elementary - Refer to PM schedule details. | 9/29/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | room 5 one unit is leaking room 6 unit is leaking per Ms. Davis 416-8800 | 10/1/13 | | | | Heating/Ventilation /Air Conditioning |
| Berclair ES (2045) 2A | We have 2 outside doors which was replace (Courtyard Area) need to be painted. | 1/27/14 | Hallway/Corridor | Outside Doors (Courtyard) | | Painting |
| Berclair ES (2045) 2A | VULGAR GRAFFITI OUTSIDE PLAYGROUND AREA ON FRONT SLIDING BOARD ON THE PERKINS ST. SIDE- PLANT MGR DAVIS 416-8800 KLR | 4/2/14 | | | | Painting |
| Berclair ES (2045) 2A | Painting boys Restroom. | 7/29/13 | | | | Painting |
| Berclair ES (2045) 2A | TOILET & FLR DRAIN ARE STOPPED UP & OVERFLOWING IN G/RR MAIN LOBBY PLANT MGR-DAVIS/416.5952 | 10/1/13 | | | | Plumbing |
| Berclair ES (2045) 2A | The Commode in the Main Office restroom is stopped up. | 10/1/13 | Administration Area | Main Office Restroom | | Plumbing |

| | | | | | | |
|-----------------------|--|----------|------------------|------------------------|--|----------|
| Berclair ES (2045) 2A | FAUCET HANDLE CONTINUES TO MOVE AROUND & AROUND IN EAST-END HALL LONG SINK PLANT MGR-DAVIS/416.8800 | 10/3/13 | | | | Plumbing |
| Berclair ES (2045) 2A | unstop sewer | 10/14/13 | | | | Plumbing |
| Berclair ES (2045) 2A | The ESL Classroom in the back of the Library has a sink in her classroom with a leaking faucet. We cannot turn the water off underneath it at all . Please fix A. S. A. P. | 10/24/13 | Library | ESL Clasroom | | Plumbing |
| Berclair ES (2045) 2A | We have a commode in the Pre - K restroom , leaks very bad when you flush it. | 10/28/13 | Restroom (Girls) | Pre - K Restroom | | Plumbing |
| Berclair ES (2045) 2A | UV RM 2-LEAKING FROM BOTTOM CAUSING FLOOR TILE TO COME UP PER SBE-PLANT MGR DAVIS 416-8800 KLR | 10/30/13 | | | | Plumbing |
| Berclair ES (2045) 2A | Pipe is BROKEN underneath the sink in the Girl's RR (in the Annex bldg.) per Geraldine Davis, Plant Mgr. 416.8800 | 12/16/13 | | | | Plumbing |
| Berclair ES (2045) 2A | UV IS LEAKING WATER IN RM-8 PLANT MGR-DAVIS/416.8800 | 12/17/13 | | | | Plumbing |
| Berclair ES (2045) 2A | We have 2 commodes which are stop up. We have plunge the commode and they are still stop up. | 1/6/14 | Restroom (Girls) | Eastend of the Hallway | | Plumbing |
| Berclair ES (2045) 2A | The Cafeteria Manager has a stopped up sink and a running faucet which she cannot turn off. Please fix A. S. A. P..... | 1/10/14 | Cafeteria | Kitchen | | Plumbing |
| Berclair ES (2045) 2A | 2-COMPARTMENT SINK KITCHEN AREA-STOPPED UP & 2-COMPARTMENT SINK KITCHEN AREA-FAUCET RUNNING AT A STREAM, CAN'T CUT OFF-PLANT MGR DAVIS 416-8800 KLR | 1/14/14 | | | | Plumbing |
| Berclair ES (2045) 2A | We have a urinal in the boys restroom which is stopped up. Please fix . | 1/16/14 | Restroom (Boys) | Eastend of Hallway | | Plumbing |

| | | | | | | |
|-----------------------|---|---------|---------------------|-----------------------|--|----------|
| Berclair ES (2045) 2A | UNIT IS LEAKING WATER IN RM-6 PLANT MGR-JEFFERSON/644.1319 | 6/9/14 | | | | Plumbing |
| Berclair ES (2045) 2A | A/C TEACHER'S LOUNGE-LEAKING-PLANT MGR JEFFERSON 416-8800 KLR | 6/19/14 | | | | Plumbing |
| Berclair ES (2045) 2A | UV RM 1 & 2-BOTH LEAKING-PLANT MGR DAVIS 416- 8800 KLR | 5/13/14 | | | | Plumbing |
| Berclair ES (2045) 2A | We have a commode in the girls restroom which is stopped up. Please fix A. S. A. P. | 5/14/14 | Restroom (Girls) | Eastend of Hall | | Plumbing |
| Berclair ES (2045) 2A | TOILETS OVERFLOW when ONE TOILET is FLUSHED in the BOY'S RR, on N. end of building per Geraldine Davis, Plant Mgr. 416.8800 | 5/16/14 | | | | Plumbing |
| Berclair ES (2045) 2A | 3-UNITS ARE LEAKING WATER IN RM-8,10,CAFE EAST-END . PLANT MGR-DAVIS/416.8800 | 4/24/14 | | | | Plumbing |
| Berclair ES (2045) 2A | The Boys & Girls restroom has a set of lights out in the restroom. The bulbs has been change in each restroom. | 3/27/14 | Annex | Boys & Girls Restroom | | Plumbing |
| Berclair ES (2045) 2A | CUST SINK IS STOPPED UP IN BOILER RM. PLANT MGR-DAVIS/416.8800 | 3/27/14 | | | | Plumbing |
| Berclair ES (2045) 2A | The facing on the water fountain came off & I can't put it back on to stay. Please fix A. S. A. P. | 4/7/14 | Cafetorium | Cafetoriumn | | Plumbing |
| Berclair ES (2045) 2A | (2) 3-COMPARTMENT SINKS KITCHEN AREA-BOTH STOPPED UP-PLANT MGR DAVIS 416-8880 KLR | 4/10/14 | | | | Plumbing |
| Berclair ES (2045) 2A | There are a couple of leaking faucet in the kitchen. Please fix A. S. A. P. | 4/14/14 | Cafeteria | Kitchen Area | | Plumbing |

| | | | | | |
|-----------------------|--|---------|------------------|--------------------|----------|
| Berclair ES (2045) 2A | A/C RM 4-LEAKING-PLANT MGR DAVIS 416-8880 KLR | 4/16/14 | | | Plumbing |
| Berclair ES (2045) 2A | per ms davis 416-8800 boys restroom east end 2 commodes stopped up can't unstop also boys restroom in annex 1 commode stopped up | 4/17/14 | | | Plumbing |
| Berclair ES (2045) 2A | per ms davis 416-8800 in girls restroom east end there are 3 commodes that are stopped up | 1/30/14 | | | Plumbing |
| Berclair ES (2045) 2A | Request back flow test. | 2/5/14 | | | Plumbing |
| Berclair ES (2045) 2A | We are still having a problem with a commode being stopped up. | 2/10/14 | Restroom (Girls) | Eastend of Hallway | Plumbing |
| Berclair ES (2045) 2A | We have a water fountain in the hallway which do not work. It need too be remove from that area . | 2/11/14 | Hallway/Corridor | Eastend of Hallway | Plumbing |
| Berclair ES (2045) 2A | (2) FLOOR DRAINS B RR ACROSS FROM BOILER RM- BACKING UP-PLANT MGR DAVIS 416-8800 KLR | 2/12/14 | | | Plumbing |
| Berclair ES (2045) 2A | The Adult Restroom is stopped up. | 2/17/14 | Annex | Adult Restroom | Plumbing |
| Berclair ES (2045) 2A | TOILET IS STOPPED UP IN ANNEX BLDG PLANT MGR-DAVIS/416.8800 | 2/19/14 | | | Plumbing |
| Berclair ES (2045) 2A | per ms davis 416-8800 the boys restroom there is a sink that is leaking from underneath and can't shut off | 2/21/14 | | | Plumbing |
| Berclair ES (2045) 2A | Boys restroom in the annex BLDG need pipes installed. | 2/21/14 | | | Plumbing |

| | | | | | |
|-----------------------|--|---------|------------------|-----------------------------|----------|
| Berclair ES (2045) 2A | Remove fixtures out the rest room. | 7/5/13 | Restroom (Boys) | | Plumbing |
| Berclair ES (2045) 2A | STEAMTABLE-PILOT NEED TO BE LIT-SBE DAVIS 416-8800 KLR | 7/31/13 | | | Plumbing |
| Berclair ES (2045) 2A | We have several leaking faucets located in large sink near Boiler Room. | 3/5/14 | Hallway/Corridor | Northend (near boiler room) | Plumbing |
| Berclair ES (2045) 2A | The Commode seat in the boys' restroom is broke. | 3/25/14 | Annex | Boys Restroom | Plumbing |
| Berclair ES (2045) 2A | SINK B RR NORTH END OF HALL-WATER HAS BEEN CUT OFF TO SINK & IT'S STOPPED UP WITH FROM WHERE CONTRACTORS WERE WORKING-SBE DAVIS 416-8800 KLR | 8/12/13 | | | Plumbing |
| Berclair ES (2045) 2A | UV-34 RM 15 WEST & AHU-2 CAFE WEST-BOTH LEAKING-SBE DAVIS 416-8800 KLR | 8/13/13 | | | Plumbing |
| Berclair ES (2045) 2A | Room #2 (002002) AHU leaking water and the cafeteria AHU is leaking water per Ms. Davis 416-8800 | 8/15/13 | | | Plumbing |
| Berclair ES (2045) 2A | UV-27 RM 6 NORTH-LEAKING-SBE DAVIS 416-8800 KLR | 8/19/13 | | | Plumbing |
| Berclair ES (2045) 2A | FLOOR DRAIN BACKING UP IN G RR ACROSS FROM PRIN'S OFC-SBE DAVIS 416-8800 KLR | 8/19/13 | | | Plumbing |
| Berclair ES (2045) 2A | OTHER UV RM 15-LEAKING-PLANT MGR DAVIS 416-8800 KLR | 8/20/13 | | | Plumbing |
| Berclair ES (2045) 2A | The water fountain on the Main Hallways is leaking very bad .Please fix A. S. A. P. | 8/21/13 | Hallway/Corridor | Main Hallway | Plumbing |

| | | | | | | |
|-----------------------|--|----------|------------------|--|--|----------|
| Berclair ES (2045) 2A | UNIT NOT COMING ON PORT-149 PLANT MGR-DAVIS/416.8800 | 9/3/13 | | | | Plumbing |
| Berclair ES (2045) 2A | 2-UV ARE LEAKING WATER IN RM-6, CAFE PLANT MGR-DAVIS/416.8800 | 9/17/13 | | | | Plumbing |
| Berclair ES (2045) 2A | 3-COMPARTMENT SINK KITCHEN AREA-LEAKING FROM BOTTOM, CAN'T CONTAIN-WRITTEN UP BY HEALTH DEPT PER SBE-PLANT MGR DAVIS 416-8800 KLR | 9/24/13 | | | | Plumbing |
| Berclair ES (2045) 2A | both AHU's in cafetorium are leaking really bad per Ms. Davis 416-8800 | 9/25/13 | | | | Plumbing |
| Berclair ES (2045) 2A | uv in room #6 both units are leaking water per Ms. Davis 416-8800 | 9/30/13 | | | | Plumbing |
| Berclair ES (2045) 2A | We are having a leak in the ceiling. The ceiling tile has a bad stain on it. | 11/15/13 | Hallway/Corridor | Northend of Hallway (near Boiler Room) | | Roof |
| Berclair ES (2045) 2A | The Library has a roof leak. Please fix A. S . A. P. | 1/23/14 | Library | Library | | Roof |
| Berclair ES (2045) 2A | The Facilitator Office has a bad roof leak. Please fix A. S. A. P. | 5/14/14 | Portables | # 149 | | Roof |
| Berclair ES (2045) 2A | We have a bad leak in the kitchen .Please see Plant Manager or Cafeteria Manager. | 4/28/14 | Cafeteria | Kitchen Area | | Roof |
| Berclair ES (2045) 2A | We have a bad roof leak in the kitchen. Please see Plant Manager or Cafeteria Manager. | 4/28/14 | Cafeteria | Kitchen Area | | Roof |
| Berclair ES (2045) 2A | The library has a roof leak. | 4/16/14 | Classroom | Library | | Roof |

| | | | | | |
|-----------------------|--|---------|-----------|-------|-------------|
| Berclair ES (2045) 2A | The Financial Secretary has a bad roof leak in her office. Please fix A. S. A. P. | 3/7/14 | Portables | # 149 | Roof |
| Berclair ES (2045) 2A | Remove panels off Portables #309A&B, 237 & 149 to allow access for termite treatment. Call Bill Spitznas 626-5003 and will have tech meet to show which panels need to be removed. | 4/15/14 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|---------------------------|----------|---------|-----------|------------|------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Plumbing | Roof | Sheet Metal | Grand Total |
| Bethel Grove ES (2050) 2B | 1 | 4 | 6 | 20 | 18 | 11 | 5 | 2 | 67 |
| Grand Total | 1 | 4 | 6 | 20 | 18 | 11 | 5 | 2 | 67 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|---------------------------|---|----------------|------------------|-------------|-----------|
| Bethel Grove ES (2050) 2B | in room 15 need tile replace and the main office tile in room 20 need tile replace | 10/2/13 | | | Asbestos |
| Bethel Grove ES (2050) 2B | in room 15 internet wire broken.computer jack in room 16 and 5 needs replaced | 4/7/14 | | | Cabling |
| Bethel Grove ES (2050) 2B | in room 15 internet jack wire are broken . (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 2/11/14 | | | Cabling |
| Bethel Grove ES (2050) 2B | computer jake in room 16 and 5 need replace. | 3/20/14 | | | Cabling |
| Bethel Grove ES (2050) 2B | in room 15 and 5 computer outlet not work each outlet supply 2 computer. Please help asap | 5/8/14 | | | Cabling |
| Bethel Grove ES (2050) 2B | ENTRANCE DOOR CAFE SOUTH END-CTR MULL DAMAGED OR MISSING- WON'T BE ABLE TO SECURE- PLANT MGR HASLETT 416-1743 KLR | 2/24/14 | | | Carpentry |
| Bethel Grove ES (2050) 2B | ROLL-UP WINDOW IN MAIN OFC FOR CONCESSION STAND-WON'T COME DOWN, WON'T BE SECURED-PLANT MGR HASLETT 416-1743 KLR | 1/15/14 | | | Carpentry |
| Bethel Grove ES (2050) 2B | WINDOW DOOR HAS SCATTER IN ANNEX NORTH-END PLANT MGR- HASLETT/416.5012 | 5/5/14 | | | Carpentry |
| Bethel Grove ES (2050) 2B | WINDOW and FRAMING needs to be REPLACED in the back area of the school by the FIRE ESCAPE per Jessie Haslett, Plant Mgr. 416.1743 | 2/18/14 | | | Carpentry |

| | | | | | |
|---------------------------|---|---------|--|--|------------|
| Bethel Grove ES (2050) 2B | i need a 2 box 4ft fiberglass ceiling tiles. | 8/7/13 | | | Carpentry |
| Bethel Grove ES (2050) 2B | need ceiling tiles | 8/6/13 | | | Carpentry |
| Bethel Grove ES (2050) 2B | UNIT NOT COMING ON IN RM-23 PLANT MGR- HASLETT/416.5012 | 5/5/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | A/C RM 23 & 12-BOTH NOT COMING ON-PLANT MGR HASLETT 416-1743 KLR | 5/8/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | principal office and the one in front of the office ballet are out. | 7/25/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | half the hall clock need seting! | 3/19/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | A/C RM 27-NOT COMING ON- PLANT MGR HASLETT 416- 1743 KLR | 5/9/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | UNIT NOT COMING ON IN FRONT OFFICE PLANT MGR- HASSLETT/416.4578 | 6/3/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | i need fir lamps 4ft long / 28 watt / 25 in a boxes. | 8/6/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | i have 4 ballet out in the clue room. | 8/13/13 | | | Electrical |

| | | | | | |
|---------------------------|--|----------|--|--|------------|
| Bethel Grove ES (2050) 2B | UV-1 RM 1, UV-2 RM 14, & UV-3 RM 25-ALL NOT COMING ON-PLANT MGR HASSETT 416-1743 KLR | 8/19/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | up stair teacher lounge restroom (light fixture broken from the ceiling hanging). | 8/23/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | LIGHT FIXTURE IS HANGING IN TEACHERS' LOUNGE. PLANT MGR- HASSETT/416.5012 | 8/30/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | in room 15 have 2 ballet out | 9/10/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | A/C CAFE & RM 13-BOTH NOT COMING ON-PLANT MGR HASLETT 416-1743 KLR | 9/13/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | need 4 box flr lamp 4ft long 28/ watt | 10/25/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | main office clock need set. Also timmer outside light need reset. | 11/4/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | Check pumps that are tripped. and room 13 | 12/9/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | the clock on the main hall by the office, up stair hall clock. | 1/23/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | UNIT NOT COMING ON IN PRIN OFFICE, CONFERENCE RM PLANT MGR- JESSIE/626.4271 | 1/27/14 | | | Electrical |

| | | | | | |
|---------------------------|---|----------|--|--|---------------------------------------|
| Bethel Grove ES (2050) 2B | fir lamps | 8/6/13 | | | Electrical |
| Bethel Grove ES (2050) 2B | the cafe table need spraying! | 1/30/14 | | | Electrical |
| Bethel Grove ES (2050) 2B | A/C MAIN OFC AREA-NOT COMING ON-LEAD CUST BARTON 416-5012 KLR | 6/30/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Monthly - Filter-Bethel Grove Elementary - Refer to PM schedule details. | 10/25/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Monthly - Air Compressor-Bethel Grove Elem - Refer to PM schedule details. | 12/30/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Monthly - Air Compressor-Bethel Grove Elem - Refer to PM schedule details. | 7/1/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Monthly - Oil Lube & Belt-Bethel Grove Elementary - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | UNIT VENT IN RM 8 IS NOT COMING ON. SBE HASSLETT | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | UNIT IN RM 14 IS NOT COOLING. SBE HASSLETT | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | CHANGE FROM HEAT TO A/C REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------|--|----------|--|--|--|
| Bethel Grove ES (2050) 2B | UNIT NOT COOLING IN MAIN OFFICE PLANT MGR- HASLETT/416.4578 | 5/14/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | HEAT RM 24-MAKING NOISES-PLANT MGR HASLETT 416-1543 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | HEAT MAIN OFC & CUSTODIAL LOUNGE-BOTH NOT HEATING-PLANT MGR HASLETT 416-1743 KLR | 1/15/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | HEATING UNIT RM 27- MAKING LOUD NOISES- PLANT MGR HASLETT 416- 1743 KLR | 2/24/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | UV-1 RM 1, UV-2 RM 14, & UV- 1 RM 25-ALL NOT COOLING- SBE HASLETT 416-5012 KLR | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | 3-UV NOT HEATING IN RM- 11,12,8, & UV IS OVERHEATING (87)IN RM-7 PLANT MGR- HASLETT/416.5012 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | HEAT ANNEX BLDG (8)RMS 1- 10-NOT HEATING-PLANT MGR HASLETT 416-4578 KLR | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Yearly - Boiler # 031-Bethel Grove Elm - Refer to PM schedule details. | 3/3/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Monthly - Filter-Bethel Grove Elementary - Refer to PM schedule details. | 6/27/14 | | | Heating/Ventilation /Air Conditioning |
| Bethel Grove ES (2050) 2B | Monthly - Filter-Bethel Grove Elementary - Refer to PM schedule details. | 2/21/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------|--|----------|----------|--|----------|
| Bethel Grove ES (2050) 2B | boy restroom up stair sink pipe are leaking water. | 2/10/14 | | | Plumbing |
| Bethel Grove ES (2050) 2B | girl restroom on the second floor (one has a broken seat ,the other 2 toilet has pipe leak i have them turn off please come out asap) . Thank u | 4/23/14 | | | Plumbing |
| Bethel Grove ES (2050) 2B | the girl restroom up stair, sink has broken from the wall. | 12/16/13 | | | Plumbing |
| Bethel Grove ES (2050) 2B | SINK PIPE HAS BUSTED & WATER IS RUNNING IN B/RR 2ND FLR. PLANT MGR- HASLETT/416.5012 | 4/1/14 | | | Plumbing |
| Bethel Grove ES (2050) 2B | Per United the elevator pit needs to be pump/cleaned out and a new seal applied | 8/6/13 | Elevator | | Plumbing |
| Bethel Grove ES (2050) 2B | boy restroom on the blue hall, can't turn water off in the sank. | 9/13/13 | | | Plumbing |
| Bethel Grove ES (2050) 2B | IN THE KITCHEN SINK, THE PIPE ARE LEAKING BAD. | 10/15/13 | | | Plumbing |
| Bethel Grove ES (2050) 2B | toilet in the girl the keep run after flush | 10/16/13 | | | Plumbing |
| Bethel Grove ES (2050) 2B | The per k room 100, the sink clog and the toilet,flush handle is broken. | 12/3/13 | | | Plumbing |
| Bethel Grove ES (2050) 2B | There's a gas smell in the kitchen per Jessie Haslett, Plant Mgr. 416.1743 | 12/3/13 | | | Plumbing |

| | | | | | |
|---------------------------|--|----------|--|--|-------------|
| Bethel Grove ES (2050) 2B | Request back flow test. | 9/5/13 | | | Plumbing |
| Bethel Grove ES (2050) 2B | in the annex bldg has a bad leak in the girl restroom water is all over the floor. | 4/14/14 | | | Roof |
| Bethel Grove ES (2050) 2B | on the first floor by the boy restroom a very bad leak. | 7/23/13 | | | Roof |
| Bethel Grove ES (2050) 2B | roof drain need cleaning. | 3/19/14 | | | Roof |
| Bethel Grove ES (2050) 2B | on the first floor hall by the boy restroom has their a bad leak. | 5/9/14 | | | Roof |
| Bethel Grove ES (2050) 2B | the gutter and roof need cleaning because of leaves | 12/5/13 | | | Roof |
| Bethel Grove ES (2050) 2B | the corner wall by the office the metal has come . | 12/13/13 | | | Sheet Metal |
| Bethel Grove ES (2050) 2B | The fence around the play area has 2 very large hole in it . Department of health said this have to be fix. She was here 11/14/2013, she be back on the of 11/25/2013. | 11/18/13 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | |
|-----------------------|-----------|------------|------|----------|----------|------|-------------|
| Location | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| Brewster ES (2053) 2B | 16 | 29 | 30 | 2 | 42 | 1 | 120 |
| Grand Total | 16 | 29 | 30 | 2 | 42 | 1 | 120 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-----------------------|--|----------------|---------------------|------------------|-----------|
| Brewster ES (2053) 2B | handrail needs to repair | 5/7/14 | Hallway/Corridor | Music room | Carpentry |
| Brewster ES (2053) 2B | side door not closing went opening | 5/9/14 | 1st Floor | B wing Side door | Carpentry |
| Brewster ES (2053) 2B | Replace missing ceiling tiles | 1/22/14 | Cafeteria | kitchen | Carpentry |
| Brewster ES (2053) 2B | Make repairs to desk. | 2/7/14 | Administration Area | Guidance Office | Carpentry |
| Brewster ES (2053) 2B | per ms brunson 416-7150 room E210 the cylinder is broken and can't get into the room | 2/13/14 | | | Carpentry |
| Brewster ES (2053) 2B | Request to have broken door fix. (urgent) | 7/23/13 | Administration Area | Teacher Lounge | Carpentry |
| Brewster ES (2053) 2B | door broken | 7/24/13 | Classroom | Rm.E103 | Carpentry |
| Brewster ES (2053) 2B | Main entrance door broken (urgent) | 7/29/13 | Library | Library | Carpentry |
| Brewster ES (2053) 2B | Repair fence around the school (not security) | 7/29/13 | Grounds | Fence Areas | Carpentry |

| | | | | | |
|-----------------------|---|----------|---------------------|----------------|------------|
| Brewster ES (2053) 2B | Door broken can't security record. | 7/29/13 | Administration Area | Record room | Carpentry |
| Brewster ES (2053) 2B | stall needs to be replaced | 7/31/13 | Restroom (Boys) | Near A 200 | Carpentry |
| Brewster ES (2053) 2B | stall door needs to be replaced | 7/31/13 | Restroom (Girls) | near room A200 | Carpentry |
| Brewster ES (2053) 2B | ceiling leaking Falling tiles (Damage Urgent) | 8/14/13 | Classroom | Computer Lab | Carpentry |
| Brewster ES (2053) 2B | Repair locks on girl's restroom stall door | 8/14/13 | Restroom (Girls) | | Carpentry |
| Brewster ES (2053) 2B | Install bulletin board | 8/14/13 | Administration Area | Fin SEC | Carpentry |
| Brewster ES (2053) 2B | Sec. need a bulletin board install (URGENT) | 10/29/13 | Administration Area | See Fin. Sec | Carpentry |
| Brewster ES (2053) 2B | per Ms. Brunson 416-7150 no heat in cafeteria not coming on | 12/9/13 | | | Electrical |
| Brewster ES (2053) 2B | Needs a lift light out in both area | 12/18/13 | Cafeteria | Cafetorium | Electrical |
| Brewster ES (2053) 2B | HOT WATER TANK 2ND FLR CUST CLOSET FOR KITCHEN- KEEPS TRIPPING BREAKER PER SBE-PLANT MGR BRONSON 416-7150 KLR | 1/8/14 | | | Electrical |

| | | | | | |
|-----------------------|--|---------|---------------------|------------------------|------------|
| Brewster ES (2053) 2B | WATER TANK NOT RELEASING ANY HOT WATER IN KITCHEN. PLANT MGR- BRUNSON/277.8353 | 1/21/14 | | | Electrical |
| Brewster ES (2053) 2B | Request to have Master Clock reset | 1/21/14 | Administration Area | | Electrical |
| Brewster ES (2053) 2B | Replace broken clocks | 1/31/14 | Administration Area | See Plant Mgr. | Electrical |
| Brewster ES (2053) 2B | Emer. lights not working. | 2/6/14 | Hallway/Corridor | See Plant Mgr. | Electrical |
| Brewster ES (2053) 2B | Small heat fan not working | 2/6/14 | Hallway/Corridor | See Plant Mgr. | Electrical |
| Brewster ES (2053) 2B | Senor not working | 2/6/14 | Administration Area | near Plant Mgr. Office | Electrical |
| Brewster ES (2053) 2B | Clock not working (MAIN HALL) | 2/19/14 | Administration Area | See Plant Mgr. | Electrical |
| Brewster ES (2053) 2B | light out in room X3 | 2/21/14 | Classroom | Room E 210 | Electrical |
| Brewster ES (2053) 2B | needs 3 boxes each for both school Brewster & Springdale Elementary | 2/24/14 | Custodial | See Plant Mgr. | Electrical |
| Brewster ES (2053) 2B | Light out X3 | 3/4/14 | Hallway/Corridor | A 109, A 108, A 103 | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|---------------------|------------|
| Brewster ES (2053) 2B | Heating in hallway near back door KK hall won't cut off. | 4/4/14 | Hallway/Corridor | See Plant Mgr. | Electrical |
| Brewster ES (2053) 2B | UNIT NOT COMING ON IN LIBRARY. PLANT MGR-BRUNSON/416- 7150 | 7/29/13 | | | Electrical |
| Brewster ES (2053) 2B | Outlet not working (microphone amp) | 8/2/13 | Cafetorium | Closet | Electrical |
| Brewster ES (2053) 2B | Need bucket truck outside light out and paragon clock set | 8/2/13 | Administration Area | See Plant Manager | Electrical |
| Brewster ES (2053) 2B | light out in hallway near restroom (very Dark) | 8/14/13 | Hallway/Corridor | 1st floor | Electrical |
| Brewster ES (2053) 2B | near room w211 | 8/14/13 | Hallway/Corridor | 2nd floor | Electrical |
| Brewster ES (2053) 2B | Request for portable lift light out very dark down only 1 light working(URGENT) | 8/27/13 | Hallway/Corridor | Main Entrance Lobby | Electrical |
| Brewster ES (2053) 2B | a/c not working at all in kitchen per Pegues 416-7150 | 9/16/13 | | | Electrical |
| Brewster ES (2053) 2B | repair ground light | 9/26/13 | Grounds | near flag pole | Electrical |
| Brewster ES (2053) 2B | Electronic door not working main entrance and Cafeteria door | 10/1/13 | Hallway/Corridor | See Mgr. | Electrical |

| | | | | | | |
|-----------------------|---|----------|---------------------|------------------------|--|---------------------------------------|
| Brewster ES (2053) 2B | LIGHTS are going ON & OFF in the CAFETERIA per Ms. Brunson, Plant Mgr. 416.7150 | 10/2/13 | | | | Electrical |
| Brewster ES (2053) 2B | needs 3 boxes of bulb | 10/29/13 | Custodial | See Plant Manager | | Electrical |
| Brewster ES (2053) 2B | Light out (URENT) | 11/7/13 | Classroom | A119, A109, A105, A104 | | Electrical |
| Brewster ES (2053) 2B | Reset outside light(timer) parking lot light set to go out to early very very dark on Campus(URGENT) Safety Issue | 11/19/13 | Parking Lot | See Mgr. | | Electrical |
| Brewster ES (2053) 2B | Exhaust fan not working and a gas leak | 11/21/13 | Kitchen | See Cafe Mgr. | | Electrical |
| Brewster ES (2053) 2B | hood vent not working | 2/11/14 | Kitchen | See Mgr. | | Electrical |
| Brewster ES (2053) 2B | per ms brunson 416-7150 a/c in main office and cafeteria are blowing hot | 5/6/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | HEAT PE OFC-NOT COMING ON- PLANT MGR 416-7150 KLR | 12/5/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | A/C MAIN OFC-NOT COOLING- PLANT MGR BRUNSON 416-7158 KLR | 5/27/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | air handled 8 & 9 not working | 5/12/14 | Administration Area | Main Office | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|---|---------|---------------------|----------------|--|---------------------------------------|
| Brewster ES (2053) 2B | UNIT NOT HEATING IN GUIDANCE OFFICE PLANT MGR- BRUNSON/416.4883 | 1/10/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | per Ms. Brunson 416-7150 no heat in cafeteria | 1/27/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | per ms brunson 416-7150 there is no heat in kitchen blowing cold | 2/10/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | UNIT in ROOM E206 is NOT HEATING per Ms. Brunson, Plant Mgr. 416.7150 | 2/13/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | repair ah#8 | 4/2/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Prin. request for emer. HVAC change over (UGRENT) | 4/3/14 | Administration Area | See Plant Mgr. | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | 3-UV NOT COOLING IN RM-A100(088) RM-A103(041) RM-B101(046). SBE-BRUNSON/416-7150 | 7/23/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | UV NOT COOLING IN RM-E212(109), & UNIT IN LIBRARY. SBE-BRUNSON/416-4883 | 7/24/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | CHILLER IS NOT COMING ON. SBE BRUNSON 416-7150 | 7/29/13 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|--|----------|---------------------|----------------|--|---------------------------------------|
| Brewster ES (2053) 2B | W212 id041138 and A103 id041091 not cooling per Ms. Brunson 416-7150 | 7/30/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | UV NOT COOLING IN RM-E213(111), & AHU#8 GUIDANCE OFFICE(041) PLANT MGR-BRUNSON/416.7150 | 8/19/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | UNIT NOT COOLING IN CAFE, & GUIDANCE OFFICE PLANT MGR-BRUNSON/416.7150 | 8/26/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | 4-UV NOT COOLING IN RM-A106, A103,W204,W106 PLANT MGR-BRUNSON/416.7150 | 8/28/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Monthly - Oil Lube & Belt-Brewster Elem - Refer to PM schedule details. | 9/20/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Ready for change over (HEAT) | 11/5/13 | Administration Area | See Plant Mgr. | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | UNIT IS OVERHEATING (79) IN LIBRARY. PLANT MGR-BRUNSON/416.7150 | 11/7/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | HEAT RM A106-NOT HEATING- PLANT MGR BRONSON 416-7150 KLR | 11/13/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | HEAT LIBRARY-OVERHEATING, TEMP IS 78 PER SBE-PLANT MGR BRONSON 416-7150 KLR | 11/13/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | UNIT NOT HEATING IN CAFE. PLANT MGR-BRUNSON/416.4883 | 11/13/13 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|---|----------|---------------------|-----------------|--|---------------------------------------|
| Brewster ES (2053) 2B | HEAT PRIN'S OFC, CAFE, & RM B106-ALL NOT HEATING-PLANT MGR BRUNSON KLR | 11/25/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Unit is NOT HEATING in the CAFETERIA per Ms. Brunson, Plant Mgr. 416.7150 | 12/2/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Monthly - Oil Lube & Belt-Brewster Elem - Refer to PM schedule details. | 4/25/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Monthly - Filter-Brewster Elementary - Refer to PM schedule details. | 5/10/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Monthly - Filter-Brewster Elementary - Refer to PM schedule details. | 1/11/14 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Monthly - Filter-Brewster Elementary - Refer to PM schedule details. | 9/7/13 | | | | Heating/Ventilation /Air Conditioning |
| Brewster ES (2053) 2B | Room W106F patch and paint damaged sheetrock wall. | 2/11/14 | Administration Area | Guidance Office | | Painting |
| Brewster ES (2053) 2B | Put a clear finish on plywood shelving see Mike Carmony. | 2/11/14 | | | | Painting |
| Brewster ES (2053) 2B | urnial stopped up | 1/9/14 | Restroom (Boys) | 2nd floor | | Plumbing |
| Brewster ES (2053) 2B | Hand sink runnig dirty water | 1/16/14 | Kitchen | See Cafe Mgr | | Plumbing |

| | | | | | |
|-----------------------|--|---------|---------------------|---------------------------|----------|
| Brewster ES (2053) 2B | HOT WATER TANK has STOPPED WORKING (located in the Maintenance Closet on the 2nd Floor) per Ms. Brunson, Plant Mgr. 416.7150 | 1/16/14 | | | Plumbing |
| Brewster ES (2053) 2B | urnial stopped up | 1/22/14 | Restroom (Boys) | 1st & 2nd Floor | Plumbing |
| Brewster ES (2053) 2B | WATER TANK WONT STAY ON IN KITCHEN 2ND FLR. PLANT MGR- BRUNSON/277.8353 | 1/23/14 | | | Plumbing |
| Brewster ES (2053) 2B | Reset water heater tank (too hot) Student hand sink | 2/3/14 | Kitchen | See MGr. | Plumbing |
| Brewster ES (2053) 2B | HOT WATER TANK FOR KITCHEN AREA-NOT COMING ON-NO HOT WATER TO KITCHEN-PLANT MGR BRONSON 416-7150 KLR | 2/5/14 | | | Plumbing |
| Brewster ES (2053) 2B | toilet not working water not coming on | 3/6/14 | Restroom (Girls) | near room W 210 | Plumbing |
| Brewster ES (2053) 2B | per ms brunson 416-7150 2nd floor girls restroom there is a toilet that is overflowing and can't shut off | 3/19/14 | | | Plumbing |
| Brewster ES (2053) 2B | Sink stopped (urgent) | 3/21/14 | Administration Area | Teacher Lounge | Plumbing |
| Brewster ES (2053) 2B | INSIDE PIPE is LEAKING behind the URINAL in the BOY'S RR on the 1ST GRADE HALL per Ms. Brunson, Plant Mgr. 416.7150 | 4/10/14 | | | Plumbing |
| Brewster ES (2053) 2B | toilet broken | 4/22/14 | Administration Area | Teacher planner near W111 | Plumbing |

| | | | | | | |
|-----------------------|---|---------|------------------|-------------------|--|----------|
| Brewster ES (2053) 2B | COMMODE IN THE TEACHER LOUNGE IS BROKEN AND THE COMMODE IS CONSTANTLY RUNNING. SBE BRUNSON 416- | 7/23/13 | | | | Plumbing |
| Brewster ES (2053) 2B | COMMODE IN GIRLS RSTRM NEAR A12 IS CONSTANTLY RUNNING (SCARED IT MIGHT OVERFLOW). SBE BRUNSON 416- | 7/24/13 | | | | Plumbing |
| Brewster ES (2053) 2B | COMMODE G RR 2ND FLR- CONSTANTLY RUNNING & LEAKING WATER OUT PER SBE- PLANT MGR 416-7150 KLR | 8/22/13 | | | | Plumbing |
| Brewster ES (2053) 2B | Pipe leaking (ceiling tile falling) | 8/2/13 | Classroom | A100 computer lab | | Plumbing |
| Brewster ES (2053) 2B | pipe leaking | 8/2/13 | Portables | 2nd floor | | Plumbing |
| Brewster ES (2053) 2B | pipe leaking | 8/2/13 | Restroom (Girls) | | | Plumbing |
| Brewster ES (2053) 2B | (URGENT) toilet won't stop running. | 8/8/13 | Restroom (Girls) | 2nd floor | | Plumbing |
| Brewster ES (2053) 2B | URGENT pipe leaking from sink | 8/8/13 | Hallway/Corridor | 2nd floor | | Plumbing |
| Brewster ES (2053) 2B | A/C IN RM A109-LEAKING-SBE BRONSON 416-7050 KLR | 8/14/13 | | | | Plumbing |
| Brewster ES (2053) 2B | urinal leaking from wall | 8/22/13 | Restroom (Boys) | 1st floor | | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------------|------------|----------|
| Brewster ES (2053) 2B | sink leaking (URGENT) | 8/23/13 | Restroom (Boys) | 2nd floor | Plumbing |
| Brewster ES (2053) 2B | toilet running sink leaking (URGENT) | 8/23/13 | Restroom (Girls) | 2nd floor | Plumbing |
| Brewster ES (2053) 2B | There is a ceiling leak in cafe mgr's office that happens after a/c is worked on per Ms. Brunson 416-7150 | 9/9/13 | | | Plumbing |
| Brewster ES (2053) 2B | water cooler leaking | 9/24/13 | Hallway/Corridor | w106 | Plumbing |
| Brewster ES (2053) 2B | Water cooler leaking, urnial stopped up and urnial leaking from wall. URGENT) | 9/25/13 | Restroom (Girls) | near A 109 | Plumbing |
| Brewster ES (2053) 2B | SOMETHING IN THE MECH RM 2ND FLR IS LEAKING AND FLOODING THE AREA AND LEAKING DOWN INTO THE 1ST FLR CAFE PER SBE-PLANT MGR BRONSON 416-7150 KLR | 9/25/13 | | | Plumbing |
| Brewster ES (2053) 2B | Leaks on toilet handicap. | 10/3/13 | 2nd Floor | Girls RR | Plumbing |
| Brewster ES (2053) 2B | Toilet leaking. | 10/3/13 | 2nd Floor | Boys RR | Plumbing |
| Brewster ES (2053) 2B | toilet not working | 10/7/13 | Restroom (Girls) | nea A 106 | Plumbing |
| Brewster ES (2053) 2B | urnial stopped up | 10/7/13 | Restroom (Boys) | w208 | Plumbing |

| | | | | | |
|-----------------------|--|----------|------------------|---------------------|----------|
| Brewster ES (2053) 2B | pipe broken | 10/14/13 | Restroom (Girls) | | Plumbing |
| Brewster ES (2053) 2B | sink leaking X2 (URGENT) Can't turn water off | 10/22/13 | Restroom (Girls) | Near Teacher Lounge | Plumbing |
| Brewster ES (2053) 2B | Test and repair RP Devices per MLG&W. | 10/31/13 | Mechanical Room | | Plumbing |
| Brewster ES (2053) 2B | Grease trap needs to empty | 11/8/13 | Kitchen | See Cafe Mgr. | Plumbing |
| Brewster ES (2053) 2B | Check drains in Kitchen | 11/8/13 | Kitchen | See Mgr. | Plumbing |
| Brewster ES (2053) 2B | toilet broken | 11/8/13 | Restroom (Girls) | near A111 | Plumbing |
| Brewster ES (2053) 2B | CEILING PIPE FROM UNIT IS LEAKING WATER IN KITCHEN. PLANT MGR- BRUNSON/416.7150 | 11/11/13 | | | Plumbing |
| Brewster ES (2053) 2B | NO HOT IN KITCHEN. PLANT MGR- BRUNSON/416.7150 | 11/14/13 | | | Plumbing |
| Brewster ES (2053) 2B | GAS LEAK IN KITCHEN - PM/BRUNSON 416-7150 | 11/22/13 | | | Plumbing |
| Brewster ES (2053) 2B | WATER HEATER FOR KITCHEN AREA-NOT COMING ON-NO HOT WATER TO KITCHEN- PLANT MGR BRUNSON KLR | 11/25/13 | | | Plumbing |

| | | | | | |
|-----------------------|---|---------|---------|-----------|------|
| Brewster ES (2053) 2B | ceiling tile falling (leaking ceiling) | 9/24/13 | Kitchen | near sink | Roof |
|-----------------------|---|---------|---------|-----------|------|

| Count of Craft | Craft | | | | | | | | |
|------------------------------------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Central Nutrition Ctr-OPS (8407) 2 | 3 | 24 | 53 | 26 | 7 | 40 | 2 | 6 | 161 |
| Grand Total | 3 | 24 | 53 | 26 | 7 | 40 | 2 | 6 | 161 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|--|--|----------------|---------------------|---------------|-----------|
| Central Nutrition Ctr-OPS (8407) 2B | Assessment of new equipment being installed which may need network or low voltage cabling, provide project management if needed. Contact Charity Williams (416-3992). (Request Network Cabling Project Management). | 8/1/13 | | | Cabling |
| Central Nutrition Ctr-OPS (8407) 2B | Need new drop installed for the new freezer/refrigeration temperature controls system. Gregory Holloway will work with the District personnel who comes out the assesd the order. | 3/24/14 | Administration Area | | Cabling |
| Central Nutrition Ctr-OPS (8407) 2B | Need new data drop for telephone installation in the front training area. Contact: Roderick Hill 416-1236 | 1/28/14 | Classroom | Training Room | Cabling |
| Central Nutrition Ctr-OPS (8407) 2B | Need ladder fixed that gives access to roof. It is unsafe, the anachors are coming out of the wall. | 5/21/14 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | pour concrete pad for transformer | 2/4/14 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry/Welder(Mr. Lonnie Grimes),to replace,lid,on #8,dumpster,in roll-up door#14,shipping dock... | 7/18/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop, to re-alinge door to restroom on mezzine floor upstairs..... | 8/27/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | PANIC BAR DOOR IS LOOSE, CANT SECURE NORTH FREEZER DOOR PLANT MGR-HINES/416.550 | 9/16/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop,to fix (TWO) sets of double doors,first set located to washware room,next to bakery,second set,is back entrance to fresh produce room doors can not be secured... | 9/16/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop,to re-alinge,admin.bldg.north-east door,entering admin. off.guard shack parking lot... | 8/13/13 | | | Carpentry |

| | | | | | |
|--|--|----------|-----------|--|-----------|
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop,to fix (second) set of double doors leading into Sandwich prep. area,doors can not be secured... | 8/9/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop, to replace door, to washware room,entering from shipping dock,door hit by forklift,knocked off hinges... | 10/15/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | ENTRANCE DOOR LEADING TO DOCK AREA-PANIC BAR BROKEN-WON'T BE ABLE TO SECURE-CALLED IN BY J CRUTHIRDS 416-5550 KLR | 11/18/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry,shop,to repair hole in wall between window frame and wall,wasp and other pest are entering office area.Please! See Ms. Alexis Caston Mgr. | 11/1/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop, to repair hole,in wall,accounting office,Please! see Ms.Jeanette Hunt-Mgr. | 11/1/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Carpentry shop, to repair hole,in wall,Please! see Ms. Anita Hays,Accounting Supervisor | 11/1/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need new door closer for double doors in meat slicing area. part of closer have come off and cannot find. | 3/24/14 | Cafeteria | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need carpentry shop to repair doors into meat slicing area. Doors will not close by themselves. | 3/7/14 | Cafeteria | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Self closures on the entrance door is broken. | 2/18/14 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Exterior Entrance doors on southwest side need repairing | 2/26/14 | Cafeteria | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Metal molding on the wall is damaged and prevents the door from closing. | 4/25/14 | | | Carpentry |

| | | | | | |
|--|--|---------|---------|--------------------------------|------------|
| Central Nutrition Ctr-OPS (8407) 2B | Handicap stall in ladies room doesn't lock. | 5/2/14 | | Ladies RestroomH | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | HANDICAP RAIL IS OFF THE WALL IN LADIES/RR EMPLOYEE LUNCH RM HALL PLANT MGR-HINES/416.5550 | 8/27/13 | | | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Repair large cracks in hallway floor. | 4/14/14 | | Near shipping office | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Double doors to food processing area are off track. | 4/14/14 | | Food processing area | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Both rooms salad prep rm. and ingredient rm. metal plates inside coolers are coming up and causing tripping. | 4/14/14 | | Salad prep and ingredient room | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Repair 2 holes in wall. | 4/14/14 | | Salad prep room | Carpentry |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,to fix (12) , lights out on production hallway... | 9/5/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to fix (14) light fixtures on main hallway also Directors office,southeast end of main hallway... | 9/5/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,to replace ballast in light fixture,located in copy room storage room,on main hallway... | 9/9/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need fire alarm systems,to replace pull down station,and connecting conduit on wall,hit by forklift,location outboard freezer northend door... | 9/16/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | 200 Amp. main tripped in catering, can't reset.Mike Smith called Jim Davis direct. | 9/17/13 | Kitchen | | Electrical |

| | | | | | |
|--|--|---------|--|--|------------|
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to fix garbage disposal,not working,located in catering dept... | 9/19/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to install two (2) air-line drops (3/8" in Cook/Chill area for new pump stations(See Mr. Michael Smith) | 9/19/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,(ASAP),need to run voltage,for new chemical dispenser,in washware room,(Please! See Mr.Jim Cruthirds) | 8/13/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric Shop, to fix (10),metal halide lights,six in dry goods,2 in warehouse(E),two out in warehouse H | 8/16/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,to fix lights,in walk-in cooler,located in Sandwich prep. area... | 7/3/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric Shop, to repair (three),metal halide lights,in warehouse drive-in cooler... | 7/3/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | NO IN THE REAR OF THE BLDG. FAC. SUP. 416-5560 | 7/15/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | 3 metal halide lights out in outboard freezer per Mike Hines 416-5550 | 7/23/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,to repair lights out in warehouse forklift and jack maintenance area... | 7/26/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,to change out ballast,on stage in Cook/Chill dept.(new bulbs already installed), Mr. Joe King-Production Mgr.,will coordinate timing,of work... | 8/7/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to install (TWO) recepticals,for new temperture monitoring system,one outside ingredient room,on end of northwest hall under monitor,and one on northeast end wall under monitor,between cheese cooler and computer wiring room... | 8/23/13 | | | Electrical |

| | | | | | |
|--|---|----------|---------------------|------------------|------------|
| Central Nutrition Ctr-OPS (8407) 2B | No lights in the entire warehouse area. Per Jim Curthirds | 9/24/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to reset breaker box (LK) in warehouse staging area, lights out, in warehouse. - Completed..... | 9/25/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to hook-up 220 plug, for Tenn. Belting Co. station-outside bakery... | 10/9/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to fix (two) light fixtures in warehouse outboard freezer, both lights out... | 10/11/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to replace light bulbs and ballasts (8) fixtures, in Meat Processing room area (20') ceiling... | 10/23/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop, to fix exhaust fan in Catering dept. not running... | 11/13/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Lights and equipment out/no power (Mike Martin @ 7:26am). | 11/11/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | BREAKER- IN THE WAREHOUSE - ON GRL PANEL KEEPS TRIPPING - JIM CRUTHIRDS 416-5550 | 10/28/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | No POWER in the SHIPPING DOCK area per Ms. Boykins, Plant Mgr. 416.5550 | 4/7/14 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need electrician to wire up new cardboard baler machine will be next to the old machine. | 3/24/14 | Administration Area | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need 6 ballast changed in ceiling. | 3/31/14 | Hallway/Corridor | next to catering | Electrical |

| | | | | | |
|--|--|---------|---------------------|----------------------|------------|
| Central Nutrition Ctr-OPS (8407) 2B | :Cold Assembly department the overhead lights aren't working properly causing the room to be too dim. | 4/1/14 | | meat processing room | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need electrician to repair 5 light fixtures in catering area. See Mike Martin if any questions | 3/7/14 | Cafeteria | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Change out 3 phase 4 wire 200 amp. 250 volt panel gut, the existing one is damaged where the main breaker attaches to the buss. Per Master Elect. K Carter | 3/11/14 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | 4-BREAKER BOXES ARE TRIPPING IN PANEL HO PLANT MGR-MIKE/647.3732 | 3/12/14 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need electrician to repair 24volt. light switches in hallway outside of catering. switch get "Hot" and turn off on their own. and you have to let them cool & turn them back on. | 3/19/14 | Cafeteria | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electrician to repair 3 lights in catering | 3/19/14 | Cafeteria | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need loading dock lights repaired. most if the lights are out | 3/24/14 | Administration Area | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | (6) Warehouse ceiling lights out. High Bays by the panel | 2/5/14 | 1st Floor | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Lights out on the stairway by Joe Kings office | 2/5/14 | 2nd Floor | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Bakery/Scaling Area Bulb Needed in the ceiling | 2/13/14 | Cafeteria | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Rows of overhead lights are blown out. Ceiling vents are dusty | 2/18/14 | Kitchen | | Electrical |

| | | | | | |
|--|--|---------|------------------|---|------------|
| Central Nutrition Ctr-OPS (8407) 2B | Electrical Covers missing off outlets in the Sald Room. Covers need to be replaced | 2/18/14 | Kitchen | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Tie in new charger into sub- charging panel outside the Bakery. | 2/27/14 | Cafeteria | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Repair light prongs in ladies restroom. | 4/21/14 | Restroom (Girls) | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Repair light prongs inside cooler | 4/21/14 | | Meat slicing room | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Install light for employees computer lab. | 4/24/14 | Hallway/Corridor | small computer lab across from SBE office | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | A/C UNIT is NOT COMING ON in the FRONT LOBBY and UPSTAIRS CENTRAL OFFICES per Ms. Boykins, Plant Mgr. 416.5550 | 4/25/14 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | per ms boykins 416-5550 there is no power to the RTU #4 | 5/7/14 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Install new outlet in bakery for pump machine.(Mike Martin has the parts.) | 6/26/14 | | Bakery | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Blown Ballast | 5/21/14 | | Ladies restroom near the front breakroom | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | I need 3 cases of fluorescent light bulbs. Bulbs #F28T8/XLSPX4/ECO 36 bulbs to each case. | 6/4/14 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Partial power outage. | 6/6/14 | | | Electrical |

| | | | | | |
|-------------------------------------|--|---------|-----------|--------------|---------------------------------------|
| Central Nutrition Ctr-OPS (8407) 2B | Nearly have the lights out could be a circuit breaker tripped. | 6/16/14 | Library | Admin. Bldg. | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need electrician to replace boxes and wiring in freezer for pull station hit by fork lift. | 9/23/13 | | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electrician to repair 5 light fixtures in catering area. See Mike Martin | 3/7/14 | Cafeteria | | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | New baller need to be wired. CNC/ Production | 5/2/14 | | Baller room | Electrical |
| Central Nutrition Ctr-OPS (8407) 2B | UNITS NOT COOLING IN MAIN LOBBY, UPSTAIR CENTRAL OFFIICE, CENTRAL KITCHEN PLANT MGR-BOYKINS/416.5550 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | replace washroom a/c. RTU #11 | 6/18/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Oil Lube & Belt-Nutrition Servs Ctr - Refer to PM schedule details. | 3/4/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | need rooftop units R.T.U. & RTU #11 repaired. units turned in 1-21-14. and units are still out. Ticket 410088. | 3/24/14 | Cafeteria | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | RTU#33 NOT COOLING IN WHSE-STORAGE AREA(106). PLANT MGR-HINES/416.5550 | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | RTU-2 CATERING KITCHEN-NOT COOLING-PLANT MGR HINES 416-5550 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--|---|---------|-----------------|--|--|
| Central Nutrition Ctr-OPS (8407) 2B | RTU#5 NOT COOLING INGREDIENT OFFICE PLANT MGR-HINN/416.5550 | 8/22/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | RTU-9 & RTU-10 BAKERY AREA-BOTH NOT COOLING-PLANT MGR 416-5550 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | RTU-2 ZONE 2 CATERING KITCHEN- NOT COOLING-SBE HINES 416-5550 KLR | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Roof top units not cooling #38 disposable area, #39 storage cage 1, #40 storage cage 2, #41 storage cage 3 per Michael Hines 416-5550 | 8/27/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Air Comp-West Ground by Ice Bldr-CNC - Refer to PM schedule details. | 9/2/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Air Comp-West Ground by Ice Bldr-CNC - Refer to PM schedule details. | 9/2/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Need H.V.A.C., to fix R.T.U.-2, I.D.#407- 110, not (COOLING)... | 7/10/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Rooftop Unit #2 ID#407-110 NOT COOLING per Mike Hines, Plant Mgr. at 901.416.5550. | 7/11/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | getting boiler ready for inspection | 7/22/13 | Mechanical Room | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Dry goods pulling area Roof top unit 31 - ID#407090 32 - ID# 407097 33 - ID# 407098 35 - ID# 407099 not cooling per Mike Hines 416-5550 | 7/23/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | HEAT MAIN OFC AREA-NOT HEATING- CALLED IN BY J CRUTHIRDS 416-5550 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--|---|----------|--|--|--|
| Central Nutrition Ctr-OPS (8407) 2B | RTU-11 DISHRM & RTU-1 MAIN OFC AREA-BOTH NOT HEATING-PLANT MGR MARTIN 416-5550 KLR | 1/21/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Need H.V.A.C. shop, to replace,old thermostats,with new ones,old thermostats,not working,no display,won't activate heat... | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Need H.V.A.C. shop, to replace thermostats on R.T.U's numbers 9.11.and 19.in reference to w.o.i.d.-396906 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Filter-Nutrition Servs Ctr - Refer to PM schedule details. | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Air Comp-West Ground by Ice Bldr-CNC - Refer to PM schedule details. | 3/3/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Air Comp-West Ground by Ice Bldr-CNC - Refer to PM schedule details. | 3/3/14 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Filter-Nutrition Servs Ctr - Refer to PM schedule details. | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Monthly - Filter-Nutrition Servs Ctr - Refer to PM schedule details. | 12/23/13 | | | Heating/Ventilation /Air Conditioning |
| Central Nutrition Ctr-OPS (8407) 2B | Need Paint shop, to reline,parking lots,front / back lots,parking spaces... | 11/5/13 | | | Painting |
| Central Nutrition Ctr-OPS (8407) 2B | Need Paint shop, to scrape, and paint hallway outside,I.T. new office due to health dept .request. | 11/13/13 | | | Painting |
| Central Nutrition Ctr-OPS (8407) 2B | Need Paint shop,to paint main hallway and patch walls. | 11/13/13 | | | Painting |

| | | | | | |
|--|--|---------|------------------|---------------|----------|
| Central Nutrition Ctr-OPS (8407) 2B | Walls need to be painted. | 5/1/14 | | Dish room | Painting |
| Central Nutrition Ctr-OPS (8407) 2B | Paint last 4 offices on the front west side of the building | 5/16/14 | | Front Offices | Painting |
| Central Nutrition Ctr-OPS (8407) 2B | Need Paint shop, to repair wall, in office of Mr. Mike Esposito, located on main hallway... | 10/2/13 | | | Painting |
| Central Nutrition Ctr-OPS (8407) 2B | Need Paint shop, to paint, new network specialist office next to boiler room, (See Mr. Mike Esposito)... | 11/5/13 | | | Painting |
| Central Nutrition Ctr-OPS (8407) 2B | Drain stopped up in the Baler Room (roll up door 14) per Michael Hines 416-5550 | 8/27/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Large Flow Drain is stopped up in the wash ware room by double doors per Mike Hines 416-5550 | 9/3/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | check site glass blow down valve boiler #2 (id# 407008) site glass leaking per Mike Hines 416-5550 | 9/3/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Check out irrigation system , water running into parking lot. | 9/5/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | 3-COMPARTMENT SINK WASH/WEAR RM-HOT WATER SIDE CONSTANTLY RUNNING AT FULL FORCE, CAN'T CUT OFF PER SBE-PLANT MGR HINES 416-5550 KLR | 9/9/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Urinal, water running continuously won't cut off. | 9/12/13 | Hallway/Corridor | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need Plumber shop, to repair busted pvc pipe on main valve of irrigation system, water flooding parking lot, on eastside of guard shack... | 9/19/13 | | | Plumbing |

| | | | | | |
|--|--|----------|--|--|----------|
| Central Nutrition Ctr-OPS (8407) 2B | Need Plumber shop, to stop drain leak, on single compartment sink, in Ingredient room... | 9/20/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need Plumber shop, to fix broken vacuum breaker, on three compartment sink, located in washware room... | 8/1/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Large Floor drain in wash ware room stopped up (the one in front of the pressure washer) per Mike Hines 416-5550 | 8/19/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | FLR DRAIN IS STOPPED UP IN MEAT RM PLANT MGR-HINN/550.7769 | 8/19/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Test and/or repair RP devices per MLGW. | 8/21/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Assist with installation of water heater | 9/26/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need Plumber shop, to fix broken drain pipe on tempering box located in Meat processing room... | 10/9/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Install backflow preventer for hoop house | 10/14/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | per mike hines 416-5550 the feed water tank on boilers has loud water hammering sound and went from 200 to 140 | 11/14/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Winterize RP device . | 11/22/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need six toilet seats deliever to Mike Martin. | 12/10/13 | | | Plumbing |

| | | | | | |
|--|---|----------|-----------|--|----------|
| Central Nutrition Ctr-OPS (8407) 2B | FLR DRAIN IS BACKING IN CATERING AREA PLANT MGR-MICHAEL/416.5550 | 12/20/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need Plumber shop, to fix leaking faucet on (two) compartment sink, located on main hallway, in test kitchen... | 11/11/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | RUNNING WATER IN 3-COM SINK, CANT CONTROL IN WAS WEAR RM. PLANT MGR-HINES/416.5550 | 11/11/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | FLR DRAIN BY 3-COM SINK IS STOPPED UP IN WASH-WEAR RM PLANT MGR-HINES/416.5550 | 10/30/13 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Disposal stopped up in Dish room. | 1/13/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Ware washing Floor Drainage The floor drainage in the Ware washing (dish room) is clogged up on the west side, per R. Johnson. | 1/30/14 | Kitchen | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Hot water tank in warehouse not working. Tank take care of kitchen and restrooms. The tank is leaking | 2/10/14 | Custodial | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | DISPOSAL WARE WASHING RM- STOPPED UP-CALLED IN BY A WRIGHT 416-5580 KLR NOTE: PLUMBER ON SITE | 2/13/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Cook-chill (Floor Area) Per J. Wilkes, the hand sink is lose and the faucet handles need adjusting. Sink continues to leak. | 2/14/14 | Kitchen | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Hand sink by the first Meri Pak is leaking and has be cited as a health violation and needs to be repaired. | 2/18/14 | Kitchen | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need plumber to fix urinal's in men's restroom in warehouse next to the break room. See Mike Martin | 2/20/14 | | | Plumbing |

| | | | | | |
|--|--|---------|-----------------|---------------------------|----------|
| Central Nutrition Ctr-OPS (8407) 2B | Water Facet not working properly continuous to drip - drip in the Salad Room at handwash station | 2/26/14 | Cafeteria | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Water faucet not working properly continuous to drip - drip. two compartment sink in Salad Room. | 2/26/14 | Cafeteria | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | SINK BAILER RM-STOPPED UP-PLANT MGR BOYKINS 416-5550 KLR | 4/24/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | SINKS are CLOTTED in MEAT SLICING ROOM AND DISH ROOM; FAUCET is SPRAYING in the SALAD ROOM per Ms. Boykins, Plant Mgr. 416.5550 | 4/25/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | DISPOSAL & 3-COMPARTMENT SINK DISH RM AREA-BOTH ARE STOPPED UP-PLANT MGR BOYKINS 416-5550 KLR | 4/30/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Urinals not flushing.(sensor has stop working) | 5/1/14 | Restroom (Boys) | Warehouse men restroom | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Ladies 1st. stall toilet won't flush. (sensor has stop working.) | 5/1/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Need plumber to fix water pressure problem on the roof. | 5/27/14 | | Roof | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Replace faucet that has been trashed. | 5/28/14 | | Break room by catering | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | per ms boykins 416-5550 the cheese cooler is pouring water | 4/14/14 | | | Plumbing |
| Central Nutrition Ctr-OPS (8407) 2B | Reprogram the sprinklers for the yard | 6/19/14 | | outside | Plumbing |

| | | | | | |
|--|---|----------|---------------------|------------------|-------------|
| Central Nutrition Ctr-OPS (8407) 2B | d roof shop.,to fix leaks.in test kitchen,in front of two compartment sink,also ceiling leak,in men's restroom,both areas,on main hallway... | 7/22/13 | | | Roof |
| Central Nutrition Ctr-OPS (8407) 2B | Roof leaking in cook chill ingredient office. | 4/4/14 | | Manager's office | Roof |
| Central Nutrition Ctr-OPS (8407) 2B | install corners on door frames in office area | 11/11/13 | | | Sheet Metal |
| Central Nutrition Ctr-OPS (8407) 2B | Make cover to protect water service from freezing. | 11/1/13 | | | Sheet Metal |
| Central Nutrition Ctr-OPS (8407) 2B | Need sheet metal worker to make six pieces at rain flashing for outside racks to keep new monitors dry. see Mike Martin | 3/24/14 | Administration Area | | Sheet Metal |
| Central Nutrition Ctr-OPS (8407) 2B | Need 4 strips od stainless steel broken up so I can repair door way in freezer,I will get measurments to Gary as soon as possible. | 5/2/14 | | | Sheet Metal |
| Central Nutrition Ctr-OPS (8407) 2B | Make 10 pcs of s.s. angle. to repair tempering boxes. Thanks Mike Martin | 5/7/14 | | | Sheet Metal |
| Central Nutrition Ctr-OPS (8407) 2B | Need Electric shop,and Sheet metal shop,to check installation,of new dryer,in washware laundry room,due to fire in dryer...also venting systems... | 10/23/13 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|-----------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Cherokee ES (2100) 2B | 4 | 2 | 30 | 65 | 50 | 5 | 49 | 12 | 2 | 219 |
| Grand Total | 4 | 2 | 30 | 65 | 50 | 5 | 49 | 12 | 2 | 219 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-----------------------|--|----------------|---------------------|----------------|-----------|
| Cherokee ES (2100) 2B | I need shade installed, the sun light is blocking the read of the boiler log. | 11/12/13 | Mechanical Room | window | Asbestos |
| Cherokee ES (2100) 2B | The pipe insulation have a hole in it, and mices are coming in though the hole. | 11/14/13 | Kitchen | | Asbestos |
| Cherokee ES (2100) 2B | The pipe insulation has a hole in it. | 9/24/13 | Hallway/Corridor | by room 148 | Asbestos |
| Cherokee ES (2100) 2B | The pipe insulation is crackly, and this is a kindergarden classroom were they sit at on the rug. | 11/1/13 | Classroom | 154 | Asbestos |
| Cherokee ES (2100) 2B | I need power for the projector, the projector is up. | 10/10/13 | Administration Area | front entrance | Cabling |
| Cherokee ES (2100) 2B | Need a computer lab for 25 student computer/ laptops stations, It will need to be wire-up for the equipement. If you have any question please call me / Ms Strong in the office. | 2/5/14 | Classroom | Room 129 | Cabling |
| Cherokee ES (2100) 2B | WINDOW IS OUT IN RM-100, 2-DOORS FRAMES ARE LOOSE IN RM-123,128 PLANT MGR-DENMAN/650.9273 | 2/17/14 | | | Carpentry |
| Cherokee ES (2100) 2B | The stall door is loosed, need to be repaired. | 1/14/14 | Restroom (Girls) | by room 148 | Carpentry |

| | | | | | |
|-----------------------|---|----------|---------------------|-------------|-----------|
| Cherokee ES (2100) 2B | I need the ends doors repaired, from vandalize. Someone was tring to get in. | 1/21/14 | Administration Area | | Carpentry |
| Cherokee ES (2100) 2B | The tile is coming up on the stage stairs. | 1/3/14 | Cafetorium | | Carpentry |
| Cherokee ES (2100) 2B | I need a hasp on the staff stall door. | 11/12/13 | Restroom (Boys) | | Carpentry |
| Cherokee ES (2100) 2B | I need the broken cord repaired | 11/19/13 | Cafetorium | | Carpentry |
| Cherokee ES (2100) 2B | I need the stub door repaired | 9/30/13 | Restroom (Girls) | by room 148 | Carpentry |
| Cherokee ES (2100) 2B | I need 3 pack of mineral ceiling tile | 10/17/13 | Hallway/Corridor | | Carpentry |
| Cherokee ES (2100) 2B | The stub door is broken and need to be repaired. | 10/21/13 | Restroom (Girls) | by room 137 | Carpentry |
| Cherokee ES (2100) 2B | I need a 2 bullinet broads 4 x 8 installed on the front wall. | 10/25/13 | Hallway/Corridor | main hall | Carpentry |
| Cherokee ES (2100) 2B | I need the old black broad replace with a white broad. Can not write on it , it damaged . | 11/1/13 | Classroom | 135 | Carpentry |

| | | | | | |
|-----------------------|---|---------|---------------------|--|-----------|
| Cherokee ES (2100) 2B | I need the old black broad replace with a white broad. Can not write on it , it damaged . | 11/1/13 | Classroom | 135 | Carpentry |
| Cherokee ES (2100) 2B | I need the bulletin board taken down and a white board put up in it placed. We have the boards already. | 8/8/13 | Cafetorium | | Carpentry |
| Cherokee ES (2100) 2B | The stalled door is off and need to be repaired. | 8/9/13 | Restroom (Boys) | by room 122 | Carpentry |
| Cherokee ES (2100) 2B | fabricate window guard for TWO windows see principal(his office) Lonnie should fabricate & install, painter paint before installed-os | 7/24/13 | | | Carpentry |
| Cherokee ES (2100) 2B | Emergency (school will started and the mailboxes need to be in placed) need to move teacher mailboxes from room 156 to main office, also painted and refinished. | 7/29/13 | Administration Area | Main office | Carpentry |
| Cherokee ES (2100) 2B | I need the windows security, a guard on them. I had a break-in. | 2/17/14 | Classroom | 129/ computer room | Carpentry |
| Cherokee ES (2100) 2B | I need the stub door repaired, it hanging off. | 2/24/14 | Restroom (Boys) | front hall | Carpentry |
| Cherokee ES (2100) 2B | I need a whitr broad for PE teacher | 2/24/14 | Cafetorium | Back / PE | Carpentry |
| Cherokee ES (2100) 2B | I need a security lock on these doors, due to computers and laptop computers are store in these area. | 2/27/14 | Cafetorium | 129 / 126/CONFERENCE ROOM and room 145 | Carpentry |

| | | | | | |
|-----------------------|---|----------|---------------------|---------------------------|-----------|
| Cherokee ES (2100) 2B | REAR ENTRANCE DOOR TO BLDG VIEW GLASS-RUBBER HAS BEEN TAMPHERED WITH AS IF THEY ARE PLANNING TO BREAK IN-WON'T BE ABLE TO SECURE-PLANT MGR DENMAN 416-5028 KLR | 3/20/14 | | | Carpentry |
| Cherokee ES (2100) 2B | In the main office the door have come off attached to the counter. And the cafe the ceiling bracket have come a loosed. | 3/21/14 | Administration Area | main office/cafe | Carpentry |
| Cherokee ES (2100) 2B | I have three set of doors that need to be security, someone is tried to broke-in. | 3/24/14 | Administration Area | west entrances | Carpentry |
| Cherokee ES (2100) 2B | The door holder came off | 3/25/14 | Hallway/Corridor | across from room 119 | Carpentry |
| Cherokee ES (2100) 2B | The stall door came off. | 4/2/14 | Restroom (Boys) | across from room 148 | Carpentry |
| Cherokee ES (2100) 2B | I need a hasp on the doors that have the electronic access to, because when the door access break, the door open-up automatic. This is a security problem with the school being opened all night. | 12/5/13 | Administration Area | | Carpentry |
| Cherokee ES (2100) 2B | I need some hooks installed for the plants. I need this done as quickly as possibly. thank you | 5/14/14 | Courtyard | | Carpentry |
| Cherokee ES (2100) 2B | I need bars put on these windows, because we keeping have break-in. In each area there are (3) windows that need security. | 10/17/13 | Administration Area | main office/ computer lab | Carpentry |
| Cherokee ES (2100) 2B | Need shelves for supplies | 12/3/13 | Administration Area | 148 | Carpentry |

| | | | | | |
|-----------------------|--|----------|---------------------|----------------------------------|------------|
| Cherokee ES (2100) 2B | I need bars put on these windows, because we keeping have break-in. In each area there are (3) windows that need security. | 7/22/13 | Administration Area | office/princial/ computer lab | Carpentry |
| Cherokee ES (2100) 2B | I need the ballast replace in 3 light fixtures and 3 boxes of light bulbs. Fluroscnt 32w/T8/ 30bulbs in boxes. I have replaced the bulbs and I have 2 fixture need the bulbs replaced, can not reach the fixtures. | 1/9/14 | Cafetorium | | Electrical |
| Cherokee ES (2100) 2B | I need 2 light fixtures ballast replaced. | 1/10/14 | Kitchen | front by boiler room | Electrical |
| Cherokee ES (2100) 2B | I need a electricity outside for a pond, the pump will need to be installed along with the pond. | 1/10/14 | Courtyard | | Electrical |
| Cherokee ES (2100) 2B | The ballast need to be replaced, the bulbs have been replaced. | 1/21/14 | Hallway/Corridor | by 100 | Electrical |
| Cherokee ES (2100) 2B | The ballast need to be change, the bulbs are working. | 12/10/13 | Library | 142 | Electrical |
| Cherokee ES (2100) 2B | The light fixture donot work, need to be repaired/replace. | 12/10/13 | Data Closet | In the cafe | Electrical |
| Cherokee ES (2100) 2B | I need the emergency light fixture repaired. | 1/3/14 | Hallway/Corridor | by room 126 | Electrical |
| Cherokee ES (2100) 2B | I need the ballast change out, the light fixture is out, I have change out the bulbs. | 1/3/14 | Classroom | room 147 | Electrical |

| | | | | | |
|-----------------------|---|----------|------------------|-------------------------|------------|
| Cherokee ES (2100) 2B | In room 129 the ballast need to be replaced, the bulbs have been changed | 11/11/13 | Classroom | 132 | Electrical |
| Cherokee ES (2100) 2B | The magnet holder need to be remounted on the wall. | 11/11/13 | Hallway/Corridor | Entrance by boiler room | Electrical |
| Cherokee ES (2100) 2B | HEAT ALL RESTRMS AND HALLWAYS-NOT COMING ON-PLANT MGR DENMAN 416-5028 KLR | 11/14/13 | | | Electrical |
| Cherokee ES (2100) 2B | main office clocks not working per Martha Denman 416-5010 | 11/20/13 | | | Electrical |
| Cherokee ES (2100) 2B | I need the bulbs for the stage, Mr. tony Wright order the bulbs already for monday, the size are First choice – mogul to medium base adapter and 22 watt LED A-Lamp. Second choice - 42 watt TCP CFL mogul base. All items are in stock at The Lighting | 11/21/13 | Cafetorium | Stage | Electrical |
| Cherokee ES (2100) 2B | I need the emergency exit light repaired, the battery need charging. | 12/3/13 | Mechanical Room | | Electrical |
| Cherokee ES (2100) 2B | I need the emergency exit light repaired, the battery need charging. Two lights | 12/3/13 | Kitchen | | Electrical |
| Cherokee ES (2100) 2B | I need the light fixture change out, | 9/23/13 | Custodial Closet | front hall | Electrical |
| Cherokee ES (2100) 2B | I have a light fixture out, over the teacher desk. | 9/25/13 | Classroom | room 149 | Electrical |

| | | | | | |
|-----------------------|---|----------|-----------|-------------------------------|------------|
| Cherokee ES (2100) 2B | In room 129 the ballast need to be replaced, the bulbs have been changed. | 9/30/13 | Classroom | room 129 | Electrical |
| Cherokee ES (2100) 2B | I have one emergency light out | 9/30/13 | Cafeteria | back on the side of courtyard | Electrical |
| Cherokee ES (2100) 2B | I have two light fixtures out, the bulbs been change out. | 10/23/13 | Classroom | 153 | Electrical |
| Cherokee ES (2100) 2B | The ballasts need to be replaced, all bulbs have been change-out. | 10/26/13 | Classroom | 154/149/130/122 | Electrical |
| Cherokee ES (2100) 2B | Can not get the flag down, it stuff. | 10/29/13 | Grounds | flag ploe | Electrical |
| Cherokee ES (2100) 2B | LIGHT FIXTURE IS HANGING IN G/RR FRONT ENTRY HALL. PLANT MGR-DENMAN/416.5010 | 10/31/13 | | | Electrical |
| Cherokee ES (2100) 2B | The ballasts need to be replaced, all bulbs have been change-out. | 11/1/13 | Classroom | 107 | Electrical |
| Cherokee ES (2100) 2B | In room 130 the ballast need to be replaced, in the hall by rm 128 the light fixture need to be repaired. Also I need 3 boxes of light bulbs. | 8/23/13 | Classroom | 130/hall by rm 128 | Electrical |
| Cherokee ES (2100) 2B | repair ballast 2ct. | 8/27/13 | Cafeteria | dinning area rear | Electrical |

| | | | | | | |
|-----------------------|--|---------|---------------------|-----------------|--|------------|
| Cherokee ES (2100) 2B | outlets in cafeteria not of them are working per Martha Denman 416-5010 | 9/3/13 | | | | Electrical |
| Cherokee ES (2100) 2B | I need 4 boxes of light blubs. I have several light out, and need the blubs replaced. | 9/5/13 | Administration Area | main office | | Electrical |
| Cherokee ES (2100) 2B | I need type S amp 30 / fuses, 4boxes. I need 40W HI-PRO SPIRAL bulbs / 20 each. | 9/9/13 | Administration Area | main office | | Electrical |
| Cherokee ES (2100) 2B | A/C WINDOW UNIT CAFE MGR OFC-NOT COMING ON-PLANT MGR DENMAN 416-5028 KLR | 9/13/13 | | | | Electrical |
| Cherokee ES (2100) 2B | I have lights out on the park lot by the Aud. and teacher's parking lot. | 9/13/13 | Administration Area | main office | | Electrical |
| Cherokee ES (2100) 2B | The ballast in the pantry in kitchen is not working and it is dark. Bulbs have been changed but still not working per Martha Denman 416-5010 | 8/8/13 | | | | Electrical |
| Cherokee ES (2100) 2B | I have one light fixture out, the bulbs have been charge-out. | 8/8/13 | Classroom | room 133 | | Electrical |
| Cherokee ES (2100) 2B | Change the bulbs out, the whole fixture out, this is the front of the room | 8/8/13 | Classroom | 139 | | Electrical |
| Cherokee ES (2100) 2B | I need the lighth fixture repaired. I can not get the cover off to change the bulbs. | 8/13/13 | Administration Area | conference room | | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|----------------------------------|------------|
| Cherokee ES (2100) 2B | There's an outlet with a WIRE STICKING OUT in Pre-School Classroom, 152 per Ms. Martha Denman, Plant Mgr. 901.416.5010 | 8/19/13 | | | Electrical |
| Cherokee ES (2100) 2B | WHEEL CHAIR LIFT HAS NO POWER BY CAFE. SBE-DENMAN/416-5028 | 7/1/13 | | | Electrical |
| Cherokee ES (2100) 2B | The vent fan is not working | 7/8/13 | Restroom (Boys) | by room 136 | Electrical |
| Cherokee ES (2100) 2B | Half of the Room LIGHTS ARE OUT in Room #145 per Ms. Denman, Plant Mgr. at 901.416.5010. Not the bulbs but the Balance! | 7/10/13 | | | Electrical |
| Cherokee ES (2100) 2B | I need 40W energy save spiral bulbs (10) for the restrooms. | 7/12/13 | Administration Area | by room 145/141 | Electrical |
| Cherokee ES (2100) 2B | I need the outlet exchange out for the equipment in the cafe area. the end on the equipement is differ from the outlet. | 7/22/13 | Cafeteria | office/princial/ computer lab | Electrical |
| Cherokee ES (2100) 2B | Outlet in main office for fax machine not working per Martha Denman 416-5028 | 7/23/13 | | | Electrical |
| Cherokee ES (2100) 2B | I have half the room in the dark, bulbs have been charge-out. | 7/29/13 | Classroom | 139 room | Electrical |
| Cherokee ES (2100) 2B | RECEPTACLE IN KITCHEN AREA FOR STAND-UP FREEZER-HAS NO POWER-WILL NEED-SBE DENMAN 416-5028 KLR | 8/1/13 | | | Electrical |

| | | | | | |
|-----------------------|--|---------|---------------------|-----------------------|------------|
| Cherokee ES (2100) 2B | These emergency lights in the hall and the cafe are not working. | 8/1/13 | Hallway/Corridor | 133,106 room and cafe | Electrical |
| Cherokee ES (2100) 2B | LIGHTS ARE OUT IN RM 139 SBE DENMAN | 8/5/13 | | | Electrical |
| Cherokee ES (2100) 2B | I need the bell ringing for the school | 8/6/13 | Administration Area | office | Electrical |
| Cherokee ES (2100) 2B | I need the clock set for day light saving time. Day light saving time starts Sunday march 9th. | 2/21/14 | Administration Area | Conference Room | Electrical |
| Cherokee ES (2100) 2B | per ms denman 416-5010 rooms 100 and 101 have lost partial power (to computers) | 2/25/14 | | | Electrical |
| Cherokee ES (2100) 2B | The emergency exit lights in the kitchen, boiler room and by the boy restroom by room 135 need to be replaced. | 2/4/14 | Hallway/Corridor | by rm 124 | Electrical |
| Cherokee ES (2100) 2B | The ballast need to be replaced, the bulbs have been replaced. | 2/4/14 | Classroom | by rm 152 | Electrical |
| Cherokee ES (2100) 2B | The main clock/ master clock need to be set. | 2/7/14 | Administration Area | Conference Room | Electrical |
| Cherokee ES (2100) 2B | I have a whole light fixtures out in each room, the bulbs have been replaced. | 3/4/14 | Classroom | 152,129,121 | Electrical |

| | | | | | |
|-----------------------|--|---------|------------------|----------------------|------------|
| Cherokee ES (2100) 2B | UNIT NOT COMING ON IN RM-121,102,125,152,104 PLANT MGR-DENMAN/416.5010 | 4/2/14 | | | Electrical |
| Cherokee ES (2100) 2B | I need a cover over the pull station at the back door of the kitchen. | 2/12/14 | Kitchen | back door | Electrical |
| Cherokee ES (2100) 2B | PARTIAL LIGHTS IN RM-128 PLANT MGR-DENMAN/416.5028 | 12/4/13 | | | Electrical |
| Cherokee ES (2100) 2B | A/C CAFE AREA, RM 152, 133, 121, 104, & 148-ALL NOT COMING ON-PLANT MGR DENMAN 416-5028 KLR | 5/13/14 | | | Electrical |
| Cherokee ES (2100) 2B | I have a light bulb brken off in the light fixture | 6/2/14 | Library | | Electrical |
| Cherokee ES (2100) 2B | The emergency light will not come on. | 4/22/14 | Classroom | 154 | Electrical |
| Cherokee ES (2100) 2B | The light fixture over the freezer is out, and need to be repaired. Also i need some light bulbs for the vent hood fixtures. | 4/28/14 | Kitchen | | Electrical |
| Cherokee ES (2100) 2B | I need outlet in the ceiling for projector smart broad. | 7/19/13 | Classroom | 122,124,126,136 | Electrical |
| Cherokee ES (2100) 2B | need outlet in the ceiling for projector smart broad. | 7/19/13 | Hallway/Corridor | Front Hall by office | Electrical |

| | | | | | |
|-----------------------|--|----------|---------------------|-----------------|---------------------------------------|
| Cherokee ES (2100) 2B | Check all outside lights and doorways. | 9/23/13 | Administration Area | main building | Electrical |
| Cherokee ES (2100) 2B | outlet install outside wall north | 8/28/13 | Courtyard | north-west wall | Electrical |
| Cherokee ES (2100) 2B | First choice – mogul to medium base adapter and 22 watt LED A-Lamp. Second choice - 42 watt TCP CFL mogul base. All items are in stock at The Lighting Source. | 11/21/13 | Cafetorium | | Electrical |
| Cherokee ES (2100) 2B | A/C RM 120 & 121-BOTH NOT COOLING-PLANT MGR DENMAN 416-5028 KLR | 4/30/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | PARTIAL POWER OUTAGE INCLUDING THE GENERATOR - PM/BANKS | 6/30/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | per ms denman 416-5010 room 100 is blowing hot | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | per ms denman 416-5010 back of cafeteria is blowing cold air | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | per martha denman 416-5010 cafeteria unit is not heating and making loud noise | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | UV RM 136-LEAKING AGAIN-PLANT MGR DENMAN 416-5028 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|------------------|--|--|
| Cherokee ES (2100) 2B | rebuild leaking pump - not to exceed \$5000.00 | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | PUMP-3 MECH RM-MAKING LOUD NOISES-PLANT MGR DENMAN 416-5028 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | 4-UV NOT HEATING IN RM-136,132,139,149. PLANT MGR-DENMAN/416.5028 | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | HEAT PRIN'S OFC, RM 119, 120, 121, & 154-ALL NOT HEATING-PLANT MGR DENMAN 416-5028 KLR | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Unit Ventilators are NOT COMING ON in ROOMS 136 and 154 per Ms. Denman, Plant Mgr. 416.5010 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Unit Ventilators are NOT HEATING in ROOMS 128, 129, 131, 132, 134, and 150 per Ms. Denman, Plant Mgr. 416.5010 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | BOILER NOT COMING ON. PLANT MGR-DENMAN/416.5028 | 11/8/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | BOILER NOT COMING ON. PLANT MGR-DENMAN/416.4840 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | The heater need to be clean out so it can heat the area. | 11/14/13 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|------------------|----------|--|
| Cherokee ES (2100) 2B | The heater in the restrooms both girls and boys need to be turn on. | 11/14/13 | Restroom (Girls) | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | radiator busted and water flooding room 130 and hallway and can't cut off per Martha Denman 416-5010 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Monthly - Oil Lube & Belts - Cherokee Elem - Refer to PM schedule details. | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | UNIT IS LEAKING WATER CONTINUOUSLY IN RM-120. PLANT MGR-DENMAN/416.5028 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C unit is LEAKING in CLASSROOM 152 per Ms. Martha, Plant Mgr. 416.5010 | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | It only blowing warm air/ not cooling | 10/2/13 | Classroom | room-138 | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | The A/c is not working, leaking and putting out hot air. | 10/2/13 | Classroom | room-104 | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | UNIT NOT COOLING IN RM-120. PLANT MGR-DENMAN/416.5028 | 10/15/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C LEAKING water in ROOM 149 per Ms. Denman, Plant Mgr. 416.5010 | 10/23/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|--|--|--|
| Cherokee ES (2100) 2B | RTU-2 & RTU-3 CAFE AREA- BOTH NOT COOLING-PLANT MGR JEFFERSON 416-5028 KLR | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | a/c units leaking rooms 123, 126, 102 per Martha Denman 416-5010 | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C RM 123-LEAKING-PLANT MGR DENMAN 416-4840 KLR | 9/5/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C RM 104-NOT COOLING- PLANT MGR DENMAN 416-5028 KLR | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | UNIT IS LEAKING WATER IN RM- 120 PLANT MGR-DENMAN/416.5028 | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | UV RM 104-NOT COOLING- PLANT MGR DENMAN 416-5028 KLR | 9/13/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C UNIT RM 145, RM 136, & RM 102-ALL ARE LEAKING-SBE DENMAN 416-5010 KLR | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | AHU CAFE SOUTH END-NOT COOLING-SBE DENMAN 416- 5028 KLR | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | RTU CAFE AREA-NOT COOLING- PLANT MGR DENMAN 416-5028 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|-----------|---------------------|--|
| Cherokee ES (2100) 2B | Monthly - Filter-Cherokee Elementary - Refer to PM schedule details. | 7/5/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Check units for leak | 7/11/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | a/c units leaking in rooms 130, 132, 134, 143 Martha Denman 416-5028 | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | These rooms are not cooling/ and energy management show that the units are dead. | 7/17/13 | Classroom | by room 151/152/155 | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | RTU#3 NOT COMING ON IN CAFE . SBE-DENMAN/416-5028 | 7/22/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C IN RM 136-NOT COOLING AND LEAKING ALL OVER FLOOR PER SBE-SBE DENMAN 416-5028 KLR | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | A/C IN RM 126-NOT COOLING-SBE DENMAN 416-5028 KLR | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | UNITS ARE NOT COOLING IN RMS 121,139,155,150,136 SBE DENMAN | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | HEAT RM 155, 149, 134, 135, 136, & MAIN OFC-ALL NOT HEATING-PLANT MGR DENMAN 416-5028 KLR | 2/24/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|-----------|--------|--|
| Cherokee ES (2100) 2B | UNIT NOT HEATING IN RM-150 PLANT MGR-DENMAN/416.5010 | 3/6/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Monthly - Filter-Cherokee Elementary - Refer to PM schedule details. | 3/7/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Bad sensor need lap top. | 5/14/14 | Classroom | Rm 148 | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Yearly - Boiler 002 - Cherokee Elem - Refer to PM schedule details. | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Yearly - Boiler 001 - Cherokee Elm - Refer to PM schedule details. | 3/4/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Monthly - Filter-Cherokee Elementary - Refer to PM schedule details. | 11/8/13 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | Monthly - Oil Lube & Belts - Cherokee Elem - Refer to PM schedule details. | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Cherokee ES (2100) 2B | I need the building pressure washed. | 5/22/14 | | | Painting |

| | | | | | |
|-----------------------|--|----------|------------------|-------------------|----------|
| Cherokee ES (2100) 2B | plse remove graffiti from sidewalk | 10/21/13 | | | Painting |
| Cherokee ES (2100) 2B | paint mail boxes | 8/9/13 | | | Painting |
| Cherokee ES (2100) 2B | Paint window guards for Cherokee Elm see Tom Ford. | 2/20/14 | | | Painting |
| Cherokee ES (2100) 2B | GRAFFITI on the BRICK of SCHOOL in the back by LARGE PARKING LOT per Ms. Denman, Plant Mgr. 416.5010 | 2/24/14 | | | Painting |
| Cherokee ES (2100) 2B | UNIT IN RM 125 IS LEAKING. SBE DENMAN 416-5010 | 8/7/13 | | | Plumbing |
| Cherokee ES (2100) 2B | STOVE NEEDS TO BE LIT IN KITCHEN PLANT MGR-DENMAN/416.5028 | 1/16/14 | | | Plumbing |
| Cherokee ES (2100) 2B | EXPANSION TANK MECH RM-LEAKING-PLANT MGR DENMAN 416-5028 KLR | 1/23/14 | | | Plumbing |
| Cherokee ES (2100) 2B | The toilet seat need to be repaired. | 12/5/13 | Restroom (Girls) | 143 | Plumbing |
| Cherokee ES (2100) 2B | In room 106 the sink is stop-up, in room 104 the tiolet flush valve need to be repaired, and the girl restroom by 148 two tiolets are stop-up. | 12/27/13 | Restroom (Girls) | rm 104/106/by 148 | Plumbing |

| | | | | | |
|-----------------------|---|----------|------------------|---------------------------|----------|
| Cherokee ES (2100) 2B | I need the sink in the boiler room unstopped. | 1/3/14 | Mechanical Room | | Plumbing |
| Cherokee ES (2100) 2B | Test and repair RP Devices per MLG&W. | 11/8/13 | Mechanical Room | | Plumbing |
| Cherokee ES (2100) 2B | I need the drain cover repaired, pest control came out and requested the drain cover be replaced. | 11/14/13 | Kitchen | | Plumbing |
| Cherokee ES (2100) 2B | PUMP IS LEAKING WATER IN BOILER RM PLANT MGR-DENMAN/416.4840 | 12/2/13 | | | Plumbing |
| Cherokee ES (2100) 2B | I have a leak pipe from the ceiling, a copper line. I can not contain it. | 12/2/13 | Cafetorium | | Plumbing |
| Cherokee ES (2100) 2B | The toilet is crack and when flushed it leaking all over the floor. | 12/2/13 | Restroom (Girls) | by room 140 | Plumbing |
| Cherokee ES (2100) 2B | The fault on the sink are very loosed and need to be repaired. | 12/2/13 | Hallway/Corridor | main hall by boy restroom | Plumbing |
| Cherokee ES (2100) 2B | The toilet seats are loosed, and need repaired. | 12/2/13 | Restroom (Girls) | by room 109 | Plumbing |
| Cherokee ES (2100) 2B | boys restroom next to room 145 and girls restroom next to room 139 toilets flooding per Ms. Denman 416-5010 | 9/24/13 | | | Plumbing |

| | | | | | |
|-----------------------|--|----------|------------------|----------------------------|----------|
| Cherokee ES (2100) 2B | The toilet are stop-up and the restroom by 139 had three toilets stop-up in it. These are the same toilets that keep stop-up, can they be pull-up, because something is in the pipe. | 10/10/13 | Restroom (Girls) | by rm 140,139,137 | Plumbing |
| Cherokee ES (2100) 2B | The hot water tank need to be repair, there water leaking out | 10/17/13 | Mechanical Room | | Plumbing |
| Cherokee ES (2100) 2B | pilot light on steam table will not light per Ms. Denman 416-5010 | 10/23/13 | | | Plumbing |
| Cherokee ES (2100) 2B | repair urinal, constantly running none stop | 8/27/13 | 1st Floor | main-hall boy's rr | Plumbing |
| Cherokee ES (2100) 2B | faucet need a better stem, problem cutting off | 8/28/13 | Courtyard | water faucet | Plumbing |
| Cherokee ES (2100) 2B | water fountain not working, id#060 | 8/28/13 | Cafeteria | dining area water fountain | Plumbing |
| Cherokee ES (2100) 2B | Boys restroom by rm 122 the urinal top has come off and has to cut water off per Martha Denman 416-5010 | 9/3/13 | | | Plumbing |
| Cherokee ES (2100) 2B | 1 toilet by room 106; 2 toilet by room 137, I need these toilet fixed, because this cause the students to be back-up and later for support classes. Also the staff used these restroom because it location by the main office. | 9/17/13 | Restroom (Girls) | main office | Plumbing |
| Cherokee ES (2100) 2B | 1 toilet by room the principal office and it a handiicap; 1 toilet by room 135, I need these toilet fixed, because this cause the students to be back-up and later for support classes. | 9/17/13 | Restroom (Boys) | main office | Plumbing |

| | | | | | | |
|-----------------------|--|---------|------------------|-------------|--|----------|
| Cherokee ES (2100) 2B | COMMODE PRIN'S OFC RR- STOPPED UP & OVERFLOWING PER SBE-PLANT MGR DENMAN 416-4840 KLR | 9/18/13 | | | | Plumbing |
| Cherokee ES (2100) 2B | I need the toilet removed and a faucet place in the girl restroom. Also in the plant management restroom the seat need to be repaired. | 8/7/13 | Restroom (Girls) | by room 139 | | Plumbing |
| Cherokee ES (2100) 2B | The toilet flush valve need to be replaced. | 8/8/13 | Restroom (Boys) | by room 132 | | Plumbing |
| Cherokee ES (2100) 2B | The toilet is stop-up and broken. | 8/9/13 | Restroom (Boys) | by room 122 | | Plumbing |
| Cherokee ES (2100) 2B | PER SBE FRONT ENTRANCE NEAR B/G RR'S FLOODED- DON'T KNOW WHAT OR WHERE WATER COMING FROM-SBE DENMAN 416-5028 KLR | 8/14/13 | | | | Plumbing |
| Cherokee ES (2100) 2B | 2-COMPARTMENT SINK KITCHEN-RIGHT SIDE FAUCET STRIPPED-HOT WATER RUNNING AT A STREAM PER SBE-SBE DENMAN 416-5028 KLR | 8/20/13 | | | | Plumbing |
| Cherokee ES (2100) 2B | WALL UNIT IS LEAKING IN RM- 134 PLANT MGR-DENMAN/416.5028 | 8/21/13 | | | | Plumbing |
| Cherokee ES (2100) 2B | FCU IS LEAKING WATER IN RM- 130(NO ID). SBE-DENMAN/416-5028 | 7/1/13 | | | | Plumbing |
| Cherokee ES (2100) 2B | The sink is leaking on the floor. | 7/3/13 | Hallway/Corridor | front hall | | Plumbing |

| | | | | | |
|-----------------------|--|---------|---------------------|------------------------|----------|
| Cherokee ES (2100) 2B | Toilet stop-up and flush valve need replacing. | 7/3/13 | Restroom (Boys) | by teacher lounge | Plumbing |
| Cherokee ES (2100) 2B | FCU LEAKING IN RMS 130,132,134. SBE DENMAN 416- | 7/8/13 | | | Plumbing |
| Cherokee ES (2100) 2B | The restroom sink is stop-up | 7/12/13 | Administration Area | by room 145/141 | Plumbing |
| Cherokee ES (2100) 2B | The toilet is broken, and need to be replaced. | 7/26/13 | Kitchen | | Plumbing |
| Cherokee ES (2100) 2B | UNITS ARE LEAKING IN RM 100,125,120,136,132,124,121. SBE DENMAN | 8/5/13 | | | Plumbing |
| Cherokee ES (2100) 2B | The flush valve in the classroom 151 the toilet need to be repaired. | 2/18/14 | Restroom (Boys) | 151/boy restroom by151 | Plumbing |
| Cherokee ES (2100) 2B | The flush valve in the need to be repaired | 2/18/14 | Restroom (Boys) | by room 151 | Plumbing |
| Cherokee ES (2100) 2B | per ms denman 416-5010 the pilot on the steam table is out | 2/4/14 | | | Plumbing |
| Cherokee ES (2100) 2B | per ms denman 416-5010 the courtyard drain is stopped up and coming back into the building and the mop sink in the cafeteria is stopped up | 2/4/14 | | | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------------|-----------------------|----------|
| Cherokee ES (2100) 2B | PILOT NEEDS TO BE LIT ON STEAMTABLE-KEEPS GOING OUT-PLANT MGR DENMAN 416-5028 KLR | 3/19/14 | | | Plumbing |
| Cherokee ES (2100) 2B | The toilet seat is coming off, need to be replace with a white seated. | 3/28/14 | Restroom (Boys) | across from room 119 | Plumbing |
| Cherokee ES (2100) 2B | UNIT IS LEAKING WATER IN RM-120 PLANT MGR-DENMAN/416.5010 | 4/2/14 | | | Plumbing |
| Cherokee ES (2100) 2B | UNIT IS LEAKING WATER IN RM-131 PLANT MGR-DENMAN/416.5028 | 4/9/14 | | | Plumbing |
| Cherokee ES (2100) 2B | The toilet seat is coming off. | 12/4/13 | Restroom (Boys) | by 145 | Plumbing |
| Cherokee ES (2100) 2B | The water fountain is stop-up, the water will not go down. | 5/5/14 | Hallway/Corridor | Front hall by room109 | Plumbing |
| Cherokee ES (2100) 2B | In the boy restroom the toilet is stop-up. In room 145 the flush valve need to be replaced. | 5/13/14 | Restroom (Boys) | by rm 149/145 | Plumbing |
| Cherokee ES (2100) 2B | A/C RM 122-LEAKING-PLANT MGR DENMAN 416-5028 KLR | 6/17/14 | | | Plumbing |
| Cherokee ES (2100) 2B | I have a roof leaked in the girl restroom over the floor drain. | 1/9/14 | Restroom (Girls) | front by boiler room | Roof |

| | | | | | |
|-----------------------|---|----------|---------------------|---------------|------|
| Cherokee ES (2100) 2B | Leaking from the ceiling in the girl restroom, from the rain. | 11/22/13 | Restroom (Girls) | main hall | Roof |
| Cherokee ES (2100) 2B | ROOF IS LEAKING WATER IN CAFE PLANT MGR-DENMAN/416.5028 | 12/2/13 | | | Roof |
| Cherokee ES (2100) 2B | The down spout need to be clean out, they are spot-up from the leaves. | 12/2/13 | Administration Area | main building | Roof |
| Cherokee ES (2100) 2B | I have aleak in the room and can not contain it. | 10/31/13 | Classroom | 154 | Roof |
| Cherokee ES (2100) 2B | I have aleak in the room and can not contain it. | 10/31/13 | Classroom | 135/146/148 | Roof |
| Cherokee ES (2100) 2B | I have aleak in the room and can not contain it. | 10/31/13 | Library | 142 | Roof |
| Cherokee ES (2100) 2B | I have aleak in the room and can not contain it. | 11/1/13 | Mechanical Room | | Roof |
| Cherokee ES (2100) 2B | Roof leaks in following rooms 133, 134, 126, 140, library, 136, computer lab, 107, 103, 128, 127, 120, 101, 106, 145, 151, 153 per Martha Denman 416-5028 | 7/22/13 | | | Roof |
| Cherokee ES (2100) 2B | In the back of the room there is a leak coming from the ceiling. | 2/5/14 | Classroom | 152 | Roof |

| | | | | | |
|-----------------------|---|----------|---------------------|--------------------------------------|-------------|
| Cherokee ES (2100) 2B | I need the roof drains unstoped, they have leaves in the roof drains. | 3/18/14 | Administration Area | | Roof |
| Cherokee ES (2100) 2B | I have two main leak in the cafe, this is a tripping problem and I have a program in here at 12:00 pm today. Which mean all the room will be used. This is an emergency, please help!!! | 5/14/14 | Cafeteria | | Roof |
| Cherokee ES (2100) 2B | I have a hole in the metel boiler room door. It need to be cover with metal | 12/13/13 | Administration Area | outside entrance by boiler room door | Sheet Metal |
| Cherokee ES (2100) 2B | The gutter need repaired, and cleaning out. | 9/26/13 | Administration Area | around school | Sheet Metal |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|--------------------------|--|---------------|------------------|---------------------|-----------|
| Chimneyrock ES (2049) 2A | Floor tile needs replacing by gym.(broken) | 3/31/14 | 1st Floor | Red Hall | Asbestos |
| Chimneyrock ES (2049) 2A | Ceiling tile in cafeteria need to be replace (water damage) | 7/9/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Clean out cafeteria where A/C is being installed. | 7/29/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | The wood in front of these portable are tripping hazard. Teacher has fallen) | 8/1/13 | Portables | 060,109,020,019,018 | Carpentry |
| Chimneyrock ES (2049) 2A | Request ceiling tile be place back in the ceiling in the cafe. | 8/2/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Ceiling tile need to be replace there is no ceiling tile in this area .(water damage) | 8/7/13 | Cafeteria | A | Carpentry |
| Chimneyrock ES (2049) 2A | per Ms. Jones 416-9034 classroom #25 can't open door | 1/3/14 | | | Carpentry |

| | | | | | |
|--------------------------|---|---------|-----------|--------------------|-----------|
| Chimneyrock ES (2049) 2A | FRONT ENTRY DOOR NOT CLOSING, CANT SECURE PLANT MGR-JONES/416.2067 | 1/17/14 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Two ceiling tiles in Ms. Hall's room # 28 on the Green hall need to be replaced. They are hanging down and they are presenting a hazard for students. | 2/10/14 | 1st Floor | 28 | Carpentry |
| Chimneyrock ES (2049) 2A | latched not secured on playground area (safety of the children) per sacc. | 2/21/14 | Courtyard | Playground | Carpentry |
| Chimneyrock ES (2049) 2A | Request bricks be replaced on the BLDG. | 2/27/14 | | front of school | Carpentry |
| Chimneyrock ES (2049) 2A | Fence outside on playground broken (sharp object) per sacc. | 3/7/14 | | outside playground | Carpentry |
| Chimneyrock ES (2049) 2A | Railing about to fall. | 4/1/14 | | Portable 2 | Carpentry |
| Chimneyrock ES (2049) 2A | Has a hole in floor tile need replacing. | 4/9/14 | Portables | 2 | Carpentry |
| Chimneyrock ES (2049) 2A | There was a break in and there are 2 rooms that the windows cannot be secured Room 60 and Room 48 per Ms. Jones 416-3781 | 8/22/13 | | | Carpentry |

| | | | | | |
|--------------------------|---|----------|------------|------------|-----------|
| Chimneyrock ES (2049) 2A | 6-WINDOWS CANT SECURE DUE TO BREAK-IN RM-10,30,31,61,56 PLANT MGR-JONES/416.2067 | 8/23/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Doors not locking. | 8/30/13 | 1st Floor | 36,42 | Carpentry |
| Chimneyrock ES (2049) 2A | Replace ceiling tile in this classroom water damage. | 9/4/13 | 1st Floor | 7 | Carpentry |
| Chimneyrock ES (2049) 2A | Replace floor tile in front entrance area (tripping hazard) | 9/6/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Playground gate need to be secure (won't lock) per child care inspector. | 9/17/13 | | Playground | Carpentry |
| Chimneyrock ES (2049) 2A | Pick-up and deliver the lift to White Station Ele. | 10/11/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Request hole be repaired in the wall | 10/16/13 | Cafetorium | | Carpentry |
| Chimneyrock ES (2049) 2A | object hanging from the ceiling over both staircases to the stage. The ceiling tiles have already fallen from the casings (or whatever they are called) coming loose and dangling. (Per SACC Aftercare Director) | 11/7/13 | | | Carpentry |

| | | | | | |
|--------------------------|---|----------|------------------|--|------------|
| Chimneyrock ES (2049) 2A | DOOR WONT CLOSE IN MAIN ENTRY PLANT MGR-DENMAN/416.2067 | 11/22/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | 2-WINDOWS ARE BROKEN COMPLETELY OUT IN RM-41,43 PLANT MGR-JONES/416.2067 | 12/9/13 | | | Carpentry |
| Chimneyrock ES (2049) 2A | Repair or replace exhaust fans in all girls and boys resroom. Received complaint concerning bacteria. | 4/28/14 | Restroom (Girls) | | Electrical |
| Chimneyrock ES (2049) 2A | WATER FOUNTAIN GREEN HALL-HAS LIVE WIRES EXPOSED AND IT'S SPARKING- PLANT MGR JONES 416-3781 KLR | 5/2/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | Power outage at the school. | 5/19/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | ROOFTOP UNIT is NOT COMING ON which controls the CLASSROOMS 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, and 62 down YELLOW HALLWAY and CLASSROOM 29 down GREEN HALLWAY per Ms. Jones, Plant Mgr. 416-3781 | 5/19/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | LIGHT FIXTURE CAFE AREA-DANGLING FROM CEILING, ABOUT TO FALL-THEY ARE HAVING SUMMER CAMP IN AREA PER SBE-PLANT MGR LONDON KLR | 6/30/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU IN RM 8 IS NOT COMING ON. SBE JONES 416-3067 | 7/26/13 | | | Electrical |

| | | | | | |
|--------------------------|--|--------|-----------|---------------|------------|
| Chimneyrock ES (2049) 2A | Outlet not working. | 8/1/13 | 1st Floor | 55 | Electrical |
| Chimneyrock ES (2049) 2A | A/C IN RMS 16 & 109-BOTH NOT COMING ON-SBE JONES 416-2067 KLR | 8/6/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | Clock not working. | 8/8/13 | 1st Floor | Green Hallway | Electrical |
| Chimneyrock ES (2049) 2A | A/C IN RM 55 YELLOW HALL & RM 32 RED HALL-BOTH NOT COMING ON-SBE JONES 416-3781 KLR | 8/8/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | fire alarm panel shows trouble and there is a piercing noise coming from it per Ms. Jones 416-9034 | 1/3/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | HEAT RM 9-NOT COMING ON-PLANT MGR JONES 416-9034 KLR | 1/7/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU NOT COMING ON IN RM-21,17 PLANT MGR-JONES/416.2067 | 1/8/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | Unit is NOT COMING ON in PORTABLE 1 per Ms. Jones, Plant Mgr. 416.3781 | 1/9/14 | | | Electrical |

| | | | | | |
|--------------------------|---|---------|--|--|------------|
| Chimneyrock ES (2049) 2A | per Ms. Jones 416-3781 room 19 unit not coming on | 1/13/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | HEAT RM 23-NOT COMING ON-PLANT MGR JONES 416-2067 KLR | 1/15/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | Unit is NOT COMING ON in the MAIN OFFICE per Ms. Jones, Plant Mgr. 416.3781 | 1/17/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | HEAT RM 9-NOT COMING ON-PLANT MGR JONES 416-2067 KLR | 1/23/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | per Ms. Jones 416-3781 room21 heat not coming on at all | 1/23/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | Fire Alarm Horn/Strobe by Room 51 needs to be replaced. It was found faulty during a fire alarm test. | 1/24/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU NOT COMING ON IN RM-19,23 PLANT MGR-JONES/416.2067 | 1/27/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | per Ms. Jones 416-9631 main office heat is not coming on | 1/27/14 | | | Electrical |

| | | | | | |
|--------------------------|---|---------|--|--|------------|
| Chimneyrock ES (2049) 2A | MAIN OFC AREA-HAS NO POWER TO RECEPTACLES- PLANT MGR JONES 416-9341 KLR | 2/11/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | 2-UNIT NOT COMING ON IN RM-42,19 PLANT MGR-JONES/416.2067 | 3/6/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | per ms jones 416-2067 room 22 heat not coming on at all | 3/6/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | per ms jones 416-3781 room 34 lights are out | 3/20/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | per ms jones room 61 wall unit heat not coming on | 3/20/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | UNIT is NOT COMING ON in PORTABLE 14 per Ms. Jones, Plant Mgr. 416.3781 | 3/26/14 | | | Electrical |
| Chimneyrock ES (2049) 2A | A/C IN RM 23-NOT COMING ON-SBE JONES 416-2067 KLR | 8/13/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU NOT COMING ON IN RM-16,12 PLANT MGR-JONES/416.2067 | 8/21/13 | | | Electrical |

| | | | | | |
|--------------------------|---|----------|-----------|------|------------|
| Chimneyrock ES (2049) 2A | Ballast out. | 8/21/13 | Portables | 9,15 | Electrical |
| Chimneyrock ES (2049) 2A | Rooftop unit NOT COMING ON per Priscilla Jones, Plant Mgr. @ 901.416.3781 | 8/27/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | Power outage in the parking lot. | 8/29/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU NOT COMING ON IN RM-053 PLANT MGR-JONES/416.3781 | 9/3/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | UNIT NOT COMING ON IN LIBRARY. PLANT MGR-JONES/416.2067 | 9/25/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | A/C unit in ROOM 25 NOT COMING ON per Ms. Jones, Plant Mgr. 416.3781 | 10/9/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | LIGHTS RM 32-NOT COMING ON-COMPLETLY DARK PER SBE & DO HAVE WINDOWS- PLANT MGR JONES 416-9430 KLR | 10/23/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | LIGHTS RM 23-NOT COMING ON-PLANT MGR JONES 416-2067 KLR | 11/8/13 | | | Electrical |

| | | | | | |
|--------------------------|--|----------|--|--|---------------------------------------|
| Chimneyrock ES (2049) 2A | UNIT NOT COMING ON IN PORT-15. PLANT MGR-JONES/416.3781 | 11/13/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | HEAT RM 35-NOT COMING ON-PLANT MGR JONES 416-3781 KLR | 11/15/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU NOT COMING ON IN CAFE PLANT MGR-JONES/416.2067 | 12/3/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | RTU NOT COMING ON IN RM-35 PLANT MGR-JONES/416.2067 | 12/9/13 | | | Electrical |
| Chimneyrock ES (2049) 2A | A/C LIBRARY-WON'T CUT OFF & IT'S TOO COLD IN LIBRARY-TEMP NOT SHOWING-PLANT MGR JONES 416-2067 KLR | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | ROOFTOP UNIT is TOO HOT in ROOM 51 per Ms. Jones, Plant Mgr. 416.3781 | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C RM 37-BLOWING TOO COLD-SBE DON'T KNOW THE TEMP, NO THERMOSTAT-PLANT MGR JONES 416-3781 KLR | 5/16/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Units NOT COOLING in Portables #'s 2, 11, and 17. Also, in Classroom #53. Per Priscilla Jones, Engineer at 416.2067. | 7/8/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|--|--|---------------------------------------|
| Chimneyrock ES (2049) 2A | RTU NOT COOLING IN RM-55. SBE-JONES/416-2067 | 7/23/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Per Ms. Jones 416-2067 following rooms are not cooling 6, 8, 35, 37, 44, 45 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN RMS 35 & 55-NOT COOLING-SBE JONES 416-2067 KLR | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN LIBRARY BLOWING TOO COLD-TEMP IS 62 PER SBE-SBE JONES 416-2067 KLR | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Install unit for cafe | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN PORT 2-MAKING LOUD NOISES-SBE JONES 416-3781 KLR | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | no heat room 9 & 35 & guidance office-os | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | HEAT CAFE AREA-OVERHEATING, TEMP IS 95-PLANT MGR JONES 416-3781 KLR | 1/21/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--|--|
| Chimneyrock ES (2049) 2A | HEAT CAFE AREA- OVERHEATING, TEMP IS 77- PLANT MGR JONES 416-2067 KLR | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | room 21 blowing cold per ms jones 416-3781 | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | HEAT CAFE AREA- OVERHEATING, TEMP IS 80- PLANT MGR JONES 416-2067 KLR | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | per ms jones 416-3781 room 21 not heating | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | portable 14 is overheating per ms jones 416-9034 | 2/19/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | per ms jones 416-1568 room 21 blowing cold | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | HEAT LIBRARY AREA- CONSTANTLY RUNS, NOT CYCLING OFF-PLANT MGR JONES 416-2067 KLR | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--|---------------------------------------|
| Chimneyrock ES (2049) 2A | per ms jones 416-3781 room 51 is overheating | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | install evap in library | 4/7/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN RM 16-NOT COOLING-SBE JONES 416-2067 KLR | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN LIBRARY BLOWING TOO COLD-TEMP IS 60 PER SBE-SBE JONES 416-2067 KLR | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN RM 51-NOT COOLING-SBE JONES KLR | 8/15/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | A/C IN RMS 8 & MAIN OFC-NOT COOLING-PLANT MGR JONES 416-3781 KLR | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | portable #11 not cooling per Ms. Jones 416-9034 | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Unit NOT COOLING in Room 57 per Ms. Jones, Plant Mgr. 416.3781 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|--|--|---------------------------------------|
| Chimneyrock ES (2049) 2A | portable 11 and the library is very cold per Ms. Jones 416-3781 | 11/7/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | 2-RTU NOT HEATING IN RM-19,21 PLANT MGR-JONES/416.2067 | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | 2-RTU NOT HEATING IN RM-43,23. PLANT MGR-JONES/416.2067 | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | HEAT RM 35-NOT HEATING- PLANT MGR JONES 416-3781 KLR | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Units NOT COMING ON in ROOMS 19, 21, 23, AND 35 per Ms. Jones, Plant Mgr. 416.3781. | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Rooftop unit is NOT HEATING in ROOM 19 per Ms. Jones, Plant Mgr. 416.2067 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Portable #14 blowing cold air per Ms. Jones 416-3781 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | RTU IS OVERHEATING IN CAFE PLANT MGR-JONES/416.2067 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|----------|-----------|-----------------|---------------------------------------|
| Chimneyrock ES (2049) 2A | Monthly - Filters - Chimneyrock Elementary - Refer to PM schedule details. | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Monthly - Filters - Chimneyrock Elementary - Refer to PM schedule details. | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Monthly - Filters - Chimneyrock Elementary - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Chimneyrock ES (2049) 2A | Main - Entrance hallway needs painting paint peeling off the wall. | 11/4/13 | 1st Floor | Main - Entrance | Painting |
| Chimneyrock ES (2049) 2A | To cut water fountain on/off handle is broken on green hallway and front entrance hallway. | 5/2/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Request back-flow test. | 5/6/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Drinking fountain in cafeteria constantly on want turn off. | 6/17/14 | Cafeteria | | Plumbing |
| Chimneyrock ES (2049) 2A | Toilet in girls restroom constantly running also toilet in kitchen. | 6/17/14 | Gym | | Plumbing |

| | | | | | |
|--------------------------|---|----------|-----------------|---------------|----------|
| Chimneyrock ES (2049) 2A | A/C RM 50-LEAKING-PLANT MGR JONES 416-3027 KLR | 6/20/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | UNIT IS LEAKING IN THE CAFE. SBE JONES 416- | 7/1/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Boys restroom needs a flush valve water constanly running | 7/9/13 | Restroom (Boys) | green hallway | Plumbing |
| Chimneyrock ES (2049) 2A | Sink in hallway not working | 7/9/13 | | green hallway | Plumbing |
| Chimneyrock ES (2049) 2A | REAL BAD SEWER SMELL AT THE FRONT ENTRANCE OF BLDG PER SBE-SBE JONES 416- 3781 KLR | 8/8/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Water will not turn off.(Water fountain) | 8/9/13 | Gym | | Plumbing |
| Chimneyrock ES (2049) 2A | Kindergarten green hall water fountains are leaking(2) | 12/16/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Orange hall boys restroom toilet stopped up | 12/16/13 | | | Plumbing |

| | | | | | |
|--------------------------|---|----------|------------------|----------------|----------|
| Chimneyrock ES (2049) 2A | GAS SMELL THRU BLDG. PLANT MGR-JONES/416.2067 | 12/19/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Preform back flow test. | 12/23/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Water faucet outside constanly dripping. | 1/6/14 | | OUTSIDE | Plumbing |
| Chimneyrock ES (2049) 2A | WATER TANK IS LEAKING WATER IN BOOK RM PLANT MGR-JONES/416.2067 | 1/16/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | STEAMTABLE KITCHEN AREA- PILOT NEED TO LIT-PLANT MGR JONES 416-3781 KLR | 1/28/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | per ms jones 416-3781 the kitchen sink is leaking water from underneath | 2/10/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Water constanly running. | 4/2/14 | 1st Floor | yellow hallway | Plumbing |
| Chimneyrock ES (2049) 2A | Second commode water constanly running. | 4/3/14 | Restroom (Girls) | yellow hall | Plumbing |

| | | | | | |
|--------------------------|--|---------|------------------|----------------------|----------|
| Chimneyrock ES (2049) 2A | GAS SMELL in the KITCHEN AREA per Ms. Jones, Plant Mgr. 416.3781 | 4/7/14 | | | Plumbing |
| Chimneyrock ES (2049) 2A | There is a need for a flush valve. | 8/19/13 | 1st Floor | Teacher lounge (men) | Plumbing |
| Chimneyrock ES (2049) 2A | Toilet need a flush valve.(water running) | 8/23/13 | Restroom (Girls) | yellow hall | Plumbing |
| Chimneyrock ES (2049) 2A | Sink water constanly running. | 8/23/13 | 1st Floor | yellow hall | Plumbing |
| Chimneyrock ES (2049) 2A | Sink in girls restroom constanly running. | 8/27/13 | 1st Floor | | Plumbing |
| Chimneyrock ES (2049) 2A | AC CAFE AREA-LEAKING-PLANT MGR JONES 416-2067 KLR | 9/4/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | SEWER GAS SMELL IN BLDG COMING FROM DUMPSTER AREA PER SBE-PLANT MGR JONES 416-2067 KLR | 9/4/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Sink in boys restroom not working | 9/4/13 | 1st Floor | yellow hall | Plumbing |

| | | | | | |
|--------------------------|--|----------|---------------------|-------------|----------|
| Chimneyrock ES (2049) 2A | Ladies toilet constanly running | 9/6/13 | Kitchen | restroom | Plumbing |
| Chimneyrock ES (2049) 2A | Water fountain not working. | 9/10/13 | Gym | | Plumbing |
| Chimneyrock ES (2049) 2A | Water fountain water will not turn off. | 9/17/13 | Gym | | Plumbing |
| Chimneyrock ES (2049) 2A | Water constanly dripping from faucet. | 10/15/13 | Kitchen | | Plumbing |
| Chimneyrock ES (2049) 2A | Toilet in principal office constanly running. | 10/18/13 | Administration Area | Restroom | Plumbing |
| Chimneyrock ES (2049) 2A | there is a leak in teacher's lounge pipe in ceiling - per Ms. Jones 416-3781 | 10/29/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Sunk in hallway leaking water from the bottom. | 10/30/13 | 1st Floor | yellow hall | Plumbing |
| Chimneyrock ES (2049) 2A | Sink leaking in restroom at the bottom. | 10/31/13 | Gym | Girls | Plumbing |

| | | | | | |
|--------------------------|---|----------|-----------|-------------|----------|
| Chimneyrock ES (2049) 2A | Handle broke on toilet. | 10/31/13 | Gym | Boy | Plumbing |
| Chimneyrock ES (2049) 2A | Girls toilet stopped up. | 10/31/13 | 1st Floor | girls | Plumbing |
| Chimneyrock ES (2049) 2A | WATER IS LEAKING FROM FLR IN RM-20. PLANT MGR-JONES/416.2067 | 11/1/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | install gas pipe to library and cafe a/c units | 11/12/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | SEWER SMELL ON YELLOW HALL PER SBE-PLANT MGR JONES 416-2067 KLR | 11/14/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | WALL IS LEAKING WATER ONTO FLR IN RM-20 PLANT MGR-JONES/416.2067 | 11/18/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Boys Restroom water leaking from flush valve. | 11/18/13 | 1st Floor | yellow hall | Plumbing |
| Chimneyrock ES (2049) 2A | Water leaking from water fountain (Big puddle everymorning on floor) | 11/18/13 | 1st Floor | Red hallway | Plumbing |

| | | | | | |
|--------------------------|---|----------|-----------|------------------|----------|
| Chimneyrock ES (2049) 2A | Water leaking at the front entrance door of the GYM per Ms. Jones, Plant Mgr. 416.3781. | 11/25/13 | | | Plumbing |
| Chimneyrock ES (2049) 2A | Water fountain stopped up... | 12/4/13 | 1st Floor | Green Hallway | Plumbing |
| Chimneyrock ES (2049) 2A | Roof leaking . | 1/9/14 | 1st Floor | Green hall 26,18 | Roof |
| Chimneyrock ES (2049) 2A | water leaking in classroom | 3/17/14 | 1st Floor | green hall 30-k | Roof |
| Chimneyrock ES (2049) 2A | Leak in cafeteria. | 8/19/13 | Cafeteria | | Roof |

| Count of Craft | Craft | | | |
|--------------------------------|-----------|------------|------|-------------|
| Location | Carpentry | Electrical | HVAC | Grand Total |
| Colonial Hearing Ctr (8012) 2B | 4 | 2 | 7 | 13 |
| Grand Total | 4 | 2 | 7 | 13 |

| Location | Request Description | Submittal Date | Area Descript | Area Number | Craft |
|-----------------------------------|---|-----------------------|------------------------|---------------------|--|
| Colonial Hearing Ctr (8012) 2B | The entrance gate needs to be repaired. It is dangling. | 10/22/13 | Grounds | Entrance/ Southeast | Carpentry |
| Colonial Hearing Ctr (8012) 2B | The bus entrance sign has been rolled over by a vehicle. Need to have it reattached to the ground at the main entrance. | 1/13/14 | Grounds | Main entrance | Carpentry |
| Colonial Hearing Ctr (8012) 2B | The panic bar needs to be replaced on the electronic door. Was determined by tech that new bar was needed. | 9/6/13 | Administration Area | Main door | Carpentry |
| Colonial Hearing Ctr (8012) 2B | The main door will not close all the way when buzzing someone in the building. | 10/21/13 | Administration Area | Main entrance | Carpentry |
| Colonial Hearing Ctr (8012) 2B | fire alarm panel box lock cylinder is broken and cannot lock or unlock per Mr. Hardman 416-8940 | 11/18/13 | | | Electrical |
| Colonial Hearing Ctr (8012) 2B | PULL STATION LOCK IS BROKEN MAIN ENTRY. PLANT MGR-HARDMAN/416.8980 | 3/24/14 | | | Electrical |
| Colonial Hearing Ctr (8012) 2B | Roof top unit #94 blowing cold air per Mr. Hardman 416-8980 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------------------|---|--------|--|--|--|
| Colonial Hearing Ctr (8012) 2B | per Mr. Hardman 416-8980 RTU #94 for warehouse is blowing cold air | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Hearing Ctr (8012) 2B | RTU-94 WAREHOUS AREA-NOT HEATING-PLANT MGR HARDMAN 416-8980 KLR | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Hearing Ctr (8012) 2B | Roof Top #93 for Administration Area not cooling per Mr. Hardman 416-8940 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Hearing Ctr (8012) 2B | Roof top unit #93 for Administration area not cooling per Mr. Hardman 416- 8940 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Hearing Ctr (8012) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Hearing Ctr (8012) 2B | Yearly - Boiler 001 - Colonial Hearing Ctr - Refer to PM schedule details. | 3/8/14 | | | Heating/Ventilation /Air Conditioning |

| Count of Craft | Craft | | | | | | | | |
|---------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| onial Middle (2115) | 1 | 16 | 39 | 43 | 5 | 20 | 6 | 2 | 132 |
| Grand Total | 1 | 16 | 39 | 43 | 5 | 20 | 6 | 2 | 132 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------------|--|-----------------------|-------------------------|-------------------------------|--------------|
| Colonial Middle (2115) 2B | Request for the gym floor to be redone. | 10/11/13 | Gym | Floor | Asbestos |
| Colonial Middle (2115) 2B | Request for the door to the laundry room to be adjusted. It will drag when opened. | 2/4/14 | Cafeteria | Laundry room | Carpentry |
| Colonial Middle (2115) 2B | Request for the door closure to be repaired to the door leading into the Auditorium from the custodial hall. | 2/4/14 | Auditorium | Side door cust hall | Carpentry |
| Colonial Middle (2115) 2B | The door closure on the electronic Handicapped door needs to be adjusted. The door will not close all the way when opened. | 2/14/14 | 1st Floor | Main Entrance | Carpentry |
| Colonial Middle (2115) 2B | The main door will not open. Crash bar will not open all the way when button is used. | 8/27/13 | Administration Area | Main doors | Carpentry |
| Colonial Middle (2115) 2B | The gate is dangling at this entrance to the campus. Was hit by a car. | 11/22/13 | Grounds | Back entrance | Carpentry |
| Colonial Middle (2115) 2B | The door will drag when you try to close it. | 10/22/13 | 2nd Floor | G-Hall Teacher lounge/ Female | Carpentry |

| | | | | | |
|------------------------------|--|---------|---------------------|----------------------------------|-----------|
| Colonial Middle (2115) 2B | Need electronic door closure adjusted. Door will not close all the way on its own. | 8/12/13 | 1st Floor | Main door | Carpentry |
| Colonial Middle (2115) 2B | The electronic door needs a new crash bar installed. Will only click if used or sometimes open randomly. Was checked by tech and crash bar was determined to be problem. | 8/12/13 | 1st Floor | Teachers entrance | Carpentry |
| Colonial Middle (2115) 2B | The door knob needs to be repaired entering this area. | 8/2/13 | Auditorium | entrance(right door) | Carpentry |
| Colonial Middle (2115) 2B | The door knob to the right needs to be repaired. | 8/2/13 | Administration Area | Main office | Carpentry |
| Colonial Middle (2115) 2B | The handicapp entrance door needs the closure adjusted. The door will not close when used. | 5/1/14 | 1st Floor | Main entrance | Carpentry |
| Colonial Middle (2115) 2B | The entrance gate needs to be repaired. It is dangling on the left side entering campus. | 5/19/14 | Grounds | Southeast entrance | Carpentry |
| Colonial Middle (2115) 2B | The door handle to the left side, needs to be repaired. entering this hall from the main hall. | 5/27/14 | 1st Floor | Band hall entrance/ left door | Carpentry |
| Colonial Middle (2115) 2B | Request for the broken cabinets under the lab tables to be repaired at the broken hinges, or sealed permanently. | 5/28/14 | 2nd Floor | Science lab/ F-hall / 229 | Carpentry |

| | | | | | | |
|------------------------------|---|---------|---------------------|-------------------|--|------------|
| Colonial Middle (2115) 2B | repair fence car ran thru it- os | 2/27/14 | | | | Carpentry |
| Colonial Middle (2115) 2B | Need a new rolling wheel installed on the gate at the main entrance. Gate will drag if opened. | 3/24/14 | Grounds | Main entry gate | | Carpentry |
| Colonial Middle (2115) 2B | Replace parking lot lighting with LED fixtures. | 2/27/14 | | | | Electrical |
| Colonial Middle (2115) 2B | Need a ground plug removed from a computer cart power strip. Will spark when plugged In. | 1/7/14 | 1st Floor | B-142 | | Electrical |
| Colonial Middle (2115) 2B | Request for the blown bulbs In the gym to be changed. | 1/17/14 | Gym | Gym | | Electrical |
| Colonial Middle (2115) 2B | As per conversation with Mr. Anthony Krone Request for the the computer carts with power strip fault to be repaired. They are In the following rooms. A-148, A-150, A-151, A-154 | 1/21/14 | Classroom | See list | | Electrical |
| Colonial Middle (2115) 2B | The lights are going out at 9pm In the evenings. Need the timers changed to 11pm. | 2/7/14 | Administration Area | Interior of bldg | | Electrical |
| Colonial Middle (2115) 2B | The Is a prong broken off In the electrical receptacle In this room. Need to have removed. | 2/12/14 | 1st Floor | Behind desk/A-127 | | Electrical |

| | | | | | |
|------------------------------|--|----------|---------------------|-----------------|------------|
| Colonial Middle (2115) 2B | Fire Alarm in trouble. | 2/20/14 | Administration Area | | Electrical |
| Colonial Middle (2115) 2B | The outlet on the west wall will not work. It is under the smart board. | 8/15/13 | Library | West wall | Electrical |
| Colonial Middle (2115) 2B | Request a box of T8 lamps for the auditorium lighting to be changed. | 11/15/13 | Auditorium | Ceiling | Electrical |
| Colonial Middle (2115) 2B | Request for the recess lights to be changed Inside at the front entrance and outside the auditorium. | 11/19/13 | 1st Floor | Main corridor | Electrical |
| Colonial Middle (2115) 2B | Several bulbs need to be changed on the exterior of building and parking lot. See Plant manager for locations. | 9/6/13 | Grounds | campus | Electrical |
| Colonial Middle (2115) 2B | Request for the bulbs to be changed at the main entrance under the canopy. | 10/2/13 | Grounds | Main entrance | Electrical |
| Colonial Middle (2115) 2B | Assist Siemens trace cable for energymagament. | 10/17/13 | | | Electrical |
| Colonial Middle (2115) 2B | Request for 5 led lights to be changed on the exterior of the building. Most are in the rear. | 10/24/13 | Grounds | behind building | Electrical |

| | | | | | |
|------------------------------|--|----------|---------------------|----------------------|------------|
| Colonial Middle (2115) 2B | Request for the street light to be changed in this area. | 10/24/13 | Grounds | Cafeteria dock area | Electrical |
| Colonial Middle (2115) 2B | Need the lights changed at the Cafeteria worker entrance at the back dock. | 10/29/13 | Cafeteria | Cafeteria back dock | Electrical |
| Colonial Middle (2115) 2B | Request for the lights to be changed at the before care entrance down to the band hall entrance. All are blown | 11/4/13 | Cafeteria | Before care entrance | Electrical |
| Colonial Middle (2115) 2B | Power outage check equipment after power restored. | 8/6/13 | | | Electrical |
| Colonial Middle (2115) 2B | Total power outage, reset main and check equipment after power has been restored. | 8/6/13 | | | Electrical |
| Colonial Middle (2115) 2B | need clock in main office reset after a power surge | 7/2/13 | Administration Area | | Electrical |
| Colonial Middle (2115) 2B | lights out in main hall in front of main office | 7/5/13 | 1st Floor | | Electrical |
| Colonial Middle (2115) 2B | lights out in hallway in front of cafeteria | 7/5/13 | 1st Floor | | Electrical |

| | | | | | |
|------------------------------|--|---------|-----------|----------------------|------------|
| Colonial Middle (2115) 2B | lights out on northeast hall in front of gym | 7/5/13 | 1st Floor | | Electrical |
| Colonial Middle (2115) 2B | Relamp stage lights and stage house lights. per os | 7/10/13 | | | Electrical |
| Colonial Middle (2115) 2B | UNIT NOT COMING ON IN AUDIT (NO ID). ZONE MAN-BEAN/606-2780 | 7/15/13 | | | Electrical |
| Colonial Middle (2115) 2B | UNIT IN THE G229 IS NOT COMING ON -SBE BROWN 416-8980 | 7/29/13 | | | Electrical |
| Colonial Middle (2115) 2B | electrical outlet for refridg. & hot box kicked out will not reset | 7/30/13 | Kitchen | | Electrical |
| Colonial Middle (2115) 2B | The lighting poles on the north side of the campus are all out In addition to the two on the back of the campus In front of the cafeteria. | 4/7/14 | Grounds | North campus grounds | Electrical |
| Colonial Middle (2115) 2B | RTU-51 in Room B109 is NOT COMING ON per Mr. Hardman, Plant Mgr. 416.8980 | 4/7/14 | | | Electrical |
| Colonial Middle (2115) 2B | Request for a new thermostat, and cover box to be installed. | 4/26/14 | Gym | Northeast wall | Electrical |

| | | | | | |
|------------------------------|--|----------|---------------------|----------------------------------|------------|
| Colonial Middle (2115) 2B | Request a box of lamps for lighting to be changed. (F32T8/ADV841/EW) | 5/13/14 | Administration Area | plant manager | Electrical |
| Colonial Middle (2115) 2B | The electrical outlet is not working below the scoreboard. | 5/19/14 | Grounds | Scoreboard/ electrical outlet | Electrical |
| Colonial Middle (2115) 2B | Request four bulbs to be changed in this area. | 3/2/14 | Administration Area | Inside main entrance | Electrical |
| Colonial Middle (2115) 2B | Request for the interior lights to go off at 10.30 pm in the evenings. They are going off at 9:00 currently. | 12/12/13 | Administration Area | Interior of bldg | Electrical |
| Colonial Middle (2115) 2B | Request for the lighting on the grounds to come on at 4:00 pm. They are currently coming on at 5:30 pm. | 12/12/13 | Grounds | Campus | Electrical |
| Colonial Middle (2115) 2B | Request for the blown exterior lights to be changed. See plant manager for locations. | 3/17/14 | Grounds | Grounds | Electrical |
| Colonial Middle (2115) 2B | There is a street light across from the cafeteria dock that needs to be changed in this area. | 12/10/13 | Grounds | across from Cafeteria dock | Electrical |
| Colonial Middle (2115) 2B | Request for the blown bulbs to be changed in this area. | 11/10/13 | Auditorium | ceiling lamps | Electrical |

| | | | | | |
|------------------------------|---|----------|-----------|-----------|---------------------------------------|
| Colonial Middle (2115) 2B | The back dock lighting are completely blown on the dock. It is completely dark In this area ,and the before and aftercare entrance as well. | 11/14/13 | Cafeteria | Back dock | Electrical |
| Colonial Middle (2115) 2B | RTU - RM B109 - NOT COMING ON & THERMOSTAT IS NOT WORKING -PM/HARDMAN 416-8980 | 5/5/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | ROOFTOP (#53) is NOT COOLING in ROOM S232 per Mr. Hardman, Plant Mgr. 416.8980 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-41 RM B113 & RTU-57 RM F204-BOTH NOT COOLING-PLANT MGR HARDMAN 416-8980 KLR | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Unit not cooling thru coaches' gym plant mgr- Hardman/416.8980 | 6/19/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Request for a new thermostat for this room. Led screen Is burned out on current one and cannot adjust temps. | 12/10/13 | 2nd Floor | f-220 | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU - #7 AUDITORIUM - NOT COMING ON - PM/HARDMAN 416-8980 | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Monthly - Filter-Colonial Middle - Refer to PM schedule details. | 4/5/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|--|---------|-----|-----------------|---------------------------------------|
| Colonial Middle (2115) 2B | Request for a new thermostat to be Installed In this area. | 8/5/13 | Gym | North east wall | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | have contractor repair rooftops. not to exceed \$5000.00 | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Monthly - Filter-Colonial Middle - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU #53 F232 blowing hot air, RTU #1 C103 blowing hot air per Mr. Hardman 416-8980 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-53 RM F232, RTU-91 RM C140 FOOTBALL LOCKER RM & RTU-1 RM C103-ALL NOT COOLING-SBE HARDMAN 416-8980 KLR | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Monthly - Oil Lube & Belt-Colonial Middle - Refer to PM schedule details. | 1/4/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | per Mr. Hardman 416-8980 RTU #82 for room F219 , RTU #83 for F stairwell both are blowing cold air | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | per Mr. hardman 416-8980 rooms F202 and A161 are blowing cold air | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|---|---------|--|--|--|
| Colonial Middle (2115) 2B | per Mr. Hardman 416-8980 room F217 is not coming on no heat | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU#27 NOT HEATING IN RM-G218 PLANT MGR- HARDMAN/416.8980 | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-57 RM F204, RTU-75- A152, & RTU-60 RM F206- ALL NOT HEATING-PLANT MGR HARDMAN 416-8980 KLR | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU#71 NOT HEATING IN RM-A154, & RTU#75 IS OVERHEATING (90) IN RM- A152 PLANT MGR- WHARWOOD/416.2104 | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU#55 NOT HEATING IN RM-F202,& RTU#82 IN RM- F219 PLANT MGR- HARDMAN/416.8980 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU#91 NOT HEATING IN FOOTBALL LOCKER RM PLANT MGR- HARDMAN/652.4926 | 2/3/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | F217 RTU# 78 the unit is running on roof but the t'stat is not working therefore there is no a/c in the room per Mr. Hardman 416-8980 also RTU #91 C140 football locker room compressor will not come on | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-53 SERVES RM F232 & RTU-1 SERVES RM C103- BOTH NOT COOLING-SBE HARMAN 416-8980 KLR | 8/19/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|--|----------|--|--|---------------------------------------|
| Colonial Middle (2115) 2B | RTU - RM F204 - BLOWING NOT HEATING - PM/HARDMAN 416-8980 | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-82 RM 219-NOT COOLING-PLANT MGR 416- 8980 KLR | 9/18/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU's NOT COMING ON in the MAIN OFFICE, GYM, AUDITORIUM, ALL MAIN HALLS, AND THE LIBRARY per Mr. Hardman, Plant Mgr. 416.8980 | 10/10/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Monthly - Air Compressor- Colonial Middle - Refer to PM schedule details. | 7/1/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Air Handler Unit which controls the Cafeteria is NOT COOLING per Darrell Olive at 901.416.1179! | 7/11/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU NOT COMING ON IN AUDIT. SBE-BROWN/416-2104 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | UNIT IN THE AUDIT. IS NOT COOLING. SBE BROWN 416- | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | UV NOT COOLING IN RM- 116. PLANT MGR-BROWN/8980 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|--|----------|--|--|--|
| Colonial Middle (2115) 2B | UNIT IN THE AUDIT. & LIBRARY IS NOT COOLING. SBE BROWN 416-8988 | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU - #82 - COVERS RM219 - FAN IS LOCK AND THE COMPRESSOR WON'T COME ON - PM/HARDMAN 416-8980 | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU#55 NOT HEATING IN RM-F204 PLANT MGR- WHARWOOD/416.8980 | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Monthly - Air Compressor- Colonial Middle - Refer to PM schedule details. | 12/30/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU NOT COOLING IN RM- G206. PLANT MGR- HARDMAN/416.8980 | 3/19/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-91 RM C135-NOT COMING ON-PLANT MGR HARDMAN 416-8980 KLR | 3/21/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | RTU-59 SERVES RM A157 & RTU-81 SERVES RM F217-BOTH NOT COOLING- PLANT MGR HARDMAN 416-8980 KLR | 4/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|---|---------|-----|--|---------------------------------------|
| Colonial Middle (2115) 2B | RTU'S RMS G218, A137, A152, F204, C103, GYM & F206-ALL NOT HEATING-PLANT MGR HARDMAN 416-8980 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Monthly - Filter-Colonial Middle - Refer to PM schedule details. | 12/7/13 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Yearly - Fire Boiler #129 - Colonial Middle - Refer to PM schedule details. | 3/9/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | Yearly - Fire Boiler #162 - Colonial Middle - Refer to PM schedule details. | 3/10/14 | | | Heating/Ventilation /Air Conditioning |
| Colonial Middle (2115) 2B | need gym floor refinished | 7/6/13 | Gym | | Painting |
| Colonial Middle (2115) 2B | paint lines on football field | 9/5/13 | | | Painting |
| Colonial Middle (2115) 2B | paint lines on football field | 8/2/13 | | | Painting |
| Colonial Middle (2115) 2B | paint lines on football field | 5/12/14 | | | Painting |

| | | | | | |
|------------------------------|---|---------|------------------|--------------------|----------|
| Colonial Middle (2115) 2B | Request for the front entrance grounds to be power washed for gum removal. | 5/22/14 | Grounds | Front entrance | Painting |
| Colonial Middle (2115) 2B | Request for a toilet seat to be installed in the first commode. The seat was broken and thrown away. | 1/31/14 | Restroom (Boys) | F-Hall | Plumbing |
| Colonial Middle (2115) 2B | The pipe will leak from under the sink when the water is cut on in this room. | 2/5/14 | 2nd Floor | Science Lab/ F-232 | Plumbing |
| Colonial Middle (2115) 2B | The water to the sink will not release. | 2/26/14 | Cafeteria | Main sink | Plumbing |
| Colonial Middle (2115) 2B | The hot water handle to the sink to the far left will make a loud noise when cut on. | 8/23/13 | Restroom (Boys) | G-hall | Plumbing |
| Colonial Middle (2115) 2B | The water will continue to run at random if the toilet is flushed. | 8/23/13 | Restroom (Girls) | Handicapp stall | Plumbing |
| Colonial Middle (2115) 2B | Request for the student restroom hot water heater temps to cut down. The water is too hot in student restrooms. | 8/16/13 | Restroom (Girls) | Student restrooms | Plumbing |
| Colonial Middle (2115) 2B | Need a new toilet seat installed for the handicapp stall. | 8/21/13 | Restroom (Boys) | Gym | Plumbing |

| | | | | | |
|------------------------------|---|----------|-----------------|-----------|----------|
| Colonial Middle (2115) 2B | Winterize RP device . | 11/22/13 | | | Plumbing |
| Colonial Middle (2115) 2B | Winterize RP device . | 11/22/13 | | | Plumbing |
| Colonial Middle (2115) 2B | The Handicapp stall commode will not flush. | 9/9/13 | Restroom (Boys) | Gym | Plumbing |
| Colonial Middle (2115) 2B | The urinal pipe Is broken. Needs to be repaired. | 9/10/13 | Restroom (Boys) | G-hall | Plumbing |
| Colonial Middle (2115) 2B | The cold water faucet handle needs to be repaired. Will not cut off from this point. | 9/12/13 | Cafeteria | Prep area | Plumbing |
| Colonial Middle (2115) 2B | The three urinal pipes are all very loose on the necks. The one to the far left will splash water from the rear when flushed. | 4/8/14 | Restroom (Boys) | F-hall | Plumbing |
| Colonial Middle (2115) 2B | URINAL PIPE IS LEAKING WATER IN B/RR F-HALL PLANT MGR- HARDMAN/652.4926 | 4/10/14 | | | Plumbing |
| Colonial Middle (2115) 2B | GARBAGE DISOPAL will NOT DRAIN per Hardman, Plant Mgr. 416.8980 | 5/23/14 | | | Plumbing |

| | | | | | |
|------------------------------|---|----------|------------------|------------------------------------|----------|
| Colonial Middle (2115) 2B | This commode will spray water from the back when flushed. | 3/25/14 | Restroom (Girls) | G-hall first commode | Plumbing |
| Colonial Middle (2115) 2B | The water fountain has become detached from the wall. Needs to be reattached. | 3/25/14 | 1st Floor | Water fountain/ left of auditorium | Plumbing |
| Colonial Middle (2115) 2B | The handicap commode will not flush. | 4/2/14 | Restroom (Boys) | G-hall | Plumbing |
| Colonial Middle (2115) 2B | Urinal over flowing can't contain. | 4/3/14 | | | Plumbing |
| Colonial Middle (2115) 2B | The pipe above the urinal is loose. It is the middle urinal. | 12/10/13 | Restroom (Boys) | G-hall | Plumbing |
| Colonial Middle (2115) 2B | The roof is leaking in front of room C-120. | 11/22/13 | 1st Floor | C-hall | Roof |
| Colonial Middle (2115) 2B | down spout on north end of building near glass doors not flowing | 7/31/13 | | | Roof |
| Colonial Middle (2115) 2B | The roof leaks on this hall when it rains at two locations. | 3/29/14 | Hallway/Corridor | C-hall | Roof |

| | | | | | |
|------------------------------|--|----------|------------------|--------------------------|-------------|
| Colonial Middle (2115) 2B | The roof leaks In this area when It rains | 3/29/14 | Hallway/Corridor | D-hall in front of D-132 | Roof |
| Colonial Middle (2115) 2B | These three areas has water leaks due to rain. See SBE for exact locations. | 6/29/14 | 1st Floor | C-hall,Gym, Aud stage | Roof |
| Colonial Middle (2115) 2B | The roof Is leaking on this hall In front of these rooms | 6/9/14 | 1st Floor | C-hall/ C-122,C-123 | Roof |
| Colonial Middle (2115) 2B | The gate post at this entrance Is leaning along with gate. Was hit by a car. | 8/14/13 | Grounds | Southeast entrance | Sheet Metal |
| Colonial Middle (2115) 2B | Request for the bench to be reattached to floor. Sbe has bench | 11/21/13 | Gym | Boys/ Locker room | Sheet Metal |

| Count of Craft | Craft | |
|---------------------------------|-------|-------------|
| Location | HVAC | Grand Total |
| Colonial Visually Ltd (8193) 2B | 1 | 1 |
| Grand Total | 1 | 1 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|------------------------------------|--|----------------|------|-------------|-------------|--|
| Colonial Visually Ltd (8193) 2B | CHANGE FROM HEAT TO A/C REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | | Heating/Ventilation /Air Conditioning |

| Count of Craft | Craft | | | | | | | | |
|--------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| ordova El (2117) 2 | 2 | 4 | 8 | 25 | 17 | 1 | 17 | 5 | 79 |
| Grand Total | 2 | 4 | 8 | 25 | 17 | 1 | 17 | 5 | 79 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|----------------------|---|---------------|---------------------|--------------------------|-----------|
| Cordova EI (2117) 2A | insulate pipes in boiler room | 1/30/14 | Mechanical Room | bioler rm. | Asbestos |
| Cordova EI (2117) 2A | Parts of the playground needs to be re-surfaced. | 3/18/14 | Grounds | Kindergarten play ground | Asbestos |
| Cordova EI (2117) 2A | Please repair drop #2 IDF #1 cat 6 jack is broken 4th grade hall C-206 | 6/16/14 | | | Cabling |
| Cordova EI (2117) 2A | #2 IDF#1 CAT6 is broken. 4th grade hall C-206 | 2/27/14 | Classroom | 4th grade hall C-206 | Cabling |
| Cordova EI (2117) 2A | Cordova ei -wo373782-373782-Computer#5 IDF#1 Cat 6 is broken, We need help thanks.(Request Network Cabling Maintenance Repair). Request received and will receive support as soon as | 8/12/13 | Classroom | 2nd hall E-204 | Cabling |
| Cordova EI (2117) 2A | This room need 25 computer drops it is to be the new computer lab. Can you help us figure this out? | 9/10/13 | Classroom | 3rd hall D213 | Cabling |
| Cordova EI (2117) 2A | When we buzz people into the building the door is not closing. | 4/25/14 | Administration Area | The front entrance door | Carpentry |
| Cordova EI (2117) 2A | Difficult securing door at closing time, door mechanism sticks. | 4/25/14 | Gym | Gym exterior door 103 | Carpentry |

| | | | | | |
|----------------------|---|---------|---------------------|------------------|------------|
| Cordova EI (2117) 2A | The door mechanism is sticking, making it hard to exit. | 4/30/14 | Classroom | 6th hall K-7 | Carpentry |
| Cordova EI (2117) 2A | Exit door will not close properly when exiting. | 5/20/14 | Hallway/Corridor | K-wing Exit door | Carpentry |
| Cordova EI (2117) 2A | It rains through window sill into classroom. | 4/7/14 | Classroom | 1st grade B-204 | Carpentry |
| Cordova EI (2117) 2A | The door closer mechanism has broken. | 9/16/13 | Hallway/Corridor | K-wing exit door | Carpentry |
| Cordova EI (2117) 2A | The door closer mechanism is broken. | 12/9/13 | Library | Admin area 102 | Carpentry |
| Cordova EI (2117) 2A | Door closer mechanism is broken. | 12/9/13 | Administration Area | 100C | Carpentry |
| Cordova EI (2117) 2A | Fire alarm panel reading low battery | 4/9/14 | | | Electrical |
| Cordova EI (2117) 2A | Cannot reset alarm panel, cause dirty smoke detector. | 5/30/14 | Classroom | Gallery A A-206 | Electrical |
| Cordova EI (2117) 2A | Need 2 boxes of T8 long tube bulbs. | 6/25/14 | 1st Floor | Entire plant | Electrical |

| | | | | | |
|----------------------|---|---------|---------------------|----------------------|------------|
| Cordova EI (2117) 2A | Need 2 boxes of T8 long tube bulbs. | 1/16/14 | 1st Floor | Entire Plant | Electrical |
| Cordova EI (2117) 2A | Light out above teacher's desk, Bad ballast. | 2/25/14 | Classroom | 4th grade hall C-207 | Electrical |
| Cordova EI (2117) 2A | Master clock need to be set forward. | 3/10/14 | Administration Area | Main Office 100 N | Electrical |
| Cordova EI (2117) 2A | Light switch is sparking. | 3/20/14 | Classroom | 4th grade C-210 | Electrical |
| Cordova EI (2117) 2A | Wall outlet blown. | 3/20/14 | Classroom | 4th grade C210 | Electrical |
| Cordova EI (2117) 2A | Working for Energy Managment. | 7/22/13 | | | Electrical |
| Cordova EI (2117) 2A | The master clock needs to be set, THANKS. | 7/26/13 | Administration Area | Rm.100 | Electrical |
| Cordova EI (2117) 2A | The emergency light is buzzing, and is battery acid leaking . Need help thanks. | 8/12/13 | Hallway/Corridor | 1st grade | Electrical |
| Cordova EI (2117) 2A | 8 Boxes of T-80 tube light bulbs. | 9/25/13 | 1st Floor | Total plant area | Electrical |

| | | | | | |
|----------------------|---|----------|------------------|-----------------------|------------|
| Cordova EI (2117) 2A | There are four large bulbs blown out. | 10/3/13 | Cafeteria | Cafeteria 101 | Electrical |
| Cordova EI (2117) 2A | Bad ballast in light fixture. | 10/18/13 | Mechanical Room | Plant Mgr. Office 113 | Electrical |
| Cordova EI (2117) 2A | CHILL WATER PUMP-5 MECH RM-CAUGHT ON FIRE HAS SHUT EVERYTHING DOWN PER SBE-PLANT MGR CLARK 416-1707 KLR | 10/21/13 | | | Electrical |
| Cordova EI (2117) 2A | Emergency light out per Fire Marshal. | 11/1/13 | Hallway/Corridor | Outside library 102A | Electrical |
| Cordova EI (2117) 2A | Emergency light out per Fire Marshal. | 11/1/13 | Kitchen | Kichen | Electrical |
| Cordova EI (2117) 2A | Emergency light out per Fire Marshal. | 11/1/13 | Hallway/Corridor | 4th hall | Electrical |
| Cordova EI (2117) 2A | Emergency light out per Fire Marshal. | 11/1/13 | Hallway/Corridor | 2nd hall | Electrical |
| Cordova EI (2117) 2A | Emergency light out per Fire Marshal. | 11/1/13 | Hallway/Corridor | 1st hall | Electrical |
| Cordova EI (2117) 2A | Emergency light out per Fire Marshal. | 11/1/13 | Mechanical Room | Main Elec. 111M6 | Electrical |

| | | | | | |
|----------------------|--|---------|---------------------|--------------------|---------------------------------------|
| Cordova EI (2117) 2A | Install emergency light in Pre-K classroom per Fire Marshal. | 11/1/13 | Classroom | Kindergarten A-205 | Electrical |
| Cordova EI (2117) 2A | Master clock needs to be set back 1 hour. | 11/4/13 | Administration Area | Front office 100 | Electrical |
| Cordova EI (2117) 2A | Bad ballast in light fixture. | 11/4/13 | Classroom | 4th hall C208 | Electrical |
| Cordova EI (2117) 2A | Need 2 boxes of T8 long tube bulbs. | 12/2/13 | 1st Floor | Entire Plant | Electrical |
| Cordova EI (2117) 2A | Fan Coil Unit is OVERHEATING in Room C200 per J.T. Clark, Plant Mgr. 416.1701 | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | DRAIN BOTTOM OF BOILER MECH RM-IS CRACKED AND LEAKING WATER PER SBE-PLANT MGR CLARK 416-1707 KLR | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | CHILLER MECH RM-KEEPS TRIPPING OFF-PLANT MGR CLARK 416-1707 KLR | 3/28/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | replace chemical in cooling tower | 4/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|----------|--|--|--|
| Cordova EI (2117) 2A | No a/c in main office Charles Truesdale 416-1700 | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | A wing and B wing have no a/c per J. T. Clark 416-1707 | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | A/C IN A WING-NOT COOLING ABOUT (10) RMS & B WING WING NOT COOLING ABOUT (7) RMS-SBE CLARK 416-1707 KLR | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Monthly - Oil Lube & Belt- Cordova Elementary - Refer to PM schedule details. | 12/7/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | AHU-2 SERVES C WING, AHU-3 SERVES B WING, AHU-4 SERVES E WING, & FCU RM C200-ALL ARE OVERHEATING, TEMP IS OVER 80 IN EACH- PLANT MGR CLARK 416-1703 KLR | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Monthly - Filter-Cordova Elementary - Refer to PM schedule details. | 12/15/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Monthly - Filter-Cordova Elementary - Refer to PM schedule details. | 8/18/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Yearly - Oil Samples-Cordova Elementary - Refer to PM schedule details. | 9/2/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Yearly - Cooling Towers(STRAINERS)-Cordova Elem - Refer to PM schedule details. | 3/2/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|---------|---------------------|---------------------|---------------------------------------|
| Cordova EI (2117) 2A | Daily - Cordova Elem Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Monthly - CORDOVA ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Monthly - Filter-Cordova Elementary - Refer to PM schedule details. | 4/13/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova EI (2117) 2A | Plaster is hanging from ceiling in atrium area. Also needs painting. | 4/8/14 | Administration Area | Outside library 102 | Painting |
| Cordova EI (2117) 2A | The hot water return pipe in the ceiling is leaking outside of principal's office. | 5/20/14 | Administration Area | Outside 100F | Plumbing |
| Cordova EI (2117) 2A | Repair water line in room #100. | 6/3/14 | | | Plumbing |
| Cordova EI (2117) 2A | Request pipe be installed near Room#100. Pipe is leaking on to the hallway. | 6/5/14 | | | Plumbing |
| Cordova EI (2117) 2A | FLOOR DRAIN KITCHEN AREA- BACKING UP-PLANT MGR TRUESDALE 416-1700 KLR | 1/17/14 | | | Plumbing |
| Cordova EI (2117) 2A | Ladies room sink has a leak underneath. | 2/25/14 | Restroom (Girls) | 3rd grade lounge | Plumbing |

| | | | | | |
|----------------------|--|---------|------------------|----------------------|----------|
| Cordova EI (2117) 2A | Sewer drain cap is broken, With 4 inch gaping hole. | 3/18/14 | Grounds | Outside B-200 | Plumbing |
| Cordova EI (2117) 2A | The sink faucet will not turn off, need help thanks. | 7/30/13 | Kitchen | kitchen 101C | Plumbing |
| Cordova EI (2117) 2A | Per J. T. Clark 416-1707 Rm A107 and E212 fan coil leaking | 7/31/13 | | | Plumbing |
| Cordova EI (2117) 2A | fan coil unit leaking in rm B203 ID042118 per JT Clark 416-1707 | 8/7/13 | | | Plumbing |
| Cordova EI (2117) 2A | Custodial closet sink water is spewing from top of faucet. | 8/7/13 | Custodial Closet | 3rd grade D203j | Plumbing |
| Cordova EI (2117) 2A | 3-FCU ARE LEAKING WATER IN RM-A05(105) RM-E202(163) RM-A200(102). PLANT MGR-CLARK/416.1700 | 8/8/13 | | | Plumbing |
| Cordova EI (2117) 2A | Back flow test. | 8/8/13 | | | Plumbing |
| Cordova EI (2117) 2A | Dripping middle faucet. | 8/12/13 | Restroom (Boys) | 1st grade hall B104T | Plumbing |
| Cordova EI (2117) 2A | FCU RM C211-LEAKING-PLANT MGR CLARK 416-1707 KLR | 9/4/13 | | | Plumbing |

| | | | | | |
|----------------------|---|----------|------------------|-----------------|----------|
| Cordova EI (2117) 2A | The water fountain is leaking from the bottom. | 10/11/13 | Cafeteria | Cafe 101 | Plumbing |
| Cordova EI (2117) 2A | Water is leaking into classroom, we placed buckets to catch the water. | 10/16/13 | Classroom | 4th Hall C-207 | Plumbing |
| Cordova EI (2117) 2A | Drain stopped up in kitchen per Mr. Clark, Plant Mgr. 416.1707 | 12/3/13 | | | Plumbing |
| Cordova EI (2117) 2A | There is water leaking over the ovens. | 5/14/14 | Kitchen | kitchen 101-C | Roof |
| Cordova EI (2117) 2A | Water leaking from 4 roof sections, And parts of ceiling falling, it flooded half of hallway. | 2/10/14 | Hallway/Corridor | Outside Library | Roof |
| Cordova EI (2117) 2A | Tar and water substance is running down the wall in classroom. | 8/15/13 | Classroom | 4th Grade C207 | Roof |
| Cordova EI (2117) 2A | Wet tar substance is leaking from the roof onto the floor and pianos. | 11/1/13 | Classroom | 2nd hall D205 | Roof |
| Cordova EI (2117) 2A | Tar and water is running from the ceiling onto the floor. | 11/1/13 | Classroom | 4th hall C207 | Roof |

| Count of Craft | Craft | | | | | | | | |
|----------------------|----------|----------|-----------|------------|------|----------|----------|------|-------------|
| | Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal |
| Cordova HS (2119) 2A | 2 | 18 | 56 | 54 | 2 | 74 | 6 | 2 | 214 |
| Grand Total | 2 | 18 | 56 | 54 | 2 | 74 | 6 | 2 | 214 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|----------------------|--|----------------|------------------|--------------------------------|-----------|
| Cordova HS (2119) 2A | repair ceiling insulation falling,need repairing | 4/22/14 | 1st Floor | equipment rm.plant mgr. office | Asbestos |
| Cordova HS (2119) 2A | AMG in gym office | 7/1/13 | Gym | | Asbestos |
| Cordova HS (2119) 2A | ENTRANCE DOOR ART RM: HINGES BROKEN-WON'T BE ABLE TO SECURE BLDG-PLANT MGR BREWER 416-4540 KLR | 5/2/14 | | | Carpentry |
| Cordova HS (2119) 2A | Flag pole cable is broken | 5/7/14 | | | Carpentry |
| Cordova HS (2119) 2A | Bells need to be reset we had a power outage last night | 3/28/14 | | | Carpentry |
| Cordova HS (2119) 2A | The A lunch and the 6 period bells are not working | 4/4/14 | | | Carpentry |
| Cordova HS (2119) 2A | I need 5 bundles of ceiling tiles with the insulation on the back | 1/3/14 | | | Carpentry |

| | | | | | |
|----------------------|--|----------|--|--|-----------|
| Cordova HS (2119) 2A | ROOF HATCH LADDER IS VERY LOOSE ABOVE FREEMAN SIDE PLANT MGR- CHARLES/416.4540 | 1/22/14 | | | Carpentry |
| Cordova HS (2119) 2A | One of the main lobby door glasses are broken and need replaced | 1/24/14 | | | Carpentry |
| Cordova HS (2119) 2A | I need 10 bundles of ceiling tiles 2x4 insulation on the back | 7/8/13 | | | Carpentry |
| Cordova HS (2119) 2A | Door latch broken | 7/8/13 | | | Carpentry |
| Cordova HS (2119) 2A | I need a 12 foot ladder to replace several ceiling tiles in the cafeteria before the meeting friday thanks | 7/16/13 | | | Carpentry |
| Cordova HS (2119) 2A | I need two bundles of ceiling tiles without the insulation on the back | 7/17/13 | | | Carpentry |
| Cordova HS (2119) 2A | install noseing on riser"s in choir room, M. Tutton"s crew will be laying floor tile on tread"s.-os | 7/29/13 | | | Carpentry |
| Cordova HS (2119) 2A | Expansino joint cover need to be reattached to the wall main hallway outside of pe gym door | 10/10/13 | | | Carpentry |

| | | | | | |
|----------------------|--|----------|-----------|--------|------------|
| Cordova HS (2119) 2A | The cable is broken on the flag it will not go up or down (it's stuck uo there) | 10/21/13 | | | Carpentry |
| Cordova HS (2119) 2A | (3) STORM DRAIN COVERS MISSING IN THE VISITOR SIDE OF FOOTBALL STADIUM AREA-PLANT MGR TRUESDALE 416-4540 KLR | 10/21/13 | | | Carpentry |
| Cordova HS (2119) 2A | Expansion joint cover outside the gym at picnic area need to be replaced | 10/28/13 | | | Carpentry |
| Cordova HS (2119) 2A | Counter top in boys restroom across from rm#232 is missing | 11/4/13 | | | Carpentry |
| Cordova HS (2119) 2A | Broken door glass in the varsity gym | 12/9/13 | | | Carpentry |
| Cordova HS (2119) 2A | CLOCKS NEED REPAIRING THRU-OUT BLDING. | 4/22/14 | 1st Floor | CLOCKS | Electrical |
| Cordova HS (2119) 2A | OUTLET COVER HAS BEEN REMOVED FROM AUDIT BY FRONT DOOR, & FEELS HOT PLANT MGR- CHARLES/416.4540 | 5/21/14 | | | Electrical |
| Cordova HS (2119) 2A | I have 29 lights out in the auditorium par-38 | 5/27/14 | | | Electrical |

| | | | | | |
|----------------------|---|---------|--|--|------------|
| Cordova HS (2119) 2A | We have an intermitng bell that has started ringing mid way into six period | 5/2/14 | | | Electrical |
| Cordova HS (2119) 2A | OUTSIDE LIGHTS SOCCER FIELD-NOT WORKING, THEY WILL HAVE A CHAMPIONSHIP GAME TOMORROW-PLANT MGR TRUESDALE 416-4540 KLR | 5/7/14 | | | Electrical |
| Cordova HS (2119) 2A | per truesdale 416-4540 auditorium unit is not coming on and they have a play in there starting tonight | 5/8/14 | | | Electrical |
| Cordova HS (2119) 2A | RTU RM 111, ATTENDANCE OFC, & RM 100-ALL NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 8/26/13 | | | Electrical |
| Cordova HS (2119) 2A | FCU CAFE MGR-NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 8/26/13 | | | Electrical |
| Cordova HS (2119) 2A | Please install 3 door magnets. I have them i my office. | 8/27/13 | | | Electrical |
| Cordova HS (2119) 2A | LIGHT SWITCH OUTSIDE RM 211 IN HALLWAY- SPARKED FIRE-PLANT MGR TRUESDALE 416-4540 KLR | 9/4/13 | | | Electrical |
| Cordova HS (2119) 2A | A/C RM 111 & 150-BOTH NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 9/10/13 | | | Electrical |

| | | | | | |
|----------------------|--|---------|--|--|------------|
| Cordova HS (2119) 2A | Crad 2 power supply | 4/1/14 | | | Electrical |
| Cordova HS (2119) 2A | The lunch bell schedule is not set on time | 4/2/14 | | | Electrical |
| Cordova HS (2119) 2A | UNIT NOT COMING ON IN PRIN OFFICE PLANT MGR- CHARLES/416.4540 | 4/9/14 | | | Electrical |
| Cordova HS (2119) 2A | RECEPTACLE RM 232-HAS BEEN PULLED FROM OUT OF WALL WITH WIRES EXPOSED-PLANT MGR TRUESDALE 416-4540 KLR | 4/14/14 | | | Electrical |
| Cordova HS (2119) 2A | Lights and not working properly in the sports complex. | 1/21/14 | | | Electrical |
| Cordova HS (2119) 2A | per Mr. Truesdale 416-4540 room 168 and main lobby heat not coming on | 1/22/14 | | | Electrical |
| Cordova HS (2119) 2A | The bleachers in the varsity gym home side wires were caught up in the rollers and torn apart | 1/22/14 | | | Electrical |
| Cordova HS (2119) 2A | Card 2 power supply/charger battery charger capacity | 1/27/14 | | | Electrical |

| | | | | | |
|----------------------|--|---------|--|--|------------|
| Cordova HS (2119) 2A | Theater lights remote control wire is broken | 7/7/14 | | | Electrical |
| Cordova HS (2119) 2A | BROKEN PULL STATION, SYS IS STILL IN ALARM. ALBERT HERMAN | 7/2/13 | | | Electrical |
| Cordova HS (2119) 2A | The fire alarm went off again sunday the trouble showing a dirty duct detector in the cafeteria and also still showing the PIV | 7/8/13 | | | Electrical |
| Cordova HS (2119) 2A | Bell timers need to be set | 7/9/13 | | | Electrical |
| Cordova HS (2119) 2A | Rear row of lights in auditorium are not working | 7/16/13 | | | Electrical |
| Cordova HS (2119) 2A | I need 25 par 38 bulbs for the auditorium there is a principals meeting friday | 7/16/13 | | | Electrical |
| Cordova HS (2119) 2A | A row of lights are not working in the auditorium(changed bulbs) still not working | 7/16/13 | | | Electrical |
| Cordova HS (2119) 2A | I need eight stage lights replaced | 7/17/13 | | | Electrical |

| | | | | | |
|----------------------|--|---------|--|--|------------|
| Cordova HS (2119) 2A | 4-RTU NOT COMING ON FOR RM-130 THRU 137.(NO ID) SBE-CHARLES/416-4540 | 7/18/13 | | | Electrical |
| Cordova HS (2119) 2A | replace pipe for unit in auditorium and pull new wire | 7/19/13 | | | Electrical |
| Cordova HS (2119) 2A | THE CLOCK IN THE CAFETERIA HAS FALLEN FROM WALL NEED TO BE REPLACED. | 7/22/13 | | | Electrical |
| Cordova HS (2119) 2A | Request outside lights that are out be replaced. | 7/29/13 | | | Electrical |
| Cordova HS (2119) 2A | Rm#150 the home economic room has no wall socket power to the any appliances | 7/29/13 | | | Electrical |
| Cordova HS (2119) 2A | RTU NOT COMING ON IN RM-100 PLANT MGR- CAIN/412.4540 | 7/31/13 | | | Electrical |
| Cordova HS (2119) 2A | Front security door is not working properly will not unlock with the security phone button | 8/6/13 | | | Electrical |
| Cordova HS (2119) 2A | RTU - COVER RM 100 - SPEC ED RM - NOT COMING ON - HAS CONDENSATION ON THE FLR - PM/TRUSDALE 416-4540 | 8/9/13 | | | Electrical |

| | | | | | |
|----------------------|---|---------|--|--|------------|
| Cordova HS (2119) 2A | Bell timers need adjusted | 8/12/13 | | | Electrical |
| Cordova HS (2119) 2A | Room 228 and 232 a/c not coming on at all per Truesdale 416-4540 | 8/14/13 | | | Electrical |
| Cordova HS (2119) 2A | RTU NOT COMING ON IN RM-100 PLANT MGR- CHARLES/416.4540 | 8/19/13 | | | Electrical |
| Cordova HS (2119) 2A | Rm# 100 need washer and dryer hooked up and a stove no stove jasmith | 8/19/13 | | | Electrical |
| Cordova HS (2119) 2A | Attendance office a/c is not coming on at all per Charles Truesdale 416-4540 | 8/20/13 | | | Electrical |
| Cordova HS (2119) 2A | Per Charles Truesdale 416-4540, there was an electrical fire in the guidance office (one of the cubicles) the socket has melted and sparking. | 8/20/13 | | | Electrical |
| Cordova HS (2119) 2A | Electrical outlet in the guidance office needs replaced | 8/21/13 | | | Electrical |
| Cordova HS (2119) 2A | RTU NOT COMING ON IN RM-202 PLANT MGR- TRUESDALE/416.4540 | 8/22/13 | | | Electrical |

| | | | | | |
|----------------------|--|----------|--|--|------------|
| Cordova HS (2119) 2A | a/c not working at all room 230 per truesdale 416-4540 | 9/20/13 | | | Electrical |
| Cordova HS (2119) 2A | Could we have someone check the parking lot lights far end of the students lot (Please have an Z2A electrician check this out if the bucket truck is needed then we'll assist). jd | 9/23/13 | | | Electrical |
| Cordova HS (2119) 2A | Computer lab several outlets are out | 10/22/13 | | | Electrical |
| Cordova HS (2119) 2A | The vent a hood in the kitchen isn't working checked breaker it's ok. Gross was here to due an inspection on it | 10/28/13 | | | Electrical |
| Cordova HS (2119) 2A | Problem with the track lights in rm#168 tripping breaker | 10/30/13 | | | Electrical |
| Cordova HS (2119) 2A | RTU RM 201-NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 11/1/13 | | | Electrical |
| Cordova HS (2119) 2A | No lights all around the school the far students parking lot are on | 11/7/13 | | | Electrical |
| Cordova HS (2119) 2A | BELLS - ARE NOT RINGING - WON'T RESET TO THE CORRECT DAY OR TIME - PM/TRUSEDAL 416-4540 | 11/8/13 | | | Electrical |

| | | | | | |
|----------------------|--|----------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | HEAT 2ND FLR RMS 239 - 241, AUDITORIUM, & ATTENDANCE OFC-ALL NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 11/25/13 | | | Electrical |
| Cordova HS (2119) 2A | RECEPTACLE IS MAKING NOISE, BURNING SMELL IN RM-223 PLANT MGR- CHARLES/416.4540 | 12/4/13 | | | Electrical |
| Cordova HS (2119) 2A | 8-RTU NOT COMING ON IN RM- 134,168,237,238,239,240,241 VARSITY GYM, PE GYM PLANT MGR- CHARLES/416.4540 | 12/10/13 | | | Electrical |
| Cordova HS (2119) 2A | HEAT RMS 101, 103, 205, 238, 239, 240, 241, 245, 246, & VARSITY GYM-ALL NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 12/10/13 | | | Electrical |
| Cordova HS (2119) 2A | RTU RMS 144, 145, 164, & 245-ALL NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 12/11/13 | | | Electrical |
| Cordova HS (2119) 2A | per mr truesdale 416-4540 serving line a/c blowing hot | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | RTU RM 102 & RTU RM 103-BOTH NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C drain broken on the theater office unit | 6/18/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|---------|------------|--|---------------------------------------|
| Cordova HS (2119) 2A | RTU RM 116-NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C RM 119 & 120-BOTH NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 5/27/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | RTU RM 237 & 240-BOTH NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 5/5/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | No air in the auditorium, not cooling. | 5/8/14 | Auditorium | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | RTU NOT COOLING IN PRESS BOX(FOOTBALL FIELD) PLANT MGR- CHARLES/416.4540 | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C PE GYM-NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | HEAT RM 103-NOT COMING ON-PLANT MGR BREWER 416-4540 KLR | 3/10/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | HEAT RM 204-NOT HEATING-PLANT MGR BREWER 416-4540 KLR | 3/11/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|---------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C in the kitchen on the serving line is not working | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | 2-UNIT NOT COMING ON IN KITCHEN PLANT MGR/CHARLES/416.4540 | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | UNIT NOT COOLING IN RM 237 PLANT MGR/CHARLES/416.4540 | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C LIBRARY AREA & RM 18-BOTH NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | per mr truesdale 416-4540 serving line RTU not coming on and library RTU not coming on | 4/7/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | UNIT NOT COOLING IN RM 209 PLANT MGR-CHARLES/416.4540 | 4/9/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C RM 243-NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|---------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | RTU'S RMS 245, 243, 240, & 127-ALL NOT HEATING-PLANT MGR TRUESDALE 416-4540 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Units are NOT HEATING in 205 & 207 per Charles Tresdale, Plant Mgr. 416.4540 | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | HEAT RMS 200 & 152-BOTH NOT HEATING-PLANT MGR TRUESDALE 416-4540 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Unit is NOT HEATING in Room 150 per Charles Truesdale, Plant Mgr. 416.4540 | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | per Mr. Truesdale 416-4540 room 163 blowing cold | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | RTU RM 150, 144, 205, & 245-ALL NOT HEATING-PLANT MGR TRUESDALE 416-4540 KLR | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | RTU RM 111, 245, & 163-ALL NOT HEATING-PLANT MGR TRUESDALE 416-4540 KLR | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Unit in ROOM 163 is NOT HEATING per Mr. Trusdale, Plant Mgr. 416.4540 | 2/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|---------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | RTU NOT HEATING IN RM-119,120. PLANT MGR-CHARLES/416.4540 | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | per truesdale 416-4540 Roof Top Unit room 144 blowing cold | 2/13/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | UNIT NOT HEATING IN RM-141,142,146, PLANT MGR OFFICE. PLANT MGR-CHARLES/416.4540 | 2/26/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C not working in rm#116 | 7/9/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | The A/C is not working in the cafeteria | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | The A/C is not working in the library | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Thermostat missing in the main lobby | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Room 132 - A/C running but not cooling Principal's Meeting Friday 7/19/13 and will be using this area. Charles Truesdale 416-4540 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|---------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | a/c in cafeteria is leaking water using this area for principal's meeting friday 7/19/13 Charles Truesdale 416-4540 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Rm#202 A/C blowing but not cooling | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Rm#232 has no a/c | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | A/C in rm#237 blowing but not cooling | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Band room #164 has an a/c leak | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Rm#100 a/c not working | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Room 102 and Room 135 not cooling per truesdale 416-4540 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Monthly - Oil Lube & Belt-Cordova High - Refer to PM schedule details. | 10/5/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|----------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | A/C LIBRARY-NOT COOLING-PLANT MGR TRUESDALE 416-4540 KLR | 10/16/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | HEAT 1ST FLR ATTENDANCE HALL ABOUT (8) RMS, ENGLISH HALL ABOUT (4) RMS, & AUDITORIUM-ALL NOT HEATING-PLANT MGR TRUESDALE 416-4540 KLR | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | 3-RTU NOT HEATING IN RM-205,206,207 PLANT MGR-CHARLES/416.4540 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | RTU'S RMS 245 & 249-NOT HEATING & RM 145-HEAT IS ON BUT BLOWR MOTOR NOT BLOWING HEAT IN RM-PLANT MGR TRUESDALE 416-4540 KLR | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | HEAT RM 144-COMES ON, BUT STAYS ON FOR ABOUT A MINUTE THEN CUTS OFF AND WON'T COME BACK ON TIL ABOUT AN HOUR LATER PER SBE-PLANT MGR TRUESDALE 416.4540 KLR | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | HEAT VARSITY GYM AREA-NOT COMING ON-PLANT MGR TRUESDALE 416-4540 KLR | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Monthly - Oil Lube & Belt-Cordova High - Refer to PM schedule details. | 5/10/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Monthly - Filter-Cordova High - Refer to PM schedule details. | 4/19/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|----------|--|--|---------------------------------------|
| Cordova HS (2119) 2A | Yearly - Cooling Towers (STRAINERS)-Cordova High - Refer to PM schedule details. | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Monthly - Filter-Cordova High - Refer to PM schedule details. | 12/21/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | Monthly - Filter-Cordova High - Refer to PM schedule details. | 8/24/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova HS (2119) 2A | GRAFFITI -OUTSIDE ON BRICK BASEBALL TICKET BOOTH -GANG RELATED - PM/TRUSDALE 416-4540 | 11/12/13 | | | Painting |
| Cordova HS (2119) 2A | Gang graffiti on the walls in the Boy's & Girl's RR on the 1st and 2nd floors per Charles Truedale, Plant Mgr. 901416.4540 | 11/21/13 | | | Painting |
| Cordova HS (2119) 2A | Sink stopped up in the main office custodial closet | 6/18/14 | | | Plumbing |
| Cordova HS (2119) 2A | Toilet in the main lobby restrooms girls stopped up | 6/18/14 | | | Plumbing |
| Cordova HS (2119) 2A | baseball sprinkler has leak 1st base line | 6/18/14 | | | Plumbing |

| | | | | | |
|----------------------|---|---------|-----------|---------------------------------|----------|
| Cordova HS (2119) 2A | Assist zone with water main repair | 6/27/14 | | | Plumbing |
| Cordova HS (2119) 2A | unstop sink | 4/22/14 | 1st Floor | rm.122 social studies | Plumbing |
| Cordova HS (2119) 2A | Hot water tank is Leaking. Tank number is 106-259 | 4/26/14 | Kitchen | Back of the Kitchen on the dock | Plumbing |
| Cordova HS (2119) 2A | kitchen Faucets is leaking. | 4/26/14 | Kitchen | Kitchen | Plumbing |
| Cordova HS (2119) 2A | WASHING MACHINE DRAIN IS BACKING UP IN KITCHEN PLANT MGR- CHARLES/416.4540 | 5/15/14 | | | Plumbing |
| Cordova HS (2119) 2A | FLOOR DRAIN KITCHEN AREA-BACKING UP SEWAGE-PLANT MGR TRUESDALE 416-4540 KLR | 5/21/14 | | | Plumbing |
| Cordova HS (2119) 2A | Request back flow test. | 6/2/14 | | | Plumbing |
| Cordova HS (2119) 2A | Sink in the kitchen will not turn off | 5/5/14 | | | Plumbing |

| | | | | | |
|----------------------|---|---------|--|--|----------|
| Cordova HS (2119) 2A | RTU RM 224-LEAKING-PLANT MGR TRUESDALE 416-4540 KLR | 8/26/13 | | | Plumbing |
| Cordova HS (2119) 2A | Boys Restroom upstairs near rm#225 toilet stopped up | 8/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | Boys restroom near ROTC room toilet stopped up | 8/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | Girls restroom across from rm#140 toilet stopped up | 8/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | Boy's RR next to CAFETERIA urinal is broken and water is running allover per Charles, Plant Mgr. at 901.416.4540. | 8/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | back closet in room 216 which is a lab, there is a water leak on pipe per Truesdale 416-4540 | 9/3/13 | | | Plumbing |
| Cordova HS (2119) 2A | install new washer & dryer in Funcinal Skills Class room #100. This work will be taken care during fall break Oct. 7th thru Oct. 11th. No students allowed in room while work is going on.-os | 9/10/13 | | | Plumbing |
| Cordova HS (2119) 2A | We have a base ball gathering here at cordova high coaches request the restrooms and concessions be unwinterized | 3/6/14 | | | Plumbing |

| | | | | | |
|----------------------|--|---------|-----------------|------------------------|----------|
| Cordova HS (2119) 2A | Toilet in the teachers lounge next to room 100 men's side will not flush | 3/24/14 | | | Plumbing |
| Cordova HS (2119) 2A | Girls restroom upstairs across from rm232 is leaking | 3/24/14 | | | Plumbing |
| Cordova HS (2119) 2A | We have two water fountains in the main lobby leaking | 3/24/14 | | | Plumbing |
| Cordova HS (2119) 2A | Rm 165 sink leaking | 3/26/14 | | | Plumbing |
| Cordova HS (2119) 2A | Girls restroom across from rm 140 toilet is loose | 3/26/14 | | | Plumbing |
| Cordova HS (2119) 2A | Urinal in the boys restroom on the rotc hall stopped up | 4/11/14 | | | Plumbing |
| Cordova HS (2119) 2A | The outside Boy's toilet is leaking on the baseball field. | 4/15/14 | Restroom (Boys) | Outside Baseball Field | Plumbing |
| Cordova HS (2119) 2A | The outside Boy's restroom toilet is leaking on the baseball field. | 4/15/14 | Restroom (Boys) | Outside Baseball Field | Plumbing |

| | | | | | |
|----------------------|---|---------|-----------|---------------------------|----------|
| Cordova HS (2119) 2A | Hot Water won't cut-off. | 4/16/14 | 1st Floor | Fine Art Hall-Room 161 | Plumbing |
| Cordova HS (2119) 2A | the hot water in room F161 in the fine arts department. the water will not stop running it is striped. | 4/16/14 | Classroom | F161 | Plumbing |
| Cordova HS (2119) 2A | Toilet in the teachers lounge next to room 100 will not flush | 1/14/14 | | | Plumbing |
| Cordova HS (2119) 2A | RTU HALL BY VOC TECH- HAS A GAS SMELL COMING FROM IT-PLANT MGR TRUESDALE 416- 4540 KLR | 1/15/14 | | | Plumbing |
| Cordova HS (2119) 2A | two toilets in the girls restroom across from rm140 | 1/22/14 | | | Plumbing |
| Cordova HS (2119) 2A | CEILING PIPE IS LEAKING WATER IN B/RR BY VARSITY GYM PLANT MGR- CHARLES/416.4540 | 1/27/14 | | | Plumbing |
| Cordova HS (2119) 2A | I have aleak in rm#200 | 2/3/14 | | | Plumbing |
| Cordova HS (2119) 2A | custodial closet sink next door to the principals office is stopped up will not drain tried to plung | 2/5/14 | | | Plumbing |

| | | | | | |
|----------------------|---|---------|--|--|----------|
| Cordova HS (2119) 2A | Faucet broken in the auto shop wash sink | 2/5/14 | | | Plumbing |
| Cordova HS (2119) 2A | 2-TOILETS ARE OVERFLOWING IN B/RR-G/RR 1ST FLR. PLANT MGR- CHARLES/416.4540 | 2/11/14 | | | Plumbing |
| Cordova HS (2119) 2A | Sink in the main office stopped up | 2/11/14 | | | Plumbing |
| Cordova HS (2119) 2A | Restroom across from room 140 urinal stopped up | 2/26/14 | | | Plumbing |
| Cordova HS (2119) 2A | STRONG GAS SMELL IN MAIN FRONT LOBBY AREA. PLANT MGR TRUESDALE 416-4540 KLR | 2/27/14 | | | Plumbing |
| Cordova HS (2119) 2A | test back flow device-os | 7/2/13 | | | Plumbing |
| Cordova HS (2119) 2A | Water fountain in main lobby leaking across from the varsity gym | 7/5/13 | | | Plumbing |
| Cordova HS (2119) 2A | THE RESTROOM IN BACK OF THEATER DRESSING ROOM IS NOT WORKING.IT WILL NOT FLUSH. | 7/22/13 | | | Plumbing |

| | | | | | |
|----------------------|---|---------|--|--|----------|
| Cordova HS (2119) 2A | a/c leaking in rm#239 | 7/26/13 | | | Plumbing |
| Cordova HS (2119) 2A | a/c leaking in rm#227 | 7/26/13 | | | Plumbing |
| Cordova HS (2119) 2A | UNITS IN THE CAFE. ARE LEAKING. SBE TRUESDALE 416-4540 | 7/29/13 | | | Plumbing |
| Cordova HS (2119) 2A | (2) RTU'S CAFE AREA- LEAKING-SBE CAIN 416-4540 KLR | 8/2/13 | | | Plumbing |
| Cordova HS (2119) 2A | Band rm#164 has several water leaks on intruments | 8/8/13 | | | Plumbing |
| Cordova HS (2119) 2A | Back flow test. | 8/8/13 | | | Plumbing |
| Cordova HS (2119) 2A | a/c pouring water 234, 239, 240, 127 per Truesdale 416-4540 | 8/13/13 | | | Plumbing |
| Cordova HS (2119) 2A | Floor drains in the cafeteria stopped up | 8/13/13 | | | Plumbing |

| | | | | | |
|----------------------|---|---------|--|--|----------|
| Cordova HS (2119) 2A | RTU IS LEAKING IN RM-164,210 PLANT MGR-CHARLES/416.4540 | 8/14/13 | | | Plumbing |
| Cordova HS (2119) 2A | GREASE TRAP IS BACKING IN KITCHEN. PLANT MGR-GERARD/416.4540 | 8/16/13 | | | Plumbing |
| Cordova HS (2119) 2A | RTU MAIN ROOF RM W234 LEAKING-PLANT MGR TRUESDALE 416-4540 KLR | 8/19/13 | | | Plumbing |
| Cordova HS (2119) 2A | BROWN WATER IN KITCHEN AREA PLANT MGR-CHARLES/416.4540 | 8/19/13 | | | Plumbing |
| Cordova HS (2119) 2A | 2-RTU ARE LEAKING WATER IN RM-224,239 PLANT MGR-TRUESDALE/416.4540 | 8/22/13 | | | Plumbing |
| Cordova HS (2119) 2A | RTU'S RM 235 & 221-BOTH LEAKING-TRUESDALE 416-4540 KLR | 9/12/13 | | | Plumbing |
| Cordova HS (2119) 2A | install new water fountain, in hall way across from rm. 100, Mike Hughs is aware of fountain, after 1st of Oct. will be ok-os | 9/12/13 | | | Plumbing |
| Cordova HS (2119) 2A | Rm # 150 sinks clogged up the home economic room | 9/19/13 | | | Plumbing |

| | | | | | |
|----------------------|---|----------|--|--|----------|
| Cordova HS (2119) 2A | Toilet stopped up boys restroom across from rm#100 | 9/20/13 | | | Plumbing |
| Cordova HS (2119) 2A | Faucet broken in the boys restroom across from rm#100 | 10/10/13 | | | Plumbing |
| Cordova HS (2119) 2A | urinal partially off wall can't turn off - 2nd floor in freshman academy per Truesdale 416-4540 | 10/18/13 | | | Plumbing |
| Cordova HS (2119) 2A | Boys restroom near rm#136 toilet leaking | 10/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | Girls restroom across from the varsity gymtoilet leaking | 10/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | RTU IS LEAKING WATER IN RM-202. PLANT MGR- CHARLES/416.4540 | 10/30/13 | | | Plumbing |
| Cordova HS (2119) 2A | Barbering rm#151 shampoo bowl drains stopped up | 11/1/13 | | | Plumbing |
| Cordova HS (2119) 2A | Shower in the girls locker room will not turn off constantly running | 11/5/13 | | | Plumbing |

| | | | | | |
|----------------------|--|----------|--|--|----------|
| Cordova HS (2119) 2A | The sink in the girls locker room is leaking | 11/5/13 | | | Plumbing |
| Cordova HS (2119) 2A | Shower in the boys locker is leaking | 11/5/13 | | | Plumbing |
| Cordova HS (2119) 2A | Urinal across from room #238 stopped up | 11/5/13 | | | Plumbing |
| Cordova HS (2119) 2A | Urinal in boys restroom across from rotc is stopped up | 11/13/13 | | | Plumbing |
| Cordova HS (2119) 2A | pvc pipe in ceiling in cafeteria over warmer is leaking bad per Mr. Truesdale 416-4540 | 11/21/13 | | | Plumbing |
| Cordova HS (2119) 2A | Dishwasher sinks stopped up in the cafeteria(per cafeteria mgr) | 12/10/13 | | | Plumbing |
| Cordova HS (2119) 2A | Sensor loop plugged on discharge line- very low pressure. water treatment system.-os | 9/11/13 | | | Plumbing |
| Cordova HS (2119) 2A | Rm#240has a leak | 1/9/14 | | | Roof |

| | | | | | |
|----------------------|--|----------|--|--|-------------|
| Cordova HS (2119) 2A | A leak outside of the cafeteria double doors | 2/4/14 | | | Roof |
| Cordova HS (2119) 2A | WE have two roof leaks rm#241 rm#240 | 7/22/13 | | | Roof |
| Cordova HS (2119) 2A | We have a leak in the fine arts hallway | 8/7/13 | | | Roof |
| Cordova HS (2119) 2A | Roof leak in the main office mens restroom | 10/16/13 | | | Roof |
| Cordova HS (2119) 2A | Rm#202 has a leak near the a/c unit | 10/31/13 | | | Roof |
| Cordova HS (2119) 2A | Request dryer vent be installed in the conmetology class room. | 8/15/13 | | | Sheet Metal |
| Cordova HS (2119) 2A | Install dryer vent. | 8/15/13 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | Grand Total |
|-------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | |
| Location | | | | | | | | | | |
| Jordova MS (2118) | 1 | 1 | 23 | 66 | 28 | 2 | 37 | 3 | 1 | 162 |
| Grand Total | 1 | 1 | 23 | 66 | 28 | 2 | 37 | 3 | 1 | 162 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|----------------------|--|----------------------|----------------------|---------------------|--------------|
| Cordova MS (2118) 2A | Wipe down mold on books and shelves. Thanks. | 8/27/13 | Library | Library | Asbestos |
| Cordova MS (2118) 2A | This room needs 30 computer drops, It will be the new computer lab. Also need price quote. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 2/4/14 | Classroom | 5th grade hall M-22 | Cabling |
| Cordova MS (2118) 2A | The door handle fell off from the inside the door, I cannot repair. | 2/4/14 | Classroom | 7th grade hall M-14 | Carpentry |
| Cordova MS (2118) 2A | The door handle is broken, Hard to gain entry. | 2/25/14 | Library | Library A-6 | Carpentry |
| Cordova MS (2118) 2A | The children knocked a hole in the kiosk need repairs. | 2/25/14 | Hallway/Corridor | 7th grade hall | Carpentry |
| Cordova MS (2118) 2A | Door closer arm is broken, door will not close back. | 4/30/14 | Hallway/Corridor | 8th grade hall | Carpentry |
| Cordova MS (2118) 2A | Stall door torn off the hinges. | 5/14/14 | Restroom (Boys) | 7th grade | Carpentry |

| | | | | | |
|----------------------|--|---------|------------------|---------------------|-----------|
| Cordova MS (2118) 2A | Door closer arm is broken. | 5/14/14 | Hallway/Corridor | 8th grade exit door | Carpentry |
| Cordova MS (2118) 2A | When it rains water comes through plexy glass on back door and wets carpet. | 5/14/14 | Classroom | K -wing k-2 | Carpentry |
| Cordova MS (2118) 2A | ENTRANCE DOOR 8TH GRADE HALL-NOT LATCHING-WON'T BE ABLE TO SECURE-PLANT MGR CLARK 416-2189 KLR | 1/28/14 | | | Carpentry |
| Cordova MS (2118) 2A | The door handle mechanism is falling apart. | 3/10/14 | Classroom | 7th grade M-9 | Carpentry |
| Cordova MS (2118) 2A | The stall door has fell off the hinges. | 3/10/14 | Restroom (Boys) | Main hall | Carpentry |
| Cordova MS (2118) 2A | Stall door coming off the hinges. | 3/18/14 | Restroom (Girls) | 7th grade hall | Carpentry |
| Cordova MS (2118) 2A | CTR MULL DAMAGED ON FRONT ENTRANCE DOOR DUE TO A BREAK IN-WON'T BE ABLE TO SECURE-PLANT MGR CLARK 416-2189 KLR | 3/21/14 | | | Carpentry |
| Cordova MS (2118) 2A | Water is coming into the room through loose window seals. The tile has buckled on the floor. | 9/4/13 | Auditorium | Multipurpose Rm. | Carpentry |

| | | | | | |
|----------------------|---|----------|------------------|------------------|-----------|
| Cordova MS (2118) 2A | Water damage to 20 squares of tile, has to be repaired. Thanks. | 9/4/13 | Auditorium | Multipurpose Rm. | Carpentry |
| Cordova MS (2118) 2A | The outside exit door will not close properly. | 9/18/13 | Hallway/Corridor | 8th hall | Carpentry |
| Cordova MS (2118) 2A | Install locks on restroom stall doors. | 9/24/13 | | | Carpentry |
| Cordova MS (2118) 2A | The door mechanism is broken. | 10/11/13 | Classroom | 8th Hall M-27 | Carpentry |
| Cordova MS (2118) 2A | Library doors hard to open | 10/15/13 | | | Carpentry |
| Cordova MS (2118) 2A | Water is coming into the bldg under the door. | 10/25/13 | | | Carpentry |
| Cordova MS (2118) 2A | Door handle mechanism is broken. | 10/29/13 | Classroom | 7th hall M-8 | Carpentry |
| Cordova MS (2118) 2A | Repair counter top in room E-4. | 11/19/13 | | | Carpentry |

| | | | | | |
|----------------------|---|----------|-----------|----------------|------------|
| Cordova MS (2118) 2A | Move lift from Kate Bond Mid to Cordova Mid. | 12/4/13 | | | Carpentry |
| Cordova MS (2118) 2A | Request lift be move to new location. | 12/13/13 | | | Carpentry |
| Cordova MS (2118) 2A | Need 2 boxes of T8 long tube bulbs. | 6/25/14 | 1st Floor | Entire plant | Electrical |
| Cordova MS (2118) 2A | Need 4 boxes of single two pin bulbs F138X/827/eco. | 6/25/14 | 1st Floor | Entire plant | Electrical |
| Cordova MS (2118) 2A | The front and back canopies bulbs are blown, need changing out. | 6/30/14 | Grounds | Outside canopy | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 6/11/14 | Classroom | 8th hall M-24 | Electrical |
| Cordova MS (2118) 2A | A/C PRIN'S OFC-NOT COMING ON-PLANT MGR CLARK 416-2189 KLR | 6/17/14 | | | Electrical |
| Cordova MS (2118) 2A | Install a portable chiller. | 4/22/14 | | | Electrical |

| | | | | | |
|----------------------|--|---------|---------------------|---------------|------------|
| Cordova MS (2118) 2A | Two bad ballast in light fixtures. atten Richard Powell. | 4/23/14 | Classroom | 6th grade E-8 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 4/30/14 | Restroom (Girls) | Front hall | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 5/5/14 | Classroom | 6th hall K-5 | Electrical |
| Cordova MS (2118) 2A | 2 Bad ballast out in light fixtures. | 5/30/14 | Administration Area | Admin. A-11 | Electrical |
| Cordova MS (2118) 2A | Alarm panel will not reset, panel showing #1 smoke detector dirty. | 5/30/14 | Administration Area | Admin . | Electrical |
| Cordova MS (2118) 2A | Bad ballast the light are strobing. | 8/20/13 | Restroom (Boys) | 6th grade RR | Electrical |
| Cordova MS (2118) 2A | Exposed wiring on wall outlet. need help thanks. | 8/20/13 | Classroom | Spanish Class | Electrical |
| Cordova MS (2118) 2A | Bad ballast needs to be replaced, Thanks. | 8/26/13 | Restroom (Boys) | 7th Restroom | Electrical |

| | | | | | |
|----------------------|--|---------|------------------------|-----------------|------------|
| Cordova MS (2118) 2A | Bad ballast. | 8/27/13 | Restroom (Girls) | 8th grade hall | Electrical |
| Cordova MS (2118) 2A | Need 3 boxes of T8 long tube bulbs. | 1/16/14 | 1st Floor | Entire Plant | Electrical |
| Cordova MS (2118) 2A | The alarm panel will not reset, It reads 011 smoke door F wing east. | 1/21/14 | Administration Area | Main office | Electrical |
| Cordova MS (2118) 2A | Master clock need to be set forward. | 3/10/14 | Administration Area | Main Office A-8 | Electrical |
| Cordova MS (2118) 2A | Electrical wires protruding from wall railing. | 3/24/14 | Classroom | 5th grade E-22 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 4/11/14 | Classroom | 6th grade K-8 | Electrical |
| Cordova MS (2118) 2A | Two bad ballast in light fixtures. | 4/11/14 | Classroom | 6th grade E-14 | Electrical |
| Cordova MS (2118) 2A | Bad light switch. | 4/11/14 | Classroom | 7th grade M-16 | Electrical |

| | | | | | |
|----------------------|---|---------|---------------------|---------------------|------------|
| Cordova MS (2118) 2A | install power to tempary chiller- os | 4/21/14 | | | Electrical |
| Cordova MS (2118) 2A | Light switch in classroom closet is not working. | 9/5/13 | Classroom | K-wing K5 | Electrical |
| Cordova MS (2118) 2A | Wall outlet exposed wires are hanging. | 9/5/13 | Classroom | K-wing K5 | Electrical |
| Cordova MS (2118) 2A | Timer switch needs to be set. Lights remain on day and night. | 9/10/13 | Grounds | Outside pole lights | Electrical |
| Cordova MS (2118) 2A | Bad ballast. | 9/25/13 | Classroom | 8th hall M-32 | Electrical |
| Cordova MS (2118) 2A | Bad ballast. | 9/25/13 | Classroom | 8th hall M-31 | Electrical |
| Cordova MS (2118) 2A | Office hallway light has a bad ballast. | 9/25/13 | Administration Area | Main Office | Electrical |
| Cordova MS (2118) 2A | The U-bulb light next to kiosk has a bad ballast. | 9/25/13 | Hallway/Corridor | 6th hall | Electrical |

| | | | | | |
|----------------------|---|----------|---------------------|-----------------------|------------|
| Cordova MS (2118) 2A | There are two bad ballast in this classroom. | 10/3/13 | Classroom | 6th hall K-2 | Electrical |
| Cordova MS (2118) 2A | One bad ballast in this classroom. | 10/3/13 | Classroom | 6th hall E-6 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in hallway lights. | 10/3/13 | Hallway/Corridor | 6th Outside K-1 | Electrical |
| Cordova MS (2118) 2A | Bad ballast outside A-3 above the exit doors. | 10/3/13 | Hallway/Corridor | Outside A-3 | Electrical |
| Cordova MS (2118) 2A | Master clock bells needs added schedules. | 10/3/13 | Administration Area | Main Office | Electrical |
| Cordova MS (2118) 2A | Need 6 boxes of light bulbs T8 long tubes. | 10/4/13 | 1st Floor | Entire Plant | Electrical |
| Cordova MS (2118) 2A | Bad ballast in hallway light fixture. | 10/10/13 | Hallway/Corridor | 7th Outside M-15 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in hallway light fixture. | 10/10/13 | Hallway/Corridor | 7th hall Outside M-18 | Electrical |

| | | | | | |
|----------------------|--|----------|---------------------|-------------------------|------------|
| Cordova MS (2118) 2A | Bad ballast in room light fixture. | 10/10/13 | Administration Area | Main office A-12A | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 10/11/13 | Classroom | 8th Hall M-30 | Electrical |
| Cordova MS (2118) 2A | Two bad ballast in light fixtures. | 10/11/13 | Classroom | 8th Hall M-24 | Electrical |
| Cordova MS (2118) 2A | Two bad ballast outside teachers lounge U-shape bulbs. | 10/11/13 | Hallway/Corridor | 5th Hall outside lounge | Electrical |
| Cordova MS (2118) 2A | BREAKER KITCHEN AREA- KEEPS TRIPPING KNOCKING POWER OUT TO FREEZER- PLANT MGR CLARK 416-2189 KLR | 10/22/13 | | | Electrical |
| Cordova MS (2118) 2A | We need 4 boxes of each, the U-Bent FB32T8/TL741/6 ALTO. The F32T8/ADV841/EW. Thanks. | 7/23/13 | Hallway/Corridor | The entire building | Electrical |
| Cordova MS (2118) 2A | The master clock needs to be set for school start, Thanks. | 7/26/13 | Administration Area | Main office | Electrical |
| Cordova MS (2118) 2A | AIR NOT COMING ON IN ENTIRE B WING-SBE CLARK 416-2189 KLR | 8/1/13 | | | Electrical |

| | | | | | |
|----------------------|--|----------|---------------------|---------------------|------------|
| Cordova MS (2118) 2A | Burned out light ballast. | 8/2/13 | Restroom (Boys) | Gym area | Electrical |
| Cordova MS (2118) 2A | Master clock needs to be set for class changing. Thanks for your help. | 8/12/13 | Administration Area | Office100n | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture above the steps . | 8/15/13 | Mechanical Room | Air-handler | Electrical |
| Cordova MS (2118) 2A | The timer switch for the outside lights is not working. | 8/15/13 | Parking Lot | Front & back lots | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 10/29/13 | Restroom (Boys) | Main front hall | Electrical |
| Cordova MS (2118) 2A | There are 3 rows of lights out. | 10/29/13 | Auditorium | Multi-purpose rm. | Electrical |
| Cordova MS (2118) 2A | The parking lot light timer is not set properly, When I arrive at 6:00 am no lights, pitch black at 7:00 pm also dark. | 10/29/13 | Parking Lot | Back and front lots | Electrical |
| Cordova MS (2118) 2A | The light switch has broken off the wall. | 10/30/13 | Kitchen | Pantry | Electrical |

| | | | | | |
|----------------------|---|----------|---------------------|--------------------|------------|
| Cordova MS (2118) 2A | The timer switch for outside pole lights is broken. | 11/1/13 | Mechanical Room | Electrical room | Electrical |
| Cordova MS (2118) 2A | Light switch is broken, room is partially lit. | 11/13/13 | Classroom | 5thgrade hall E-17 | Electrical |
| Cordova MS (2118) 2A | Electrical wires pertruding from wall outlet. | 11/19/13 | Classroom | 7th grade hall M-6 | Electrical |
| Cordova MS (2118) 2A | Need 3 boxes of T8 long tube bulbs. | 12/2/13 | 1st Floor | Entire Plant | Electrical |
| Cordova MS (2118) 2A | The alarm panel will not reset, It reads 011 smoke door F wing east. Per. Mr. Otto Schlafer. The alarm was going off over the Thanksgiving Holiday. | 12/2/13 | Administration Area | Front office | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 12/11/13 | Classroom | 7th Grade hall M-1 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 12/11/13 | Classroom | 7th Grade hall M-2 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 12/11/13 | Administration Area | Main hall A-4 | Electrical |

| | | | | | |
|----------------------|--|----------|-----------|------------------|---------------------------------------|
| Cordova MS (2118) 2A | Bad ballast above sink. | 12/16/13 | Kitchen | Kitchen C-3 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture above cash register. | 12/16/13 | Kitchen | Serving line C-3 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 12/18/13 | Classroom | Art room A-13 | Electrical |
| Cordova MS (2118) 2A | Bad ballast in light fixture. | 12/18/13 | Classroom | Spanish room A-3 | Electrical |
| Cordova MS (2118) 2A | Daily - Cordova Middle Level 1 Water Treatment - Refer to PM schedule details. | 6/6/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | UNIT NOT COOLING IN PRIN OFFICE PLANT MGR-CLARK/361.2056 | 6/20/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Daily - Cordova Middle Level 1 Water Treatment - Refer to PM schedule details. | 2/14/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Purchase one chemical pump-GE water& Process Technologies | 8/20/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|---------|-----------------|--|---------------------------------------|
| Cordova MS (2118) 2A | UNIT VENT - RM A13 - COIL BURST FLOODED THE RM AND WTR IS DOWN THE HALLWAY - PM/CLARKE 416-2189 | 1/21/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Water and steam was discovered leaking from boiler. | 1/28/14 | Mechanical Room | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Replace safety valve on boiler | 1/28/14 | Mechanical Room | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Daily - Cordova Middle Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | replace mixing valve actuator in boiler room | 3/19/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Daily - Cordova Middle Level 1 Water Treatment - Refer to PM schedule details. | 3/28/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | per mr clark 416-1513 the make up line on cooling tower #3 has burst, and chiller is low on freon | 3/31/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|----------|--|--|---------------------------------------|
| Cordova MS (2118) 2A | CHILLER NOT COMING ON PLANT MGR-CLARK/361.2056 | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | CHILLER MECH RM-NOT COMING ON-PLANT MGR CLARK 416-1513 KLR | 4/10/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Monthly - Oil Lube & Belt-Cordova Middle - Refer to PM schedule details. | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | CHILLER - NOT COMING ON - PM/CLARKE 416-1513 | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | install tempary chiller | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Monthly - Oil Lube & Belt-Cordova Middle - Refer to PM schedule details. | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | repair hvac controls in library-os | 10/17/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Yearly - #1 Boiler 114-Cordova Mdl- Blr Rm C2F - Refer to PM schedule details. | 7/8/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|----------|--|--|--|
| Cordova MS (2118) 2A | Yearly - #2 Boiler 115-Cordova Mdl- Boiler Rm C2F - Refer to PM schedule details. | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | UNIT VENT ALL ON THE MAIN HALL IN RMS, A1, A2, A3, A4, AND LIBRARY, ALL ARE BLOWING BUT NOT COOLING -HAVING AMINISTRATORS TRAINING CLASSSS TODAY PRIN WHITEHEAD 416-2189 | 7/22/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Monthly - Filter-Cordova Middle - Refer to PM schedule details. | 12/24/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Monthly - Filter-Cordova Middle - Refer to PM schedule details. | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Monthly - Filter-Cordova Middle - Refer to PM schedule details. | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Monthly - CORDOVA MID LVL 2 WATER TREATMENT - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Yearly - Oil Sample-Cordova Middle - Refer to PM schedule details. | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Cordova MS (2118) 2A | Yearly - Cooling Towers(STRAINERS)-Cordova Middle - Refer to PM schedule details. | 3/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|---------|------------------|--------------------------|----------|
| Cordova MS (2118) 2A | The stalls in the restrooms are full of filthy graffiti that needs to be removed before school starts. Need help thanks. | 7/3/13 | Restroom (Girls) | All Restrooms | Painting |
| Cordova MS (2118) 2A | GRAFFITI THRU OUT THE BLDG IN ALL THE RESTROOMS. SBE CLARK 416-1707 | 7/3/13 | | | Painting |
| Cordova MS (2118) 2A | 2 Sunroc water fountains are broken, there is no water flow. | 6/25/14 | Hallway/Corridor | Outside 6th grade lounge | Plumbing |
| Cordova MS (2118) 2A | Underneath water fountain is leaking. | 6/25/14 | Hallway/Corridor | 6th hall outside K-5 | Plumbing |
| Cordova MS (2118) 2A | Assist zone with installing H W Heater | 6/26/14 | | | Plumbing |
| Cordova MS (2118) 2A | The sink near the exit door is leaking. | 4/23/14 | Kitchen | Kitchen C-3 | Plumbing |
| Cordova MS (2118) 2A | UNDERGROUND SPRINKLER OUTSIDE BY DUMPSTER-HAS BURST AND WATER COMING UP THRU GROUND-PLANT MGR CLARK 416-1513 KLR | 4/23/14 | | | Plumbing |
| Cordova MS (2118) 2A | Toilet seat broken off. | 5/14/14 | Restroom (Boys) | 7th grade | Plumbing |

| | | | | | |
|----------------------|---|---------|-----------------|-----------------------|----------|
| Cordova MS (2118) 2A | Install water tank | 5/27/14 | | | Plumbing |
| Cordova MS (2118) 2A | Front entrance right side, water drain pipe has come apart. Need help thanks. | 8/22/13 | Grounds | Front entrance | Plumbing |
| Cordova MS (2118) 2A | Toilet leaking water on the floor. | 8/23/13 | Restroom (Boys) | 8th Lounge | Plumbing |
| Cordova MS (2118) 2A | After plunging urinal it still over flows when flushed. | 1/16/14 | Restroom (Boys) | 7th Grade hall | Plumbing |
| Cordova MS (2118) 2A | Urinal water will not stop running. | 1/28/14 | Restroom (Boys) | 8th grade hall | Plumbing |
| Cordova MS (2118) 2A | 6th grade has two toilets down. The 8th grade has one urinal down. | 3/4/14 | Restroom (Boys) | 6th grade & 8th grade | Plumbing |
| Cordova MS (2118) 2A | There is a strong sewer odor. | 3/24/14 | Library | Library A-6 | Plumbing |
| Cordova MS (2118) 2A | Urinal line clogged and runs over when flushed. | 3/31/14 | Restroom (Boys) | 7th grade hall | Plumbing |

| | | | | | |
|----------------------|--|---------|------------------|------------------|----------|
| Cordova MS (2118) 2A | Water is leaking from the top of urinal. | 4/11/14 | Restroom (Boys) | 6th grade hall | Plumbing |
| Cordova MS (2118) 2A | Receive water and place it inside of the building. | 4/16/14 | | | Plumbing |
| Cordova MS (2118) 2A | Water fountain broken, no water flow. | 9/5/13 | Hallway/Corridor | 8th grade lounge | Plumbing |
| Cordova MS (2118) 2A | Every morning the restroom floor is flooded from leaking toilet. | 9/16/13 | Restroom (Girls) | 6th wing | Plumbing |
| Cordova MS (2118) 2A | Toilet is leaking water onto the floor. | 9/16/13 | Restroom (Boys) | 7th wing | Plumbing |
| Cordova MS (2118) 2A | Urinal water constantly runs. | 9/19/13 | Restroom (Boys) | 6th wing | Plumbing |
| Cordova MS (2118) 2A | FOUNTAIN IS RUNNING, CANT CONTROL IN CAFE. PLANT MGR-CLARK/416.1700 | 9/20/13 | | | Plumbing |
| Cordova MS (2118) 2A | The hand wash sink sensors are bad, no water flow. | 9/25/13 | Restroom (Boys) | 6th hall | Plumbing |

| | | | | | |
|----------------------|--|---------|---------------------|----------------|----------|
| Cordova MS (2118) 2A | Water running in sink, cannot turn off. | 7/23/13 | Restroom (Boys) | 7th grade hall | Plumbing |
| Cordova MS (2118) 2A | Water is not coming on in hand sink. | 7/23/13 | Restroom (Girls) | 8th grade hall | Plumbing |
| Cordova MS (2118) 2A | The urinals are barley flushing. | 7/23/13 | Administration Area | boys restroom | Plumbing |
| Cordova MS (2118) 2A | The toilet seat is broken. | 7/23/13 | Restroom (Girls) | 8th grade hall | Plumbing |
| Cordova MS (2118) 2A | Toilet seat is broken, needs to be changed out. Thanks. | 8/2/13 | Restroom (Boys) | Gym area | Plumbing |
| Cordova MS (2118) 2A | Urinal is clogged and will not flush properly. Need help thanks. | 8/5/13 | Restroom (Boys) | Front hall | Plumbing |
| Cordova MS (2118) 2A | Unit ventilator in M14 running water per JT Clark 416-2189 | 8/13/13 | | | Plumbing |
| Cordova MS (2118) 2A | Toilet seat has been broken off. | 8/15/13 | Restroom (Boys) | 6th Grade hall | Plumbing |

| | | | | | |
|----------------------|--|----------|------------------|--------------------------|----------|
| Cordova MS (2118) 2A | Cafeteria manager said garbage disposal is not operating properly. | 10/29/13 | Kitchen | kitchen area | Plumbing |
| Cordova MS (2118) 2A | Water fountain broken. | 11/13/13 | Gym | Boys Locker RM. | Plumbing |
| Cordova MS (2118) 2A | Water fountain is not cooling water. | 11/13/13 | Gym | Outside of gym boys side | Plumbing |
| Cordova MS (2118) 2A | Water fountain not working. | 11/13/13 | Gym | Outside gym girls side | Plumbing |
| Cordova MS (2118) 2A | Two water fountains clogged. | 11/13/13 | Hallway/Corridor | 7th grade hall | Plumbing |
| Cordova MS (2118) 2A | Urinal pipe has come apart leaking water. I closed off water inlet. | 12/9/13 | Restroom (Boys) | 7th grade hall | Plumbing |
| Cordova MS (2118) 2A | The toilet still not flushing after plunging and snaking. | 12/9/13 | Restroom (Boys) | 7th grade hall | Plumbing |
| Cordova MS (2118) 2A | Every rainy day, water comes out of electrical outlets left side of concession area. | 5/14/14 | Concession Stand | Outside concession area | Roof |

| | | | | | |
|----------------------|---|----------|--|--|-------------|
| Cordova MS (2118) 2A | Request gutter around BLDG be cleaned out. | 10/24/13 | | | Roof |
| Cordova MS (2118) 2A | gutters front of bldg. must be cleaned out Per. John Smith-os | 10/22/13 | | | Roof |
| Cordova MS (2118) 2A | Request duct work be done for new water heater. | 6/9/14 | | | Sheet Metal |

| Count of Craft | Craft | | | |
|------------------------|------------|----------|----------|-------------|
| Location | Electrical | Painting | Plumbing | Grand Total |
| Cordova Stadium 606-2A | 1 | 8 | 4 | 13 |
| Grand Total | 1 | 8 | 4 | 13 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|--|----------------|------------------|-------------|------------|
| Cordova Stadium 606-2A | outside lights around the concession stand area are out, please repair | 9/10/13 | Athletic Field | | Electrical |
| Cordova Stadium 606-2A | paint lines on football field | 8/20/13 | | | Painting |
| Cordova Stadium 606-2A | paint lines on football field | 8/26/13 | | | Painting |
| Cordova Stadium 606-2A | paint lines on football field | 9/3/13 | | | Painting |
| Cordova Stadium 606-2A | paint lines on football field | 9/9/13 | | | Painting |
| Cordova Stadium 606-2A | paint lines on football field | 9/23/13 | | | Painting |
| Cordova Stadium 606-2A | paint lines on football field | 10/7/13 | | | Painting |

| | | | | | |
|------------------------|--|----------|----------------|--|----------|
| Cordova Stadium 606-2A | paint lines on football field | 10/21/13 | | | Painting |
| Cordova Stadium 606-2A | paint lines on football field | 10/28/13 | | | Painting |
| Cordova Stadium 606-2A | Sprinkler heads out on football field | 8/22/13 | | | Plumbing |
| Cordova Stadium 606-2A | please repair broken toilet that will not flush and is leaking in men's restroom at football stadium | 8/27/13 | Athletic Field | | Plumbing |
| Cordova Stadium 606-2A | Request Stadium be winterized. | 11/12/13 | Athletic Field | | Plumbing |
| Cordova Stadium 606-2A | Turn on water to sprinkler system, check all zones, and make needed sprinkler head repairs, thanks | 5/22/14 | Athletic Field | | Plumbing |

| Count of Craft | Craft | | | | | | | | | |
|--------------------|----------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| | Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal |
| Dexter ES (0067) 2 | 1 | 1 | 19 | 40 | 23 | 3 | 19 | 11 | 6 | 123 |
| Grand Total | 1 | 1 | 19 | 40 | 23 | 3 | 19 | 11 | 6 | 123 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|---------------------|---|---------------|---------------------|-------------------|-----------|
| Dexter ES (0067) 2A | Request is to Have Carpet replaced in the Main office area due to bad smell that students have been having accidents on and Have a Bad oder. request is to have tile in it's place (Per request by the principal) | 9/17/13 | Administration Area | Main Office | Asbestos |
| Dexter ES (0067) 2A | Dexter EI- WO385465-- Request that computer drop to be placed on the childcare office. THANK-YOU (SCS Network Cabling and Electronics dept. "Please see the principal") | 9/23/13 | Cafeteria | Child care Office | Cabling |
| Dexter ES (0067) 2A | Request is to have a Cork board hung in the Hallway down the 300-Hall per request by the principal. Thank-you (Please see the Plant Manager or Principal) | 9/19/13 | 1st Floor | 300 Hall | Carpentry |
| Dexter ES (0067) 2A | Request is to have cork board removed from the Plant Managers office to the assistant Principals office. Thank-you Please see the PM | 9/19/13 | 1st Floor | Plant Mnager | Carpentry |
| Dexter ES (0067) 2A | Request is to have cork board removed out of the T W A on the 100 Hall to be placed in the Principals office. Thank-you (please locate Plant manager or Principal) | 9/23/13 | | | Carpentry |
| Dexter ES (0067) 2A | Dexter Elementary 0067-4A Request is to have cork board removed out of the T W A on the 100 Hall to be placed in the Principals office. Thank-you (please locate Plant manager or Principal) 2nd request | 10/10/13 | Administration Area | office | Carpentry |
| Dexter ES (0067) 2A | Dexter Elementary 0067-4A Request is to have cork board removed from the Plant Managers office to the assistant Principals office. Thank-you Please see the PM (2nd request) | 10/10/13 | 1st Floor | Hallway/Corridor | Carpentry |

| | | | | | |
|---------------------|---|----------|------------------|-----------------|-----------|
| Dexter ES (0067) 2A | Dexter Elementary 0067-4A Request is to have a Cork board hung in the Hallway down the 300-Hall per request by the principal. Thank-you (Please see the Plant Manager or Principal) | 10/10/13 | 1st Floor | 300 hall | Carpentry |
| Dexter ES (0067) 2A | Request that diverter be placed around vent in the ceiling it's making the projector over heat in the classroom. Thank-you | 12/13/13 | Classroom | 202 | Carpentry |
| Dexter ES (0067) 2A | Request that the tile be repaired in the gym by the exterior door that Leads out. Thank-you | 1/8/14 | Gym | gym | Carpentry |
| Dexter ES (0067) 2A | Request that counter in the girls restroom be repaired it's a hazard to the students. Thank-you | 1/16/14 | Restroom (Girls) | 100-Hall | Carpentry |
| Dexter ES (0067) 2A | Request that Door to storage room be repaired. Thank you | 1/27/14 | Classroom | 115 Music | Carpentry |
| Dexter ES (0067) 2A | Request is that exterior door that Leads out to the bus lane be repaired it's sticking. Thank-you | 1/27/14 | Cafeteria | cafeteria | Carpentry |
| Dexter ES (0067) 2A | Request that cut ceiling tile be place in the restroom in the Teachers lounge. Thank-you | 2/7/14 | 1st Floor | Teachers Lounge | Carpentry |
| Dexter ES (0067) 2A | Request that Door to the Restroom be repaired will not lock. Thank-you | 2/12/14 | 1st Floor | TWA 200-Hall | Carpentry |

| | | | | | |
|---------------------|---|---------|---------------------|---------------|------------|
| Dexter ES (0067) 2A | Request that door mullion be repaired to the cafeteria at the bottom. THANK-YOU | 8/8/13 | Cafeteria | entrance door | Carpentry |
| Dexter ES (0067) 2A | Request that latch to book room be repaired due to other side will not open. THANK-YOU door is located on the right side as you enter the 300-Hall | 8/13/13 | Hallway/Corridor | Book room | Carpentry |
| Dexter ES (0067) 2A | Request that the handle to the door in the Main office be repaired has come off several times. Thank-you | 9/12/13 | Administration Area | Main Office | Carpentry |
| Dexter ES (0067) 2A | Request that interior door be repaired due to slamming of the door. Thank-you (Door on the left) | 2/25/14 | Administration Area | Main office | Carpentry |
| Dexter ES (0067) 2A | Request that exterior second Door on the right as you exit need to be repaired. Need door closer.(See Plant Manager) Thank-you | 2/25/14 | Administration Area | Main entrance | Carpentry |
| Dexter ES (0067) 2A | Request that restroom door lock be repaired as you enter the teachers workroom. Thank-you | 2/25/14 | 1st Floor | TWA-200 Hall | Carpentry |
| Dexter ES (0067) 2A | Please run Test. Generator Level 2 Facilities ETSS annual load test NFPA 110 | 7/19/13 | | | Electrical |
| Dexter ES (0067) 2A | Request is to have metal lens repaired in the Library due to falling damaged in nee of repair. Thank-you (only 1 that's Damaged) | 7/31/13 | Library | Library | Electrical |

| | | | | | | |
|---------------------|--|----------|---------------------|--|-------------------------|------------|
| Dexter ES (0067) 2A | Urgent test and turn in by 7/29/2013. Retest Generator. | 7/25/13 | | | | Electrical |
| Dexter ES (0067) 2A | Request two lens on pole light be replaced they have been broken. | 7/30/13 | | | | Electrical |
| Dexter ES (0067) 2A | Request that key switch be repaired in the gym as you enter on the right. THANK-YOU | 7/31/13 | Gym | | gym | Electrical |
| Dexter ES (0067) 2A | Request is for T-8 1022A 6 cases of Lights for school Thank-you What is the STOCK # ? | 9/23/13 | Administration Area | | Plant manager | Electrical |
| Dexter ES (0067) 2A | 4-UNITS NOT COMING ON IN RM-301,303,307,305 PLANT MGR- HUMES/373.3647 | 9/25/13 | | | | Electrical |
| Dexter ES (0067) 2A | Request that 6 cases of Fluorescent lights for school #10221 is the type of bulb that's needed. THANK-YOU | 10/14/13 | 1st Floor | | Plant Manager Office | Electrical |
| Dexter ES (0067) 2A | Verify database in burglar alarm panel. | 10/29/13 | | | | Electrical |
| Dexter ES (0067) 2A | Request that 2 Light ballast be placed in light fixture in the computer lab. Thank-you | 11/6/13 | 1st Floor | | Computer Lab 101 | Electrical |

| | | | | | |
|---------------------|--|----------|-----------------|----------|------------|
| Dexter ES (0067) 2A | Request that light ballast be repaired in the classroom there 3 that are bad. Thank-you | 11/20/13 | Classroom | 306 | Electrical |
| Dexter ES (0067) 2A | Request that Light ballast be repaired in the classroom there 2 that are out. Thank-you | 11/20/13 | Classroom | 303 | Electrical |
| Dexter ES (0067) 2A | Request that 5 Light be repaired in the cafeteria. Thank-you | 11/20/13 | Cafeteria | ceiling | Electrical |
| Dexter ES (0067) 2A | Request that exhaust fan in the Restroom boys be repaired come in and out. Thank-you | 12/3/13 | Restroom (Boys) | 100-Hall | Electrical |
| Dexter ES (0067) 2A | Request that button to the door bell be replaced. Thank-you | 12/18/13 | Kitchen | kitchen | Electrical |
| Dexter ES (0067) 2A | Put in code for GCA Delbert Means Jr. | 2/3/14 | | | Electrical |
| Dexter ES (0067) 2A | Request that exhaust fan in the restroom be repaired Not working. Thank-you | 2/20/14 | Restroom (Boys) | 200 Hall | Electrical |
| Dexter ES (0067) 2A | Dexter Elementary (0067) 4A Request that exhaust fan in the restroom be repaired Not working. Thank-you | 2/20/14 | Restroom (Boys) | 300-Hall | Electrical |

| | | | | | |
|---------------------|--|---------|---------------------|-------------------|------------|
| Dexter ES (0067) 2A | Request that light be repaired in the Confr room in the main office. Thank-you | 8/8/13 | Administration Area | confrenance room | Electrical |
| Dexter ES (0067) 2A | Request that Exhaust fan in the electrical closet be repaired not working. THANK-YOU | 8/13/13 | Gym | Electrical closet | Electrical |
| Dexter ES (0067) 2A | Request that the Light ballast be repaired in the classroom witch is as you enter the classrooms Thank you | 8/22/13 | Classroom | 107 | Electrical |
| Dexter ES (0067) 2A | Request that exhaust fan in the gym be repaired in the electrical closet. thank-you | 8/22/13 | Gym | Eletrical closet | Electrical |
| Dexter ES (0067) 2A | Request is to have Lights change in the cafeteria there several that are out and the PM have bulbs. Thank you | 8/22/13 | Cafeteria | cafeteria | Electrical |
| Dexter ES (0067) 2A | Request that Light ballast be put in the light behind the stage in the cafeteria. THANK-YOU | 8/22/13 | | | Electrical |
| Dexter ES (0067) 2A | Request that light be repaired need a ballast. Thank-you | 9/4/13 | Library | Library | Electrical |
| Dexter ES (0067) 2A | Request that Lights be changed in the cafe have 8 10 that are out and need to be replaced. thank-you | 9/4/13 | Cafeteria | cafeteria | Electrical |

| | | | | | |
|---------------------|--|---------|-----------------|----------|------------|
| Dexter ES (0067) 2A | Request that three pole Lights be repaired in the Main Parking Lot. Thank-you | 9/17/13 | Parking Lot | front | Electrical |
| Dexter ES (0067) 2A | Exhaust fan in the 300 restroom needs to be repaired, it's not working. Please contact Plant Mgr when onsite, Thank-you | 3/19/14 | Restroom (Boys) | | Electrical |
| Dexter ES (0067) 2A | Exhaust fan in the 200 restroom needs to be repaired also, it's not working. Please contact Plant Mgr when onsite, Thank-you | 3/19/14 | Restroom (Boys) | | Electrical |
| Dexter ES (0067) 2A | Request that exhaust fan in the restroom be repaired Not working. Thank-you | 3/28/14 | Restroom (Boys) | 100-Hall | Electrical |
| Dexter ES (0067) 2A | Request that exhaust fan in the classroom of the functional skills student are be repaired. Thank-you | 4/3/14 | Classroom | 110 | Electrical |
| Dexter ES (0067) 2A | Request that the exhaust fan be repaired in the Boys restroom Thank-you | 4/3/14 | Restroom (Boys) | 100-Hall | Electrical |
| Dexter ES (0067) 2A | Request that Pole Lights be repaired there 3 that are out. Thank-you | 4/8/14 | Parking Lot | Bus Lane | Electrical |
| Dexter ES (0067) 2A | Request that belt be placed on the restroom exhaust fan in the Preschool classroom. Thank-you | 4/8/14 | Classroom | 204-206 | Electrical |

| | | | | | |
|---------------------|---|---------|---------------------|-------------------|---------------------------------------|
| Dexter ES (0067) 2A | Request that floor receptacle be repaired in the gym due to sparks coming from the plugs. Thank-you | 4/24/14 | Gym | gym | Electrical |
| Dexter ES (0067) 2A | Request that light ballast in the storage room across from classroom 103. Thank-you | 5/5/14 | 1st Floor | storage room | Electrical |
| Dexter ES (0067) 2A | Request is for a light ballast to be place in the light fixture. Thank-you | 5/5/14 | Classroom | 111 | Electrical |
| Dexter ES (0067) 2A | Dexter Middle 0068-4A Request that 2 Light ballast be repaired in the Main office area. Thank you this ticket is for the elementary school and not Dexter middle. THANK YOU | 7/19/13 | Administration Area | Main office | Electrical |
| Dexter ES (0067) 2A | Please repair the light in classroom 413 near the teachers desk. | 7/15/13 | | | Electrical |
| Dexter ES (0067) 2A | Request that Exhaust fan be repaired in the gym electrical closet belt broken. THANK-YOU | 7/31/13 | Gym | electrical closet | Electrical |
| Dexter ES (0067) 2A | Request is to have the AC unit repaired in the science Lab. Thank-you | 9/19/13 | 1st Floor | Science Lab 102 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Check no cool in 4 rooms on 400 hall | 10/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|----------|---------------------|-----------------------|---------------------------------------|
| Dexter ES (0067) 2A | Request that thermostat be calibrated due to it will not come on in the classroom. Thank-you | 10/16/13 | 1st Floor | 206 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that system run during the PTA program on Thursday 17 2003 from 4:00Pm Till 9:00Pm Thank-you | 10/17/13 | Cafeteria | Cafeteria/Main Office | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit in the Principal office be repaired due to not heating. Thank-you | 11/14/13 | Administration Area | Principals Office | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be repaired in the Library due to not Heating Thank-you | 11/14/13 | Library | Library | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be repaired blow cold air. Thank-you | 11/25/13 | 1st Floor | 118 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request is to have the units repaired in the school All Not working. Thank-you | 12/9/13 | Classroom | school | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be repaired blowing cold air in the classroom. Thank-you | 12/9/13 | Classroom | 118 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be repaired in the Art room blowing cold air. Thank-you | 12/10/13 | Classroom | 215 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|---------|---------------------|--------------|---------------------------------------|
| Dexter ES (0067) 2A | Request that unit be repaired in the preschool not working. Thank-you | 1/8/14 | Classroom | 206 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request is to have the unit checked for heat it's blowing low in the front office area were the receptionist sit. Thank-you | 1/28/14 | Administration Area | front | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that Heat exchange be checked due to slight gas smell in the preschool classroom. Thank-you | 1/30/14 | Classroom | 206 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | per mcmickens 373-3526 library heat not working and rooms 414 and 416 heat goes off and doesn't come back on after lunch | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Change filters on whole building | 2/13/14 | | Whole School | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | UNIT NOT COMING ON IN RM-111. PLANT MGR-SMITH/373.3263 | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | UNIT HAS A FOUL ODOR IN RM-205. PLANT MGR-SMITH/373.3659 | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be repaired not working. Thank-you | 9/9/13 | Classroom | Science Lab | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|---------|---------------------|---------------|---------------------------------------|
| Dexter ES (0067) 2A | Request that unit be repaired not working and will not run. Thank-you | 9/9/13 | Classroom | Science Lab | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | PM kitchen | 7/10/13 | | kitchen | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be repaired in the main Hallway/Corridor has dripping and not cooling. THANK-YOU | 8/1/13 | Hallway/Corridor | main hallway | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that unit be checked not cooling blowing warm air. THANK-YOU | 8/1/13 | Classroom | 311 | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Program whole school for GCA cleaning and waxing | 7/22/13 | | Whole school | Heating/Ventilation /Air Conditioning |
| Dexter ES (0067) 2A | Request that the exterior Doors be painted outside next to the Coaches office. Thank-you | 6/17/14 | Gym | Door-Exterior | Painting |
| Dexter ES (0067) 2A | Request that back wall to be painted due to chipping paint. Thank-you | 12/2/13 | Administration Area | Main Office | Painting |
| Dexter ES (0067) 2A | Request that 24 cans of KILZ sealer primer #PT18 or #10658 | 3/10/14 | 1st Floor | Plant Manager | Painting |

| | | | | | |
|---------------------|---|----------|-----------------|----------------------|----------|
| Dexter ES (0067) 2A | Monthly grease trap inspection. | 7/16/13 | | | Plumbing |
| Dexter ES (0067) 2A | Please repair the toilet in the teachers lounge.. | 7/26/13 | | | Plumbing |
| Dexter ES (0067) 2A | Request that the drinking fountain in the cafe be repaired due to low water. THANK-YOU | 10/14/13 | Cafeteria | cafeteria | Plumbing |
| Dexter ES (0067) 2A | Request that urinal be repaired due to water will not stop running. Thank-you | 10/24/13 | Restroom (Boys) | Across from Gym | Plumbing |
| Dexter ES (0067) 2A | Test the following RP Serial # L05995 3" 975 W/Z | 1/15/14 | | Outside storage room | Plumbing |
| Dexter ES (0067) 2A | Test the following RP Serial # L05986 3" 975 W/Z | 1/15/14 | | Outside storage room | Plumbing |
| Dexter ES (0067) 2A | Test the following RP Serial # 1361882 1 1/4" 975 W/Z | 1/15/14 | | Room 102 | Plumbing |
| Dexter ES (0067) 2A | Test the following RP Serial # 1361894 1 1/4" 975 W/Z | 1/15/14 | | Room 102 | Plumbing |

| | | | | | |
|---------------------|--|---------|------------------|----------|----------|
| Dexter ES (0067) 2A | TOILET IS OVERFLOWING , CANT CONTROL GREEN HALL B/RR PRIN-ANGELA/373.3659 | 1/29/14 | | | Plumbing |
| Dexter ES (0067) 2A | Request that urinal be repaired it's leaking from the bottom Thanks | 1/30/14 | Restroom (Boys) | 300 Hall | Plumbing |
| Dexter ES (0067) 2A | This ticket was sent to the wrong location #412802 But this request is for the clogged up urinal on the 300 Hall at Dexter elementary. Thank-you | 1/30/14 | Restroom (Boys) | 300-Hall | Plumbing |
| Dexter ES (0067) 2A | Request that Drinking fountain be repaired outside the restroom on the 100-Hall. Thank-you | 8/16/13 | Hallway/Corridor | 100-Hall | Plumbing |
| Dexter ES (0067) 2A | Request is to have the drinking fountain be repaired in the middle. THANK-YOU | 8/16/13 | Hallway/Corridor | 300-Hall | Plumbing |
| Dexter ES (0067) 2A | Request that urinal be repaired in the boys restroom on the 300 Hall. (water has been shut off) THANK-you | 8/22/13 | Hallway/Corridor | | Plumbing |
| Dexter ES (0067) 2A | toilet is stop up it will not flush | 3/26/14 | Cafeteria | | Plumbing |
| Dexter ES (0067) 2A | Request is to have toilet repaired in the kitchen due to being clogged. Thank-you | 3/26/14 | Kitchen | Restroom | Plumbing |

| | | | | | |
|---------------------|---|---------|------------------|-----------------|----------|
| Dexter ES (0067) 2A | Request that sink be repaired leaking around the u pipe under the sink. Thank-you | 4/8/14 | Classroom | 108 | Plumbing |
| Dexter ES (0067) 2A | Request that toilet be repaired around the bottom in the Preschool classroom. Thank-you | 4/8/14 | | | Plumbing |
| Dexter ES (0067) 2A | Request that Hot water heater be repaired will not stop leaking. Thank-you | 6/16/14 | Custodial Closet | 100-Hall | Plumbing |
| Dexter ES (0067) 2A | Request that roof leak be repaired in the coaches office. Thank-you | 1/15/14 | Gym | office | Roof |
| Dexter ES (0067) 2A | Request that leak be repaired in the Preschool restroom between both classrooms. THANK-YOU | 2/7/14 | Classroom | 204-206 | Roof |
| Dexter ES (0067) 2A | Request that leak in the classroom over the window be repaired. Thank-you | 2/7/14 | Classroom | 409 | Roof |
| Dexter ES (0067) 2A | Request that leak be repaired in the classroom next to the window. THANK-YOU | 8/16/13 | Classroom | 400 | Roof |
| Dexter ES (0067) 2A | Request that roof leak be repaired over the restroom in the Teachers Lounge Thank-you | 3/4/14 | 1st Floor | Teachers Lounge | Roof |

| | | | | | |
|---------------------|---|----------|----------------|-------------|-------------|
| Dexter ES (0067) 2A | Request that leak in the classroom be repaired over the Teachers Desk | 3/4/14 | Classroom | 407 | Roof |
| Dexter ES (0067) 2A | Request that roof Leaks be repaired in the science Lab classroom 407 and the Teachers Lounge this ticket was sent in but was told by email to put all roof tickets on one. Thank-you | 3/4/14 | Classroom | Science Lab | Roof |
| Dexter ES (0067) 2A | Request that roof leak be repaired in the Art room witch is leaking over the sink. Thank-you | 4/8/14 | Classroom | 212 | Roof |
| Dexter ES (0067) 2A | Request that leak be repaired in the classroom in the corner SW of the classroom. Thank-you | 4/30/14 | Classroom | 413 | Roof |
| Dexter ES (0067) 2A | Request that leak be repaired in the right corner of he classroom. Thank-you | 5/2/14 | Classroom | 212 | Roof |
| Dexter ES (0067) 2A | Request that Leak in Both classrooms be repaired and both are near window. Thank-you | 6/11/14 | Classroom | 400-403 | Roof |
| Dexter ES (0067) 2A | Request that anchor pole be placed in the lawn shed floor. Thank-you Please see the Plant manager or Principal or Assistant principal. | 9/23/13 | Athletic Field | Lawn shed | Sheet Metal |
| Dexter ES (0067) 2A | Request that mail box be repaired or replaced due to Damage very badly. Thank-you | 10/28/13 | Parking Lot | parking lot | Sheet Metal |

| | | | | | |
|---------------------|---|----------|----------------|----------------------|-------------|
| Dexter ES (0067) 2A | Please make a diverter for heat vent. | 12/17/13 | | | Sheet Metal |
| Dexter ES (0067) 2A | Request that damage mailbox in the front of school due to Bus hitting the mailbox. Need to be relocated and replaced. Thank-you | 2/19/14 | Parking Lot | Front entrance | Sheet Metal |
| Dexter ES (0067) 2A | Request that latch be made for the preschool playground so students would be secure. Thank-you | 8/16/13 | Athletic Field | Preschool Playground | Sheet Metal |
| Dexter ES (0067) 2A | Request that Mail box to be relocated Per request by the Principal because the box has been damaged several were it's Located. | 2/21/14 | Parking Lot | Mail Box | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|---------------------|----------|----------|-----------|------------|------|----------|----------|------|-------------|
| | Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal |
| Dexter MS (0068) 2A | 1 | 22 | 45 | 35 | 1 | 27 | 7 | 3 | 141 |
| Grand Total | 1 | 22 | 45 | 35 | 1 | 27 | 7 | 3 | 141 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|---------------------|---|----------------------|-------------------------|--------------------|--------------|
| Dexter MS (0068) 2A | Request that missing ceramic tiles be repaired in the boys and girls restrooms across from class 200 Thank you | 4/30/14 | Restroom (Boys) | Boys-Girls | Asbestos |
| Dexter MS (0068) 2A | Request that pristege Board o be placed on the wall in the main office please see the Sec. Thank-yoe | 5/2/14 | Administration Area | Main office | Carpentry |
| Dexter MS (0068) 2A | Request that both exterior doors be repaired due to the latch not catching. by the gym and the band room Thank-you | 5/6/14 | 1st Floor | Hall | Carpentry |
| Dexter MS (0068) 2A | Request that rack for ropes and hoops need to hung in the back storage room. (see the gym coach) Thank-you | 5/15/14 | Gym | office | Carpentry |
| Dexter MS (0068) 2A | Request that door handle be repaired to the interior door to the gym as you enter. Thank-you | 5/27/14 | Gym | interior door | Carpentry |
| Dexter MS (0068) 2A | Request that cable be replaced on the flag pole in front of school the cable is damaged. THANK-YOU | 8/14/13 | Parking Lot | front parking Lot | Carpentry |
| Dexter MS (0068) 2A | CTR MULL DAMAGED ON FRONT ENTRANCE DOORS WILL NOT BE ABLE TO SECURE BLDG-CALLED IN BY PRIN JONES 373-3134 KLR | 8/23/13 | | | Carpentry |

| | | | | | |
|---------------------|--|----------|-----------|-----------------|-----------|
| Dexter MS (0068) 2A | Request that the door on the left as you enter the school be repaired. the mullion has come out several times. THANK-YOU | 8/24/13 | 1st Floor | Main Entrance | Carpentry |
| Dexter MS (0068) 2A | Request that door be repaired on the back door lock sticking. Thank-you | 9/3/13 | Kitchen | kitchen | Carpentry |
| Dexter MS (0068) 2A | Mullon on door need fixing the bottom is broken. | 10/22/13 | | Cafeteria | Carpentry |
| Dexter MS (0068) 2A | Request that projector screen be hung on the wall in the cafe per request by the Assistant principal. Thank-you | 10/23/13 | Cafeteria | cafeteria | Carpentry |
| Dexter MS (0068) 2A | Request that the front door be repaired very soon will not shut Tight at all. Thank-you | 10/29/13 | 1st Floor | Main entrance | Carpentry |
| Dexter MS (0068) 2A | Request that over head screen to be placed on the wall. Thank-you | 11/5/13 | Cafeteria | Cafeteria/stage | Carpentry |
| Dexter MS (0068) 2A | Request that Door to the stall be repaired has fallen off the Hinges. Thank you (Door Location in the PM office) if the Plant Manager is Not there go to the main office. | 1/21/14 | Gym | Boys Restroom | Carpentry |
| Dexter MS (0068) 2A | Request that third door on the right be repaired screws on the top of the door need to be replaced as well as the mullion. Thank-you | 2/12/14 | 1st Floor | Main Entrance | Carpentry |

| | | | | | |
|---------------------|---|---------|-------------|-----------------------------|-----------|
| Dexter MS (0068) 2A | Request that cracks be repaired around the drinking Fountain in the gym due to students. Thank-you | 2/13/14 | Gym | Gym | Carpentry |
| Dexter MS (0068) 2A | Request that the door to the restroom be repaired. Thank-you | 2/13/14 | 1st Floor | across from the science Lab | Carpentry |
| Dexter MS (0068) 2A | Request that snagged cable to the flag pole be repaired. Thank-you | 2/24/14 | Parking Lot | Flag pole | Carpentry |
| Dexter MS (0068) 2A | Request is to have cork boards placed on the wall for the title Admin. THANK-YOU | 3/7/14 | Classroom | 115 | Carpentry |
| Dexter MS (0068) 2A | Request that cork board to be hung in the classroom on the east wall. Thank-you | 3/19/14 | Classroom | 118 | Carpentry |
| Dexter MS (0068) 2A | Request that door lock be repaired in the classroom 222 (sticking) | 4/2/14 | Classroom | 222 | Carpentry |
| Dexter MS (0068) 2A | Request that front Door that leads into the main office be repaired door closer is damaged. it's the interior as you enter the building. Thank-you | 4/16/14 | 1st Floor | Main Office | Carpentry |
| Dexter MS (0068) 2A | Request that 1by2 wooden tack strip be placed on the wall in the Band room. Thank-you | 4/25/14 | Classroom | Band room | Carpentry |

| | | | | | |
|---------------------|---|---------|---------------------|------------------|------------|
| Dexter MS (0068) 2A | See Principle she ask for new codes and a removal of one code. | 5/7/14 | | | Electrical |
| Dexter MS (0068) 2A | Request that 10 to 13 Lights be replaced in the cafeteria that are bad in the ceiling. 2 that are ballast. Thank-you | 7/19/13 | Cafeteria | cafeteria | Electrical |
| Dexter MS (0068) 2A | Request that lights in the foyer be repaired there several that are out. 3 to 4 THANK-YOU | 7/19/13 | Hallway/Corridor | Main Entrance | Electrical |
| Dexter MS (0068) 2A | Request is for 7-8 cases of Fluorescent lights for Hallway/corridor due to many Lights that are burned out. Fluorescent Lights 30 count (10221) THANK-you | 7/19/13 | | | Electrical |
| Dexter MS (0068) 2A | Request that 2 Light ballast be repaired in the Main office area. Thank you | 7/19/13 | Administration Area | Office | Electrical |
| Dexter MS (0068) 2A | Request that plate be placed on electrical cover in the ceiling of the gym near light fixture. (please locate the plant manager) Thank-you | 7/23/13 | Gym | gym | Electrical |
| Dexter MS (0068) 2A | Request that exhaust fan in the kitchen restroom be repaired. Thank-you | 7/23/13 | Kitchen | Restroom | Electrical |
| Dexter MS (0068) 2A | Request that key switch be repaired in the corridor near the main office.THANK-YOU | 7/29/13 | Hallway/Corridor | Hallway/Corridor | Electrical |

| | | | | | |
|---------------------|---|---------|------------------|-----------------------------|------------|
| Dexter MS (0068) 2A | Request that wall plate be placed on the wall in the coaches on the right side as you enter the Office. Thankyou | 7/29/13 | Gym | coaches office | Electrical |
| Dexter MS (0068) 2A | Request that lights in the cafeteria be changed there several out and to high to reach. THANK-YOU | 7/15/13 | Cafeteria | cafeteria | Electrical |
| Dexter MS (0068) 2A | Request is to have exhaust fan in the kitchen restroom repaired belt broken #TRUFLEX 2107 - 4L107 THANK-YOU | 8/1/13 | Kitchen | Restroom | Electrical |
| Dexter MS (0068) 2A | Request that light be repaired outside the main office a ballast is needed. THANK-YOU | 8/6/13 | Hallway/Corridor | outside main office | Electrical |
| Dexter MS (0068) 2A | Request that Light ballast be placed in the light over the smart board in the classroom. Thank-you | 8/6/13 | Classroom | 211 | Electrical |
| Dexter MS (0068) 2A | Request that 10 cases of Fluorescent lights for school #10221 is the type of bulb that's needed. THANK-YOU | 8/6/13 | Hallway/Corridor | Hallway/Corridor-Classrooms | Electrical |
| Dexter MS (0068) 2A | Request that canopy Lights in the front entrance be repaired there 4 that are out. THANK-YOU | 8/13/13 | 1st Floor | Main entrance | Electrical |
| Dexter MS (0068) 2A | Request that Air unit be repaired in the classroom due to breaker will not reset. THANK-YOU | 8/13/13 | Classroom | 206 | Electrical |

| | | | | | |
|---------------------|--|----------|---------------------|-------------------------|------------|
| Dexter MS (0068) 2A | Request that exit light be repaired there's 1 that is out. THANK-YOU | 8/14/13 | Hallway/Corridor | outside Teachers Lounge | Electrical |
| Dexter MS (0068) 2A | Request that exit light be repaired in the gym as you enter. THANK-YOU | 8/14/13 | | | Electrical |
| Dexter MS (0068) 2A | Request that Exit Light be repaired in the gym as you enter the Gym. Thank-you | 9/3/13 | Gym | Entrance | Electrical |
| Dexter MS (0068) 2A | Request is for T-8 1022A 6 cases of Lights for school Thank-you | 9/23/13 | Administration Area | Plant manager | Electrical |
| Dexter MS (0068) 2A | Request that 5 pole Lights be repaired in the front entrance as you enter the Middle school. Thank-you | 9/27/13 | Parking Lot | Main drive | Electrical |
| Dexter MS (0068) 2A | Request that 3 canopy Lights be repaired as you enter the school not working and is a safety issue as when faculty and staff as they enter building in the mourning. (Per request by the principal) A S A D | 9/27/13 | 1st Floor | Main Entrance | Electrical |
| Dexter MS (0068) 2A | Request that belt be replaced on the exhaust fan in the restroom. Thank-you belt#1031 | 10/1/13 | 1st Floor | TWA | Electrical |
| Dexter MS (0068) 2A | Request that Light be repaired in the girls Locker room. Need to repaired soon because it's out. THANK-YOU | 10/17/13 | Gym | Gym | Electrical |

| | | | | | |
|---------------------|---|----------|---------------------|------------------------|------------|
| Dexter MS (0068) 2A | Request that all Exhaust fan belts be replaced due to there broken in Hallways and Main Office. Thank-you | 10/18/13 | Administration Area | Restroom/School | Electrical |
| Dexter MS (0068) 2A | Request that light ballast to be put in the fixture as you walk in the Lounge. Thank-you | 10/18/13 | 1st Floor | TWA-100 Hall | Electrical |
| Dexter MS (0068) 2A | Request that Light in the boys restroom be repaired over the toilet. (the lights are out) Thank-you | 10/21/13 | Restroom (Boys) | Restroom-100 Hall boys | Electrical |
| Dexter MS (0068) 2A | Request that 6 cases of Fluorescent lights for school #10221 is the type of bulb that's needed. THANK-YOU | 10/22/13 | 1st Floor | Plant Manager office | Electrical |
| Dexter MS (0068) 2A | Request that 4 canopy Lights be repaired in the main entrance due to all the Lights at the entrance are out. Please take of this ticket as soon as possible. (due to security issues) Per request by the Assistant | 10/25/13 | 1st Floor | Main Entrance | Electrical |
| Dexter MS (0068) 2A | Verify database in burglar alarm panel. | 10/29/13 | | | Electrical |
| Dexter MS (0068) 2A | Request that All belts be replace on the exhaust fans in the restroom due to bad smell in the main office Restrooms as well as all the others.(2ND Request has been placed for this school)Please Help? | 11/4/13 | 1st Floor | School | Electrical |
| Dexter MS (0068) 2A | Request that Light ballast be put in the Assistant principals office there is only one light in her area. Thank-you | 12/12/13 | Administration Area | Assistant Principal | Electrical |

| | | | | | |
|---------------------|--|----------|-----------|---------------|------------|
| Dexter MS (0068) 2A | Request that clock in the Hall next to classroom 221 be repaired. Thank-you | 12/13/13 | 1st Floor | 221 | Electrical |
| Dexter MS (0068) 2A | Request that clock in the Hall next to classroom 125 be repaired. Thank-you | 12/13/13 | 1st Floor | 125 | Electrical |
| Dexter MS (0068) 2A | Put in code for GCA Delbert Means Jr. | 2/3/14 | | | Electrical |
| Dexter MS (0068) 2A | Request that lights in the gym be repaired there 2 that are out. Thank-you | 2/24/14 | Gym | Lights | Electrical |
| Dexter MS (0068) 2A | Request is for switch for the bleachers the switch for the Bleachers is not working and need a new or used on for the school games. Thank-you | 3/17/14 | Gym | gym/Office | Electrical |
| Dexter MS (0068) 2A | Request that Canopy Lights be repaired as you enter the school there 2 that's out THANK-YOU | 4/3/14 | 1st Floor | Main Entrance | Electrical |
| Dexter MS (0068) 2A | Request to have to canopy lights repaired there 2 that are out. Thank-you | 4/8/14 | 1st Floor | Main Entrance | Electrical |
| Dexter MS (0068) 2A | Request that 3 Recess Lights to be repaired in the main lobby Thank-you | 4/8/14 | 1st Floor | Main Lobby | Electrical |

| | | | | | |
|---------------------|--|---------|-----------|----------------|---------------------------------------|
| Dexter MS (0068) 2A | Request the electrical plate needs to be put back place in the ceiling due to ball hitting the live wires. plate is missing due to contractors working over the summer. Please send someone soon as possible. | 4/14/14 | Gym | gym | Electrical |
| Dexter MS (0068) 2A | the number 1 on one of my key pads isn't working | 4/22/14 | Kitchen | | Electrical |
| Dexter MS (0068) 2A | Request that plate be placed the floor outlet in the gym. Thank-you | 4/24/14 | Gym | gym | Electrical |
| Dexter MS (0068) 2A | Dexter Elementary 0067-4A Request is to have metal lens repaired in the Library due to falling damaged in nee of repair. Thank-you (only 1 that's Damaged) This Tick was sent the wrong school and it should be | 7/31/13 | Library | library | Electrical |
| Dexter MS (0068) 2A | Request that Light be replaced in the EPSON projector were it has gone out and in need of repair due to the Teacher use. SCS#186448 THANK-YOU | 9/12/13 | Classroom | 112 | Electrical |
| Dexter MS (0068) 2A | Request that unit be repaired due to a loud sound coming from unit when the Air is running. Thank-you | 6/11/14 | 1st Floor | Teacher-Lounge | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired will not run during class. Thank-you | 8/5/13 | Classroom | 118 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that Thermostat be repaired need to be calibrated. THANK-YOU | 8/16/13 | Classroom | 215 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|----------|---------------------|----------------|---------------------------------------|
| Dexter MS (0068) 2A | Request that Gym unit be checked for wasp nest because wasp are coming in Thank-you | 8/28/13 | Gym | gym | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired blowing warm air and not cooling. Thank-you | 9/3/13 | Classroom | 111 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be checked not cooling and condensation coming from the unit on both sides. Thank-you | 9/3/13 | Hallway/Corridor | Front corridor | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired outside the boys restroom. THANK-YOU | 9/30/13 | Restroom (Boys) | 200-Hall | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that AC unit be repaired fan blower not working. Thank you | 10/1/13 | Administration Area | Main office | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that system run during the PSTA program on Thursday 17 2003 from 4:00Pm Till 9:00Pm Thank-you | 10/17/13 | Cafeteria | Cafeteria | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit in the main office be repaired due to not coming on Thank-you | 10/18/13 | Administration Area | office | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request is to have sensors in these classrooms relocated to other classrooms on this hallway so the Classrooms with students in it can have a good reading. Thank-you | 10/25/13 | Classroom | 123-129 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|----------|---------------------|------------------|---------------------------------------|
| Dexter MS (0068) 2A | Request is for Tamper proof screws for the covers in all classroom with sensors. Thank-you | 10/25/13 | Classroom | All classrooms | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired will not heat in the Teachers Lounge. Thank-you | 11/13/13 | 1st Floor | TWA South | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that T-Stat be repaired in the Lawn shed need to be repaired Heater will not come on at all. Thank-you | 11/19/13 | 1st Floor | Lawn Shed | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that Thermostat be repaired next to the gym office has no power. Thank-you | 11/21/13 | Gym | gym | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that the unit be repaired in the classroom will not run. Thank-you | 11/25/13 | 1st Floor | Classroom | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired in this classroom not working. Fan comes on but no heat. Thank you | 12/2/13 | 1st Floor | 202 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired in the principals office due to no Heat. Thank-you | 12/9/13 | Administration Area | Principal office | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired in both fans are Blowing but no heat in these classrooms. THANK-YOU | 12/10/13 | Classroom | 215-218 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|----------|------------------|----------|---------------------------------------|
| Dexter MS (0068) 2A | Request that heat unit be checked not coming on at All. Thank-you | 12/13/13 | Classroom | 217 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired not working. Thank-you | 1/2/14 | Classroom | 216 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired not working nothing is coming out. Thank-you | 1/8/14 | Classroom | 215 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired will not come on at all. Thank-you | 1/15/14 | Classroom | 120 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired due to will not come on Thank-you | 1/16/14 | Classroom | 215 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired near the restroom by the girls on the 100-Hall. Thank-you | 1/22/14 | Restroom (Girls) | Restroom | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that T-stat be repaired in this Classroom unit will not come on. Thank-you | 1/22/14 | Classroom | 113 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit in the boys restroom be checked due to blowing cold air. Thank-you | 1/24/14 | Gym | Restroom | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|---------|-----------|---------|---------------------------------------|
| Dexter MS (0068) 2A | Request is to have the unit repaired in the classroom does not blow heat just hummmm. Thank-you | 1/28/14 | Classroom | 215 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | UNIT NOT COMING ON IN RM-221,120,101 PLANT MGR-CALVIN/596.8540 | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repaired in the computer lab Thank-you | 2/10/14 | 1st Floor | 103 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Change filters in RTU's. | 2/19/14 | | | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Replace A/C unit that caught on fire | 2/20/14 | | 220 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Request that unit be repair in this classroom due to not coming on. Thank-you | 3/25/14 | Classroom | 220 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | Check no A/C on rm 106 | 7/16/13 | | Rm 106 | Heating/Ventilation /Air Conditioning |
| Dexter MS (0068) 2A | PM kitchen | 7/10/13 | | kitchen | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|----------|---------------------|------------------|----------|
| Dexter MS (0068) 2A | Request that outside the Principal office be touched up with white paint due to chipping. Thank-you | 6/17/14 | Administration Area | Principal office | Painting |
| Dexter MS (0068) 2A | Monthly grease trap inspection. | 7/16/13 | | | Plumbing |
| Dexter MS (0068) 2A | Please show plant manager plumbing and gas shut off valves. Also show them problem areas of sewers. | 7/12/13 | | | Plumbing |
| Dexter MS (0068) 2A | Request that urinal be repaired in the boy restroom across from room 102. (leaking from the back on the bottom) | 8/8/13 | Restroom (Boys) | outside 102 | Plumbing |
| Dexter MS (0068) 2A | Request that drinking Fountain be repaired leaking from the bottom. THANK-YOU | 8/22/13 | Restroom (Boys) | 200 hall | Plumbing |
| Dexter MS (0068) 2A | two of my sinks have leaks in one is at the spigot level but one is in the t zone and is leaking water on the floor | 10/15/13 | Kitchen | | Plumbing |
| Dexter MS (0068) 2A | Request that seal be checked on the clean out drain on the side were the band room located. Thank-you | 11/15/13 | 1st Floor | Restrooms | Plumbing |
| Dexter MS (0068) 2A | Request that Pressure valve be repaired due to low water in the dish washer. Thank-you | 11/18/13 | Kitchen | dish room | Plumbing |

| | | | | | |
|---------------------|--|----------|-----------------|------------------|----------|
| Dexter MS (0068) 2A | Request that seal around the clean out drain be repaired in the boy restroom. Thank-you | 11/20/13 | Restroom (Boys) | Main Hall | Plumbing |
| Dexter MS (0068) 2A | Request that the Toilet that located on the right as you enter the second one. Thank-you | 11/20/13 | Restroom (Boys) | 100-Hall | Plumbing |
| Dexter MS (0068) 2A | Request that the clean out drain in the storage room that belong to G C A b repaired. THANK-YOU | 12/3/13 | 1st Floor | GCA storage room | Plumbing |
| Dexter MS (0068) 2A | Request that Gas regulator be checked for trouble due to sticking. Thank-you | 12/12/13 | Kitchen | kitchen | Plumbing |
| Dexter MS (0068) 2A | Test the following RP Serial # L05749 3" 909 Watts | 1/15/14 | | Yard storage | Plumbing |
| Dexter MS (0068) 2A | Test the following RP Serial # L05751 3" 909 Watts | 1/15/14 | | Yard storage | Plumbing |
| Dexter MS (0068) 2A | Test the following RP Serial # 1361833 1 1/4" 909 Watts | 1/15/14 | | Science Lab | Plumbing |
| Dexter MS (0068) 2A | Test the following RP Serial # 131879 1 1/4" 909 Watts | 1/15/14 | | Science Lab | Plumbing |

| | | | | | |
|---------------------|--|---------|-----------------|-----------------------------|----------|
| Dexter MS (0068) 2A | Test the following RP Serial # 1361887 1 1/4" 909 Watts | 1/15/14 | | Science Lab | Plumbing |
| Dexter MS (0068) 2A | Test the following RP Serial # 1361884 1 1/4" 909 Watts | 1/15/14 | | Science Lab | Plumbing |
| Dexter MS (0068) 2A | Request to have urinal repaired clogged. Thank-you | 1/23/14 | Restroom (Boys) | Gym | Plumbing |
| Dexter MS (0068) 2A | gas smell in lobby area | 1/30/14 | | | Plumbing |
| Dexter MS (0068) 2A | Request that urinal be repaired it's leaking from the bottom Thanks | 1/30/14 | Restroom (Boys) | 100-Hall | Plumbing |
| Dexter MS (0068) 2A | Request that urinal be repaired in the boys restroom there 2 that need to be repaired Thank-you | 2/12/14 | Restroom (Boys) | across from the science Lab | Plumbing |
| Dexter MS (0068) 2A | Gas piping failed drop test after fire in RTU. Test all gas piping through out the building. | 2/18/14 | | | Plumbing |
| Dexter MS (0068) 2A | Change out the bad regulators on the RTUs. | 2/19/14 | | | Plumbing |

| | | | | | |
|---------------------|--|---------|-----------|-----------------------|----------|
| Dexter MS (0068) 2A | Request is to have dishwasher repaired leaking water from the bottom. Thank-you | 3/27/14 | Kitchen | Dish room | Plumbing |
| Dexter MS (0068) 2A | Request that area were the generator sits there is water that is about 1ft deep back were the Gas cut off to the school is and the Generator is located. Thanks | 4/28/14 | Gym | Generator area | Plumbing |
| Dexter MS (0068) 2A | Request that the drinking fountain handle be repaired. Thank-you | 4/28/14 | 1st Floor | Boys restroom area | Plumbing |
| Dexter MS (0068) 2A | Request that drinking fountain be repaired across from the science Lab in the main Lobby. Thank-you | 4/28/14 | 1st Floor | Main Lobby | Plumbing |
| Dexter MS (0068) 2A | Request that leak be repaired in the classroom over the window. Thanks. | 5/2/14 | Classroom | 220-226 | Roof |
| Dexter MS (0068) 2A | Request that Leak in the classroom over the Teachers desk be repaired. THANK-YOU | 7/19/13 | Classroom | 401 | Roof |
| Dexter MS (0068) 2A | Request that leak be repaired in classroom near the window to the left. Thanks | 7/23/13 | Classroom | 221 | Roof |
| Dexter MS (0068) 2A | Request that ceiling leak in the Restroom in the Teachers workroom be repaired. Thank-you | 1/15/14 | 1st Floor | TWA-Restroom-100-hall | Roof |

| | | | | | |
|---------------------|---|----------|-----------|-------------------------|-------------|
| Dexter MS (0068) 2A | Request that leak be repaired outside the gym in the hallway/corridor Thank-you | 2/7/14 | Gym | outside the Gym/Hallway | Roof |
| Dexter MS (0068) 2A | Request that leaks be repaired in the computer Lab 210 classroom 218 216 and 217 202 Thank-you | 3/17/14 | 1st Floor | 210 | Roof |
| Dexter MS (0068) 2A | Request that leak in the cafe managers office be repaired over the file cabinets. Thank-you | 4/28/14 | Kitchen | office | Roof |
| Dexter MS (0068) 2A | Request that handrail to bleachers be repaired broken bolt. Thank-you | 11/4/13 | Gym | gym | Sheet Metal |
| Dexter MS (0068) 2A | repair downspout that was hit by car | 11/14/13 | | | Sheet Metal |
| Dexter MS (0068) 2A | Request that down spout be repaired that was damaged due to car. THANK-YOU | 11/15/13 | 1st Floor | outside | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|-----------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Douglass HS (2160)-2B | 2 | 33 | 29 | 45 | 2 | 28 | 6 | 5 | 150 |
| Grand Total | 2 | 33 | 29 | 45 | 2 | 28 | 6 | 5 | 150 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|-----------------------|--|---------------|------------------|---------------------|-----------|
| Douglass HS (2160)-2B | Insulation on ductwork is water saturated from old ac leak, needs to be reinsulated. | 11/21/13 | Hallway/Corridor | 2nd Flr. @ Elevator | Asbestos |
| Douglass HS (2160)-2B | Insulation on ductwork is water saturated from plumbing pipe leak, pipe is repaired needs to be reinsulated along with the duct work. | 1/6/14 | Hallway/Corridor | 2nd Flr. @ Elevator | Asbestos |
| Douglass HS (2160)-2B | Fabricate access ladder. from kitchen roof to cafe roof for servicing hvac equipment. jd needed for safe access to this location. | 10/16/13 | | | Carpentry |
| Douglass HS (2160)-2B | need a lock and latch, on double doors from inside for security reason, what's happening now is the student bumps against the door thumb latch, leaving the door unlocked all night un | 10/3/13 | Gym | room E113 | Carpentry |
| Douglass HS (2160)-2B | need barrel and bolt lock for athletic storage room to secure, basket ball equipment. the double doors that open to rear parking lot. | 10/4/13 | Gym | room E113 | Carpentry |
| Douglass HS (2160)-2B | elbo on double hallway doors is still broke, mr. lonnie and mr. ford look at it and my self i told them i had a work order in on it, i dont see the ticket order on line any more its been taken out, the elbo still | 10/8/13 | 1st Floor | hall west | Carpentry |
| Douglass HS (2160)-2B | EXIT DOOR WONT DOOR METAL PIECE CAME LOOSE NORTH A-HALL PLANT MGR- HOLTON/416.5946 | 9/19/13 | | | Carpentry |

| | | | | | |
|-----------------------|---|---------|------------|----------------------|-----------|
| Douglass HS (2160)-2B | please replace the damaged ceiling tiles in the cafeteria its at least 25' in height | 7/26/13 | Cafeteria | dining hall | Carpentry |
| Douglass HS (2160)-2B | need ceiling tile replaced, special cut is required, exit light is in the center of the ceiling tile. | 9/20/13 | 1st Floor | main office | Carpentry |
| Douglass HS (2160)-2B | ceiling tile has sprinkler in center of it need special cut to replace it. | 9/24/13 | 2nd Floor | by elevator | Carpentry |
| Douglass HS (2160)-2B | hallway gate from wall to wall is broken, difficult to push open and close, nuts & bolts are missing and one brackets that holds the fence sturdy. Lonnie G. Fab new gates (see Ty A.) | 9/26/13 | 1st Floor | by Auditorium | Carpentry |
| Douglass HS (2160)-2B | please repair the broken door closer in the foyer of the gym | 8/22/13 | Gym | main entrance | Carpentry |
| Douglass HS (2160)-2B | two doors, south end of auditorium, the two doors that swing to your left or swing west, they are dragging very hard on the door frame at top of door. need correcting. | 8/30/13 | Auditorium | 1st floor | Carpentry |
| Douglass HS (2160)-2B | door dragging very hard, and dry food door dragging very hard, need correcting. | 8/30/13 | Kitchen | manager office | Carpentry |
| Douglass HS (2160)-2B | please adjust the panic bar on the rear entrance to the band room, takes a great deal of effort to secure | 7/30/13 | Classroom | band room rear entry | Carpentry |

| | | | | | |
|-----------------------|--|----------|-----------|------------------|-----------|
| Douglass HS (2160)-2B | Please deliver at least 1 box of ceiling tiles we have several in need of replacement and none on campus | 7/30/13 | 2nd Floor | stairwell | Carpentry |
| Douglass HS (2160)-2B | hallway gate from wall to wall is broken, difficult to push open and close, nuts & bolts are missing and one brackets that holds the fence sturdy. | 8/12/13 | 1st Floor | by Auditorium | Carpentry |
| Douglass HS (2160)-2B | the elbow has broken on the band room door | 3/31/14 | 1st Floor | A114 band room | Carpentry |
| Douglass HS (2160)-2B | Door drags hallway floor, very hard to move door to open or close. | 2/27/14 | 1st Floor | room D133 | Carpentry |
| Douglass HS (2160)-2B | need swing gate in hallway, east hall by gym. | 10/16/13 | 1st Floor | by gym hallway | Carpentry |
| Douglass HS (2160)-2B | 1st floor middle stairwell double exit doors can't secure because of missing screw per Mr. Holton 416-6159 | 10/17/13 | | | Carpentry |
| Douglass HS (2160)-2B | band room door has a screw in top hinge broke, and door is over lapping. | 10/18/13 | 1st Floor | room A114 | Carpentry |
| Douglass HS (2160)-2B | stair well, ceiling tiles water lodge, need special cut and one with security camera in center of ceiling tile. | 9/27/13 | 2nd Floor | F wing in middle | Carpentry |

| | | | | | |
|-----------------------|---|----------|-----------|----------------------|-----------|
| Douglass HS (2160)-2B | between speacial need and auditorium, door handle is broken, dont work. the door handle is on my desk. and door handle room A119 is also broken, with handle intach. | 12/20/13 | 1st Floor | double wooden doors | Carpentry |
| Douglass HS (2160)-2B | there is five water stain ceiling tile in the cafeteria, need a high lift to get to them. | 4/7/14 | 1st Floor | cafeteria | Carpentry |
| Douglass HS (2160)-2B | base need to be stable, it move a half inch when door shut, make it hard for door latch to catch. | 4/24/14 | 1st Floor | stair well exit door | Carpentry |
| Douglass HS (2160)-2B | has come off on double doors by auditorium black gates | 5/7/14 | 1st Floor | door handle | Carpentry |
| Douglass HS (2160)-2B | top of door need grinding down a little so it wont hit the head of sensor and short out, it will be the door to the east that do not have a sensor, push door open look up you will see a hole without a sensor that will be the sensor | 5/7/14 | 1st Floor | main entrance | Carpentry |
| Douglass HS (2160)-2B | storage door broke off the hinges need replaced. | 5/23/14 | 1st Floor | Room D 110 | Carpentry |
| Douglass HS (2160)-2B | please repair the broken magnetic door holder in the 1st stairwell (2nd floor) | 6/10/14 | 2nd Floor | 1st stairwell | Carpentry |
| Douglass HS (2160)-2B | cancel work order for hanging banners in auditorium & gym, the work order # is 380266 , the banners are up. thank you. | 10/16/13 | 1st Floor | banners | Carpentry |

| | | | | | |
|-----------------------|--|---------|------------------|-------------------|------------|
| Douglass HS (2160)-2B | need a gate to come across the hall to close that end of hall when there is nobody in the building, after hour. | 8/30/13 | Hallway/Corridor | by the gym | Carpentry |
| Douglass HS (2160)-2B | dumpster lid one is missing and the other one is broken on (8) eight cubic dumpster. | 3/27/14 | Kitchen | kitchen dumpster | Carpentry |
| Douglass HS (2160)-2B | showing complete #373618 date entered 8-12-2013 by auditorium need repairs, had one man came out here, he said to me he have the ticket on the gate for repair and ticket on door closer broken, which is 18 feet from gate ho | 9/26/13 | 1st Floor | gate in hall | Carpentry |
| Douglass HS (2160)-2B | DOOR SENSOR NOT READING, & CAN'T SECURE WITH ALARM SYS PLANT MGR- MITCHELL/416.0990 | 6/5/14 | | | Carpentry |
| Douglass HS (2160)-2B | by room E113 dont work. its black on the out side from sparks. | 10/8/13 | Gym | rec in short hall | Electrical |
| Douglass HS (2160)-2B | need new rec, some time it sparks. one at center wall. | 9/24/13 | Kitchen | center wall | Electrical |
| Douglass HS (2160)-2B | showing complete, no one been out here to fix the rec cover. now the cover is broken, a hole is exsposed, hope nobody hurt them self. | 9/24/13 | Gym | floor rec cover | Electrical |
| Douglass HS (2160)-2B | bad ballast 4 lamp. | 9/24/13 | 1st Floor | room A122 | Electrical |

| | | | | | |
|-----------------------|---|---------|------------------|---------------------|------------|
| Douglass HS (2160)-2B | for score board, thats in the floor, only the orange rec is bad, it keep grounding out,its three orange rec, right on the out of bound line, with a black metal cover on it. | 8/20/13 | Basketball Court | receptical | Electrical |
| Douglass HS (2160)-2B | please replace the (4) blown light bulbs over the courtyard | 8/22/13 | Courtyard | courtyard | Electrical |
| Douglass HS (2160)-2B | please replace the (3) overhead parking lot lights | 8/22/13 | Grounds | faculty entrance | Electrical |
| Douglass HS (2160)-2B | please replace the burned out electrical outlet above the west wall bleachers | 8/22/13 | Gym | west side bleachers | Electrical |
| Douglass HS (2160)-2B | receptical thats in the floor the cover that cover the the rec is broken, need new cover to replace the old one, and need to be heavy. so when the basket ball hit the cover it wont pop up. and cause a messin up | 8/26/13 | Gym | score board | Electrical |
| Douglass HS (2160)-2B | all of the exit lights in the auditorium and surrounding hallways will not illuminate, L.E.D. light no blown bulbs nor tripped breakers | 8/28/13 | Auditorium | foyer | Electrical |
| Douglass HS (2160)-2B | please replace the 4 blown lights outside of the auditorium west wall | 8/29/13 | Auditorium | exterior lights | Electrical |
| Douglass HS (2160)-2B | need lift to put banners up in both areas. | 9/3/13 | 1st Floor | Auditorium / GYM | Electrical |

| | | | | | |
|-----------------------|---|---------|-----------|--------------------------|------------|
| Douglass HS (2160)-2B | two lights are out at back of gym, and three light are out , coming in the drive way at back of gym and cafeteria, area. | 9/6/13 | Grounds | courtyard | Electrical |
| Douglass HS (2160)-2B | a/c not coming on in E115 per Mr. Holton 416-6159 | 9/12/13 | | | Electrical |
| Douglass HS (2160)-2B | please repair the faulty electrical outlet that powers the left hand milk box, there appears to be a short in this outlet | 7/29/13 | Kitchen | serving line (left hand) | Electrical |
| Douglass HS (2160)-2B | STEAMER IN THE KITCHEN KEEP TRIPPING. AND RECEPTACLES ARE BURNOUT ON THE EAST WALL SBE HOLTON 416-6159 | 7/30/13 | | | Electrical |
| Douglass HS (2160)-2B | please reattach the broken electrical outlet at the rear entrance of the cafeteria. | 7/30/13 | Cafeteria | rear entrance | Electrical |
| Douglass HS (2160)-2B | FIRE ALARM KEEPS TRIPPING. PLANT MGR- HOLTON/416.0990 | 8/1/13 | | | Electrical |
| Douglass HS (2160)-2B | FRONT MAIN ENTRANCE- DOOR NOT OPENING, MECHANISM IN DOOR NOT WORKING-SBE HOLTON 416-0990 KLR | 8/12/13 | | | Electrical |
| Douglass HS (2160)-2B | clocks not synchronized and intercomb dont work and bells dont work. before the change over they all were working well, now they dont work. | 3/17/14 | 1st Floor | main office | Electrical |

| | | | | | |
|-----------------------|---|----------|-----------|-------------------|------------|
| Douglass HS (2160)-2B | please replace the blown ballast in the middle stairwell 1st floor | 3/18/14 | Stairway | middle stairwell | Electrical |
| Douglass HS (2160)-2B | 12 bulbs blowed, I need 20 bulbs, 42 w 4 pin. | 10/16/13 | 1st Floor | front lobby | Electrical |
| Douglass HS (2160)-2B | there are sixty (60) blowed lights in the gym ceiling need replaced, by a lift that can go that high. | 9/30/13 | Gym | ceiling lights | Electrical |
| Douglass HS (2160)-2B | RECEPTACLE IS MAKING POPPING NOISE IN RM-F128 2ND FLR. PLANT MGR-HOLTON/416.0990 | 12/16/13 | | | Electrical |
| Douglass HS (2160)-2B | UNIT HAS BURNING SMELL IN RM-129 PLANT MGR-HOLTON/416.6159 | 4/15/14 | | | Electrical |
| Douglass HS (2160)-2B | RM F129-HAS A STRONG BURNING SMELL IN IT- PLANT MGR HOLTON 416-0990 KLR | 4/29/14 | | | Electrical |
| Douglass HS (2160)-2B | exit light fixture dont work. | 5/6/14 | 1st Floor | middle stair well | Electrical |
| Douglass HS (2160)-2B | the vent-a-hood in the main kitchen will not come on,power button is illuminated ut unit will not come on | 5/19/14 | Kitchen | kitchen | Electrical |

| | | | | | |
|-----------------------|--|---------|--|----------------|---------------------------------------|
| Douglass HS (2160)-2B | RTU NOT COMING IN GUIDANCE OFFICE PLANT MGR- MITCHELL/416.0990 | 7/29/13 | | | Electrical |
| Douglass HS (2160)-2B | filter need changing, the date on the filter is 8-13 2013, RTU #06 #07 #09 #63 | 4/23/14 | | roof top | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | filters need changing #32,33,35,47 | 4/29/14 | | roof top units | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | ROOFTOP UNIT is NOT COOLING in the KITCHEN per Mr. Holton, Plant Mgr. 416.6159 | 5/22/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | R T U 32 need 2 inch filters change out. | 4/16/14 | | roof top | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | replace comp 1 (holly) | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | replace comp 2 (holly) | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | GAS SMELL COMING THRU VENT IN ROTC PLANT MGR- HOLTON/416.0990 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|---|----------|-----------|--|-----------------------|---------------------------------------|
| Douglass HS (2160)-2B | UNIT IS MAKING NOISE IN CU1 PLANT MGR- HOLTON/416.0990 Electrician installed condensor fan motor, unit runs, but is not cooling.jd | 4/23/14 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | 2" filters need changing | 3/31/14 | Gym | | roof top | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | per mr holton 416-6159 C110 the cafeteria manager's office is blowing cold air | 3/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | per mr holton 416-6376 roof top unit #41 needs gas regulator and also roof top unit #40 burner not working properly and letting off fumes | 3/26/14 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | RTU NOT COOLING IN LAUNDRY RM GYM. PLANT MGR- HOLTON/490.4457 | 9/18/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | water still coming inside hallway, leaking from a/c duct on to ceiling tile in the hallway, a/c duct is sagging very badly, holding water, need new insulation and tear out old insulation. this is third request and same problem. | 10/28/13 | 2nd Floor | | hall unit on roof top | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | Monthly - Oil Lubes & Belts- Douglass High - Refer to PM schedule details. | 11/4/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | ALL RTU GYM AREA- MAKING NOISES PER SBE- PLANT MGR HOLTON 416-0990 KLR | 10/4/13 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|--|--|---------------------------------------|
| Douglass HS (2160)-2B | DUCT LEAKING 2ND FLR HALL-PLANT MGR HOLTON 416-5946 KLR | 10/4/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | A/C RM D102-NOT COOLING-PLANT MGR HOLTON 416-0990 KLR | 9/19/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | RTU#18 NOT COMING ON IN GUIDANCE OFFICE . PLANT MGR- MITCHELL/416.0990 | 7/25/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | 5-RTU NOT COOLING IN RM 121F,F126,F128,D101,D104 PLANT MGR- HOLTON/416.0990 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | RTU PRIN'S OFC-NOT COOLING-PLANT MGR MITCHELL 416-0990 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | A/C RM D102-NOT COMING ON-PLANT MGR HOLTON 416-6159 KLR (see journal notes).jd | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | RTU NOT COOLING in RM D102 per Mr. Holden, Plant Mgr. 416.6159. | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | A/C IN RMS D103 & D105- BOTH NOT COOLING- PLANT MGR HOLTON 416-5946 KLR | 9/16/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|--|---------|-----------|--|----------|---------------------------------------|
| Douglass HS (2160)-2B | UNIT IN RM 121 IS NOT COMING.S BE HOLTON 416-6159 | 8/2/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | UNIT IN THE MAIN LOBBY IS NOT COOLING .SBE MITCHELL 416-0990 | 8/2/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | A/C IN RM 128-NOT COOLING-SBE HOLTON 416-6159 KLR | 8/6/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | A/C IN RMS A131 & F128-BOTH NOT COOLING-SBE HOLTON 416-0990 KLR | 8/8/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | A/C IN RM F121-NOT COOLING-SBE HOLTON 416-0990 KLR | 8/9/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | R.T.U. 41 has a natural gas leak at the fuel pressure regulator valve Per MLG&W, they were called do to a faint smell of gas in the 2nd floor teachers lounge,.gas has been shut off to this unit. | 3/26/14 | 2nd Floor | | roof top | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | Per MLG&W RTU 40 is emitting a great deal of carbon monoxide, they were out due to a gas leak at RTU 41 when this additional problem was discovered appears unit may be going out on the high limit. | 3/26/14 | 2nd Floor | | roof top | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | UNITS are NOT HEATING in the CAFETERIA per Eddie Holton, Plant Mgr. 416.6159 | 2/13/14 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|----------|------------|--------------------|---------------------------------------|
| Douglass HS (2160)-2B | dont work hall way is very cold next to auditorium. | 3/6/14 | 1st Floor | heaters in hallway | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | HEAT RM A122-NOT HEATING-PLANT MGR HOLTON 416-0990 KLR | 3/7/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | RTU#33 NOT HEATING IN RM-D102, & AUDIT PLANT MGR- HOLTON/416.0990 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | HEAT GYM AREA & COACH'S OFC-BOTH NOT HEATING-PLANT MGR HOLTON 416-0990 KLR | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | auditorium thermostat dont work, when i push the key pad, it dont light up and no display of number, it is located in the north west corner by stage steps. | 12/12/13 | Auditorium | 1st floor | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | RTU-2 SERVES BANDRM/PIANO RM-KEEPS TRIPPING BREAKER- PLANT MGR HOLTON 416-6159 KLR | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | THERMOSTAT AUDITORIUM FRONT AREA-DAMAGED, HAS WIRES EXPOSED- PLANT MGR HOLTON 416-6159 KLR | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | HEAT GYM AREA-NOT HEATING-PLANT MGR HOLTON 416-5960 KLR | 1/8/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|------------|-----------------|---------------------------------------|
| Douglass HS (2160)-2B | per Mr. Holton 416-6159 the gym and room D102 are blowing cold air | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | Monthly - Oil Lubes & Belts-Douglass High - Refer to PM schedule details. | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | Monthly - Filter-Douglass High - Refer to PM schedule details. | 5/23/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | Monthly - Filter-Douglass High - Refer to PM schedule details. | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | Monthly - Filter-Douglass High - Refer to PM schedule details. | 9/20/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass HS (2160)-2B | FLOOR NEED PAINTING IN AUDITORIUM. | 8/14/13 | Auditorium | | Painting |
| Douglass HS (2160)-2B | outside has vandalism marking on front door, three of the doors. | 8/15/13 | Auditorium | exit doors from | Painting |

| | | | | | |
|-----------------------|--|----------|-----------------|-------------------|----------|
| Douglass HS (2160)-2B | Test and repair RP Devices per MLG&W. | 10/30/13 | Mechanical Room | | Plumbing |
| Douglass HS (2160)-2B | sink leaking water down to floor. | 11/1/13 | Kitchen | three compartment | Plumbing |
| Douglass HS (2160)-2B | COMMODE 1ST FLR B RR BY AUDITORIUM-1ST STALL STOPPED UP-PLANT MGR HOLTON 416-0990 KLR | 11/13/13 | | | Plumbing |
| Douglass HS (2160)-2B | AC duct leaking in the Cafeteria per Eddie Holton, Plant Mgr. at 416.1990. | 7/9/13 | | | Plumbing |
| Douglass HS (2160)-2B | RTU IS LEAKING WATER CONTINUOUSLY 2ND FLR HALL. PLANT MGR- HOLTON/416.0990 | 9/24/13 | | | Plumbing |
| Douglass HS (2160)-2B | RTU CAFE AREA-LEAKING & F WING 2ND FLR EAST WING DUCT WORK INSULATION HOLDING A LOT OF WATER PER SBE- COULD CAUSE TILE TO FALL-PLANT MGR HOLTON 416.0990 KLR | 9/25/13 | | | Plumbing |
| Douglass HS (2160)-2B | water leaking from fountain in cafeteria, from under fountain. | 8/19/13 | Cafeteria | | Plumbing |
| Douglass HS (2160)-2B | there is a large HVAC duct that is leaking condensation, which is causing mold | 9/10/13 | 2nd Floor | elevator entrance | Plumbing |

| | | | | | |
|-----------------------|---|---------|-----------------|------------------|----------|
| Douglass HS (2160)-2B | is at the high school, not the elementary, work order # 374845, douglass high. | 9/13/13 | 1st Floor | room a131 | Plumbing |
| Douglass HS (2160)-2B | handicap toilet in girls locker room south end is stopped up and cannot get unstopped per Mr. Holton 416-6159 | 9/17/13 | | | Plumbing |
| Douglass HS (2160)-2B | water fountain leaking water from pipe under neath. | 8/1/13 | 1st Floor | east hall wing | Plumbing |
| Douglass HS (2160)-2B | please repair the (boys) handicap accessible toilet, It appears someone has kicked it, when flushed it shoots a great deal of water out the supply line | 8/7/13 | Restroom (Boys) | main office hall | Plumbing |
| Douglass HS (2160)-2B | DISREGAURD WORK ORDER # 374845 FOR ELEMENTARY SCHOOL DOUGLASS, THE SINK IN ROOM A131 IS LEAKING AROUND DRAIN DOWN TO TILE FLOOR, | 8/14/13 | 1st Floor | room a131 | Plumbing |
| Douglass HS (2160)-2B | RTU-60 GYM AREA- LEAKING WATER ONTO HARDWOOD FLR-PLANT MGR HOLTON KLR | 3/28/14 | | | Plumbing |
| Douglass HS (2160)-2B | urinal #1 flush valve is bad. | 3/19/14 | 1st Floor | boys rr A-B Hall | Plumbing |
| Douglass HS (2160)-2B | Gas ordor in the cafe. trouble on RTU's. | 3/25/14 | | | Plumbing |

| | | | | | |
|-----------------------|--|----------|-----------|-------------------|----------|
| Douglass HS (2160)-2B | three facet need three washers in class room D102 | 2/4/14 | 1st Floor | class room D102 | Plumbing |
| Douglass HS (2160)-2B | sink is stoped up. | 2/5/14 | 2nd Floor | class room F121 | Plumbing |
| Douglass HS (2160)-2B | by middle stairs first floor. water fountain stop up, will not drain. | 2/10/14 | 1st Floor | hallway D | Plumbing |
| Douglass HS (2160)-2B | somthing down in the spout that cause the water to spray all over the place when the button is press down for water. that fountain is two doors down from plant manager office | 2/27/14 | 1st Floor | water foutain has | Plumbing |
| Douglass HS (2160)-2B | shower constant runing will not shut off. | 10/1/13 | Gym | boys locker | Plumbing |
| Douglass HS (2160)-2B | DUCT WORK IS LEAKING WATER,F-HALL 2 ND FLR PLANT MGR- HOLTON/416.0990 | 12/3/13 | | | Plumbing |
| Douglass HS (2160)-2B | Water fountain on the 1st floor on D-Hall across from Room 104 is LEAKING WATER (a constant dip) per Mr. Holton, Plant Mgr. 416.6159 | 12/13/13 | | | Plumbing |
| Douglass HS (2160)-2B | gym lobby last stall, water leaking between the wall and porcelin toilet, the toilet will have to be pull away from wall to see the leak, these toilet is made defferent. | 12/18/13 | 1st Floor | girls rest room | Plumbing |

| | | | | | |
|-----------------------|---|---------|-----------------|--------------------|----------|
| Douglass HS (2160)-2B | across from GYM between second and third stall water is runing from busted pipe inside the wall seeping at base of wall and tile floor, water has to be mopped up every two hours, lotta water. | 4/30/14 | Restroom (Boys) | 1st floor | Plumbing |
| Douglass HS (2160)-2B | center toilet leaking water on to tile floor | 5/6/14 | 1st Floor | gym lobby girls rr | Plumbing |
| Douglass HS (2160)-2B | Video pipe chase for leak | 5/20/14 | | | Plumbing |
| Douglass HS (2160)-2B | I just come down off the ladder, what i saw from last time , too this time there is 7 feet of insulation need to come off the south side of the duct work that is soiled with water, and is still leaking water on to ceiling tile from | 12/4/13 | 2nd Floor | by elevator | Plumbing |
| Douglass HS (2160)-2B | ROOF LEAK ON 2ND FLR EAST-WING HALL AND CAUSE CEILING TILE TO FALL IN. SBE-HOLTON/416-0990 | 7/17/13 | | | Roof |
| Douglass HS (2160)-2B | please repair the roof leak in this stairwell | 7/26/13 | Stairway | Middle stairwell | Roof |
| Douglass HS (2160)-2B | roof leak on to stage wood grain floor, need fixing. | 9/20/13 | Auditorium | stage west | Roof |
| Douglass HS (2160)-2B | water coming in from roof. | 2/4/14 | 2nd Floor | roof middle stairs | Roof |

| | | | | | |
|-----------------------|--|----------|-----------|-----------------------|-------------|
| Douglass HS (2160)-2B | roof leak, water running off A/C duct extending down in class room. | 2/5/14 | 1st Floor | stage craft room A111 | Roof |
| Douglass HS (2160)-2B | above the camera in the middle stair well. | 4/7/14 | 2nd Floor | roof leak | Roof |
| Douglass HS (2160)-2B | plant manager office, when they put the drop ceiling in place, they for got to put, a A/C duct from existing duct, thats already there blowing cold air into void space, and not in the office, need flexible duct guided into | 10/2/13 | 1st Floor | room A137 | Sheet Metal |
| Douglass HS (2160)-2B | south end a locker to be re revited so combination or pad lock can work again, the revit came out. only one locker need it. | 11/1/13 | Gym | boys locker room | Sheet Metal |
| Douglass HS (2160)-2B | A/C DUCT WORK IS HANGING DOWN IN B/RR 2ND FLR PLANT MGR- HOLTON/416.5946 | 10/23/13 | | | Sheet Metal |
| Douglass HS (2160)-2B | please install a retractable gate, at the gymnasium entrance to cordon off the main building. | 8/29/13 | Gym | | Sheet Metal |
| Douglass HS (2160)-2B | plant manager and sheet metal man talk, he took measurements, said he will be back with the air duct, he came back on another ticket, and said we just about got you fix up, see you in a few days | 11/25/13 | 1st Floor | room A 137 | Sheet Metal |

| Count of Craft | Craft | | | | | | | | Grand Total |
|-------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Wolcott KS (2155) | 1 | 29 | 36 | 38 | 2 | 40 | 8 | 3 | 156 |
| Grand Total | 1 | 29 | 36 | 38 | 2 | 40 | 8 | 3 | 156 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|-----------------------|--|---------------|---------------|----------------------|-----------|
| Douglass K8 (2155) 2B | of hall ceiling tile the the chill water pipe need insulation on them water dripping on to ceiling tile and then floor between room 208 and 209 | 5/29/14 | 2nd Floor | hallway in center | Asbestos |
| Douglass K8 (2155) 2B | is broken out, need replaced. | 1/8/14 | Kitchen | window | Carpentry |
| Douglass K8 (2155) 2B | Repair threshold at the notheast exit. | 1/15/14 | | | Carpentry |
| Douglass K8 (2155) 2B | has come aloose need put back in place. | 1/22/14 | Kitchen | counter top trimming | Carpentry |
| Douglass K8 (2155) 2B | by room 205 ceiling tile support bracket is gone, it was not here when i got here, ceiling tile is sagging, two of them, bracket need put back in. | 10/18/13 | 2nd Floor | hallway | Carpentry |
| Douglass K8 (2155) 2B | two ceiling tile need replaced. | 11/6/13 | Cafeteria | 1st floor | Carpentry |
| Douglass K8 (2155) 2B | (4) four floor tile need replaced. | 11/6/13 | Cafeteria | 1st floor | Carpentry |

| | | | | | |
|-----------------------|---|----------|-----------|----------------------|-----------|
| Douglass K8 (2155) 2B | the wall that divide both class room will not close all the way, it stop two feet from the latch, P. E. Coach can not get it to close. | 11/18/13 | 1st Floor | room 117 & 118 | Carpentry |
| Douglass K8 (2155) 2B | class rooms 219, 224, 214, 212,211, 210 need ceiling tile replaced they are water damaged, water log and has fallin to the floor.(Deliver tile to plant manager,make special cuts only). | 9/27/13 | 2nd Floor | class rooms | Carpentry |
| Douglass K8 (2155) 2B | by stair well need new door closer, the back stop do not work, door swing to freely open and bend the elbo support base causing the door not to close properly. | 10/3/13 | 1st Floor | exit door north west | Carpentry |
| Douglass K8 (2155) 2B | room 224, 13 cuts, 201, 2 cuts, 204, 3 cuts, 206, 4 cuts, 207, 6 cuts, 208, 1 cut, 210, 10 cuts, 211, 6 cuts. | 10/14/13 | 2nd Floor | special cuts | Carpentry |
| Douglass K8 (2155) 2B | need new floor tiles only in the area where the lockers were removed and relocated on second floor. tiles are damaged very badly. | 10/14/13 | 2nd Floor | second floor | Carpentry |
| Douglass K8 (2155) 2B | north west exit door has a hole at bottom of door that rats have excess to school entry, back and forth, hole need fixing. | 8/23/13 | 1st Floor | south east exit door | Carpentry |
| Douglass K8 (2155) 2B | disregard downtown ELEM. NAME, the room numbers is for douglass elem. work order # 379492 | 8/29/13 | 2nd Floor | doors dragging | Carpentry |
| Douglass K8 (2155) 2B | class rooms 219, 224, 214, 212,211, 210,209,208, 207,206,205,204,203,202 need ceiling tile replaced they are water damaged, water log and has fallin to the floor.(Deliver tile to plant manager,make special cuts only). | 7/30/13 | 2nd Floor | class rooms | Carpentry |

| | | | | | |
|-----------------------|--|---------|-----------|-------------------|-----------|
| Douglass K8 (2155) 2B | need thresh hole plate at door way in pantry room and need thresh hole plate at door way in mop room. | 8/1/13 | Kitchen | | Carpentry |
| Douglass K8 (2155) 2B | rooms 207, 208,206,204,203,109. | 8/8/13 | 2nd Floor | door over lapping | Carpentry |
| Douglass K8 (2155) 2B | pencil sharpner, wooden block to place on concrete wall for pencil sharpner to be attach to. in room 221 | 8/13/13 | 2nd Floor | penci sharnpner | Carpentry |
| Douglass K8 (2155) 2B | need two more bundles of ceiling tile. | 8/19/13 | 1st Floor | 2nd floor | Carpentry |
| Douglass K8 (2155) 2B | door closer on men rest room is broken dont work. | 4/8/14 | 1st Floor | men restroom | Carpentry |
| Douglass K8 (2155) 2B | 3 square floor tile has come up at door entrance. | 3/20/14 | 1st Floor | room 109 | Carpentry |
| Douglass K8 (2155) 2B | remove the obsolete black board off wall, two of them, and in room 118 remove the obsolete black board off wall, two of them and put the white board on the brick wall that is now screwed into the black board on the north wall. | 5/23/14 | 1st Floor | room117 | Carpentry |
| Douglass K8 (2155) 2B | the tracks that hold the ceiling tile in place is broken and ceiling tile is tore up due to break in, need repaired. | 5/27/14 | 1st Floor | main lobby | Carpentry |

| | | | | | |
|-----------------------|---|---------|-----------|----------------------------|------------|
| Douglass K8 (2155) 2B | EAST ENTRANCE DOOR-AUTO LOCK NOT LOCKING, CAN STILL BE PULLED OPEN WHILE IN LOCK POSITION- WON'T BE ABLE TO SECURE BLDG- PLANT MGR HOLTON 416-5946 KLR | 5/27/14 | | | Carpentry |
| Douglass K8 (2155) 2B | special cut around A/C coil unit hanging from ceiling. | 5/29/14 | 2nd Floor | ceiling tile need | Carpentry |
| Douglass K8 (2155) 2B | 204,214,217, need planing down and mechanical room 204A. doors Drag. | 5/30/14 | 2nd Floor | class rooms | Carpentry |
| Douglass K8 (2155) 2B | window missing one handle at bottom of window very difficult to shut window with one handle missing at bottom of window to lock down the window properly. | 6/12/14 | 2nd Floor | room 210 | Carpentry |
| Douglass K8 (2155) 2B | fire safty reason. | 6/13/14 | Kitchen | kitchen serving line doors | Carpentry |
| Douglass K8 (2155) 2B | direction of three doors. | 5/28/14 | Kitchen | change door swing | Carpentry |
| Douglass K8 (2155) 2B | bad ballast between 203 & 204 and by mechanical room 204A west hall bad ballast. | 1/8/14 | 2nd Floor | hall west | Electrical |
| Douglass K8 (2155) 2B | computer rec. dont work in room 204 & 205. | 1/8/14 | 2nd Floor | 204 & 205 | Electrical |

| | | | | | |
|-----------------------|---|----------|-----------|--------------------|------------|
| Douglass K8 (2155) 2B | 3-LOOP PUMPS HAVE FROZEN UP ON 2ND FLR EAST, SOUTH, WEST HALLS, - 1ST FLR SOUTH-END HALL, & AHU#1,2 SOUTH-END OUTSIDE COLD AIR COMING IN THRU DUCT WORK. PLANT MGR-HOLTON/416.5946 | 1/10/14 | | | Electrical |
| Douglass K8 (2155) 2B | the breaker switch will not cut off fan coil units 016-066 & 016-067, they did at one time. the rest still works | 1/13/14 | 2nd Floor | custodial 222a | Electrical |
| Douglass K8 (2155) 2B | receptical on east wall dont work. | 1/14/14 | 1st Floor | class room 101 102 | Electrical |
| Douglass K8 (2155) 2B | need one two lamp ballast. | 11/25/13 | 2nd Floor | room 210 | Electrical |
| Douglass K8 (2155) 2B | 209 & 212 heater A/C blower motor burn up, dont work, it is getting electrical current, or power supply. | 11/25/13 | 2nd Floor | room 209 & 212 | Electrical |
| Douglass K8 (2155) 2B | Fan Coil Unit has BURNING SMELL and has STOPPED TURNING in Room 119 per Mr. Holton, Plant Mg.r 416.6376 | 12/2/13 | | | Electrical |
| Douglass K8 (2155) 2B | suport base has come aloose and light fixture is resting on the plastic light cover, thats all keeping it from continuing down to floor. | 10/17/13 | 1st Floor | light fixture | Electrical |
| Douglass K8 (2155) 2B | assist. principal need a ballast for light fixture in her office. 4 lamp. | 10/23/13 | 1st Floor | main office | Electrical |

| | | | | | |
|-----------------------|---|----------|-----------|----------------|------------|
| Douglass K8 (2155) 2B | room 107 need a light ballast and room 208 need a light ballast. | 11/4/13 | 1st Floor | 2nd floor | Electrical |
| Douglass K8 (2155) 2B | need 4 ballast and 102 need one ballast | 11/5/13 | 1st Floor | room 101 | Electrical |
| Douglass K8 (2155) 2B | need one (1) ballast. | 11/8/13 | 1st Floor | class room 101 | Electrical |
| Douglass K8 (2155) 2B | 201 & 202 & 203 the rec dont work , on east wall , i reset the breaker , still dont work, teacher did say when she plug up an audio, she heard a pop. that was in room 202. | 11/15/13 | 2nd Floor | class rooms | Electrical |
| Douglass K8 (2155) 2B | need rec for washing machine, what is there now is a light switch,that is obsolete, the switch and cover is gone and wires cap off. | 10/1/13 | 1st Floor | boiler room | Electrical |
| Douglass K8 (2155) 2B | rec dont work on east wall north inside class room. | 10/15/13 | 2nd Floor | room 221 | Electrical |
| Douglass K8 (2155) 2B | clock and bells to be sychronize to new bell time. | 9/4/13 | | main office | Electrical |
| Douglass K8 (2155) 2B | rec dont work on north wall, i flip the breaker on & off, still dont work. need checking out. | 8/26/13 | 2nd Floor | room 211 | Electrical |

| | | | | | |
|-----------------------|---|---------|-----------|---------------|------------|
| Douglass K8 (2155) 2B | need three (3) boxes of 46758 lights for school | 8/29/13 | 1st Floor | 2nd floor | Electrical |
| Douglass K8 (2155) 2B | RECEPTACLES HAVE NO POWER IN RM-210,211 PLANT MGR-HOLTON/416.5946 | 8/29/13 | | | Electrical |
| Douglass K8 (2155) 2B | dont work in class room 221 on east wall. | 8/5/13 | 2nd Floor | receptical | Electrical |
| Douglass K8 (2155) 2B | receptical front lobby dont work, i switch the breaker still didnt work, need repair. | 8/7/13 | 1st Floor | west hall | Electrical |
| Douglass K8 (2155) 2B | exit light north west dont work, exit light boiler room stair well dont work, stair well east 2nd fl dont work north end, exit lighting dont work 2nd fl south stair well hall, exit light dont work stair well 2nd floor,west | 8/8/13 | 1st Floor | exit lighting | Electrical |
| Douglass K8 (2155) 2B | room 102 and 217 fan blower motor not working, room 215 and 202 actuator not working per Mr. Holton 416-5946 | 8/14/13 | | | Electrical |
| Douglass K8 (2155) 2B | exit light 1st floor northwest at elevator dont work, exitlight northwest 2nd floor stairwell dont work, exit light northeast stairwell 2nd floor dont work, exit light boiler room stairwell dont work, exit light southeast 2nd floor stairwell dont work, exit light southeast 2nd floor hallway | 9/19/13 | 1st Floor | 2nd floor | Electrical |
| Douglass K8 (2155) 2B | light bulbs 100 watts need 40, of them, and fluorescent lights, I ordered last week the 46758 T8s, they send me the 37326, they dont fit, I did try them. they can pick these up when they bring the new ones. | 9/19/13 | 1st Floor | 2nd floor | Electrical |

| | | | | | |
|-----------------------|--|---------|-----------|-------------------------|------------|
| Douglass K8 (2155) 2B | FCU NOT COMING ON IN RM-209 PLANT MGR-WILLIAMS/416.5946 | 2/7/14 | | | Electrical |
| Douglass K8 (2155) 2B | main office has loud beeping sound on display panel that read trouble in zone two, east mechanic room, must be a bad sensor. | 2/18/14 | 1st Floor | main office | Electrical |
| Douglass K8 (2155) 2B | need two box of t8 lights #46758 | 3/17/14 | 1st Floor | 2nd floor | Electrical |
| Douglass K8 (2155) 2B | work order #372717 is showing complete, the repairs are still waiting to be fixed. | 5/28/14 | 1st Floor | 2nd floor | Electrical |
| Douglass K8 (2155) 2B | need emergency lights & a fire extinguisher. | 5/28/14 | 1st Floor | room 104 | Electrical |
| Douglass K8 (2155) 2B | each class room need a ballast for 1 light fixture. | 5/30/14 | 2nd Floor | room 205,206,213 | Electrical |
| Douglass K8 (2155) 2B | room 224 1 ballast. | 5/30/14 | 2nd Floor | room 224 need 1 ballast | Electrical |
| Douglass K8 (2155) 2B | receptical east wall dont work. | 5/2/14 | 2nd Floor | class room 221 | Electrical |

| | | | | | |
|-----------------------|--|---------|-----------|----------------------|---------------------------------------|
| Douglass K8 (2155) 2B | auto lock door need wiring up to wire on the door panic bar. | 5/29/14 | 1st Floor | east hall exit doors | Electrical |
| Douglass K8 (2155) 2B | two box of bulbbs for class rooms. | 6/2/14 | 2nd Floor | | Electrical |
| Douglass K8 (2155) 2B | A/C RM 112-NOT COOLING-PLANT MGR HOLTON KLR | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | per holton 416-6376 main office is not cooling | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | CHILL WATER PIPES BASEMENT MECH RM-SHAKING BADLY AND SWEATING-PLANT MGR HOLTON 416-5948 KLR | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | CHILLER NOT COOLING THRU ENTIRE 2ND FLR PLANT MGR-HOLTON/416.5946 | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | A/C IN RMS 101, 102, 203, 205, 212, 213, 214, 215, 216, 218, 219, 221, 222, & CAFE MGR'S OFC-ALL NOT COOLING-PLANT MGR HOLTON 416-5946 KLR | 9/5/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|-----------|----------------------|---------------------------------------|
| Douglass K8 (2155) 2B | cooling tower need cleaning. | 4/1/14 | Grounds | roof top | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | drum unit 1791 hypochlorite solutions, delivered on 08/28/13 and to day is the 11th, two weeks later and its empty,i dont know if thats correct, I came from coming elementary school in july,I had no water tower just a condenser and fans, 4 pipe. | 9/11/13 | 1st Floor | boiler room basement | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | BOILER MECH RM-KEEPS SHUTTING DOWN-PLANT MGR 416-5946 KLR | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | one inch filters have not been change, need changing. | 8/19/13 | 1st Floor | 2nd floor | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | 14-CEILING UNITS NOT COOLING IN RM-101,102,119,203,205,212,213,214,215,216,218,219,221,222 PLANT MGR-HOLTON/416.5946 | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | the hypochlorite drum is still empty, the 1791, has not been replace, the pumps that send the chemical to treat the water work fine before the man came to check it out after he left, the 2 pumps do not work, they are not sending chemical to treat the water, and one drum never refilled. | 9/23/13 | 1st Floor | boiler room | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | the hypochlorite solutions arrived on 10-15 -2013 and the pump sill dont work on the two drums they were working before the tech came out the very first time they do not work at all now, and the chemical solution is just sitting there. | 10/16/13 | 1st Floor | boiler room | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | (2) AHU'S 2ND FLR RM 211A-COILS HAVE BURST ON BOTH-WATER RUNNING OUT-PLANT MGR HOLTON 416-5946 KLR * (see journal notes) | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|-----------|-------------|---------------------------------------|
| Douglass K8 (2155) 2B | repair busted coils | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | BOILER MECH RM-NOT HEATING-AFFECTS ENTIRE BLDG-PLANT MGR HOLTON 416-5946 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | need new thermostats, it is stuck on hot position, contacts will not seperate, i can force them to seperate with plastic, temp come down, when i take the plastic away the temp goes back up, along with moving the dial up or down. | 12/3/13 | 1st Floor | 106 107 108 | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | need a thormostat, to control the heat temp, it was taken out a few years ago, becaus it was broken, dont work, that was before I receive this school, it is extreamly hot, take your breath away. | 12/4/13 | 2nd Floor | library | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Monthly - Oil Lube & Belt-Douglas Elem - Refer to PM schedule details. | 12/7/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | BOILER-NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR HOLTON 416-5946 KLR | 11/15/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | CHILLER IS NOT COMING ON . SBE MITCHELL 416-5946 | 7/22/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | CHILLER NOT COOLING. PLANT MGR-HOLTON/416-5946 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------|---|---------|-----------|----------|--|---------------------------------------|
| Douglass K8 (2155) 2B | CHILLER NOT COOLING . PLANT MGR-HOLTON/416.5946 | 8/5/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | 7-RTU NOT COOLING IN RM-102,103,104,202,203,223,224 PLANT MGR-HOLTON/416.0990 | 8/8/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | A/C IN RMS 201 & 214-BOTH NOT COOLING-SBE HOLTON 416-5946 KLR | 8/9/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | A/C ENTIRE 2ND FLR ABOUT (22) RMS & 1ST FLR RMS 102 & 103-ALL NOT COOLING-SBE HOLTON 416-5946 KLR | 8/12/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Replace defective actuator on FCU at room 202. | 8/15/13 | | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | thermostat in room 113 dont work need new replacement. | 1/31/14 | 1st Floor | room 113 | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | HEAT 6TH GR AREA 2ND FLR-ABOUT (20) RMS NOT HEATING-PLANT MGR HOLTON 416-5946 KLR | 3/6/14 | | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | A/C 2ND FLR ABOUT (20) RMS & MAIN OFC-ALL NOT COOLING-PLANT MGR 416-5946 KLR | 5/12/14 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|--|--|---------------------------------------|
| Douglass K8 (2155) 2B | Yearly - WCC Filter-Douglass Elementary - Refer to PM schedule details. | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Monthly - Filter-Douglass Elementary - Refer to PM schedule details. | 1/27/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Yearly - Oil Samples-Douglas Elementary - Refer to PM schedule details. | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Monthly - Filter-Douglass Elementary - Refer to PM schedule details. | 5/26/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Yearly - Cooling Towers-Douglass Elementary - Refer to PM schedule details. | 3/10/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Monthly - Filter-Douglass Elementary - Refer to PM schedule details. | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Daily - Douglass Elem Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Douglass K8 (2155) 2B | Monthly - DOUGLASS ELEM LVL 2 WATER TREATMENTS - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|-------------|----------------|----------|
| Douglass K8 (2155) 2B | Carpenter has reworked counter top and cabinet and the wall need painting. | 4/15/14 | Kitchen | Serving Line | Painting |
| Douglass K8 (2155) 2B | put on parking lot for secretary parking. | 10/16/13 | Parking Lot | secretary sign | Painting |
| Douglass K8 (2155) 2B | TOILET PIPE IS LEAKING WATER IN B/RR 2ND FLR BY RM-213 PLANT MGR-HOLTON/416.0990 | 12/3/13 | | | Plumbing |
| Douglass K8 (2155) 2B | ICE MAKER DRAIN LINE IS BACKING UP IN KITCHEN PLANT MGR-HOLTON/416.5946 | 12/4/13 | | | Plumbing |
| Douglass K8 (2155) 2B | 1st fl girls rr by custodial closet 110A, 2nd stall & 3rd stall leaking water from pipe, when flushed, down to tile floor. | 12/4/13 | 1st Floor | 2nd floor | Plumbing |
| Douglass K8 (2155) 2B | by custodial closet 210A 1st stall leaking water when flushed, on down to tile floor. | 12/4/13 | 2nd Floor | girls rr | Plumbing |
| Douglass K8 (2155) 2B | by room 211A stall 1st 3rd 4th, leaking water when flushed on down to tile floor. | 12/4/13 | 2nd Floor | girls rr | Plumbing |
| Douglass K8 (2155) 2B | across from room 213, leaking water from pipe, when flushed, on down to tile floor. | 12/4/13 | 2nd Floor | boys rr | Plumbing |

| | | | | | |
|-----------------------|---|----------|-----------------|------------------------|----------|
| Douglass K8 (2155) 2B | lady rest room last stall when you flush the water come out of pipe where they connect , need new rubber seal to stop the water . | 10/17/13 | 1st Floor | teacher lounge | Plumbing |
| Douglass K8 (2155) 2B | north end boys restroom urinal need strainer to keep kids from putting juice bottle down the hatch or urinal drain. | 10/18/13 | 1st Floor | east hall | Plumbing |
| Douglass K8 (2155) 2B | sink on north wall the stop that holds water in sink dont work anymore, foot operated. | 10/18/13 | Kitchen | two compartment | Plumbing |
| Douglass K8 (2155) 2B | COMMODE PRIN'S OFC-SKEETING WATER OUT PER SBE-PLANT MGR HOLTON 416-5946 KLR | 10/28/13 | | | Plumbing |
| Douglass K8 (2155) 2B | Test and repair RP Devices per MLG&W. | 10/30/13 | Mechanical Room | | Plumbing |
| Douglass K8 (2155) 2B | URINAL 2ND FLR B RR-OVERFLOWING-PLANT MGR HOLTON 416-5946 KLR | 11/8/13 | | | Plumbing |
| Douglass K8 (2155) 2B | room 208 & 209 leaking water from pipe, every time they flush on to tile floor. last stall. | 11/15/13 | 2nd Floor | girls rest room facing | Plumbing |
| Douglass K8 (2155) 2B | by room 109, second stall, leaking water from piping every time they flush, need new seal to stop water leak. | 11/20/13 | 1st Floor | girls rest room (rr) | Plumbing |

| | | | | | |
|-----------------------|---|---------|-----------|-------------------|----------|
| Douglass K8 (2155) 2B | work order#376854 urinal stop up and need strainer over hole, they unstop the urinal, but did not put the strainer over the hole to keep the plastic juice bottle, and paper from going down the hole, still need strainer two of them. | 9/27/13 | 2nd Floor | boys rest room | Plumbing |
| Douglass K8 (2155) 2B | has water leak from foot pedal when you step on it, need washer replaced. | 9/27/13 | Kitchen | porcelain sink | Plumbing |
| Douglass K8 (2155) 2B | urinal stop up, and need strainer on two of them need replaced, it must be juice bottle or a milk carton in the hole, need unstop. | 8/21/13 | 2nd Floor | boys rest room | Plumbing |
| Douglass K8 (2155) 2B | the three compartment sink and two compartment sink need stop valve replaced on the sinks in the kitchen so the sink can hold water again to wash food and served other needs. | 8/1/13 | Kitchen | | Plumbing |
| Douglass K8 (2155) 2B | toilet leaking water at base of toilet, every time its flushes o ring or washer is broken. | 8/1/13 | Kitchen | cafeteria manager | Plumbing |
| Douglass K8 (2155) 2B | three compartment sink leaking water from pipe under neath need repair | 8/8/13 | Kitchen | east wall | Plumbing |
| Douglass K8 (2155) 2B | office stage has a pipe that run through about head high, every time the toilets is flushed on the second floor middle school boys restroom, water from toilet leaks on teacher desk,pipe need repair. | 8/13/13 | 1st Floor | office stage | Plumbing |
| Douglass K8 (2155) 2B | SINK IN ROOM LEAKING water under neath, around drain outlet. | 8/14/13 | 1st Floor | ROOM A131 | Plumbing |

| | | | | | |
|-----------------------|---|---------|-----------------|------------------------|----------|
| Douglass K8 (2155) 2B | VALVE IS LEAKING WATER IN BOILER RM PLANT MGR-HOLTON/416.5946 | 1/29/14 | | | Plumbing |
| Douglass K8 (2155) 2B | boys urinal stop up both on south end of building, hallway. | 1/29/14 | 1st Floor | and second floor | Plumbing |
| Douglass K8 (2155) 2B | still leaking from the same exact area, where water drain out of sink, the work order is showing complete, i got down on my knees to make sure it was the same problem. still need fixing.work order #372726. | 9/16/13 | Kitchen | three compartment sink | Plumbing |
| Douglass K8 (2155) 2B | leaking wateer from under neath it, on west side of cafeteria. | 2/6/14 | Cafeteria | water fountain | Plumbing |
| Douglass K8 (2155) 2B | Loop pump leaking contact Paul Simmions for assistance. | 2/17/14 | Mechanical Room | 217-A | Plumbing |
| Douglass K8 (2155) 2B | Loop pump frozeup contact Paul Simmions for assistance. | 2/17/14 | Mechanical Room | 1st Floor Southend | Plumbing |
| Douglass K8 (2155) 2B | LOOP PUMP 2ND FLR MECH RM EAST SIDE-LEAKING-PLANT MGR HOLTON 416-0990 KLR | 2/24/14 | | | Plumbing |
| Douglass K8 (2155) 2B | theres a leak on stage from pipes over head in office on stage leaking on to tile floor, and small fragments of cement between pipes and wall falling to tile floor. | 4/7/14 | 1st Floor | stage office | Plumbing |

| | | | | | |
|-----------------------|---|---------|-----------------|---------------------|----------|
| Douglass K8 (2155) 2B | next to mechanical room 111 last stall bad flush valve wont stop continue to flush. | 4/10/14 | 1st Floor | girls rest room | Plumbing |
| Douglass K8 (2155) 2B | the urinal drain stainer is missing need new drain strainer for boys rr the boys are stuffing paper towels in drain causing over flow on to tile floor. | 4/11/14 | 1st Floor | boys rr | Plumbing |
| Douglass K8 (2155) 2B | hot water tank dont work and all the water has leak out of it through the escape pipe. or emergency pipe. | 3/17/14 | 1st Floor | classroom 114 | Plumbing |
| Douglass K8 (2155) 2B | the two sinks facet in rest room will not stop running in the off position two of them at far right. | 3/20/14 | 1st Floor | west hall | Plumbing |
| Douglass K8 (2155) 2B | please unstop this urinal, overflows with each flush | 5/16/14 | 2nd Floor | boys r/r 2nd urinal | Plumbing |
| Douglass K8 (2155) 2B | these urinals have very low water pressure, they have to e maually flushed with uckets of water | 5/16/14 | Restroom (Boys) | 1st floor (rm 114) | Plumbing |
| Douglass K8 (2155) 2B | please repair the leaking roof drain p-trap, water continually leaks, due to cooling tower | 5/16/14 | 2nd Floor | custodia; closet | Plumbing |
| Douglass K8 (2155) 2B | COOLING TOWER-OVERFLOWING-PLANT MGR HOLTON 416-5946 KLR | 5/21/14 | | | Plumbing |

| | | | | | |
|-----------------------|--|----------|------------------|-------------------|----------|
| Douglass K8 (2155) 2B | by room 210 toilet #3 still leaking water from pipe when flushed on down to tile floor, this is the old ticket on that toilet #401377 | 4/24/14 | Restroom (Girls) | 2nd floorb | Plumbing |
| Douglass K8 (2155) 2B | per Mr. Holton 416-6376 2nd floor boys restroom across from 213 in the 2nd stall the porcelain part of toilet is broken with very sharp edges | 11/21/13 | | | Plumbing |
| Douglass K8 (2155) 2B | 222A directly Above clock north end of building, roof leak. | 1/13/14 | 2nd Floor | hallway near room | Roof |
| Douglass K8 (2155) 2B | water is coming down beside the roof drain pipe or its coming from where the pipe joint or connection and is leaking down to center of class room tile floor. I check the roof drain there is no standing water in the area of room 203. | 12/9/13 | 2nd Floor | class room 203 | Roof |
| Douglass K8 (2155) 2B | Roof Leaking in Rooms 214 & 219 per Mr. Eddie Holton, Plant Mgr. at 901.416.5946. Roof Leaks everytime it rains! | 7/30/13 | | | Roof |
| Douglass K8 (2155) 2B | above door in room 119, the exit door. | 2/4/14 | 1st Floor | room 119 | Roof |
| Douglass K8 (2155) 2B | above door in room 119. | 2/4/14 | 1st Floor | roof leak | Roof |
| Douglass K8 (2155) 2B | roof leak by room117 from ceiling down to tile floor. | 4/2/14 | 1st Floor | east hallway | Roof |

| | | | | | |
|-----------------------|--|---------|-----------|-------------|-------------|
| Douglass K8 (2155) 2B | between room 221 & 222 in hallway from ceiling on to sensor in ceiling from sensor to hall floor. | 5/29/14 | 2nd Floor | roof leak | Roof |
| Douglass K8 (2155) 2B | the roof is leaking in that area on to tile floor , the tile is starting to seperate from over the years. | 6/5/14 | 1st Floor | by room 117 | Roof |
| Douglass K8 (2155) 2B | need to move from present location to east hall, west wall across from 219, and the lockers from south east end of building to across from 219, and the locker on the north west end sitting on the west wall and east wall to be put across from 201 on east wall and locker on north wall to go across from 219. | 9/4/13 | 2nd Floor | lockers | Sheet Metal |
| Douglass K8 (2155) 2B | theres a hole in the wall where rats go back and forth need sealed off. | 8/1/13 | Kitchen | pantry room | Sheet Metal |
| Douglass K8 (2155) 2B | need a lock loop welded on each dumpster, to slide lock threw the loop to lock it, and a rod across the top to keep the lid from being pull open, on both dumpster | 9/4/13 | Grounds | dumpster | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|--------------------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Junbar ES (2165) 2 | 3 | 18 | 30 | 17 | 10 | 36 | 1 | 4 | 119 |
| Grand Total | 3 | 18 | 30 | 17 | 10 | 36 | 1 | 4 | 119 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|---------------------|---|----------------------|-------------------------|--------------------|--------------|
| Dunbar ES (2165) 2B | open wires in main office,need to be closed off (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 10/28/13 | Administration Area | main office | Cabling |
| Dunbar ES (2165) 2B | SCS FP-3500 Network Cabling Project- Provide project management for Access DNSI to install network cabling installations and any associated electrical wiring. (Request Network Cabling Project Management) | 7/26/13 | | | Cabling |
| Dunbar ES (2165) 2B | smartboards moved in class room 306 (Request Interactive White board Assistance). | 7/15/13 | Classroom | | Cabling |
| Dunbar ES (2165) 2B | stall door broken off girls restroom 2nd floor | 5/20/14 | Restroom (Girls) | | Carpentry |
| Dunbar ES (2165) 2B | Boys Restroom On The 3rd Floor Hallway Need a Door To The Toilet | 6/17/14 | | | Carpentry |
| Dunbar ES (2165) 2B | weather stripping under doors in cafeteria and kitchen | 2/17/14 | Cafeteria | | Carpentry |
| Dunbar ES (2165) 2B | weather stripping under doors in boiler room | 2/19/14 | 1st Floor | | Carpentry |

| | | | | | |
|---------------------|---|---------|---------------------|--------------------------------|-----------|
| Dunbar ES (2165) 2B | repair hand-rail | 10/3/13 | Stairway | east hall | Carpentry |
| Dunbar ES (2165) 2B | hole in floor ,it need to be filled | 7/22/13 | Classroom | 313 | Carpentry |
| Dunbar ES (2165) 2B | wood breaking off door in multi purpose room. | 7/22/13 | Classroom | | Carpentry |
| Dunbar ES (2165) 2B | entrance door not closing properly | 8/6/13 | Administration Area | entrance door west | Carpentry |
| Dunbar ES (2165) 2B | bulletin board placed on hallway wall first floor | 8/20/13 | Hallway/Corridor | hallway | Carpentry |
| Dunbar ES (2165) 2B | REPAIR FLOOR TILES | 1/13/14 | 1st Floor | principal office DR. GENTRY | Carpentry |
| Dunbar ES (2165) 2B | REPAIR BASE BOARD UNDERNEATH | 1/13/14 | 1st Floor | WASH BASIN | Carpentry |
| Dunbar ES (2165) 2B | REPLACE STALL DOOR | 1/14/14 | 3rd Floor | GIRL'S RR | Carpentry |

| | | | | | |
|---------------------|--|---------|---------------------|-----|------------|
| Dunbar ES (2165) 2B | screen on outside door falling off,need to be replaced | 1/29/14 | Cafeteria | | Carpentry |
| Dunbar ES (2165) 2B | arm closer on principal's door to office broken | 2/27/14 | Administration Area | 107 | Carpentry |
| Dunbar ES (2165) 2B | arm closer,on door to multipurpose building broken | 2/27/14 | Gym | | Carpentry |
| Dunbar ES (2165) 2B | stall door in boys restroom 1st floor broken | 2/27/14 | Restroom (Boys) | | Carpentry |
| Dunbar ES (2165) 2B | need room numbers placed on all doors ,inside building | 2/26/14 | Hallway/Corridor | | Carpentry |
| Dunbar ES (2165) 2B | need room number signs, on doors around building | 2/10/14 | | | Carpentry |
| Dunbar ES (2165) 2B | WALL UNIT RM 310-NOT COMING ON-PLANT MGR CRADDOCK 416-5000 KLR | 4/15/14 | | | Electrical |
| Dunbar ES (2165) 2B | time off clocks,in building | 4/23/14 | Hallway/Corridor | | Electrical |

| | | | | | |
|---------------------|---|----------|---------------------|---------|------------|
| Dunbar ES (2165) 2B | UNIT NOT COMING ON IN RM- 313,302,207,210B PLANT MGR- CRADDOCK/416.5000 | 4/24/14 | | | Electrical |
| Dunbar ES (2165) 2B | 2 ballast out in hallway lights by principal's office | 5/20/14 | Hallway/Corridor | | Electrical |
| Dunbar ES (2165) 2B | three cases of bulbs for lights in hallway and classrooms | 6/4/14 | | | Electrical |
| Dunbar ES (2165) 2B | electrical breaker to exhaust fan in kitchen, constantly tripping. | 2/20/14 | | kitchen | Electrical |
| Dunbar ES (2165) 2B | reset clocks around building | 3/11/14 | Administration Area | | Electrical |
| Dunbar ES (2165) 2B | three ballast in classroom # 305 | 4/9/14 | Classroom | 305 | Electrical |
| Dunbar ES (2165) 2B | 3 ballast out in classroom 301 | 10/25/13 | | 301 | Electrical |
| Dunbar ES (2165) 2B | Extend 120V. recept. circuit to the opposite wall in the main office work room. | 10/28/13 | | | Electrical |

| | | | | | |
|---------------------|---|----------|---------------------|------------------|------------|
| Dunbar ES (2165) 2B | FIN SECRETARY LIGHTS IN OFFICE HAVE NO POWER. PLANT MGR- CRADDOCK/347.9794 | 11/5/13 | | | Electrical |
| Dunbar ES (2165) 2B | UV NOT COMING ON IN RM- 209. PLANT MGR- CRADDOCK/416.5974 | 11/5/13 | | | Electrical |
| Dunbar ES (2165) 2B | clocks reset in building | 9/27/13 | Administration Area | | Electrical |
| Dunbar ES (2165) 2B | LIGHTS NOT COMING ON EAST SIDE OF BLDG-PLANT MGR CRADDOCK 416-5000 KLR | 10/10/13 | | | Electrical |
| Dunbar ES (2165) 2B | RECEPTACLES TO STEAM TABLE IN THE SERVING LINE IS NOT WORKING. SBE JEFFERSON 416-5000 | 8/2/13 | | | Electrical |
| Dunbar ES (2165) 2B | repair light on poles,security asap,too dark at closing | 8/6/13 | Parking Lot | west pole lights | Electrical |
| Dunbar ES (2165) 2B | repair security lights on pole,need more lighting,high volume of traffic entering | 8/6/13 | Parking Lot | west pole lights | Electrical |
| Dunbar ES (2165) 2B | A/C IN RMS 302 & 309-BOTH NOT COMING ON-PLANT MGR CRADDOCK 416-5000 KLR | 9/5/13 | | | Electrical |

| | | | | | |
|---------------------|---|----------|-----------|--------------|------------|
| Dunbar ES (2165) 2B | need 120 receptacal placed in 2nd floor copy room | 12/9/13 | | copy room | Electrical |
| Dunbar ES (2165) 2B | 4 ballast out in school kitchen | 12/10/13 | | | Electrical |
| Dunbar ES (2165) 2B | stairway lights on southside of building ballast out | 1/8/14 | Stairway | | Electrical |
| Dunbar ES (2165) 2B | light ballast in storage room,in library not working | 1/9/14 | Library | storage room | Electrical |
| Dunbar ES (2165) 2B | two ballast in classroom out | 1/9/14 | Classroom | 110 | Electrical |
| Dunbar ES (2165) 2B | two ballast out in class 301. | 1/9/14 | Classroom | 301 | Electrical |
| Dunbar ES (2165) 2B | Per Mr. Craddock 416-5000 there are a lot of lights out in the kitchen and cafeteria area and has checked breaker | 1/13/14 | | | Electrical |
| Dunbar ES (2165) 2B | classroom 101 2 ballast out | 2/6/14 | Classroom | | Electrical |

| | | | | | |
|---------------------|---|----------|-----------|-----|---------------------------------------|
| Dunbar ES (2165) 2B | flag pole wire broken, hard to pull up or down | 2/27/14 | Grounds | | Electrical |
| Dunbar ES (2165) 2B | five ballast out in class room 313 | 2/28/14 | | 313 | Electrical |
| Dunbar ES (2165) 2B | Check out heating equipement, had a power outage this weekend. | 3/4/14 | | | Electrical |
| Dunbar ES (2165) 2B | 4 ballast out in classroom 306 | 3/7/14 | Classroom | 306 | Electrical |
| Dunbar ES (2165) 2B | A/C unit is LEAKING in the Kitchen per Mr. Craddock, Plant Mgr. 416.5000 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Monthly - Filter-Dunbar Elementary - Refer to PM schedule details. | 10/21/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | A/C ENTIRE 3RD FLR ABOUT (11) RMS-ALL NOT COOLING-PLANT MGR CRADDOCK 416-5000 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Monthly - AirCompressor #072 Blr rm Dunbar Elm - Refer to PM schedule details. | 7/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|----------|--|--|--|
| Dunbar ES (2165) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | per mr craddock 416-5000 the chiller is down | 10/14/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Chiller on 1st floor NOT COOLING per Mr. Craddock, Plant Mgr. at 901.416.5000. | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | WALL UNIT NOT COMING ON IN MAIN OFFICE. SBE-CRADDOCK/416-5974 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | 8-UV NOT COOLING IN RM- 106(003) RM-110(006) RM- 209(033) RM-107(060) RM- 310(064) RM-307(055) RM- 308(066). PLANT MGR- CRADDOCK/416.500 | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | UNIT NOT COOLING THRU ALL HALLS 1ST, 2ND, 3RD FLRS. PLANT MGR- CRADDOCK/416.5974 | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | BOILER is NOT COMING on per Mr. Craddock, Plant Mgr. 416.5000 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Monthly - AirCompressor #072 Blr rm Dunbar Elm - Refer to PM schedule details. | 1/5/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|---------|-----------|--|---------------------------------------|
| Dunbar ES (2165) 2B | Monthly - Oil Lube & Belt-Dunbar Elementary - Refer to PM schedule details. | 1/10/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | UNIT IS OVERHEATING (85)IN MAIN BLDG PLANT MGR-JEFFERSON/416.5000 | 1/15/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Yearly - Boiler - Dunbar Elem - Refer to PM schedule details. | 3/11/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Monthly - Filter-Dunbar Elementary - Refer to PM schedule details. | 2/24/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | Monthly - Filter-Dunbar Elementary - Refer to PM schedule details. | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Dunbar ES (2165) 2B | paint pilling off wall in cafeteria. | 11/6/13 | Cafeteria | | Painting |
| Dunbar ES (2165) 2B | repair plaster in restroom | 6/12/14 | | | Painting |
| Dunbar ES (2165) 2B | paint walls in classrooms touch up lockers | 6/13/14 | | | Painting |

| | | | | | |
|---------------------|--|----------|-----------|---------|----------|
| Dunbar ES (2165) 2B | Paint window screens for Tom Ford. | 2/11/14 | | | Painting |
| Dunbar ES (2165) 2B | paint outside door to cafe with markings on it | 10/24/13 | | | Painting |
| Dunbar ES (2165) 2B | paint rails and columns front of bldg | 10/28/13 | | | Painting |
| Dunbar ES (2165) 2B | paint doors | 7/16/13 | | | Painting |
| Dunbar ES (2165) 2B | collums and rails painted on outside of school | 9/19/13 | Grounds | | Painting |
| Dunbar ES (2165) 2B | paint chipping off ceiling in cafeteria,kitchen | 11/11/13 | Cafeteria | kitchen | Painting |
| Dunbar ES (2165) 2B | GRAFFITI THRU OUT ENTIRE BLDG . PLANT MGR- CRADDOCK/416.5000 | 1/24/14 | | | Painting |
| Dunbar ES (2165) 2B | CHILLER IS LEAKING WATER IN BOILER RM PLANT MGR- CRADDOCK/347.9794 | 4/22/14 | | | Plumbing |

| | | | | | |
|---------------------|--|----------|-----------------|------------------------------|----------|
| Dunbar ES (2165) 2B | AIR COMPRESSOR MECH RM- HAS LOCKED UP & SMOKING- AFFECTS AIR TO BLDG- PLANT MGR JOHNSON 416-5000 KLR | 6/4/14 | | | Plumbing |
| Dunbar ES (2165) 2B | DRAIN - OUTSIDE BETWEEN FOOTBALL FIELD & SCHOOL - WTR HIS SHOOTING POURING OUT - PM/CRADDOCK 416-5000 | 6/5/14 | | | Plumbing |
| Dunbar ES (2165) 2B | 1rd Floor Girls restroom Has 3 Toilet Not Working Repair Are Needed | 6/16/14 | 1st Floor | 1st floor Girls Restroom | Plumbing |
| Dunbar ES (2165) 2B | Library Clinic Has a Restroom 2 toilet Not Working Need To Be Repair | 6/17/14 | 2nd Floor | 2nd Library Clinic Restrooms | Plumbing |
| Dunbar ES (2165) 2B | 2nd Fioor Hallway Has 2 Restrooms Each Girls/Boys/RestRooms Has 2 Toilet Not Working Need To be Repair | 6/17/14 | 2nd Floor | 2nd Floor Restrooms | Plumbing |
| Dunbar ES (2165) 2B | Girls Room ON The 3rd Floor Need a Toilet Seats Need To Be Repair | 6/17/14 | 3rd Floor | 3rd Floor Rests | Plumbing |
| Dunbar ES (2165) 2B | toielts not flushing first floor boys restroom | 7/15/13 | Restroom (Boys) | | Plumbing |
| Dunbar ES (2165) 2B | water in boys restroom, second floor ,in sink will not turn off constantly running | 10/22/13 | Restroom (Boys) | | Plumbing |

| | | | | | |
|---------------------|---|----------|------------------|-----------------|----------|
| Dunbar ES (2165) 2B | sink faucet running | 10/25/13 | Restroom (Boys) | 3rd floor | Plumbing |
| Dunbar ES (2165) 2B | TOILET IS FLOODING IN B/RR 1ST FLR, CANT CONTROL. PLANT MGR- CRADDOCK/416.5974 | 11/5/13 | | | Plumbing |
| Dunbar ES (2165) 2B | flush vale not working on toilet in girl restroom across from room 101 | 9/25/13 | Restroom (Girls) | | Plumbing |
| Dunbar ES (2165) 2B | toilet leaking from bottom in boys restroom 2nd floor per Mr. Craddock 416-5000 | 10/1/13 | | | Plumbing |
| Dunbar ES (2165) 2B | repair water faucet,leaking | 10/8/13 | 1st Floor | girl's restroom | Plumbing |
| Dunbar ES (2165) 2B | Test and repair RP Devices per MLG&W. | 10/10/13 | Mechanical Room | | Plumbing |
| Dunbar ES (2165) 2B | Room 208 a/c leaking per Mr. Craddock 416-5000 | 8/5/13 | | | Plumbing |
| Dunbar ES (2165) 2B | UV-1 2ND FLR RM 208- LEAKING-SBE CRADDOCK 416-5000 KLR | 8/6/13 | | | Plumbing |

| | | | | | |
|---------------------|---|---------|--|--|----------|
| Dunbar ES (2165) 2B | UV IS LEAKING WATER IN RM-215. PLANT MGR- CRADDOCK/416.500 | 8/8/13 | | | Plumbing |
| Dunbar ES (2165) 2B | 2-WALL UNITS ARE LEAKING IN RM-308,215 PLANT MGR- CRADDOCK/416.5974 | 8/13/13 | | | Plumbing |
| Dunbar ES (2165) 2B | WALL UNIT IS LEAKING WATER IN RM-310 PLANT MGR- CRADDOCK/416.5000 | 8/22/13 | | | Plumbing |
| Dunbar ES (2165) 2B | A/C RM 106-LEAKING-PLANT MGR CRADDOCK 416-5000 KLR | 8/30/13 | | | Plumbing |
| Dunbar ES (2165) 2B | WALL UNIT IS LEAKING WATER IN RM-201, & RM-108 PLANT MGR- CRADDOCK/416.5000 | 9/3/13 | | | Plumbing |
| Dunbar ES (2165) 2B | 3-WALL UNITS NOT COMING ON IN RM-301,209,103 PLANT MGR- CRADDOCK/416.5000 Electrician checked out, leaking | 9/19/13 | | | Plumbing |
| Dunbar ES (2165) 2B | UNIT IS LEAKING WATER CONTINUOUSLY IN CAFE PLANT MGR- CRADDOCK/347.9794 | 9/23/13 | | | Plumbing |
| Dunbar ES (2165) 2B | TOILET IS OVERFLOWING IN B/RR 1ST FLR PLANT MGR- CRADDOCK/416.5000 | 12/3/13 | | | Plumbing |

| | | | | | |
|---------------------|---|----------|------------------|---------------------------|----------|
| Dunbar ES (2165) 2B | WALL UNIT IS LEAKING WATER IN RM-304 PLANT MGR- CRADDOCK/416.5000 | 12/10/13 | | | Plumbing |
| Dunbar ES (2165) 2B | need toilet seat for girls restroom first floor | 12/11/13 | Restroom (Girls) | | Plumbing |
| Dunbar ES (2165) 2B | toilet leaking around bottom, girl's first floor restroom | 12/11/13 | Restroom (Girls) | | Plumbing |
| Dunbar ES (2165) 2B | water leaking from fountain, thrid floor by room 304 | 12/19/13 | Hallway/Corridor | | Plumbing |
| Dunbar ES (2165) 2B | REPAIR PIPE (j)leaking | 1/13/14 | 3rd Floor | WATER FOUNTAIN WEST | Plumbing |
| Dunbar ES (2165) 2B | GAS SMELL IN RM 307- CALLED IN BY GUID COUNSELOR MIDDLETON 416- 5000 KLR | 1/14/14 | | | Plumbing |
| Dunbar ES (2165) 2B | TOILET IS OVERFLOWING IN B/RR 3RD FLR. PLANT MGR- CRADDOCK/416.5000 | 1/23/14 | | | Plumbing |
| Dunbar ES (2165) 2B | BUSTED PIPE 3RD FLR DRINKING FOUNTAIN PLANT MGR- CRADDOCK/416.5000 | 1/24/14 | | | Plumbing |

| | | | | | |
|---------------------|---|---------|-----------------|----------------------|-------------|
| Dunbar ES (2165) 2B | GAS LEAK BACK OF BLDG. PLANT MGR- CRADDOCK/416.5974 | 1/30/14 | | | Plumbing |
| Dunbar ES (2165) 2B | toilet not flushing in boys restroom third floor | 2/6/14 | Restroom (Boys) | | Plumbing |
| Dunbar ES (2165) 2B | GAS SMELL THRU ENTIRE 3RD FLR PLANT MGR- CRADDOCK/347.9794 | 1/14/14 | | | Plumbing |
| Dunbar ES (2165) 2B | water leak in multipurpose room ceiling | 9/23/13 | | multipurpose room | Roof |
| Dunbar ES (2165) 2B | door on wall unit need repair. | 2/10/14 | Classroom | 310 | Sheet Metal |
| Dunbar ES (2165) 2B | door on wall unit need repair | 2/10/14 | | 309 | Sheet Metal |
| Dunbar ES (2165) 2B | door on wall unit need repair | 2/10/14 | Classroom | 301 | Sheet Metal |
| Dunbar ES (2165) 2B | door on wall unit need repair | 2/10/14 | Classroom | 208 | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|-------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| East HS (2180) 2A | 23 | 4 | 123 | 89 | 41 | 33 | 106 | 15 | 11 | 445 |
| Grand Total | 23 | 4 | 123 | 89 | 41 | 33 | 106 | 15 | 11 | 445 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-------------------|--|----------------|------------------|---|----------|
| East HS (2180) 2A | Replace broken floor tiles. | 5/27/14 | Hallway/Corridor | 3rd fl. east end | Asbestos |
| East HS (2180) 2A | Replace broken floor tiles in front of rm#330. | 2/27/14 | Hallway/Corridor | 3rd floor | Asbestos |
| East HS (2180) 2A | Replace soiled ceiling tiles. | 3/25/14 | Hallway/Corridor | 3rd floor west end | Asbestos |
| East HS (2180) 2A | Replace missing and soiled ceiling tiles. | 2/7/14 | Restroom (Boys) | 2nd Floor west end | Asbestos |
| East HS (2180) 2A | Replace missing and soiled ceiling tiles. | 2/7/14 | Restroom (Girls) | 2nd floor west end | Asbestos |
| East HS (2180) 2A | Please allow asbestos team to come out and change out ceiling tile in boys and girls restroom on the 1st. and 2nd. fl. where there are spinkler heads. | 2/12/14 | | boys and girls restroom 1st. and 2nd. fl. | Asbestos |
| East HS (2180) 2A | Replace broken floor tiles . | 2/13/14 | Hallway/Corridor | 3rd floor | Asbestos |

| | | | | | |
|-------------------|---|----------|------------------|--------------------|----------|
| East HS (2180) 2A | Replace broken and missing floor tiles. | 2/13/14 | Classroom | Rm#328 | Asbestos |
| East HS (2180) 2A | Replace missing cold base, on baseboards. | 2/13/14 | Classroom | Rms#327, 328 &329 | Asbestos |
| East HS (2180) 2A | Replace missing and broken floor tiles. | 2/18/14 | Classroom | Rm#320 | Asbestos |
| East HS (2180) 2A | Replace old torn carpet with floor tiles in elevator. | 9/9/13 | | | Asbestos |
| East HS (2180) 2A | Replace missing and soiled ceiling tiles. | 12/19/13 | Classroom | Rms#216 & 219 | Asbestos |
| East HS (2180) 2A | Replace missing and soiled ceiling tiles. | 1/9/14 | Restroom (Boys) | 2nd floor east end | Asbestos |
| East HS (2180) 2A | Replace missing and broken floor tiles. | 1/16/14 | Hallway/Corridor | 2nd floor | Asbestos |
| East HS (2180) 2A | Replace soiled ceiling tiles. | 1/17/14 | Classroom | Rm#212 | Asbestos |

| | | | | | |
|-------------------|---|----------|---------------------|-----------------------------|----------|
| East HS (2180) 2A | Please allow a team to come out and restore East High gym floor for basketball season. | 10/29/13 | Gym | Gym floor | Asbestos |
| East HS (2180) 2A | Please allow painters to come out and paint in coaches box onto gym floor. | 10/31/13 | Gym | gym floor | Asbestos |
| East HS (2180) 2A | Please allow a carpenter to come out and replace floor tile out side of conference room. Tile is asbestos filled. | 8/15/13 | Administration Area | Out side of conference room | Asbestos |
| East HS (2180) 2A | Please allow an asbestos team to come out and remove fungus like substance from the top of book shelf that seem to be growing. | 8/22/13 | | library | Asbestos |
| East HS (2180) 2A | Please allow asbestos team to come out and replace fiberglass insulation in band room insulation has been stripped away on section of piping. | 8/8/13 | | band room | Asbestos |
| East HS (2180) 2A | Replace missing and broken floor tiles. | 8/8/13 | Hallway/Corridor | 3rd Floor | Asbestos |
| East HS (2180) 2A | Replace missing and broken floor tiles. | 8/8/13 | Hallway/Corridor | 2nd Floor | Asbestos |
| East HS (2180) 2A | Soiled and black molded ceiling tile, please for mold. | 8/8/13 | 1st Floor | | Asbestos |

| | | | | | | |
|-------------------|---|----------|---------------------|--------------------|--|-----------|
| East HS (2180) 2A | Need a Network Drop installed in conference room for new Security Camera System to be operational. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 2/19/14 | 2nd Floor | | | Cabling |
| East HS (2180) 2A | Please allow a tech to come out and repair computer hub in the auditorium. | 11/21/13 | | | | Cabling |
| East HS (2180) 2A | Please allow an electrician to come out and reset the bell system for East High.(Intercom Service). | 8/9/13 | Administration Area | Main office | | Cabling |
| East HS (2180) 2A | EAST- WO417713- Dell 2330d Printer displaying the message "Replace PC Kit". Printer is malfunctioning. I am Financial Secretary and need this printer to perform daily accounting tasks. This is the 2nd request. | 2/19/14 | 2nd Floor | | | Cabling |
| East HS (2180) 2A | WINDOW - PRIN OFC AND INSIDE OF THE CAFE - WTR COMING THRU - LEAKING - PM/HAMMER 416-5960 | 6/23/14 | | | | Carpentry |
| East HS (2180) 2A | Replace broken peep glass in classroom door. | 6/24/14 | Classroom | Rm#105 | | Carpentry |
| East HS (2180) 2A | Close overhead door completely, it has a gap that is letting water in when it rains. | 6/24/14 | Gym | Girl's Locker room | | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and repair door closure on the 2nd fl. west end. (2 different door closures in need of repair). | 4/5/14 | | 2nd. fl. west end | | Carpentry |

| | | | | | |
|-------------------|---|---------|-----|-------------------------------|-----------|
| East HS (2180) 2A | WINDOW IS BROKEN IN MAIN ENTRY ABOVE DOOR FRAME PLANT MGR- HAMER/650.9273 | 4/8/14 | | | Carpentry |
| East HS (2180) 2A | ENTRANCE DOOR FOOTBALL LOCKER RM- NOT LOCKING-CAN STILL BE PULLED OPEN FROM OUTSIDE WHILE IN LOCK POSITION-WON'T BE ABLE TO SECURE-PLANT MGR HAMER 416 6475 415 | 4/14/14 | | | Carpentry |
| East HS (2180) 2A | Broken center bar on back entrance door, hard to secure door. | 4/14/14 | Gym | Back entrance door | Carpentry |
| East HS (2180) 2A | Please allow carpenter to come out and repair door closure to doors on the 3rd fl. west stairway by elevator, 3 in need of repair and southwest end next to room 306 also custodial closet on the 3rd fl. across from gym | 4/16/14 | | 3rd fl. west | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and install 2 white boards in classroom #314. Magnetic if possible. | 5/27/14 | | RM# 314 | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and repair door closures to fire doors on the 1st. fl. | 5/27/14 | | 1st fl. west end stairway | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and repair door closure to gym doors. | 6/5/14 | | gym area | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and repair door closures to the gym doors east and west entry and replace the door closure that is missing from the auditorium door. | 6/10/14 | | Gym doors and auditorium door | Carpentry |

| | | | | | |
|-------------------|--|---------|-----------|-----------------------------|-----------|
| East HS (2180) 2A | CENTER MULL needs to be REMOVED from FIRE DOOR on the 3rd FLOOR per Mr. Hamer, Plant Mgr. 416.6060 | 6/11/14 | | | Carpentry |
| East HS (2180) 2A | TOP WINDOW OUTSIDE WONT RAISE UP IN RM-301 BY RM 300 PLANT MGR-HAMER/650.9273 | 6/12/14 | | | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and repair roof hatch that want close. Inside custodial closet on 3-A | 6/13/14 | | 3rd fl custodial closet 3-A | Carpentry |
| East HS (2180) 2A | per mr hamer 416-6175 room 317 there is a window that is open and can't close and raining inside | 4/28/14 | | | Carpentry |
| East HS (2180) 2A | ENTRANCE DOOR 2ND FLR HOLMES SIDE-LATCH NOT CATCHING-WON'T BE ABLE TO SECURE-PLANT MGR HAMER 416-6175 KLR | 4/29/14 | | | Carpentry |
| East HS (2180) 2A | per mr hamer 416-6175 in the weight room on 1st floor window has fallen down and can't secure | 4/29/14 | | | Carpentry |
| East HS (2180) 2A | Pleasea allow carpenter to come out and replace floor tile in the weight room, several sections of tile broken into pices. | 4/29/14 | Classroom | 1st. fl. weight room | Carpentry |
| East HS (2180) 2A | SINK RM 328 ART RM-HAS COME OFF THE WALL- PLANT MGR HAMER 416-6175 KLR | 5/7/14 | | | Carpentry |

| | | | | | |
|-------------------|--|---------|-----------------|---------------------------------|-----------|
| East HS (2180) 2A | Please allow a carpenter to come out and secure drop ceiling in the clinic, ceiling sags. located above clinic front desk. | 5/9/14 | | Clinic | Carpentry |
| East HS (2180) 2A | Ceiling falling in. | 5/13/14 | | 210 | Carpentry |
| East HS (2180) 2A | Replace exterior doors that lead to the basement tunnel. | 1/31/14 | Mechanical Room | | Carpentry |
| East HS (2180) 2A | Please repair fence that surround HVAC units outside of Plant managers room. Fence damaged from car accident | 2/25/14 | | across from Plant managers room | Carpentry |
| East HS (2180) 2A | FIRE DOOR 3RD FLR HALLWAY-HANGING OFF HINGES-PLANT MGR HAMER 416-6175 KLR | 2/25/14 | | | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and repair two door closer ot doors on the 3rd. fl above the auditorium. | 2/26/14 | | 3rd. fl. above auditorium | Carpentry |
| East HS (2180) 2A | please allow carpenters to come out and secure fire alarm stobe light and horn housing to wall. out side of auditorium as you exit to rear studen parking lot. | 2/26/14 | | out side of auditorium | Carpentry |
| East HS (2180) 2A | ENTRANCE DOOR GYM BY BOYS' LOCKER RM-NOT LOCKING, CAN STILL BE PULLED OPEN WHILE IN LOCK POSITION-WON'T BE ABLE TO SECURE & KNOB FRAME COMING LOOSE FROM MAIN SEC DOOR | 3/17/14 | | | Carpentry |

| | | | | | |
|-------------------|--|---------|------------------|---|-----------|
| East HS (2180) 2A | Please allow a carpenter to come out and replace metal support strap for drop ceiling in hallway. Drop ceiling sags. | 3/17/14 | | 3rd fl. north east end of hall just before you ente | Carpentry |
| East HS (2180) 2A | entry door to clinic door - the closer is damaged and can't close | 3/19/14 | | | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and repair or replace door closer to rear door in cafeteria. | 3/28/14 | Cafeteria | rear entry door | Carpentry |
| East HS (2180) 2A | KNOB TO MAIN OFC DOOR- IS FALLING OFF DOOR- NOT ABLE TO USE DOOR & ONLY ENTRANCE TO OFC PER SBE-PLANT MGR HAMER 416-6175 KLR | 3/31/14 | | | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace hook to flag pole line. Not able to display flag. | 4/1/14 | | Flag Pole | Carpentry |
| East HS (2180) 2A | CEILING IS HANGING IN RM-206. PLANT MGR- HAMER/650.9273 | 1/21/14 | | | Carpentry |
| East HS (2180) 2A | WINDOW RM 215 2ND FLR- CAN'T RAISE TO CLOSE- TOO MUCH COLD AIR COMING IN-PLANT MGR HAMER 416-6175 KLR | 1/24/14 | | | Carpentry |
| East HS (2180) 2A | Replace three missing stall doors. | 2/4/14 | Restroom (Girls) | 2nd floor east end | Carpentry |

| | | | | | |
|-------------------|--|---------|-----------|------------------------------------|-----------|
| East HS (2180) 2A | install 36 inch handi-cap grab bars in each bathroom stall girls and boys thru out bldg.- os ASAP per Brian Shipp | 2/5/14 | | | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and construct door framing rough opening and walls and install a door with locks to secure a section of tunnel area that leads from kitchen area to tunnel. Also 2 doors in the same area will | 2/5/14 | | Tunnel area | Carpentry |
| East HS (2180) 2A | per mr hamer 416-6175 boys restroom 3rd floor has broken window with jagged edges | 2/7/14 | | | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and repair piano hinge to gym door next to auditorium. | 2/7/14 | | Gym door across netx to auditorium | Carpentry |
| East HS (2180) 2A | paint stall doors (3 Each) battleship gray. | 2/12/14 | | | Carpentry |
| East HS (2180) 2A | Window open will not close. | 2/13/14 | Classroom | Rm#308 | Carpentry |
| East HS (2180) 2A | DROP CEILING STRAPS HAS FALLEN IN RM-217 PLANT MGR- HAMER/650.9273 | 2/17/14 | | | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and replace door holder attachment round. | 2/19/14 | | 1st.fl. by elevator lobby | Carpentry |

| | | | | | |
|-------------------|---|---------|------------------|---------------------------------|-----------|
| East HS (2180) 2A | Please allow carpenter to come out and replace seal tight too fire doors. (Exposed wires) | 2/19/14 | | 2nd fl. by elevator stairwell | Carpentry |
| East HS (2180) 2A | please allow carpenters to come out and replace door holder attchement and and remount screws. | 2/19/14 | | 3rd. fl. outside of rm#316 | Carpentry |
| East HS (2180) 2A | EAST ENTRANCE DOOR- PANIC BAR DAMAGED- WON'T BE ABLE TO SECURE-PLANT MGR HAMER 416-6175 KLR | 8/28/13 | | | Carpentry |
| East HS (2180) 2A | Restroom entrance door lock broke, door will not secure, per A. Harris. | 8/28/13 | Restroom (Boys) | 3rd floor east end | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and repair door lock to boys restroom. Key cylinder will not turn when trying to secure rest room door. | 8/29/13 | | 3rd.fl. Boys restroom | Carpentry |
| East HS (2180) 2A | Pleas allow a carpenter to come out and install bulletin board out side of classroom 304 | 8/30/13 | | room 304 theater room | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and patch hole in ceilings plaster on the 3rd. fl. across from rm#334 | 8/30/13 | | | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace floor tile on the 3rd.fl. southeast hallway. 4 pieces 12x12in has come lose from floor. Trip Hazard. | 9/4/13 | Hallway/Corridor | 3rd. fl. east southeast hallway | Carpentry |

| | | | | | |
|-------------------|---|---------|-----------|--|-----------|
| East HS (2180) 2A | Please allow carpenters to come out and replace cove base in classroom. RM# listed above. | 9/26/13 | Classroom | RM#301/302/304/339/327/326/325/323/322/320 | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and replace white board in classroom 339. | 9/26/13 | Classroom | RM#339 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace floor tile in classroom 320. | 9/26/13 | Classroom | RM#320 | Carpentry |
| East HS (2180) 2A | Ceiling falling. | 9/26/13 | Classroom | Rm#214 | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and secure drop ceiling in two places in the cafeteria area main entry. ceiling grid is sagging. | 10/1/13 | Cafeteria | cafeteria | Carpentry |
| East HS (2180) 2A | ENTRANCE DOOR BY AUDITORIUM-LATCH STICKING & LIBRARY ENTRANCE TO THE OUTSIDE-LATCH STICKING PER SBE-PLANT MGR HAMER 416-6175 KLR | 10/4/13 | | | Carpentry |
| East HS (2180) 2A | DROP CEILING TILE IS HANGING FROM CEILING IN RM-214 PLANT MGR- HAMER/650.9273 | 10/8/13 | | | Carpentry |
| East HS (2180) 2A | Please allow a sheetmetalst to come out and repair steps that lead to teachers parking lot. Step give way when walking up the steps. Deterioration of metal plates that secure steps. | 9/12/13 | | rear exit to teacher parking lot | Carpentry |

| | | | | | | |
|-------------------|--|----------|-----------|---------------------------------|--|-----------|
| East HS (2180) 2A | DOOR LEADS INTO TUNNEL CANT SECURE BY PLANT MGR OFFICE PLANT MGR- HAMER/416.6960 | 9/19/13 | | | | Carpentry |
| East HS (2180) 2A | Broken door lock on entrance door beside auditorium, hard to lock. | 9/19/13 | 2nd Floor | | | Carpentry |
| East HS (2180) 2A | Door lock broke, classroom door will not lock. | 12/18/13 | Classroom | Rm#310 | | Carpentry |
| East HS (2180) 2A | Request wood be painted. | 1/9/14 | | | | Carpentry |
| East HS (2180) 2A | BACK METAL STAIRS IS SINKING IN BY PARKING LOT AREA. PLANT MGR- HAMER/650.9273 | 1/14/14 | | | | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and install 2 4x6 white board in classroom 211 and the srem lab 1st. fl. Please see plant manager for exact location. (WHITE BOARDS ARE ON SITE). | 1/14/14 | Classroom | Rm 211 and the Stem lab 1st fl. | | Carpentry |
| East HS (2180) 2A | Metal steps are badly rusted out, safety hazard. | 1/16/14 | Stairway | Outside East end | | Carpentry |
| East HS (2180) 2A | Please allow carepenters to come and change out ceiling tile that is surroundd by sprinkler head in the these classrooms. RM# 202/203/211/301/331. | 10/8/13 | Classroom | RM#202/203/211/301 /331 | | Carpentry |

| | | | | | |
|-------------------|---|----------|-----------|---------------------------|-----------|
| East HS (2180) 2A | Pleas allow a carpenter to come out and repair or replace panic ware on north east door on the 3rd fl. Panic ware is detached from door frame | 10/18/13 | Stairway | south east stairwell door | Carpentry |
| East HS (2180) 2A | Pleas allow a carpenter to come our and replace window seal wood trim. Wood trim has termite dammage | 10/18/13 | Classroom | 217 | Carpentry |
| East HS (2180) 2A | WINDOW ON THE REAR ENTRANCE TO BLDG-IS COMPLETELY OUT, WON'T STAY IN-PLANT MGR HAMER 416-6175 KLR | 10/23/13 | | | Carpentry |
| East HS (2180) 2A | WINDOW HAS CAME COMPLETELY OUT IN RM-303 PLANT MGR-HAMER/650.9273 | 10/31/13 | | | Carpentry |
| East HS (2180) 2A | Please allow a carpentr to come out and hang frames on the gym walls that have East High athletic jersys inside of frames. | 11/5/13 | Gym | Gym | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace floor tile in the clinic hear at East. About 6 to 8 pieces of floor tile has rust all over tile. | 11/7/13 | | Clinic | Carpentry |
| East HS (2180) 2A | WINDOW PANE CRACKED AND ABOUT TO FALL PER SBE RM 203 2ND FLR-PLANT MGR HAMER-416-6160 KLR | 11/12/13 | | | Carpentry |
| East HS (2180) 2A | Replace broken window glass. | 11/14/13 | Classroom | Rm#216 | Carpentry |

| | | | | | |
|-------------------|--|----------|------------------|-----------------------------|-----------|
| East HS (2180) 2A | Please allow a carpenter to come out and repair fire door retracting arm. Arm is broke in half. | 11/19/13 | | 1st. fl. down by the clinic | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace wheels on coaches score board table. Table about 6. ft. long. | 11/21/13 | Gym | Gym storage | Carpentry |
| East HS (2180) 2A | Please allow an electrician to come out and install 2 6x6 white board. in classroom 211. | 11/25/13 | | RM# 211 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and secure stall door. Door has come off the hinges. | 11/26/13 | Restroom (Boys) | 3rd. fl. annex | Carpentry |
| East HS (2180) 2A | Replace missing baseboard strips(cold base). | 8/12/13 | Hallway/Corridor | 2nd floor | Carpentry |
| East HS (2180) 2A | Replace broken and missing floor tiles. | 8/13/13 | Classroom | Rm#328 | Carpentry |
| East HS (2180) 2A | Replace missing baseboard strips(cold base). | 8/13/13 | Classroom | Rm#328 | Carpentry |
| East HS (2180) 2A | Replace broken and missing floor tiles. | 8/13/13 | Classroom | Rm#132 | Carpentry |

| | | | | | |
|-------------------|--|---------|-----------|---|-----------|
| East HS (2180) 2A | Please allow a carpenter to come out and replace floor tile in classroom 328. About 8 to 9 floor tile missing. | 8/14/13 | Classroom | RM# 328 | Carpentry |
| East HS (2180) 2A | Replace missing baseboard strips(cold base),also broken glass window in classroom. | 8/14/13 | Classroom | Rm#325 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace window pain in room 325. window pain has several cracks in it | 8/15/13 | Classroom | RM 325 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace cove base in classroom and to remove old white board and replace with new one. | 8/15/13 | Classroom | RM# 325 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and install pad lock latch to the weight room interior door. Principal request do to the incident that accured on 8-14-13 in the weight room. | 8/16/13 | | weight Room 1st .fl. south west end of building | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replase door closer to door. The door closer is missing, so door will not close when entering/exiting building. Security risk, door is always | 8/16/13 | | 1st. fl. clinic area leading to parking lot | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace door knob to door inside of room 304. the door in need of door knob is located in the back rooms. | 8/20/13 | Classroom | 304 | Carpentry |
| East HS (2180) 2A | In need of 4 cases of hard ceiling tile here at East High. | 8/21/13 | | Building Managers office | Carpentry |

| | | | | | |
|-------------------|---|---------|---------------------|--|-----------|
| East HS (2180) 2A | Ceiling has fallen. | 8/22/13 | Classroom | Rm#304 | Carpentry |
| East HS (2180) 2A | Replace missing door closer on 1st floor outside exit door west end of building, hard to keep door secured, per E. Harris (ASAP). | 8/22/13 | | | Carpentry |
| East HS (2180) 2A | DOOR WONT CLOSE BEHIND CLINIC NORTHWEST-END, CANT SECURE PLANT MGR- HAMER/416.6175 | 8/23/13 | | | Carpentry |
| East HS (2180) 2A | Remove wall in the band room. | 8/23/13 | | | Carpentry |
| East HS (2180) 2A | Please allow carpenter to come out and replace cove base in the attendance office and main office are where the mail boxes are. | 8/23/13 | Administration Area | Attendance office and main office area | Carpentry |
| East HS (2180) 2A | Ceiling has fallen. | 8/23/13 | Classroom | Rm#102 | Carpentry |
| East HS (2180) 2A | Install heavy duty toilet paper holders in girls and boys restrooms, students are kicking toilet paper holders off. | 8/23/13 | Gym | Locker Rooms | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace ciling tile that has sprinkler heads, in the main office area and main office. | 8/27/13 | Administration Area | main office and cafeteria | Carpentry |

| | | | | | |
|-------------------|--|---------|-----------|--|-----------|
| East HS (2180) 2A | The glass in this door is cracked and needs to be replaced in this room. | 7/29/13 | 3rd Floor | #323 | Carpentry |
| East HS (2180) 2A | carpenter to come out and replace windowpane in theater room. Big safety infraction. | 8/8/13 | | theater Room 304 | Carpentry |
| East HS (2180) 2A | Replace all ceiling tiles, bad water damage fallen ceiling tiles. | 8/8/13 | 3rd Floor | Rm#304 | Carpentry |
| East HS (2180) 2A | Broken glass window. | 8/8/13 | 3rd Floor | Rm#304 | Carpentry |
| East HS (2180) 2A | There is a broken window in this stairwell that needs to be replaced or repaired asap!!! | 7/29/13 | 3rd Floor | #301 Southwest Stairwell | Carpentry |
| East HS (2180) 2A | There is a cracked window in this room that needs to be repaired or replaced. | 7/29/13 | 1st Floor | #100 | Carpentry |
| East HS (2180) 2A | The access door to the main hall is not working properly. It needs to be repaired or replaced. | 7/29/13 | Cafeteria | Cafe Managers Office Door to Main Hall | Carpentry |
| East HS (2180) 2A | The double doors in this area needs to be repaired or replaced in the serving line. | 7/29/13 | Cafeteria | Serving Line | Carpentry |

| | | | | | |
|-------------------|---|---------|---------------------|----------------------------|-----------|
| East HS (2180) 2A | The door to this office needs to be repaired or replaced or adjusted so that it will open properly as it should. | 7/29/13 | 2nd Floor | Cafe Manager's Door | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace cove base in Rm# 307. | 7/31/13 | Classroom | Rm# 307 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and install a security plate over door latch to room 312. Door can be open using a flat object. | 7/11/13 | | Room 312 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and replace cove base in the main office and rm# 107. | 7/11/13 | | Main office and room 107 | Carpentry |
| East HS (2180) 2A | There is a door in this area that is not closing properly. The door closure is not latching when the door is being closed. | 7/16/13 | Administration Area | Main Office | Carpentry |
| East HS (2180) 2A | There is a need to have the chalk boards and dry erase boards removed from the walls in this room. This room is being converted to a parent resource center. The principal would like to have this done ASAP if possible. | 7/26/13 | 2nd Floor | 213 | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and repair panic ware to fire door. 2nd floor next to auditorium | 7/8/13 | | 2nd fl. next to auditorium | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and remove white board from security office. | 7/11/13 | | security office | Carpentry |

| | | | | | |
|-------------------|--|----------|-----------------|--|------------|
| East HS (2180) 2A | Please allow a carpenter to come out and repair door to women coach office in gym. (door handel, door lock and door it self are damaged. | 7/11/13 | | womens track coach office in gym | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and repair panic ware to fire door. 3rd.fl. next to rm#335/ next to rm#317 | 7/11/13 | | | Carpentry |
| East HS (2180) 2A | Need welder to weld tabs back on to dumpster to attach dumpster lids to. | 2/7/14 | | | Carpentry |
| East HS (2180) 2A | Please allow a carpenter to come out and restrig cable to motorized curtain machine. (Cable is off track) | 12/10/13 | | Auditorium Stage | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and install grab bars in the boys and girls restroom stall. on the 2nd. and 3rd. fl. East and West ends of building. Federal OCR Regulation has give | 1/7/14 | | 2nd and 3rd. fl. restrooms East And West End | Carpentry |
| East HS (2180) 2A | Please allow carpenters to come out and replace cove base in these class rooms. RM#214/215/216/218/219/213/220/221/205/204/202/206/208/209. | 10/8/13 | | Rm#214/215/216/218/219/213/220/221/204/205/202/209 | Carpentry |
| East HS (2180) 2A | Please allow carpenter to come out and repair or replace doors to chiler room. doors are easly pulled open when locked Anthony Crone request that removable center piece be put in plase | 8/8/13 | Mechanical Room | | Carpentry |
| East HS (2180) 2A | Replace two burnt out ceiling lights, high ceiling. | 6/24/14 | Gym | Girl's Coach office | Electrical |

| | | | | | |
|-------------------|---|---------|-----------------|------------------------|------------|
| East HS (2180) 2A | Please deliver 3 cases of rapid start slim lights. All so needed Sylvania M400/u/BT28 Metalarc bulb 400 watts. Please provide the shorter bulb. | 4/5/14 | | Plant Managers Office | Electrical |
| East HS (2180) 2A | Replace broken ceiling light cover. | 4/15/14 | Restroom (Boys) | 2nd fl. east end | Electrical |
| East HS (2180) 2A | Replace two broken globe ceiling lights. | 4/15/14 | Gym | | Electrical |
| East HS (2180) 2A | Stage lights not working properly. | 5/23/14 | Auditorium | | Electrical |
| East HS (2180) 2A | Replace broken ceiling light cover. | 5/27/14 | Classroom | Rm#212 | Electrical |
| East HS (2180) 2A | A/C UNIT is NOT COMING ON in ROOM 213 per Ms. White, Plant Mgr. 416.6341 | 5/27/14 | | | Electrical |
| East HS (2180) 2A | Please allow a tech to come out and replace the fire alarm/light cover. Cover is missing. | 6/10/14 | | Out side of auditorium | Electrical |
| East HS (2180) 2A | UNIT NOT COMING ON IN PRIN OFFICE. PLANT MGR- HAMER/650.9273 | 6/13/14 | | | Electrical |

| | | | | | |
|-------------------|--|---------|--|---|------------|
| East HS (2180) 2A | FIRE ALARM IS SHOWING IN TROUBLE ON 2ND FLR PLANT MGR- HAMER/650.9273 | 4/28/14 | | | Electrical |
| East HS (2180) 2A | Please deliver 3 cases of rapid start slim lamps. | 5/3/14 | | Plant Managers Office | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace ballast to 3 different light fixtures on the 3rd . fl. west in front of rm# 300 and 313 also in front of handicap boys restroom. 2nd request | 4/5/14 | | 3rd. fl. west in front of RM#300 and 313 and hall | Electrical |
| East HS (2180) 2A | UNIT NOT COMING ON IN RM-320,325,328 PLANT MGR- THOMAS/650.9273 | 3/6/14 | | | Electrical |
| East HS (2180) 2A | Please allow electrician to come out and replace light fixture in gym. Fixture is damaged, also allow lights to be replaced in gym area as well. (lift needed) | 3/6/14 | | Gym | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace exit sign inside of weight room. sign has been destroyed. 3rd request. | 2/28/14 | | weight room 1st floor | Electrical |
| East HS (2180) 2A | Please deliver 3 cases of rapid start lights for East High and 3 cases for Lesater Middle. | 3/17/14 | | Plant managers office | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace ballast in the hallways. hallway in front of 213 and 3rd. fl. north west end hallway. | 3/19/14 | | in front of 213 and 3rd. fl north west end by | Electrical |

| | | | | | |
|-------------------|---|---------|------------------|-----------------------|------------|
| East HS (2180) 2A | LIGHTS ELEVATOR MAIN BLDG-NOT COMING ON-PLANT MGR HAMER 416-6175 KLR | 3/25/14 | | | Electrical |
| East HS (2180) 2A | Ceiling light out,bad ballast. | 3/25/14 | Clinic | Girl's restroom | Electrical |
| East HS (2180) 2A | Replace broken ceiling light cover. | 3/25/14 | Clinic | | Electrical |
| East HS (2180) 2A | Ceiling light out, bad ballast. | 3/25/14 | Restroom (Girls) | 2nd floor east end | Electrical |
| East HS (2180) 2A | NO POWER TO LIGHTS IN RM-305,306,307 PLANT MGR-HEARD/416.6160 | 3/31/14 | | | Electrical |
| East HS (2180) 2A | GRAFITTI - 3RD B RR - ON STALLS & WALL - GANG RELATED PM/HAMER 416-6175 | 1/21/14 | | | Electrical |
| East HS (2180) 2A | RTU GYM AREA-NOT COMING ON-PLANT MGR HAMER 416-6175 KLR | 1/24/14 | | | Electrical |
| East HS (2180) 2A | Please deleiver 3 cases of rapid strat lamps. | 2/5/14 | | Plant managers office | Electrical |

| | | | | | |
|-------------------|--|---------|------------------|--|------------|
| East HS (2180) 2A | per mr hamer 416-6175 the fire alarm system is showing trouble and the lights keep flashing | 2/7/14 | | | Electrical |
| East HS (2180) 2A | Ceiling light out, bad ballast. | 2/10/14 | Restroom (Girls) | 2nd floor west end | Electrical |
| East HS (2180) 2A | COOLING TOWER HAS A BELL RINGING IN IT-SBE THINKS IT'S AN ALARM GOING OFF-PLANT MGR HAMER 416-6175 KLR | 2/11/14 | | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace magnetic door holder magnetic door holders are missing. Cant keep open fire doors. | 2/14/14 | | Main allway fire door and 3rd. fl. fire door | Electrical |
| East HS (2180) 2A | ELECTRICAL BURNING SMELL IN 2ND FLR RM 206, LIBRARY, & RM 106 PER SBE-PLANT MGR HAMER 416-6175 KLR | 8/29/13 | | | Electrical |
| East HS (2180) 2A | Five burnt out ceiling lights, high ceiling. | 9/5/13 | Library | | Electrical |
| East HS (2180) 2A | 3RD FLR NORTH END WHERE ROOF LEAK IS- WATER LEAKED IN FIXTURE AND SHORTED IT OUT PER SBE-PLANT MGR HAMER 416-6175 KLR | 9/23/13 | | | Electrical |
| East HS (2180) 2A | Please deliver 50 or 2 boxes of fluorescent rapid start lamps to East High. | 9/25/13 | | SBE's office | Electrical |

| | | | | | |
|-------------------|---|----------|-----------------|--------------------------------------|------------|
| East HS (2180) 2A | Please allow an electrician to come out and replace a light fixture in the kitchen area. Requested by (Health Department). | 9/26/13 | Cafeteria | kitchen | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and secure light cove on the outside of chiller room. Lift truck needed. | 9/26/13 | | | Electrical |
| East HS (2180) 2A | Two ceiling lights out, bad ballast. | 9/26/13 | Restroom (Boys) | Gym Locker room | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace ballast in the cafeteria dining area and in r in the CTC building RM# 138 storage closet. | 10/1/13 | Cafeteria | dinning area | Electrical |
| East HS (2180) 2A | Please allow an electrician to deliver 3 cases of fluorescent rapid start lights to East for East High and Lester Middle | 10/1/13 | | SBE's office | Electrical |
| East HS (2180) 2A | UV NOT COMING ON IN RM 319 PLANT MGR- HAMER/650.9273 | 10/2/13 | | | Electrical |
| East HS (2180) 2A | Please allow electricians to come out and replace lights in light fixtures in stairwell. This job requires a ladder that is over 12ft. tall and two men for safety reasons. | 12/11/13 | | North East and South East Stairwells | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace damaged wall receptacle. 3rd. fl. North West End 20ft. before northwest stairway. | 12/11/13 | | 3rd. fl. North West End | Electrical |

| | | | | | |
|-------------------|--|----------|-----------|-----------------------|------------|
| East HS (2180) 2A | in the votech the stem lab no heat not coming on per Ms. Mallory 416-6160 | 12/13/13 | | | Electrical |
| East HS (2180) 2A | FIRE ALARM SHOWING TROUBLE PER SBE-PLANT MGR HAMER 416-5960 KLR | 1/6/14 | | | Electrical |
| East HS (2180) 2A | Please deleiver 3 cases of rapid start lamps to East | 1/9/14 | | plant managers office | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and set clocks in CTC building. | 1/15/14 | | CTC building | Electrical |
| East HS (2180) 2A | Light out in stairway, between band room and auditorium, high ceiling. Safety hazard. | 10/14/13 | Stairway | Band room | Electrical |
| East HS (2180) 2A | Ceiling light out, bad ballast. | 10/14/13 | Classroom | Rm#304 | Electrical |
| East HS (2180) 2A | LIGHT HAVE NO POWER THRU ENTIRE EAST-END STAIRWAY 2ND-1ST FLR PLANT MGR- HAMER/650.9273 | 10/16/13 | | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and install additional lighting in the conference room here at East, only light source in this area is light from a ceiling fan in room. | 10/16/13 | | conference room | Electrical |

| | | | | | | |
|-------------------|---|----------|------------------|--|-----------------------------|------------|
| East HS (2180) 2A | LIGHTS RM 108-NOT COMING ON-DARK IN RM PER SBE-PLANT MGR HAMER 416-6175 KLR | 10/24/13 | | | | Electrical |
| East HS (2180) 2A | Please deliver 3 cases of rapid start tubes. East High | 10/25/13 | | | Plant managers office | Electrical |
| East HS (2180) 2A | auditorium lights blinking and there is something in there tomorrow night per Mr. Hamer 416-6160 | 11/11/13 | | | | Electrical |
| East HS (2180) 2A | Please deliver 3 cases of rapid start lights (tube). | 11/12/13 | | | Plant managers office | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and secure smoke detector to ceiling tile. (smoke detector hangs). | 11/12/13 | Hallway/Corridor | | 1st. fl. west end | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out an repair exit sign and emergency light. lighting on the third fl. west end. | 11/12/13 | | | 3rd. fl. west end | Electrical |
| East HS (2180) 2A | please allow an electrician to come out and repair exit sign and emergency lighting. 1st. fl. west by clinic. | 11/12/13 | | | 1st. fl. west end by clinic | Electrical |
| East HS (2180) 2A | in the auditorium, when the breaker to sound system is turned on, the lights go out, when the breaker to turn lights on, sound system goes out and they are having something in auditorium tonight per mr hamer 416 | 11/12/13 | | | | Electrical |

| | | | | | |
|-------------------|---|----------|------------------|-------------------------------|------------|
| East HS (2180) 2A | BELLS NOT RINGING AT ALL-PLANT MGR HAMER 416-6175 KLR | 11/15/13 | | | Electrical |
| East HS (2180) 2A | Please deliver 3 cases of rapid start lamps to East High. | 11/19/13 | | Plant managers office | Electrical |
| East HS (2180) 2A | RTU NOT COMING ON IN GYM PLANT MGR-HAMER/416-6175 | 11/21/13 | | | Electrical |
| East HS (2180) 2A | Air Handler unit in MAIN OFFICE is NOT COMING ON per Mr. Hamer, Plant Mgr. 416.6175 | 12/9/13 | | | Electrical |
| East HS (2180) 2A | UNIT NOT COMING ON IN RM-212 PLANT MGR-HAMER/650.9273 | 12/10/13 | | | Electrical |
| East HS (2180) 2A | FCU 3RD FLR EAST WING RM 331-SMOKING-SBE HAMER 416-6175 KLR | 8/14/13 | | | Electrical |
| East HS (2180) 2A | Replace burnt out ceiling lights , very high ceiling. | 8/14/13 | Stairway | 3rd floor | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and repair/replace exit, smoke detectors and emergence lighting in the area that want illuminate doing test. (3rd. fl. west end)2nd. fl. by trophy case | 8/16/13 | Hallway/Corridor | 3rd. fl. west end of building | Electrical |

| | | | | | |
|-------------------|--|---------|-----------|-----------------------------------|------------|
| East HS (2180) 2A | A/C IN RM 331 3RD FLR- NOT COMING ON-SBE HAMER 416-6175 KLR | 8/20/13 | | | Electrical |
| East HS (2180) 2A | Seven ceiling lights burnt out, very high ceiling. | 8/20/13 | Gym | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and install a clock on each side of gym. | 8/21/13 | Gym | gym | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and install eletrical outlets for metal detectors on the east end of building. No out let in foyer to use. Requested by risk managements Eric Thomas | 8/21/13 | | | Electrical |
| East HS (2180) 2A | Install clock in gym, coaches need to monitor time. | 8/21/13 | Gym | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace light pole light cover. Cover is missing. | 8/22/13 | | North wall outside of gym area | Electrical |
| East HS (2180) 2A | Two ceiling lights out, bad ballast. | 8/22/13 | 2nd Floor | Teacher's Lounge | Electrical |
| East HS (2180) 2A | Two ceiling lights out in front of room#300, bad ballast. | 8/26/13 | 3rd Floor | | Electrical |

| | | | | | |
|-------------------|---|---------|------------------|--------------------------|------------|
| East HS (2180) 2A | Ceiling light out, bad ballast. | 8/26/13 | Classroom | Rm#304 | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and deliver 75 rapid start lamps to East High. For Lester Middle and East High | 8/27/13 | | building managers office | Electrical |
| East HS (2180) 2A | Please deliver 100 flr. rapid start bulbs to east high. | 8/12/13 | | Building Managers office | Electrical |
| East HS (2180) 2A | BURNING SMELL IN KITCHEN SERVING LINE DOESN'T KNOW WHAT IT IS-PER SBE, BREAKER TRIPPED AND HE DIDN'T RESET DUE TO THE SMELL-SBE HAMER 416-6166115 | 8/8/13 | | | Electrical |
| East HS (2180) 2A | Replace burnt out ceiling lights and missing light cover in front entrance foyer, very high ceiling. | 8/8/13 | 2nd Floor | Front entrance | Electrical |
| East HS (2180) 2A | Replace battery in defibrillator, constantly beeps. | 8/8/13 | Hallway/Corridor | 2nd floor | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and replace light on the stage and in the auditorium. Very few lights are working in the and the principal is planning for an event in the coming week. Thanks | 8/9/13 | Auditorium | Strage and Auditorium | Electrical |
| East HS (2180) 2A | The exit sign in this area is missing and needs to be replaced asap!!!! | 7/29/13 | 3rd Floor | #311 | Electrical |

| | | | | | |
|-------------------|--|---------|---------------------|----------------------------------|------------|
| East HS (2180) 2A | Please deliver to East High 100 flr.ripid start lamps. | 8/1/13 | | send to building managers office | Electrical |
| East HS (2180) 2A | FCU ZONE 18 3RD FLR EAST WING RM 322-NOT COMING ON-SBE HAMER 416-6175 KLR | 8/6/13 | | | Electrical |
| East HS (2180) 2A | BREAKER BOX KEEPS TRIPPING IN KITCHEN AREA. PLANT MGR- HAMMER/416.6660 | 8/7/13 | | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and repair emegency exit signs and lighting that failed test in auditorium. (west side of stage area/ west side of auditorium the east side of auditorium and east side of | 8/7/13 | | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and repair rubber covering that cover wires that feeds electricity to door magnetic door holders for fire doors. (exsposed wires. 3rd.fl. next to room 310 and on the other side of 310) | 7/11/13 | | | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and repair/replace exit sign next to room 300. Exit sign has been destroyed by students. | 7/11/13 | | next to Rm 300 | Electrical |
| East HS (2180) 2A | The bell system needs to be reset for the school year for the new bell schedule for the new adjusted school hours. | 7/23/13 | Administration Area | Main Office | Electrical |
| East HS (2180) 2A | Please allow an electrician to come out and install flood or high intensity lights over 8 firing lanes that are being ready for a firing range for JROTC. lights must be 8 feet off the floor to illuminate target. (This might need to be | 7/8/13 | | Auto mechanic area | Electrical |

| | | | | | |
|-------------------|---|---------|--|--|---------------------------------------|
| East HS (2180) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | CHILLER IS IN ALARM PLANT MGR-HAMER/650.9273 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | CHILLER #2 IN ALARM - & PUMP #4 IS NOT RUNNING - PM/HAMER 650-9273 | 4/24/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | per mr hamer 416-6175 the chiller is not running it is in alarm and also pump #70 is in alarm | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | A/C LIBRARY & GYM AREA- BOTH NOT COOLING- PLANT MGR MALLORY 416-6160 KLR | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | CHILLERS NOT COMING ON IN MAIN BLDG & ANNEX PLANT MGR-HAMER/650.9273 | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | CHILLER-2 MECH RM-IN ALARM-PLANT MGR HAMER 416-6175 KLR | 6/10/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | supply chemical | 3/31/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------|--|----------|--|--|---------------------------------------|
| East HS (2180) 2A | HEAT MAIN OFC AREA- NOT HEATING-PLANT MGR HAMER 416-6175 KLR | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | per mr hamer 416-3960 the gym has no heat | 1/30/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | HEAT PRIN'S OFC-NOT HEATING-PLANT MGR HAMER 416-6175 KLR | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | RTU NOT HEATING IN GYM PLANT MGR- HAMER/650.9273 | 2/18/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | A/C IN 329-NOT COOLING- PLANT MGR HAMER 416- 6175 KLR | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Chiller is in ALARM per Thomas Hamer, Plant Mgr. 416.6175 | 9/27/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | main office blowing cold air per Ms. Mallory 416-6160 | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | RTU RM 212-NOT HEATING- PLANT MGR HAMER 416- 6175 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------|---|----------|--|--|--|
| East HS (2180) 2A | Monthly - Oil Lube & Belt- East High - Refer to PM schedule details. | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | UNIT NOT HEATING IN G/LOCKER RM GYM PLANT MGR- HAMER/650.9273 | 1/17/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | 2-RTU NOT HEATING IN 211,212. PLANT MGR- HAMER/650.9273 | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | 3-BOILERS NOT HEATING PLANT MGR- HAMER/650.9273 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | RTU NOT HEATING IN B/LOCKER RM. PLANT MGR- HAMER/650.9273 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Unit B in the LIBRARY is NOT HEATING per Mr. Hamer, Plant Mgr. 416.6175 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Pump #3 is in ALARM per Mr. Hamer, Plant Mgr. 416.6175 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | BOILER is in ALARM per Mr. Hamer, Plant Mgr. 416.6175 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------|---|---------|--|--|---------------------------------------|
| East HS (2180) 2A | FCU 3RD FLR WEST WING RM 313-NOT COOLING-SBE HAMER 416-6175 KLR | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | chiller is down per Thomas Hamer 416-6175 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | A/C IN RM 329-NOT COOLING-SBE HAMER 416-6175 KLR | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | FCU NOT COOLING IN RM-329 PLANT MGR-HAMER/416.6175 | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | FCU IN RM 331 SMOKING., E138 IS NOT COOLING SBE ARNOLD. 416-8574 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Air Handler units in Rooms 322 & 325 NOT COMING per Thomas Hamer, Plant Mgr. at 901.416.6175. | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Chiller down per EMS 7.2.13 | 7/14/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | CHILLER - NOT COMING ON - SBE/HAMMER 416-6175 | 7/5/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------|---|---------|--|-----------|---------------------------------------|
| East HS (2180) 2A | Please allow HVAC tech to come out and install an exsaut system in the band room the room is equipped with an heating and air system but no ventalation system to pull out stagnant air. This will help us keep the | 8/1/13 | | Band room | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Yearly - Oil Samples-East High - Refer to PM schedule details. | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Monthly - Filter-East High - Refer to PM schedule details. | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Monthly - Filter-East High - Refer to PM schedule details. | 1/20/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Daily - East High Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Monthly - EAST HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Yearly - Cooling Towers (STRAINERS)-East High - Refer to PM schedule details. | 3/10/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Yearly - Water Cool Chiller Filter-East High - Refer to PM schedule details. | 2/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------|---|---------|-----------|----------|---------------------------------------|
| East HS (2180) 2A | Monthly - Filter-East High - Refer to PM schedule details. | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| East HS (2180) 2A | Please allow a painter to come out and remove paint from classroom door window. Room334 | 7/11/13 | Classroom | room 334 | Painting |
| East HS (2180) 2A | This classroom is in bad need of painting. The principal would like to have this room painted asap!!!! | 7/29/13 | 3rd Floor | #333 | Painting |
| East HS (2180) 2A | Theater room ceiling and walls need to be re-painted black. | 8/8/13 | 3rd Floor | Rm#304 | Painting |
| East HS (2180) 2A | Disregard work request #372879. Instead re-paint ceiling and walls to original color. | 8/9/13 | 3rd Floor | Rm#304 | Painting |
| East HS (2180) 2A | There is a need to have this room painted. This room is being converted to a parent resource center. The principal would like to have this done ASAP if at all is possible. | 7/26/13 | 2nd Floor | 213 | Painting |
| East HS (2180) 2A | Re-paint classroom walls, badly chipped. | 8/9/13 | Classroom | Rm#318 | Painting |
| East HS (2180) 2A | Re-paint wall, water damage, plaster cracked and coming off wall. | 8/12/13 | 3rd Floor | Foyer | Painting |

| | | | | | |
|-------------------|--|---------|--|--------------------------|----------|
| East HS (2180) 2A | Please deliver 2 cans of kilz for ciling tile that have small water spots. | 8/27/13 | | building managers office | Painting |
| East HS (2180) 2A | Please allow paint department to come out and paint the weight room here at East High, if possible please paint a dark red or burgundy for this color will help hide finger prints and sweat stains that are left behind after | 2/28/14 | | weight room 1st floor | Painting |
| East HS (2180) 2A | Please allow painters to come out and paint a section of wall where chairs that rest on wall has rubbed the paint away. Clinic Area. | 4/5/14 | | clinic area | Painting |
| East HS (2180) 2A | GRAFFITI HALL WEST-END WALLS HALL 3RD FLR PLANT MGR- HAMER/65.9273 | 4/7/14 | | | Painting |
| East HS (2180) 2A | Paint the new stairs at rear of Main Building. | 5/2/14 | | | Painting |
| East HS (2180) 2A | GANG GRAFFITI B RR 2ND FLR EAST ON STALLS & METAL DOOR, B RR 3RD FLR WEST ON STALLS, G RR 2ND FLR EAST ON STALLS AND BLOCK WALLS & LIBRARY REAR METAL DOOR PLANT MGR | 3/25/14 | | | Painting |
| East HS (2180) 2A | GANG GRAFFITI NE STAIRWELL 3RD FLR ON BLOCK WALLS AND METAL DOORS-PLANT MGR HAMER 416-6175 KLR | 1/23/14 | | | Painting |
| East HS (2180) 2A | GANG GRAFFITI IN 3RD FLR NE STAIRWELL ON BLOCK WALL & METAL DOOR-PLANT MGR HAMER 416-6175 KLR | 9/23/13 | | | Painting |

| | | | | | |
|-------------------|---|----------|--|-------------|----------|
| East HS (2180) 2A | GRAFFITI ON STAIRWAY DOOR WEST-END 1ST FLR PLANT MGR- HAMER/650.9273 | 9/24/13 | | | Painting |
| East HS (2180) 2A | GRAFFITI 2ND FLR EAST END HALL ON METAL DOOR-PLANT MGR WHITE 416-6160 KLR | 9/24/13 | | | Painting |
| East HS (2180) 2A | Please allow painters to come out and paint in the parent center. White boards were removed leaving two diffrent shades of color in parent center. | 9/26/13 | | | Painting |
| East HS (2180) 2A | GRAFFITI SW STAIRWELL ON METAL DOORS-PLANT MGR HAMER 416-6175 KLR | 9/11/13 | | | Painting |
| East HS (2180) 2A | plse paint walls in rifle range | 9/16/13 | | | Painting |
| East HS (2180) 2A | GRAFFITI G RR 3RD FLR ON STALLS & WALLS, EAST STAIRWELL 2ND & 3RD FLRS ON WALLS, & GYM METAL DOORS 3RD FLR HALL-PLANT MGR HAMER 416-6175 KLR | 1/7/14 | | | Painting |
| East HS (2180) 2A | boys restroom 2nd floor graffiti inside and on doors (across from attendance office) also northeast stairwell on 3rd floor on doors per Mr. Hamer 416- 6175 | 10/18/13 | | | Painting |
| East HS (2180) 2A | Please allow team to come out and replaster wall in clinic area and paint. Wood framing is exposed. | 10/25/13 | | Clinic area | Painting |

| | | | | | |
|-------------------|---|----------|--|--|----------|
| East HS (2180) 2A | GANG GRAFFITI GYM AREA ABOVE BLEACHERS ON WALL-PLANT MGR HAMER 416-6175 KLR | 10/25/13 | | | Painting |
| East HS (2180) 2A | GRAFFITI ON LOCKERS 2ND FLR WEST-END BY RM-205. PLANT MGR- HAMER/650.9273 | 11/5/13 | | | Painting |
| East HS (2180) 2A | GRAFFITI IN HALL OUTSIDE RM 313 ON BLOCK WALL & 2ND & 3RD PLATFORMS IN STAIRWELL PER SBE- PLANT MGR HAMER 416- 6175 KLR | 11/15/13 | | | Painting |
| East HS (2180) 2A | Gang graffiti on the walls in the Boy's RR on the 2nd floor E. end per Mr. Hamer, Plant Mgr. 416.6175 | 12/3/13 | | | Painting |
| East HS (2180) 2A | GRAFFITI ON DOOR G/RR 3RD FLR WEST. PLANT MGR- HAMER/416.6175 | 8/20/13 | | | Painting |
| East HS (2180) 2A | Graffiti in girls restroom 3rd floor west end per Ms. Mallary 416-6160 | 8/20/13 | | | Painting |
| East HS (2180) 2A | Please allow a carpenter to come out and resurface plaster on wall in the library. South exit in library. | 8/22/13 | | | Painting |
| East HS (2180) 2A | GANG GRAFFITI IN STAIRWELL ACROSS FROM LIBRARY ON WEST BLOCK WALL-SBE HAMER 416-6160 KLR | 8/8/13 | | | Painting |

| | | | | | | |
|-------------------|--|---------|-----------------|------------------------------------|--|----------|
| East HS (2180) 2A | GRAFFITI ON 1ST STAIRWAY WEST-END. PLANT MGR-MALLARY/416.6160 | 8/9/13 | | | | Painting |
| East HS (2180) 2A | Please allow painters to come out and walls an off white (egg shell or similar color in). Paint 8 lane for firing range (colocr red) exactly 10 meters from target stand. Would like to have work completed before the | 7/8/13 | | Portion of the auto mechanics shop | | Painting |
| East HS (2180) 2A | A/C RM 209-LEAKING-PLANT MGR WHITE 416-6160 KLR | 6/24/14 | | | | Plumbing |
| East HS (2180) 2A | PIPE RM 203-LEAKING-PLANT MGR WHITE 416-6160 KLR | 6/26/14 | | | | Plumbing |
| East HS (2180) 2A | Ceiling light out, bad ballast. | 4/17/14 | Restroom (Boys) | 3rd fl. east end | | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 5/27/14 | Restroom (Boys) | 2nd fl. west end | | Plumbing |
| East HS (2180) 2A | CEILING UNIT IS LEAKING WATER IN LIBRARY. PLANT MGR-HAMER/650.9273 | 5/29/14 | | | | Plumbing |
| East HS (2180) 2A | WATER FAUCET OUTSIDE FRONT OF BLDG-STRIPPED AND CAN'T CUT OFF, WATER RUNNING AT FULL FORCE-PLANT MGR WHITE 416-6160 KLR | 5/30/14 | | | | Plumbing |

| | | | | | |
|-------------------|---|---------|-----------------|-----------------------|----------|
| East HS (2180) 2A | Replace outside water spigot, stripped. | 5/30/14 | Grounds | Front of school bldg. | Plumbing |
| East HS (2180) 2A | Please allow plumbers or pipe fitter to come out and repair leaking hot water return pipe in tunnel area. Piping has a leak that needs repairing. | 6/3/14 | | Tunnel area | Plumbing |
| East HS (2180) 2A | A/C RM 309-LEAKING IN CEILING-PLANT MGR HAMER 416-6175 KLR | 6/5/14 | | | Plumbing |
| East HS (2180) 2A | A/C UNIT is LEAKING in ROOM 320 per Ms. Mallary, Plant Mgr. 416.6160 | 6/16/14 | | | Plumbing |
| East HS (2180) 2A | Two commodes stopped up. | 4/30/14 | Restroom (Boys) | 3rd floor west end | Plumbing |
| East HS (2180) 2A | WATER COMING UP THRU FLOOR TILE IN CLINIC AREA-PLANT MGR HAMER 416-6175 KLR | 5/6/14 | | | Plumbing |
| East HS (2180) 2A | A/C RM 206-LEAKING-PLANT MGR WHITE 416-6175 KLR | 5/12/14 | | | Plumbing |
| East HS (2180) 2A | STEAMTABLE KITCHEN AREA-LEAKING WATER ALL OVER KITCHEN FLOOR-PLANT MGR HAMER 416-6175 KLR | 5/13/14 | | | Plumbing |

| | | | | | | |
|-------------------|--|---------|------------------|--------------------|------------------------------------|----------|
| East HS (2180) 2A | A/C RM 309-LEAKING- PLANT MGR WHITE 416- 6175 KLR | 5/13/14 | | | | Plumbing |
| East HS (2180) 2A | Per Plant Manager: MLG&W recommend that a Cathodic Protection be added to the gas line to prevent rust. | 4/1/14 | | | | Plumbing |
| East HS (2180) 2A | Please allow plumbers to come out and add cothodic protection to gas line. This request is from MLG&W. | 3/6/14 | | | where ever gas lins are located | Plumbing |
| East HS (2180) 2A | Flush handle leaking on commode. | 2/19/14 | Restroom (Girls) | Clinic | | Plumbing |
| East HS (2180) 2A | Two commode stopped up. | 3/20/14 | Restroom (Boys) | 3rd West end | | Plumbing |
| East HS (2180) 2A | Two commodes leaking. | 3/21/14 | Restroom (Boys) | 2nd floor east end | | Plumbing |
| East HS (2180) 2A | Urinal stopped up. | 3/28/14 | Restroom (Boys) | Gym locker room | | Plumbing |
| East HS (2180) 2A | Commode constantly running and leaking, shut-off water to commode. | 1/21/14 | Restroom (Girls) | 2nd floor West end | | Plumbing |

| | | | | | |
|-------------------|--|---------|---------------------|--------------------|----------|
| East HS (2180) 2A | per Mr. Hamer 416-6175 in the tunnel, hot water return pipe is leaking | 1/28/14 | | | Plumbing |
| East HS (2180) 2A | Urinal stopped up. | 1/28/14 | Restroom (Boys) | 2nd floor west end | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 1/30/14 | Administration Area | Restroom | Plumbing |
| East HS (2180) 2A | Two commodes stopped up. | 2/4/14 | Restroom (Girls) | 2nd floor east end | Plumbing |
| East HS (2180) 2A | Flush handle leaking on commode. | 2/7/14 | Restroom (Girls) | 2nd floor west end | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 2/12/14 | Restroom (Girls) | 3rd floor west end | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 2/18/14 | Restroom (Girls) | 3rd floor east end | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 2/18/14 | Restroom (Boys) | 3rd floor east end | Plumbing |

| | | | | | |
|-------------------|---|---------|------------------|--------------------|----------|
| East HS (2180) 2A | Commode stopped up. | 8/27/13 | Gym | Boy's locker room | Plumbing |
| East HS (2180) 2A | A/C UNIT RM 221 2ND FLR- LEAKING-PLANT MGR MALLORY 416-6175 KLR | 8/27/13 | | | Plumbing |
| East HS (2180) 2A | Two commodes stopped up. | 8/27/13 | Restroom (Boys) | 3rd floor east end | Plumbing |
| East HS (2180) 2A | WATER FOUNTAIN - INSIDE THE CAREER TECH CENTER TO THE LEFT - CONSTANTLY RUNNING - CAN'T SHUT OFF - PM/HAMER 416-6175 | 8/28/13 | | | Plumbing |
| East HS (2180) 2A | TOILET PIPE IS LEAKING IN PRIN OFFICE PLANT MGR- HAMER/416.6260 | 8/29/13 | | | Plumbing |
| East HS (2180) 2A | Flush handle leaking on commode. | 8/29/13 | Restroom (Girls) | 2nd floor east end | Plumbing |
| East HS (2180) 2A | UNIT IS LEAKING WATER IN RM-316 PLANT MGR- WHITE/416.6160 | 8/30/13 | | | Plumbing |
| East HS (2180) 2A | TOILET WONT FLUSH IN CAFE MGR OFFICE. PLANT MGR- HAMER/416.6160 | 9/5/13 | | | Plumbing |

| | | | | | |
|-------------------|--|---------|------------------|--------------------|----------|
| East HS (2180) 2A | Flush handle broke on commode. | 9/5/13 | Restroom (Boys) | 2nd Floor east end | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and clear drain to 3 compartment sink in kitchen, sink drain slow. (Health Department request). | 9/26/13 | Cafeteria | kitchen | Plumbing |
| East HS (2180) 2A | Gas Main leaking | 9/26/13 | | | Plumbing |
| East HS (2180) 2A | Mop sink stopped up. | 9/27/13 | Custodial Closet | 3rd floor west end | Plumbing |
| East HS (2180) 2A | WATER PIPE CAFE AREA- LEAKING OVER TABLE- PLANT MGR HAMER 416- 6160 KLR | 10/2/13 | | | Plumbing |
| East HS (2180) 2A | SINK BOYS' LOCKER RM GYM-PIPE HAS A HOLE ON THE BOTTOM & LEAKING WATER OUT PER SBE- PLANT MGR WHITE 416- 6160 KLR | 10/2/13 | | | Plumbing |
| East HS (2180) 2A | Urinal stopped up. | 10/2/13 | Restroom (Boys) | Clinic | Plumbing |
| East HS (2180) 2A | PILOT NEEDS TO BE LIT ON OVEN IN KITCHEN PLANT MGR- HAMER/650.9273 | 10/3/13 | | | Plumbing |

| | | | | | |
|-------------------|--|----------|------------------|-------------------------------|----------|
| East HS (2180) 2A | A/C RM 323-LEAKING-PLANT MGR WHITE 416-6160 KLR | 9/10/13 | | | Plumbing |
| East HS (2180) 2A | Water CANNOT BE CONTAINED in the Cafeteria area, Dining Area, and inside Custodial closet per Thomas Hamer, Plant Mgr. 416.6090. | 9/17/13 | | | Plumbing |
| East HS (2180) 2A | per Mr. Hamer 416-1675 2nd boiler in the boiler room the flue cylinder is leaking water and inspector is there and said it is not normal | 12/16/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair butter fly valve to boiler for kitchen area. (Two valves leaking). | 12/17/13 | Mechanical Room | Mechanical room below kitchen | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair leaking faucet in guidance office rm#225 | 12/18/13 | | Guidance office 225 | Plumbing |
| East HS (2180) 2A | Mop sink stopped up. | 12/19/13 | Custodial Closet | 3rd floor west end | Plumbing |
| East HS (2180) 2A | per Mr. Hamer 416-6175 in the kitchen the 3 compartment sink drain pipe is leaking really bad | 1/9/14 | | | Plumbing |
| East HS (2180) 2A | Commodes leaking, water constantly standing on floor. | 1/9/14 | Restroom (Boys) | 2nd floor east end | Plumbing |

| | | | | | |
|-------------------|---|----------|------------------|--------------------|----------|
| East HS (2180) 2A | Please allow a plumber to come out and unclog sinks drain in room 332 the art room. Two sinks in room. | 1/14/14 | Classroom | rm# 332 | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 10/14/13 | Restroom (Boys) | 1st floor | Plumbing |
| East HS (2180) 2A | Pipe leaking in the BLDG. | 10/24/13 | 2nd Floor | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and replace drain hose to washer. Hose is cracked and water run onto flooring when in use. | 10/25/13 | | Rm# 105 | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and replace toilet in boys locker room. Toilet beyond repair. | 10/25/13 | | boys locker room | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair drain piping to 3 compartment sink in kitchen area | 10/29/13 | Kitchen | kitchen area | Plumbing |
| East HS (2180) 2A | Flush handle leaking on commode. | 10/30/13 | Restroom (Boys) | 2nd floor east end | Plumbing |
| East HS (2180) 2A | Toilet seat broke on commode. | 11/5/13 | Restroom (Girls) | East Wing | Plumbing |

| | | | | | |
|-------------------|--|----------|------------------|-------------------|----------|
| East HS (2180) 2A | Two commodes stopped up. | 11/5/13 | Restroom (Girls) | East wing | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair piping in art room RM#328. Piping leaks. | 11/7/13 | | 328 | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair piping to sink in art room. (Drain piping damaged) | 11/12/13 | Classroom | rm#328 | Plumbing |
| East HS (2180) 2A | 1-COM SINK IS STOPPED UP IN KITCHEN. PLANT MGR- HAMER/416.6160 | 11/15/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair piping to sink and 1st. stall toilet will not flush, boys restroom in gym. This is the restroom that is used by the public when basketball game are played here at East High | 11/19/13 | | boys restroom Gym | Plumbing |
| East HS (2180) 2A | WATER IS COMING FLR IN B/RR IN GYM, CANT CONTROL PLANT MGR-HAMER/416-6175 | 11/21/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair ice maker in rm# 211, ice maker needs for stem program. | 11/25/13 | | rm#211 | Plumbing |
| East HS (2180) 2A | Request back flow be winterized. | 11/26/13 | | | Plumbing |

| | | | | | |
|-------------------|---|---------|------------------|-------------------|----------|
| East HS (2180) 2A | Commode constantly running and leaking, turn-off water to commode. | 12/5/13 | Restroom (Girls) | West end | Plumbing |
| East HS (2180) 2A | CEILING PIPE IS LEAKING WATER IN 1ST FLR WEST-END HALL PLANT MGR- HAMER/650.9273 | 12/9/13 | | | Plumbing |
| East HS (2180) 2A | Water cooler beside auditorium is stopped up. | 8/12/13 | 2nd Floor | | Plumbing |
| East HS (2180) 2A | FCU-1202 2ND FLR EAST WING RM 221N-LEAKING-SBE HAMER 416-6175 KLR | 8/14/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and seal around wall or find what is creating leak where base board is missing. Water leaks from bottom were wall meets floor. | 8/15/13 | Classroom | RM 325 | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair toilet in last stall in girls restroom. 2nd. fl. East end | 8/15/13 | Restroom (Girls) | 2nd. fl. west end | Plumbing |
| East HS (2180) 2A | CUST CLOSET CAFE-SOMETHING IS LEAKING-SBE DOES NOT KNOW WHAT OR WHERE IT'S COMING FROM-SBE HAMER 416-6175 KLR | 8/15/13 | | | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 8/15/13 | Restroom (Girls) | 2nd floor | Plumbing |

| | | | | | |
|-------------------|--|---------|------------------|------------------------------|----------|
| East HS (2180) 2A | Replace broken toilet seat. | 8/15/13 | Restroom (Girls) | 3rd floor east wing | Plumbing |
| East HS (2180) 2A | WALL UNIT IS LEAKING IN RM-221 PLANT MGR- MALLARY/416.6160 | 8/19/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a sheet metalist to come out and replace drain cover in the boy football locker room. | 8/20/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and check piping above drop ceiling (for leaks), there are a number of ceiling tile that has water spots so Eric Thomas from Risk Management asked for this to be done before | 8/20/13 | Cafeteria | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and inspect sprinkler head to fire suppressionion system that is surrounded by ceiling tile. Tiles are wet where sprinklers are. Main office | 8/21/13 | | | Plumbing |
| East HS (2180) 2A | CUT OFF VALVE PIPE IS LEAKING WATER IN CHILLER RM PLANT MGR- HAMER/416.6960 | 8/22/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and plases drain covers to urinals and floor drains in the football locker room. | 8/22/13 | | Foot ball locker room | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and secure toilet to wall there is 3 inch gap between the wall and toilet. | 8/23/13 | Restroom (Girls) | 2nd. fl. wst end of building | Plumbing |

| | | | | | |
|-------------------|--|---------|------------------|--|----------|
| East HS (2180) 2A | Please allow a plumber to come out and unclog toilet in security office. toilies will not flush away. | 8/27/13 | | security office restroom | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and replace the flush valve in the restroom inside the boy coaches office | 8/12/13 | Gym | boy locker inside the coaches office | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 8/9/13 | Restroom (Boys) | 3rd floor | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 8/9/13 | Restroom (Girls) | 3rd floor | Plumbing |
| East HS (2180) 2A | Replace broken toilet seat. | 8/9/13 | Restroom (Girls) | 2nd floor | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair water fountain piping. Piping leaks. | 8/8/13 | | east end of building across from gym on the 2nd fl | Plumbing |
| East HS (2180) 2A | FCU 3RD FLR WEST RM 308 & FCU 2ND FLR EAST WING RM 222-BOTH LEAKING-SBE MALLORY 416-6160 KLR | 8/8/13 | | | Plumbing |
| East HS (2180) 2A | Stopped up water cooler beside rm#312. | 8/8/13 | Hallway/Corridor | 3rd floor | Plumbing |

| | | | | | |
|-------------------|--|---------|-----------------|---------------------------------|----------|
| East HS (2180) 2A | Commode stopped up. | 8/8/13 | Restroom (Boys) | 2nd floor west end | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 8/8/13 | Gym | Boys restroom | Plumbing |
| East HS (2180) 2A | Commode stopped up. | 8/8/13 | Gym | Girls restroom | Plumbing |
| East HS (2180) 2A | URINAL 3RD FLR B RR E END-CONSTANTLY RUNNING AND WATER IS FLOODING RR BELOW PER SBE-SBE HAMER 416- 6160 KLR | 8/9/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair water fountain across from room 213, handles stick when pushed in. Also spouts needs to be ajusted or turned toward the drain of water fountains as when in use | 8/9/13 | | 2nd. fl. across from rm# 213 | Plumbing |
| East HS (2180) 2A | VALVE LINE TO FREEZER IS STOPPED UP IN KITCHEN . PLANT MGR- ARNOLD/416.8574 | 7/31/13 | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and replace p-trap piping to sink in football boy locker room. | 8/1/13 | | football locker room | Plumbing |
| East HS (2180) 2A | Assist MLGW turning the water on. | 8/6/13 | | | Plumbing |

| | | | | | | |
|-------------------|---|---------|---------------------|-------------------|--|----------|
| East HS (2180) 2A | FCU ZONE 12 2ND FLR EAST WING RM 216S- LEAKING-SBE MALLORY 416-6175 KLR | 8/6/13 | | | | Plumbing |
| East HS (2180) 2A | WALL UNIT IS LEAKING WATER IN RM-204. PLANT MGR-/ | 8/7/13 | | | | Plumbing |
| East HS (2180) 2A | Assist MLGW with turning on the water. | 7/23/13 | | | | Plumbing |
| East HS (2180) 2A | Please allow a plumber to come out and repair shower in girls rest room. (Shower leaks). | 7/11/13 | | girls locker room | | Plumbing |
| East HS (2180) 2A | Water leaking from ceiling, when it rains. | 6/25/14 | Classroom | Rms#202 & 203 | | Roof |
| East HS (2180) 2A | Water leaking from ceiling, when it rains. | 5/28/14 | Administration Area | Main office | | Roof |
| East HS (2180) 2A | Water leaking from ceiling, when it rains. | 5/28/14 | Administration Area | Main office | | Roof |
| East HS (2180) 2A | Water leaking from ceiling, when it rains. | 2/4/14 | Hallway/Corridor | Next to gym | | Roof |

| | | | | | |
|-------------------|--|----------|---------------------|----------------------------|------|
| East HS (2180) 2A | Please allow roofers to come out and address roof leak on third floor on the northwest hallway. Water from last fridays rain has leaked into the light fixtures causing light system to short out. | 9/23/13 | 3rd Floor | northwest hallway | Roof |
| East HS (2180) 2A | Please allow roofers to come out and repair roof leak. Leak is located in the serving line area above one of the cash registers | 9/20/13 | Cafeteria | serving line | Roof |
| East HS (2180) 2A | Please allow roofers to come out and repair roof leak in the guidance counselors office. | 1/14/14 | Administration Area | Guidance counselors office | Roof |
| East HS (2180) 2A | ROOF IS LEAKING WATER OVER SERVING LINE PLANT MGR- HAMER/650.9273 | 11/22/13 | | | Roof |
| East HS (2180) 2A | Water leaking from ceiling when it rains. | 12/5/13 | Classroom | Rm#318 | Roof |
| East HS (2180) 2A | Water leaking from ceiling, when it rains. | 8/12/13 | Restroom (Boys) | 2nd floor | Roof |
| East HS (2180) 2A | Please allow a roofers to come out and inspect the CTC roof top for leaks. Greant number of ceiling tile have water spots. | 8/21/13 | | all of the CTC roof top | Roof |
| East HS (2180) 2A | Water leaking from ceiling, when it rains. | 8/8/13 | 3rd Floor | Rm#304 | Roof |

| | | | | | |
|-------------------|--|---------|------------------|---|-------------|
| East HS (2180) 2A | Please allow the roofer to come out and repair roof leaks that leak inside of library. Leaks have destroyed books, shelving, wood molding and plaster inside of library. | 8/7/13 | Library | 3 areas in the library | Roof |
| East HS (2180) 2A | There is a leak in the ceiling over the cash register in the serving line. This needs to be checked out as soon as possible. | 7/22/13 | 2nd Floor | Cafeteria Serving Line | Roof |
| East HS (2180) 2A | There is a leak in the hallway in the ceiling. This area is located on the first floor going towards the weight room. This needs to be checked out asap and repaired | 7/22/13 | 1st Floor | hallway | Roof |
| East HS (2180) 2A | Please allow sheet metalist to come out and repair locker. Locker#150/ 2011 and 2 lockers next to room 202. | 2/28/14 | | locker#s 150/2011 and 2 lockers next to rm202 | Sheet Metal |
| East HS (2180) 2A | Please allow sheet metalist to come out and repair locker 1147. Door is coming detached from frame and student cant secure belongings. | 3/27/14 | Hallway/Corridor | 3rd fl west locker1147 | Sheet Metal |
| East HS (2180) 2A | Please allow sheet metalist to come out and secure air tank that stands 5ft tall and cylinder shape to wall. | 3/27/14 | | Ctc rifle range | Sheet Metal |
| East HS (2180) 2A | Please allow a sheet metalist to come out and place metal covering over two broken out windows in the base ball locker room that leads to the tunnel area. | 2/7/14 | | Base Ball teams locker room | Sheet Metal |
| East HS (2180) 2A | Please allow sheetmetalist to come out and repair digital sign on the front of campus, metal housing is damaged on the front of digital sign housing. | 10/5/13 | Grounds | front campus | Sheet Metal |

| | | | | | | |
|-------------------|---|---------|-----------|--------|--------------------------------------|-------------|
| East HS (2180) 2A | Request pan for U/V in room #331 be repaired. | 8/15/13 | | | | Sheet Metal |
| East HS (2180) 2A | Please allow a sheet metalist to come out and make drip pan for unit ventilator in room 321. Drip pan is cracked | 8/15/13 | Classroom | RM#321 | | Sheet Metal |
| East HS (2180) 2A | Please allow a sheet metalist to come out and repair dry vent housing. | 8/21/13 | | | foot ball locker room | Sheet Metal |
| East HS (2180) 2A | Please allow a sheet metalist to come out and repair/replace metal cover to hvac unit outside. | 8/22/13 | | | across from Building managers office | Sheet Metal |
| East HS (2180) 2A | Please allow the sheet metal department to make a drip pan for air unit oom 307. Drip pan cracked in half. | 8/9/13 | Classroom | Rm 307 | | Sheet Metal |
| East HS (2180) 2A | Please allow a sheet metalist to come out and replace front cover to water fountain. No cover to fountain and wires are exsposed. | 7/31/13 | 2nd Floor | | across from gym | Sheet Metal |

| Count of Craft | Craft | | | | |
|----------------------------|-----------|------------|----------|----------|-------------|
| Location | Carpentry | Electrical | Painting | Plumbing | Grand Total |
| Fairgrounds Stadium 181-2A | 4 | 3 | 23 | 9 | 39 |
| Grand Total | 4 | 3 | 23 | 9 | 39 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|----------------------------|---|----------------|------------------|-------------|------------|
| Fairgrounds Stadium 181-2A | South end zone goal post is turned sideways (facing the east) please repair | 8/5/13 | Athletic Field | | Carpentry |
| Fairgrounds Stadium 181-2A | goal post at the north end zone (near Central Ave) is not leveled, please repair | 8/5/13 | Athletic Field | | Carpentry |
| Fairgrounds Stadium 181-2A | broken bar on front row rail of the home side (pressbox) stadium bleachers. safty hazard, please weld back together | 8/6/13 | Athletic Field | | Carpentry |
| Fairgrounds Stadium 181-2A | please add nuts and screws to pole vault standards for upcoming 2014 Track and Field Season. 1st track meet is 1 March | 2/12/14 | Athletic Field | | Carpentry |
| Fairgrounds Stadium 181-2A | bad electrical outlet in middle section of the press box. This is the outlet that the scoreboard controller and microphone amp is plugged into, please repair | 8/5/13 | Athletic Field | | Electrical |
| Fairgrounds Stadium 181-2A | Lights above the urinals and toilets are out in the southside locker room, please repair. This is for the locker room that is closest to the bleachers | 9/26/13 | Athletic Field | | Electrical |
| Fairgrounds Stadium 181-2A | Check the heating in the stadium. | 11/12/13 | | | Electrical |

| | | | | | |
|----------------------------|-------------------------------|---------|--|--|----------|
| Fairgrounds Stadium 181-2A | paint lines on football field | 8/12/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 8/15/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 8/26/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 9/3/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 9/4/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 9/16/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 9/16/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 9/30/13 | | | Painting |

| | | | | | |
|----------------------------|-------------------------------|----------|--|--|----------|
| Fairgrounds Stadium 181-2A | paint lines on football field | 9/30/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/7/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/7/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/14/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/14/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/21/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/21/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/28/13 | | | Painting |

| | | | | | |
|----------------------------|--|----------|----------------|--|----------|
| Fairgrounds Stadium 181-2A | paint lines on football field | 10/28/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 11/4/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 11/11/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 11/18/13 | | | Painting |
| Fairgrounds Stadium 181-2A | paint lines on football field | 11/18/13 | | | Painting |
| Fairgrounds Stadium 181-2A | Please remove graffiti from rear wall of locker rooms | 11/25/13 | Athletic Field | | Painting |
| Fairgrounds Stadium 181-2A | please paint the sector lines for the shot put pad and discus pad. The sector lines are the "V" shape lines that participants use to gage when throwing the shot put and discus. | 2/21/14 | Athletic Field | | Painting |
| Fairgrounds Stadium 181-2A | Toilet in the Visitors Locker Room is stopped up, please repair | 10/14/13 | Athletic Field | | Plumbing |

| | | | | | |
|----------------------------|---|----------|----------------|--|----------|
| Fairgrounds Stadium 181-2A | Toilet in the visitor locker room is jammed up, please repair, we have play offs this Friday | 11/12/13 | Athletic Field | | Plumbing |
| Fairgrounds Stadium 181-2A | Please unclog both locker rooms toilets | 11/20/13 | Athletic Field | | Plumbing |
| Fairgrounds Stadium 181-2A | Request Stadium be winterized. | 11/26/13 | | | Plumbing |
| Fairgrounds Stadium 181-2A | Stadiums were winterized in late fall, please bring the water back online for the upcoming soccer and track & field season. Track Season starts March 1, 2014 and | 2/24/14 | Athletic Field | | Plumbing |
| Fairgrounds Stadium 181-2A | Need the sprinkler system cut back on for field repairs and prep for football season. Also need the plumber to check and make sure all sprinkler heads are working properly, thanks | 4/10/14 | Athletic Field | | Plumbing |
| Fairgrounds Stadium 181-2A | we have a clogged toilet in the visitor locker room, please repair | 4/16/14 | | | Plumbing |
| Fairgrounds Stadium 181-2A | toilet is clogged and flooding in the visitor locker room, please repair | 5/12/14 | Athletic Field | | Plumbing |
| Fairgrounds Stadium 181-2A | Turn on water to sprinkler system, check all zones, and make needed sprinkler head repairs, thanks | 5/22/14 | Athletic Field | | Plumbing |

| Count of Craft | Craft | | | | Grand Total |
|--------------------------|----------|-----------|------------|------|-------------|
| | Location | Carpentry | Electrical | HVAC | |
| Farmville Bus Lot 298-2B | 1 | 4 | 3 | 7 | 15 |
| Grand Total | 1 | 4 | 3 | 7 | 15 |

| Location | Request Description | Submittal Date | Area Descript | Area Number | Craft |
|--------------------------|---|----------------|---------------|-------------|---------------------------------------|
| Farmville Bus Lot 298-2B | Front door will not lock administrative office (drivers building). | 1/28/14 | | | Carpentry |
| Farmville Bus Lot 298-2B | Bus hit Light pole, repair wires as needed. Need bucket truck/lift. | 7/31/13 | Parking Lot | | Electrical |
| Farmville Bus Lot 298-2B | The lighting in employees parking lot for Durham School Services 1384 Farmville is out and on the outside of the shop at Durham is out. per Prentiss 620-1835 | 8/26/13 | | | Electrical |
| Farmville Bus Lot 298-2B | Ballast out ladies restroom. Exit sign has fallen - exposed wires. | 10/29/13 | | | Electrical |
| Farmville Bus Lot 298-2B | Check two gas fired unit heaters in truck shop. Will not fire. | 1/23/14 | | | Electrical |
| Farmville Bus Lot 298-2B | Monthly - Filter-North Bus Lot - Refer to PM schedule details. | 4/12/14 | | | Heating/Ventilation /Air Conditioning |
| Farmville Bus Lot 298-2B | Monthly - Filter-North Bus Lot - Refer to PM schedule details. | 8/17/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|--|--|---------------------------------------|
| Farmville Bus Lot 298-2B | Monthly - Filter-North Bus Lot - Refer to PM schedule details. | 12/14/13 | | | Heating/Ventilation /Air Conditioning |
| Farmville Bus Lot 298-2B | women's and men's restrooms faucets leaking per ms. Chester at 1384 Farmville | 7/26/13 | | | Plumbing |
| Farmville Bus Lot 298-2B | Commode in restroom in the maintenance shop of Durham Bus Services in 1384 Building is broken per Prentiss 620-1825 | 8/26/13 | | | Plumbing |
| Farmville Bus Lot 298-2B | Commode in maintenance building does not flush. | 8/26/13 | | | Plumbing |
| Farmville Bus Lot 298-2B | MEN TOILET IS STOPPED UP PLANT MGR-CHASER/620.1835 | 9/16/13 | | | Plumbing |
| Farmville Bus Lot 298-2B | TOILET OVERFLOWING IN DRIVERS BUILDING | 9/23/13 | | | Plumbing |
| Farmville Bus Lot 298-2B | MEN/RR TOILET IS OVERFLOWING. PLANT MGR-CHESTER/320.9356 | 10/17/13 | | | Plumbing |
| Farmville Bus Lot 298-2B | Toilet mechanics shop will not flush/ | 1/23/14 | | | Plumbing |

| Count of Craft | Craft | | | |
|--------------------------|-----------|------------|----------|-------------|
| Location | Carpentry | Electrical | Plumbing | Grand Total |
| Flicker Street Clinic 2B | 1 | 1 | 1 | 3 |
| Grand Total | 1 | 1 | 1 | 3 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|--------------------------|--|----------------|---------------------|----------------------------|------------|
| Flicker Street Clinic 2B | Renovation Project for Brian Shipp. | 6/19/14 | Administration Area | | Carpentry |
| Flicker Street Clinic 2B | Demo as necessary any electrical fixtures and devices, including wiring and conduit for ADA remodel. | 6/18/14 | | Rest rooms near main entry | Electrical |
| Flicker Street Clinic 2B | Demo plumbing fixtures, water and waste lines as necessary. | 6/18/14 | | Rest rooms near main entry | Plumbing |

| Count of Craft | Craft | | | | | | |
|------------------------|-----------|------------|------|----------|------|-------------|-------------|
| Location | Carpentry | Electrical | HVAC | Plumbing | Roof | Sheet Metal | Grand Total |
| Getwell Bus Lot 195-2E | 5 | 10 | 8 | 16 | 1 | 2 | 42 |
| Grand Total | 5 | 10 | 8 | 16 | 1 | 2 | 42 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|------------------------|---|---------------|---------------|---------------|------------|
| Getwell Bus Lot 195-2B | Base bord need to be replaced in the men rest room, and the women rest room to on the 1st floor. urgent. | 4/15/14 | 1st Floor | men rest room | Carpentry |
| Getwell Bus Lot 195-2B | Their is a hole in the wall need to be fix. urgent. | 3/31/14 | 1st Floor | Main hall way | Carpentry |
| Getwell Bus Lot 195-2B | Can not secure door north side of building. | 8/7/13 | | | Carpentry |
| Getwell Bus Lot 195-2B | Replace damaged ceiling in ABC office,and driver breakroom. | 8/7/13 | | | Carpentry |
| Getwell Bus Lot 195-2B | Repair door knob between break room and office area. | 10/31/13 | | | Carpentry |
| Getwell Bus Lot 195-2B | RTU ENTIRE BLDG-NOT COMING ON-PLANT MGR JACKSON KLR | 5/6/14 | | | Electrical |
| Getwell Bus Lot 195-2B | Their are 10 lights in side the garage that is not working. the lights are to high for me to reach. urgent. | 6/12/14 | 1st Floor | Garage | Electrical |

| | | | | | |
|------------------------|--|---------|-----------|--------|------------|
| Getwell Bus Lot 195-2B | UNIT NOT COMING ON THRU BLDG PLANT MGR- JACKSON/416.1250 | 6/12/14 | | | Electrical |
| Getwell Bus Lot 195-2B | Their are five lights out in the garage that is not working. the lights are to high for me to reach. urgent. | 4/4/14 | 1st Floor | Garage | Electrical |
| Getwell Bus Lot 195-2B | Repair/replace balast in Mechanic break room, and Drivers lounge. | 8/1/13 | | | Electrical |
| Getwell Bus Lot 195-2B | Lights out in the stairwell. | 8/15/13 | | | Electrical |
| Getwell Bus Lot 195-2B | Repair electrical panel that serves outside gas pumps. | 8/16/13 | | | Electrical |
| Getwell Bus Lot 195-2B | BALLAST OUT IN DRIVERS BREAK RM PLANT MGR- LARRY/743.1277 | 8/19/13 | | | Electrical |
| Getwell Bus Lot 195-2B | REP/REPL OUTSIDE LIGHTS- CALLED IN BY LARRY MONGER 214-7571 KLR | 8/20/13 | | | Electrical |
| Getwell Bus Lot 195-2B | bad breaker for fuel pump need asap per Thomas Dougherty 734-3334 | 10/2/13 | | | Electrical |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Getwell Bus Lot 195-2B | Monthly - Filter - Getwell Transport - Refer to PM schedule details. | 1/21/14 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | Monthly - Filter - Getwell Transport - Refer to PM schedule details. | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | AC not working properly on 1st floor. | 6/6/14 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | down stairs unit not cooling | 6/9/14 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | UNIT NOT COMING ON THRU ENTIRE BLDG PLANT MGR- JACKSON/416.1250 | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | UNIT NOT COMING ON THRU ENTIRE FLR. PLANT MGR- LARRY/743.1277 | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | down stairs a/c not working | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Getwell Bus Lot 195-2B | Monthly - Filter - Getwell Transport - Refer to PM schedule details. | 9/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|-----------|-----------------|----------|
| Getwell Bus Lot 195-2B | The urinal in side the men rest room on the 1st floor is leaking water from the bottom of the urinal. urgent. | 4/9/14 | 1st Floor | Men rest room | Plumbing |
| Getwell Bus Lot 195-2B | The flush vaule on the commode will not flush. urgent. | 6/12/14 | 1st Floor | Women rest room | Plumbing |
| Getwell Bus Lot 195-2B | Heat is not working in the shop area. | 1/28/14 | | | Plumbing |
| Getwell Bus Lot 195-2B | No hot water in the shop area. | 1/29/14 | | | Plumbing |
| Getwell Bus Lot 195-2B | Commode backing in the ladies employee restroom. | 2/7/14 | | | Plumbing |
| Getwell Bus Lot 195-2B | FAUCET MEN'S RR 1ST FLR- HANGING OFF & COMMODE IN SAME RR-STOPPED UP- CALLED IN BY MAINT DIR HOLT 214-7571 KLR | 3/5/14 | | | Plumbing |
| Getwell Bus Lot 195-2B | Commode running over 1st floor ladies. | 3/19/14 | | | Plumbing |
| Getwell Bus Lot 195-2B | Faucet on the sink in the men rest room is broken need to be replaced. urgent. | 3/31/14 | 1st Floor | men rest room | Plumbing |

| | | | | | |
|------------------------|--|---------|-----------|-----------------|----------|
| Getwell Bus Lot 195-2B | Commode in the men rest room need to be replaced, the commode is running and old. urgent. | 3/31/14 | 1st Floor | Men rest room | Plumbing |
| Getwell Bus Lot 195-2B | Need a commode top on back of the commode, the rest room is on the 1st floor. | 3/31/14 | 1st Floor | Women rest room | Plumbing |
| Getwell Bus Lot 195-2B | The boys & girls restroom by sbe's office sink fauset not working and needs to be repaired as soon as possible. | 7/19/13 | 1st Floor | restrooms | Plumbing |
| Getwell Bus Lot 195-2B | The girls restroom by cross connect closet B143M have a sink fauset that's not working and needs to be repaired as soon as possible. | 7/19/13 | 1st Floor | restroom | Plumbing |
| Getwell Bus Lot 195-2B | The boys & girls restroom by room B-115 have a sink fauset that's not working and needs to be repaired as soon as possible. | 7/19/13 | 1st Floor | restrooms | Plumbing |
| Getwell Bus Lot 195-2B | The boys & girls restroom by room A-115 have a sink fauset that's not working and needs to be repaired as soon as possible. | 7/19/13 | 1st Floor | restroom | Plumbing |
| Getwell Bus Lot 195-2B | Leaking sink in employee restroom ladies. | 12/5/13 | | | Plumbing |
| Getwell Bus Lot 195-2B | HEaters are not working in the shop areas. | 12/9/13 | | | Plumbing |

| | | | | | |
|------------------------|---|---------|-----------|-----------|-------------|
| Getwell Bus Lot 195-2B | The cafeteria have a roof leak by room B-134 that needs to be repaired as soon as possible. | 7/19/13 | 1st Floor | cafeteria | Roof |
| Getwell Bus Lot 195-2B | Garage door is broken, will not open. urgent. | 3/31/14 | 1st Floor | Garage | Sheet Metal |
| Getwell Bus Lot 195-2B | Overhead door,last bay roller off track | 8/1/13 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | |
|------------------------|-----------|------------|------|----------|----------|------|-------------|
| Location | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| Information Technology | 7 | 5 | 7 | 1 | 2 | 2 | 24 |
| Grand Total | 7 | 5 | 7 | 1 | 2 | 2 | 24 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|---|--|-----------------------|-------------------------|--|--------------|
| Gragg-Information Technology 1108-2B | 2-EXIT DOORS CANT SECURE. SBE-COX/416-4250 | 7/1/13 | | | Carpentry |
| Gragg-Information Technology 1108-2B | Request to inspect the floor where construction is being done. | 8/14/13 | Classroom | | Carpentry |
| Gragg-Information Technology 1108-2B | Hang pictures | 8/9/13 | | Gragg Technology information building | Carpentry |
| Gragg-Information Technology 1108-2B | Would like to have a small white board installed on the wall (Deangelo Brooks) please see Crystal Henderson | 6/19/14 | Administration Area | New system administrator manager | Carpentry |
| Gragg-Information Technology 1108-2B | Install dry eraser board in Dorren Ball's office. Please see Tina Pope | 9/12/13 | Administration Area | see Tina Pope | Carpentry |
| Gragg-Information Technology 1108-2B | Replace damaged ceiling tile in network operations office | 4/22/14 | Administration Area | Network operations office | Carpentry |
| Gragg-Information Technology 1108-2B | Replace damaged ceiling tile in Dorian Balls office | 2/17/14 | Administration Area | I T Building | Carpentry |
| Gragg-Information Technology 1108-2B | Power line down. | 6/11/14 | | | Electrical |

| | | | | | |
|--------------------------------------|---|---------|---------------------|--|---------------------------------------|
| Gragg-Information Technology 1108-2B | Need to have an electric outlet checked for repairs. outlet not working. SEE Victoria Middleton, GCA Rep | 7/11/13 | Hallway/Corridor | Rear Entrance Near Security Access Pad | Electrical |
| Gragg-Information Technology 1108-2B | Monitor is reading Check Genset | 5/5/14 | Administration Area | IT building | Electrical |
| Gragg-Information Technology 1108-2B | emergence light in ladies restroom in the I T building is not working | 3/25/14 | Administration Area | IT building | Electrical |
| Gragg-Information Technology 1108-2B | Attention: Richard Powell Emergency light in Ladies restroom not working again | 3/28/14 | Administration Area | IT Department | Electrical |
| Gragg-Information Technology 1108-2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg-Information Technology 1108-2B | I.T. room not cooling | 4/8/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg-Information Technology 1108-2B | A/C IT DEPT AREA-NOT COOLING-PLANT MGR COX 416- 5904 KLR | 9/25/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg-Information Technology 1108-2B | Monthly - Oil Lube & Belt- Gragg/North Area Office - Refer to PM schedule details. | 1/19/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg-Information Technology 1108-2B | Monthly - Filter-Gragg/North Area Office - Refer to PM schedule details. | 6/13/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------------|---|----------|---------------------|---------------------|---------------------------------------|
| Gragg-Information Technology 1108-2B | Monthly - Filter-Gragg/North Area Office - Refer to PM schedule details. | 2/14/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg-Information Technology 1108-2B | Monthly - Filter-Gragg/North Area Office - Refer to PM schedule details. | 10/18/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg-Information Technology 1108-2B | Chris Hughes (Field support manager) wants the holes in the wall filled and the wall painted. | 6/16/14 | Administration Area | Chris Hughes Office | Painting |
| Gragg-Information Technology 1108-2B | Unstop Sewer | 2/12/14 | | | Plumbing |
| Gragg-Information Technology 1108-2B | Water leaking from ceiling into light fixture | 8/1/13 | | cubicle area | Plumbing |
| Gragg-Information Technology 1108-2B | Roof is leaking inside a storage room closet next to dorian balls office in the rear of the building. | 4/25/14 | Administration Area | IT | Roof |
| Gragg-Information Technology 1108-2B | Roof leak in Network Operations Office | 3/4/14 | Administration Area | Network Operations | Roof |

| Count of Craft | Craft | | | | | |
|--------------------------|-----------|------------|------|----------|------|-------------|
| Location | Carpentry | Electrical | HVAC | Plumbing | Roof | Grand Total |
| Gragg Trng Ctr (8653) 2# | 2 | 16 | 17 | 9 | 1 | 45 |
| Grand Total | 2 | 16 | 17 | 9 | 1 | 45 |

| Location | Request Description | Submittal Date | Area Descript | Area Number | Craft |
|-----------------------------|--|----------------|---------------------|---------------|------------|
| Gragg Trng Ctr (8653) 2B | The inside IT entrance door will not lock | 7/19/13 | | IT Department | Carpentry |
| Gragg Trng Ctr (8653) 2B | ENTRANCE DOOR NORTH SIDE OF BLDG-BAR HAS BEEN TAMPERED WITH DUE TO A BREAK IN-WILL NOT BE ABLE TO SECURE-CALLED IN BY CUST SUPV G DEAN KLR | 6/27/14 | | | Carpentry |
| Gragg Trng Ctr (8653) 2B | A/C EQUIPMENT RM-NOT COMING ON-CAUSING THE EQUIPMENT TO SHUT DOWN-PLANT MGR COX 416-5904 KLR | 4/4/14 | | | Electrical |
| Gragg Trng Ctr (8653) 2B | Bad ballasts | 4/14/14 | | Lab 9 | Electrical |
| Gragg Trng Ctr (8653) 2B | Electrical outlet making humming noise | 4/15/14 | Administration Area | lab 9 | Electrical |
| Gragg Trng Ctr (8653) 2B | AHU-2-HAS NO POWER-PLANT MGR COX 416-4207 KLR | 4/25/14 | | | Electrical |
| Gragg Trng Ctr (8653) 2B | HEATING UNIT RM 3-KEEPS TRIPPING BREAKER WHEN TURNED ON-PLANT MGR COX 416-5904 KLR | 1/7/14 | | | Electrical |

| | | | | | |
|-----------------------------|--|---------|------------------------|-------------|------------|
| Gragg Trng Ctr (8653) 2B | 2 bad ballast in call center area | 1/8/14 | Administration Area | call center | Electrical |
| Gragg Trng Ctr (8653) 2B | Electrical outlet humming | 1/14/14 | | Lab 1 | Electrical |
| Gragg Trng Ctr (8653) 2B | Light bulbs for cubicles – tube bulbs 4 - Long bulb GE Cool White 30W F30T8/CW 6 - Short bulb GE Cool White 18W FT2T8CW-4 Around 23" in length Need light bulbs for cubicles in | 1/16/14 | Administration Area | Call Center | Electrical |
| Gragg Trng Ctr (8653) 2B | Bad ballast | 1/27/14 | Administration Area | call center | Electrical |
| Gragg Trng Ctr (8653) 2B | Fire control panel in trouble mode | 2/4/14 | Administration Area | Main Office | Electrical |
| Gragg Trng Ctr (8653) 2B | The fire alarm system is in trouble mode (possibly battery needs replacing) | 3/26/14 | Administration Area | main office | Electrical |
| Gragg Trng Ctr (8653) 2B | front office does not have any air per Marlo Cox 416-4207 | 8/12/13 | | | Electrical |
| Gragg Trng Ctr (8653) 2B | UNIT HAS A BURNING SMELL LAB-5. PLANT MGR-COX/416.4222 | 8/16/13 | | | Electrical |

| | | | | | |
|-----------------------------|---|----------|--|-----------------|---------------------------------------|
| Gragg Trng Ctr (8653) 2B | Need 4 cases of T-8 light bulbs for North Area office and Gragg building | 8/28/13 | | main office | Electrical |
| Gragg Trng Ctr (8653) 2B | 10 Exit lights need repairing or replacing 7 Emergency lights need repairing or replacing Call center also has 4 Emergency lights out and 5 Exit lights out | 11/12/13 | | Training Center | Electrical |
| Gragg Trng Ctr (8653) 2B | per ms cox 416-5904 AHU #1 and #2 do not have power | 5/5/14 | | | Electrical |
| Gragg Trng Ctr (8653) 2B | A/C LAB1 & TEACHER'S LOUNGE-BOTH NOT COOLING-PLANT MGR COX 416-4207 KLR | 4/25/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | RTU NOT HEATING THRU ENTIRE BACK AREA PLANT MGR-COX/596.2039 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | RTU NOT HEATING IN MAIN OFFICE PLANT MGR-CINDY NEWMAN/416.4271 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | per ms cox 416-4203 chiller is in alarm | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------------|--|---------|--|--|--|
| Gragg Trng Ctr (8653) 2B | HEAT RM 4 & LESLIE PHILLIPS'S OFC-BOTH NOT HEATING-PLANT MGR COX 416-5904 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | CHILLER NOT COOLING. SBE-COX/596-2039 | 7/22/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | UNIT NOT COOLING IN LAB-2. PLANT MGR-COX/416.5904 | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | front office does not have any a/c working per Marlo Cox 416- 4207 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | CHILLER IS IN ALARM-SBE COX 416-5904 KLR | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | Unit Ventilator NOT COOLING in Room 3 per Ms. Marlo, Plant Mgr. at 901.416.4203. | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | CHILLER NOT COOLING- PLANT MGR COX 416-4250 KLR | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | Chiller is down per Marlo Cox 416-5904 | 8/30/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-----------------------------|---|----------|-------------|----------------|--|---------------------------------------|
| Gragg Trng Ctr (8653) 2B | CHILLER - NOT COMING ON - PM/COX 416-5904 | 9/3/13 | | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | UV IS OVERHEATING (82) IN LAB-1 RM. PLANT MGR-COX/416.4222 | 11/12/13 | | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | UNIT VENTILATOR in MAIN OFFICE and LAB 8 is LEAKING per Marlo Cox, Plant Mgr. 416.4222 | 5/5/14 | | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | AHU-1 & AHU-2 IT DEPT-BOTH NOT COOLING-PLANT MGR COX 416-5904 KLR | 6/9/14 | | | | Heating/Ventilation /Air Conditioning |
| Gragg Trng Ctr (8653) 2B | AHU - LAB 3 & LAB 5 - BOTH ARE LEAKING - PM/COX 416- 5904 | 4/21/14 | | | | Plumbing |
| Gragg Trng Ctr (8653) 2B | Request pipes be re-instilled in Lab #3 and lab #5. The instillation was remove to repair leaks. | 4/21/14 | | | | Plumbing |
| Gragg Trng Ctr (8653) 2B | last toilet from entry leaking | 1/24/14 | Data Closet | women restroom | | Plumbing |
| Gragg Trng Ctr (8653) 2B | Drain backing up into the building. | 2/3/14 | | | | Plumbing |

| | | | | | |
|-----------------------------|---|---------|---------------------|---------------------------|----------|
| Gragg Trng Ctr (8653) 2B | In the last stall from entry the toilet leakes from shut off area | 3/25/14 | | Ladies restroom | Plumbing |
| Gragg Trng Ctr (8653) 2B | connect water line to new refrigerator | 8/23/13 | | Break room in IT building | Plumbing |
| Gragg Trng Ctr (8653) 2B | UNIT IS LEAKING WATER IN LAB#8 PLANT MGR-COX/596.2039 | 4/28/14 | | | Plumbing |
| Gragg Trng Ctr (8653) 2B | UNIT IS LEAKING WATER IN BOILER RM PLANT MGR-COX/596.2039 | 6/16/14 | | | Plumbing |
| Gragg Trng Ctr (8653) 2B | water fountain outside of Men's restroom leaking | 6/19/14 | Administration Area | outside men's restroom | Plumbing |
| Gragg Trng Ctr (8653) 2B | Roof leaks into light fixture when it rains | 7/23/13 | 1st Floor | Lab 8 | Roof |

| Count of Craft | Craft | | | | | | | | | |
|--------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Shamwood ES (2285) | 3 | 4 | 36 | 59 | 75 | 1 | 45 | 2 | 18 | 243 |
| Grand Total | 3 | 4 | 36 | 59 | 75 | 1 | 45 | 2 | 18 | 243 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|-------------------------|--|----------------|------------|--------------------------|-------------|----------|
| Grahamwood ES (2285) 2B | install floor tile in library-os | 7/24/13 | | | | Asbestos |
| Grahamwood ES (2285) 2B | The pipes in this classroom need to be rewrap. It looks as mold is on it. | 9/24/13 | Classroom | | # 214 | Asbestos |
| Grahamwood ES (2285) 2B | This classroom has a bad leak from this pipe . This pipe has a lot of mold forming on it. Please remove A. S. A. P. The teacher in this classroom has health issue. | 4/25/14 | Classroom | | # 320 | Asbestos |
| Grahamwood ES (2285) 2B | Att: Leslie Ratliff, In reference too work order # 160483; At the Principal request , we need a drop install in a room located on the stage. (SCS Network Cabling and Electronics dept. --"Please See Journal Notes") | 1/28/14 | Cafetorium | Room on located on Stage | | Cabling |
| Grahamwood ES (2285) 2B | The first computer drop is bad in this classroom.(Request Network Cabling Maintenance Repair).(Request Network Cabling Maintenance Repair). | 8/21/13 | Classroom | | 216 | Cabling |
| Grahamwood ES (2285) 2B | The Afterschool Director office is located on the stage. She need a network drop for her afterschool care telephone and computer. Also c lassroom # 227 need a telephone + network install for her telephone and computer. | 12/20/13 | Cafetorium | Stage | | Cabling |
| Grahamwood ES (2285) 2B | cLASSROOM # 106 NEED TELEPHONE REPAIR. (Request Network Cabling Maintenance Repair). (SCS Network Cabling and Electronics dept.--Response --"Please See Journal Notes") | 8/12/13 | Classroom | | # 106 | Cabling |

| | | | | | |
|----------------------------|---|----------|------------------------|--------------------------------------|-----------|
| Grahamwood ES (2285) 2B | FRONT ENTRY DOOR, CANT SECURE. SBE-DAVIS/416-5952 | 7/1/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | DOOR TO THE MECHANICAL RM IS NOT CLOSING AND THE BLDG CANNOT BE SECURED. SBE DAVIS 416-5952 | 7/2/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | We have a large Bullentin Board which need too be install in the Teacher Lounge. It has some very important information which need too be read by the employees. Please see Plant Manager or the Financial Secretary for further information. | 9/30/13 | Administration Area | Teacher Lounge | Carpentry |
| Grahamwood ES (2285) 2B | We have 2 paper towels holder which need too be install in the restroom. The Plant Manager do not have any tools too work with. | 10/2/13 | Restroom (Boys) | 3 rd floor | Carpentry |
| Grahamwood ES (2285) 2B | The Plant Manager is requesting too have a drop ceiling install in the Plant Manager Office. I have an allergic reactions to the blown insulation in the ceiling. | 9/4/13 | Custodial | Plant Manager Office | Carpentry |
| Grahamwood ES (2285) 2B | Panic bar on double doors leading to parking lot north end is coming loose from door per Ms. Davis 416-5952 | 9/25/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | We are requesting that the girls restroom on the 3rd floor, westend of hallway, restroom doors be inspected too see if there is a problem with the door lock sticking or the doors sticking. Please report too the Principal after completion of the | 11/12/13 | Restroom (Girls) | 3 rd Floor (westend of building) | Carpentry |
| Grahamwood ES (2285) 2B | We have a double door where the magnet holds it open from the top. It is not holding it open. | 11/13/13 | Hallway/Corri dor | Hallway across from Cafetoriumn | Carpentry |

| | | | | | | |
|-------------------------|---|---------|---------------------|--------------------------|--|-----------|
| Grahamwood ES (2285) 2B | front entrance door east end can't be opened and it is the door that is the security door per Ms. Davis 416-5952 said someone bolted it down | 12/4/13 | | | | Carpentry |
| Grahamwood ES (2285) 2B | There are about 6 or 7 pieces of ceiling tiles missing from the ceiling in the boys restroom . | 1/13/14 | Restroom (Boys) | 1 st Floor | | Carpentry |
| Grahamwood ES (2285) 2B | We have a lock which is broke on the restroom door. Please fix A. S. A. P. | 1/21/14 | Restroom (Girls) | Old Annex Hall | | Carpentry |
| Grahamwood ES (2285) 2B | At the Principal request, the following classroom windows need too be weatherize due too so much cold air is coming underneath the windows. Please service A. S. A. . | 1/24/14 | Classroom | # 109,203,244,303, & 318 | | Carpentry |
| Grahamwood ES (2285) 2B | We have a door in the Boys restroom which we cannot open. | 8/15/13 | Restroom (Boys) | Across from Main Office | | Carpentry |
| Grahamwood ES (2285) 2B | We have two outside doors exiting the building which will not close completely. Please see Plant Manager upon arrival at the school. | 8/19/13 | Hallway/Corridor | Westend of Building | | Carpentry |
| Grahamwood ES (2285) 2B | At the Principal request, We need too have the Safe bolted down too the top of the counter. | 7/15/13 | Administration Area | Financial Office | | Carpentry |
| Grahamwood ES (2285) 2B | The Glass in the Fire Extinguisher Case Door is broke. Please fix A. S. A. P. This is a safety hazard..... | 7/16/13 | Hallway/Corridor | Northend of Hallway | | Carpentry |

| | | | | | |
|----------------------------|--|---------|------------|-------------|-----------|
| Grahamwood ES (2285) 2B | ENTRANCE SOUTH FRONT- NOT CATCHING & (3) ENTRANCE DOORS BASEMENT AREA-ALL NOT CATCHING-WON'T BE ABLE TO SECURE-PLANT MGR 416- 5952 KLR | 8/28/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | HALL PARTITION HAS CAME A LOOSE EAST-END 3RD FLR BY STAIRWAY PLANT MGR-DAVIS/416.5952 | 8/28/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | Exterior doors out of kitchen are not closing good and can't secure and door in basement middle office door not closing per Ms. Davis 416-5952 | 9/12/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | another door in the basement won't close. it is an exterior door (2 others were fixed) per ms. davis 416-5952 | 9/13/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | 2nd floor front door on east end is not locking can't secure per Ms. Davis 416-5952 | 9/17/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | We have about 2 steps going onto the stage which are broke. They are split in half. This isa a safety hazard. | 9/18/13 | Cafetorium | Stage Steps | Carpentry |
| Grahamwood ES (2285) 2B | The Teacher in this classroom has problems with windows when it rain. There are 3 sets of windows in this classroom. The rain comes down the 1st & 3rd set of windows very hard. Please see Teacher for further information | 9/24/13 | Annex | (new # 276) | Carpentry |
| Grahamwood ES (2285) 2B | per ms davis 416-5952 the double cafeteria door (across from lounge) the center bar fell out | 2/10/14 | | | Carpentry |

| | | | | | |
|-------------------------|---|----------|------------------|------------------------|-----------|
| Grahamwood ES (2285) 2B | The Teacher in this classroom need a dry erase board install in this classroom. The former teacher in this classroom had her own personal dry erase board install in this classroom & when she left she took it down. She did some damage to the wall. We | 2/19/14 | Classroom | # 311 | Carpentry |
| Grahamwood ES (2285) 2B | The P. E. Teacher has a bulletin board and he need it install on the wall in the hallway. (Please see P. E. teacher or Plant Manager). | 2/19/14 | Hallway/Corridor | (Northend of Hallway) | Carpentry |
| Grahamwood ES (2285) 2B | FRONT ENTRY & EAST-END DOORS CANT SECURE PLANR MGR-DAVIS/416-5952 | 12/17/13 | | | Carpentry |
| Grahamwood ES (2285) 2B | per ms davis the back doors leading to main parking lot panic bars are not opening | 4/11/14 | | | Carpentry |
| Grahamwood ES (2285) 2B | The Teacher in this classroom has a large pull down screen. The large screen is connected to a piece of wood which screws into the wall, The wood is coming loose from the wall. Please fix A. S. A. P..... | 5/7/14 | Classroom | 213 (Main Hall) | Carpentry |
| Grahamwood ES (2285) 2B | The teacher in this classroom has 4 small dry erase board which need too be install. | 4/25/14 | Classroom | #250 (old annex) | Carpentry |
| Grahamwood ES (2285) 2B | DOOR PANIC BAR IS STUCK, CAN'T SECURE BY DUMPSTER PLANT MGR-DAVIS/416.5952 | 5/15/14 | | | Carpentry |
| Grahamwood ES (2285) 2B | drop ceiling in conference room,boilerroom area | 6/4/14 | 1st Floor | conference room | Carpentry |

| | | | | | |
|----------------------------|---|----------|------------------------|--|------------|
| Grahamwood ES (2285) 2B | door closure need adjusting,security a must,not closing properly | 6/4/14 | Administration Area | front door | Carpentry |
| Grahamwood ES (2285) 2B | leaking windows on to tile floor,renewing floors with wax | 6/10/14 | 3rd Floor | rm.320 | Carpentry |
| Grahamwood ES (2285) 2B | The Facilitator in this room wants the window too be able to open and close. We cannot open the window in this room. | 4/8/14 | Administration Area | # 226 | Carpentry |
| Grahamwood ES (2285) 2B | The Panic Bar is getting real loose on the door. Please fix A. S. A. P. | 9/24/13 | Hallway/Corri dor | Double Doors (Northend of Hallway) | Carpentry |
| Grahamwood ES (2285) 2B | A/C RMS 238 & 241-BOTH NOT COMING ON-PLANT MGR DAVIS 416-5952 KLR | 9/25/13 | | | Electrical |
| Grahamwood ES (2285) 2B | A/C OLD ANNEX RM 245-NOT COMING ON-PLANT MGR DAVIS 416-5952 KLR | 9/26/13 | | | Electrical |
| Grahamwood ES (2285) 2B | CEILING UNIT IS MAKING NOISE IN LIBRARY. PLANT MGR-DAVIS/416.5952 | 10/17/13 | | | Electrical |
| Grahamwood ES (2285) 2B | 2-RECEPTACLES HAVE NO POWER IN RM-250. PLANT MGR-DAVIS/416.5952 | 10/25/13 | | | Electrical |

| | | | | | | |
|----------------------------|--|----------|------------------------|------------------------------------|--|------------|
| Grahamwood ES (2285) 2B | 2-RECEPTACLES SHOOTING OUT FIRE RM-108. PLANT MGR-DAVIS/416.5952 | 10/25/13 | | | | Electrical |
| Grahamwood ES (2285) 2B | RECEPTACLES RM 108 BASEMENT AREA-MAKING A POPPING NOISE PER SBE- PLANT MGR DAVIS 416-5952 KLR | 10/29/13 | | | | Electrical |
| Grahamwood ES (2285) 2B | We need our clock set for Daylights Saving Time. | 11/4/13 | Administration Area | Main Office | | Electrical |
| Grahamwood ES (2285) 2B | The Thermostat in this classroom is dangling off of the wall. You can see the wire. | 11/12/13 | Classroom | # 305 | | Electrical |
| Grahamwood ES (2285) 2B | We have about 4 clocks on each hallway which the time need too be changed too the daylight savings time. Please A. S. A. P. | 11/13/13 | Hallway/Corri dor | 1st floor 2nd floor & 3rd floor | | Electrical |
| Grahamwood ES (2285) 2B | Grahamwood Elementary need 3 boxes of Flourescent Light Bulbs (flr. rapid start 30 / bx. 32 watts). | 11/15/13 | Custodial | Boiler Room | | Electrical |
| Grahamwood ES (2285) 2B | Ther are 3 sets of bulbs in this classroom which do not work. The bulb has been change and the light will not come on. | 12/2/13 | Classroom | 243 (old annex) | | Electrical |
| Grahamwood ES (2285) 2B | SEWAGE PUMPS EMERGENCY LIGHTS ARE ON IN BASEMENT PLANT MGR-DAVIS/416.5952 | 12/2/13 | | | | Electrical |

| | | | | | |
|-------------------------|---|---------|---------------------|---------------------------|------------|
| Grahamwood ES (2285) 2B | We have some lights out in this stairway area . The ceiling is very, very high up . We need a lift too help change the bulbs. | 1/10/14 | Hallway/Corridor | Stairwell / near room 320 | Electrical |
| Grahamwood ES (2285) 2B | BOILER HAS A BURNING SMELL BY CAFE. PLANT MGR-DAVIS/416.5952 | 1/13/14 | | | Electrical |
| Grahamwood ES (2285) 2B | RECEPTACLES HAVE NO POWER IN RM-111,112. PLANT MGR-DAVIS/416.5952 | 1/14/14 | | | Electrical |
| Grahamwood ES (2285) 2B | The Double Door in the Hallway Leading from old annex too the new annex is not working. The magnet will not hold the door open. | 1/15/14 | Hallway/Corridor | Double Magnetic Door | Electrical |
| Grahamwood ES (2285) 2B | Get quotes on electrical circuits/lighting/fans install on pavillion. | 1/16/14 | | | Electrical |
| Grahamwood ES (2285) 2B | PARTIAL POWER IN RM-111,112 PLANT MGR-DAVIS/416.5952 | 1/16/14 | | | Electrical |
| Grahamwood ES (2285) 2B | The light in the Teacher Lounge is out. The bulb has been changed here at Grahamwood Elementary. | 1/21/14 | Administration Area | Teachers Lounge | Electrical |
| Grahamwood ES (2285) 2B | HEAT RM 307-HAS NO POWER TO IT-PLANT MGR DAVIS 416-5952 KLR | 1/21/14 | | | Electrical |

| | | | | | |
|----------------------------|---|---------|------------------------|-------------|------------|
| Grahamwood ES (2285) 2B | The Flag is stuck on the flagpole. Please fix A. S. A. P. | 1/28/14 | Grounds | Flagpole | Electrical |
| Grahamwood ES (2285) 2B | We have about 2 set of lights out in the Cafetoriumn. They are to high for the Plant Manager to reach . You will need a small lift too change the bulbs.. | 1/30/14 | Cafetorium | Cafetoriumn | Electrical |
| Grahamwood ES (2285) 2B | NEW ANNEX IS NOT COMING ON. ZONE SUP. DEAN | 7/26/13 | | | Electrical |
| Grahamwood ES (2285) 2B | UV NOT COMING ON IN RM- 241(006) PLANT MGR-DAVIS/416.5952 | 7/30/13 | | | Electrical |
| Grahamwood ES (2285) 2B | The light on the front porch is out .This is a safety hazard. | 8/7/13 | Grounds | Front Porch | Electrical |
| Grahamwood ES (2285) 2B | The clock in the Main Office need to be set so when the r bell | 8/8/13 | Administration Area | Main Office | Electrical |
| Grahamwood ES (2285) 2B | Receptacle shot fire circuit out, no power. | 8/14/13 | Library | | Electrical |
| Grahamwood ES (2285) 2B | (2) A/C UNITS IN LIBRARY NOT COMING ON-SBE DAVIS 416- 5952 KLR | 8/19/13 | | | Electrical |

| | | | | | |
|----------------------------|--|---------|----------------------|-------------------------|------------|
| Grahamwood ES (2285) 2B | LIGHT IN WALK-IN COOLER- NOT COMING ON-SBE HAS CHANGED BULB, STILL NOT COMING ON-PLANT MGR DAVIS 416-5952 KLR | 8/19/13 | | | Electrical |
| Grahamwood ES (2285) 2B | Classroom 106 a/c not coming on at all per Ms. Davis 416-5952 | 8/20/13 | | | Electrical |
| Grahamwood ES (2285) 2B | repair burnt wires on Chiller | 7/10/13 | | | Electrical |
| Grahamwood ES (2285) 2B | LIGHTS - CAFE - HALF OF THEM ARE OUT & THEY ARE ARE WORKING IN THERE - SBE/DAVIS 416-5952 | 7/12/13 | | | Electrical |
| Grahamwood ES (2285) 2B | We have a prone broke off into the wall outlet near classroom # 219. (Eastend of Hallway). This is dangerous..... | 7/16/13 | Hallway/Corri dor | Near Classroom # 219 | Electrical |
| Grahamwood ES (2285) 2B | Rooftop unit NOT COMING ON it controls the area in the Cafeteria (Serving area) per Geraldine Davis, Plant Mgr. 901.416.5952. | 8/22/13 | | | Electrical |
| Grahamwood ES (2285) 2B | PUMP IS MAKING NOISE IN BASEMENT SEC-PAM/416.5952 | 9/9/13 | | | Electrical |
| Grahamwood ES (2285) 2B | A/C RMS 106 1ST FLR & RM 256 NEXT TO SBE'S OFC- BOTH NOT COMING ON- PLANT MGR DAVIS 416-5952 KLR | 9/11/13 | | | Electrical |

| | | | | | |
|-------------------------|--|----------|---------------------|-------------------------------|------------|
| Grahamwood ES (2285) 2B | The Teacher in this classroom had a burning smell coming from the computers or the outlet. Please fix A. S. A. P. | 9/18/13 | Classroom | # 215 | Electrical |
| Grahamwood ES (2285) 2B | HAS A COMPLETE POWER OUTAGE-PLANT MGR DAVIS 416-5952 KLR | 9/20/13 | | | Electrical |
| Grahamwood ES (2285) 2B | We need our clock change to Daylight Saving Time..... | 2/28/14 | Administration Area | Main Office | Electrical |
| Grahamwood ES (2285) 2B | We need a box of fluorescent light bulbs her at Grahamwood Elementary. | 2/17/14 | Custodial | Boiler Room | Electrical |
| Grahamwood ES (2285) 2B | Unit Ventilators in Rooms 204, 205, 206, 213, and 214 are NOT COMING ON per Geraldine Davis, Plant Mgr. 416.5952 | 12/10/13 | | | Electrical |
| Grahamwood ES (2285) 2B | per Ms. Davis 416-5952 pump in boiler room is making a really loud noise | 12/10/13 | | | Electrical |
| Grahamwood ES (2285) 2B | The front entrance of the school has about 3 sets of lights out in the entrance hallway. The lights are very, very high up. You will need a lift to change the lights. Also classroom # 216 has a set of lights out and the bulb has been changed. | 12/19/13 | 1st Floor | Front Entrance of School | Electrical |
| Grahamwood ES (2285) 2B | Att: Mr Otto S. We are having a problem with the Fire Alarm System in the Main Office. It is showing trouble. Security called to say we are having a problem with the system. | 12/20/13 | Administration Area | Main Office (High Priority) | Electrical |

| | | | | | |
|-------------------------|--|---------|---------------------|-------------|------------|
| Grahamwood ES (2285) 2B | The Bell in the Main Office is not ringing like it should. We has too ring it by hand. | 3/26/14 | Administration Area | Main Office | Electrical |
| Grahamwood ES (2285) 2B | We need the regular kind of light bulbs. # 37326. Qty. 30. 1 box please. | 3/31/14 | Custodial | Boiler Room | Electrical |
| Grahamwood ES (2285) 2B | per ms davis 416-5952 room 264 a/c not coming on at all | 4/3/14 | | | Electrical |
| Grahamwood ES (2285) 2B | 2nd request. The thermostat in this classroom is dangling off of the wall. Please fix A. S. A. P. | 4/8/14 | Classroom | # 305 | Electrical |
| Grahamwood ES (2285) 2B | We are still having a problem with the school bell ringing automatically. We have to ring it manual. Please fix. | 4/21/14 | Administration Area | Main Office | Electrical |
| Grahamwood ES (2285) 2B | per Ms. Davis 416-5852 no power to receptacles in principal's office, main office, secretary's office, lights are on | 1/9/14 | | | Electrical |
| Grahamwood ES (2285) 2B | LIGHTS HALLWAY OUTSIDE OFC & STAIRWELL NEXT TO OFC-NOT COMING ON-PLANT MGR DAVIS 416-5952 KLR | 4/10/14 | | | Electrical |
| Grahamwood ES (2285) 2B | BALLAST IS OUT IN SPECIAL NEED CLASS RM-240 OLD ANNEX. PLANT MGR-DAVIS/416.5952 | 4/24/14 | | | Electrical |

| | | | | | | |
|----------------------------|---|---------|---------------------|----------------------|--|---------------------------------------|
| Grahamwood ES (2285) 2B | UNIT NOT COMING ON IN RM-303 PLANT MGR-DAVIS/416.5952 | 5/14/14 | | | | Electrical |
| Grahamwood ES (2285) 2B | FIRE ALARM DOORS WONT CLOSE BACK TO WALL (HAVING SUMMER CAMP) PLANT MGR-JEFFERSON/644.1319 | 6/11/14 | | | | Electrical |
| Grahamwood ES (2285) 2B | re-set magnet holders,chains are to long,need wedges on floor in order to hold back doors,violation of codes,will not release during fire drills | 6/13/14 | Administration Area | doors main-hall | | Electrical |
| Grahamwood ES (2285) 2B | door magnet holder need repairing | 6/13/14 | 1st Floor | center hall doors | | Electrical |
| Grahamwood ES (2285) 2B | A/C UNIT is NOT COMING ON down KINDERGARTEN HALL per Horace Jefferson, Plant Mgr. 416.5952 | 6/30/14 | | | | Electrical |
| Grahamwood ES (2285) 2B | drop ceiling in conference room,boilerroom area, install lights. | 6/24/14 | 1st Floor | conference room | | Electrical |
| Grahamwood ES (2285) 2B | The Fire Marshal was here at Grahamwood & he found quite a few floodlights out throughout the school. Please fix A. S. A. P. Please check with Main Office or see Plant Manager for findings. | 4/2/14 | Hallway/Corridor | Classroom & Hallways | | Electrical |
| Grahamwood ES (2285) 2B | UNIT NOT COOLING IN MAIN & PRIN OFFICES PLANT MGR-DAVIS/416.8800 | 4/22/14 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|--|
| Grahamwood ES (2285) 2B | CHILLERS NOT COMING ON. PLANT MGR-DAVIS/416.5952 | 4/24/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 234-NOT COMING ON- PLANT MGR DAVIS 416-5952 KLR | 4/29/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHILLER is NOT COMING ON per Geraldine Davis, Plant Mgr. 416.5952 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHILLER NOT COMING ON plant mgr- JEFFERSON/416.5952 | 6/19/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C MAIN OFC & LIBRARY- BOTH NOT COOLING-PLANT MGR JEFFERSON 416-5952 KLR | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | per ms davis 416-5952 rooms 237 in old annex is blowing hot and also the cafeteria serving line blowing hot | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | replace comp on carrier chiller | 7/18/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|----------|--|--|--|
| Grahamwood ES (2285) 2B | A/C NOT COOLING IN RM 205- PLANT MGR DAVIS 416-5952 KLR | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHILLER NOT COMING ON . PLANT MGR-DAVIS/416.5952 | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C LIBRARY RM 219-MAKING NOISES & NOT COOLING- PLANT MGR DAVIS 416-5952 KLR | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 250-NOT COOLING- PLANT MGR DAVIS 416-5952 KLR | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 216-NOT COOLING- PLANT MGR DAVIS 416-5952 KLR | 9/5/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | no a/c in the entire building and condensation is so bad afraid that children may slip and fall on floor per Ms. McLoftin 416-5986 | 10/31/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | HEAT RMS 312, 318, & 278-ALL NOT HEATING-PLANT MGR DAVIS 416-5952 KLR | 11/15/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | HEAT RM 265 NEW ANNEX- OVERHEATING, TEMP IS 92 PER SBE-PLANT MGR DAVIS 416-5952 KLR | 11/15/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|----------|--|--|---------------------------------------|
| Grahamwood ES (2285) 2B | 4-CEILING UNITS ARE OVERHEATING (95) IN RM-229,206,264, LIBRARY, & 2-UNITS NOT HEATING IN RM-278,318 PLANT MGR-DAVIS/416.5952 | 11/19/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CEILING UNIT NOT HEATING IN RM-318. PLANT MGR-DAVIS/416.5952 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | 2-UNITS NOT HEATING IN RM-278,206 . PLANT MGR-DAVIS/416.5952 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Unit in Room 278 in the NEW ANNEX BUILDING is NOT HEATING per Geraldine Davis, Plant Mgr. 416.5852 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - Grahamwood Elm Air Compressor #025047 - Refer to PM schedule details. | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | 2-BOILERS NOT COMING ON THRU ENTIRE 1ST-2ND FLRS. PLANT MGR-DAVIS/416.5952 | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | per Ms. Davis 416-5952 the boiler in the old building is down - no heat | 1/15/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | 5-CEILING UNITS NOT HEATING IN MAIN OFFICE, RM-106,238,306,315 PLANT MGR-DAVIS/416.5952 | 1/16/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|--|
| Grahamwood ES (2285) 2B | Monthly - Oil, Lube, & Belt- Grahamwood Elem - Refer to PM schedule details. | 1/20/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHILLER IS NOT COMING ON/SBE DAVIS | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Chiller down per Ms. Davis 416- 5952 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Room 237 blowing hot air per Geraldine Davis 4165952 | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHILLER NOT COMING ON IN ANNEX BLDG . PLANT MGR-DAVIS/416.8800 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | UV OLD ANNEX RM 234-NOT COOLING-SBE DAVIS 416-5952 KLR | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | UNIT IN RM 272 IS BLOWING HOT AIR. SBE DAVIS 416-5952 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | NORTHEAST OF THE HALL HEATER IS BLOWING HOT AIR AND THEY CANNOT TURN THE UNIT OFF. SBE DAVIS 416- 5952 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|--|--|---------------------------------------|
| Grahamwood ES (2285) 2B | Room 106 unit ventilator not cooling per Ms. Davis 416-5952 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Unit Ventilators blowing hot air in Rm 238 and Rm 205W (id 025018) per Ms. Davis 416-5952 | 8/15/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | UV 1ST FLR RM 104 & FCU-12 NEW ANNEX RM 274-BOTH NOT COOLING-SBE DAVIS 416-5952 KLR | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C UNIT RM 238-NOT COOLING-SBE DAVIS 416-5952 KLR | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Per Ms. Davis 416-5952 the following rooms are not cooling - rm 238, 109 and the library | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | The chiller located on the north side of bldg. NOT COMING ON, ID#025-108 CH1! Per Ms. Geraldine, Plant Mgr. at 901.416.5952. | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - Grahamwood Elm Air Compressor #025047 - Refer to PM schedule details. | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | RTU SERVING LINE AREA & UV RM 238-BOTH NOT COOLING-PLANT MGR DAVIS 416-5952 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|----------|--|--|--|
| Grahamwood ES (2285) 2B | CEILING UNIT NOT COOLING IN RM-102 PER:DAVIS WANTS THERMOSTAT CHECK PLANT MGR-DAVIS/416.5952 | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHILLER NOT COMING ON. PLANT MGR-ADVIS/416.5952 | 9/6/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | 5-UNITS NOT COOLING IN RM- 211,110,256,241, ASSIST PRIN OFFICE SEC-PAM/416.5952 | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 250 OLD ANNEX-NOT COOLING-PLANT MGR DAVIS 416-5952 KLR | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | (old) chiller is down per Ms. Davis 416-5952 (not annex) | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | room 238 in old annex a/c not cooling per Ms. Davis 416-5952 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | UV NOT COOLING IN RM-215. PLANT MGR-DAVIS/416.5952 | 9/18/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Unit in Room 309 is NOT HEATING per Geraldine Davis, Plant Mgr. 416.5952 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|--|
| Grahamwood ES (2285) 2B | UNIT NOT HEATING IN RM-236 ANNEX PLANT MGR-DAVIS/416.5952 | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | UNIT NOT COOLING THE MAIN OFFICE E& THRU EAST-END RMS PLANT MGR-DAVIS/416.5952 | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Units in the Piano Room (inside Cafeteria) and Main Office are NOT HEATING per Geraldine Davis, Plant Mgr. 416.5952 | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 237 & 238-BOTH NOT COOLING-PLANT MGR DAVIS 416-5952 KLR | 4/29/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | replace comp in room 248 | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 226A-NOT COOLING- PLANT MGR DAVIS 416-5952 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | A/C RM 234 & 238 OLD ANNEX- BOTH NOT COOLING-PLANT MGR DAVIS 416-5952 KLR | 5/8/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|---------|------------------|---------------------------------------|
| Grahamwood ES (2285) 2B | The thermostat needs too be add in this classroom/ | 8/21/13 | Library | Library AreaHvac | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 3/7/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - Filter-Grahamwood Elementary - Refer to PM schedule details. | 12/30/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Yearly - Boiler 041-Grahamwood El-Annex Blr Rm - Refer to PM schedule details. | 3/16/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Yearly - Boiler 067 -Grahamwood El-Boiler Rm W - Refer to PM schedule details. | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Yearly - Boiler 068 -Grahamwood El-Boiler Rm E - Refer to PM schedule details. | 3/18/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 4/11/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 1/10/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|--|
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 6/6/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - Filter-Grahamwood Elementary - Refer to PM schedule details. | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 5/9/14 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 9/6/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 11/8/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 7/5/13 | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - Filter-Grahamwood Elementary - Refer to PM schedule details. | 9/2/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-------------------------|---|----------|------------------|----------------------|--|---------------------------------------|
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 10/11/13 | | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | Monthly - 1' Filters (Monthly)- Grahamwood Elem - Refer to PM schedule details. | 12/6/13 | | | | Heating/Ventilation /Air Conditioning |
| Grahamwood ES (2285) 2B | PAINT GAME STIPES IN FLOOR AREA,REMOVE EXITING TAPE | 6/11/14 | 1st Floor | CENTER HALL | | Painting |
| Grahamwood ES (2285) 2B | Pump sewer ejecter | 2/26/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | We have a water fountain which has water on the floor all of the time. This a safety hazard. | 8/30/13 | Hallway/Corridor | Eastend By office | | Plumbing |
| Grahamwood ES (2285) 2B | SEWAGE DRAIN IS BACKING UP ON WEST-END BLDG. PLANT MGR-DAVIS/416.8800 | 8/12/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | SINK B RR 3RD FLR EAST END FAUCET RUNNING AT FULL FORCE PER SBE, CAN'T CUT OFF-PLANT MGR DAVIS 416-5952 KLR | 9/26/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | We have a commode in the girls restroom which will not flush. Please fix A. S. A. P. | 10/1/13 | Restroom (Girls) | 2 nd floor (westend) | | Plumbing |

| | | | | | |
|----------------------------|---|----------|----------------------|-----------------------------|----------|
| Grahamwood ES (2285) 2B | sewage pump making noise. | 10/14/13 | | | Plumbing |
| Grahamwood ES (2285) 2B | STEAM TABLE NEEDS TO BE LIT IN CAFE. PLANT MGR-DAVIS/416.5952 | 10/25/13 | | | Plumbing |
| Grahamwood ES (2285) 2B | need toilet seat broken need replacement | 11/1/13 | Restroom (Girls) | 2nd annex | Plumbing |
| Grahamwood ES (2285) 2B | Test and repair RP Devices per MLG&W. | 11/5/13 | Mechanical Room | | Plumbing |
| Grahamwood ES (2285) 2B | SEWAGE BELL GOING OFF PER SBE-PLANT MGR DAVIS 416-5952 KLR | 11/20/13 | | | Plumbing |
| Grahamwood ES (2285) 2B | SINK WATER CONTINUES TO RUN IN B/RR 3RD FLR WESTEND. PLANT MGR/DAVIS/416.5952 | 11/25/13 | | | Plumbing |
| Grahamwood ES (2285) 2B | We need all of the water fountain adjusted thru- out the entire school. We are having a problem with too much water on the floors thru- out the school. | 11/25/13 | Hallway/Corri dor | Thru - Out Entire School | Plumbing |
| Grahamwood ES (2285) 2B | FLR DRAIN IS BACKING IN NORTH-WEST END OF BLDG. PLANT MGR-DAVIS/416.5952 | 12/3/13 | | | Plumbing |

| | | | | | |
|-------------------------|---|---------|------------------|---|----------|
| Grahamwood ES (2285) 2B | Look at noise pump with HVAC, clean adjacent strainer. | 12/4/13 | Mechanical Room | | Plumbing |
| Grahamwood ES (2285) 2B | sewer pump in basement light is on and water is halfway down hall per Ms. Davis 416-5952 | 1/13/14 | | | Plumbing |
| Grahamwood ES (2285) 2B | per ms davis 416-4825 on the lower level CR 101 there is water coming in the classroom because of the trench in the outdoor classroom is stopped up and backing into building | 2/4/14 | | | Plumbing |
| Grahamwood ES (2285) 2B | per ms davis 416-5952 the pump room light is on (usually means serious problems) | 2/5/14 | | | Plumbing |
| Grahamwood ES (2285) 2B | PILOT NEED TO BE LIT ON OVEN IN KITCHEN-SBE DOES NOT KNOW WHICH STOVE, SEE CAFE MGR-SBE DAVIS 416-5952 KLR | 8/5/13 | | | Plumbing |
| Grahamwood ES (2285) 2B | We have a commode in the Girls Restroom which will not flush. | 8/14/13 | 2nd Floor | Girls Restroom (Past Principal Office) | Plumbing |
| Grahamwood ES (2285) 2B | We have a commode in the girls restroom located on the 2nd floor which will not flush. It is located on the west end of the building. | 8/15/13 | Restroom (Girls) | West End of Building | Plumbing |
| Grahamwood ES (2285) 2B | Unstop sewer drain | 8/19/13 | | | Plumbing |

| | | | | | | |
|----------------------------|---|---------|----------------------|-----------------------------|--|----------|
| Grahamwood ES (2285) 2B | A/C UNIT IN LIBRARY LEAKING: SBE DAVIS 416-5952 KLR | 8/19/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | This classroom has a sink inside the classroom. It has a bad leak underneath it. Please fix A. S. A. P..... | 7/9/13 | Classroom | # 220 | | Plumbing |
| Grahamwood ES (2285) 2B | Dishmachine leaking. | 8/22/13 | Kitchen | | | Plumbing |
| Grahamwood ES (2285) 2B | UV IS LEAKING WATER IN RM- 241 PLANT MGR-DAVIS/416.5952 | 8/23/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | CEILING LEAK IN FIN SECRETARY OFFICE SEC-PAM/416.5952 | 9/9/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | Sewage bell going off in the basement per Ms. Davis 416- 5952 | 9/9/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | boys restroom 3rd floor east end, commode when flushed water is shooting out of it and 2nd floor east end urinal in boys restroom is leaking really bad per Ms. Davis 416-5952 | 9/17/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | We need all of the water fountain adjusted thru- out the entire school. We are having a problem with too much water on the floors thru- out the school. | 9/17/13 | Hallway/Corri dor | Thru - Out Entire School | | Plumbing |

| | | | | | | |
|----------------------------|--|----------|------------------------|------------------------|--|----------|
| Grahamwood ES (2285) 2B | FLUSH VALVE ON COMMODE IN FACULTY RR BASEMENT AREA-WHEN FLUSHED, WATER SHOOTS OUT EVERYWHERE PER SBE- PLANT MGR DAVIS 416-5952 KLR | 9/18/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | Repair RP device at the Green Houses. | 2/27/14 | Grounds | | | Plumbing |
| Grahamwood ES (2285) 2B | pump in main boiler room is not on per Ms. Davis 416-5842 | 12/12/13 | | | | Plumbing |
| Grahamwood ES (2285) 2B | BOILER - LEAKING BAD - WTR ALL OVER THE 1ST FLR - PM/DAVIS 416-5952 | 3/18/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | Sewer ordor | 3/21/14 | Administration Area | Assistant Prin. Office | | Plumbing |
| Grahamwood ES (2285) 2B | Repair damaged water hydrant at Hoop House (garden area) charge material to CNC. | 3/12/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | The sink in the Art room drains very slowly when water is in it. | 4/8/14 | Classroom | # 234 Art Room) | | Plumbing |
| Grahamwood ES (2285) 2B | In the girls restroom we have a commode which will not flush . Also we have a restroom where the lock is broke. Please fix A. S. A. P. | 4/23/14 | Restroom (Girls) | Old Annex | | Plumbing |

| | | | | | | |
|----------------------------|---|---------|----------------------|-----------------------------------|--|----------|
| Grahamwood ES (2285) 2B | COMMODE - OLD ANNEX HALL - G RR - CONSTANTLY RUNNING - PM/DAVIS 416-5952 | 4/24/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | UNIT IS LEAKING WATER IN RM-214 PLANT MGR-DAVIS/416.5952 | 4/10/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | TOILET is STOPPED UP in the BOY'S RR on the 3RD FLOOR per Geraldine Davis, Plant Mgr. 416.5952 | 5/16/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | Outdoor classroom in service test and repair. | 5/27/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | WATER TANK IS LEAKING WATER IN RM-260 BOILER RM, & B/RR 2-TOILETS ARE OVERFLOWING, CANT CONTROL OLD ANNEX BLDG. PLANT MGR-DAVIS/416.5952 | 2/20/14 | | | | Plumbing |
| Grahamwood ES (2285) 2B | We have a water fountain where both handles are broke. Please fix A. S. A. P. Located eastend of hall. | 4/28/14 | Hallway/Corri dor | 3rd Floor (eastend of hallway) | | Plumbing |
| Grahamwood ES (2285) 2B | The faucet in the boys' restroom is leaking very bad. Please fix A. S. A. P. | 9/25/13 | Restroom (Boys) | Eastend | | Plumbing |
| Grahamwood ES (2285) 2B | We have a pump leaking in the Boiler Room . Please fix A. S. A. P. | 2/19/14 | Mechanical Room | # 260 | | Plumbing |

| | | | | | |
|-------------------------|---|----------|---------------------|-----------------------------|-------------|
| Grahamwood ES (2285) 2B | There is a roof leak in this hallway near the Music Room. | 2/5/14 | Hallway/Corridor | (Old Annex Hall) | Roof |
| Grahamwood ES (2285) 2B | The Financial Secretary has a leak in her office. She seems to think it may be mold underneath the ceiling tiles, in her office. She has problem with her sinus and it don't happen until she comes too work. | 3/7/14 | Administration Area | Financial Secretary Office | Roof |
| Grahamwood ES (2285) 2B | This classrom has several lockers with broken handles. | 4/8/14 | Classroom | # 213 | Sheet Metal |
| Grahamwood ES (2285) 2B | The gate on the fence, latch is broke. Please fix . | 8/29/13 | Grounds | PK playground outside # 106 | Sheet Metal |
| Grahamwood ES (2285) 2B | LOCKER WONT OPEN & STUDENT'S ITEM IS LOCKED IN RM-312. PLANT MGR-DAVIS/416.5952 | 8/9/13 | | | Sheet Metal |
| Grahamwood ES (2285) 2B | The lock on the door facing of this unit ventilator is broke. It is tape down too keep the door from falling. | 11/14/13 | Annex | (old annex) # 241 | Sheet Metal |
| Grahamwood ES (2285) 2B | This classroom has a locker which is stuck and cannot be open. Also this classroom has about 5 or 6 lockers where the handle is about too come off. Please fix A. S. A. P..... | 8/8/13 | Classroom | # 402 | Sheet Metal |
| Grahamwood ES (2285) 2B | This classroom has several broken handles on the children lockers. Please fix A. S. A. P. | 8/15/13 | Classroom | # 220 | Sheet Metal |

| | | | | | |
|-------------------------|---|----------|-----------|----------------|-------------|
| Grahamwood ES (2285) 2B | This classroom has some lockers which need too be repaired. Also their are several lockers handlers which are broken. | 9/24/13 | Classroom | # 220 Eastend) | Sheet Metal |
| Grahamwood ES (2285) 2B | 6-LOCKER HANDLES HAVE BROKEN OFF, CANT OPEN TO GET PERSONAL ITEMS OUT IN RM-320 PLANT MGR- SCURLOCK/416.5952 | 12/11/13 | | | Sheet Metal |
| Grahamwood ES (2285) 2B | per ms davis 416-5952 room 214 there is a student locker that is stuck and can't open and child's personal belongings are in it | 3/18/14 | | | Sheet Metal |
| Grahamwood ES (2285) 2B | This classroom has several lockers where the handles are broken. | 4/8/14 | Classroom | # 203 | Sheet Metal |
| Grahamwood ES (2285) 2B | This classroom lockers has no locker facing on them at all. Please fix. | 4/8/14 | Classroom | # 211 | Sheet Metal |
| Grahamwood ES (2285) 2B | This classroom has several locker handles which are broken. | 4/8/14 | Clinic | # 305 | Sheet Metal |
| Grahamwood ES (2285) 2B | All of the lockers in this classroom need too be repaired. | 4/8/14 | Classroom | 215 | Sheet Metal |
| Grahamwood ES (2285) 2B | This classroom has some lockers with handles broke. They need too be repaired. | 4/8/14 | Classroom | # 309 | Sheet Metal |

| | | | | | |
|-------------------------|---|----------|-----------|------------------------|-------------|
| Grahamwood ES (2285) 2B | The majority of the handles on these lockers need to be replaced. | 4/8/14 | Classroom | # 315 | Sheet Metal |
| Grahamwood ES (2285) 2B | All of these classrooms has handles on the lockers which need to be replaced. Please fix A. S. A. P. | 4/8/14 | Classroom | # 316, 317, 318, & 319 | Sheet Metal |
| Grahamwood ES (2285) 2B | At the Principal request , he wants the lockers in this classroom replaced. They are in bad shape. | 4/8/14 | Classroom | 314 | Sheet Metal |
| Grahamwood ES (2285) 2B | This is the 2nd request. The Teacher in this classroom has 8 lockers where the handles are broken. They cannot close the lockers . Please fix A. S. A. P. | 10/23/13 | Classroom | # 220 | Sheet Metal |

| Count of Craft | Craft | | |
|-------------------------|----------|---------|-----------|
| | Asbestos | Cabling | Carpentry |
| Location | | | |
| rays Creek Admin 0000-2 | 2 | 2 | 28 |
| Grand Total | 2 | 2 | 28 |

| Location | Request Description | Submittal Date | Area Descript | Area Number | Craft |
|------------------------------|---|----------------|---------------|-------------------|-----------|
| Grays Creek Admin 0000-2A | MOLD - C BLDG IN PURCHASING @ ENTRANCE DR PM/SMITH 321-2248 | 4/24/14 | | | Asbestos |
| Grays Creek Admin 0000-2A | broken tile in room #2 | 6/20/14 | Clinic | room 2 | Asbestos |
| Grays Creek Admin 0000-2A | AccessDNSI (Service Call) test and repair fiber optical cable or otherwise at grays creek. Requested by Albert Herman (901- 626-4626) and Leslie Ratliff (901 301- 2661) Approved by Eddie Miller (Use this Work Order as Pre- Purchase Order) send invoice to Leslie Ratliff (email) (Request Network Cabling Maintenance Repair) | 8/5/13 | | | Cabling |
| Grays Creek Admin 0000-2A | Support needed for Teacher meeting with Superintendent | 9/25/13 | | | Cabling |
| Grays Creek Admin 0000-2A | Please install Bracket on wall in fitness center room 1222 for Germicide wipes. Thank you | 5/23/14 | 1st Floor | Fitness Center | Carpentry |
| Grays Creek Admin 0000-2A | Bins need to be reinforce to the wall. | 6/3/14 | 1st Floor | room 1130 | Carpentry |
| Grays Creek Admin 0000-2A | Door on the east side will not unlock. | 6/3/14 | 1st Floor | east side door | Carpentry |

| | | | | | |
|------------------------------|--|---------|-------------|---------------------------|-----------|
| Grays Creek Admin 0000-2A | Please seal window in office 2225 water is getting in when it rain. Thank you | 4/28/14 | 2nd Floor | Office 2225 | Carpentry |
| Grays Creek Admin 0000-2A | Please replace ceiling tile with sprinkler in warehouse D break room. Thank you | 4/30/14 | | Warehouse D break room | Carpentry |
| Grays Creek Admin 0000-2A | Overhead door in the maint whs is off track at door E-8. Thanks. | 6/13/14 | | | Carpentry |
| Grays Creek Admin 0000-2A | remove directors sign from inside the fence at Farmville and relocate Grays creek please complete this work order the week of January 27, 2014 | 1/27/14 | Parking Lot | 568-6069 | Carpentry |
| Grays Creek Admin 0000-2A | Repair ceiling grid in Benny's office. | 7/22/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Build frames for window darkening material for Valerie Speakman's office | 7/23/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Move Bobbi's office into Troy's old office | 7/23/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Clean out trucks and make ready for roofers. | 7/23/13 | | | Carpentry |

| | | | | | |
|------------------------------|--|---------|--------------|--|-----------|
| Grays Creek Admin 0000-2A | Unload and pack up all keys, key boxes, pinning kits, etc. on truck 1394 and give to Timmy Jones | 7/23/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Cut out and paint bathroom stall doors for Houston High | 7/30/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | refer to work order 365082 | 7/30/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Board up the EADs property | 4/2/14 | | | Carpentry |
| Grays Creek Admin 0000-2A | requesting 1 box of ceiling tile. number2910A. (cw0011) | 7/17/13 | Machine Shop | | Carpentry |
| Grays Creek Admin 0000-2A | Please cut sheet rock for fire sprinkler company. This is located in the auditorium. | 9/16/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Expand mailbox in office. | 7/24/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Clean up wood shop and install all guards on equipment | 7/24/13 | | | Carpentry |

| | | | | | |
|------------------------------|---|---------|-----------------|-----------|-----------|
| Grays Creek Admin 0000-2A | Sharpen blades on all in house machinery as needed | 7/18/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | replace broken pick handle, for concrete crew. | 7/18/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Repair mechanics cart | 7/18/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Move desk in Building C for John Pierce. | 7/18/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Need a Pallet Jack ramp installed for Shelby General warehouse. See Steffern Cunningham for details. | 7/29/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Please replace ceiling tiles with mold in break room near dock 4. Thanks. | 8/23/13 | | | Carpentry |
| Grays Creek Admin 0000-2A | Please leave 2 packages of 769A ceiling tiles CWOOO25 to administration building plant manager office 0011. Thank you | 4/30/14 | | | Carpentry |
| Grays Creek Admin 0000-2A | Take down the TV on the wall near the mechanical room 0020 and cut out the sheet rock. There is water coming from under the wall by the water heater. The condensate line has a hole in it. | 6/10/14 | Mechanical Room | Room 0020 | Carpentry |

| | | | | | |
|------------------------------|--|---------|------------|-----------------------|------------|
| Grays Creek Admin 0000-2A | The clinic has 2- tables that needs to be anchored to the wall. | 6/13/14 | Clinic | Grays Creek | Carpentry |
| Grays Creek Admin 0000-2A | Please check lights in office 1209 will not come on when you enter the room I have changed setting that do not work I am not sure how they works please let me know. Thank you | 5/5/14 | 1st Floor | Office 1209 | Electrical |
| Grays Creek Admin 0000-2A | Please check exhaust fan in hallway making noise East Region first floor thank you | 3/25/14 | 1st Floor | East Region | Electrical |
| Grays Creek Admin 0000-2A | Please check projector screen will not come down first floor conference room 1107 thank you | 3/27/14 | 1st Floor | Conference R. 1107 | Electrical |
| Grays Creek Admin 0000-2A | Please check light in office 2266 2nd floor not working also check hallway light through office 2266 at the end of the hall buzzing noise. Thank you | 5/8/14 | 2nd Floor | Office 2266 | Electrical |
| Grays Creek Admin 0000-2A | A/C UNIT is NOT COMING ON in the WEST WING of BUILDING per Margaret Irvin, Plant Mgr. 321.2248 | 6/24/14 | | | Electrical |
| Grays Creek Admin 0000-2A | A/C UNIT WEST WING - SHOWING CODE - CH87 - KEEPS TRIPPING - PM/ERVIN 473-2660 | 6/24/14 | | | Electrical |
| Grays Creek Admin 0000-2A | Please check lights in auditorium will not come on also lights on LOW LEVER hall and some rooms do not turn off controls do not work on 1st. floor. Thank you | 4/30/14 | Auditorium | Auditorium | Electrical |

| | | | | | |
|------------------------------|--|---------|--|--|------------|
| Grays Creek Admin 0000-2A | Put in new code. | 1/10/14 | | | Electrical |
| Grays Creek Admin 0000-2A | Operations Center Repair the wall pack. | 7/19/13 | | | Electrical |
| Grays Creek Admin 0000-2A | No power to recepticals in Mrs. Kite reception area. | 7/19/13 | | | Electrical |
| Grays Creek Admin 0000-2A | West double pole light in employee parking lot by warehouse is out. | 7/30/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Operations front lot South pole light is out. | 7/30/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Urgent test and turn in by 7/29/2013. Retest Generator. Sewer pumping station | 7/30/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Urgent test and turn in by 7/29/2013. Retest Generator. building D & gas pumps. | 7/30/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Urgent test and turn in by 7/29/2013. Retest Generator. building C. | 7/30/13 | | | Electrical |

| | | | | | |
|------------------------------|---|----------|--|----------------------|------------|
| Grays Creek Admin 0000-2A | All heaters in stairwells are not working. | 1/28/14 | | | Electrical |
| Grays Creek Admin 0000-2A | Run conduit and wire for line voltage t-stats in 3 mechanical rooms for electric heaters | 2/5/14 | | Admin AHU's rooms | Electrical |
| Grays Creek Admin 0000-2A | Burglar alarm panel mother board Transmitter failure. | 2/21/14 | | | Electrical |
| Grays Creek Admin 0000-2A | Building "C", need 4 new access codes to alarm system. Please program and and give to me. Thanks, Benny | 3/24/14 | | | Electrical |
| Grays Creek Admin 0000-2A | Verify burglar alarm data base. | 10/28/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Repair the main circuit in B building. | 8/12/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Repair the burglar alarm for B building. | 8/13/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Warehouse install access code for Ken White. | 7/26/13 | | | Electrical |

| | | | | | |
|------------------------------|--|---------|--|--|------------|
| Grays Creek Admin 0000-2A | Move electrical for office. | 8/6/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Add AV and phone lines for office. | 8/6/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Meet with electrician At the Coe to shut down the burglar alarm system. | 7/25/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Provide George Dean with codes and profiles of all burglar alarm systems. | 7/25/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Several conference rooms have the can lights programmed with the flourescent lights. these need to be separated. | 7/19/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Exits Lights not working in bus shop and wood shop | 7/25/13 | | | Electrical |
| Grays Creek Admin 0000-2A | need a couple lights installed in the Shelby General Warehouse. | 9/5/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Broken Receptacle - Breaker keeps tripping, will not stay on. | 9/11/13 | | | Electrical |

| | | | | | |
|------------------------------|---|---------|---------------------|----------------------------|------------|
| Grays Creek Admin 0000-2A | Please have Electrician to look at small bulb with no number to see if it can be replaced I have it in my office. Thank you | 4/4/14 | | LL Plant manager room 0011 | Electrical |
| Grays Creek Admin 0000-2A | Please install Burglar alarm code for Pamela Anderson in Transportation she do not have a code. Thank you | 4/10/14 | | Transportation | Electrical |
| Grays Creek Admin 0000-2A | Please check Transfer Switch in alarm mechanical room 0020 thank you | 4/28/14 | | LL IEVER | Electrical |
| Grays Creek Admin 0000-2A | Please ceiling tile with intercom speaker in warehouse D break room. Thank you | 4/30/14 | | Warehouse D break room | Electrical |
| Grays Creek Admin 0000-2A | Alarm panel reading Transmit - Trouble, sounding off alarm | 3/10/14 | Administration Area | | Electrical |
| Grays Creek Admin 0000-2A | 2- pole lights out, one on the east side and one in the front. | 6/5/14 | Mechanical Room | parking lot | Electrical |
| Grays Creek Admin 0000-2A | Light ballast out in women restroom in the clinic. | 6/9/14 | Clinic | women restroom | Electrical |
| Grays Creek Admin 0000-2A | Please check Light in Clinic file room not working have changed bulbs. Thank you | 5/12/14 | Clinic | Clinic | Electrical |

| | | | | | |
|------------------------------|--|---------|------------------|--------------------|---------------------------------------|
| Grays Creek Admin 0000-2A | Please check light in Clinic Electrical room not working have changed bulbs. Thank you | 5/13/14 | Clinic | Electrical room | Electrical |
| Grays Creek Admin 0000-2A | Light ballast out in clinic . | 6/30/14 | Clinic | Room #1 | Electrical |
| Grays Creek Admin 0000-2A | Light ballast out in clinic. Room 1 | 6/30/14 | Clinic | examination Room 1 | Electrical |
| Grays Creek Admin 0000-2A | warehouse D girls bathroom light fixture need ballast | 8/12/13 | Restroom (Girls) | | Electrical |
| Grays Creek Admin 0000-2A | Repair the fans restrooms. Operations center | 7/19/13 | | | Electrical |
| Grays Creek Admin 0000-2A | Repair the fans wood shop. Operations center | 7/19/13 | | | Electrical |
| Grays Creek Admin 0000-2A | need ballast in light fixture in HVAC office B Building | 7/19/13 | | B building | Electrical |
| Grays Creek Admin 0000-2A | The air is down on the west side, The Thermostat is reading CH21. | 6/16/14 | 1st Floor | all-First floor | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|---|---------|---------------------|-----------------------|---------------------------------------|
| Grays Creek Admin 0000-2A | Please check water leak air hand duct work in air handle room 1st floor break room 1160 and duct work LL in exit hallway by elevator. Thank you | 3/28/14 | 1st Floor | 1160 Break Area | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | Removing freon from units. | 2/26/14 | Grounds | | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | Check noise in 2 area's | 3/28/14 | | | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | WAREHOUSE COOLER FRONT SENSOR IS READING +327 | 9/11/13 | | WAREHOUSE COOLER | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | THREE OF THE FOUR RTU'S ARE OFF LINE | 9/11/13 | | IT & FOOD SERVICES | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | Ac in break room not working. Shelby General Warehouse Dock 2. See Steffern for questions. 321-2207 | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | Air Conditioners in Terry and Steffern's office needs to be serviced. Turned fans on low and unit had a really bad burning smell. Water is leaking onto carpet below AC unit. Shelby General Warehouse Dock 2 | 9/16/13 | | 901-321-2204 | Heating/Ventilation /Air Conditioning |
| Grays Creek Admin 0000-2A | The thermostats in office 1222, 1216, 1217 keep turning off. Air will not come back on. | 6/11/14 | Administration Area | office 1216,1217,1222 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------------|--|----------|-----------|-------------------------|----------|
| Grays Creek Admin 0000-2A | Paint plywood that was put up to cover the windows and doors at the old Eads Building | 5/29/14 | | | Painting |
| Grays Creek Admin 0000-2A | paint walls in bldg. | 5/22/14 | | | Painting |
| Grays Creek Admin 0000-2A | Need lines painted at the dock bays for deliveries For shelby General warehouse and Parts Warehouse - Contact Steffern cunningham for questions 321-2207 | 11/14/13 | | | Painting |
| Grays Creek Admin 0000-2A | Please mud sheet rock and paint where Fire Sprinkler repairs were made. This is located in the Auditorium. | 9/17/13 | | | Painting |
| Grays Creek Admin 0000-2A | paint office complex | 8/20/13 | | | Painting |
| Grays Creek Admin 0000-2A | Supply room in the transportation building has a water leak coming from the ceiling. | 6/17/14 | 1st Floor | Transportation Building | Plumbing |
| Grays Creek Admin 0000-2A | There is a water in office 2201 coming from the ceiling. | 6/19/14 | 2nd Floor | Office 2201 | Plumbing |
| Grays Creek Admin 0000-2A | A/C MAINTENANCE BLDG C BREAKRM-LEAKING-CALLED IN BY MELANIE LANG KLR | 6/26/14 | | | Plumbing |

| | | | | | |
|------------------------------|--|---------|--|----------------------------|----------|
| Grays Creek Admin 0000-2A | Transportation building has a water leak. | 6/30/14 | | Transportation building | Plumbing |
| Grays Creek Admin 0000-2A | Shelby General Warehouse - Backflow preventor is leaking. This is located right outside Terry's office door. | 11/1/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | Test the following RPs. SS 460488 2" 909 Watts SS 460296 2" 909 Watts | 5/14/14 | | | Plumbing |
| Grays Creek Admin 0000-2A | Please check the sewer smell in the ladies restroom in the warehouse. See Terry | 7/30/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | Drains backing up in the basement. | 3/24/14 | | | Plumbing |
| Grays Creek Admin 0000-2A | Repair the man hole near the fence. | 8/13/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | Move furniture in several offices. | 7/16/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | Repair the leaking line on the air compressor. | 8/5/13 | | | Plumbing |

| | | | | | |
|------------------------------|--|---------|---------------------|--|----------|
| Grays Creek Admin 0000-2A | Please meet with Kirk at Sheffield High school. Carry the large sewer truck and camera line. | 7/26/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | Please empty truck 1466. and move contents of truck 1381 into 1466. | 7/24/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | Unload truck# 1454 move into truck#1401. | 7/18/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | grass crew ran over water line clinic no water | 8/5/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | B BUILDING bOYS bathroom faucet leaking | 8/6/13 | | | Plumbing |
| Grays Creek Admin 0000-2A | administration bldg girls bathroom first floor turn on water from sink very slow | 8/6/13 | Administration Area | | Plumbing |
| Grays Creek Admin 0000-2A | leaking water value in bus shop basement by oil tanks | 7/24/13 | Administration Area | | Plumbing |
| Grays Creek Admin 0000-2A | mechanical room behind building A flooded with water | 8/15/13 | Mechanical Room | | Plumbing |

| | | | | | |
|------------------------------|--|---------|-----------------|-----------------|-------------|
| Grays Creek Admin 0000-2A | Mechanical room 0020 there is water coming from under the wall by the water heater. | 6/5/14 | Mechanical Room | Room 0020 | Plumbing |
| Grays Creek Admin 0000-2A | bathroom toilet continually running | 7/29/13 | Clinic | | Plumbing |
| Grays Creek Admin 0000-2A | Please check leaking roof in air handle room 1st floor break room 1160 and LL lever in exit hallway by elevator. Thank you | 3/31/14 | 1st Floor | Air Handle Room | Roof |
| Grays Creek Admin 0000-2A | Office 2205 has a water leak. | 6/16/14 | 2nd Floor | office 2205 | Roof |
| Grays Creek Admin 0000-2A | Please repair roof leak in warehouse D in break room. Thank you | 4/30/14 | | Break Room | Roof |
| Grays Creek Admin 0000-2A | Part Warehouse - Warehouse roll-up door will not close. We will not be able to set alarm until door is closed. Please call Melanie Lang for questions 321-2264 | 1/22/14 | | 321-2264 | Sheet Metal |
| Grays Creek Admin 0000-2A | Repair vise on truck 1346 | 7/23/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | hang locking cabinet on wall | 7/23/13 | | A/C Shop | Sheet Metal |

| | | | | | |
|------------------------------|--|---------|--|--------------|-------------|
| Grays Creek Admin 0000-2A | Clean out truck 1468 | 7/30/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | repair tool bins on truck 1453 | 7/30/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | Need 2 plates made for Scott Halliburton | 7/30/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | Please repair the AC duct where Fire Sprinkler repairs were made. | 9/17/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | Make 12 Wall plates for electrician. these are for wall pacs being put up by Richard Martin. | 7/26/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | Make sure all equipment is secured to the floor in metal shop. | 7/24/13 | | | Sheet Metal |
| Grays Creek Admin 0000-2A | Service Bay door not working - The door stopped working half way up. The door is now closed but it will not open. Please call Steffern with Questions @ 321-2207 | 8/30/13 | | 901-321-2204 | Sheet Metal |
| Grays Creek Admin 0000-2A | Shelby General Warehouse Dock 2. Warehouse roll-up door will not go all the way down, even manually. | 9/19/13 | | | Sheet Metal |

| Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
|------------|------|----------|----------|------|-------------|-------------|
| 46 | 9 | 5 | 21 | 3 | 11 | 127 |
| 46 | 9 | 5 | 21 | 3 | 11 | 127 |

| Count of Craft | Craft | | | | | |
|---------------------|-----------|------|----------|----------|------|-------------|
| Location | Carpentry | HVAC | Painting | Plumbing | Roof | Grand Total |
| Grays Creek Bus Lot | 9 | 2 | 1 | 5 | 1 | 18 |
| Grand Total | 9 | 2 | 1 | 5 | 1 | 18 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|---------------------|--|----------------|----------|-------------|-------------|-----------|
| Grays Creek Bus Lot | Remove cabinets from old roofing/flooring office and take to wood shop | 8/7/13 | | | | Carpentry |
| Grays Creek Bus Lot | paper towel dispenser and tissue dispenser need to be put in girls and boys bathroom | 8/9/13 | Restroom | (Boys) | | Carpentry |
| Grays Creek Bus Lot | Building "A", cut and install one cased doorway and remove one existing door w/frame and frame as cased doorway. | 8/15/13 | | | | Carpentry |
| Grays Creek Bus Lot | #121 passenger side windshield cracked | 1/10/14 | | | | Carpentry |
| Grays Creek Bus Lot | Bus 159 windshield is cracked on the right side bottom to the top. | 2/24/14 | | | | Carpentry |
| Grays Creek Bus Lot | Bus 328 both side of windshield is cracked. | 3/17/14 | | | | Carpentry |
| Grays Creek Bus Lot | Bus 39 driver's side windshield is crack from the top to bottom. | 4/28/14 | | | | Carpentry |

| | | | | | |
|---------------------|---|---------|--|-------------------|---------------------------------------|
| Grays Creek Bus Lot | Bus 128 left side windshield is cracked. | 5/1/14 | | | Carpentry |
| Grays Creek Bus Lot | #180 rear door emergency glass needs to be replaced | 5/6/14 | | | Carpentry |
| Grays Creek Bus Lot | G Building Gray's Creek NO AIR Conditioning | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Grays Creek Bus Lot | No A/C in office | 5/23/14 | | Bus shop office | Heating/Ventilation /Air Conditioning |
| Grays Creek Bus Lot | Building "A", Repair sheetrock, mud, sand and paint where two cased doorways installed in Transportation Offices. | 8/15/13 | | | Painting |
| Grays Creek Bus Lot | Sink backing up. | 1/14/14 | | Managers Building | Plumbing |
| Grays Creek Bus Lot | PRESSURE WASHER PIPE BUSTED | 2/25/14 | | | Plumbing |
| Grays Creek Bus Lot | Repair leak on bus washing machine | 3/19/14 | | | Plumbing |

| | | | | | |
|---------------------|---|---------|--|--|----------|
| Grays Creek Bus Lot | Transportation office ladies restroom has a toilet stopped up that will not flush | 5/2/14 | | | Plumbing |
| Grays Creek Bus Lot | transportation office in Building A has a kitchen sink stopped up | 1/13/14 | | | Plumbing |
| Grays Creek Bus Lot | Bus 92 driver side headlight out, check passenger side emergency window | 4/3/14 | | | Roof |

| Count of Craft | Craft | |
|----------------------|-----------|-------------|
| Location | Carpentry | Grand Total |
| Grays Creek Clinc 2A | 1 | 1 |
| Grand Total | 1 | 1 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|----------------------|----------------------------|----------------------|----------------------|--------------------|--------------|
| Grays Creek Clinc 2A | Repair floor in clinic | 6/23/14 | | | Carpentry |

| Count of Craft | Craft | | | | | | | Grand Total |
|----------------------|----------|----------|-----------|------------|------|----------|----------|-------------|
| | Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | |
| Jackson ES (2360) 2B | 1 | 24 | 36 | 40 | 1 | 23 | 1 | 126 |
| Grand Total | 1 | 24 | 36 | 40 | 1 | 23 | 1 | 126 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|----------------------|---|----------------|-----------|----------------|-------------|-----------|
| Jackson ES (2360) 2B | Cracked floor tile in classroom 202 | 9/23/13 | Classroom | RM 202 | | Asbestos |
| Jackson ES (2360) 2B | The entire window pane is OUT. There was a break-in over the weekend per Ms. Marlo at 901.416.5904. | 8/19/13 | | | | Carpentry |
| Jackson ES (2360) 2B | Door closer need to be fixed or repaired. Door will not secure on it's own | 9/5/13 | Cafeteria | back exit door | | Carpentry |
| Jackson ES (2360) 2B | Repair or replace screen on iron door | 9/11/13 | Kitchen | | | Carpentry |
| Jackson ES (2360) 2B | reinforce wood planks on ramp and platform of portable 307 (SAFETY HAZARD) | 9/11/13 | Portables | 307 | | Carpentry |
| Jackson ES (2360) 2B | IT inside entrance door will not lock | 7/19/13 | | IT Entrance | | Carpentry |
| Jackson ES (2360) 2B | reinforce wood planks and slacks on ramps and steps | 7/31/13 | Portables | P307-P285-P286 | | Carpentry |

| | | | | | |
|----------------------|--|----------|------------------|-----------|-----------|
| Jackson ES (2360) 2B | CEILING IS CAVING IN G/RR 1ST FLR EAST-WING PLANT MGR-COX/416.4222 | 8/13/13 | | | Carpentry |
| Jackson ES (2360) 2B | Repair restroom stall door | 10/24/13 | Restroom (Girls) | West Wing | Carpentry |
| Jackson ES (2360) 2B | Broken spindles on the ramp of portable 285 | 10/28/13 | Portables | 285 | Carpentry |
| Jackson ES (2360) 2B | CEILING ROD HAS FALLEN IN PORT-286. PLANT MGR-COX/596.2039 | 10/29/13 | | | Carpentry |
| Jackson ES (2360) 2B | The Emergency exit window in RM 109 is leaking water from the rain | 10/31/13 | Classroom | RM 109 | Carpentry |
| Jackson ES (2360) 2B | FLR IS SINKING IN PORT-281. PLANT MGR-COX/416.4222 | 11/12/13 | | | Carpentry |
| Jackson ES (2360) 2B | Wood plank on ramp side of portable 286 needs repairing. The support beams underneath the plank has fallen off causing the plank to have no support. | 12/9/13 | Portables | P.286 | Carpentry |
| Jackson ES (2360) 2B | WINDOW BROKEN OUT ON PORT 139-WON'T BE ABLE TO SECURE-PLANT MGR COX 416-5904 KLR | 1/2/14 | | | Carpentry |

| | | | | | | |
|----------------------|--|---------|---------------------|-----------------|--|-----------|
| Jackson ES (2360) 2B | Window is KNOCKED OUT of Portable #139 (on parking lot side) per Dorothy Hale, Plant Mgr. 416.5904 | 1/2/14 | | | | Carpentry |
| Jackson ES (2360) 2B | Replace damaged window | 4/4/14 | 1st Floor | Rm.103 | | Carpentry |
| Jackson ES (2360) 2B | Reinforce plywood on ramp side of portable 307 | 5/6/14 | Portables | Portable 307A | | Carpentry |
| Jackson ES (2360) 2B | Door knob needs repairing. It's hard to twist the knob to get in and out of the classroom. | 1/22/14 | Classroom | Rm. 106 | | Carpentry |
| Jackson ES (2360) 2B | Door will not lock | 1/28/14 | 2nd Floor | Rm. 210 | | Carpentry |
| Jackson ES (2360) 2B | Replace flag pole pull wire | 2/27/14 | Administration Area | front of School | | Carpentry |
| Jackson ES (2360) 2B | Doorknob not working properly | 6/2/14 | 1st Floor | Rm 106 | | Carpentry |
| Jackson ES (2360) 2B | Serving line tray rail needs replacing | 1/9/14 | Cafeteria | serving line | | Carpentry |

| | | | | | |
|----------------------|--|---------|------------------|-----------|------------|
| Jackson ES (2360) 2B | CEILING CAFE SERVING LINE-HAS CAVED IN ABOVE DROP CEILING-NO WATER IS PRESENT-PLANT MGR COX 416-5904 KLR | 6/19/14 | | | Carpentry |
| Jackson ES (2360) 2B | The brand new Door knob is not working properly. | 6/20/14 | 1st Floor | Rm.106 | Carpentry |
| Jackson ES (2360) 2B | UV NOT COMING ON IN PORT-285. PLANT MGR-COX/674.8700 | 8/16/13 | | | Electrical |
| Jackson ES (2360) 2B | A/C IN PORT 285-NOT COMING ON-SBE COX 416-5904 KLR | 8/22/13 | | | Electrical |
| Jackson ES (2360) 2B | AHU NOT COMING ON IN CAFE PLANT MGR-COX/416.4222 | 9/12/13 | | | Electrical |
| Jackson ES (2360) 2B | PORT 139-NOT COMING ON-PLANT MGR COX 416-5904 KLR | 10/4/13 | | | Electrical |
| Jackson ES (2360) 2B | Bad ballast in cafeteria | 7/18/13 | | | Electrical |
| Jackson ES (2360) 2B | bad ballast | 7/23/13 | Hallway/Corridor | 2nd floor | Electrical |

| | | | | | |
|----------------------|---|----------|---------------------|----------------------|------------|
| Jackson ES (2360) 2B | bad ballasts | 8/6/13 | 2nd Floor | Rm. 205 | Electrical |
| Jackson ES (2360) 2B | need one case of T-8 fluorescent light bulbs | 8/6/13 | Custodial | Plant Manager office | Electrical |
| Jackson ES (2360) 2B | Need 10 light bulbs for stairwell light fixture model GU24 Springlamp 13W and a case of 13 watt duo tube compact fluorescent base GX23 DT13/41 | 10/14/13 | Administration Area | Plant Manager | Electrical |
| Jackson ES (2360) 2B | SCHOOL BELL CONTINUES TO RING THRU BLDG. PLANT MGR-COX/416.4222 | 10/22/13 | | | Electrical |
| Jackson ES (2360) 2B | 5 Exit lights need fixing or repairing 1) East wing stairwell 2) Main hall near main office 3) Across from Rm. 108 4) Mid stairwell 5) 2nd floor Near Rm. 201 & 5 Emergency lights need replacing 4) main hall area | 10/22/13 | 1st Floor | Main Hall | Electrical |
| Jackson ES (2360) 2B | bad ballast | 10/24/13 | Classroom | Rm. 204 | Electrical |
| Jackson ES (2360) 2B | Bad ballast | 11/1/13 | Classroom | Rm 201 | Electrical |
| Jackson ES (2360) 2B | Set master clock | 11/2/13 | Administration Area | | Electrical |

| | | | | | |
|----------------------|---|----------|---------------------|---------------------|------------|
| Jackson ES (2360) 2B | Replace light bulb on the outside security light pole between Portables 285 & 139 | 11/4/13 | Parking Lot | Between P285 & P139 | Electrical |
| Jackson ES (2360) 2B | UV IS MAKING NOISE IN RM-103 PLANT MGR-COX/416.4222 | 11/13/13 | | | Electrical |
| Jackson ES (2360) 2B | UV TEACHER'S LOUNGE- NOT COMING ON-PLANT MGR COX 416-5904 KLR | 11/14/13 | | | Electrical |
| Jackson ES (2360) 2B | BAD BALLAST | 11/20/13 | Classroom | RM 109 | Electrical |
| Jackson ES (2360) 2B | Bad Ballast | 11/20/13 | Classroom | RM 104 | Electrical |
| Jackson ES (2360) 2B | Need 2 cases of T-8 light bulbs | 11/21/13 | Administration Area | Plant Manager | Electrical |
| Jackson ES (2360) 2B | Bad Ballast | 11/22/13 | Portables | 307 A | Electrical |
| Jackson ES (2360) 2B | bad ballast | 11/27/13 | Hallway/Corridor | 2nd floor | Electrical |

| | | | | | |
|----------------------|--|----------|---------------------|--------------------------|------------|
| Jackson ES (2360) 2B | bad ballast | 12/11/13 | 2nd Floor | Library | Electrical |
| Jackson ES (2360) 2B | Bad Ballast | 1/3/14 | 1st Floor | Rm 104 | Electrical |
| Jackson ES (2360) 2B | per ms cox 416-5904 t'stat in portable 280 is not working | 3/20/14 | | | Electrical |
| Jackson ES (2360) 2B | Emergency lights not working 1 Kitchen 3 Cafeteria 1 Portable 307B 1 Across from rm. 207 and 1 in mid stairwell on top landing | 4/1/14 | | over the entire building | Electrical |
| Jackson ES (2360) 2B | Bells are not ringing | 4/2/14 | Administration Area | 1st and 2nd floor | Electrical |
| Jackson ES (2360) 2B | Bad ballasts in room 210 | 4/21/14 | 2nd Floor | Rm. 210 | Electrical |
| Jackson ES (2360) 2B | Electrical outlet making humming sound | 5/2/14 | Portables | Portable 307 B | Electrical |
| Jackson ES (2360) 2B | 2 Bad ballast | 5/7/14 | | Rm. 104 | Electrical |

| | | | | | |
|----------------------|--|---------|---------------------|---------------|---------------------------------------|
| Jackson ES (2360) 2B | Bad Ballast | 5/21/14 | 2nd Floor | Rm.202 | Electrical |
| Jackson ES (2360) 2B | Need 5 cases of 13 watt compact flouresnt light bulbs | 1/17/14 | Custodial | Plant Manager | Electrical |
| Jackson ES (2360) 2B | UV in room 211 no power per ms cox 416-5904 | 2/4/14 | | | Electrical |
| Jackson ES (2360) 2B | Bad ballast.....Attention Richard Powell | 2/4/14 | 2nd Floor | Rm.211 | Electrical |
| Jackson ES (2360) 2B | UNIT IS MAKING NOISE IN RM-103 PLANT MGR-COX/416.4222 | 2/6/14 | | | Electrical |
| Jackson ES (2360) 2B | Set Master Clock for Day Light Saving Time | 3/4/14 | Administration Area | Main office | Electrical |
| Jackson ES (2360) 2B | CHILLER MECH RM-NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR COX 416-5904 KLR | 5/22/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | AIR HANDLING UNIT is MAKING A LOUD NOISE in the CAFETERIA per Marlo Cox, Plant Mgr. 416.5904 | 6/18/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|--|---------|-----------|---------------------------|---------------------------------------|
| Jackson ES (2360) 2B | Units are NOT HEATING in ROOMS 104, 106, 108, 112, 208, 210, 212, and 214 per Marlo Cox, Plant Mgr. 416.5904 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Units are OVERHEATING in ROOMS 101, 103, 110, 201, 205, 207, and 211 per Marlo Cox, Plant Mgr. 416.5904 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Monthly - Filter-Jackson Elementary - Refer to PM schedule details. | 2/17/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | per Marlo Cox 416-5904 teacher's lounge unit is not working properly - not heating | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | per ms cox 416-5904 portable 280 is blowing cold air | 3/6/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Clean outside coils on unit ventilator | 8/14/13 | Portables | P280, P286, P139, P307A&B | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Coils on chiller need cleaning | 8/14/13 | | outside Chiller | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | A/C PORT 139-NOT COOLING-PLANT MGR COX 416-42222 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|----------|--|--|---------------------------------------|
| Jackson ES (2360) 2B | AHU-1 & AHU-4 CAFE- BOTH ARE IN ALARM- PLANT MGR COX 416-4222 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | AHU-2 & AHU-3 CAFE- BOTH NOT COOLING- PLANT MGR COX 416-4222 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Unit ventilator room 109 not cooling per Marlo Cox 416- 5904 | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | AHU NOT COOLING IN RM- 104,212 PLANT MGR-COX/416.4222 | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | AHU NOT COOLING IN CAFE PLANT MGR-COX/416.4222 | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Monthly - Oil Lube & Belt- Jackson Elem - Refer to PM schedule details. | 10/12/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | UNIT IN RM 108 IS NOT COOLING. SBE COX 416- 5904 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Chiller down per EMS 7.15.13 | 7/20/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|----------|--|--|---------------------------------------|
| Jackson ES (2360) 2B | UNIT IN RM 214 IS NOT COOLING. SBE COX 416-5904 | 7/23/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | UV NOT COOLING IN PORT-139. SBE COX 596.2039 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Portable 281 not cooling per Marlo Cox 416-5904 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | A/C IN PORT 285-NOT COOLING-SBE COX 416-5904 KLR | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Portable 139 the heating unit is making a loud humming noise per Ms. Cox 416-5904 | 10/25/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | UV NOT HEATING IN RM-100 TEACHERS' LOUNGE. PLANT MGR-COX/416.4222 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | BOILER#2 HAS A FLAME FAILURE PLANT MGR-COX/596.2039 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | UV OVERHEATING (80)IN RM-101 PLANT MGR-COX/416.4222 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|----------|-----------------|--|---------------------------------------|
| Jackson ES (2360) 2B | HEAT PORT 281-NOT HEATING-PLANT MGR COX 416-5904 KLR | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | HEAT RM 103-MAKING NOISES-PLANT MGR COX 416-5904 KLR | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | BOILER-2 SHUTTING DOWN-PLANT MGR COX 416-5904 KLR | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | repair boiler down per EMS | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | remove and install 2 boiler. | 5/13/14 | Mechanical Room | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Monthly - Oil Lube & Belt- Jackson Elem - Refer to PM schedule details. | 5/17/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | UNIT NOT HEATING IN PORT-281 PLANT MGR-COX/596.2039 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------|---|----------|--|--|---------------------------------------|
| Jackson ES (2360) 2B | UNIT NOT HEATING IN PORT-286. PLANT MGR-COX/596.2039 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | repair boiler shut down by fire dept | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | purchase two new boilers-os | 2/12/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Boilers down per EMS | 3/4/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Monthly - Filter-Jackson Elementary - Refer to PM schedule details. | 10/14/13 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Monthly - Filter-Jackson Elementary - Refer to PM schedule details. | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| Jackson ES (2360) 2B | Graffiti on the door of Portable 286 per Ms. Marlo Cox, Plant Mgr. 416.5904 | 10/14/13 | | | Painting |
| Jackson ES (2360) 2B | FLR DRAIN IS BACKING UP IN G/RR WEST-END. PLANT MGR-COX/416.5904 | 9/6/13 | | | Plumbing |

| | | | | | | |
|----------------------|--|---------|-----------|------------------------|--|----------|
| Jackson ES (2360) 2B | AHU IS LEAKING WATER IN NURSE STATION PLANT MGR-COX/416.4222 | 9/10/13 | | | | Plumbing |
| Jackson ES (2360) 2B | toilet leaking | 9/16/13 | Classroom | Rm 108 | | Plumbing |
| Jackson ES (2360) 2B | sink in girls restroom has fallen off wall per Ms. Cox 416-5904 | 9/17/13 | | | | Plumbing |
| Jackson ES (2360) 2B | Request Back flow test. | 9/25/13 | | | | Plumbing |
| Jackson ES (2360) 2B | UV CAFE SERVING LINE- LEAKING-PLANT MGR COX 416-5904 KLR | 10/4/13 | | | | Plumbing |
| Jackson ES (2360) 2B | Conduct back-flow test. | 7/5/13 | | | | Plumbing |
| Jackson ES (2360) 2B | mop sink has a slow drain | 7/23/13 | Kitchen | | | Plumbing |
| Jackson ES (2360) 2B | floor drain stopped up | 7/23/13 | Kitchen | underneath cooks sinks | | Plumbing |

| | | | | | |
|----------------------|---|----------|------------------|---------------------|----------|
| Jackson ES (2360) 2B | Third toilet from entry needs flush valve | 8/14/13 | Restroom (Girls) | 1st floor main hall | Plumbing |
| Jackson ES (2360) 2B | 5-TOILETS IS LEAKING FROM G/RR 2ND FLR INTO G/RR 1ST FLR PLANT MGR-COX/416.4222 | 8/14/13 | | | Plumbing |
| Jackson ES (2360) 2B | 3rd sink from entry handle stripped. Water will not shut off | 10/15/13 | 2nd Floor | Boys restroom | Plumbing |
| Jackson ES (2360) 2B | Garbage disposal leaking | 10/30/13 | Kitchen | | Plumbing |
| Jackson ES (2360) 2B | TOILET PIPE IS LEAKING WATER IN G/RR ON 2ND FLR PLANT MGR-COX/596.2039 | 12/9/13 | | | Plumbing |
| Jackson ES (2360) 2B | SEWAGE IS BACKING UP BY WEST WING IN G/RR. PLANT MGR-COX/596.2039 | 4/24/14 | | | Plumbing |
| Jackson ES (2360) 2B | Sprayer leaking | 5/20/14 | Kitchen | Dish washing room | Plumbing |
| Jackson ES (2360) 2B | LOUD sound and smell of GAS outside BOILER ROOM per Marlo Cox, Plant Mgr. 416.5904. | 1/15/14 | | | Plumbing |

| | | | | | |
|----------------------|--|---------|------------------|---------------------|-------------|
| Jackson ES (2360) 2B | There are 2 sinks leaking from underneath the bottom. See Cafeteria manager | 1/22/14 | Kitchen | | Plumbing |
| Jackson ES (2360) 2B | gas smell in the kitchen per Ms. Cox 416-5904 | 1/23/14 | | | Plumbing |
| Jackson ES (2360) 2B | TOILET G/RR 2ND FLR IS LEAKING WATER INTO G/RR 1ST FLR PLANT MGR-COX/596.2039 | 1/29/14 | | | Plumbing |
| Jackson ES (2360) 2B | The Mop sink in the custodial closet thats located inside the boys restroom on the 2nd floor east wing is stopped up. | 2/20/14 | Custodial Closet | 2nd floor East wing | Plumbing |
| Jackson ES (2360) 2B | FAUCET in the BOILER ROOM will NOT TURN OFF per Marlo Cox, Plant Mgr. 416.5904 | 5/22/14 | | | Plumbing |
| Jackson ES (2360) 2B | 5-TOILETS ARE LEAKING FROM G/RR 2ND FLR INTO G/RR 1ST FLR PLANT MGR-COX/416.4222 | 8/14/13 | | | Plumbing |
| Jackson ES (2360) 2B | The doors at Jackson Elementary School need sheetmetal kick plates. We are going to paint the doors in our window project that is coming up this summer. (1) Clinic Area exterior door West end of Main building | 4/3/14 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | |
|-----------------------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Kate Bond El (2116) 2 | 52 | 54 | 44 | 1 | 49 | 19 | 4 | 223 |
| Grand Total | 52 | 54 | 44 | 1 | 49 | 19 | 4 | 223 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|--|----------------|------------------|----------------------|-----------|
| Kate Bond EI (2116) 2A | floor board loose, this keeps main door from opening | 5/1/14 | Portables | #303 | Carpentry |
| Kate Bond EI (2116) 2A | lock broken | 5/1/14 | Auditorium | | Carpentry |
| Kate Bond EI (2116) 2A | broken door handle | 10/28/13 | Classroom | Ms.Hunter rm#13 | Carpentry |
| Kate Bond EI (2116) 2A | doors to inside cabinets have been torn away from frame (repair) | 11/1/13 | 1st Floor | teachers work room | Carpentry |
| Kate Bond EI (2116) 2A | storage room doors not securing properly | 11/4/13 | Annex | boys/girls rr 2nd fl | Carpentry |
| Kate Bond EI (2116) 2A | door will not close ,hinges bent | 11/4/13 | Classroom | #8 | Carpentry |
| Kate Bond EI (2116) 2A | broken door knob and door will not close properly | 11/5/13 | Classroom | rm#34 | Carpentry |

| | | | | | |
|------------------------|--|---------|------------------|--------------------------|-----------|
| Kate Bond EI (2116) 2A | need 4 boxes of hard ceiling tile | 6/10/14 | Annex | | Carpentry |
| Kate Bond EI (2116) 2A | need (4) boxes of soft tile for ceiling projects in classrooms | 6/11/14 | | projects | Carpentry |
| Kate Bond EI (2116) 2A | door not working properly | 6/12/14 | 1st Floor | assistant teacher lounge | Carpentry |
| Kate Bond EI (2116) 2A | door handle broken | 6/17/14 | Gym | inside gym door by stage | Carpentry |
| Kate Bond EI (2116) 2A | door has broken panic | 6/18/14 | Custodial | exit door to cafe | Carpentry |
| Kate Bond EI (2116) 2A | floor tile needs to be replaced in front of water fountain | 6/25/14 | Hallway/Corridor | by boys restroom | Carpentry |
| Kate Bond EI (2116) 2A | missing floor tile | 6/25/14 | Cafetorium | by west exit doors | Carpentry |
| Kate Bond EI (2116) 2A | WOODEN WALKWAY has become uneven between PORTABLES 302 and 303 per Mr. Campbell, Plant Mgr. 826.7298 | 5/6/14 | | | Carpentry |

| | | | | | |
|------------------------|---|---------|------------------|------------------------------|-----------|
| Kate Bond EI (2116) 2A | broken panic bar (replace) | 5/12/14 | Portables | 304 | Carpentry |
| Kate Bond EI (2116) 2A | need back door panic bar replaced | 5/13/14 | Portables | #304 | Carpentry |
| Kate Bond EI (2116) 2A | broken cabinet door hinges | 5/13/14 | 1st Floor | teacher lounge | Carpentry |
| Kate Bond EI (2116) 2A | library shelves are in need of repair due to termite damage | 5/14/14 | Library | | Carpentry |
| Kate Bond EI (2116) 2A | door to classroom not working properly, will not secure | 5/19/14 | Classroom | #41 Ms.Wells | Carpentry |
| Kate Bond EI (2116) 2A | broken door to restroom stall #1 | 5/20/14 | Restroom (Girls) | kindergarden hallway | Carpentry |
| Kate Bond EI (2116) 2A | closure not working/door won't close without slamming **safety concern expressed by aftercare director for students** | 7/16/13 | Cafetorium | entrance to dock & cafeteria | Carpentry |
| Kate Bond EI (2116) 2A | Please deliver two boxes of fiberglass ceiling tiles, for replacement of missing and soiled ceiling tiles in classrooms. Thank-you | 7/24/13 | | | Carpentry |

| | | | | | |
|------------------------|--|----------|---------------------|---------------------|-----------|
| Kate Bond EI (2116) 2A | Adjust back entrance door for positive closure, doesn't close completely. | 8/1/13 | Cafeteria | Kitchen | Carpentry |
| Kate Bond EI (2116) 2A | The door to the kitchen is not working properly. The door closure may need to be adjusted or repaired. | 8/19/13 | Cafeteria | Kitchen Door | Carpentry |
| Kate Bond EI (2116) 2A | There is a door in this area that does not close properly. It needs to be repaired asap. The door does not close as it should when it is being used. | 8/28/13 | Administration Area | Front Door Entrance | Carpentry |
| Kate Bond EI (2116) 2A | There are a couple of door closures in this area that are broken and need to be repaired or replaced. | 8/28/13 | Gym | | Carpentry |
| Kate Bond EI (2116) 2A | MAIN ENTRANCE DOOR-NOT LOCKING-WON'T BE ABLE TO SECURE-PLANT MGR ARNOLD 416-8574 KLR | 8/29/13 | | | Carpentry |
| Kate Bond EI (2116) 2A | emergency window in room 8 won't secure - pops open by itself per Mr. Arnold 416-8574 | 10/3/13 | | | Carpentry |
| Kate Bond EI (2116) 2A | broken door knob(repair) | 10/21/13 | Classroom | rm#4 Ms.Allen | Carpentry |
| Kate Bond EI (2116) 2A | REAR ENTRANCE DOOR KITCHEN AREA-WAS DAMAGED DUE TO A BREAK-IN-WON'T BE ABLE TO SECURE-PLANT MGR CAMPBELL 416-0640 KLR | 11/19/13 | | | Carpentry |

| | | | | | |
|------------------------|---|----------|-----------|---------|-----------|
| Kate Bond EI (2116) 2A | broken kickplate will not let door open | 11/25/13 | Portables | 304 | Carpentry |
| Kate Bond EI (2116) 2A | broken door closer | 11/25/13 | Portables | 301 | Carpentry |
| Kate Bond EI (2116) 2A | door will not secure.... lock not working properly. | 12/8/13 | Classroom | room 30 | Carpentry |
| Kate Bond EI (2116) 2A | broken door closer | 1/6/14 | Portables | 301 | Carpentry |
| Kate Bond EI (2116) 2A | Repair gate and set the post. | 1/10/14 | | | Carpentry |
| Kate Bond EI (2116) 2A | defected panic bar by gym north back exit doors. security issue | 1/14/14 | 1st Floor | | Carpentry |
| Kate Bond EI (2116) 2A | Replace ceiling tiles and clean vents in the cafeteria. | 1/16/14 | | | Carpentry |
| Kate Bond EI (2116) 2A | door handles to the library are not working properly. both entrance doors ,and the office door. children are unable to exit the area. | 1/23/14 | Library | | Carpentry |

| | | | | | |
|------------------------|--|---------|------------------|-----------------------|-----------|
| Kate Bond EI (2116) 2A | door knob will not secure, key broken off into handle. | 1/28/14 | Classroom | rm#1 | Carpentry |
| Kate Bond EI (2116) 2A | Deliver lift to the school. | 2/5/14 | | | Carpentry |
| Kate Bond EI (2116) 2A | librarian is requesting for (2) wall mounted book shelves to be removed, for her smart board install. | 2/28/14 | Library | | Carpentry |
| Kate Bond EI (2116) 2A | window to area will not secure | 3/24/14 | 1st Floor | yellow hall rm #40 | Carpentry |
| Kate Bond EI (2116) 2A | need carpet removed and tile installed on 4 x 2 slot. tile replacements are on campus for tech. | 3/24/14 | Library | | Carpentry |
| Kate Bond EI (2116) 2A | baseboard hit and miss spots inside of hallways (replace). | 3/24/14 | | inside campus | Carpentry |
| Kate Bond EI (2116) 2A | per mr campbell 826-7298 outside north side entry door from annex the panic bar is broken can't secure | 4/2/14 | | | Carpentry |
| Kate Bond EI (2116) 2A | exit door closing too slow, dosen't fall and secure | 4/14/14 | Hallway/Corridor | purple hall exit door | Carpentry |

| | | | | | |
|------------------------|---|----------|------------|---------------------|------------|
| Kate Bond EI (2116) 2A | broken panic bar will not secure | 4/16/14 | Cafetorium | southside exit door | Carpentry |
| Kate Bond EI (2116) 2A | broken door handle | 4/21/14 | 1st Floor | room #17 Mr.Hudson | Carpentry |
| Kate Bond EI (2116) 2A | need 10 boxes of soft ceiling tile for kitchen and serving line area (replace) | 4/24/14 | Kitchen | project work | Carpentry |
| Kate Bond EI (2116) 2A | westside bleacher needs repair | 4/24/14 | Gym | | Carpentry |
| Kate Bond EI (2116) 2A | entrance door panic bar broken | 4/24/14 | Annex | | Carpentry |
| Kate Bond EI (2116) 2A | bad ballast | 10/28/13 | Classroom | Ms.Bomar | Electrical |
| Kate Bond EI (2116) 2A | LIGHTS PORT 301-NOT COMING ON-WILL NEED-PLANT MGR CAMPBELL 416-0640 KLR | 11/4/13 | | | Electrical |
| Kate Bond EI (2116) 2A | lots of lights out at this location, need (4) boxes of 12T light bulbs for project work. Attn: Mr.Means | 11/5/13 | Classroom | | Electrical |

| | | | | | |
|------------------------|--|---------|-----------|------------------|------------|
| Kate Bond EI (2116) 2A | need t-12's to complete projects | 6/10/14 | | campus projects | Electrical |
| Kate Bond EI (2116) 2A | POWER OUTAGE - COMPLETELY OUT - PM/CAMPBELL 826-7298 | 6/13/14 | | | Electrical |
| Kate Bond EI (2116) 2A | FIRE ALARM IS SHOWING TROUBLE & SHUT DOWN THE AIR(SUMMER CAMP) PLANT MGR-CAMPBELL/826.7298 | 6/16/14 | | | Electrical |
| Kate Bond EI (2116) 2A | mutipal units out on campus with out power...Attn: Richard Powell | 6/16/14 | | whole campus | Electrical |
| Kate Bond EI (2116) 2A | bad ballast in area | 6/17/14 | Kitchen | helpers restroom | Electrical |
| Kate Bond EI (2116) 2A | no power to ventahood | 6/17/14 | Kitchen | | Electrical |
| Kate Bond EI (2116) 2A | clock not working by clsroom #16 | 6/17/14 | 1st Floor | | Electrical |
| Kate Bond EI (2116) 2A | bad ballast in eletrical closet | 6/17/14 | Gym | | Electrical |

| | | | | | |
|------------------------|--|---------|------------------|----------------|------------|
| Kate Bond EI (2116) 2A | Venting hood have no power in kitchen (summer school). Plant Mgr-Campbell/416-0640 | 6/18/14 | | | Electrical |
| Kate Bond EI (2116) 2A | lights out in hall,too high to reach need lift | 6/20/14 | Hallway/Corridor | | Electrical |
| Kate Bond EI (2116) 2A | need lights replaced, whole row of lights out(dark) | 6/20/14 | | outside canipy | Electrical |
| Kate Bond EI (2116) 2A | Please install 3 pull station cover alarms over 3 pull stations designated by Principal/Plant Manager. | 6/24/14 | | | Electrical |
| Kate Bond EI (2116) 2A | repair leaks over light fixture,filled with water | 5/9/14 | 1st Floor | library | Electrical |
| Kate Bond EI (2116) 2A | power whips are needed to be installed behide both cash registers, and a new power pole needs to be installed. | 5/13/14 | Cafeteria | serving line | Electrical |
| Kate Bond EI (2116) 2A | bad ballist in hallway light fixture | 5/13/14 | 1st Floor | | Electrical |
| Kate Bond EI (2116) 2A | Operation Student occupation awareness on site. | 5/14/14 | | | Electrical |

| | | | | | |
|------------------------|---|----------|-----------|-----------------------|------------|
| Kate Bond EI (2116) 2A | Replace broken ceiling light cover. | 7/1/13 | Classroom | Rm#6 | Electrical |
| Kate Bond EI (2116) 2A | There are several outside lights that are out around the outside of the building. These are lights that are located close on the outside exterior walls of the building. | 8/29/13 | Grounds | | Electrical |
| Kate Bond EI (2116) 2A | The lights in this area that are located in the canopy over the doors are out. There is a lift or a bucket truck needed to reach these areas of lights. | 8/29/13 | Grounds | Main Entrance Outside | Electrical |
| Kate Bond EI (2116) 2A | There is an electrical outlet in this room that needs to be checked out and repaired or replaced. It caused an electrical cord to get charred around the edges of the plug. | 9/12/13 | 1st Floor | 40 | Electrical |
| Kate Bond EI (2116) 2A | a/c not coming on entire building per mr. arnold 416-8574 | 9/30/13 | | | Electrical |
| Kate Bond EI (2116) 2A | no power in portable 301 per Mr. Campbell 416-0020 | 10/18/13 | | | Electrical |
| Kate Bond EI (2116) 2A | requesting light bulbs for campus classrooms(*8 boxes of T-12's). | 10/25/13 | 1st Floor | | Electrical |
| Kate Bond EI (2116) 2A | PARTIAL OUTAGE-NO POWER AT ALL TO PORT 302 PER SBE-PLANT MGR CAMPBELL KLR | 11/25/13 | | | Electrical |

| | | | | | |
|------------------------|--|----------|---------------------|----------------------|------------|
| Kate Bond EI (2116) 2A | Need T12 light bulbs for major projects at this campus (6 boxes) | 12/10/13 | 1st Floor | | Electrical |
| Kate Bond EI (2116) 2A | electric generator not working properly, didn't power-up during power outage | 1/2/14 | | north wall/ outside | Electrical |
| Kate Bond EI (2116) 2A | PORT 302-HAS NO POWER AT ALL-PER SBE, NOTHING IS COMING ON-PLANT MGR CAMPBELL KLR | 1/6/14 | | | Electrical |
| Kate Bond EI (2116) 2A | No power to clocks or bells, students are unable to move through location. bells are being rung by hand! | 1/9/14 | Administration Area | | Electrical |
| Kate Bond EI (2116) 2A | recepticals in area arnot working properly. | 1/10/14 | Classroom | #28 Ms.Wheeler | Electrical |
| Kate Bond EI (2116) 2A | bad ballast in light | 1/10/14 | Hallway/Corridor | blue | Electrical |
| Kate Bond EI (2116) 2A | front parking lot extra dark (5) light poles not working properly | 1/14/14 | | front of campus | Electrical |
| Kate Bond EI (2116) 2A | north side of location extra dark , night security light not working properly | 1/14/14 | | north side of campus | Electrical |

| | | | | | |
|------------------------|---|---------|-------------|-----------------|------------|
| Kate Bond EI (2116) 2A | need light bulbs for portables 301,302,303, and 304. extra dark areas. | 1/14/14 | Portables | | Electrical |
| Kate Bond EI (2116) 2A | Need (6) boxes of T-12 Light bulbs, several lights out in classrooms. | 1/24/14 | | campus projects | Electrical |
| Kate Bond EI (2116) 2A | RECEPTACLE CAFETORIUM SOUTH WALL-HANGING DOWN WITH LIVE WIRES EXPOSED-PLANT MGR CAMPBELL 826-7298 KLR | 2/10/14 | | | Electrical |
| Kate Bond EI (2116) 2A | Replace parking lot lighting with LED fixtures. | 2/27/14 | Parking Lot | | Electrical |
| Kate Bond EI (2116) 2A | need (3) boxes of T-12's for project work in classrooms during the spring break. | 3/7/14 | | campus | Electrical |
| Kate Bond EI (2116) 2A | DISHWASHER KITCHEN AREA-NOT COMING ON-WILL NEED-PLANT MGR CAMPBELL 826-7298 KLR | 3/17/14 | | | Electrical |
| Kate Bond EI (2116) 2A | principal is requesting for the building and parking lot lights to come on at 7:45 p.m. and go off at 7:15 a.m. | 3/24/14 | Parking Lot | front and back | Electrical |
| Kate Bond EI (2116) 2A | UNITS NOT COMING ON IN RM-48,47,46. PLANT MGR-CAMPBELL/416.0640 | 3/28/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|-----------------|-------------------|------------|
| Kate Bond EI (2116) 2A | UNIT NOT COMING ON FOR ANNEX BLDG. PLANT MGR-CAMPBELL/826.7298 | 4/1/14 | | | Electrical |
| Kate Bond EI (2116) 2A | loose wires in serving area | 4/8/14 | Kitchen | serving line area | Electrical |
| Kate Bond EI (2116) 2A | PARTIAL OUTAGE-SEVERAL AREAS HAVE NO POWER INCLUDING NO AIR-PLANT MGR CAMPBELL KLR | 4/8/14 | | | Electrical |
| Kate Bond EI (2116) 2A | Reset clocks | 4/9/14 | | | Electrical |
| Kate Bond EI (2116) 2A | outside campus lighting not working. parking lot and building lights out . black dark in area | 4/10/14 | | outside of campus | Electrical |
| Kate Bond EI (2116) 2A | clocks not working properly | 4/16/14 | | campus | Electrical |
| Kate Bond EI (2116) 2A | bad ballast in area | 4/16/14 | Restroom (Boys) | 3rd grade hallway | Electrical |
| Kate Bond EI (2116) 2A | light inside freezer not woking properly. area too dark | 4/16/14 | Kitchen | walkin freezer | Electrical |

| | | | | | |
|------------------------|---|---------|---------|-----------------|---------------------------------------|
| Kate Bond EI (2116) 2A | need T-12's light bulbs for project work assignments (4 boxes) | 4/22/14 | | campus projects | Electrical |
| Kate Bond EI (2116) 2A | power pole by regester's are losing power during lunch operations | 4/24/14 | Kitchen | | Electrical |
| Kate Bond EI (2116) 2A | There's NO POWER to the POLE in the CAFETERIA per Mr. Campbell, Plant Mgr. 826.7298 | 4/25/14 | | | Electrical |
| Kate Bond EI (2116) 2A | per mr campbell 826-7298 room 49 and annex 171 blowing heat | 5/5/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | A/C RM 55, 59, & 60-ALL NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT COOLING IN RM-171,170,169,70,28,49. PLANT MGR-CAMPBELL/416.0640 | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | A/C RM 70, 39, 27, & 49-ALL NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 4/25/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | A/C KITCHEN AREA-NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 5/2/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|-----|--|---------------------------------------|
| Kate Bond EI (2116) 2A | A/C RM 28-NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 6/30/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | 2-RTU ARE OVERHEATING IN RM-171,170 ANNEX. PLANT MGR-CAMPBELL/416.0640 | 10/31/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT COOLING IN RM-23,28,55,70 ANNEX,171 ANNEX. PLANT MGR-CAMPBELL/ | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT COOLING IN RM-72 ANNEX, 49 PLANT MGR-CAMPBELL/ | 5/15/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | broken thermostat hanging from wall (child hazzard) | 5/16/14 | Gym | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Monthly - Oil Lube & Belt-Kate Bond Elementary - Refer to PM schedule details. | 5/23/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | 4-RTU#9,10,11,6 NOT COOLING IN RM-70,72,73,171. PLANT MGR-WHITE/416-0020 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Air Handler unit NOT COOLING in Portable #302 per Mr. Arnold, Plant Mgr. 901.416.0014 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|--|--|---------------------------------------|
| Kate Bond EI (2116) 2A | RTU NOT COOLING IN RM-70,171 PLANT MGR-ARNOLD/416.0640 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | RTU NOT COOLING IN RM-170. PLANT MGR-ARNOLD/416.8574 | 9/4/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Port 301. change filter, clean evap. turn over supply grill or replace | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | a/c not cooling in rooms 170 and 171 per Mr. Arnold 416-8574 | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | rooms 170 and 171 a/c not cooling per Mr. Arnold 416-8574 | 10/3/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Monthly - Oil Lube & Belt-Kate Bond Elementary - Refer to PM schedule details. | 10/25/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Unit is NOT HEATING in ROOM 23 per Mr. Campbell, Plant Mgr. 826.7298 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT HEATING IN RM-4, ANNEX-168. PLANT MGR-CAMPBELL/826.7298 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|---------------------|--|---------------------------------------|
| Kate Bond EI (2116) 2A | Monthly - Filters - Kate Bond Elem - Refer to PM schedule details. | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | HEAT RMS 58, 28, 53, 49, 48, 50, 55, 16, 51, 17, CAFE, & MAIN OFC-ALL NOT HEATING-PLANT MGR CAMPBELL KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | roof top unit door will not stay in place . the main office area is recieveing draft from outside because of this issue. | 1/14/14 | Administration Area | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | HEAT RM 168 & 171-BOTH NOT HEATING-PLANT MGR CAMPBELL 416.0640 KLR | 1/17/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | HEAT RM 16, 38, 44, 37, 39, 36, 41, & TEACHER'S LOUNGE-ALL NOT HEATING-PLANT MGR CAMPBELL 416.0640 KLR | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT HEATING PORT-303 PLANT MGR-CAMPBELL/416.0640 | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT HEATING IN RM-35,16 PLANT MGR-CAMPBELL/826.7298 | 1/30/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT HEATING IN LIBRARY PLANT MGR-CAMPBELL/866.7298 | 1/30/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|-------|-----------|---------------------------------------|
| Kate Bond EI (2116) 2A | per mr campbell 826-7298 annex #171 and room 47 in main building blowing cold no heat | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | rooftop unit not working properly , hallway cold | 2/26/14 | Annex | roof area | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | HEAT RM 47-NOT HEATING-PLANT MGR CAMPBELL 416-0640 KLR | 3/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | 4- UNITS NOT HEATING IN RM-35,40,49,53 PLANT MGR-CAMPBELL/416.0640 | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT HEATING IN RM-69,166 ANNEX PLANT MGR-CAMPBELL/416.0640 | 3/18/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | THERMOSTATS IN RMS 35 THRU 60-ARE NOT WORKING AT ALL-HAVE NO POWER-PLANT MGR CAMPBELL 416-0640 KLR | 3/19/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | RTU - RM 47, 48, 49, ARE EXTREMELY COLD - BLOWING COLD AIR - PM/CAMPBELL 826-7298 | 3/26/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT COOLING IN RM-170,49. PLANT MGR-CAMPBELL/826.7298 | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------|--|---------|---------|--|-----------------|---------------------------------------|
| Kate Bond EI (2116) 2A | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT COOLING IN RM-171 ANNEX 2ND FLR PLANT MGR-CAMPBELL/826.7298 | 4/2/14 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT COOLING IN CAFE PLANT MGR/CAMPBELL/416.0640 | 4/3/14 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT COOLING IN CAFE, & RM-49 PLANT MGR-CAMPBELL/416.0640 | 4/11/14 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | UNIT NOT COOLING IN CAFE, & RM-49 PLANT MGR-CAMPBELL/826.7298 | 4/22/14 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Monthly - Filters - Kate Bond Elem - Refer to PM schedule details. | 5/5/14 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Monthly - Filters - Kate Bond Elem - Refer to PM schedule details. | 9/9/13 | | | | Heating/Ventilation /Air Conditioning |
| Kate Bond EI (2116) 2A | Principal is requesting for " fire lane lines and signs" to be re-painted in front of campus area. | 3/24/14 | Grounds | | front of campus | Painting |

| | | | | | |
|------------------------|---|----------|------------------|----------------------|----------|
| Kate Bond EI (2116) 2A | broken stall door hinges (6th stall on thr right) | 5/1/14 | Restroom (Girls) | 3rd grade hallway | Plumbing |
| Kate Bond EI (2116) 2A | 5 stand- up urinals hanging from wall area need to be re-hung onto wall . also 3 urinal are over flowing onto floor area stoppage inside wall . floors stay wet to long(child hazzard)! | 10/25/13 | Restroom (Boys) | 1st floor | Plumbing |
| Kate Bond EI (2116) 2A | 3 compartment sink not working properly, drain plug broken will not hold water inside unit. | 10/25/13 | Kitchen | | Plumbing |
| Kate Bond EI (2116) 2A | roof units that have stopped up condensation pipes | 6/6/14 | | campus | Plumbing |
| Kate Bond EI (2116) 2A | AIR DUCT LEAKING WATER in CLASSROOM ANNEX 72 per Mr. Campbell, Plant Mgr. 826.7298 | 6/9/14 | | | Plumbing |
| Kate Bond EI (2116) 2A | hand sink faucet leaking water around handle | 6/10/14 | Kitchen | | Plumbing |
| Kate Bond EI (2116) 2A | two standing urinals are not working properly, summer school in progress | 6/18/14 | Restroom (Boys) | by purple hall | Plumbing |
| Kate Bond EI (2116) 2A | toilet not working properly, summer school in progress | 6/18/14 | Restroom (Girls) | 2nd stall ,left side | Plumbing |

| | | | | | |
|------------------------|--|---------|------------------|----------------------------|----------|
| Kate Bond EI (2116) 2A | urinal on the right side wall, not working properly....summer school in progress | 6/18/14 | Restroom (Boys) | by yellow hallway | Plumbing |
| Kate Bond EI (2116) 2A | test back flow device-os | 7/2/13 | | | Plumbing |
| Kate Bond EI (2116) 2A | 3 faucets running @ steady flow | 7/16/13 | Hallway/Corridor | front of restrm near rm#45 | Plumbing |
| Kate Bond EI (2116) 2A | I.D.#432-099 Water heater leaking. | 7/22/13 | Custodial Closet | | Plumbing |
| Kate Bond EI (2116) 2A | The toilet is leaking in this room when it is being flushed. This needs to be repaired asap. | 8/5/13 | 1st Floor | 31 | Plumbing |
| Kate Bond EI (2116) 2A | There is a toilet in this area that is leaking, and is causing a smell in this restroom. Restroom between yellow and blue hallway. | 8/13/13 | Restroom (Boys) | Main Hall in Main Building | Plumbing |
| Kate Bond EI (2116) 2A | NO HOT WATER TO KITCHEN AREA-SBE NOT SURE WHICH ONE CTRLS KITC AND DOES NOT KNOW WHAT'S WRONG-SBE ARNOLD 416-8574 KLR | 8/19/13 | | | Plumbing |
| Kate Bond EI (2116) 2A | Inspect sewer drains | 8/26/13 | | | Plumbing |

| | | | | | |
|------------------------|---|----------|---------------------|-------------------|----------|
| Kate Bond EI (2116) 2A | There are several urinals in this area that are not working properly. These are located near the blue and yellow hallways on the main hall. | 9/6/13 | 1st Floor | Restrooms | Plumbing |
| Kate Bond EI (2116) 2A | There is a sink that is stopped up in this area, and needs to be repaired or replaced. | 10/1/13 | Cafeteria | Kitchen | Plumbing |
| Kate Bond EI (2116) 2A | 3 compartment sink will not release water in kitchen area.health hazzard to small children. | 10/17/13 | Kitchen | | Plumbing |
| Kate Bond EI (2116) 2A | sprayer over sink area not worker properly. | 10/21/13 | Kitchen | | Plumbing |
| Kate Bond EI (2116) 2A | clinic area sink not working properly. | 10/21/13 | Administration Area | | Plumbing |
| Kate Bond EI (2116) 2A | standing urinal not working properly, when flushing unit it will activate the urinals next to it. | 11/13/13 | Restroom (Boys) | 3rd grade hallway | Plumbing |
| Kate Bond EI (2116) 2A | Flush sewer | 11/20/13 | | | Plumbing |
| Kate Bond EI (2116) 2A | GAS SMELL KINDERGARTEN HALL-PLANT MGR CAMPBELL KLR | 12/13/13 | | | Plumbing |

| | | | | | | |
|------------------------|--|----------|------------------|---------------------|--|----------|
| Kate Bond EI (2116) 2A | (3) COMMODES G RR KINDERGARTEN AREA-ONLY (4) IN RR & (3) NOT FLUSHING PER SBE-PLANT MGR CAMPBELL 416-0640 KLR | 12/17/13 | | | | Plumbing |
| Kate Bond EI (2116) 2A | toilet in 1st stall not working properly. | 1/6/14 | Restroom (Boys) | | | Plumbing |
| Kate Bond EI (2116) 2A | toilet not working propely, stall#6, south wall | 1/6/14 | Restroom (Girls) | | | Plumbing |
| Kate Bond EI (2116) 2A | GAS SMELL IN RM 28-PLANT MGR CAMPBELL 416-0640 KLR | 1/9/14 | | | | Plumbing |
| Kate Bond EI (2116) 2A | GAS SMELL IN RM-28. PLANT MGR-CAMPBELL/416.0640 | 1/14/14 | | | | Plumbing |
| Kate Bond EI (2116) 2A | SINK HALL STEM HAS BROKEN & WATER IS RUNNING BY CAFE. PLANT MGR-CAMPBELL/826.7298 | 1/23/14 | | | | Plumbing |
| Kate Bond EI (2116) 2A | toilet spilling water and defacation onto the floor where the kindergarden students are walking . this is a serious children hazzard and health issue. | 1/24/14 | Restroom (Boys) | | | Plumbing |
| Kate Bond EI (2116) 2A | (2) standing urinals not working properly, (1) toilet not working properly. | 2/3/14 | Restroom (Boys) | 1st /2nd grade hall | | Plumbing |

| | | | | | |
|------------------------|--|---------|------------------|----------------------|----------|
| Kate Bond EI (2116) 2A | toilet in girls restroom not working properly | 2/3/14 | Restroom (Girls) | 3rd /4th grade hall | Plumbing |
| Kate Bond EI (2116) 2A | (2) toilets not working properly (2) standing urinals not working properly. | 2/3/14 | Restroom (Boys) | 3rd/4th grade hall | Plumbing |
| Kate Bond EI (2116) 2A | per mr campbell 826-7298 kitchen manager's restroom is flooding | 2/7/14 | | | Plumbing |
| Kate Bond EI (2116) 2A | I have several unit (faucets) that will not stop leaking water. by the boys/girls restroom. troff style sinks in area. | 2/26/14 | 1st Floor | | Plumbing |
| Kate Bond EI (2116) 2A | replace pressure rerulator on the hot water tank. also the tank needs to be turned up too 140 degrees | 3/11/14 | Kitchen | | Plumbing |
| Kate Bond EI (2116) 2A | toilet not working properly | 3/27/14 | Annex | boys handicap stall | Plumbing |
| Kate Bond EI (2116) 2A | toilet not working properly. | 3/27/14 | Annex | girls handicap stall | Plumbing |
| Kate Bond EI (2116) 2A | toilet leaking water from under the bottom. | 3/27/14 | Classroom | #46 | Plumbing |

| | | | | | |
|------------------------|---|----------|------------------|-------------------|----------|
| Kate Bond EI (2116) 2A | Flush sewer | 3/31/14 | | | Plumbing |
| Kate Bond EI (2116) 2A | urinal on west wall not working properly | 4/3/14 | Restroom (Boys) | 1st grade hallway | Plumbing |
| Kate Bond EI (2116) 2A | per mr campbell 826-7298 no hot water in kitchen | 4/9/14 | | | Plumbing |
| Kate Bond EI (2116) 2A | floor drain not working properly, drain holding water . | 4/10/14 | Kitchen | lundry area | Plumbing |
| Kate Bond EI (2116) 2A | hot water coming from under the bottom of unit while in operation | 4/24/14 | Kitchen | dish washing area | Plumbing |
| Kate Bond EI (2116) 2A | urinal not woking properly | 4/25/14 | Restroom (Boys) | 4th grade hall | Plumbing |
| Kate Bond EI (2116) 2A | 5th stall toilet not working properly | 4/25/14 | Restroom (Girls) | 4th grade hall | Plumbing |
| Kate Bond EI (2116) 2A | requesting 6 soap dispensers for location | 10/25/13 | Restroom (Boys) | | Plumbing |

| | | | | | |
|------------------------|--|----------|------------------|------------------|----------|
| Kate Bond EI (2116) 2A | 3 stalls on the kindergarden hallway overflowing, unable to control. | 11/12/13 | Restroom (Girls) | 1st floor | Plumbing |
| Kate Bond EI (2116) 2A | ROOF KITCHEN PANTRY AREA- LEAKING-PLANT MGR CAMPBELL 416- 0640 KLR | 4/29/14 | | | Roof |
| Kate Bond EI (2116) 2A | ROOF IS LEAKING WATER IN KITCHEN, CAFE MANAGER OFFICE. PLANT MGR-CAMPBELL/416.0640 | 4/29/14 | | | Roof |
| Kate Bond EI (2116) 2A | water leak by electrical socket on to tile floor | 4/29/14 | Gym | | Roof |
| Kate Bond EI (2116) 2A | water leaking into room on top of computers. | 11/7/13 | Classroom | #13 | Roof |
| Kate Bond EI (2116) 2A | water leaking in the following areas: (1) library north wall over book shelves (2) north end custodial closet wall(3) main office hallway eastside wall | 6/6/14 | | campus issues | Roof |
| Kate Bond EI (2116) 2A | (5)ceiling tile have callasped inside classroom #72 | 6/9/14 | Annex | room 72 | Roof |
| Kate Bond EI (2116) 2A | water leaking in area coming through light fixture. electrical hazzard | 6/11/14 | Library | librain's office | Roof |

| | | | | | |
|------------------------|--|---------|------------------|-----------------------|------|
| Kate Bond EI (2116) 2A | water leaking through ceiling tile on to floor tile | 6/30/14 | Cafetorium | | Roof |
| Kate Bond EI (2116) 2A | roof leaking in libairans office and out in the main lobby area. | 5/14/14 | Library | office and main lobby | Roof |
| Kate Bond EI (2116) 2A | Water leaking from ceiling, when it rains. | 7/8/13 | Classroom | Rm#34 | Roof |
| Kate Bond EI (2116) 2A | roof leaking on registers & throughout serving line area/ceiling tiles have fallen out from weight of rain water | 7/19/13 | Kitchen | serving line area | Roof |
| Kate Bond EI (2116) 2A | Water leaking from ceiling, when it rains. | 7/22/13 | Custodial Closet | | Roof |
| Kate Bond EI (2116) 2A | Water leaking from ceiling, when it rains, behind service area. | 7/22/13 | Cafeteria | Kitchen | Roof |
| Kate Bond EI (2116) 2A | There is a roof leak in this classroom. Whenever it rains, the ceiling leaks in this classroom. | 8/13/13 | 1st Floor | 34 | Roof |
| Kate Bond EI (2116) 2A | There is a roof leak in this classroom, this needs to be checked and repaired asap!!! | 9/24/13 | 1st Floor | 5 | Roof |

| | | | | | |
|------------------------|--|----------|-----------|--|-------------|
| Kate Bond EI (2116) 2A | water leaking over stove area on to cooking surface. | 10/17/13 | Kitchen | over stove area | Roof |
| Kate Bond EI (2116) 2A | water pouring down from ceiling area in the center of the classroom. | 1/9/14 | Classroom | #19 | Roof |
| Kate Bond EI (2116) 2A | water running down rapidly on top of computers | 1/9/14 | Classroom | #9 | Roof |
| Kate Bond EI (2116) 2A | there is a roof leak serving line in cafeteria per mr campbell 826-7298 | 4/7/14 | | | Roof |
| Kate Bond EI (2116) 2A | There is a downspout that needs to be repaired or replaced. The brackets have broken at the middle and bottom of it, and it is bending in the middle of it. This needs to be repaired or replaced. | 9/4/13 | Grounds | Outside of the gym | Sheet Metal |
| Kate Bond EI (2116) 2A | There are two downspouts that were blown down or either fell during the storm that passed through the area the other day. | 9/12/13 | Grounds | Behind the gym in between the playground and the s | Sheet Metal |
| Kate Bond EI (2116) 2A | down spouts have fallen to the ground onto the childrens play area (child hazzard). | 10/21/13 | | Rear of Campus | Sheet Metal |
| Kate Bond EI (2116) 2A | Request two downspouts be remounted to the wall. | 2/12/14 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | |
|------------------------|----------|-----------|------------|------|----------|----------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Sheet Metal | Grand Total |
| Kate Bond MS (2007) 2A | 1 | 57 | 52 | 41 | 11 | 35 | 1 | 198 |
| Grand Total | 1 | 57 | 52 | 41 | 11 | 35 | 1 | 198 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|------------------------|---|---------------|---------------------|----------------------|-----------|
| Kate Bond MS (2007) 2A | There is a need to have the gym floor resurfaced. It needs to be done, is starting to look bad. | 10/9/13 | Gym | | Asbestos |
| Kate Bond MS (2007) 2A | need 4 boxes of hard tile for projects | 6/10/14 | 1st Floor | | Carpentry |
| Kate Bond MS (2007) 2A | door not closing properly | 5/23/14 | 1st Floor | rm (f) 220 ms.greer | Carpentry |
| Kate Bond MS (2007) 2A | broken door knob | 5/27/14 | Administration Area | main office entrance | Carpentry |
| Kate Bond MS (2007) 2A | broken door knob | 5/27/14 | Cafeteria | entrance doors | Carpentry |
| Kate Bond MS (2007) 2A | OUTSIDE DOOR is BROKEN on the W. Side of the BUILDING per Mr. Campbell, Plant Mgr. 826.7298 | 5/20/14 | | | Carpentry |
| Kate Bond MS (2007) 2A | broken door closer | 5/14/14 | | west entrance doors | Carpentry |

| | | | | | |
|------------------------|--|---------|---------------------|--------------------|-----------|
| Kate Bond MS (2007) 2A | broken front door knob at main entrance of office area | 5/19/14 | Administration Area | main office | Carpentry |
| Kate Bond MS (2007) 2A | lockerroom entrance door handle broken | 5/7/14 | Gym | boys lockerroom | Carpentry |
| Kate Bond MS (2007) 2A | re-hang stall doors | 5/7/14 | Restroom (Girls) | | Carpentry |
| Kate Bond MS (2007) 2A | broken cabinet door (hinges) | 5/7/14 | Classroom | Ms.Thompson(A) 168 | Carpentry |
| Kate Bond MS (2007) 2A | broken lock at back door | 5/1/14 | Auditorium | | Carpentry |
| Kate Bond MS (2007) 2A | entrance door not working properly, broken door closer | 5/2/14 | Cafeteria | | Carpentry |
| Kate Bond MS (2007) 2A | Replace broken floor tiles. | 7/1/13 | 2nd Floor | | Carpentry |
| Kate Bond MS (2007) 2A | Carpet loose in reception area. | 7/1/13 | Administration Area | Main office | Carpentry |

| | | | | | |
|------------------------|--|---------|-----------------|------------------------|-----------|
| Kate Bond MS (2007) 2A | The latch on the exterior door in the cafeteria is not catching properly. Security notified that there was movement on more than one occasion. The latch needs to be replaced. This is the third repair. | 7/2/13 | Cafeteria | exterior door | Carpentry |
| Kate Bond MS (2007) 2A | Doors will not latch to secure cafeteria. Doors have been repaired at least three times. Be consider changing the hardware. | 7/24/13 | Cafeteria | | Carpentry |
| Kate Bond MS (2007) 2A | Restroom stall doors do no open or close properly. Hinges are not properly set. This is a serious conflict to individual privacy in each staff within the boys restroom. | 7/24/13 | Restroom (Boys) | 8th and 7th grade hall | Carpentry |
| Kate Bond MS (2007) 2A | Doors handle missing screws. Door does not close properly. | 7/24/13 | Classroom | A137 and A150 | Carpentry |
| Kate Bond MS (2007) 2A | Hole in the wall that was never closed or covered during construction. | 7/24/13 | Classroom | G206 | Carpentry |
| Kate Bond MS (2007) 2A | DOOR NOT ALINED CORRECTLY | 4/1/14 | Classroom | ROOM #150 | Carpentry |
| Kate Bond MS (2007) 2A | new seat for area (install) | 4/1/14 | Auditorium | | Carpentry |
| Kate Bond MS (2007) 2A | handicap stall door not working properly, hinges bent outward. | 4/3/14 | Restroom (Boys) | by gym area | Carpentry |

| | | | | | |
|------------------------|--|----------|------------------|-----------------------|-----------|
| Kate Bond MS (2007) 2A | door latch is missing, unable to secure area at night | 4/3/14 | Hallway/Corridor | band /chior entrance | Carpentry |
| Kate Bond MS (2007) 2A | lock not working properly on inside of classrooms closet will not secure! | 4/7/14 | Classroom | #B125 | Carpentry |
| Kate Bond MS (2007) 2A | handicap stall door has broken hinges, will not secure properly. | 4/7/14 | Restroom (Boys) | by gym area | Carpentry |
| Kate Bond MS (2007) 2A | door to stall torn off fraim, door is now inside of custodial closet area. | 4/7/14 | Restroom (Boys) | 2nd fl 6th grade hall | Carpentry |
| Kate Bond MS (2007) 2A | broken door handle | 4/24/14 | Classroom | G219 | Carpentry |
| Kate Bond MS (2007) 2A | magnet on the back of door area broken will not hold door open. | 11/4/13 | Hallway/Corridor | 2nd fl area | Carpentry |
| Kate Bond MS (2007) 2A | Bed post to clinic area beds need securing to allow students to lay in them. | 11/5/13 | Clinic | | Carpentry |
| Kate Bond MS (2007) 2A | metal plate has broken away from rear door area. | 11/15/13 | Kitchen | | Carpentry |

| | | | | | |
|------------------------|---|----------|---------------------|-------------------|-----------|
| Kate Bond MS (2007) 2A | baseboard missing from ends of the stair case area | 11/21/13 | Stairway | Main entrance | Carpentry |
| Kate Bond MS (2007) 2A | cabnet door off hinges | 12/5/13 | 2nd Floor | scenice lab f-228 | Carpentry |
| Kate Bond MS (2007) 2A | door handle broken to main office | 12/6/13 | Administration Area | entrance door | Carpentry |
| Kate Bond MS (2007) 2A | broken door magnet holder (repair) | 12/10/13 | Hallway/Corridor | | Carpentry |
| Kate Bond MS (2007) 2A | girls restroom stall divider wall is broken, and has fallen off the fraim's base! | 12/17/13 | Restroom (Girls) | 6th grade hallway | Carpentry |
| Kate Bond MS (2007) 2A | Deliver lift to the school. | 2/28/14 | | | Carpentry |
| Kate Bond MS (2007) 2A | broken door handle, unable to secure area | 3/11/14 | Cafeteria | | Carpentry |
| Kate Bond MS (2007) 2A | (2) broken seat in area , replacement seats are here at the campus | 3/11/14 | Auditorium | | Carpentry |

| | | | | | |
|------------------------|--|---------|---------------------|------------------------------|-----------|
| Kate Bond MS (2007) 2A | The door to this storage room is damaged. The plate where the door locks is damaged and needs to be repaired or replaced. | 8/6/13 | 1st Floor | C125 | Carpentry |
| Kate Bond MS (2007) 2A | The door to this office is damaged and needs to be repaired. | 8/6/13 | Auxiliary Gym | P. E. Office | Carpentry |
| Kate Bond MS (2007) 2A | The principal would like to have some tack bulletin board strips installed on this hallway. | 8/6/13 | 1st Floor | B Hallway | Carpentry |
| Kate Bond MS (2007) 2A | The door to the main office is broken and needs to be repaired or replaced. This needs to be done as soon as possible. | 8/12/13 | Administration Area | Main Office | Carpentry |
| Kate Bond MS (2007) 2A | The door to this area is broken and needs to be repaired. The door is being pulled open, which is causing the problem. | 8/14/13 | 1st Floor | C #125 Storage Room | Carpentry |
| Kate Bond MS (2007) 2A | The door in this area is not closing properly. Door is dragging and closing very slowly. This needs to be repaired asap. | 8/22/13 | 1st Floor | 8th grade hallway exit doors | Carpentry |
| Kate Bond MS (2007) 2A | GYM ENTRANCE DOOR- NOT LOCKING-WON'T BE ABLE TO SECURE-PLANT MGR ARNOLD 416-8574 KLR | 8/29/13 | | | Carpentry |
| Kate Bond MS (2007) 2A | There is a door that does not close properly as it should. This door is located in the main lobby entrance, and is the last door on the end in the entrance of the second set of doors in this area. | 9/6/13 | Administration Area | Main Lobby Front Entrance | Carpentry |

| | | | | | | |
|------------------------|---|----------|-----------|--|----------------------|-----------|
| Kate Bond MS (2007) 2A | GYM ENTRANCE DOOR- NOT LOCKING, WON'T BE ABLE TO SECURE BLDG- PLANT MGR ARNOLD 416- 8574 KLR | 9/6/13 | | | | Carpentry |
| Kate Bond MS (2007) 2A | There is a door that does not close properly, the door keeps getting hung. | 9/6/13 | Gym | | Door | Carpentry |
| Kate Bond MS (2007) 2A | There is a need to have some tack bulletin board strips installed on this hallway in front of the classrooms. | 9/11/13 | 1st Floor | | B Hallway | Carpentry |
| Kate Bond MS (2007) 2A | There is a door handle that is broken on this hallway. This door is on the hallway near the girls restroom on the band hallway. | 10/1/13 | 1st Floor | | Band Hallway | Carpentry |
| Kate Bond MS (2007) 2A | The door closure holder is broken and needs to be repaired. | 10/1/13 | 1st Floor | | Gym Outside Entrance | Carpentry |
| Kate Bond MS (2007) 2A | automatic handicap door not oprating properly, will not close and secure (principal's request) | 10/18/13 | 1st Floor | | main hallway | Carpentry |
| Kate Bond MS (2007) 2A | cord on backside of basketball goal not working properly , will not raise or let down unit. | 10/28/13 | Gym | | | Carpentry |
| Kate Bond MS (2007) 2A | broken door not working properly | 10/29/13 | 1st Floor | | B115 Ms.Marshall | Carpentry |

| | | | | | | |
|------------------------|---|----------|-----------------|--|-------------------------|------------|
| Kate Bond MS (2007) 2A | FRONT HANDICAP DOOR, CANT SECURE. PLANT MGR- CAMPBELL/416.0640 | 10/30/13 | | | | Carpentry |
| Kate Bond MS (2007) 2A | carpet/metal style floor matt is too long for doorway, keeps door from closing during nightside close-out. | 3/11/14 | 1st Floor | | eastside entrance doors | Carpentry |
| Kate Bond MS (2007) 2A | Doors in service area will not lock. | 7/2/13 | Cafeteria | | Kitchen | Carpentry |
| Kate Bond MS (2007) 2A | need 4 boxes of T-8's for projects | 6/10/14 | | | projects | Electrical |
| Kate Bond MS (2007) 2A | POWER OUTAGE - COMPLETELY - PM/CAMPBELL 826-7298 | 6/13/14 | | | | Electrical |
| Kate Bond MS (2007) 2A | domestic hot water tank not working properly attn: Richard Powell | 6/16/14 | Restroom (Boys) | | 8th grade hallway | Electrical |
| Kate Bond MS (2007) 2A | not working properly, no power Attn:Richard Powell | 6/16/14 | Elevator | | | Electrical |
| Kate Bond MS (2007) 2A | sign not working properly, no power....Attn: Richard Powell | 6/16/14 | | | outside campus | Electrical |

| | | | | | |
|------------------------|--|---------|-----------|------------------|------------|
| Kate Bond MS (2007) 2A | lights not working properly(A) 155 | 6/17/14 | 1st Floor | classroom # | Electrical |
| Kate Bond MS (2007) 2A | hallway clock not working properly, no power | 6/17/14 | 1st Floor | classroom (A)135 | Electrical |
| Kate Bond MS (2007) 2A | no power to lights(dark) | 6/27/14 | Classroom | (B)134 | Electrical |
| Kate Bond MS (2007) 2A | Operation Careen Day. | 5/20/14 | | | Electrical |
| Kate Bond MS (2007) 2A | receptical behind above ceiling unit fan inside of freezer not working properly! | 5/5/14 | Kitchen | walk-in freezer | Electrical |
| Kate Bond MS (2007) 2A | FIRE ALARM IS SHOWING TROUBLE (NO ID). SBE-WHITE/416-0640 | 7/1/13 | | | Electrical |
| Kate Bond MS (2007) 2A | Two receptacles coming out of wall. | 7/1/13 | Cafeteria | Serving area | Electrical |
| Kate Bond MS (2007) 2A | Working for Energy Managment. | 7/22/13 | | | Electrical |

| | | | | | |
|------------------------|---|---------|------------------|-----------------|------------|
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 complete power outage | 3/17/14 | | | Electrical |
| Kate Bond MS (2007) 2A | Annunciator open circuit | 3/17/14 | | | Electrical |
| Kate Bond MS (2007) 2A | room 161A unit not coming on per campbell 826-7298 | 3/19/14 | | | Electrical |
| Kate Bond MS (2007) 2A | principal is requesting for the building and parking lot lights be re-set to come on at 7:45 p.m and go off at 7:15 a.m. | 3/24/14 | Parking Lot | front/back | Electrical |
| Kate Bond MS (2007) 2A | need vent-a-hood repair.....dosen't work properly | 3/24/14 | Kitchen | | Electrical |
| Kate Bond MS (2007) 2A | broken light fixture in boys lockerroom shower area. | 3/25/14 | Gym | boys lockerroom | Electrical |
| Kate Bond MS (2007) 2A | UNIT NOT COMING ON IN RM-161A. PLANT MGR- CAMPBELL/416.0640 | 3/27/14 | | | Electrical |
| Kate Bond MS (2007) 2A | broken door holding magnet arm | 3/27/14 | Hallway/Corridor | 7th grade hall | Electrical |

| | | | | | |
|------------------------|---|----------|---------------------|-------------------|------------|
| Kate Bond MS (2007) 2A | need T 8's light bulbs for project assignment on campus(4 boxes) | 4/24/14 | | campus projects | Electrical |
| Kate Bond MS (2007) 2A | need master clock set in main office area. | 11/5/13 | Administration Area | | Electrical |
| Kate Bond MS (2007) 2A | fire alarm system not working properly, monitor is saying (duct fault -line 1). system is chaming every morning vary loudly | 11/19/13 | Administration Area | Main Office | Electrical |
| Kate Bond MS (2007) 2A | POWER OUTAGE IN PORT - 301 PLANT MGR- CAMPBELL/416.0640 | 12/2/13 | | | Electrical |
| Kate Bond MS (2007) 2A | lab tables have no power, even when you hit the reset. | 12/5/13 | 2nd Floor | scenice lab rm228 | Electrical |
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 cafeteria heat is not coming on 56 degrees | 12/9/13 | | | Electrical |
| Kate Bond MS (2007) 2A | outside door pad will not let parents in to the location when pressed or activated. | 12/19/13 | Cafeteria | entrance doors | Electrical |
| Kate Bond MS (2007) 2A | back-up generator not working properly | 1/2/14 | | outside building | Electrical |

| | | | | | |
|------------------------|---|---------|------------------|---------------------------|------------|
| Kate Bond MS (2007) 2A | Unit is NOT COMING ON in ROOM A218 per Mr. Campbell, Plant Mgr. 826.7298 | 1/6/14 | | | Electrical |
| Kate Bond MS (2007) 2A | several lighrts out on both side of the campus | 2/10/14 | | canapy (east/south sides) | Electrical |
| Kate Bond MS (2007) 2A | receptical plate broken by milk box (replace) | 2/10/14 | Kitchen | | Electrical |
| Kate Bond MS (2007) 2A | RECEPTACLE KITCHEN AREA FOR MILKBOX-HANGING FROM WALL WITH LIVE WIRES EXPOSED-PLANT MGR CAMPBELL 826-7298 KLR | 2/10/14 | | | Electrical |
| Kate Bond MS (2007) 2A | broken door holder (Door magnet) | 2/11/14 | Hallway/Corridor | 2nd floor area | Electrical |
| Kate Bond MS (2007) 2A | FIRE ALARM KEEPS TRIPPING PLANT MGR-CAMPBELL/826.7298 | 2/21/14 | | | Electrical |
| Kate Bond MS (2007) 2A | Need assistance locating a broken/open data wire to the main lobby annunciator from the fire alarm panel. | 2/26/14 | | | Electrical |
| Kate Bond MS (2007) 2A | Replace HID fixture with LED fixtures in the main lobby. | 2/27/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|-------------|---------------------|------------|
| Kate Bond MS (2007) 2A | Replace parking lot lighting with LED fixtures. | 2/27/14 | Parking Lot | | Electrical |
| Kate Bond MS (2007) 2A | need (6) boxes of T-8's for project work jobs in classroom areas | 2/27/14 | Classroom | | Electrical |
| Kate Bond MS (2007) 2A | outside lights are not working properly under the east and west entrance doors,also on the northside entrance door. | 2/28/14 | | outside campus area | Electrical |
| Kate Bond MS (2007) 2A | need T-8's to start project work here on campus for spring break | 3/7/14 | | campus | Electrical |
| Kate Bond MS (2007) 2A | UNIT NOT COMING ON IN GYM. PLANT MGR-ARNOLD/416-8574 | 7/29/13 | | | Electrical |
| Kate Bond MS (2007) 2A | Complete circuit for new sign. | 7/31/13 | | | Electrical |
| Kate Bond MS (2007) 2A | BALLAST OUT IN RM A135 RM IS DARK. SBE ARNOLD 416-8574 | 8/5/13 | | | Electrical |
| Kate Bond MS (2007) 2A | The door magnetic holder on this hallway corridor doors are broken. This needs to be repaired asap. | 8/6/13 | 1st Floor | B Hallway | Electrical |

| | | | | | |
|------------------------|---|----------|-----------|----------------|---------------------------------------|
| Kate Bond MS (2007) 2A | There are several lights that are out in this area. It is approximately 15 to 20 lights that are blown on the outside campus lights. | 8/6/13 | Grounds | Outside Lights | Electrical |
| Kate Bond MS (2007) 2A | There are a few lights that are blown in the main lobby. These lights are located on the walls in the lobby. There is a lift needed to change these lights. | 8/6/13 | 1st Floor | | Electrical |
| Kate Bond MS (2007) 2A | There is a basketball goal that is hung, and will not move. It is making a humming noise, but will not move. This needs to be repaired or replaced. | 9/6/13 | Gym | | Electrical |
| Kate Bond MS (2007) 2A | RTU NOT COMING ON IN GYM PLANT MGR- ARNOLD/416.8574 | 9/10/13 | | | Electrical |
| Kate Bond MS (2007) 2A | LIGHTS NOT COMING ON IN RM A146-COMpletely DARK-DON'T HAVE ANOTHER RM FOR CLASS- PLANT MGR ARNOLD 416-8574 KLR | 9/11/13 | | | Electrical |
| Kate Bond MS (2007) 2A | a/c won't come on room A152 and Gym a/c won't come on per Mr. Arnold 416-8574 | 9/11/13 | | | Electrical |
| Kate Bond MS (2007) 2A | several lights out inside gym area, principal requesting repairs due to basketball season starting soon | 10/22/13 | Gym | | Electrical |
| Kate Bond MS (2007) 2A | A/C G234, G206, F234, B115, B125, ISS RM, B150, B117, A151, G224, B139, & A137- ALL NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 4/25/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|-----|--|--|
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 room 115 and dining area in cafeteria blowing hot | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT NOT COOLING IN BAND, GYM, DINNING RM, KITCHEN, ENTIRE 2ND FLR. PLANT MGR- CAMPBELL/416.0640 | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 main office principals office blowing heat | 5/5/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | A/C KITCHEN AREA-NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 5/5/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU - CAFE - BLOWING NOT COOLING - PM/CAMPBELL 826-7298 | 5/21/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Monthly - Filters - Kate Bond Middle - Refer to PM schedule details. | 6/29/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | A/C BANDRM-NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 5/15/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | broken thermostat hanging from wall | 5/16/14 | Gym | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|---------|--|--|---------------------------------------|
| Kate Bond MS (2007) 2A | UNIT IN THE GYM AND MAIN OFFICE IS NOT COOLING. | 7/10/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | AHU NOT COOLING IN MAIN OFFICE. SBE-SNERLING/416-0640 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | A/C UNIT NOT COOLING IN MAIN OFFICE. SBE-WHITE/416-0020 | 7/22/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT IS OVERHEATING (83) IN MAIN OFFICE. PLANT MGR- CAMPBELL/416.0640 | 3/27/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | A/C RM 228, 231, & 204-ALL NOT COOLING-PLANT MGR CAMPBELL 416-0640 KLR | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT NOT COOLING IN CAFE PLANT MGR/CAMPBELL/416.0640 | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | rooms F229, F233, F206, F221, F204 too hot (83 degrees and above) per Mr. Campbell 826-7298 | 12/5/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|--|--|---------------------------------------|
| Kate Bond MS (2007) 2A | no heat cafe and auditorium | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | HEAT RM A137-NOT HEATING-PLANT MGR CAMPBELL 416-0640 KLR | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Unit is NOT HEATING in ROOMS A137 & A146 per Mr. Campbell, Plant Mgr. 826.7298 | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT NOT HEATING IN RM-A161 PLANT MGR-CAMPBELL/416.0640 | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT NOT HEATING IN RM-F232, & MAIN OFFICE PLANT MGR-CAMPBELL/416.0640 | 1/30/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 rooms A168, A169, A137, F206 no heat blowing cold also principal's office in main office | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT NOT HEATING IN LIBRARY, RM-47, ANNEX HALL PLANT MGR-CAMPBELL/416.0640 | 2/12/14 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Monthly - Filters - Kate Bond Middle - Refer to PM schedule details. | 3/2/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|---------|--|--|---------------------------------------|
| Kate Bond MS (2007) 2A | A/C in gym not cooling per ms white 416-0640 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT IN THE GYM IS NOT COOLING. SBE WHITE 416-0640 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT IN THE MAIN OFFICE IS NOT COOLING. SBE WHITE 416-0640 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | UNIT IN THE CAFE IS NOT COOLING. SBE WHITIE 416-0640 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU - RM F234 & RM G206 - BLOWING BUT NOT COOLING - PM/ARNOLD 416-8574 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU NOT COOLING IN RM-B131, B143 PLANT MGR-ARNOLD/416.0640 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | 6-RTU NOT COOLING IN GYM, RM-F234, F235, G233 PLANT MGR-ARNOLD/267.3738 | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Unit will NOT COME ON in the main office per Mr. Arnold, Plant Mgr. 901.416.8574. | 8/15/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|-----|--|---------------------------------------|
| Kate Bond MS (2007) 2A | F234 and F235 a/c not cooling per Mr. Arnold 416-8574 | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Rooms F234 and F235 a/c not cooling per Mr. Arnold 416-0640 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Unit Ventilator leaking from the ceiling (7th Grade Hallway) per Mr. Arnold, Plant Mgr. 416.8574 | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU # 4 Not Cooling | 10/17/13 | Gym | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU # 5 Not Cooling | 10/17/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU # 6 Not Cooling | 10/17/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | RTU # 3 NOT Cooling gym | 10/17/13 | | | Heating/Ventilation /Air Conditioning |
| Kate Bond MS (2007) 2A | Monthly - Filters - Kate Bond Middle - Refer to PM schedule details. | 11/3/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|---------|------------------|------------------------|----------|
| Kate Bond MS (2007) 2A | Joint composite material has been removed from several wall seams exposing cinder blocks and dead bugs. | 7/25/13 | Hallway/Corridor | Throughout building | Painting |
| Kate Bond MS (2007) 2A | head principal requesting for multiplal area to be touched - up painted (attn Mr. Gilliam) | 5/19/14 | Restroom (Boys) | | Painting |
| Kate Bond MS (2007) 2A | graffitti in boys restroom area (remove) | 6/3/14 | Restroom (Boys) | | Painting |
| Kate Bond MS (2007) 2A | paint lines on football field | 5/27/14 | | | Painting |
| Kate Bond MS (2007) 2A | remove graffiti from walkway | 5/30/14 | | | Painting |
| Kate Bond MS (2007) 2A | Paint touch up needed throughout the building especially in high traffic areas. | 7/24/13 | Restroom (Boys) | 8th and 7th grade hall | Painting |
| Kate Bond MS (2007) 2A | paint lines on football field | 8/20/13 | | | Painting |
| Kate Bond MS (2007) 2A | GRAFFITI IN B/RR 2ND FLR PLANT MGR- ARNOLD/416.8574 | 8/28/13 | | | Painting |

| | | | | | | |
|------------------------|--|---------|-----------------|------------------|--|----------|
| Kate Bond MS (2007) 2A | paint lines on football field | 9/9/13 | | | | Painting |
| Kate Bond MS (2007) 2A | There is a lot of graffiti in this restroom that needs to be removed. | 10/9/13 | Restroom (Boys) | G Hallway | | Painting |
| Kate Bond MS (2007) 2A | There is some graffiti in this restroom that needs to be removed from the walls and stall doors. | 10/9/13 | 2nd Floor | F Hallway | | Painting |
| Kate Bond MS (2007) 2A | water leak from pipe on to gym floor area (wood floor) | 6/9/14 | Gym | by boys restroom | | Plumbing |
| Kate Bond MS (2007) 2A | Request back flow test. | 6/2/14 | | | | Plumbing |
| Kate Bond MS (2007) 2A | Water is leaking from pipe underneath garbage desposial, unable to control | 5/12/14 | Kitchen | | | Plumbing |
| Kate Bond MS (2007) 2A | WATER PIPE RM A115-LEAKING IN CEILING-PLANT MGR CAMPBELL KLR | 5/8/14 | | | | Plumbing |
| Kate Bond MS (2007) 2A | GAS SMELL IN KITCHEN AREA-PLANT MGR CAMPBELL KLR | 4/29/14 | | | | Plumbing |

| | | | | | |
|------------------------|---|---------|---------------------|----------------|----------|
| Kate Bond MS (2007) 2A | restroom sink has low water flow | 5/2/14 | Custodial | break room | Plumbing |
| Kate Bond MS (2007) 2A | Very low water pressure in all custodial closets. | 7/25/13 | Custodial Closet | | Plumbing |
| Kate Bond MS (2007) 2A | keys flushed down the toilet in area | 3/26/14 | Gym | coach restroom | Plumbing |
| Kate Bond MS (2007) 2A | Flush sewer | 3/31/14 | | | Plumbing |
| Kate Bond MS (2007) 2A | head principal's office sink in restroom area not working properly. low water flow | 4/1/14 | Administration Area | | Plumbing |
| Kate Bond MS (2007) 2A | low water flow in restroom area. | 4/1/14 | Classroom | ISS room | Plumbing |
| Kate Bond MS (2007) 2A | GAS SMELL MAIN HALLWAY BY MAIN OFC/MIDDLE STAIRWELL-PLANT MGR CAMPBELL 416-0640 KLR | 4/11/14 | | | Plumbing |
| Kate Bond MS (2007) 2A | standing urinal will not stop running water | 4/25/14 | Restroom (Boys) | by gym area | Plumbing |

| | | | | | |
|------------------------|---|----------|------------------|-------------------|----------|
| Kate Bond MS (2007) 2A | TOILET PIPE is RUNNING WATER (THIRD STALL) in the GIRL'S RR on 6TH Grade Hall per Mr. Campbell, Plant Mgr. 826.7289 | 4/25/14 | | | Plumbing |
| Kate Bond MS (2007) 2A | principal requesting for toilet to be removed to get keys that where dropped into toilet by custodial helper. | 11/21/13 | Restroom (Girls) | annex | Plumbing |
| Kate Bond MS (2007) 2A | sink in area has broken faucet handle . | 12/9/13 | Restroom (Boys) | 7th grade hallway | Plumbing |
| Kate Bond MS (2007) 2A | Handicap toilet seat needs repair (broken) last stall | 12/16/13 | Restroom (Girls) | 1st fl (A) | Plumbing |
| Kate Bond MS (2007) 2A | SCIENCE LAB RM F232-GAS LEAKING FROM LAB TABLE- PLANT MGR CAMPBELL 416-0640 KLR | 1/23/14 | | | Plumbing |
| Kate Bond MS (2007) 2A | 3 compartment sink will not hold water, stopper to drain area not working properly. | 2/4/14 | Kitchen | | Plumbing |
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 in the CDC room 2nd floor in the restroom the floor drain is backing up into the classroom | 2/12/14 | | | Plumbing |
| Kate Bond MS (2007) 2A | per mr campbell 826-7298 kitchen has no hot water | 2/26/14 | | | Plumbing |

| | | | | | |
|------------------------|---|---------|-----------------|-------------|----------|
| Kate Bond MS (2007) 2A | handicap stall not working properly | 2/27/14 | Restroom (Boys) | 2nd fl (G) | Plumbing |
| Kate Bond MS (2007) 2A | Gas smell in main office per Ms. White 416-0640 | 7/26/13 | | | Plumbing |
| Kate Bond MS (2007) 2A | Water pressure very low in urinals. | 7/29/13 | Restroom (Boys) | 7th & 8th | Plumbing |
| Kate Bond MS (2007) 2A | Broken faucet on mop sink. | 7/31/13 | Cafeteria | Kitchen | Plumbing |
| Kate Bond MS (2007) 2A | There is an smell that is occurring quite often on this hallway. This smell is a strong sewer gas type smell, that is very loud on this hallway. This problem needs to be rectified asap!!! | 8/28/13 | 2nd Floor | F Hallway | Plumbing |
| Kate Bond MS (2007) 2A | There is a leak in this classroom under one of the science lab tables. This needs to be repaired asap!!! | 9/10/13 | 1st Floor | Science Lab | Plumbing |
| Kate Bond MS (2007) 2A | Sewer manhole stopped-up | 9/26/13 | | | Plumbing |
| Kate Bond MS (2007) 2A | Flush Sewer Lines | 9/26/13 | | | Plumbing |

| | | | | | |
|------------------------|--|----------|------------------|---------------------------------------|-------------|
| Kate Bond MS (2007) 2A | gas smell in the kitchen per Mr. Arnold 416-8574 | 10/1/13 | | | Plumbing |
| Kate Bond MS (2007) 2A | The faucet in this closet is leaking and needs to be repaired. | 10/2/13 | Custodial Closet | C Hallway near Plant Mangers Office | Plumbing |
| Kate Bond MS (2007) 2A | There is a toilet in this restroom that is leaking. This needs to be repaired asap!!!! | 10/3/13 | Restroom (Girls) | 1ST FLOOR MAIN HALLWAY NEAR CAFETERIA | Plumbing |
| Kate Bond MS (2007) 2A | Flush sewer | 10/14/13 | | | Plumbing |
| Kate Bond MS (2007) 2A | hadicapp stall not working properly,will not flush...kids in area. | 10/15/13 | Restroom (Boys) | 2nd fl 8th grade hallway | Plumbing |
| Kate Bond MS (2007) 2A | GARBAGE DISPOSAL IS BACKING UP IN 3-COM SINK KITCHEN. PLANT MGR- CAMPBELL/416.0640 | 10/30/13 | | | Plumbing |
| Kate Bond MS (2007) 2A | There is a need to have some covers installed in this room to cover the wires fro the piano's that are in this classroom. The wires are exposed from the piano's and are causing problems for the teacher and students in this room. | 8/19/13 | 1st Floor | Piano Lab | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|-------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| gsbury CTC (2377) | 1 | 20 | 59 | 24 | 2 | 25 | 14 | 1 | 146 |
| Grand Total | 1 | 20 | 59 | 24 | 2 | 25 | 14 | 1 | 146 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-------------------------|--|----------------|---------------------|--|-----------|
| Kingsbury CTC (2377) 2A | section of 12 floor tiles aloose on short hall off AP Office between the restrms **student tripped/safety concern** | 9/24/13 | Hallway/Corridor | 2nd floor | Asbestos |
| Kingsbury CTC (2377) 2A | plastic brown molding has come aloose from wall | 5/13/14 | 2nd Floor | corner of wall near 202 | Carpentry |
| Kingsbury CTC (2377) 2A | brown piece of molding missing | 5/21/14 | 1st Floor | Childcare entrance/103 | Carpentry |
| Kingsbury CTC (2377) 2A | Ceiling tiles need replace in Conference Room. Please , send extra ceiling tiles for stock. | 7/23/13 | 1st Floor | Conference Room | Carpentry |
| Kingsbury CTC (2377) 2A | closure isn't working properly causing exit door not to completely close **safety concern** | 8/8/13 | 1st Floor | end of hall leading to elevator | Carpentry |
| Kingsbury CTC (2377) 2A | the metal door coming aloose hindges **safety concern** | 9/5/13 | 1st Floor | welding shop | Carpentry |
| Kingsbury CTC (2377) 2A | missing baseboard & 2 peices detaching along base of wall | 9/6/13 | Hallway/Corridor | corner of rm#210 | Carpentry |
| Kingsbury CTC (2377) 2A | base board has come aloose/also on wall near eating area on main hall off elevator | 9/17/13 | Administration Area | wall @ entrance of Principal's office | Carpentry |

| | | | | | |
|-------------------------|--|----------|---------------------|----------------------------------|-----------|
| Kingsbury CTC (2377) 2A | new Teacher needs 2 4X6 dry eraser boards installed write classrm assignments. | 9/24/13 | 2nd Floor | mezaline/Mr. Moses | Carpentry |
| Kingsbury CTC (2377) 2A | oil leaking down door from closure | 10/16/13 | Administration Area | 1st FL./storage closet | Carpentry |
| Kingsbury CTC (2377) 2A | seal corner, mice running in/out | 10/16/13 | 1st Floor | corner across from snack machine | Carpentry |
| Kingsbury CTC (2377) 2A | baseboard missing behind his desk | 10/17/13 | Classroom | Mr. Butler/M-3 | Carpentry |
| Kingsbury CTC (2377) 2A | Top hindge is off set/cylinder misses strike plate/can't secure expensive graphic design equipment **URGENT, PLEASES** | 12/10/13 | Classroom | rm# 203/Mr Harris | Carpentry |
| Kingsbury CTC (2377) 2A | install 6X4 or 6X6 wht dry eraser board over dried up board that Instructor may be able to write out assignments to enhance students learning capabilities | 1/6/14 | Classroom | Mr. Applegate/rm#108 | Carpentry |
| Kingsbury CTC (2377) 2A | Cut ceiling tile in awkward shape to stop squirrel from coming down scaring young students. **Urgent, PLEASE!!** safety concern | 1/7/14 | Classroom | 1st FL/Child Care/103 | Carpentry |
| Kingsbury CTC (2377) 2A | cylinder won't release master keys | 2/28/14 | Administration Area | front office entrance door | Carpentry |
| Kingsbury CTC (2377) 2A | Principal is requesting to have a panic bar installed on MAIN office entrance. | 3/17/14 | Administration Area | main office/Per Principal | Carpentry |

| | | | | | |
|-------------------------|---|---------|---------------------|----------------------------------|------------|
| Kingsbury CTC (2377) 2A | Per Principal Batts: PLEASE install 6X6 bulletin board on wall of T. lounge to mount important papers up for teachers. | 4/9/14 | Administration Area | Teachers' Lounge | Carpentry |
| Kingsbury CTC (2377) 2A | install wht board that has been purchased by school that students be able to perform writing tasks on board. **URGENT, PLEASE!** | 4/15/14 | Classroom | Childcare/Rm#104 | Carpentry |
| Kingsbury CTC (2377) 2A | top hindge of 2nd set of doors leading to shop area is off set/door over laps & slammis | 4/17/14 | Hallway/Corridor | left of 1st Fl. mechanical rm | Carpentry |
| Kingsbury CTC (2377) 2A | Conference Room table need repair. | 7/24/13 | 1st Floor | Conf. Room | Carpentry |
| Kingsbury CTC (2377) 2A | Mr. Davis requesting wiring/piping be ran from 240 volt plug that's on wall that students be able to use newly bought equipment | 5/8/14 | Classroom | Audio Rm/#101 near elevator | Electrical |
| Kingsbury CTC (2377) 2A | UNIT NOT ON IN RM-209 THRU 212 PLANT MGR- SNERLING/416.6000 | 5/21/14 | | | Electrical |
| Kingsbury CTC (2377) 2A | 2 cs florescent tubes | 5/23/14 | Custodial | Plant mng'r's office | Electrical |
| Kingsbury CTC (2377) 2A | ballast burned out near exit door/tubes have been changed | 5/6/14 | 1st Floor | T. lounge | Electrical |
| Kingsbury CTC (2377) 2A | 1 ballast burned out/tubes changed fixture @ entrance inside of T. lounge---set of plastic contacts doesn't work | 5/6/14 | 1st Floor | Culinary Dining area | Electrical |

| | | | | | |
|-------------------------|--|---------|------------------|-----------------------------------|------------|
| Kingsbury CTC (2377) 2A | inside booth within audio rm--outlets doesn't work **need 6 flood lights for round dome over tables** | 5/6/14 | Classroom | Audio Rm/#101 near elevator | Electrical |
| Kingsbury CTC (2377) 2A | replace 2 ballasts | 7/2/13 | Hallway/Corridor | 2nd fl/hall straight off elevator | Electrical |
| Kingsbury CTC (2377) 2A | UNIT IN RM 101 IS NOT COMING ON. SBE SNERLING 416-6100 | 7/12/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | Need all clocks synchronized. | 7/30/13 | 1st Floor | 1st & 2nd floor | Electrical |
| Kingsbury CTC (2377) 2A | 3-RTU NOT COMING ON IN M1,2,3. PLANT MGR- SNERLING/416-6000 | 7/31/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | Bad condensor motor | 8/1/13 | 2nd Floor | Rooftop #10 | Electrical |
| Kingsbury CTC (2377) 2A | Install 220 outlet for new 3D printer to enhance teaching/learning of students **URGENT , PLEASE!!** | 8/2/13 | Classroom | Rm#203/Per Principal | Electrical |
| Kingsbury CTC (2377) 2A | UNIT IN THE SHOP IS NOT COMING ON SBE NOLEN 416-0581 | 8/2/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | Ballast out in hall out side of room 106. two lamp | 8/5/13 | | | Electrical |

| | | | | | |
|-------------------------|---|---------|---------------------|--------------------------------------|------------|
| Kingsbury CTC (2377) 2A | All four pole lights are out may be eye gone bad. | 8/6/13 | | out side | Electrical |
| Kingsbury CTC (2377) 2A | 2 ballasts burned out ***need tubes to replace blown tubes*** | 8/14/13 | Hallway/Corridor | that kitchen is located on | Electrical |
| Kingsbury CTC (2377) 2A | ballast burning out/flickering effect | 8/14/13 | Administration Area | main office/near Secretary's desk | Electrical |
| Kingsbury CTC (2377) 2A | 2 ballast burned out/ **need 2cs of fluorescent tubes** | 8/16/13 | Hallway/Corridor | main hallway | Electrical |
| Kingsbury CTC (2377) 2A | system is showing horn trouble/Z60 short circuit/won't reset | 8/28/13 | Administration Area | main office | Electrical |
| Kingsbury CTC (2377) 2A | ballast burned out over desk | 8/29/13 | Custodial | Plant Mng'r's Office | Electrical |
| Kingsbury CTC (2377) 2A | 1 ballast burned out | 8/30/13 | Hallway/Corridor | near sitting area/1st floor | Electrical |
| Kingsbury CTC (2377) 2A | 3 ballast burned | 8/30/13 | Hallway/Corridor | 2nd floor | Electrical |
| Kingsbury CTC (2377) 2A | Special bulbs for front entrance of gym under the canopy. Prolume LU70/MED SN134. Six bulbs needed. | 9/9/13 | | front entrance to gym | Electrical |

| | | | | | |
|-------------------------|--|---------|-----------|-----------------------------|------------|
| Kingsbury CTC (2377) 2A | ballast burned out/area is very dark **tripping concern for students** | 9/12/13 | Stairway | @ elevator | Electrical |
| Kingsbury CTC (2377) 2A | 2 ballast burned out over stove & counter/dark on this side of kitchen **URGENT, PLEASE!!** | 9/17/13 | Kitchen | Culinary Arts | Electrical |
| Kingsbury CTC (2377) 2A | 1 ballast burned out @ entrance | 9/17/13 | Kitchen | Culinary Arts/inside pantr | Electrical |
| Kingsbury CTC (2377) 2A | 3 receptacles aren't working | 9/24/13 | 1st Floor | welding lab | Electrical |
| Kingsbury CTC (2377) 2A | lights out on top corner of acility, & @ entrance across entire 2nd story. | 9/26/13 | Grounds | back wall & lot | Electrical |
| Kingsbury CTC (2377) 2A | Is completely dark ***security concern*** | 9/26/13 | Grounds | entire parking lot | Electrical |
| Kingsbury CTC (2377) 2A | lights out uder canopy/extremely dark | 9/26/13 | 2nd Floor | 1st & 2nd floor back canoay | Electrical |
| Kingsbury CTC (2377) 2A | 1 ballast burned out in staorage rm & 3 burned out in classrm | 10/1/13 | Classroom | Rms# 210 | Electrical |
| Kingsbury CTC (2377) 2A | 2 ballast burned out over students desks | 10/1/13 | Classroom | Rms# 213 | Electrical |

| | | | | | |
|-------------------------|---|----------|---------------------|--------------------|------------|
| Kingsbury CTC (2377) 2A | HALF OF THE LIGHTS IN RM 201 COSMOTOLOGY RM-NOT COMING ON-WILL NEED FOR CLASS-PLANT MGR SNERLING 416-6000 KLR | 10/4/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | Mr. Moses needs (1) 220 plug repaired & 1 plug has fuse blown | 10/21/13 | Machine Shop | welding shop | Electrical |
| Kingsbury CTC (2377) 2A | ALL RECEPTACLES HAVE NO POWER IN RM-201. PLANT MGR-SNERLING/416.6000 | 10/22/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | NO POWER IN RM-201. PLANT MGR-SNERLING/416.6040 | 10/25/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | THERMOSTAT NOT COMING ON IN RM-101 PLANT MGR-SNERLING/416.6060 | 10/30/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | 3 ballast burned out/need lights that students maybe able perform assignments | 11/6/13 | Machine Shop | Mr. Hulbert's area | Electrical |
| Kingsbury CTC (2377) 2A | All colck in building need synchronize. | 11/7/13 | 2nd Floor | Inside building | Electrical |
| Kingsbury CTC (2377) 2A | secretary's area in main office has no power per Ms. Snerling 416-6000 (SCS Network Cabling and Electronics dept. does not support this type of request. "Please See | 11/12/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | adjust clocks back an hour | 11/14/13 | Administration Area | 1st floor | Electrical |

| | | | | | |
|-------------------------|--|----------|------------------|---------------------------------------|------------|
| Kingsbury CTC (2377) 2A | smoke detector is beeping | 11/20/13 | Hallway/Corridor | 1st floor @ calinary kitchen entrance | Electrical |
| Kingsbury CTC (2377) 2A | Parking lot light pole is out,please replace bulbs. | 11/22/13 | Grounds | Back parking lot | Electrical |
| Kingsbury CTC (2377) 2A | Ballast need replace in two fixture in sewing machine room. | 11/22/13 | 2nd Floor | Sewing machine room | Electrical |
| Kingsbury CTC (2377) 2A | no power to compressor/breakers checked--not tripped **URGENT, PLEASE!!** needed for student participation | 12/3/13 | Machine Shop | Mr. Hulbart | Electrical |
| Kingsbury CTC (2377) 2A | main hall by kitchen the clock on wall has wires exposed per Ms. Snerling 416-6000 | 12/4/13 | | | Electrical |
| Kingsbury CTC (2377) 2A | install new plug to accommodate plug of dryer to enable students capability to keep towels sterile/clean | 1/7/14 | Classroom | 2nd FL/Barbering Classroom | Electrical |
| Kingsbury CTC (2377) 2A | 2 cs flourescent tubes/ 6 screw in flourescent #46820 | 1/16/14 | Custodial | Plant mngr | Electrical |
| Kingsbury CTC (2377) 2A | HEAT RM 101-NOT COMING ON-PLANT MGR SNERLING 416-6060 KLR | 1/23/14 | | | Electrical |
| Kingsbury CTC (2377) 2A | 1 ballast burned out | 2/24/14 | Classroom | rm# 103/Child care | Electrical |

| | | | | | |
|-------------------------|---|---------|---------------------|------------------------------|------------|
| Kingsbury CTC (2377) 2A | reset clocks due to daylight saving time | 3/8/14 | Administration Area | throughout facility | Electrical |
| Kingsbury CTC (2377) 2A | HEAT RM 101 AUDIO-NOT COMING ON-PLANT MGR SNERLING 416-6000 KLR | 4/2/14 | | | Electrical |
| Kingsbury CTC (2377) 2A | Mr. Yancey on site--replace 1 ballast /tubes flickering | 4/10/14 | Administration Area | over secretary's desk | Electrical |
| Kingsbury CTC (2377) 2A | per ms snerling 416-6000 no electricity in room 201 which is the cosmetology room | 4/11/14 | | | Electrical |
| Kingsbury CTC (2377) 2A | replace exit sign | 4/16/14 | Stairway | off shop leading upper floor | Electrical |
| Kingsbury CTC (2377) 2A | 2nd row opposite T. desk/changed tubes but won't stop twinkling | 4/16/14 | Classroom | rm#210 | Electrical |
| Kingsbury CTC (2377) 2A | replaced tubes/need ballast replaced/twinkling effect over computers **URGENT, PLEASE** | 4/29/14 | Classroom | 2nd FL/rm #210 | Electrical |
| Kingsbury CTC (2377) 2A | wall outlet near entrance door isn't functioning | 5/1/14 | Classroom | 2nd FL/rm #212 | Electrical |
| Kingsbury CTC (2377) 2A | 1 ballast burned out | 5/1/14 | 1st Floor | T. Lounge | Electrical |

| | | | | | |
|-------------------------|---|---------|--|--|---------------------------------------|
| Kingsbury CTC (2377) 2A | per ms snerling 416-6000 RTU #8 is blowing hot | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | AHU MAIN OFC AREA- MAKING NOISES-PLANT MGR SNERLING 416- 6000 KLR | 6/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Oil Lube & Belt- Kingsbury VoTech - Refer to PM schedule details. | 7/7/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | RTU IN RM-210 & HARRINGTON RM NOT COOLING . PLANT MGR- SNERLING/416.6060 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Air Compressor 056 - Kingsbury CTC - Refer to PM schedule details. | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Air Compressor 060 - Kingsbury CTC - Refer to PM schedule details. | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | RTU-7 SE CORNER SERVES RMS 1-3-NOT COOLING-SBE SNERLING 416-6100 KLR | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | RTU RM 101-NOT COOLING-PLANT MGR SNERLING 416-6100 KLR | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | RTU#3,9 NOT COOLING IN GUIDANCE OFFICE. SBE-NOLAN/416-6000 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|--|--|---------------------------------------|
| Kingsbury CTC (2377) 2A | UNIT IN RM 101 IS NOT COOLING. SBE NOLEN 416- | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | AHU NOT HEATING IN MAIN OFFICE PLANT MGR- SNERLING/416.6000 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | HEAT PRIN'S OFC-NOT HEATING-PLANT MGR SNERLING 416-6000 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Units are NOT HEATING in the Guidance Complex and Mezzanine per Ms. Snerling, Plant Mgr. 416.6000. | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | HEAT MUSIC STUDIO RM 101-NOT HEATING-PLANT MGR SNERLING 416-6000 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | AHU NOT HEATING IN RM-M1,2,3. PLANT MGR- SNERLING/416.6000 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Oil Lube & Belt-Kingsbury VoTech - Refer to PM schedule details. | 2/9/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Air Compressor 056 - Kingsbury CTC - Refer to PM schedule details. | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Air Compressor 060 - Kingsbury CTC - Refer to PM schedule details. | 2/11/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|----------|--|--|---------------------------------------|
| Kingsbury CTC (2377) 2A | per ms snerling 416-6000 room 205 (the barber classroom) is blowing cold | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | UNIT IS RELEASING AN ODOR IN RM-104 PLANT MGR-SNERLING/416-6060 | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Filter-Kingsbury CTC - Refer to PM schedule details. | 9/1/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Filter-Kingsbury CTC - Refer to PM schedule details. | 5/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | Monthly - Filter-Kingsbury CTC - Refer to PM schedule details. | 12/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury CTC (2377) 2A | GANG GRAFFITI OUTSIDE ON BRICK WALL REAR OF WELDING SHOP-PLANT MGR SNERLING 416-6060 KLR | 9/5/13 | | | Painting |
| Kingsbury CTC (2377) 2A | GANG GRAFFITI OUTSIDE SIDE BRICK WALL OFF ENTRANCE TO DRIVEWAY-PLANT MGR SNERLING 416-9661 KLR | 10/22/13 | | | Painting |
| Kingsbury CTC (2377) 2A | URINAL WON'T SHUT OFF IN B/RR 1ST FLR PLANT MGR-SNERLING/416.6060 | 5/6/14 | | | Plumbing |

| | | | | | |
|-------------------------|---|---------|------------------|-----------|----------|
| Kingsbury CTC (2377) 2A | 2nd stall from wall/replace set | 7/12/13 | Restroom (Boys) | 2nd Floor | Plumbing |
| Kingsbury CTC (2377) 2A | 1st & 3rd urinal/flush valve stuck & won't stop flushing | 7/12/13 | Restroom (Boys) | 1st Floor | Plumbing |
| Kingsbury CTC (2377) 2A | handicap stall/leaking from valve stem when flushed | 7/12/13 | Restroom (Girls) | 1st Floor | Plumbing |
| Kingsbury CTC (2377) 2A | 2nd stall from wall/water gushing from around base of chrome pipe when flushed | 7/12/13 | Restroom (Girls) | 2nd Floor | Plumbing |
| Kingsbury CTC (2377) 2A | Toilet Leaking. | 8/2/13 | 1st Floor | 103B | Plumbing |
| Kingsbury CTC (2377) 2A | PILOTS NEEDS TO BE LIT IN THE CULINARY OFFICE. SBE SNERLLING 416-6100 | 8/5/13 | | | Plumbing |
| Kingsbury CTC (2377) 2A | RTU SW CTR SERVES 2ND FLR BETWEEN RMS 209 & 210-LEAKING SBE SNERLING 416-6100 KLR | 8/12/13 | | | Plumbing |
| Kingsbury CTC (2377) 2A | replace faucet in restroom has constant flow from around base | 8/16/13 | Classroom | Rm#103 | Plumbing |
| Kingsbury CTC (2377) 2A | replace toilet seat/**safety concern** | 8/20/13 | Restroom (Boys) | 2nd FL | Plumbing |

| | | | | | |
|-------------------------|--|----------|------------------|-------------------------|----------|
| Kingsbury CTC (2377) 2A | anchors that on seat on comode have come out | 9/6/13 | Restroom (Boys) | 2nd floor | Plumbing |
| Kingsbury CTC (2377) 2A | pilot light needs to be lit in the culinary arts classroom per Ms. Snerling 416-6600 | 9/16/13 | | | Plumbing |
| Kingsbury CTC (2377) 2A | kitchen sink near counter stopped up/won't drain **URGENT, PLEASE!** | 10/17/13 | Kitchen | culinary arts | Plumbing |
| Kingsbury CTC (2377) 2A | deep sink stopped up/need for custodial cleaning **URGENT, PLEASE!** | 10/22/13 | Mechanical Room | across from main office | Plumbing |
| Kingsbury CTC (2377) 2A | replace seat/last stall to wall | 11/13/13 | Restroom (Girls) | 1st floor | Plumbing |
| Kingsbury CTC (2377) 2A | Gas is OUT in the Culinary Kitchen per Ms. Snerling, Plant Mgr. 416.2377 | 12/3/13 | | | Plumbing |
| Kingsbury CTC (2377) 2A | COMMODE - ADMIN AREA - CONSTANTLY RUNNING - CAN'T BE USED - PM/SNERLING 416-6000 | 12/13/13 | | | Plumbing |
| Kingsbury CTC (2377) 2A | COMMODE G RR 2ND FLR-FLUSH VALVE STUCK, CONSTANTLY RUNNING & LEAKING WATER OUT PER SBE, CAN'T CUT OFF OR CONTAIN-PLANT MGR SNERLING 416-6000 | 12/18/13 | | | Plumbing |
| Kingsbury CTC (2377) 2A | Pilots on stove needs to be LIT in the CULINARY ARTS Room per Ms. Snerling, Plant Mgr. 416.6000 | 1/14/14 | | | Plumbing |

| | | | | | |
|-------------------------|--|----------|---------------------|---------------------------------------|----------|
| Kingsbury CTC (2377) 2A | Water cooler sounds as if fan motor is stalling when compressor kicks on to cool water/manu by Elkay no ID # | 2/20/14 | Administration Area | main office between Admin restrms | Plumbing |
| Kingsbury CTC (2377) 2A | Water leaking from bowl & flood rm without faucets in use/had to shut water off under bowl to contain. **Students need sink to perform assigned tasks** | 2/24/14 | Classroom | Rm#103/Mrs Young | Plumbing |
| Kingsbury CTC (2377) 2A | faucet won't turn completely off/constant flow | 3/5/14 | Administration Area | restrm close to counter | Plumbing |
| Kingsbury CTC (2377) 2A | per ms snerling 416-6000 pilots are out in the culinary kitchen | 3/7/14 | | | Plumbing |
| Kingsbury CTC (2377) 2A | PIPE URINAL IS RUNNING WATER IN B/RR 1ST FLR. CANT CONTROL PLANT MGR-SNERLING/416.6000 | 4/8/14 | | | Plumbing |
| Kingsbury CTC (2377) 2A | Need ice maker repair, not making ice. | 7/30/13 | Kitchen | | Plumbing |
| Kingsbury CTC (2377) 2A | Leak in ceiling. | 8/2/13 | 1st Floor | 103B | Roof |
| Kingsbury CTC (2377) 2A | top left corner/water pours through every time it rains/has damaged items & wooden shelf | 8/16/13 | Classroom | Career rm 1st Fl/across from guidance | Roof |
| Kingsbury CTC (2377) 2A | roof leaking | 10/16/13 | 2nd Floor | short hall/between restrms | Roof |

| | | | | | |
|-------------------------|--|----------|------------------|------------------------|------|
| Kingsbury CTC (2377) 2A | Ceiling leaking due to crack in roof, please repair. | 11/22/13 | 2nd Floor | hallway near restrooms | Roof |
| Kingsbury CTC (2377) 2A | tiles falling out due to leak | 1/14/14 | Hallway/Corridor | in front rm#202 | Roof |
| Kingsbury CTC (2377) 2A | roof leaking 3 places left side classrm & in hall between rms # 205 & 203 | 2/3/14 | Classroom | Rm#205 & hall | Roof |
| Kingsbury CTC (2377) 2A | ceiling tiles falling out due to roof leaks | 2/6/14 | 2nd Floor | M-3/Mr. Butler | Roof |
| Kingsbury CTC (2377) 2A | roof leaking on carpet | 2/26/14 | 2nd Floor | barbering/Mr. Wilson | Roof |
| Kingsbury CTC (2377) 2A | roof leaking in 2nd floor barber rm & M-1 (mezaline) | 3/6/14 | Classroom | several areas | Roof |
| Kingsbury CTC (2377) 2A | ceiling tiles falling out due to roof leaks | 3/7/14 | 2nd Floor | Mezaline/Mr Moses | Roof |
| Kingsbury CTC (2377) 2A | roof leaking on carpet | 3/28/14 | 2nd Floor | Rm#205 | Roof |
| Kingsbury CTC (2377) 2A | between barber & drawing rm! Fast flow causing falling ceiling tiles & water flowing over into classrms! slippage/safety concern | 4/4/14 | Hallway/Corridor | 2nd floor | Roof |

| | | | | | |
|-------------------------|---|---------|---------------------|-------------------------------|-------------|
| Kingsbury CTC (2377) 2A | raining over her desk/only area to hook comp & phone **URGENT, PLEASE!** | 4/28/14 | Administration Area | 2nd FL/AP's office | Roof |
| Kingsbury CTC (2377) 2A | roof leaking **safety concern** | 4/28/14 | Hallway/Corridor | 2nd FL/between rms #203 & 204 | Roof |
| Kingsbury CTC (2377) 2A | install new vent for new dryer in classrm that students might be able to use it | 2/26/14 | 2nd Floor | barbering/Mr. Wilson | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| gsbury ES (2370) | 2 | 2 | 27 | 69 | 50 | 3 | 52 | 14 | 1 | 220 |
| Grand Total | 2 | 2 | 27 | 69 | 50 | 3 | 52 | 14 | 1 | 220 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|------------------------|---|----------------------|-------------------------|--------------------|--------------|
| Kingsbury ES (2370) 2A | please re tile entire floor. | 2/25/14 | 1st Floor | eastside rm. 10 | Asbestos |
| Kingsbury ES (2370) 2A | Please replace missing floor tile in classroom. | 3/20/14 | 2nd Floor | eastside rm. 36 | Asbestos |
| Kingsbury ES (2370) 2A | please repair the internet ports in classroom. | 1/7/14 | Portables | 339A | Cabling |
| Kingsbury ES (2370) 2A | Internet drops are not working in portable. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 12/17/13 | Portables | Portable 339A West | Cabling |
| Kingsbury ES (2370) 2A | Repair floor in portable #274 and 275. | 6/2/14 | | | Carpentry |
| Kingsbury ES (2370) 2A | please close in top wall. | 5/8/14 | 2nd Floor | speech rm. | Carpentry |
| Kingsbury ES (2370) 2A | Please repair broken stall door. | 4/25/14 | Restroom (Boys) | westside 1st. fl. | Carpentry |

| | | | | | |
|------------------------|---|---------|-------------|--------------------|-----------|
| Kingsbury ES (2370) 2A | please weld chain on gate. | 4/30/14 | Parking Lot | back driveway | Carpentry |
| Kingsbury ES (2370) 2A | please repair cable to parking lot. | 5/1/14 | Parking Lot | westside | Carpentry |
| Kingsbury ES (2370) 2A | WINDOW UNIT IN SPEECH RM - BLOWING NOT COOLING - PM/LEE 416-6020 | 5/6/14 | | | Carpentry |
| Kingsbury ES (2370) 2A | please repair handle on double door. | 4/14/14 | Stairway | eastside by rm. 13 | Carpentry |
| Kingsbury ES (2370) 2A | Replace floor tile that's been removed due to unit leaking. | 8/16/13 | Classroom | 10 east | Carpentry |
| Kingsbury ES (2370) 2A | WINDOW KITCHEN REAR DOOR ENTRANCE BROKEN OUT DUE TO A BREAK IN-SBE SNERLING 416-6040 KLR | 8/19/13 | | | Carpentry |
| Kingsbury ES (2370) 2A | OUTSIDE DOOR, CANT SECURE EAST-WING HALL. SBE-BANKS/416-6020 | 7/23/13 | | | Carpentry |
| Kingsbury ES (2370) 2A | Repair door leading into kitchen from line serving area it is very hard to open one side of the door is dragging the floor. | 7/26/13 | Kitchen | Line serving area | Carpentry |

| | | | | | |
|------------------------|--|----------|-----------|-------------------------------|-----------|
| Kingsbury ES (2370) 2A | The lock on the handicap restroom will not lock. Upstairs east hall. | 10/31/13 | 2nd Floor | East hall handicap restroom | Carpentry |
| Kingsbury ES (2370) 2A | ENTRANCE DOOR LIBRARY NOT CLOSING-WON'T BE ABLE TO SECURE-PLANT MGR BANKS 416-6020 KLR | 11/14/13 | | | Carpentry |
| Kingsbury ES (2370) 2A | replace metal plate/bent & catches door | 12/3/13 | Cafeteria | entrance door to serving line | Carpentry |
| Kingsbury ES (2370) 2A | please repair broken hinge. | 1/29/14 | 2nd Floor | eastside rm. 31 | Carpentry |
| Kingsbury ES (2370) 2A | please replace missing baseboard in classroom. | 1/29/14 | 2nd Floor | eastside rm. 31 | Carpentry |
| Kingsbury ES (2370) 2A | classroom window leaking. | 2/4/14 | Classroom | westside rm. 7 & 27 | Carpentry |
| Kingsbury ES (2370) 2A | please install a 4ft. bulletin board in classroom. | 2/7/14 | 1st Floor | westside rm. 7 | Carpentry |
| Kingsbury ES (2370) 2A | please replace missing floor tile in classroom. | 2/21/14 | 1st Floor | eastside rm. 10 | Carpentry |

| | | | | | |
|------------------------|---|---------|------------------|----------------------------|-----------|
| Kingsbury ES (2370) 2A | Repair floor in the portable. | 2/27/14 | | portable 275 | Carpentry |
| Kingsbury ES (2370) 2A | Cut vent holds in portable. | 2/27/14 | | portable 275 | Carpentry |
| Kingsbury ES (2370) 2A | Repair canopy pole in driver way. | 2/27/14 | | drive way | Carpentry |
| Kingsbury ES (2370) 2A | please repair panic bar it keep sticking. | 3/21/14 | Stairway | behind library | Carpentry |
| Kingsbury ES (2370) 2A | please repair fence that been cut open it seperate the Voctec from the elementary. | 3/21/14 | Grounds | eastside playground | Carpentry |
| Kingsbury ES (2370) 2A | please install a door sweep on outside door. | 3/27/14 | Hallway/Corridor | eastside by boy's restroom | Carpentry |
| Kingsbury ES (2370) 2A | please repair wholes in floor. | 4/2/14 | Portables | eastside 274 | Carpentry |
| Kingsbury ES (2370) 2A | Repair or replace ownings in front of the school building thats attached to the building. | 7/26/13 | | | Carpentry |

| | | | | | |
|------------------------|--|---------|------------------|--------------------------|------------|
| Kingsbury ES (2370) 2A | Bad Ballast. | 6/4/14 | 2nd Floor | eastside rm. 36 | Electrical |
| Kingsbury ES (2370) 2A | ELECTRICAL POLE is LEANING per Gerald Lee, Plant Mgr. 416.6020 | 6/5/14 | | | Electrical |
| Kingsbury ES (2370) 2A | A/C PORT 175-NOT COMING ON-PLANT MGR LEE 416-6020 KLR | 6/20/14 | | | Electrical |
| Kingsbury ES (2370) 2A | bulb arcing. | 5/14/14 | 2nd Floor | speech rm. | Electrical |
| Kingsbury ES (2370) 2A | bad ballast. | 5/14/14 | 1st Floor | east side hall by rm. 17 | Electrical |
| Kingsbury ES (2370) 2A | RTU - CAFE - MAKING A LOUD NOISE - PM/LEE 416- 6020 | 5/21/14 | | | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. | 5/21/14 | Hallway/Corridor | by rm 13 | Electrical |
| Kingsbury ES (2370) 2A | Bad ballast. | 5/21/14 | Mechanical Room | by clinic | Electrical |

| | | | | | |
|------------------------|--|---------|---------------------|----------------------------------|------------|
| Kingsbury ES (2370) 2A | Bad Ballast. | 5/21/14 | Cafeteria | by main hall | Electrical |
| Kingsbury ES (2370) 2A | RTU CAFE AREA-NOT COMING ON-PLANT MGR LEE 416-6020 KLR | 4/25/14 | | | Electrical |
| Kingsbury ES (2370) 2A | PORT #274 -A/C MAKING A LOUD NOISE - PM/LEE 416-6020 | 5/6/14 | | | Electrical |
| Kingsbury ES (2370) 2A | light outside not working [back canopy]. | 4/8/14 | 1st Floor | westside by portables | Electrical |
| Kingsbury ES (2370) 2A | light out in front of building. | 4/15/14 | Administration Area | front of building | Electrical |
| Kingsbury ES (2370) 2A | PORT 274E-NOT COMING ON-SBE BANKS 416-6020 KLR | 8/2/13 | | | Electrical |
| Kingsbury ES (2370) 2A | need lift to replace blown bulbs mounted on top frame of facility | 8/20/13 | Grounds | middle of wall inside playground | Electrical |
| Kingsbury ES (2370) 2A | UV EAST WING 1ST FLR RM10 & PORT 339-BOTH NOT COMING ON-SBE BANKS 416-6020 KLR | 7/31/13 | | | Electrical |

| | | | | | |
|------------------------|---|----------|---------------------|---------------------------------------|------------|
| Kingsbury ES (2370) 2A | Ten light fixtures are not working at all in these class rooms. | 9/18/13 | Classroom | 35E, 16E, 25W, and 339B West Portable | Electrical |
| Kingsbury ES (2370) 2A | UNIT NOT COMING ON IN RM-25 WEST PLANT MGE-BANKS/416.2172 | 9/27/13 | | | Electrical |
| Kingsbury ES (2370) 2A | Bells are not working have not worked in a while. We need bells to ring at 8:00am, 8:15am, 2:45pm and 3:00pm. | 10/16/13 | Administration Area | Main office | Electrical |
| Kingsbury ES (2370) 2A | 10 tubes through area is causing darkness | 10/23/13 | Cafetorium | PER Prin: Mrs Anderson | Electrical |
| Kingsbury ES (2370) 2A | Set time back on master clock for standard time. Equipment #031-090 | 11/4/13 | Administration Area | Main office | Electrical |
| Kingsbury ES (2370) 2A | We have no bells at Kingsbury Elem. We want bells to make school complete. | 11/12/13 | Administration Area | | Electrical |
| Kingsbury ES (2370) 2A | ROW OF LIGHTS RM 17E KINDERGARTEN-ONLY (2) ROWS PER SBE, IS COMPLETELY OUT-PLANT MGR BANKS 416-6020 KLR | 11/15/13 | | | Electrical |
| Kingsbury ES (2370) 2A | No lights in pantry in kitchen. No lights will work. | 11/15/13 | Cafeteria | Kitchen | Electrical |

| | | | | | |
|------------------------|--|----------|------------------|------------------------|------------|
| Kingsbury ES (2370) 2A | Light fixture cover broken. | 11/20/13 | Classroom | 12 East | Electrical |
| Kingsbury ES (2370) 2A | One Light fixture not working at all. | 11/20/13 | Hallway/Corridor | Hall West downstairs | Electrical |
| Kingsbury ES (2370) 2A | (3) HEATING UNITS CAFE AREA-ALL NOT COMING ON-PLANT MGR LEE 416-8060 KLR | 1/7/14 | | | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. | 1/8/14 | Classroom | eastside 2nd fl rm. 35 | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. | 1/9/14 | 2nd Floor | by elevator | Electrical |
| Kingsbury ES (2370) 2A | please send 3 cases of bulbs. | 1/9/14 | Custodial | plant manager office | Electrical |
| Kingsbury ES (2370) 2A | please install exit light. | 1/10/14 | 2nd Floor | east hall by rm. 31 | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. | 1/16/14 | Portables | 342B | Electrical |

| | | | | | |
|------------------------|---|----------|-----------------|--------------------|------------|
| Kingsbury ES (2370) 2A | Bad Ballast. | 1/22/14 | 2nd Floor | eastside rm 33 | Electrical |
| Kingsbury ES (2370) 2A | HEAT CAFE, FINANCIAL SEC OFC, & SBE'S OFC-ALL NOT COMING ON-PLANT MGR BANKS 416-6020 KLR | 12/10/13 | | | Electrical |
| Kingsbury ES (2370) 2A | PARTIAL OUTAGE-CAFE HAS NO POWER TO RECEPTACLES & COACH'S OFC IN SAME AREA HAS NO POWER TO RECEPTACLES OR LIGHTS-PLANT MGR BANKS 416-6020 KLR | 12/16/13 | | | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. please void ticket #410310 | 1/22/14 | Restroom (Boys) | 2nd floor westside | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. | 1/22/14 | Clinic | by boiler rm | Electrical |
| Kingsbury ES (2370) 2A | please replace receptcle on east serving line. | 1/22/14 | Kitchen | main hall | Electrical |
| Kingsbury ES (2370) 2A | ROW OF LIGHTS RM 23W- IS OUT-DARK IN RM PER SBE-PLANT MGR LEE 416-6020 KLR | 1/28/14 | | | Electrical |
| Kingsbury ES (2370) 2A | LIGHTS - 2ND FLR WEST END G RR - CAN'T GET ON - PM/LEE 416-6020 | 1/31/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|---------------------|--------------------|------------|
| Kingsbury ES (2370) 2A | bad ballast. | 2/5/14 | 2nd Floor | girl's restroom | Electrical |
| Kingsbury ES (2370) 2A | I have 2 bad ballast 1 in front of the library, & 1 inside the library. | 2/7/14 | Library | 1st floor westside | Electrical |
| Kingsbury ES (2370) 2A | Bad ballast. | 2/10/14 | Restroom (Girls) | westside 2nd floor | Electrical |
| Kingsbury ES (2370) 2A | Bad ballast. | 2/11/14 | Kitchen | main hall | Electrical |
| Kingsbury ES (2370) 2A | Bad ballast. | 2/14/14 | Library | 1st floor westside | Electrical |
| Kingsbury ES (2370) 2A | please set clock up 1 hour [daylight saving time]. | 2/24/14 | Administration Area | main office | Electrical |
| Kingsbury ES (2370) 2A | bad ballast. | 2/26/14 | Portables | westside 339A | Electrical |
| Kingsbury ES (2370) 2A | HEAT RM 13-NOT COMING ON, MOTOR BURNED OUT PER SBE-PLANT MGR LEE 416-6020 KLR | 2/27/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|---------------------|------------------------|------------|
| Kingsbury ES (2370) 2A | canopy lights not working. | 3/4/14 | Administration Area | front of building | Electrical |
| Kingsbury ES (2370) 2A | outside lights rm 11,12,13, cafeteria, & main hall, lights not working. | 3/4/14 | Courtyard | outside | Electrical |
| Kingsbury ES (2370) 2A | Please send 3 cases of florecent bulbs. | 3/18/14 | Cafeteria | plant manager's office | Electrical |
| Kingsbury ES (2370) 2A | bad ballast. | 3/20/14 | 1st Floor | west hall | Electrical |
| Kingsbury ES (2370) 2A | please repair bad socket on serving line. | 3/21/14 | Kitchen | east serving line | Electrical |
| Kingsbury ES (2370) 2A | Please replace 4 batteries in cafeteria emergency light. | 3/25/14 | Cafeteria | main hall | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | Kitchen | main hall | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light . | 3/25/14 | 1st Floor | east main hall | Electrical |

| | | | | | |
|------------------------|--|---------|-----------|--------------------|------------|
| Kingsbury ES (2370) 2A | replace battery in emergency light. | 3/25/14 | Stairway | eastside by rm.10 | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | 1st Floor | easeside by rm. 17 | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | 1st Floor | eastside by rm. 13 | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | Portables | westside 339B | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | Portables | westside 342B | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in exit light. | 3/25/14 | 1st Floor | westhall by rm.9 | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | Stairway | behind library | Electrical |
| Kingsbury ES (2370) 2A | please replace battery in emergency light. | 3/25/14 | 2nd Floor | westhall by rm. 29 | Electrical |

| | | | | | |
|------------------------|---|---------|-----------------|-----------------------|---------------------------------------|
| Kingsbury ES (2370) 2A | please install emergency light in classroom. | 3/25/14 | 1st Floor | westside rm. 9 | Electrical |
| Kingsbury ES (2370) 2A | bad ballast. | 3/28/14 | 1st Floor | easthall | Electrical |
| Kingsbury ES (2370) 2A | bad ballast. | 4/1/14 | Kitchen | eastside serving line | Electrical |
| Kingsbury ES (2370) 2A | bad ballast. | 4/2/14 | 2nd Floor | eastside 274 | Electrical |
| Kingsbury ES (2370) 2A | Bad Ballast. | 1/22/14 | Restroom (Boys) | 2nd floor westside | Electrical |
| Kingsbury ES (2370) 2A | A/C RM 26-NOT COOLING-PLANT MGR LEE 416-8020 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | per mr lee 416-6020 uv in room 32 not cooling | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UNIT VENT - 2ND WEST RM 26 & TCHR'S LOUNGE -P-TACK UNIT - BOTH ARE BLOWING NOT COOLING - AND HAVING SUMMER SCHOOL - PM/LEE 416-6020 | 6/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Kingsbury ES (2370) 2A | RTU -(3) CAFE - BLOWING NOT COOLING - PM/LEE 416-6020 | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | A/C RM 36-NOT COOLING-PLANT MGR LEE 416-6020 KLR | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | A/C UNIT in PORTABLE 274 NOT COMING ON per Gerald Lee, Plant Mgr. 416.6020 | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - Oil Lube & Belt-Kingsbury EI - Refer to PM schedule details. | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV RMS 34E, 12E, & 31E- ALL NOT COOLING-PLANT MGR 416-6020 KLR | 9/5/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | per mr lee 416-6020 the UV in the library is making a really loud noise | 4/7/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV RM 10 1ST FLR EAST SIDE-HAS A BURNING SMELL-PLANT MGR LEE 416-6020 KLR | 4/10/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV WEST WING 1ST FLR RM 4, WEST WING 1ST FLR RM 7, EAST WING 1ST FLR RM 12, EAST WING 1ST FLR RM 14, WEST WING 2ND FLR RM 19, WEST WING 2ND FLR RM 22, & EAST WING 2ND FLR RM 24 | 8/2/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|---------|--|--|---------------------------------------|
| Kingsbury ES (2370) 2A | UV WEST WING 1ST FLR RM 7, UV EAST WING 1ST FLR RM 12, & UV EAST WING 1ST FLR RM 14-ALL NOT COOLING-SBE BANKS 416-6020 KLR | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | PORT 339B-A/C NOT COOLING-PLANT MGR SNERLING 416-6060 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Unit Ventilator #032-053 leaking underneath in Rm 33, which is causing weaking leak in Rm 13 per Brenda Banks, Plant Mgr. @ 901.416.8256. | 7/12/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | a/c not working in following Principal's Office East Wing Rm 33 West Wing Rm 7 Brenda Banks 416-8256 | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV NOT COOLING IN RM-34 EAST-WING 2ND FLR(046) SBE-BANKS/416-6020 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | 9-UV NOT COOLING IN RM-7W(013) RM-33(050) RM-30E(053) RM-26W(019) RM-3(008) RM-10E(043) RM-14E(042) RM-15W(041) PORT-339. PLANT MGR- BANKS/416-6020 | 7/25/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV WEST WING 1ST FLR RM 7-NOT COOLING-SBE BANKS 416-6020 KLR | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Room 18 west a/c unit cover is off and making loud noise and Main office unit making loud noise and falling apart per Ms. Banks 416-6020 | 9/30/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|--|--|---------------------------------------|
| Kingsbury ES (2370) 2A | A/C RM 14W-MAKING NOISES & FRONT COVER COMING OFF-PLANT MGR BANKS 416-6020 KLR | 10/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - Oil Lube & Belt-Kingsbury EI - Refer to PM schedule details. | 10/22/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV NOT HEATING IN RM-33EAST . PLANT MGR-BANKS/416.2172 | 11/8/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | HEAT PORT 274W-NOT HEATING-PLANT MGR BANKS 416-6020 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | HEAT RM 26-NOT HEATING-PLANT MGR LEE 416-6020 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - Filter-Kingsbury Elementary - Refer to PM schedule details. | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | HEAT RM 12, 18, 32, & PORT 274-ALL NOT HEATING-PLANT MGR LEE 416-6020 KLR | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | PTAC UNIT MAIN OFC-NOT HEATING-PLANT MGR LEE 416-6020 KLR | 1/8/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|-----------|-----------|---------------------------------------|
| Kingsbury ES (2370) 2A | per Mr. Lee 416-6020 room 26 the unit ventilator has frozen up and he had to turn off | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | heater not working please replace motor. | 1/16/14 | Cafeteria | main hall | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UV NOT HEATING IN MAIN OFFICE, & CAFE PLANT MGR- HARVEY/416.2320 | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | 3-UNITS NOT HEATING IN RM-7,12,5. PLANT MGR-LEE/416.6020 | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | UNIT NOT HEATING IN RM-32,15,12,18,7,5, PORT-274 PLANT MGR-LEE/416.2172 | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | main office blowing cold air per mr lee 416-6020 | 1/30/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | per mr lee 416-6020 portable 342 unit not cooling | 2/20/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | check ptac in main office | 3/18/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|--|--|---------------------------------------|
| Kingsbury ES (2370) 2A | UNIT is NOT HEATING in Portable 342 per Mr. Lee, Plant Mgr. 416.6020 | 3/28/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 11/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 11/1/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 10/4/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 4/4/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------|--|---------|-------------|------------------|--|---------------------------------------|
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 2/28/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 1/31/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 1/3/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - Filter-Kingsbury Elementary - Refer to PM schedule details. | 9/10/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 5/2/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - Filter-Kingsbury Elementary - Refer to PM schedule details. | 5/6/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Monthly - 1' Filters (Monthly)- Kingsbury Elem - Refer to PM schedule details. | 5/30/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury ES (2370) 2A | Please re paint back parking lot. | 4/22/14 | Parking Lot | back parking lot | | Painting |

| | | | | | |
|------------------------|--|---------|------------------|--------------------------------------|----------|
| Kingsbury ES (2370) 2A | please paint or re stripe both parking lots. | 6/2/14 | Parking Lot | outside by portable 339& Graham side | Painting |
| Kingsbury ES (2370) 2A | GANG GRAFFITI OUTSIDE ON THE PARKING SIGNS- PLANT MGR BANKS 416-6020 KLR | 8/14/13 | | | Painting |
| Kingsbury ES (2370) 2A | please repair toliet won't cut off. | 6/30/14 | Restroom (Girls) | 1st fl. westside | Plumbing |
| Kingsbury ES (2370) 2A | A/C RM 28-LEAKING-PLANT MGR LEE 416-6020 KLR | 6/3/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | please repair leaking hand sink. | 5/30/14 | 2nd Floor | east hall | Plumbing |
| Kingsbury ES (2370) 2A | Please repair leaking toliet. | 4/7/14 | 1st Floor | westside girl's restroom | Plumbing |
| Kingsbury ES (2370) 2A | please repair 2 leaking faucets on hand sink. | 4/10/14 | 2nd Floor | westside hall | Plumbing |
| Kingsbury ES (2370) 2A | Please repair 2 leaking faucets in hand sink. | 4/10/14 | 1st Floor | east hall | Plumbing |

| | | | | | |
|------------------------|---|---------|-----------|-------------------|----------|
| Kingsbury ES (2370) 2A | please replace broken toilet seat. | 4/15/14 | 1st Floor | handicap restroom | Plumbing |
| Kingsbury ES (2370) 2A | please repair leaking faucet in hand sink. | 4/16/14 | 2nd Floor | east hall | Plumbing |
| Kingsbury ES (2370) 2A | A/C UNIT LIBRARY- LEAKING-SBE BANKS 416- 6020 KLR | 8/2/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | UV ARE LEAKING WATER IN LIBRARY, & ASSIST PRIN OFFICE, & TOILET WONT FLUSH IN NURSES OFFICE& SINK IS LEAKINGIN RM-17EAST PLANT MGR- BANKS/416.6020 | 8/6/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | UV EAST WING 1ST FLR RM 17E-LEAKING-SBE BANKS 416-6020 KLR | 8/6/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | GREASE TRAP IS BACKING UP.SBE BANKS 416-6020 | 8/7/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | Back flow test. | 8/8/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | 3-UV ARE LEAKING IN RM- 7 WEST(013) RM-10E(043) TEACHERS' LOUNGE (032). PLANT MGR- BANKS/416.6020 | 8/12/13 | | | Plumbing |

| | | | | | |
|------------------------|---|---------|------------|---|----------|
| Kingsbury ES (2370) 2A | Toilet leaking in school clinic. | 8/16/13 | | Clinic | Plumbing |
| Kingsbury ES (2370) 2A | leaking around neck pipe | 8/26/13 | Classroom | inside /nurse restroom | Plumbing |
| Kingsbury ES (2370) 2A | faucet leaking from handle | 8/26/13 | Classroom | rm317 | Plumbing |
| Kingsbury ES (2370) 2A | sink in classrm & 2 faucet leaking @ constant flow in hall sink | 8/26/13 | Classroom | rm#17 & hallway @rm#7 | Plumbing |
| Kingsbury ES (2370) 2A | RR SINK IS RUNNING CONTINUOUSLY IN TEACHERS' LOUNGE PLANT MGR-SNERLING/416.6020 | 8/26/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | UV WEST WING 1ST FLR RM 4-LEAKING-SBE BANKS 416-6020 KLR | 7/31/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | Water in the drinking fountain will not stop running. Equipment #032-065. One faucet. | 9/18/13 | Cafetorium | | Plumbing |
| Kingsbury ES (2370) 2A | Faucets will not stop running in these areas in hand sinks. | 9/18/13 | | West hall first fl, 2nd fl. hall, East hall 2nd | Plumbing |

| | | | | | | |
|------------------------|---|----------|-----------|-------------|--|----------|
| Kingsbury ES (2370) 2A | Request back flow test. | 9/25/13 | | | | Plumbing |
| Kingsbury ES (2370) 2A | UNIT IS LEAKING WATER IN LIBRARY NORTHWEST CORNER PLANT MGE- BANKS/416.2172 | 9/27/13 | | | | Plumbing |
| Kingsbury ES (2370) 2A | 3 compartment sink in kitchen is stopped up per Ms. Banks 416-6020 | 9/30/13 | | | | Plumbing |
| Kingsbury ES (2370) 2A | UV RMS 29W & LIBRARY NW CORNER-BOTH ARE LEAKING-PLANT MGR BANKS 416-6020 KLR | 10/7/13 | | | | Plumbing |
| Kingsbury ES (2370) 2A | Clean gutters on portables so that repairs can be made to prevent mold. | 10/16/13 | Portables | 275 and 274 | | Plumbing |
| Kingsbury ES (2370) 2A | Water leaking in air conditioners. | 10/16/13 | Portables | 275 and 274 | | Plumbing |
| Kingsbury ES (2370) 2A | girls restroom 2nd floor east commode constantly running and can't shut off per Ms. Banks 416-6020 | 10/17/13 | | | | Plumbing |
| Kingsbury ES (2370) 2A | SINK 2ND FLR KINDERGARTEN AREA ACROSS FROM RM 27- FAUCET RUNNING AT FULL FORCE, CAN'T CUT OFF PER SBE-PLANT MGR SNERLING 416-6020 KLR | 10/23/13 | | | | Plumbing |

| | | | | | |
|------------------------|--|----------|-----------------|-------------------------------------|----------|
| Kingsbury ES (2370) 2A | MOP SINK BOILER RM- STOPPED UP-WILL NEED PER SBE-PLANT MGR BANKS 416-6020 KLR | 11/1/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | MOP SINK IN STOPPED UP IN BOILER. PLANT MGR- BANKS/416.6020 | 11/6/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | Water in mop sink in boiler room drains very slow. | 11/12/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | Two urinals not working properly. | 11/20/13 | Restroom (Boys) | Upstairs East, and Upstairs West | Plumbing |
| Kingsbury ES (2370) 2A | COMMODE G RR 2ND FLR EAST END & WEST END- COMMDE CONSTANTLY RUNNING IN BOTH, CAN'T CUT OFF-PLANT MGR BANKS 416-6020 KLR | 11/25/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | urnial stopped up. | 1/9/14 | Restroom (Boys) | 2nd fl west | Plumbing |
| Kingsbury ES (2370) 2A | FLR DRAIN IS BACKING UP IN SUPPLY RM CLOSET BY CAFE PLANT MGR-LEE/416.2172 | 1/17/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | MOP SINK KIT STORAGE CLOSET-BACKING UP- PLANT MGR LEE 416-6020 KLR | 1/21/14 | | | Plumbing |

| | | | | | |
|------------------------|---|----------|-----------------|---------------------|----------|
| Kingsbury ES (2370) 2A | toilet leaking . | 1/22/14 | Restroom (Boys) | west hall 1st floor | Plumbing |
| Kingsbury ES (2370) 2A | Restroom sink faucet runing water constantly. | 12/2/13 | Gym | Girls restroom | Plumbing |
| Kingsbury ES (2370) 2A | PUMP IS LEAKING WATER IN BOILER RM, & FLR DRAIN IS BCKING UP IN BOILER RM PLANT MGR- BANKS/416.6020 | 12/5/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | 2-COM SINK IS RUNNING HOT WATER, CANT SHUT OFF IN KITCHEN, & 3-COM SINK IS STOPPED UP PLANT MGR- BANKS/416.6020 | 12/10/13 | | | Plumbing |
| Kingsbury ES (2370) 2A | mop sink is clogged up. | 1/30/14 | Mechanical Room | by clinic | Plumbing |
| Kingsbury ES (2370) 2A | 2-FLR DRAIN IS STOPPED BY PORT-274, & FRONT OF BLDG EAST SIDE. PLANT MGR-LEE/416.6020 | 2/4/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | HOT WATER TANK IN BOILER RM LEAKING - PM/ LEE 416-6020 | 2/10/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | GREASE TRAP KITCHEN AREA-BACKING UP-PLANT MGR LEE 416-6020 KLR | 2/10/14 | | | Plumbing |

| | | | | | |
|------------------------|--|---------|------------------|-------------------------|----------|
| Kingsbury ES (2370) 2A | HEATING UNIT FIN SEC OFC-LEAKING-PLANT MGR LEE 416-6020 KLR | 2/19/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | please un clog mop sink. | 2/21/14 | Mechanical Room | by clinic | Plumbing |
| Kingsbury ES (2370) 2A | please un clog roof drain. | 2/21/14 | 2nd Floor | westside roof | Plumbing |
| Kingsbury ES (2370) 2A | per mr lee 416-6020 gas smell in kitchen | 3/17/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | Request installation be put on the pipes to the new hot water heater and boiler. | 3/20/14 | | Boiler Room | Plumbing |
| Kingsbury ES (2370) 2A | UNIT IS LEAKING WATER WEST IN RM-5 PLANT MGR-LEE/416.6020 | 4/2/14 | | | Plumbing |
| Kingsbury ES (2370) 2A | roof is leaking by handicap ramp. | 6/20/14 | Hallway/Corridor | by handicap ramp | Roof |
| Kingsbury ES (2370) 2A | please repair roof leak. | 6/30/14 | 2nd Floor | 2nd fl. westside rm. 24 | Roof |

| | | | | | |
|------------------------|---|----------|---------------------|--|------|
| Kingsbury ES (2370) 2A | roof is leaking on main hall. | 6/30/14 | Administration Area | westside & eastside | Roof |
| Kingsbury ES (2370) 2A | roof leak in teacher's lounge. | 6/4/14 | Administration Area | Teacher's Lounge | Roof |
| Kingsbury ES (2370) 2A | please repair roof leak. | 5/8/14 | Administration Area | main hall by ramp | Roof |
| Kingsbury ES (2370) 2A | roof leak. | 5/30/14 | 2nd Floor | westside rm. 21 | Roof |
| Kingsbury ES (2370) 2A | roof leak. | 5/30/14 | 2nd Floor | eastside rm. 36 & 37 & 32 & 31 & 35 | Roof |
| Kingsbury ES (2370) 2A | please stop roof leak in teacher's lounge. | 5/13/14 | Administration Area | teacher's lounge | Roof |
| Kingsbury ES (2370) 2A | please repair roof leak. | 5/15/14 | 2nd Floor | eastside rm. 31 | Roof |
| Kingsbury ES (2370) 2A | Water leaking around the windows when it rain causing mold to appear on ceiling and corners of ceiling. | 10/31/13 | Classroom | 37 east | Roof |

| | | | | | |
|------------------------|--|---------|-----------|---|-------------|
| Kingsbury ES (2370) 2A | roof leaking. | 1/13/14 | Stairway | behind the library | Roof |
| Kingsbury ES (2370) 2A | leak on roof near men restroom to the right just when you enter the gym. | 12/2/13 | Gym | In the entrance way near the men restroom | Roof |
| Kingsbury ES (2370) 2A | portable has roof leak. | 2/4/14 | Portables | 274 | Roof |
| Kingsbury ES (2370) 2A | classroom has a roof leak. | 2/4/14 | 2nd Floor | eastside rm.32 | Roof |
| Kingsbury ES (2370) 2A | Request vents be painted. | 4/21/14 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|------------------|----------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| | Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal |
| gsbury HS (2375) | 4 | 1 | 85 | 121 | 81 | 30 | 62 | 34 | 8 | 426 |
| Grand Total | 4 | 1 | 85 | 121 | 81 | 30 | 62 | 34 | 8 | 426 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|--|----------------|---------------------|---------------------------------|-----------|
| Kingsbury HS (2375) 2A | Mr. Tutton came out to look at floor--replace brown floor tiles crumbling on wing | 6/16/14 | Auditorium | both wings | Asbestos |
| Kingsbury HS (2375) 2A | 10 missing brown/beige floor tiles | 5/27/14 | Classroom | Rm#253 | Asbestos |
| Kingsbury HS (2375) 2A | have about 20 missing dark brown original floor tiles & 4 crumbling tiles--*6 unstable tiles as well* | 6/25/14 | Classroom | Rm#171 | Asbestos |
| Kingsbury HS (2375) 2A | replace installation around pipes that removed to install new pump before it gets cold | 10/16/13 | Mechanical Room | behind auditorium | Asbestos |
| Kingsbury HS (2375) 2A | NCE Staff provide Project management for vendor to install Smart board and accessories at Kingsbury Hs. | 4/2/14 | | | Cabling |
| Kingsbury HS (2375) 2A | wood on stage has buckled in two areas due to roof leaks | 3/12/14 | Auditorium | front /center of stage | Carpentry |
| Kingsbury HS (2375) 2A | Per Fire Marshall:latch not catching @ rm152, 158, & 166 | 3/24/14 | 1st Floor | latch for not catching | Carpentry |
| Kingsbury HS (2375) 2A | Per Fire Marshall: @ rm 280, east of 260, & small gym | 3/24/14 | 2nd Floor | latch for not catching | Carpentry |
| Kingsbury HS (2375) 2A | CLOSER ON (2) GYM ENTRANCE DOORS HAVE BEEN BROKEN OFF- WONT BE ABLE TO SECURE PER SBE-PLANT MGR SNERLING 416-6060 K.L.R | 3/26/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | 4 closures have loss all of its oil/slamming real hard | 3/26/14 | Gym | exit doors off concession stand | Carpentry |
| Kingsbury HS (2375) 2A | Exit door handle inside band room is broken , need replace. | 3/27/14 | Gym | Band Room | Carpentry |
| Kingsbury HS (2375) 2A | closure broken on middle section left entrance/exit door | 4/10/14 | Administration Area | throughout facility | Carpentry |
| Kingsbury HS (2375) 2A | 2-WINDOWS ARE COMPLETELY OUT IN GYM | 4/10/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 closure broken off door | 4/16/14 | Gym | right center exit door | Carpentry |
| Kingsbury HS (2375) 2A | closure is twisted causing rt. door to be hard to open/needed to decrease jam volume @ bell release of students | 4/17/14 | Gym | far left entrance door | Carpentry |
| Kingsbury HS (2375) 2A | the screws are bagging out of closure**safety concern** | 4/22/14 | 1st Floor | entrance way on ramp end | Carpentry |
| Kingsbury HS (2375) 2A | replace broken closure & top hindge | 5/2/14 | Restroom (Boys) | 1st FL/@162 | Carpentry |
| Kingsbury HS (2375) 2A | entire cylinder is pulling out/presents security risk | 5/2/14 | Library | entrance near lounge | Carpentry |
| Kingsbury HS (2375) 2A | Plant mngr needs approximately 3 ft of chain to secure gated fence leading out to field. **URGENT, PLEASE!!** | 5/8/14 | Grounds | gated area leading to field | Carpentry |
| Kingsbury HS (2375) 2A | entrance off hall door handle is broken off | 5/13/14 | Gym | band rm on back hall | Carpentry |
| Kingsbury HS (2375) 2A | locker door missing beside A28 | 5/13/14 | Hallway/Corridor | 1st FL/near rm#169 | Carpentry |
| Kingsbury HS (2375) 2A | near locker #A30 wooden section between lockers kicked in | 5/13/14 | Hallway/Corridor | 1st FL/near rm#169 | Carpentry |
| Kingsbury HS (2375) 2A | closure needs replacing | 5/13/14 | 1st Floor | entrnce off ramp near 174 | Carpentry |
| Kingsbury HS (2375) 2A | closure broken off entrance door | 5/13/14 | Restroom (Boys) | across from 162 | Carpentry |
| Kingsbury HS (2375) 2A | COACHES OFFICE DOOR IS JAMMED IN GYM | 5/14/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 both door closures broken | 5/14/14 | Gym | back exit doors off band rm | Carpentry |
| Kingsbury HS (2375) 2A | door handle & cylinder cover/plates have screws missing (approx 15 doors) | 5/15/14 | Classroom | throughout facility | Carpentry |
| Kingsbury HS (2375) 2A | closure broken | 5/21/14 | Gym | entrance of doors | Carpentry |
| Kingsbury HS (2375) 2A | PANIC BAR HAS BROKEN OFF, CANT SECURE FRONT DOOR BY RM-170 . | 10/16/13 | | | Carpentry |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 DOOR HAS BEEN KICKED IN RM-265. | 10/23/13 | | | Carpentry |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 window to rm#124/someone vandilized over wkend by cut hole into window guard. Need repairing | 10/28/13 | 1st Floor | front window/2nd entrance | Carpentry |
| Kingsbury HS (2375) 2A | entrance door is completely shatter @ bottom/can't secure classrm with expensive equipment | 2/28/14 | Classroom | entrance door/rm# 162 | Carpentry |

| | | | | | |
|------------------------|---|----------|------------|---------------------------------------|-----------|
| Kingsbury HS (2375) 2A | when cylinder unlocked--you still can't open door/panic bar won't release **URGENT, PLEASE!!** Needed for lunch entrance | 11/1/13 | Cafeteria | exit doors | Carpentry |
| Kingsbury HS (2375) 2A | need (3) cases of HEAVY ceiling tiles to replace damaged tiles due to leaking roof. | 11/8/13 | Custodial | SBE's Office | Carpentry |
| Kingsbury HS (2375) 2A | Principal requesting old banners removed hanging from ceiling | 11/26/13 | Gym | hanging from ceiling | Carpentry |
| Kingsbury HS (2375) 2A | student knock square window out of wooden exit door. AP is requesting an amount as to total repair. | 1/31/14 | Classroom | Rm#262 | Carpentry |
| Kingsbury HS (2375) 2A | WINDOW BOILER RM BEHIND AUDITORIUM-BROKEN OUT DUE TO AN ATTEMPT BREAK IN, WON'T BE ABLE TO SECURE-PLANT MGR SNERLING 416-6060 KLR | 2/6/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | we need 2 cases of HEAVY ceiling tiles | 2/13/14 | Custodial | SBE's Office | Carpentry |
| Kingsbury HS (2375) 2A | Pick-up lift and deliver it to Kingsbury Hi. | 2/14/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | hidge @ top of door is sprung/door dragging scratching up floor tiles | 2/18/14 | Cafeteria | servicing line entrance @ dish window | Carpentry |
| Kingsbury HS (2375) 2A | Ceiling tiles need detail measurements to be replace in computer lab. | 2/18/14 | 2nd Floor | Computer Lab. | Carpentry |
| Kingsbury HS (2375) 2A | Request door be painted on site. (Room #265) | 2/19/14 | | room #265 | Carpentry |
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 there is a window that is shattered in the science wing between rooms 124 - 126 | 2/21/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | panic bar/hardware broken & needs replacing/security concern! left door of Middle set inside latch doesn't catch properly to secure exit door as it should/can be snatched open | 2/21/14 | Gym | PER: Mr Morris--locksmith | Carpentry |
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 the exit door to science wing and also exit door middle section of gym broken latch and can't secure | 2/25/14 | | | Carpentry |
| Kingsbury HS (2375) 2A | cylinder sticks and cause keys to get stuck in it according to AP, Mr. Miller/bent his key | 2/25/14 | 1st Floor | exit doors near lounge | Carpentry |
| Kingsbury HS (2375) 2A | mount a 8ft white board for Teacher with allergies to chalk dust | 2/26/14 | Classroom | Rm #162 | Carpentry |
| Kingsbury HS (2375) 2A | 4 sets of doors 1 exit door of kitchen need floor sweeps to keep out field mice | 2/27/14 | Cafetorium | throughout area | Carpentry |
| Kingsbury HS (2375) 2A | HARDWARE ON DOOR TO RM 163- IS DAMAGED AND CLASS IS STUCK INSIDE-PLANT MGR SNERLING 416-8080 KLR | 8/22/13 | | | Carpentry |
| Kingsbury HS (2375) 2A | need panic bar replaced/cylinder won't go in when handle is turn/High school students can get in/out for lunch. **URGENT, PLEASE** | 8/23/13 | Cafeteria | exit doors near Armory | Carpentry |
| Kingsbury HS (2375) 2A | replace broken handle | 7/2/13 | Gym | Lf middle entrance door | Carpentry |
| Kingsbury HS (2375) 2A | broken door closer. | 7/9/13 | Auditorium | by band rm. | Carpentry |
| Kingsbury HS (2375) 2A | replace door handle | 7/18/13 | Classroom | Rm#133 | Carpentry |
| Kingsbury HS (2375) 2A | I need some screws short enough to replace missing screws to hold plate cover for knobs/wooden classrm doors | 7/18/13 | Classroom | throughout facility | Carpentry |
| Kingsbury HS (2375) 2A | 7 sets of doors/install door sweeps to keep field mice from entering under doors **URGENT, PLEASE!!** | 8/2/13 | Kitchen | throughout gym | Carpentry |
| Kingsbury HS (2375) 2A | Panic bar need replace. | 8/5/13 | 1st Floor | Near Rm.142 | Carpentry |
| Kingsbury HS (2375) 2A | main hall room 162 someone tried to break into room and broke lock mechanism and the wood is damaged also. room has chemicals in it and needs to be secured Ms Snerling 416-6060 | 9/13/13 | | | Carpentry |

| | | | | | | |
|------------------------|--|----------|---------------------|--|---|-----------|
| Kingsbury HS (2375) 2A | The gym door mull has been removed and the building cannot be secured per Ms. Snerilling, Plant Mgr. 416.6660 | 9/27/13 | | | | Carpentry |
| Kingsbury HS (2375) 2A | Doorway lock area need wood replace to lock door. | 10/14/13 | 1st Floor | | Boy restroom | Carpentry |
| Kingsbury HS (2375) 2A | exit door across from guidance/top hindge off set-door dragging & hard to close | 12/5/13 | Administration Area | | Pupil Services/157 | Carpentry |
| Kingsbury HS (2375) 2A | hinges off set/door drags scarring floor tiles | 12/5/13 | Classroom | | rm#167/166 | Carpentry |
| Kingsbury HS (2375) 2A | wooden door is dragging/hindge loose | 12/9/13 | Classroom | | rm#265 | Carpentry |
| Kingsbury HS (2375) 2A | Need wall paneling put back in place. | 12/17/13 | | | | Carpentry |
| Kingsbury HS (2375) 2A | Need paneling put back on wall opening. | 12/17/13 | Gym | | concession stand | Carpentry |
| Kingsbury HS (2375) 2A | hindge broken off | 12/19/13 | Gym | | LF exit @ concessions | Carpentry |
| Kingsbury HS (2375) 2A | entrance door is completely shattered along bottom/can't close or secure rm. | 1/6/14 | Classroom | | rm #265 | Carpentry |
| Kingsbury HS (2375) 2A | replace base boards | 1/22/14 | Auditorium | | North wall/side steps to stage | Carpentry |
| Kingsbury HS (2375) 2A | replace base board under lockers coming aloose on both sides of hall | 1/27/14 | Administration Area | | between rms#164/162 | Carpentry |
| Kingsbury HS (2375) 2A | ENTRY GYM DOOR, CANT SECURE BECAUSE HINGES. CLOSER PLANT MGR-SNERLING/416.6060 | 1/27/14 | | | | Carpentry |
| Kingsbury HS (2375) 2A | TWO (2) WINDOWS have been KICKED OUT in the GYM per Ms. Snerlling, Plant Mgr. 416.6060 | 6/26/14 | | | | Carpentry |
| Kingsbury HS (2375) 2A | 20 green floor tile crumbling/need replacing | 6/30/14 | Cafetorium | | left of serving line | Carpentry |
| Kingsbury HS (2375) 2A | top hindge is off-set can't secure classrm | 6/2/14 | Classroom | | Rm#162 | Carpentry |
| Kingsbury HS (2375) 2A | plate over cylinder catches wooden & gets stuck | 6/4/14 | Administration Area | | Pupil Service door across from guidance | Carpentry |
| Kingsbury HS (2375) 2A | replace 5 floor tiles & 2 sections of base board | 5/27/14 | Classroom | | Rm#254 | Carpentry |
| Kingsbury HS (2375) 2A | hand rail has come aloose from wall | 5/27/14 | Stairway | | 2nd across from rm#260 | Carpentry |
| Kingsbury HS (2375) 2A | requesting 3 pkg of HEAVY ceiling tiles to replace damged tiles | 5/27/14 | Custodial | | SBE's office | Carpentry |
| Kingsbury HS (2375) 2A | He needs about 10-12 white tiles replaced @ desk.(some crumbling, URGENT, PLEASE that we may perform summer cleaning! | 5/29/14 | Administration Area | | Principal's Office/Mr Fuller | Carpentry |
| Kingsbury HS (2375) 2A | baseboard has coming aloose & missing under lockers between Rms #262 & 263 | 4/28/14 | Hallway/Corridor | | @ base of lockers | Carpentry |
| Kingsbury HS (2375) 2A | 16 wooden seats/backes broken/splintering**safety concern** | 4/30/14 | Auditorium | | throughout auditorium | Carpentry |
| Kingsbury HS (2375) 2A | Door need replace on toilet stall. | 8/1/13 | Gym | | Locker rooms restroom | Carpentry |
| Kingsbury HS (2375) 2A | Left side of door from cylinder to bottom is splintered & cylinder p[late has lost screws | 6/18/14 | Custodial | | closet across from rm#162 | Carpentry |
| Kingsbury HS (2375) 2A | replace abot 15 wht floor tiles/have deteriorated very badly & water going under as when mopped/tiles loose **safetv concern** | 6/18/14 | Classroom | | rm#168 & elevator | Carpentry |
| Kingsbury HS (2375) 2A | requesting 10 threshold plates install @ entrance of classrms over expansion joints/tiles cracking badly | 6/24/14 | Classroom | | throughout facility | Carpentry |
| Kingsbury HS (2375) 2A | replace hollow door/splintering very badly esp @ bottom causing to drag & scar/cut into tiles | 6/24/14 | Custodial Closet | | across from #162 | Carpentry |
| Kingsbury HS (2375) 2A | replace wooden piece missing on end of lockers | 6/25/14 | Hallway/Corridor | | 1st Fl near rm #170 | Carpentry |
| Kingsbury HS (2375) 2A | repair wooden pieces between two sections of lockers kicked in by students **safety concern** | 6/25/14 | Hallway/Corridor | | 2nd FL near rm #276 | Carpentry |
| Kingsbury HS (2375) 2A | need 3 more additional threshold plates installed in entrance of 4 more rooms due to tiles cracking over exoansion joint | 6/25/14 | Administration Area | | Per Principal/Mr. Fuller | Carpentry |
| Kingsbury HS (2375) 2A | replace 5 wht floor tiles came up during summer cleaning | 6/25/14 | Classroom | | Rm#155 | Carpentry |
| Kingsbury HS (2375) 2A | Request tables in the science lab be removed. | 6/5/14 | | | | Carpentry |

| | | | | | |
|------------------------|---|----------|---------------------|-----------------------------------|------------|
| Kingsbury HS (2375) 2A | Piece of flex-o-glass about 6x8 , and piece of plywood 6x8 for expectation of break - ins and security needs. | 4/15/14 | Gym | plant manager office | Carpentry |
| Kingsbury HS (2375) 2A | per snerling 416-6060 room 271 AHU not coming on at all | 4/3/14 | | | Electrical |
| Kingsbury HS (2375) 2A | 160 has 4 ballast burned out & 2 in 164 | 3/10/14 | Classroom | rms #160 & 164 | Electrical |
| Kingsbury HS (2375) 2A | lobby & main office, main entranceway, back of computer lab, back stairwell, 3 places in auditorium PER FIRE MARSHALL | 3/24/14 | Hallway/Corridor | replace exits signs | Electrical |
| Kingsbury HS (2375) 2A | replace emergency lights | 3/24/14 | Gym | small gym | Electrical |
| Kingsbury HS (2375) 2A | One ballast out in boys restroom. | 3/27/14 | 2nd Floor | Boy restroom | Electrical |
| Kingsbury HS (2375) 2A | One ballast out. | 3/27/14 | 2nd Floor | Boys restroom across from rm. 275 | Electrical |
| Kingsbury HS (2375) 2A | throughout auditorium | 3/28/14 | Auditorium | 5 exit signs burned out | Electrical |
| Kingsbury HS (2375) 2A | Middle set of steps/back wall | 3/28/14 | Stairway | 2nd floor | Electrical |
| Kingsbury HS (2375) 2A | Need ballast replace , light blinking rapidly. | 4/1/14 | 1st Floor | Rm.140 | Electrical |
| Kingsbury HS (2375) 2A | A/C ARMORY AREA, RM 170, & 24-ALL NOT COMING ON-PLANT MGR SNERLING 416-6060 KLR | 4/4/14 | | | Electrical |
| Kingsbury HS (2375) 2A | replace 1 ballast in library entrance | 4/15/14 | Machine Shop | inside entrance doors | Electrical |
| Kingsbury HS (2375) 2A | light burn constantly/cant shut off | 4/15/14 | Gym | side/front canopy | Electrical |
| Kingsbury HS (2375) 2A | Back porch canopy near the weightlifting room light fixtures filled with water and need replaced or repaired. | 4/15/14 | Gym | Gym | Electrical |
| Kingsbury HS (2375) 2A | In entrance door of library and hallway (9 grade)by boiler room ballast need replaced. | 4/15/14 | 1st Floor | Library&hallway | Electrical |
| Kingsbury HS (2375) 2A | 3 ballast burned out | 4/16/14 | Classroom | 157 | Electrical |
| Kingsbury HS (2375) 2A | fire doors will not latch to stay open | 4/22/14 | Hallway/Corridor | center section near court yard | Electrical |
| Kingsbury HS (2375) 2A | electrical outlet sparking fire/electrical pipe pulled loose @ wall | 5/2/14 | Cafetorium | Rt side of ramp @ bottom wall | Electrical |
| Kingsbury HS (2375) 2A | bring lift to replace blown bulbs in ceiling/floor is be refinshed | 5/9/14 | Gym | main gym/wooden floor | Electrical |
| Kingsbury HS (2375) 2A | UNIT NOT COMING ON IN RM-142,265, ROTC BLDG | 5/12/14 | | | Electrical |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 THERMOSTAT SMALL GYM AREA- HAS BEEN TORN OFF WALL BY STUDENTS EXPOSING LIVE WIRES- PLANT MGR SNERLING 416-6060 KLR | 5/14/14 | | | Electrical |
| Kingsbury HS (2375) 2A | replace switch plate | 5/15/14 | 1st Floor | handicap beside rm#136 | Electrical |
| Kingsbury HS (2375) 2A | No power from receptacles in her office | 5/16/14 | Library | Ms Sharrin's office | Electrical |
| Kingsbury HS (2375) 2A | replace receptacle cover/safety concern | 10/30/13 | Administration Area | Rm #122 | Electrical |
| Kingsbury HS (2375) 2A | COOLING VENT NOT COMING ON IN RM-139 | 10/30/13 | | | Electrical |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 | | | | |
| Kingsbury HS (2375) 2A | Two ballast out need replace. | 3/5/14 | 1st Floor | 163 Art Room | Electrical |
| Kingsbury HS (2375) 2A | need bulbs replaced in ceiling that Techs may be able see how to perform their tasks/ bulbs blown it dark | 3/5/14 | Mechanical Room | off library | Electrical |
| Kingsbury HS (2375) 2A | 1 ballast need replacing | 3/7/14 | Mechanical Room | behind Plant Mngr's office | Electrical |
| Kingsbury HS (2375) 2A | reset clocks due to daylight saving time | 3/8/14 | Administration Area | main office | Electrical |
| Kingsbury HS (2375) 2A | 3 fixture need ballast & ,(6),13 watts 2 prong plug in flourescent lamps **ALSO need (24)13 watts to replace blown lamps throughout bldg in restrms.** | 11/8/13 | Gym | football locker Rm | Electrical |
| Kingsbury HS (2375) 2A | have purchased a new score board & need electrical plug fixed to utilized. | 11/18/13 | Gym | under score board | Electrical |
| Kingsbury HS (2375) 2A | Need three cases of fluorescent lamps , for hallways and classrooms. | 11/19/13 | 1st Floor | Plant Manager office | Electrical |
| Kingsbury HS (2375) 2A | need flag pole cable replaced | 11/20/13 | Grounds | Front of main bldg | Electrical |
| Kingsbury HS (2375) 2A | Need bulbs replacement in light fixtures , very dark in that area. | 11/22/13 | Grounds | Near JROTC & BAND ROOM | Electrical |

| | | | | | |
|------------------------|---|----------|---------------------|-----------------------------|------------|
| Kingsbury HS (2375) 2A | Units in Gym and Coach McKinney's office are NOT COMING ON per Ms. Snerlling, Plant Mgr. 416.6060 | 11/26/13 | | | Electrical |
| Kingsbury HS (2375) 2A | lights mounted on bldg out**safety for workers concern** | 11/26/13 | Gym | side outer top of bldg | Electrical |
| Kingsbury HS (2375) 2A | Ballast need replace. | 1/31/14 | 2nd Floor | Rm.258 | Electrical |
| Kingsbury HS (2375) 2A | Ballast need replace. | 1/31/14 | 2nd Floor | Rm.254 | Electrical |
| Kingsbury HS (2375) 2A | Ballast need replace. | 1/31/14 | 2nd Floor | Rm.250 | Electrical |
| Kingsbury HS (2375) 2A | Ballasts burned out: (1) @ boiler rm off library (1) @rm 153 (1) in rm#266 | 2/4/14 | Hallway/Corridor | throughout facility | Electrical |
| Kingsbury HS (2375) 2A | Lights are out in six(6) light fixtures in room170 need ballast replaced or electrical problem. | 2/4/14 | 1st Floor | Rm.170 | Electrical |
| Kingsbury HS (2375) 2A | Two ballast out. | 2/4/14 | 1st Floor | Rm.168 | Electrical |
| Kingsbury HS (2375) 2A | The electrical panel or circuit breaker in the hallway do controll the lights in the hall , but is not controlling emergency lights or fixtures need new ballasts | 2/4/14 | 1st Floor | 12th grade hallway | Electrical |
| Kingsbury HS (2375) 2A | PUMP-5 BOILER RM BY SBE'S OFC- NOT COMING ON-PLANT MGR SNERLING 416-6060 KLR | 2/6/14 | | | Electrical |
| Kingsbury HS (2375) 2A | Several ballasts need replace. | 2/17/14 | 2nd Floor | Rm.266 | Electrical |
| Kingsbury HS (2375) 2A | Ballasts need replace over table. | 2/17/14 | 1st Floor | Teacher Lounge | Electrical |
| Kingsbury HS (2375) 2A | Rooms 100 &100-D need ballast replace. | 2/17/14 | 1st Floor | ARMORY | Electrical |
| Kingsbury HS (2375) 2A | School has purchased new copier for records dept/needs T-prong plug **URGENT, PLEASE!!** office Team can not make copies of school records/important papers | 2/18/14 | Administration Area | Rm#157A/Pupil Services | Electrical |
| Kingsbury HS (2375) 2A | bulbs on stage were blown out by electrical storm yesterday. need bulbs replaced for program/dark in stage area | 2/21/14 | Auditorium | on stage | Electrical |
| Kingsbury HS (2375) 2A | requesting extension pole to install bulbs in ceiling over 8ft in 4 boiler/mechanical rms. | 2/21/14 | Custodial | Plant mngr | Electrical |
| Kingsbury HS (2375) 2A | Plant mngr of Kingsbury needs fluourescent tubes as following:2 cs for middle/2cs for CTC/3cs for high | 8/16/13 | Hallway/Corridor | throughout facility | Electrical |
| Kingsbury HS (2375) 2A | bad preasure switch on the compressor causing system to go into alarm per Albert Herman-os any ?'s call Albert | 8/26/13 | | | Electrical |
| Kingsbury HS (2375) 2A | receptacles on back wall not working/brakers have been checked/Teacher need receptacles to hook up compters | 8/26/13 | Classroom | Business/#164 | Electrical |
| Kingsbury HS (2375) 2A | **URGENT. "PLEASE!"** | | | | |
| Kingsbury HS (2375) 2A | 2 ballasts burned out | 8/28/13 | Data Closet | inside rm#164 | Electrical |
| Kingsbury HS (2375) 2A | The light switch in my instrument storage closet has a short in it. | 8/29/13 | 1st Floor | 124 | Electrical |
| Kingsbury HS (2375) 2A | AHU IS MAKING NOISE IN RM-270(085). SBE-SNERLING/416-6060 | 7/2/13 | | | Electrical |
| Kingsbury HS (2375) 2A | WALL UNIT IS MAKING NOISE IN RM 164(045). PLANT MGR-SNERLING/416.6060 | 8/5/13 | | | Electrical |
| Kingsbury HS (2375) 2A | Secure cables that are down in the parking lot. | 8/8/13 | | | Electrical |
| Kingsbury HS (2375) 2A | started smoking as they trying to let out/need for games | 9/16/13 | Gym | bleachers | Electrical |
| Kingsbury HS (2375) 2A | lights need replace under canopy near room 152 stairwell exit. | 9/17/13 | Gym | Gym | Electrical |
| Kingsbury HS (2375) 2A | 1 ballast ib each office right over desk/guidance only has that one light/rm dark | 9/19/13 | Administration Area | guidance & Pupil Services | Electrical |
| Kingsbury HS (2375) 2A | Need ballasts replace in both restroom. | 9/24/13 | Gym | guest restrooms front entry | Electrical |
| Kingsbury HS (2375) 2A | Bleachers will NOT roll out per Ms. Snerlling, Plant Mgr. 416.6060 | 10/1/13 | | | Electrical |
| Kingsbury HS (2375) 2A | Under stairwell near where Principal park. | 10/2/13 | 1st Floor | EXIT DOOR | Electrical |

| | | | | | |
|------------------------|---|----------|------------------|-------------------------------|------------|
| Kingsbury HS (2375) 2A | Under the stairwell exit near the Principal parking place light fixture need ballast replace. | 10/2/13 | 1st Floor | EXIT DOOR | Electrical |
| Kingsbury HS (2375) 2A | need 100 watt house bulbs/they are emer. lights/auditorium gets blk dark if I turn off reg lights | 8/30/13 | Auditorium | along both walkways | Electrical |
| Kingsbury HS (2375) 2A | Correction of school, special bulbs for front entrance of gym under canopy. prolume LU70/MED SN134. Six bulbs needed. | 9/9/13 | Gym | Gym | Electrical |
| Kingsbury HS (2375) 2A | 2 ballasts burned out in Coaches' office--left side hall near laundry rm & 1 ballast burned out in laundry rm | 10/4/13 | Gym | side hallway | Electrical |
| Kingsbury HS (2375) 2A | light in hallway in front of computer lab. door need ballast. | 10/14/13 | 1st Floor | COMPUTER LAB. | Electrical |
| Kingsbury HS (2375) 2A | Three way light switch , third switch is bad. | 10/14/13 | 2nd Floor | room256 | Electrical |
| Kingsbury HS (2375) 2A | Emergency light are blinking rapidly, need ballast change. | 10/14/13 | 2nd Floor | Near room 266 | Electrical |
| Kingsbury HS (2375) 2A | RECEPTACLE RM 155-SMOKING-CALLED IN BY GCA SUPV T DORSEY 416-6060 KLR | 10/16/13 | | | Electrical |
| Kingsbury HS (2375) 2A | Music classrm/1 ballast burned out over pianos | 12/11/13 | Classroom | Rm#125/Dr Lane | Electrical |
| Kingsbury HS (2375) 2A | BOILER NOT COMING ON AUDIT. PLANT MGR-SNERLING/416-6060 | 12/12/13 | | | Electrical |
| Kingsbury HS (2375) 2A | per Ms. Snerling 416-6060 9th grade wing no heat and EM told her he thought pump on boiler not working | 12/12/13 | | | Electrical |
| Kingsbury HS (2375) 2A | the breakers have been ckecked but there's no power going to board today. **URGENT, PLEASE** needed for home games | 12/16/13 | Gym | score board | Electrical |
| Kingsbury HS (2375) 2A | shortage in light switch/lights won't stay on | 12/19/13 | Hallway/Corridor | @ rm #160 | Electrical |
| Kingsbury HS (2375) 2A | Light mounted on side of library building is out | 12/19/13 | Gym | Boys&girls restroom | Electrical |
| Kingsbury HS (2375) 2A | adjacent to fire lane. | | | | |
| Kingsbury HS (2375) 2A | Light out between cafeteria and ROTC building mounted on building. | 12/19/13 | Grounds | Boys&girls restroom | Electrical |
| Kingsbury HS (2375) 2A | Light under canopy where band room back door are | 12/19/13 | Gym | Boys&girls restroom | Electrical |
| Kingsbury HS (2375) 2A | across from ROTC building. | | | | |
| Kingsbury HS (2375) 2A | Light pole in the football field where the transformer is located | 12/20/13 | Grounds | Boys&girls restroom | Electrical |
| Kingsbury HS (2375) 2A | Light need replace. | | | | |
| Kingsbury HS (2375) 2A | Lights under canopy in front of gym is out. | 12/20/13 | Gym | gym | Electrical |
| Kingsbury HS (2375) 2A | Electical problem. need repair. | | | | |
| Kingsbury HS (2375) 2A | Sensor light on side of gym near security camera | 12/20/13 | Grounds | Grounds | Electrical |
| Kingsbury HS (2375) 2A | need repair. | | | | |
| Kingsbury HS (2375) 2A | Light mounted on front of gym , left side is out need | 12/20/13 | Gym | gym | Electrical |
| Kingsbury HS (2375) 2A | replace. | | | | |
| Kingsbury HS (2375) 2A | Light out under canopy back of gym | 12/20/13 | Gym | Boys&girls restroom | Electrical |
| Kingsbury HS (2375) 2A | across from old | | | | |
| Kingsbury HS (2375) 2A | merchanic shop need repair. | | | | |
| Kingsbury HS (2375) 2A | HEAT (3) UNITS GYM AREA-NOT COMING ON-PLANT MGR | 1/6/14 | | | Electrical |
| Kingsbury HS (2375) 2A | SNERLING 416-6000 KLR | | | | |
| Kingsbury HS (2375) 2A | Unit is NOT COMING ON in the ARMORY per Ms. Snerling, Plant Mgr. 416.2325 | 1/6/14 | | | Electrical |
| Kingsbury HS (2375) 2A | Please , deliver three cases of flourescent lamps the Plant Manager office as soon as possible. | 1/8/14 | Custodial | Plant Manager office | Electrical |
| Kingsbury HS (2375) 2A | 3 lights Bad Ballast in C Main Hallway. | 1/9/14 | Hallway/Corridor | C by 127 | Electrical |
| Kingsbury HS (2375) 2A | replace light switch/has a shortage | 1/14/14 | Custodial | Plant mngrs' office in restrm | Electrical |
| Kingsbury HS (2375) 2A | need ballast replace. | 1/15/14 | 2nd Floor | Rm.274 | Electrical |
| Kingsbury HS (2375) 2A | Need ballast replace. | 1/15/14 | 2nd Floor | Rm.263 | Electrical |
| Kingsbury HS (2375) 2A | Need ballast replace. | 1/15/14 | 2nd Floor | Rm.250 | Electrical |
| Kingsbury HS (2375) 2A | Need two ballast replace. | 1/15/14 | 2nd Floor | Rm.257 | Electrical |

| | | | | | |
|------------------------|--|---------|---------------------|-------------------------------|---------------------------------------|
| Kingsbury HS (2375) 2A | Need ballasts replace. | 1/15/14 | 2nd Floor | Rm.258 | Electrical |
| Kingsbury HS (2375) 2A | 3 cs flourescent tubes/ 10 screw in flourescent lamps #46820 | 1/16/14 | Custodial | Plant mngr's office | Electrical |
| Kingsbury HS (2375) 2A | Replace two ballast in class room 256. | 1/16/14 | 2nd Floor | Rm.256 | Electrical |
| Kingsbury HS (2375) 2A | CORRECTION room 250 instead of 256 need two ballast replace. | 1/16/14 | 2nd Floor | Rm.250 | Electrical |
| Kingsbury HS (2375) 2A | The electical box in the hallway control the lights fixtures in the hall. the emergency lights will not come on please help. | 1/16/14 | 1st Floor | twelfth grade hall | Electrical |
| Kingsbury HS (2375) 2A | lights will not come on one side of corridror near restroom close to main building. | 1/16/14 | Auditorium | Corridor hall | Electrical |
| Kingsbury HS (2375) 2A | need metal basket place over fire pull station--children keep breaking pull station **have spoken with Mr. Herman** Make that a pull station alarm cover, Albert Herman | 1/21/14 | Gym | North coner near band rm | Electrical |
| Kingsbury HS (2375) 2A | NO POWER TO RECEPTACLES IN RM 251-SBE CHECKED BREAKER, IT'S FINE-PLANT MGR SNERLING 416-6060 KLR | 1/22/14 | | | Electrical |
| Kingsbury HS (2375) 2A | PARTIAL LIGHTS HAVE NO LIGHT IN RM-257. | 1/23/14 | | | Electrical |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 New SPED Teacher moved into rm. Orange comp. receptacles don't work. Need to use computers. **URGENT, PLEASE!!** | 1/29/14 | Classroom | Rm#142 | Electrical |
| Kingsbury HS (2375) 2A | Blinking light , replace ballast. | 1/29/14 | 1st Floor | Rm.139 | Electrical |
| Kingsbury HS (2375) 2A | Light blinking ballast need replace or electrical problems. | 1/29/14 | 2nd Floor | Rm.266 | Electrical |
| Kingsbury HS (2375) 2A | Ballasts need replace (4). | 1/29/14 | 1st Floor | Rm.131 | Electrical |
| Kingsbury HS (2375) 2A | HEATING UNIT GUIDANCE OFC-NOT COMING ON-PLANT MGR NOLAN 416-6080 KLR | 1/30/14 | | | Electrical |
| Kingsbury HS (2375) 2A | A/C UNITS are NOT COMING ON in ROOMS 121, 124, 136, 153, 165, 167, 168, and 169 per Ms. Snerling, Plant Mgr. 416.6060 | 6/26/14 | | | Electrical |
| Kingsbury HS (2375) 2A | 3 wall receptacles need covers | 6/30/14 | Classroom | Rm#155 | Electrical |
| Kingsbury HS (2375) 2A | exhaust fan not working | 5/22/14 | Administration Area | handicap restrm beside rm#136 | Electrical |
| Kingsbury HS (2375) 2A | 1 ballast burned out | 5/23/14 | Classroom | Rm# 125/Dr Lane | Electrical |
| Kingsbury HS (2375) 2A | 3 cs flourescent tubes | 5/23/14 | Custodial | Plant mngr's office | Electrical |
| Kingsbury HS (2375) 2A | receptacle broken below smart board | 5/27/14 | Classroom | Rm#169 | Electrical |
| Kingsbury HS (2375) 2A | Synchronize clocks in main hallways. | 7/30/13 | 1st Floor | 1st &2nd floor | Electrical |
| Kingsbury HS (2375) 2A | Locker rooms light fixtures need replace. | 8/1/13 | 1st Floor | Gymnasium | Electrical |
| Kingsbury HS (2375) 2A | 1 ballast burned out/releasing burning smell | 6/18/14 | Hallway/Corridor | 2nd fl between #252 & 253 | Electrical |
| Kingsbury HS (2375) 2A | shaotage in light switch/1 complete row won't burn | 6/24/14 | Classroom | rm#156 | Electrical |
| Kingsbury HS (2375) 2A | total of 6 ballasts burned out | 6/10/14 | Classroom | Rm#s 270, 272, & 280 | Electrical |
| Kingsbury HS (2375) 2A | replace metal cover over receptacle | 6/10/14 | Classroom | Rm#268 | Electrical |
| Kingsbury HS (2375) 2A | UNITS ARE NOT WORKING THRU OUT THE BDLG. ENTIRE BLDG IS HOT. SBE SNERLING 416-6060 | 7/29/13 | | | Electrical |
| Kingsbury HS (2375) 2A | please replace broken receptacle, this control 1 security camera. | 9/12/13 | Hallway/Corridor | next to A308 | Electrical |
| Kingsbury HS (2375) 2A | A/C UNIT is MAKING LOUD NOISE in ROOM 255 per Ms. Snerlling, Plant Mgr. 416.6060 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | COMPRESSOR UNIT - 8 BRACKETS ARE BROKEN - PM/SNERLING 416-6060 | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | COIL NEEDS TO BE CLEAN FOR CHILLER BEHIND AUDIT PLANT MGR-SNERLING/416-6060 | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | THERMOSTAT GYM AREA-TORN OFF WALL-PLANT MGR SNERLING 416-6060 KLR | 4/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------|--|----------|-----------|--|----------------|---------------------------------------|
| Kingsbury HS (2375) 2A | per snerling 416-6060 room 267 blowing hot | 4/3/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Yearly - Boiler 107 - Kingsbury Hi-Ctr Wing Mech - Refer to PM schedule details. | 3/23/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Yearly - Boiler 108-Kingsbury Hi-SW East Mech Rm - Refer to PM schedule details. | 3/24/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Yearly - Boiler 112 - Kingsbury Hi-SW Ctr Mech Rm - Refer to PM schedule details. | 3/25/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 behind auditorium mechanical room u pipe on AHU is leaking and mechanical room across from 164 circulating pump is losing water | 3/27/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | A/C UNIT in the ARMORY is NOT COOLING per Ms. Snerling, Plant Mgr. 416.6060 | 5/6/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UNIT NOT COOLING IN RM-265 PLANT MGR-SNERLING/416.6060 | 5/8/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | A/C RM 263-NOT COOLING-PLANT MGR SNERLING 416-6060 KLR | 5/9/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Boilers down per EMS | 3/4/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | main hallway no heat and principal's office no heat per Ms. Snerling 416-6060 | 11/8/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UNIT NOT HEATING IN PRIN OFFICE PLANT MGR-SNERLING/416.6060 | 11/14/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | P-TAC UNIT GUIDANCE OFC-NOT HEATING-PLANT MGR SNERLING 416-6060 KLR | 11/15/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | BOILER NOT COMING ON. PLANT MGR-SNERLING/416.6060 | 11/20/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | BOILER MECH RM-NOT HEATING-AFFECTS ENTIRE BLDG-PLANT MGR NOLEN 416-6060 KLR | 11/25/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | BOILER NOT COMING ON. PLANT MGR-SNERLING/416.6060 | 11/26/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - Oil Lube & Belt-Kingsbury High - Refer to PM schedule details. | 2/2/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | HEAT RM 256-OVERHEATING, TEMP IS 92-PLANT MGR SNERLING 416-6060 KLR | 2/3/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Install heat within plant mgr's office | 2/4/14 | Custodial | | PER: Mr. Means | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | HEAT MID SCH GYM-NOT HEATING-PLANT MGR SNERLING 416-6060 KLR | 2/6/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | per ms snerling 416-8060 nurse's station is blowing cold air | 2/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | replace pump coupling | 2/10/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UV SOUTH HALL RM 162 WEST & SOUTH WALL RM 162 EAST-BOTH NOT COOLING-SBE SNERLING 416-6060 KLR | 8/13/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UV SOUTH HALL RM 152 & UV SOUTH HALL RM 152-BOTH NOT COOLING-SBE SNERLING 416-6060 KLR | 8/16/13 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|-----------|---------------------|---------------------------------------|
| Kingsbury HS (2375) 2A | Bandroom a/c is blowing hot air - there are 2 units per Ms. Snerling 416-6060 | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UV RM 153 & 165-BOTH NOT COOLING-PLANT MGR SNERLING 416-6060 KLR | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | AHU NOT COOLING IN ROTC RM (208) & 2-AHU IN GYM (NO ID), SBE-SNERLING/416-6060 | 7/2/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Chiller ID#131-125 behind the Auditorium making a LOUD HUMMING sound per Ms. Snerling at 901.416.6060. | 7/10/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | A/C Units in following blowing hot air (all 3 locations) Main Office Gym Armory Ms. Snerling 416-6060 | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UNIT IN THE AUDIT. LOBBY IS BLOWING HOT AIR. SBE SNERLING 416-6060 | 7/17/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UNIT VENT - RM 136, 129, 121, 122, 126, 152, 160, 164, 165, 168, 171.AND THE ASSISTANCE PRIN OFC - OFF THE MAIN OFC - ALL ARE BLOWING NOT COOLING - SBE/SNERLING | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Rms 252, 253, 258, 263, 265, 270 all blowing hot air Roberta Snerling 416-606 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UV NOT COOLING IN RM-168(047) . PLANT MGR-SNERLING/416.6060 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | WALL UNIT NOT COOLING IN MAIN OFFICE(194). PLANT MGR-SNERLING/416.6060 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | the door panels of both RTU are wide open/have spoken with Mr Friar pertainig to getting them locked/**risk of vandalism** | 9/12/13 | Gym | top of lobby of gym | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | room 164 unit ventilator bracket is broken on unit per Snerling 416-6060 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | room 250 and 265 a/c not cooling per Ms. Snerling 416-6060 | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | A/C RM 262-NOT COOLING-PLANT MGR SNERLING 416-6060 KLR | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | HAS A POWER SHORTAGE THAT'S KNOCKING THE AIR OUT IN THE ENTIRE BLDG PER SBE-PLANT MGR SNERLING 416-6060 KLR | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | RTU NOT COOLING ON IN COMPUTER LAB PLANT MGR-SNERLING/416.6060 | 9/25/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Unit Ventilator in Room 2375 NOT COOLING and the FAN is rubbing up against the door, causing a s noise per Ms. Snerling, Plant Mgr. - 901.416.6660. | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UV NOT COOLING IN RM-265 PLANT MGR-SNERLING/416.6060 | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | water running out of ceiling from under RTUs in different places **safety concern** **URGENT PLEASE!!** | 10/16/13 | Cafeteria | roof/several places | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | P-TAC UNIT NOT HEATING IN GUIDANCE OFFICE PLANT MGR-SNERLING/416.6060 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | AHU NOT HEATING IN AUDIT PLANT MGR-SNERLING/416.6060 | 12/11/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------|--|----------|------------------|--|--------------|---------------------------------------|
| Kingsbury HS (2375) 2A | P-TAC NOT HEATING GUIDANCE OFFICE. PLANT MGR-SNERLING/416-6060 | 12/12/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - Filter-Kingsbury High/Middle - Refer to PM schedule details. | 1/3/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | per Ms. Snerling 416-6060 rooms 138, 140, 142 blowing cold air | 1/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | ROTC Armory _ Not Heating | 1/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Hot water circulation pump is down and the 9th Grade Wing is NOT HEATING, also the ARMORY is NOT HEATING per Ms. Snerling, Plant Mgr. 416.6060 | 1/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | HEAT GYM AREA & ARMORY-BOTH NOT HEATING-PLANT MGR SNERLING 416-6060 KLR | 1/8/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | valve off radiators on 2nd floor ONLY. It's unbearable for students & Teachers as to the radiating heat!! **URGENT. PLEASE!!** | 1/17/14 | Hallway/Corridor | | 2nd Floor | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | PTAC PUPIL SERVICES-NOT HEATING-PLANT MGR SNERLING 416-6060 KLR | 1/23/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | BOILER NOT HEATING IN 9TH GRADE WING PLANT MGR-SNERLING/416.6060 | 1/28/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | HEATING UNIT GUIDANCE OFC- OTHER UNIT NOT HEATING-PLANT MGR NOLAN 416-6080 KLR | 1/30/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | A/C UNIT is NOT COOLING in the ARMORY per Ms. Snelling, Plant Mgr. 416.6060 | 6/27/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | URGENT, PLEASE, need box of metal clamps missing to ventilators to keep doors secured that units run properly! | 5/27/14 | Custodial | | SBE's office | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 armory AHU blowing hot | 4/28/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | 23-UNITS NOT COOLING IN RM- 262,261,264,263,268,265,252,270,267,269,272,274,276,273,280,260,258,257,256,251,254,266, LOBBY OF AUDIT, GYM, & ASSIST PRIN OFFICE, RM-109. PLANT MGR-SNERLING/416-6060 | 7/29/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | 2-uv not cooling in rm-152,142. PLANT MGR-SNERLING/416.6060 | 8/1/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | UNIT VENTILATOR is SMOKING in ROOM 155 per Ms. Snerling, Plant Mgr. 416.6060 | 6/24/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | COMPRESSOR - MAKING A HUMMING NOISE WHEN THEY COME ON - PM/SNERLING 416-6060 | 6/4/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1" Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 10/4/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1" Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 8/30/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - Filter-Kingsbury High/Middle - Refer to PM schedule details. | 8/30/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1" Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 1/31/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1" Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 1/3/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Yearly - Boiler 127 - Kingsbury Hi-Aud Mech Rm - Refer to PM schedule details. | 3/21/14 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------|--|----------|----------------|--|------------------------------------|---------------------------------------|
| Kingsbury HS (2375) 2A | Yearly - Boiler 219 - Kingsbury Hi-2nd Gym Mech E - Refer to PM schedule details. | 3/21/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 4/4/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 2/28/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 11/29/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 11/1/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 8/2/13 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 5/2/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - Filter-Kingsbury High/Middle - Refer to PM schedule details. | 5/2/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Monthly - 1' Filters (Monthly)-Kingsbury High - Refer to PM schedule details. | 5/30/14 | | | | Heating/Ventilation /Air Conditioning |
| Kingsbury HS (2375) 2A | Per Mr. Fuller: he would like to have parking spaces numbered | 8/8/13 | Parking Lot | | entire lot | Painting |
| Kingsbury HS (2375) 2A | the locker rms are very dark as well in need of painting/paint is peeling very badly | 10/16/13 | Gym | | girls' /boys' locker rm | Painting |
| Kingsbury HS (2375) 2A | paint lines on football field | 5/22/14 | | | | Painting |
| Kingsbury HS (2375) 2A | please line soccer field for upcoming soccer season. Call Coach Jihad Haidar at 901-503-9627 or 901-416-6060 ext#85909 because TSSAA modified the dimensions on the soccer field and requirements. | 3/17/14 | Athletic Field | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI 1ST FLR B RR BY RM 162 LAST STALL ON STALL WALLS-PLANT MGR SNERLING 416-6060 KLR | 3/19/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI IN MID GYM BACK WALL BAND RM PLANT MGR-SNERLING/416.6060 | 3/20/14 | | | | Painting |
| Kingsbury HS (2375) 2A | Hallway walls need painted same color off white. | 3/20/14 | 1st Floor | | 9th grade hall & science wing hall | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI IN B/RR-G/RR AUDIT. PLANT MGR-SNERLING/416.6060 | 3/27/14 | | | | Painting |
| Kingsbury HS (2375) 2A | PAINT LINES ON SOCCER FIELD | 3/27/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GANG GRAFFITI BACK HALL ON BRICK WALL BY BANDRM-PLANT MGR SNERLING 416-6060 KLR | 3/31/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI 2ND FLR TOP LANDING ON BLOCK WALL, UNDER LANDING NEAR RM 170 ON BLOCK WALL, GYM BY BANDRM ON BLOCK WALL, & MIDDLE GYM ON PILLAR TOWER-PLANT MGR SNERLING 416-6060 KLR | 4/22/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI ON WALLS UNDER STAIRWAY BY RM-168 PLANT MGR-SNERLING/416.6060 | 5/6/14 | | | | Painting |
| Kingsbury HS (2375) 2A | paint doors | 5/20/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI IN 2-G/RR BY RM-171, 162, & BACK CAFE DOOR . PLANT MGR-SNERLING/416.6060 | 10/16/13 | | | | Painting |
| Kingsbury HS (2375) 2A | GANG GRAFFITI OUTSIDE FRONT OF BLDG ON BRICK WALL-PLANT MGR SNERLING 416-9661 KLR | 10/22/13 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI ON OUTSIDE BACK WALL TOWARD FOOTBALL FIELD, & DOORS-INSIDE CORNER WALLS BY BAND RM. PLANT MGR-SNERLING/416.6060 | 10/25/13 | | | | Painting |

| | | | | | | |
|------------------------|---|----------|------------------|--|---|----------|
| Kingsbury HS (2375) 2A | GRAFFITI IN B/RR 2ND FLR, & G/RR 1ST FLR. PLANT MGR-SNERLING/416.6060 | 10/28/13 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI ON WALL BY RM-120. PLANT MGR-SNERLING/416.6060 | 10/30/13 | | | | Painting |
| Kingsbury HS (2375) 2A | GANG GRAFFITI B RR 2ND FLR ON ALL THE STALLS IN RR-PLANT MGR SNERLING 416-6060 KLR | 11/5/13 | | | | Painting |
| Kingsbury HS (2375) 2A | Graffiti under stairwell near room #170 and Graffiti near room#164. | 11/22/13 | 1st Floor | | near Rm.170&Rm164 | Painting |
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 gang graffiti science wing near 120, girls restroom near elevator on 2nd floor, back hall of the gym beside band room, 2nd floor boys restroom near rm 262 | 2/25/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GANG GRAFFITI OUTSIDE ON TIN BLDG-PLANT MGR SNERLING 416-6060 KLR | 9/6/13 | | | | Painting |
| Kingsbury HS (2375) 2A | Gym boys restroom walls need painting ASP paint is peeling off whole wall. | 9/9/13 | Gym | | Gym | Painting |
| Kingsbury HS (2375) 2A | girls/boys locker room gang graffiti per Ms. Snerling 416-6060 | 10/16/13 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI ON WALL BY BAND RM, DOORS IN GYM | 12/2/13 | | | | Painting |
| Kingsbury HS (2375) 2A | PLANT MGR-SNERLING/416.6060 gang graffiti under stairwell by rooms 166 & 170 per Ms. Snerling 416-6060 | 12/3/13 | | | | Painting |
| Kingsbury HS (2375) 2A | Gang graffiti outside the MAIN BUILDING on FRONT per Ms. Snerling, Plant Mgr. 416.2325 | 1/6/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GANG GRAFFITI BACK CORNER OF GYM ON BLOCK WALL-PLANT MGR SNERLING 416-6060 KLR | 1/8/14 | | | | Painting |
| Kingsbury HS (2375) 2A | Graffiti on the Old Mechanical Building per Mr. Nolen, Plant Mgr. 416.0681 | 1/8/14 | | | | Painting |
| Kingsbury HS (2375) 2A | GRAFFITI ON AUDIT B/RR WALLS. PLANT MGR-SNERLING/416.6060 | 1/24/14 | | | | Painting |
| Kingsbury HS (2375) 2A | PIPE TO AHU MECH RM BEHIND AUDITORIUM-LEAKING-PLANT MGR SNERLING 416-6060 KLR | 3/12/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | First stall at entrance toilet stop -up. | 3/21/14 | 1st Floor | | Restroom | Plumbing |
| Kingsbury HS (2375) 2A | Third stall in boy's restroom constant runing. | 3/21/14 | | | Restroom | Plumbing |
| Kingsbury HS (2375) 2A | Rain saturate on parking lot and will not drain properly. drainage pipes stop - up. | 3/27/14 | Grounds | | sewage / drainage in parking lot near Cafeteria | Plumbing |
| Kingsbury HS (2375) 2A | Request black flow test. | 4/8/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | Request support to clean out a drain. | 4/8/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | UNIT IS LEAKING WATER IN RM-253 PLANT MGR-SNERLING/416.6060 | 5/8/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 room 164 drain stopped up on cooling unit | 5/12/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | FLOOR DRAIN is BACKING UP in the GIRL'S SHOWER ROOM per Mr. Snerling, Plant Mgr. 416.6060 | 5/16/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | U-pipe stopped up/sour smell due to water sitting up to drain | 5/16/14 | Hallway/Corridor | | off boiler @ plant mgr's office | Plumbing |
| Kingsbury HS (2375) 2A | Double sink drainage pipes clog up. | 5/20/14 | 1st Floor | | Rm.121 | Plumbing |
| Kingsbury HS (2375) 2A | PUMP - MECHANICAL RM 1 - BY 1ST FLR - WATER IS SHUTTING OUT - BOILER RM FLOODED - PM/SNERLING | 10/28/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | HAND SINK IS STOPPED UP IN NURSE STATION RM-152 PLANT MGR-SNERLING/416.6060 | 2/28/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | Drinking fountain stop - up. | 3/7/14 | 1st Floor | | Near Room 167 | Plumbing |
| Kingsbury HS (2375) 2A | COMMODE FOOTBALL LOCKER RM OVERFLOWING-PLANT MGR SNERLING 416-6060 KLR | 11/1/13 | | | | Plumbing |

| | | | | | | |
|------------------------|--|----------|-----------------|--|--------------------------------|----------|
| Kingsbury HS (2375) 2A | URINAL PIPE HAS BEEN BROKE APART IN B/RR BY LIBRARY, CANT CONTROL WATER. PLANT MGR-SNERLING/334.8832 | 11/4/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | CIRCULATING PUMP IS SHOOTING OUT WATER CAUSING BOILER TO GO IN LOW PRESSURE & RMS NOT HEATING. PLANT MGR-SNERLING/416.6060 | 11/6/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | leaking at base when flush/**safety concern** SPED student use this for handicap purposes | 11/6/13 | 1st Floor | | near guidance/handicap restrm | Plumbing |
| Kingsbury HS (2375) 2A | 10-UNIT PILOT NEEDS TO BE LIT FOR HEAT IN GYM & COACHES OFFICES, & LOCKER RM PLANT MGR-SNERLING/416.6060 | 11/13/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | COMMODOE TEACHER'S LOUNGE-BOWL HAS BROKEN AND WATER RUNNING OUT EVERYWHERE, CANT CONTAIN PER SBE-PLANT SNERLING 416-6060 KLR | 11/13/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | UNIT HEATER RM 265-COILS HAVE BURST-PLANT MGR SNERLING 416-6060 KLR | 11/14/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | Girls handicap restroom sink pipe are leaking,please repair. | 11/22/13 | 1st Floor | | SCIENCE WING | Plumbing |
| Kingsbury HS (2375) 2A | HANDICAP/RR SINK IS LEAKING WATER ON NORTH-WING. PLANT MGR-NOLAN/416.0060 | 11/25/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | 3rd stall needs seat replaced | 11/26/13 | Gym | | boys' locker rm near bleachers | Plumbing |
| Kingsbury HS (2375) 2A | DRAIN IS BACKING IN PARKING LOT BY CAFE. PLANT MGR-SNERLING/416.6060 | 2/4/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | RESTROOM in the MAIN OFFICE FLOOR DRAIN BACKS UP when the TOILET is FLUSHED and causes WATER TO OVERFLOW ONTO THE FLOOR per Mr. Nolen, Plant Mgr. 416.6081 | 2/4/14 | | | | Plumbing |
| Kingsbury HS (2375) 2A | Need toilet seat in girls locker room. | 2/5/14 | Gym | | Restroom | Plumbing |
| Kingsbury HS (2375) 2A | replace toilet seat in restroom within his office | 2/11/14 | 2nd Floor | | AP, Mr Miller's Office | Plumbing |
| Kingsbury HS (2375) 2A | faucet needs replacing | 2/14/14 | Cafeteria | | Mngr's restrm | Plumbing |
| Kingsbury HS (2375) 2A | pipe in ceiling leaking down on floor | 8/9/13 | Classroom | | Rm#164 | Plumbing |
| Kingsbury HS (2375) 2A | U-pipe under both sinks leking | 8/12/13 | Kitchen | | Cook's sink & mngr's restroom | Plumbing |
| Kingsbury HS (2375) 2A | PIPE IS RUNNING DOWN WALL IN RM-157D PLANT MGR-SNERLING/416.6060 | 8/22/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | comode seal is leaking around base @ floor **safety concern** | 8/23/13 | Restroom (Boys) | | 1st Fl/1st on LF side | Plumbing |
| Kingsbury HS (2375) 2A | UNIT IN THE BAND RM IS LEAKING. SBE SNERLLING 416-6060 | 8/2/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | UNIT IN RM 273 IS LEAKING. SBE SNERLLING 416-6060 | 8/6/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | Back flow test. | 8/8/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | room 263 unit is leaking and leaking into room 164 below per ms snerling 416-6060 | 9/17/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | POWER OUTAGE - HALF OF SCHOOL IS OUT PM/SNERLING 416-6060 | 9/23/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | GAS LEAK - SCIENCE WING - PM/SNERLING 416-6060 | 9/23/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | 2-AHU ARE FLOODING IN MECH RM BEHIND AUDIT PLANT MGR-SNERLING/416.6060 | 9/30/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | UV RM 157B-DRAIN STOPPED UP & LEAKING-PLANT MGR SNERLING 416-6060 KLR | 10/3/13 | | | | Plumbing |
| Kingsbury HS (2375) 2A | Boy restroom stop - up toilet. | 9/9/13 | Gym | | restroom | Plumbing |

| | | | | | |
|------------------------|--|----------|---------------------|---------------------------------|----------|
| Kingsbury HS (2375) 2A | **Handicap restrm** PLEASE replace broken toilet seat URGENT,PLEASE!! | 9/12/13 | Stairway | across from guidance | Plumbing |
| Kingsbury HS (2375) 2A | **Handicap restrm** U-pipe has rusted out/water runs straight to floor/can't turn off water line **slippery floor/health concerns** | 9/12/13 | Restroom (Boys) | science wing | Plumbing |
| Kingsbury HS (2375) 2A | 2 comodes sopped up | 10/16/13 | Gym | girls' locker rm | Plumbing |
| Kingsbury HS (2375) 2A | 1 handsink stopped up & one need faucet replaced | 10/16/13 | Gym | girls' locker rm | Plumbing |
| Kingsbury HS (2375) 2A | Water leaking from the bottom of the toilets in both rest-rooms. | 12/3/13 | 1st Floor | 12th floor boys&girls restrooms | Plumbing |
| Kingsbury HS (2375) 2A | 3-UNITS NOT COMING ON, PILOT NEEDS TO BE LIT IN GYM PLANT MGR-SNERLING/416-6000 | 12/13/13 | | | Plumbing |
| Kingsbury HS (2375) 2A | PIPE HAS FLOODED G/RR 2ND FLR TO 1ST FLR PLANT MGR-SNERLING/416-6060 | 12/17/13 | | | Plumbing |
| Kingsbury HS (2375) 2A | Toilet constantly runing water in bowl. | 12/17/13 | 2nd Floor | across from Mr. Miller office | Plumbing |
| Kingsbury HS (2375) 2A | Need sink pipes put back together. | 12/17/13 | Gym | concession stand | Plumbing |
| Kingsbury HS (2375) 2A | COMMODE TEACHER'S LOUNGE-FLUSH VALVE BROKEN OFF & WATER RUNNING FROM STEM-CAN'T CUT OFF OR CONTAIN-PLANT MGR SNERLING 416-6060 K1 R | 12/19/13 | | | Plumbing |
| Kingsbury HS (2375) 2A | These restrooms are leaking from bottom of toilet boys last stall and girls first stall. | 12/19/13 | 1st Floor | Boys&girls restroom | Plumbing |
| Kingsbury HS (2375) 2A | 1st stall is stopped up & 2nd stall is leaking under base down in toilet on 1st floor **safety/slipage concern** | 1/10/14 | Restroom (Girls) | 2n FL @ corner from elevator | Plumbing |
| Kingsbury HS (2375) 2A | replace broken comode--water leaking out/**safety/slipage concern** | 1/13/14 | Gym | Girl's locker rm | Plumbing |
| Kingsbury HS (2375) 2A | remove old heat radiator from serving line(past request to cover with metal) now B. Shipp said to remove, cover hole with sheet metal with glued on insulation .os | 1/21/14 | | | Plumbing |
| Kingsbury HS (2375) 2A | VALVE STEM BROKEN & WATER IS RUNNING IN HANDICAP/RR 2ND FLR BY RM-251. PLANT MGR-SNERLING/416.6060 | 1/24/14 | | | Plumbing |
| Kingsbury HS (2375) 2A | hand sink against wall stopped up & rest @ corner near 169 (1) comode stopped up | 6/30/14 | Restroom (Girls) | across from #162 | Plumbing |
| Kingsbury HS (2375) 2A | double sink stopped up | 5/22/14 | Classroom | Rm#121 | Plumbing |
| Kingsbury HS (2375) 2A | Rt wall @ entrance/water leaking from under sink/can't contain after turning off with water key | 6/18/14 | Restroom (Boys) | 2nd Fl/middle hand sink | Plumbing |
| Kingsbury HS (2375) 2A | UNIT VENTILATOR is LEAKING in ROOM 264 per Ms. Snerling, Plant Mgr. 416.6060 | 6/23/14 | | | Plumbing |
| Kingsbury HS (2375) 2A | A/C RM 267-DRAIN PAN STOPPED UP AND LEAKING-PLANT MGR SNERLING 416-6060 KLR | 6/16/14 | | | Plumbing |
| Kingsbury HS (2375) 2A | water running onto floor**safety/slipage concern** | 4/2/14 | Gym | locker rms | Roof |
| Kingsbury HS (2375) 2A | roof leaking | 4/3/14 | 2nd Floor | bookrm | Roof |
| Kingsbury HS (2375) 2A | roof leaking in following areas: both front locker rms & lobby. rms#136, 251, 252, 276, 261, & Auditorium | 3/28/14 | Administration Area | several areas | Roof |
| Kingsbury HS (2375) 2A | 136, 276, 2nd floor book rm,(damaging several cs of books), several areas in lobby of gym, boys' & girls' locker rms **safety/slipage concern** | 4/4/14 | Classroom | several areas | Roof |
| Kingsbury HS (2375) 2A | roof leaking through light panel | 10/16/13 | Restroom (Boys) | near library | Roof |

| | | | | | |
|------------------------|---|----------|---------------------|----------------------------------|-------------|
| Kingsbury HS (2375) 2A | roof leaking in several different areas:2nd floor computer lab, elevator, rms#276,261, bookrm, several areas in gym, & several areas in Auditorium | 3/6/14 | Classroom | throughout facility | Roof |
| Kingsbury HS (2375) 2A | roof leaking in following areas:handicap restrm near rm#251, computer lab, #276, 261, & several areas within gym | 3/7/14 | 2nd Floor | several locations | Roof |
| Kingsbury HS (2375) 2A | roof leaking/ceiling tiles falling out/safety concern | 11/18/13 | Classroom | Rm #152 | Roof |
| Kingsbury HS (2375) 2A | raining through ceiling | 11/18/13 | Cafeteria | @ ramp | Roof |
| Kingsbury HS (2375) 2A | raining in 4 different places in lobby & 3 places in locker rm | 2/4/14 | Gym | lobby & boys' locker room | Roof |
| Kingsbury HS (2375) 2A | water running down walls into floor/**safety concern* | 2/6/14 | Auditorium | lobby/over girls' restrm door | Roof |
| Kingsbury HS (2375) 2A | roof leaking profusely | 2/6/14 | 2nd Floor | 2nd fl/ Comp. room | Roof |
| Kingsbury HS (2375) 2A | roof leaking | 2/10/14 | Classroom | closet of Rm#257 & 271 | Roof |
| Kingsbury HS (2375) 2A | roof leaking | 2/10/14 | Gym | lobby & boys' restrm | Roof |
| Kingsbury HS (2375) 2A | in front main office & closet of #157 | 2/10/14 | Hallway/Corridor | bookrm 2nd floor/main | Roof |
| Kingsbury HS (2375) 2A | water leaking through ceiling/**slipage/safety concern for students** | 2/20/14 | Stairway | off main office | Roof |
| Kingsbury HS (2375) 2A | constant flow of running water from ceiling on steps/**safety concern/slipage** | 2/20/14 | Stairway | @ rm#170 | Roof |
| Kingsbury HS (2375) 2A | roof leaking | 8/13/13 | Administration Area | 157/Mr. Mckinney's office | Roof |
| Kingsbury HS (2375) 2A | roof leaking | 8/13/13 | Cafetorium | two places | Roof |
| Kingsbury HS (2375) 2A | roof leaking/constant flow after raining | 8/19/13 | Administration Area | #157D/inside discipline office | Roof |
| Kingsbury HS (2375) 2A | raining on waxed floor | 7/19/13 | Hallway/Corridor | between rms #124 & 126 | Roof |
| Kingsbury HS (2375) 2A | raining on waxed floor | 7/19/13 | Cafetorium | in front serving doors | Roof |
| Kingsbury HS (2375) 2A | leaking when it rains | 8/7/13 | Classroom | Rm#170 | Roof |
| Kingsbury HS (2375) 2A | leaking from ceiling. | 12/10/13 | 2nd Floor | boy's restroom | Roof |
| Kingsbury HS (2375) 2A | Boys and Girls locker room / rest room have ceiling leaks. | 12/11/13 | Gym | Gym | Roof |
| Kingsbury HS (2375) 2A | water leaking throughout rm#276/ leaking in several spots in lobby of gym & 4 places in each locker rm of entrance | 1/6/14 | Classroom | rm #276 & gym | Roof |
| Kingsbury HS (2375) 2A | carpet in front of stage to left/through light fixtures & 4 other places of lobby | 1/13/14 | Auditorium | lobby/front of stage | Roof |
| Kingsbury HS (2375) 2A | ceiling tiles falling out due to leakage **Safety concern as to slipage & tiles falling on students** | 1/14/14 | Classroom | Rms#270,276, & front main office | Roof |
| Kingsbury HS (2375) 2A | roof leaking/has destroyed over 10 cases of text books | 1/14/14 | 2nd Floor | Bookroom | Roof |
| Kingsbury HS (2375) 2A | water running @ this present time from ceiling & ceiling tiles fell out in the following areas:Rms#comp lab., 261,276,136, lobby of auditorium, front of stage, cafeteria in 4 different areas & gym in 3 different areas | 6/30/14 | 2nd Floor | throughout facility | Roof |
| Kingsbury HS (2375) 2A | Starting back raining in comp area/water running into Mr. Miller office on valuable financial records. | 6/2/14 | Administration Area | AP's Office/2nd FL/#265 | Roof |
| Kingsbury HS (2375) 2A | water has been draining down through ceiling since last hard rain in #257 & book rm damaging boks, equipment, etc. | 5/23/14 | 2nd Floor | storage Rms within classrms | Roof |
| Kingsbury HS (2375) 2A | raining profusely--has damaged aprly 15 cs of books & materials | 4/28/14 | Classroom | Rm # 276 & bookrm next door | Roof |
| Kingsbury HS (2375) 2A | roof leaking & ceiling tiles falling in these areas:cafeteria, Rm#276, 2nd fl bookrm, computer rm, lobby of gym, lobby of auditorium, & down wall of girls' restrm in auditorium | 6/13/14 | Administration Area | throughout facilities | Roof |
| Kingsbury HS (2375) 2A | install metal ledge /gutter along front/side roof to deflect water running off roof--it pools in front of door instead of running out to drive. | 3/8/14 | Custodial | entrance of Plant mgr's office | Sheet Metal |
| Kingsbury HS (2375) 2A | Request gutters near courtyard, top right side. | 2/12/14 | Courtyard | | Sheet Metal |

| | | | | | |
|------------------------|---|----------|------------------|---------------------|-------------|
| Kingsbury HS (2375) 2A | per ms snerling 416-6060 locker A411 (next to rm 171) and locker #224 (2nd fl) are both jammed and can't open and belongings are in them | 2/13/14 | | | Sheet Metal |
| Kingsbury HS (2375) 2A | metal sliding door has been pulled aloose by some trying to gain access to stored equipment on field side **large hole in middle section** | 9/12/13 | Annex | Metal shop bldg | Sheet Metal |
| Kingsbury HS (2375) 2A | repair gutters torn/bent due to limb fallen from ice storm | 12/12/13 | Courtyard | top right side | Sheet Metal |
| Kingsbury HS (2375) 2A | Request a cover be fabricated and installed over the vent unit in the cafeteria. | 1/16/14 | | | Sheet Metal |
| Kingsbury HS (2375) 2A | cover missing locker door A29 | 6/25/14 | Hallway/Corridor | 1st Fl near rm #170 | Sheet Metal |
| Kingsbury HS (2375) 2A | Locker door missing beside A28. | 6/9/14 | | 1fl near RM#169 | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|------------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Kingsbury MS (2373) 2A | 1 | 35 | 39 | 23 | 10 | 44 | 10 | 3 | 165 |
| Grand Total | 1 | 35 | 39 | 23 | 10 | 44 | 10 | 3 | 165 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|---------------------------|--|----------------------|----------------------|---|--------------|
| Kingsbury MS (2373) 2A | replace floor tiles in remodeled classroom | 8/1/13 | Classroom | Rm#211/band rm | Asbestos |
| Kingsbury MS (2373) 2A | Hang large banner up between the two banners above first basketball goal near front entrance. The machine lift is already in gym. Principal request. | 5/22/14 | Gym | Gymnasium | Carpentry |
| Kingsbury MS (2373) 2A | 2 cs of HEAVY ceiling tiles to relpace damaged tiles | 5/27/14 | Custodial | SBE's office | Carpentry |
| Kingsbury MS (2373) 2A | Need to order an 3' X 3' white dry erase board mounted inside principal office before school began. | 6/19/14 | Administration Area | Principal Office | Carpentry |
| Kingsbury MS (2373) 2A | threshold has popped up causing left exit door to only open about 1/4 the way. | 5/16/14 | Cafeteria | N. W. exit doors leading to CTC | Carpentry |
| Kingsbury MS (2373) 2A | replace hardware/panic bar-- cylinder won't stay out to secure facility. | 5/20/14 | 1st Floor | entrance doors @ dock off cafeteria | Carpentry |
| Kingsbury MS (2373) 2A | 3 sets of exit doors/place door sweeps to keep field mice from entering under doors | 8/2/13 | 1st Floor | Throughout cafeteria & back door of kitchen | Carpentry |

| | | | | | |
|---------------------------|---|----------|---------------------|------------------------------------|-----------|
| Kingsbury MS (2373) 2A | electronic door will not close complete/hindge maybe off set/**security/safety concern** | 12/11/13 | 1st Floor | @ side walkway entrance | Carpentry |
| Kingsbury MS (2373) 2A | EXIT SIDE DOOR, CANT SECURE PLANT MGR-SNERLING/416.6060 | 12/18/13 | | | Carpentry |
| Kingsbury MS (2373) 2A | SIDE ENTRANCE DOOR BY MAIN OFC-NOT LOCKING-CAN BE PULLED OPEN AFTER LOCKING IT PER SBE-PLANT MGR NOLAN 416-6081 KLR | 1/2/14 | | | Carpentry |
| Kingsbury MS (2373) 2A | door knob has broken off/experiencing difficulties opening the door **URGENT, PLEASE!** | 1/17/14 | Kitchen | exit door on dock | Carpentry |
| Kingsbury MS (2373) 2A | replace base board along wall on ramp | 3/10/14 | Cafetorium | on ramp | Carpentry |
| Kingsbury MS (2373) 2A | exhaut fan cover detaching from ceiling | 3/19/14 | Administration Area | AP restrm/Ms. Young | Carpentry |
| Kingsbury MS (2373) 2A | place hasp on panel to keep students from turning off cafeteria lights | 3/27/14 | Cafetorium | outer wall leading to serving line | Carpentry |
| Kingsbury MS (2373) 2A | door knob fallen off/children stuck in rm---carpenters on site! | 3/28/14 | Classroom | Rm# 205 | Carpentry |

| | | | | | | |
|---------------------------|--|---------|------------------|------------------------------|--|-----------|
| Kingsbury MS (2373) 2A | CTR MULL BROKEN ON CAFE ENTRANCE DOOR-WILL NOT BE ABLE TO SECURE-PLANT MGR SNERLING 416-6040 KLR | 4/8/14 | | | | Carpentry |
| Kingsbury MS (2373) 2A | top hindge is off set door won't lock/over laps with LOUD slam | 4/17/14 | Restroom (Girls) | before middlle stairwell | | Carpentry |
| Kingsbury MS (2373) 2A | Rt exit door is not latching securely **security/safety concern** | 4/30/14 | Stairway | exit off cafe leading to CTC | | Carpentry |
| Kingsbury MS (2373) 2A | cylinder won't to secure expensive equipment | 8/6/13 | Classroom | Rm #111 | | Carpentry |
| Kingsbury MS (2373) 2A | windows are stuck and can't close. | 8/8/13 | 1st Floor | cafeteria | | Carpentry |
| Kingsbury MS (2373) 2A | cylinder spining around | 8/9/13 | Restroom (Boys) | 2nd Floor | | Carpentry |
| Kingsbury MS (2373) 2A | Need wet and missing ceiling tiles replace , more then 13' up to ceiling . | 8/15/13 | Cafeteria | Cafeteria | | Carpentry |
| Kingsbury MS (2373) 2A | Door lock need repair , will not lock. | 8/15/13 | 1st Floor | Asist. Principal Office | | Carpentry |

| | | | | | |
|---------------------------|--|----------|---------------------|--------------------------|-----------|
| Kingsbury MS (2373) 2A | door closes to T.Lounge/turn knob but cylinder won't go in to open door | 8/16/13 | Administration Area | Rm#103/attendance office | Carpentry |
| Kingsbury MS (2373) 2A | locker pulled aloose from wall/**safety concern** | 8/16/13 | Hallway/Corridor | near rm#113 | Carpentry |
| Kingsbury MS (2373) 2A | WINDOW KITCHEN REAR DOOR ENTRANCE BROKEN OUT DUE TO A BREAK IN-SBESNERLING 416-6040 KLR | 8/19/13 | | | Carpentry |
| Kingsbury MS (2373) 2A | Manager is requesting a new door w/o windows due to break-ins to steal money/secure equipment & food | 8/19/13 | Kitchen | entrance off dock | Carpentry |
| Kingsbury MS (2373) 2A | top hinged of entrance is off set causing door slam loudly disturbing class in surrounding area **urgent PLEASE!!** | 9/19/13 | Restroom (Boys) | main hall/1st floor | Carpentry |
| Kingsbury MS (2373) 2A | install metal plate over hasp to prevent lock being popped due to break-in | 9/25/13 | Cafeteria | entrance door on dock | Carpentry |
| Kingsbury MS (2373) 2A | replace broken door closure | 9/25/13 | Cafeteria | entrance door on dock | Carpentry |
| Kingsbury MS (2373) 2A | top hinged off set/door gets stuck when closed/ **URGENT,PLEASE--students will get stuck in classrm** | 10/10/13 | Classroom | Rm#106 | Carpentry |

| | | | | | |
|---------------------------|--|----------|---------------------|-----------------------------|------------|
| Kingsbury MS (2373) 2A | Room 108 door is jammed can't open per Ms. Snerling 416-6040 | 10/21/13 | | | Carpentry |
| Kingsbury MS (2373) 2A | Make rail for water fountain in the gym | 11/11/13 | | | Carpentry |
| Kingsbury MS (2373) 2A | Restroom door lock is broken, please repair. | 11/14/13 | 1st Floor | Girls restroom | Carpentry |
| Kingsbury MS (2373) 2A | Need ceiling tiles replace in main hallway. Some need to be cut and fitted in frame. Need a total of 150 tiles. | 12/6/13 | | Hallway | Carpentry |
| Kingsbury MS (2373) 2A | need metal rod & hasp installed on 6 file cabinets that house ISPs/IEPs on SPED student records--required by policies & procedures--keyed locks/rods broken **URGENT,PLEASE** | 12/9/13 | Administration Area | guidnce & SPED rm#101 | Carpentry |
| Kingsbury MS (2373) 2A | Electrical problem with light switches. a long delay when cut on or off. | 5/22/14 | 2nd Floor | 206 , 209 & 210 | Electrical |
| Kingsbury MS (2373) 2A | Four ballast need replace. | 5/22/14 | Gym | Back hallway near band room | Electrical |
| Kingsbury MS (2373) 2A | 2 ballasts burned out | 5/21/14 | 1st Floor | M-1/Mr Moses--upstairs | Electrical |

| | | | | | |
|---------------------------|--|----------|------------------------|---------------------|------------|
| Kingsbury MS (2373) 2A | PARTIAL POWEROUTAGE. SBE SNERLLING 416-6040 | 7/1/13 | | | Electrical |
| Kingsbury MS (2373) 2A | Synchronize clocks in main hallways. | 7/30/13 | 1st Floor | 1st &2nd floor | Electrical |
| Kingsbury MS (2373) 2A | UV NOT COMING ON IN RM-101 PLANT MGR- SNERLING/416.6060 | 12/11/13 | | | Electrical |
| Kingsbury MS (2373) 2A | Ballast need replace in computer lab. above the Viola instruments. | 1/8/14 | 2nd Floor | Computer lab. | Electrical |
| Kingsbury MS (2373) 2A | 2 cs flourescent tubes/ 6 screw in flourescent lamps #46820 | 1/16/14 | Custodial | Plant mngr | Electrical |
| Kingsbury MS (2373) 2A | Per AP, Ms. Young, need clocks synchronized to keep students on scheduled programed **URGENT, PLEASE!!** | 1/24/14 | Administration Area | throughout facility | Electrical |
| Kingsbury MS (2373) 2A | WALL UNIT NOT COMING ON IN RM-203 PLANT MGR- SNERLING/416.6060 | 1/28/14 | | | Electrical |
| Kingsbury MS (2373) 2A | LIGHT SWITCH PRIN'S OFC- HAS SHORTED OUT AND NOW CAN'T TURN LIGHTS-PLANT MGR SNERLING 416-6040 KLR | 1/30/14 | | | Electrical |

| | | | | | |
|---------------------------|--|---------|---------------------|------------------------------------|------------|
| Kingsbury MS (2373) 2A | 1 electrical fixture needs replacing & has wires exposed from it per: AS Plant mngr--can't remove bulb end | 2/26/14 | Mechanical Room | boiler rm | Electrical |
| Kingsbury MS (2373) 2A | bulbs blown due to electrical storm. Need replacing that Techs may be able to see to perform their much needed taks. | 3/5/14 | Mechanical Room | boiler rm | Electrical |
| Kingsbury MS (2373) 2A | reset clocks due to daylight saving time | 3/8/14 | Administration Area | main office | Electrical |
| Kingsbury MS (2373) 2A | 1/2 of lights in cafeteria are off/all switches are on | 3/21/14 | Cafeteria | eatery area | Electrical |
| Kingsbury MS (2373) 2A | need exit signs replaced | 3/24/14 | Hallway/Corridor | @ rm211, front, & center stairwell | Electrical |
| Kingsbury MS (2373) 2A | fire doors not latching | 3/24/14 | Hallway/Corridor | 1st FL/center stairwell | Electrical |
| Kingsbury MS (2373) 2A | back wall receptacles out | 3/26/14 | Classroom | Rm#106 | Electrical |
| Kingsbury MS (2373) 2A | per ms snerling 416-6040 room 114 unit is not coming on at all | 3/27/14 | | | Electrical |

| | | | | | |
|---------------------------|---|---------|---------------------|-------------------------|------------|
| Kingsbury MS (2373) 2A | run electricity into receptacles on back wall for usage by Teacher | 4/2/14 | Classroom | Rm# 106 | Electrical |
| Kingsbury MS (2373) 2A | UNIT HAS A BURNING SMELL IN RM-106 PLANT MGR-SNERLING/416.6000 | 4/8/14 | | | Electrical |
| Kingsbury MS (2373) 2A | Need ballast replace near secretary desk. | 4/9/14 | 1st Floor | Main office | Electrical |
| Kingsbury MS (2373) 2A | Mr. Yancey on site/will address 1 ballast blown near secretary's desk | 4/10/14 | Administration Area | main office/rm#100 | Electrical |
| Kingsbury MS (2373) 2A | 1 ballast burned out in front of main office | 8/5/13 | Hallway/Corridor | In front of main office | Electrical |
| Kingsbury MS (2373) 2A | Ceiling light fixture need ballast. | 8/8/13 | 1st Floor | main office hallway | Electrical |
| Kingsbury MS (2373) 2A | Need ballasts replace in light fixtures. | 8/15/13 | 1st Floor | room 109 Ms. Brown | Electrical |
| Kingsbury MS (2373) 2A | ballast burned out ***need 2 cases of fluorescent tubes*** | 8/16/13 | Hallway/Corridor | @cafeteria entrance | Electrical |

| | | | | | |
|---------------------------|---|----------|---------------------|-------------------------------|------------|
| Kingsbury MS (2373) 2A | ballast burned out | 8/19/13 | Stairway | middle set @ exit doors | Electrical |
| Kingsbury MS (2373) 2A | lab tables plugs aren't working/students need to perform science experiments | 8/27/13 | Classroom | Rm#126/Mr Ritter | Electrical |
| Kingsbury MS (2373) 2A | shortage in switch | 9/9/13 | Classroom | Rm #111/Ms Utley | Electrical |
| Kingsbury MS (2373) 2A | Exit signs need new batteries. | 9/18/13 | Gym | whole gym | Electrical |
| Kingsbury MS (2373) 2A | entrance is completely dark/both ballast burned out **URGENT, PLEASE!--- safety concern** | 9/25/13 | Hallway/Corridor | entrance off cafeteria | Electrical |
| Kingsbury MS (2373) 2A | synchronize clocks & bells/ringing incorrectly **URGENT, PLEASE!!** | 10/16/13 | Administration Area | throughout bldg/Per Principal | Electrical |
| Kingsbury MS (2373) 2A | Need ballasts replace in room 203. | 10/24/13 | 2nd Floor | Rm.203 | Electrical |
| Kingsbury MS (2373) 2A | COOLING VENT NOT COMING ON IN RM-212 PLANT MGR- SNERLING/416.6060 | 10/30/13 | | | Electrical |

| | | | | | |
|---------------------------|---|----------|-----------|-------------------------------------|--|
| Kingsbury MS (2373) 2A | both lights out/area dark employees' car broken into last night also safety concern for women employees going to trash bins | 11/14/13 | Grounds | pole & corner of dock | Electrical |
| Kingsbury MS (2373) 2A | light mounted off the corner of building has burned out **safety/security concern** | 11/19/13 | Grounds | corner of dock @ school entrance | Electrical |
| Kingsbury MS (2373) 2A | Switches and these classroom need replace. | 11/19/13 | 2nd Floor | Rm.206 &210 | Electrical |
| Kingsbury MS (2373) 2A | UNITS ARE NOT WORKING THRU OUT THE BDLG. ENTIRE BLDG IS HOT. SBE SNERLING 416-6060 | 7/29/13 | | | Electrical |
| Kingsbury MS (2373) 2A | UNIT NOT COOLING RM-201 PLANT MGR- SNERLING/416.6060 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | A/C UNIT is NOT COOLING in the ARMORY per Ms. Snerling, Plant Mgr. 416.6040 | 5/21/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UNIT NOT COOLING IN RM-107 PLANT MGR-LEE/416.6040 | 6/20/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UNITS NOT COOLING IN RM - 200 THRU 203 PLANT MGR-NOLAN/416.0587 | 6/10/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------|--|----------|--|--|---------------------------------------|
| Kingsbury MS (2373) 2A | per ms snerling 416-6040, hvac tech was out there yesterday to clean unit for cafetorium and water did not drain so it backed up into the unit and it is shooting all over the place | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | 3-UV NOT COOLING IN BAND RM (025,026) RM-200(020) RM-201(036). SBE-SNERLING/416-6060 | 7/2/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | A/C units are NOT COOLING in the 1st floor Rms 101 thru 115 and on the 2nd floor Rms 200 thru 212 per Ms. Snerling, Plant Mgr. at 901.334.8832. | 7/11/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UNIT NOT COOLING IN RM-109. SBSNERLING/416-6040 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | 2-UV NOT COOLING IN RM-114 & BAND RM . PLANT MGR-SNERLING/416.6060 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | A/C IN RMS 206, 109, & 114-ALL NOT COOLING-SBE NOLAN 416-6060 KLR | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | AHU NOT HEATING IN ROTC BLDG. PLANT MGR-SNERLING/416-6060 | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | per Ms. Snerling 416-6040 room 207 blowing cold | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------|--|---------|--|--|---------------------------------------|
| Kingsbury MS (2373) 2A | HEAT RM 107, 112, 113, 115, 209, & 210-ALL NOT HEATING-PLANT MGR SNERLING 416-6040 KLR | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | Circulation Pump in the Boiler Room is whining and causing a disturbance per the principal per Ms. Snerling, Plant Mgr. 416.6040 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UNIT IS MAKING NOISE IN TEACHERS' LOUNGE PLANT MGR-SNERLING/416.6060 | 2/21/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | A/C RM 101, 109, 111, & 201-ALL NOT COOLING-PLANT MGR SNERLING 416-6060 KLR | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | A/C UNIT is NOT COOLING in ROOM 101 per Ms. Snerling, Plant Mgr. 416.6040 | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UNITS NOT COOLING IN RMS 212,209,205. SBE SNERLING 416-6040 | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UV NOT COOLNG RM-114(112),206(033) . PLANT MGR-SNERLING/416.6060 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------|---|----------|---------|----------------------|--|
| Kingsbury MS (2373) 2A | A/C UNIT 2ND FLR RM 209 AREA A & A/C UNIT 2ND FLR RM 200 AREA A-BOTH NOT COOLING-SBE SNERLING 416- 6060 KLR | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | UNIT NOT HEATING IN RM-101 . PLANT MGR-SNERLING/416- 6060 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | Unit Ventilator is NOT HEATING in Room 101 per Ms. Snerlling, Plant Mgr. 416.2373 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Kingsbury MS (2373) 2A | PLEASE, paint area where wooden cabinets have been removed/very unsightly! | 8/2/13 | Kitchen | behind serving lines | Painting |
| Kingsbury MS (2373) 2A | paint lines on football field | 7/30/13 | | | Painting |
| Kingsbury MS (2373) 2A | GRAFFITI B/G RR'S 1ST & 2ND FLRS ON WALLS, STALLS, & DOORS-PLANT MGR SNERLING 416-6060 KLR | 1/6/14 | | | Painting |
| Kingsbury MS (2373) 2A | per ms snerling 416-6060 2nd floor boys and girls restrooms in the stalls gang graffiti | 2/7/14 | | | Painting |
| Kingsbury MS (2373) 2A | GRAFFITI 2ND FLR G RR STALL BY WINDOW ON STALL WALLS- PLANT MGR SNERLING 416- 6060 KLR | 3/19/14 | | | Painting |

| | | | | | |
|---------------------------|--|----------|------------------------|---------------------------------|----------|
| Kingsbury MS (2373) 2A | GRAFFITI B/G RR 1ST FLR ON STALL WALLS & WOODEN DOOR-PLANT MGR SNERLING 416-6060 KLR | 4/22/14 | | | Painting |
| Kingsbury MS (2373) 2A | GANG GRAFFITI OUTSIDE ON BRICK WALL FROM ROTC BLDG TO CAFE-PLANT MGR SNERLING 416-6060 KLR | 9/5/13 | | | Painting |
| Kingsbury MS (2373) 2A | paint lines on football field | 9/6/13 | | | Painting |
| Kingsbury MS (2373) 2A | The paint crumbled & flaked off on front RT column of main entrance/**Parents complaining of unsightliness** ** PLEASE, REPAINT** | 10/10/13 | Administration Area | Per Princ/Mr Harris | Painting |
| Kingsbury MS (2373) 2A | graffiti in boys restroom 1st floor per Ms. Snerling 416-6040 | 11/5/13 | | | Painting |
| Kingsbury MS (2373) 2A | FLR DRAIN IS BACKING UP IN KITCHEN PLANT MGR- SNERLING/416.6060 | 5/12/14 | | | Plumbing |
| Kingsbury MS (2373) 2A | COMMODE SPECIAL NEEDS RM 106-CONSTANTLY FLUSHING-PLANT MGR SNERLING 416-6040 KLR | 5/20/14 | | | Plumbing |
| Kingsbury MS (2373) 2A | water leaking from around bottom of 1st burner of table | 12/9/13 | Kitchen | 1st steam table near kitchen | Plumbing |

| | | | | | |
|---------------------------|--|----------|--------------------|------------------------------|----------|
| Kingsbury MS (2373) 2A | Last urinal clog - up water over flowing. | 12/11/13 | 2nd Floor | Boys Restroom | Plumbing |
| Kingsbury MS (2373) 2A | valve stem broken/won't flush | 1/6/14 | Restroom (Boys) | urinal/stall @ window | Plumbing |
| Kingsbury MS (2373) 2A | URINAL 1ST FLR B RR-LEAKING AROUND SEAL-PLANT MGR SNERLING 416-6060 KLR | 1/8/14 | | | Plumbing |
| Kingsbury MS (2373) 2A | Two (2) Toilets in the BOY'S RR DOWNSTAIRS and UPSTAIRS are STOPPED UP per Ms. Snerling, Plant Mgr. 416.6040 | 1/15/14 | | | Plumbing |
| Kingsbury MS (2373) 2A | URGENT, PLEASE!! water is leaking a constant flow from base or behind toilet wetting supplies & large area of floor causing a slippage/safety concern for Team--also floor drain stopped up in middle of floor | 2/25/14 | Custodial | boiler | Plumbing |
| Kingsbury MS (2373) 2A | diaphragm going out/sometimes it won't stop flushing for couple of hours at a time | 3/19/14 | Restroom (Boys) | 2nd floor | Plumbing |
| Kingsbury MS (2373) 2A | u-pipe has hole in it leaking across floor **safety concern** | 4/9/14 | Hallway/Corridor | between restrms on main hall | Plumbing |
| Kingsbury MS (2373) 2A | Unstop area drains on backside of school. | 4/15/14 | | | Plumbing |

| | | | | | |
|---------------------------|--|---------|---------------------|----------------|----------|
| Kingsbury MS (2373) 2A | TOILET IS OVER FLOWING IN B/RR ON 2ND FLR PLANT MGR- SNERLING/416.6060 | 4/15/14 | | | Plumbing |
| Kingsbury MS (2373) 2A | Replace broken toilet seat **URGENT PLEASE!!** | 4/30/14 | 1st Floor | T. Lounge | Plumbing |
| Kingsbury MS (2373) 2A | Sink faucet constantly runing water. | 5/1/14 | 2nd Floor | rest room boys | Plumbing |
| Kingsbury MS (2373) 2A | Hallway hand wash sink faucet is leaking. | 8/5/13 | 1st Floor | Main hallway | Plumbing |
| Kingsbury MS (2373) 2A | Need another toilet seat. | 8/5/13 | 2nd Floor | Girls restroom | Plumbing |
| Kingsbury MS (2373) 2A | In the kitchen the pilot light needs to be lit for the steam table per Ms, Snerling 416-2373 | 8/6/13 | | | Plumbing |
| Kingsbury MS (2373) 2A | replace toilet seat | 8/6/13 | Restroom (Girls) | 2nd floor | Plumbing |
| Kingsbury MS (2373) 2A | COMMODE B RR MAIN HALL-(2) OVERFLOWING AND THE OTHER ONE NOT IN SERVICE PER SBE-SBE SNERLING 416- 6040 KLR | 8/7/13 | | | Plumbing |

| | | | | | | |
|---------------------------|--|---------|---------------------|--------------------------------------|--|----------|
| Kingsbury MS (2373) 2A | WATER FOUNTAIN 2ND FLR- COOLING SECTION MALFUNCTIONING, IT'S SMOKING & SBE DOES NOT KNOW HOW TO CUT IT OFF- SBE SNERLING 416-6040 KLR | 8/7/13 | | | | Plumbing |
| Kingsbury MS (2373) 2A | UV IS LEAKING IN RM-206,208 (032,033) PLANT MGR- SNERLING/416.6100 | 8/12/13 | | | | Plumbing |
| Kingsbury MS (2373) 2A | Toilet not flushing. | 8/15/13 | 2nd Floor | Mrs. Johnson (family Specialist) | | Plumbing |
| Kingsbury MS (2373) 2A | handle broken off/water running fom area & it can't be flushed any more--URGENT/PLEASE!!! | 8/16/13 | 2nd Floor | Coach Taylor's office | | Plumbing |
| Kingsbury MS (2373) 2A | comode leaking around neck/base of chrome pipe ***constant flow/safety concern*** | 8/19/13 | Restroom (Boys) | 2nd Floor | | Plumbing |
| Kingsbury MS (2373) 2A | (3rd on left) stopped up & 1 urinal on 2nd floor | 8/22/13 | Restroom (Girls) | 1st/2nd floor | | Plumbing |
| Kingsbury MS (2373) 2A | UV RM 202 DRAIN STOPPED UP & ITS' LEAKING-PLANT MGR SNERLING 416-6060 KLR | 8/29/13 | | | | Plumbing |
| Kingsbury MS (2373) 2A | Toilet seat need replace. | 8/30/13 | 2nd Floor | Boys restroom | | Plumbing |

| | | | | | |
|---------------------------|---|----------|--------------------|---------------|----------|
| Kingsbury MS (2373) 2A | 3rd & 4th stall from window stopped up | 9/3/13 | Restroom (Boys) | 1st floor | Plumbing |
| Kingsbury MS (2373) 2A | 2-AHU ARE LEAKING WATER IN CAFE. PLANT MGR- SNERLING/416.6060 | 9/10/13 | | | Plumbing |
| Kingsbury MS (2373) 2A | Toilet need replace, toilet leaking. | 9/18/13 | Classroom | Boys restroom | Plumbing |
| Kingsbury MS (2373) 2A | toilet seat broken , need replace. | 9/18/13 | Restroom (Boys) | restroom | Plumbing |
| Kingsbury MS (2373) 2A | urinal is leaking from bottom. | 9/18/13 | Restroom (Boys) | restroom | Plumbing |
| Kingsbury MS (2373) 2A | UNIT IS LEAKING WATER IN RM- 203 GOING INTO RM-101. PLANT MGR- SNERLING/416.6060 | 9/24/13 | | | Plumbing |
| Kingsbury MS (2373) 2A | UV IS FLOODING IN RM-212 PLANT MGR- SNERLING/416.6060 | 10/1/13 | | | Plumbing |
| Kingsbury MS (2373) 2A | Water fountain in the gym is not working. | 10/17/13 | | | Plumbing |

| | | | | | |
|---------------------------|--|----------|---------------------|--------------------------|----------|
| Kingsbury MS (2373) 2A | TOILET BASE IS CRACK & LEAKING WATER B/RR 2ND FLR, CANT CONTROL. PLANT MGR-SNERLING/416.6000 | 10/17/13 | | | Plumbing |
| Kingsbury MS (2373) 2A | 3rd stall from door is stopped up | 10/17/13 | Restroom (Boys) | 1st FL/main hall | Plumbing |
| Kingsbury MS (2373) 2A | stopped up | 10/17/13 | Restroom (Girls) | 2dn FL/stall near window | Plumbing |
| Kingsbury MS (2373) 2A | drain is needed to perform thorough cleaning/water bags up in floor on top drain | 10/24/13 | Restroom (Girls) | floor drain | Plumbing |
| Kingsbury MS (2373) 2A | ROOF LEAKING CAFE-PER SBE, HALF OF THE CAFE IS FLOODED-WATER IS FLOWING DOWN-PLANT MGR SNERLING 416-6040 KLR This is a HVAC unit leaking | 10/31/13 | | | Plumbing |
| Kingsbury MS (2373) 2A | 2nd stall/flush valve release water from neck each flush **safety concern/slippage** | 11/8/13 | Restroom (Boys) | 1st floor | Plumbing |
| Kingsbury MS (2373) 2A | leaking water from back of flushing big pipe. **safety/slippage concern** lots of water released on ceramic tiles | 11/13/13 | Administration Area | T. Lounge | Plumbing |
| Kingsbury MS (2373) 2A | cracked flush valve/pipe water leaking @ constant flow **safety concern** | 11/14/13 | Administration Area | T. lounge restrm | Plumbing |

| | | | | | |
|---------------------------|--|----------|------------|--------------------------|----------|
| Kingsbury MS (2373) 2A | u-pipe leaking under sink/slip/safety concern | 12/9/13 | Kitchen | desert sink near closet | Plumbing |
| Kingsbury MS (2373) 2A | Roof in leaking inside room 206 , located in front of classroom near teacher desk. | 12/10/13 | 2nd Floor | Rm. 206 | Roof |
| Kingsbury MS (2373) 2A | roof leaking in middle in classrm | 12/12/13 | Classroom | Rm#206 | Roof |
| Kingsbury MS (2373) 2A | raining near window in 108 & to the LF right @ base of ramp in cafeteria | 8/5/13 | Classroom | Rms#108 & Cafeteria | Roof |
| Kingsbury MS (2373) 2A | ceiling tiles wet and falling , water leak in several area. | 8/8/13 | Cafeteria | Cafeteria | Roof |
| Kingsbury MS (2373) 2A | roof leaking @ a constant flow | 8/19/13 | Cafetorium | LF side @ bottom of ramp | Roof |
| Kingsbury MS (2373) 2A | raining in classrms | 11/1/13 | Classroom | Rm #s 204, 206, & 208 | Roof |
| Kingsbury MS (2373) 2A | Roof leak in several location in Cafeterial , Please repair. | 11/22/13 | 1st Floor | Cafeteria | Roof |

| | | | | | |
|---------------------------|---|---------|------------------|------------------|-------------|
| Kingsbury MS (2373) 2A | left of ramp, front of serving line, & right side near last set of exit/entrance doors. **URGENT, PLEASE!** safety concern | 12/9/13 | Cafetorium | different areas | Roof |
| Kingsbury MS (2373) 2A | 4 places in lobby/**through light fixtures/ on carpet area near front steps of stage | 12/9/13 | Auditorium | 2 places | Roof |
| Kingsbury MS (2373) 2A | roof leaking/ceiling tiles falling out/have changed ceiling tiles several times | 12/9/13 | Classroom | rm#276 | Roof |
| Kingsbury MS (2373) 2A | metal gutter torn down back wall/gutter is beside wall | 1/13/14 | 1st Floor | Amory | Sheet Metal |
| Kingsbury MS (2373) 2A | Lockers in need of repair for use of students to store their personal items **URGENT, PLEASE!** | 8/28/13 | Hallway/Corridor | Per AP/Ms. Young | Sheet Metal |
| Kingsbury MS (2373) 2A | the following lockers needed to be repaired: K18, K31, & K35 | 9/5/13 | Hallway/Corridor | 2nd floor | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | | |
|----------------|----------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| | Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| ster MS (2425) | | 3 | 1 | 35 | 54 | 57 | 3 | 36 | 5 | 3 | 197 |
| Grand Total | | 3 | 1 | 35 | 54 | 57 | 3 | 36 | 5 | 3 | 197 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|---------------------|---|---------------|------------------|-------------------------|-----------|
| Lester MS (2425) 2A | spray asbestos ceiling | 7/24/13 | Classroom | rm. 328 | Asbestos |
| Lester MS (2425) 2A | Please allow team to come out and restore Lester Middle School's gym floor. floor is in poor condition. | 10/22/13 | Gym | gym floor | Asbestos |
| Lester MS (2425) 2A | Insulate new piping on chiller(will be in contact when this can happen, will need asap) thanks | 6/5/14 | | | Asbestos |
| Lester MS (2425) 2A | Please allow tech to come out and install computer port in rm#225-A.. Hud housing and phone drop is in place but no port for computer line. | 10/16/13 | | rm#225-A inside library | Cabling |
| Lester MS (2425) 2A | Please allow sheet metalist to come out and weld in place the cover that was remove doing chiller replacement. Meatl cover shileds student from rain when walking across walk way to cafeteria. | 6/10/14 | | | Carpentry |
| Lester MS (2425) 2A | Set up a fence around the chiller. | 5/19/14 | | | Carpentry |
| Lester MS (2425) 2A | GYM DOOR CLOSER, CAN'T SECURE PLANT MGR- HAMER/650.9273 | 5/14/14 | | | Carpentry |

| | | | | | |
|---------------------|---|---------|-----------|--------------------------------|-----------|
| Lester MS (2425) 2A | WINDOW WON'T CLOSE IN RM-320 PLANT MGR- HAMER/650.9273 | 4/28/14 | | | Carpentry |
| Lester MS (2425) 2A | Please allow carpenters to come out and repair door closer to door in cafeteria. South West end across from main office in the cafeteria. | 2/26/14 | | cafeteria | Carpentry |
| Lester MS (2425) 2A | Please allow carpeters to come out and repair window frame housing. Housing gives when trying to close window. Window is slightly open. | 3/6/14 | | RM# 311 | Carpentry |
| Lester MS (2425) 2A | Please allow carpenter to come out and repair panel that came detached from front face of stage. Panel located on stage wall. | 4/15/14 | | cafetorium front stage | Carpentry |
| Lester MS (2425) 2A | Please allow carpenters to come out and re seal cove base on 3rd.fl. annex. Cove base peeling off. | 4/23/14 | | 3rd. fl. annex | Carpentry |
| Lester MS (2425) 2A | please allow a carpenter to come out and repair door knob housing. RM#331 | 4/24/14 | Classroom | rm3 331 annex | Carpentry |
| Lester MS (2425) 2A | Request to remove fence around the chiller. | 4/25/14 | | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and repair stall door in girls restroom on 2-A. Stall door is of the hendges. | 1/15/14 | | Girls restroom 2nd. fl. on 2-A | Carpentry |

| | | | | | |
|---------------------|--|---------|------------------|------------------------------------|-----------|
| Lester MS (2425) 2A | Please allow carpenters to come out and install 2 white board in classroom 315. Classroom not in compliance. | 1/15/14 | Classroom | 315 | Carpentry |
| Lester MS (2425) 2A | WINDOW RM 320 - CAN'T CLOSE IT TO SECURE IT - PM/HAMER 416-5960 | 1/29/14 | | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and replace door to stall in the girls restroom 3rd. fl. last stall. (door is in 3rd. fl. elevator lobby). | 1/29/14 | Restroom (Girls) | 3rd. fl. | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and remove cove base and glue that holds cove base in place on the 3rd. floor. Cove base will not stay attached to wall so we would like to have paint in place of cove base. | 1/29/14 | Hallway/Corridor | 3rd floor | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and replace window glass to gym door located on the north west end of building. Glass is shattered. | 9/12/13 | | Gym area | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and replace wood trim in window where termite has eaten away a section of the wood trim. | 9/16/13 | Cafetorium | first window on the left hand side | Carpentry |
| Lester MS (2425) 2A | please allow a carpenter to come out and repair lock to restroom door in the kitchen area. Lock to door very difficult to turn in lock position. | 1/31/14 | Kitchen | kitchen restroom | Carpentry |
| Lester MS (2425) 2A | Please allow carpenters to come out and replace door to stall in boys restroom on 3A across from RN#325. Stall door is hard plastic and cracked beyond repair | 2/12/14 | Restroom (Boys) | 3rd. fl. across from room 325 | Carpentry |

| | | | | | |
|---------------------|--|---------|---------------------|-------------------------|-----------|
| Lester MS (2425) 2A | WINDOW LEAK IN CONFERENCE RM MAIN OFFICE. PLANT MGR- HAMER/650.9273 | 2/20/14 | | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and repair panic ware to main entry door. Panic ware stick causing latch not to lock in place. | 7/3/13 | | Main entry door | Carpentry |
| Lester MS (2425) 2A | Pleas allow a carpenter to come out and repair main entry door panic ware. Panic bar stick after exiting, causing latches not to connect. | 7/8/13 | | Mani Entry | Carpentry |
| Lester MS (2425) 2A | please allow a carpenter to come out and place a mwta strip about 5 inches long and 3 inches wide on door frame to cover latch to door. Gap between door and frame allow a person to enter room using any flat object to open door | 7/8/13 | | room 320 | Carpentry |
| Lester MS (2425) 2A | The door in this area needs to be repaired or replaced. There has someone kicking and using tools to try and access the building. This needs to be corrected asap!!!! | 7/15/13 | Cafeteria | Outside Door to Kitchen | Carpentry |
| Lester MS (2425) 2A | Repair ceiling towels in principle office and cafeteria. | 7/23/13 | | | Carpentry |
| Lester MS (2425) 2A | Ceiling towel falling down. | 7/24/13 | Cafeteria | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and replace cove base and floor tile in principal restroom. | 7/30/13 | Administration Area | principal' restroom | Carpentry |

| | | | | | | |
|---------------------|---|----------|------------------|-----------------------|--|-----------|
| Lester MS (2425) 2A | 2nd floor boys restroom entry door is hanging from hinges about to fall it is across from room 217 per Mr. Hamer 416-6569 | 8/14/13 | | | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and replace cove base in hallway 3A ten ft. from elevator. | 8/15/13 | | | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and replace the cove base on hallway 3A. | 8/23/13 | Hallway/Corridor | on fl. 3A shotr hall | | Carpentry |
| Lester MS (2425) 2A | Please allow carpenter to come out and remove fencing around garbage dumpster. Fence is badly damaged and difficult for BFI to pick up garbage. | 8/23/13 | Grounds | dumpster area | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and repair ceiling grid in boy restroom in gym. Grid has two brackets missing causing ceiling tile to keep falling out of place. | 10/1/13 | Auxiliary Gym | Boy Restroom | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and repair classroom door, door crews are startin to back out of ports causing door not line up with framing when closing door. Computer lab 1st.fl. | 10/22/13 | | computer lab 1st. fl. | | Carpentry |
| Lester MS (2425) 2A | Please allow a carpenter to come out and adjust classroom door to the computer lab. Screws keep backing out of door's ports | 11/5/13 | Classroom | Computer lab 1st.fl | | Carpentry |
| Lester MS (2425) 2A | Please allow carpenters to come out and replace cove base in these classrooms. 222/311/313/330 and the hall way as well on the 3d.fl. south east hall. | 2/25/14 | | Rm#222/311/313and 330 | | Carpentry |

| | | | | | |
|---------------------|---|---------|-----------|-------------------------------------|------------|
| Lester MS (2425) 2A | Rewire electrical wiring on chiller. | 5/27/14 | | | Electrical |
| Lester MS (2425) 2A | Please allow electricians to come out and repair fan motor to fan in gym. Fan motor jumps around in cage when in use. | 6/3/14 | | Gym | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast to 2 litght fixture. | 5/14/14 | Cafeteria | cafeteria | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and repair 3 ballast in room 315 | 4/28/14 | Classroom | 315 | Electrical |
| Lester MS (2425) 2A | FIRE ALARM IS IN TROUBLE PLANT MGR-HAMER/650.9273 | 3/7/14 | | | Electrical |
| Lester MS (2425) 2A | FIRE ALARM IS SHOWING TROUBLE IN MAIN OFFICE PLANT MGR-HAMMER/650.9273 | 4/1/14 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballasts in the library and 2nd. fl. elevator lobby. | 4/1/14 | | Library and 2nd. fl. elevator lobby | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and repair large exhaust fan in gym. Fan want run just hammmms. | 4/3/14 | | Gym area | Electrical |

| | | | | | |
|---------------------|--|---------|--|---|------------|
| Lester MS (2425) 2A | Please allow an electrician to come out and replace exit sign in gym on the east wall. exit sign damaged beyond repair. | 4/23/14 | | | Electrical |
| Lester MS (2425) 2A | BREAKER ANNEX BOILER RM-HAS TRIPPED AND WON'T RESET-KNOCKED THE POWER OUT TO A/C IN RMS 331 & 223-PLANT MGR HAMER 416-5960 KLR | 4/24/14 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast to light fixture in rm# 329 and 331 | 4/24/14 | | RM# 329 and 331 | Electrical |
| Lester MS (2425) 2A | Please allow a carpenter to come out and secure electrical poles in room 329. Poles move from side to side | 4/24/14 | | RM# 329 | Electrical |
| Lester MS (2425) 2A | LARGE EXHAUST FAN GYM CEILING-MOTOR HAS GONE OUT-PLANT MGR HAMER 416-5960 KLR | 4/25/14 | | | Electrical |
| Lester MS (2425) 2A | Request chiller be replaced with the chiller from Lanier. | 4/25/14 | | | Electrical |
| Lester MS (2425) 2A | EXPOSE WIRES IN B/RR 3RD FLR WEST PLANT MGR-HAMER/650.9273 | 1/15/14 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace two ballast in the boys restroom on the 1st fl. across from band room. (Restroom is dark) | 1/16/14 | | Boys restroom across from the Band room | Electrical |

| | | | | | |
|---------------------|--|---------|-------------|---------------------------|------------|
| Lester MS (2425) 2A | Please allow an electrician to come out and repair door magnet that keep door held open. High traffic area of the school. | 1/16/14 | | | Electrical |
| Lester MS (2425) 2A | per Mr. Hamer 416-5960 room 325 in annex outlets on wall are not working (this is where guidance counselor's computer is plugged in) | 1/17/14 | | | Electrical |
| Lester MS (2425) 2A | GRAFITTI - 3RD B RR - ON STALLS - GANG RELATED PM/HAMER 416-6175 | 1/21/14 | | | Electrical |
| Lester MS (2425) 2A | RECEPTACLE IS RINGING IN RM-330, CANT SHUT NOISE OFF PLANT MGR- HAMER/650.9273 | 1/22/14 | | | Electrical |
| Lester MS (2425) 2A | per Mr. Hamer 416-5960 room 313 is not coming on at all | 1/29/14 | | | Electrical |
| Lester MS (2425) 2A | CONDENSOR UNIT - EAST SIDE OF GYM - NOT COMING ON - PM/HAMER 416-5960 | 9/12/13 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace bulbs to outside flood light. | 9/16/13 | Parking Lot | rear of cafeteria outside | Electrical |
| Lester MS (2425) 2A | UNIT VENT - RM 328 - NOT COMING ON - PM/HAMER 650-9273 | 2/21/14 | | | Electrical |

| | | | | | |
|---------------------|---|---------|--|-------------------------------|------------|
| Lester MS (2425) 2A | UNIT IN RM 320 & 316 ARE NOT COMING ON. SBE HAMER 416-5960 | 7/8/13 | | | Electrical |
| Lester MS (2425) 2A | UNIT VENT RM 313 FAN WON'T ROTATING - PM/HAMER 416-5960 | 7/30/13 | | | Electrical |
| Lester MS (2425) 2A | A/C UNIT RM 314-NOT COMING ON-SBE HAMER 416-5960 | 7/31/13 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and repair exit and flood lights. Exit signs and emergency light will not alluminate when tested. 1st. 2nd and 3rd fl. stairwell/ next to rm#224/ next to 324-A elevator lobby/ head room and | 8/1/13 | | throuh out building | Electrical |
| Lester MS (2425) 2A | Breaker keeps tripping, which causes the vent hood, stove, and dishwasher to have NO POWER in cafeteria per Thomas Hamer, Plant Mgr. at 901.416.5960. | 8/6/13 | | | Electrical |
| Lester MS (2425) 2A | PUMP#3 IS IN ALARM(108). PLANT MGR-HAMER/416.5969 | 8/12/13 | | | Electrical |
| Lester MS (2425) 2A | in serving line the milk box is shocking people per Mr. Hamer 416-6960 | 8/12/13 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast in these classrooms. RM# 310/314/316 adn 320 | 8/13/13 | | classroom#310/314/316 and 320 | Electrical |

| | | | | | |
|---------------------|--|---------|-------------|-------------------------------------|------------|
| Lester MS (2425) 2A | Please allow an electrician to come out and replace exit and emergency lights in gym. Exit and emergency lights are destroyed. | 8/15/13 | Gym | gym east exit | Electrical |
| Lester MS (2425) 2A | UNIT NOT COMING ON IN GYM EAST-SIDE PLANT MGR-HAMER/416.6960 | 8/27/13 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast in room 328 and on 3A hallway. in front of elevator lobby and in front of rm# 329 | 8/27/13 | | rm#328 and 3A hallway | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace bulbs to outside flood lights on building. southeast corner of Lester and west side of gym above outside air unit. | 8/28/13 | Parking Lot | south east and west end of building | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and reset bell system for lester Elem. | 8/28/13 | | main offic area | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and repair light system in elevator (no lights in elevator) female prong burned out and non of the bulbs light up. | 9/19/13 | | elevator lobby | Electrical |
| Lester MS (2425) 2A | Request L.E.D. light be installed above the cafe back door. (Up high as possible) | 10/2/13 | Cafeteria | | Electrical |
| Lester MS (2425) 2A | UV NOT COMING ON IN RM-320 PLANT MGR-HAMER/650.9273 | 10/2/13 | | | Electrical |

| | | | | | |
|---------------------|--|----------|------------|---|------------|
| Lester MS (2425) 2A | Please allow an electrician to come out and replase burn out bulbs in gym. (Lift needed) | 10/3/13 | Gym | gym | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast in these areas. (library 3 abllast needed0 and RM# 109 2 ballast needed). | 10/8/13 | | RM#109 and library | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast in these classrooms. RM#328/329/330/331 and in the hallway of the on the 3rd fl. (Same Ghallway) | 10/9/13 | | RM# 329/328/331/330 also in the hallway | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast in the gym=north foyer/G102/G103/Classroom 316/318 and 319 | 10/18/13 | | RM#G-103/Gym's north foyer/G102/RM#316/ 318/319 | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace blbs to outside lights. North east end of building outside of cafeteria. | 10/22/13 | | outside cafe' northeast wall | Electrical |
| Lester MS (2425) 2A | Deliver lift to Kingsbury Hi | 11/20/13 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and replace ballast to 3 diffrent fixturs in the cafeteria. | 11/22/13 | Cafetorium | cafetorium | Electrical |
| Lester MS (2425) 2A | G103 boys locker room in gym heat is not working not coming on per Mr. Hamer 416-6160 | 11/26/13 | | | Electrical |

| | | | | | |
|---------------------|--|----------|--|-------------------------------------|---------------------------------------|
| Lester MS (2425) 2A | rooms 101 and 103 in gym locker room unit keeps tripping no heat per mr hamer 416-6160 | 12/9/13 | | | Electrical |
| Lester MS (2425) 2A | Outlet is BURNED OUT in the Guidance Counselor's office, Room 223 per Mr. Hamer, Plant Mgr. 650.9273 | 12/11/13 | | | Electrical |
| Lester MS (2425) 2A | per Mr. Hamer 650-9273 UV in room 319 is not coming on | 12/16/13 | | | Electrical |
| Lester MS (2425) 2A | Please allow an electrician to come out and remove an electrical outlet that has exposed wires showing. This outlet is no longer in use and poses a serious safety infaction | 12/18/13 | | Practice rm 124 inside of band room | Electrical |
| Lester MS (2425) 2A | BREAKER KEEPS TRIPPING POWER TO RMS 329 & 331- KNOCKING THE HEAT OUT ALSO-PLANT MGR HAMER 416-5960 KLR | 1/6/14 | | | Electrical |
| Lester MS (2425) 2A | NO POWER GOING TO HEAT IN RM 316 PER SBE-PLANT MGR HAMER 416-5960 KLR | 1/6/14 | | | Electrical |
| Lester MS (2425) 2A | UNITS NOT COOLING IN RM- 218,328 PLANT MGR- HAMER/650.9273 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER -MAIN BLDG - NOT COMING ON - PM/HAMER 416-5960 | 5/5/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|---------|--|--|---------------------------------------|
| Lester MS (2425) 2A | CHILLER NOT COMING ON MAIN BLDG PLANT MGR- HAMER/650.9273 | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UNIT NOT COOLING IN RM- 318,320 PLANT MGR- MALORIE/4165969 | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER ANNEX BLDG-IN ALARM-PLANT MGR HAMER 416-5960 KLR | 6/12/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | scrap out old Carrier air cooled chiller, spoke with James Baily- os | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER ANNEX BLDG-NOT COMING ON-PLANT MGR HAMER 416-5960 KLR | 6/5/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | OUTSIDE A/C UNIT - GYM RM 101 - KEEP TRIPPING THE BREAKER -PM/HAMER 416-5960 | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | BOILER is NOT COMING ON per Mr. Hamer, Plant Mgr. 416.5960 | 3/4/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | PUMP is LEAKING in the BOILER ROOM per Mr. Hamer, Plant Mgr. 416.5960 | 3/4/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|---------|--|-------------------|---------------------------------------|
| Lester MS (2425) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Please allow a team to come out and change the filters to unit ventilators here at lester Middle School. (Filters are pass due date). | 4/15/14 | | thru out building | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Please allow a team to come out and replace filters to air handler and unit ventilators here at East High School. | 4/15/14 | | thru out building | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Install chiller | 4/25/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UNITS NOT COMING ON IN RM-313,316 PLANT MGR-HAMER/650.9273 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | BOILER IS IN ALARM IN ANNEX. PLANT MGR-HAMER/650.9273 | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | per mr hamer 416-5960 boiler is down in annex building | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | per mr hamer 416-5960 room 318 UV not heating | 1/23/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|---------|--|--|---------------------------------------|
| Lester MS (2425) 2A | ONE HEATING UNIT RM 313- NOT HEATING-PLANT MGR HAMER 416-5960 KLR | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | The AC in the cafe and food service area does not seem to be working properly. It is very hot. Thank you. | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER ANNEX-IS IN ALARM-PLANT MGR HAMER 416-5960 KLR | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | A/C ENTIRE 3RD FLR OVER (10) RMS PER SBE & RM 120- ALL NOT COOLING-PLANT MGR HAMER 416-5960 KLR | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER NOT COMING ON PLANT MGR- HAMER/650.9273 | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - Oil Lube & Belt- Lester Elementary - Refer to PM schedule details. | 2/15/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - AirCompressor 071 Add blr rm Lester Elm - Refer to PM schedule details. | 2/17/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - AirCompressor#114 MnBld Blr rmLester Elm - Refer to PM schedule details. | 2/17/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|---------|--|--|---------------------------------------|
| Lester MS (2425) 2A | UNIT IN THE SBE IS NOT COOLING,. SBE HAMER 416-5960 | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UNIT VENT IN RM 310 IS NOT COOLING. SBE HAMER 416-5951 | 7/12/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - Oil Lube & Belt-Lester Elementary - Refer to PM schedule details. | 7/13/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UNIT VENT RM 330 NOT COOLING - PM/HAMER 416-5960 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | A/C UNIT SBE'S OFC-NOT COOLING-SBE HAMER 416-5960 KLR | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | 2-RTU NOT COOLING IN KITCHEN. PLANT MGR-HAMER/650.0973 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - AirCompressor 071 Add blr rm Lester Elm - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - AirCompressor#114 MnBld Blr rmLester Elm - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|----------|--|--|--|
| Lester MS (2425) 2A | Monthly - AirCompressor #157 bl r m Lester Elm - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UV 3RD FLR RM 310, 3RD FLR RM 318 & 3RD FLR RM 320-ALL NOT COOLING-SBE HAMER 416-5960 KLR | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER IS IN ALARM PLANT MGR- HAMER/416.6660 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | A/C IN RMS 329-NOT COOLING-PLANT MGR HAMER 416-5960 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | 2-CHILLERS NOT COMING ON PLANT MGR- HAMER/650.9273 | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UNIT VENT - RM 320 - COMPUTER BOARD NEEDS TO BE REPROGRAM - UNIT IS NOT COMING ON - PM/HAMER 416-5960 | 10/3/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | purchase chemical pump -os | 10/8/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | CHILLER ANNEX BLDG-NOT COMING ON-PLANT MGR HAMER 416-5960 KLR | 10/30/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|----------|--|--|---------------------------------------|
| Lester MS (2425) 2A | PUMP NOT CIRCULATING CAUSING UNIT NOT HEATING IN CAFE. PLANT MGR- HAMER/650.9273 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | no heat in main building (everything running) but cold air per Mr. hamer 416-5960 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | BOILERS - ANNEX SIDE - NOT COMING ON - PM/HAMMER 416-5960 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UV NOT HEATING IN PRIN OFFICE PLANT MGR- HAMER/650.9273 | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | BOILER is NOT COMING ON in the ANNEX BUILDING per Mr. Hamer, Plant Mgr. 416.3660 | 1/3/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | HEAT RM 318-NOT HEATING- PLANT MGR HAMER 416-5960 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | UV NOT HEATING IN PRIN OFFICE PLANT MGR- HAMER/650.9273 | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - AirCompressor #157 blr rm Lester Elm - Refer to PM schedule details. | 2/17/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|--|---------|--|--|---------------------------------------|
| Lester MS (2425) 2A | Monthly - Filter-Lester Elementary - Refer to PM schedule details. | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Daily - Lester Middle Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Yearly - Cooling Towers(STRAINERS)-Lester Elem - Refer to PM schedule details. | 3/16/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Yearly - Boiler 112 - Lester El-Main Bldg Blr Rm - Refer to PM schedule details. | 3/22/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - Filter-Lester Elementary - Refer to PM schedule details. | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Monthly - Filter-Lester Elementary - Refer to PM schedule details. | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | Yearly - Oil Samples-Lester Elementary - Refer to PM schedule details. | 9/6/13 | | | Heating/Ventilation /Air Conditioning |
| Lester MS (2425) 2A | GRAFFITI IN B/RR 3RD FLR STALL, WALLS PLANT MGR-HAMER/650.9273 | 3/31/14 | | | Painting |

| | | | | | | |
|---------------------|--|----------|------------------|------------------------------------|--|----------|
| Lester MS (2425) 2A | paint doors to cafe | 9/11/13 | | | | Painting |
| Lester MS (2425) 2A | GRAFFITI IN B/RR 2ND LFR. PLANT MGR- HAMER/650.9273 | 11/12/13 | | | | Painting |
| Lester MS (2425) 2A | Water pressure very low on mop sink faucet. | 6/19/14 | Custodial Closet | 3rd floor 3A | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and clear floor drain in boys restroom. Gca poured wax water in floor drain. 3rd. fl west down from rm#311. | 6/24/14 | | 3rd. fl west end | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and clear water fountain drain. Plunger want fit over drain to clear line. | 6/24/14 | | 3rd. fl. west across from rm# 311 | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and repair water fountains in the Gym area and next to main office. | 6/24/14 | | Next to main office and in the gym | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and replace damaged seat to toilet in last stall on boys restroom on 3rd. fl. | 6/26/14 | | Boys restroom 3rd fl last stall | | Plumbing |
| Lester MS (2425) 2A | UNIT VENT - MAIN OFC - LEAKING - PM/HAMER 416-5960 | 5/29/14 | | | | Plumbing |

| | | | | | |
|---------------------|--|---------|------------------|--------------------------------|----------|
| Lester MS (2425) 2A | Request installation for pipes on a unit in the main office. The pipe is leaking onto the secretary's desk. | 5/29/14 | | | Plumbing |
| Lester MS (2425) 2A | WATER PIPE SERVING LINE- LEAKING OVER FOOD AREA- PLANT MGR HAMER 416-5930 KLR | 4/29/14 | | | Plumbing |
| Lester MS (2425) 2A | 3-COM SINK IS STOPPED UP IN KITCHEN PLANT MGR- HAMER/650.9273 | 2/27/14 | | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and replace washers to the mop sink and the 3 compartment sink in kitchen area. Faucets are leaking water. | 3/26/14 | Kitchen | kitchen | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and repair water fountains in lesters gym. levers are easily damaged. also spout need adjusting Ask plumber to call plant manager when on site. | 4/1/14 | | gym area | Plumbing |
| Lester MS (2425) 2A | SINK IS HANGING FROM WALL IN B/RR 2ND FLR PLANT MGR- HAMMER/650.9273 | 4/15/14 | | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and repair water fountain's push levers. levers become stuck when pressed in. Also adjust water spouts, need to turn inward more towards drain so water dont spill over sides of fountain | 4/24/14 | Hallway/Corridor | Hall way across from cafeteria | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come repair water fountains in the gym lobby. One fountain need a replacment push and release kit and the other fountain keep getting stuck in the on position. | 1/29/14 | Gym | Gym Lobby | Plumbing |

| | | | | | |
|---------------------|--|---------|------------------|----------------|----------|
| Lester MS (2425) 2A | A/C RM 328 3RD FLR- LEAKING-PLANT MGR HAMER 416-5960 KLR | 9/11/13 | | | Plumbing |
| Lester MS (2425) 2A | allow a plumber to come out and replase washer to compartment sink in kitchen, water leaks from levers that releases water from sink. All three levers are bad. Failed health inspection | 9/16/13 | Kitchen | kitchen area | Plumbing |
| Lester MS (2425) 2A | UNIT VENT - RM 217 - LEAKING DOWN INTO THE CONFERENCE RM - PM/HAMER 650-9273 | 2/21/14 | | | Plumbing |
| Lester MS (2425) 2A | VALVE IS BROKEN TO THE FACUET IN THE CUSTODIAL CLOSET MAIN HALL. SBE HAMER 416- | 7/3/13 | | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and repair toilet seat in boys resroom next to room 202/ boys restroom next to 209 a custodial closet, will not flush away waste. | 7/3/13 | Restroom (Boys) | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and repair flush valve piping to toilet in girls restroom next to room 220. Water leaks from base of piping. | 7/3/13 | Restroom (Girls) | | Plumbing |
| Lester MS (2425) 2A | The toilet in this restroom is leaking water when it is being used or flushed. This needs to be repaired asap, because the toilet is leaving a water trail on the floor. | 7/17/13 | 3rd Floor | Girls Restroom | Plumbing |
| Lester MS (2425) 2A | There is a toilet that will not flush in this area. This needs to be repaired asap. | 7/22/13 | 1st Floor | Restroom | Plumbing |

| | | | | | |
|---------------------|---|---------|---------------------|---|----------|
| Lester MS (2425) 2A | Water leaking in the principle office. | 7/24/13 | Administration Area | | Plumbing |
| Lester MS (2425) 2A | Leak in the principle office. | 7/25/13 | | | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and repair flush valve piping to toilet in boys restroom next to custodial closet 309. piping leaks. | 7/30/13 | Restroom (Boys) | Next to custodial closet 309 | Plumbing |
| Lester MS (2425) 2A | (Please allow a plumber to come out and secure fauct to sink in boys rest room 3rd. fl. west end fauct turn round and round.) 1st. fl. Boys restroom across from main office first toilet piping flush valve piping leak. | 8/15/13 | Restroom (Boys) | 3nd. fl. west end and 1st. fl. across from office | Plumbing |
| Lester MS (2425) 2A | FLOOR DRAIN BACKING UP IN B RR 3RD FLR ACROSS FROM RM 325-SBE HAMER 416-5960 KLR | 8/16/13 | | | Plumbing |
| Lester MS (2425) 2A | A/C IN RMS 328-LEAKING-PLANT MGR HAMER 416-5960 KLR | 8/23/13 | | | Plumbing |
| Lester MS (2425) 2A | Request back flow test. | 9/5/13 | | | Plumbing |
| Lester MS (2425) 2A | DISHWASHER will not DRAIN per Thomas Hamer, Plant Mgr. 416.5960 | 10/4/13 | | | Plumbing |

| | | | | | |
|---------------------|--|----------|-----------|--------------------------------|----------|
| Lester MS (2425) 2A | Please allow a plumber to come out and repair faucet in rm#225-C in the library. (Faucet leaks). | 10/16/13 | Library | rm# 225-C inside library | Plumbing |
| Lester MS (2425) 2A | Please allow a plumber to come out and secure faucet to sink and repair flush valve piping to toilet in boys restroom. (3rd.fl. west end) | 10/30/13 | | boys restroom 3rd.fl. west end | Plumbing |
| Lester MS (2425) 2A | 2-SINKS ARE STOPPED UP IN RM-310 SCIENCE LAB. PLANT MGR-HAMER/650.9273 | 10/30/13 | | | Plumbing |
| Lester MS (2425) 2A | UV MAIN OFC-LEAKING-PLANT MGR HAMER 416-5962 KLR | 11/8/13 | | | Plumbing |
| Lester MS (2425) 2A | 3 compartment sink in kitchen lever is leaking really bad and lever is hard to release per Mr. hamer 416-6560 | 12/3/13 | | | Plumbing |
| Lester MS (2425) 2A | GAS SMELL OUTSIDE OF CAFE. PLANT MGR-HAMER/650.9273 | 12/12/13 | | | Plumbing |
| Lester MS (2425) 2A | Please allow roofers to come out and repair roof leaks in room 328. There are 4 to 5 areas in this room that leaks and has caused the plaster to start peeling off the ceiling. Please follow this work order up with carpenters to come out | 2/21/14 | | rm#328 | Roof |
| Lester MS (2425) 2A | There is a leak in this classroom. This needs to be repaired asap!!! | 7/22/13 | 3rd Floor | #328 | Roof |

| | | | | | |
|---------------------|--|---------|---------------------|----------------------------------|-------------|
| Lester MS (2425) 2A | There is a leak in this area in the principal's office. This needs to be checked and repaired asap. | 7/22/13 | Administration Area | Principal's Office | Roof |
| Lester MS (2425) 2A | There is a leak in this area that needs to be checked out and repaired asap. | 7/22/13 | 3rd Floor | 324 | Roof |
| Lester MS (2425) 2A | Please allow roofer to come out and and repair roof leak on the southwest end of building. leak is causing the southeast stair well to smell and form mold in stair well | 8/7/13 | | south east stair well in library | Roof |
| Lester MS (2425) 2A | LARGE EXHAUST FAN GYM CEILING-HOUSING IS LOOSE AND ABOUT TO FALL- SAFETY ISSUE-PLANT MGR HAMER 416-5960 KLR | 4/24/14 | | | Sheet Metal |
| Lester MS (2425) 2A | Please allow a sheet metalist to come out and repair lockers in room 220. | 1/29/14 | Classroom | room 220 | Sheet Metal |
| Lester MS (2425) 2A | Please allow a sheetmetalist to come out and close a 2ft opening in ceiling. Ceiling is made of metal. Failed health department inspection. | 9/16/13 | Kitchen | serving line | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|------------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Macon-Hall ES (0118) 2 | 2 | 27 | 70 | 162 | 5 | 39 | 10 | 5 | 320 |
| Grand Total | 2 | 27 | 70 | 162 | 5 | 39 | 10 | 5 | 320 |

| Location | Request Description | Submittal Dat | Area | Descript Area | Number | Craft |
|-------------------------|---|---------------|------------------|---------------|--------|-----------|
| Macon-Hall ES (0118) 2A | Need black mold removed from all portables due to humid conditions /portables 610/809/608/607/606/605/604/603 /801/ also 2 others on back lot. Supervisor has already been out to check. | 8/6/13 | Classroom | | | Asbestos |
| Macon-Hall ES (0118) 2A | replace tile | 7/3/13 | Classroom | 208 | | Asbestos |
| Macon-Hall ES (0118) 2A | Need 2-boxes of ceiling tiles (White with insulation backing) to replace damaged tiles. Size:23 3/4 x 47 3/4 | 7/12/13 | 1st Floor | | | Carpentry |
| Macon-Hall ES (0118) 2A | Need under-pinning for portables repaired and some units need it replaced on all portables at Macon Hall Elementary. Bees and wasps and other varmints are making their homes under the Potable Classrooms. | 8/9/13 | | | | Carpentry |
| Macon-Hall ES (0118) 2A | Need protective covers cut out to allow Plant Manager to be able to check EXIT lights. Plastic is covering test buttons. | 2/5/14 | Gym | | | Carpentry |
| Macon-Hall ES (0118) 2A | Need floor tile repaired in classroom 413 yellow hall / Several pieces have come up. | 2/7/14 | Classroom | | | Carpentry |
| Macon-Hall ES (0118) 2A | Need floor tile replaced by Teacher work area heading toward Red hall. Also need floor tile replaced in front of classrooms 301 and 303 and in front of custodial closet next to plant Managers office. | 2/7/14 | Hallway/Corridor | | | Carpentry |

| | | | | | |
|-------------------------|--|---------|------------------|--|-----------|
| Macon-Hall ES (0118) 2A | Need glass pane replaced in door on portable # 617 on right-hand side. Also need glass globe replaced on portable # 618 on Right-hand side. Vandalism | 3/31/14 | Portables | | Carpentry |
| Macon-Hall ES (0118) 2A | URGENT!! Need yellow floor tile replaced in front of water fountains in yellow hallway.Trip hazard | 4/2/14 | 1st Floor | | Carpentry |
| Macon-Hall ES (0118) 2A | Need floor tile replaced in portable # 603 / Tile is broken in several places | 4/22/14 | Portables | | Carpentry |
| Macon-Hall ES (0118) 2A | Urgent!! Need entrance door handle replaced to classroom 113/ Teacher got metal in her hand, handle is splintering. Taped up now. | 5/7/14 | Classroom | | Carpentry |
| Macon-Hall ES (0118) 2A | Need floor tile replaced in Blue hall by boy's restroom and one in hallway.// Need floor tile replaced in front of girl's restroom Red hall // Need floor tile replaced in front of classroom 303 White tile | 5/13/14 | 1st Floor | | Carpentry |
| Macon-Hall ES (0118) 2A | next to portable the deck between portables the foundation has fallen a few inches and continues to drop | 5/14/14 | | | Carpentry |
| Macon-Hall ES (0118) 2A | Need top of Music riser repaired that is upon stage, danger to students. The top step is broken. | 5/14/14 | Cafetorium | | Carpentry |
| Macon-Hall ES (0118) 2A | Need counter-top repaired in Girl's restroom in (BLUE) hall / Sagging down real bad and all the water running on floor. Slip-hazard | 8/27/13 | Restroom (Girls) | | Carpentry |

| | | | | | |
|-------------------------|--|----------|------------------|--|-----------|
| Macon-Hall ES (0118) 2A | Need 48 inch board hung in closet in classroom 310 red hall to hang student's scarf's / Hot glue won't hold weight. | 9/12/13 | Classroom | | Carpentry |
| Macon-Hall ES (0118) 2A | Need framed art work hung outside of office at Macon Hall Elementary School. Will be stored in Art room to be hung. | 9/13/13 | Hallway/Corridor | | Carpentry |
| Macon-Hall ES (0118) 2A | URGENT!! Need Entrance door to back of Blue hallway repaired / Door is Dragging at top, hard to close. Entrance#4 | 9/25/13 | Hallway/Corridor | | Carpentry |
| Macon-Hall ES (0118) 2A | Need map hung in classroom 527 in emerald hall / Need metal sheet screws and clips to hang secure. Drill holes but map hangs off of chalk board. | 10/1/13 | Classroom | | Carpentry |
| Macon-Hall ES (0118) 2A | Need lock and handle repaired to Cafeteria door (first 2 on right) one on right-hand side came loose / Tried to secure but not secure enough. | 10/1/13 | Hallway/Corridor | | Carpentry |
| Macon-Hall ES (0118) 2A | Security reports P199 cannot secure door. | 10/7/13 | | | Carpentry |
| Macon-Hall ES (0118) 2A | Need hangers installed on wall for pull down screen in classroom 215 / Needs large mollies installed with screws to keep from falling. | 10/24/13 | Classroom | | Carpentry |
| Macon-Hall ES (0118) 2A | Need stage risers repaired for the program this Thursday / Chorus needs risers for program. Top step is completely loose on one of the risers. | 11/5/13 | Hallway/Corridor | | Carpentry |

| | | | | | |
|-------------------------|---|----------|------------------|--|------------|
| Macon-Hall ES (0118) 2A | Please assist plumbers with the delivery of the new water heaters for the kitchen. | 11/11/13 | | | Carpentry |
| Macon-Hall ES (0118) 2A | Hazardous areas are not properly rated / Need penetrations sealed in rated walls in the gym in mechanical room. Fire Marshall inspection | 12/5/13 | Hallway/Corridor | | Carpentry |
| Macon-Hall ES (0118) 2A | Need mirror hung back onto wall that has fallen off in the boy's restroom (Blue Hall). | 12/5/13 | Hallway/Corridor | | Carpentry |
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need right-hand side entrance door repaired will not lock on portable #601 . Have to slam door to just to get it to close. PLunger not hitting striker plate. | 1/6/14 | Portables | | Carpentry |
| Macon-Hall ES (0118) 2A | URGENT!!Need steps or platforms build in boys and girl's restrooms for students too small to reach faucets to wash their hands. | 8/19/13 | Restroom (Boys) | | Carpentry |
| Macon-Hall ES (0118) 2A | The classroom doors in the 100,200,300 and 400 hallways do not have automatic closures and are not self closing. Found during Fire Marshall inspection. | 12/5/13 | Hallway/Corridor | | Carpentry |
| Macon-Hall ES (0118) 2A | Repair the art room fan. | 7/30/13 | | | Electrical |
| Macon-Hall ES (0118) 2A | Repair the boys and girls restroom fan. | 7/30/13 | | | Electrical |

| | | | | | |
|-------------------------|--|---------|-----------|--|------------|
| Macon-Hall ES (0118) 2A | URGENT!!Need gym lights repaired in gym can't turn-off lights . Since light switch was installed the other switch's do not work. | 8/1/13 | Gym | | Electrical |
| Macon-Hall ES (0118) 2A | Need Motion Detector repaired in classroom 305/ Have been getting several alarms concerning that detector goes in alarm and 2 seconds later resets. | 7/15/13 | Classroom | | Electrical |
| Macon-Hall ES (0118) 2A | Need motion detector repaired in classroom 412 / Keeps giving off alarm and 2 seconds later resets. Came out to school found nothing causing alarm to occur. | 7/15/13 | Classroom | | Electrical |
| Macon-Hall ES (0118) 2A | During Generator maintenance check: Need transfer switch indicator light repaired. | 7/15/13 | 1st Floor | | Electrical |
| Macon-Hall ES (0118) 2A | URGENT!!!Getting trouble alarm showing problem with #2 battery on key pad / Need replaced | 7/16/13 | 1st Floor | | Electrical |
| Macon-Hall ES (0118) 2A | Please run Test. Level 2 Facilities ETSS annual load test NFPA 110 | 7/16/13 | | | Electrical |
| Macon-Hall ES (0118) 2A | Need keyed light switch installed that was removed in gym to one roll of lights in gym. | 7/23/13 | Gym | | Electrical |
| Macon-Hall ES (0118) 2A | Need exit repaired in library right-hand side going into library | 8/9/13 | Library | | Electrical |

| | | | | | |
|-------------------------|--|---------|------------------|--|------------|
| Macon-Hall ES (0118) 2A | Need Exit light repaired in yellow hallway going into entrance of hallway on other side of Fire Doors. Found during P.M. | 8/9/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need help with the sound system in the cafeteria / Teachers and staff need to be able to use microphone in cafeteria. Send Roger. Benny | 8/9/13 | Classroom | | Electrical |
| Macon-Hall ES (0118) 2A | Need battery replaced in Exit light by double doors by compactor in cafeteria. Exit light # 20 | 2/5/14 | Cafeteria | | Electrical |
| Macon-Hall ES (0118) 2A | Need ballast replaced in florescent light fixture in boy's restroom in Emerald hallway (500 area). Light fixture is marked with note bulbs have been replaced. | 2/6/14 | Restroom (Boys) | | Electrical |
| Macon-Hall ES (0118) 2A | Need office clock repaired in Main Office. See Secretary for clock. Clock is electrical and hooked in wall on simplex system | 2/12/14 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | NO HEAT IN RM 206 - NOT COMING ON PM/GAMBLE 759-4590 | 2/13/14 | | | Electrical |
| Macon-Hall ES (0118) 2A | HEAT RM 526-NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 2/28/14 | | | Electrical |
| Macon-Hall ES (0118) 2A | Need to repair 2 can lights that are out on front entrance foyer. Located on left-hand side of front entrance. | 3/4/14 | Athletic Field | | Electrical |

| | | | | | |
|-------------------------|--|---------|---------------------|--|------------|
| Macon-Hall ES (0118) 2A | Need Alarm system repaired / Mr. Morrison (Assit. Principal) stated that him and the Principal wasn't able to arm system this past Sunday. | 3/25/14 | Administration Area | | Electrical |
| Macon-Hall ES (0118) 2A | Need batteries replaced in Exit lights #23 and #25 in gym / found on P.M.maintenance | 4/2/14 | 1st Floor | | Electrical |
| Macon-Hall ES (0118) 2A | Need battery replaced in Exit light #21 in cafeteria / Need battery replaced in Exit light in green hall #15 / Need Exit repaired in 500 area Emerald hall / Light above B exit doors. Found on P.M. maintenance | 4/2/14 | 1st Floor | | Electrical |
| Macon-Hall ES (0118) 2A | Need Exit light repaired in portable# 604/ inside on left-hand side . / Exit light in portable # 605 inside right-hand side needs repair- Batterys | 4/3/14 | Portables | | Electrical |
| Macon-Hall ES (0118) 2A | Need ballast replaced in light fixture in closet in classroom 401 (Yellow hall) | 4/7/14 | 1st Floor | | Electrical |
| Macon-Hall ES (0118) 2A | URGENT!! Need assistance with intercom the cord is bad from receiver to base. Looked and do not have any at school. | 4/22/14 | Classroom | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 10 ea. of catalog # 10237 fluorescent bulbs for front foyer lights. | 4/24/14 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 20 of 13 watt Cf Quad 3500K 2pin GX23-2 from The Lighting source co. inc. | 4/24/14 | Hallway/Corridor | | Electrical |

| | | | | | |
|-------------------------|--|---------|------------------|--|------------|
| Macon-Hall ES (0118) 2A | Need to order stock # 10257 15 ea. for outside pack lights | 4/24/14 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need EXIT lights repaired / Needs new battery in portable #603 and portable #604. Found on P.M. Maintenance | 5/7/14 | Portables | | Electrical |
| Macon-Hall ES (0118) 2A | LIGHTS HAVE NO POWER IN RM 524 EMERALD HALL. PLANT MGR-GAMBLE/759.4533 | 5/22/14 | | | Electrical |
| Macon-Hall ES (0118) 2A | Portable 609 Will not set. | 5/28/14 | | | Electrical |
| Macon-Hall ES (0118) 2A | Need to repair light switch's in classrooms 524 and 526 / Switch's work sometimes but clicking. | 5/29/14 | Classroom | | Electrical |
| Macon-Hall ES (0118) 2A | URGENT!! Got alarm from fire alarm system:/ Area: Northeast Dining ceiling Duct detector / Alarm silences but starts again. | 6/10/14 | Cafeteria | | Electrical |
| Macon-Hall ES (0118) 2A | Requesting system check on panel and board for false alarms/ Getting too many and contractor's can't secure buildings. | 9/9/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | URGENT!! Need to install a floor receipt cover plate / located in front of the serving line on the floor on right-hand side. See kitchen Supervisor. Student hazard. Found on P.M. | 10/2/13 | Kitchen | | Electrical |

| | | | | | |
|-------------------------|--|----------|------------------|--|------------|
| Macon-Hall ES (0118) 2A | URGENT!! Need lights repaired in portable 608/ Only one side working/ checked breakers and are OK. | 10/2/13 | Portables | | Electrical |
| Macon-Hall ES (0118) 2A | Need 3-lights replaced in gym / don't have size or wattage due to not having any on site. | 10/18/13 | Gym | | Electrical |
| Macon-Hall ES (0118) 2A | Need outside pole lights reset on system to have them come on sooner so that staff and faculty will feel more safe doe to getting darker sooner. System is on a closed system I believe. | 10/20/13 | Athletic Field | | Electrical |
| Macon-Hall ES (0118) 2A | Need 1-case of T-8 bulbs delivered to Macon Hall Elementary / Need for outside canopy lights | 10/23/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | URGENT!! Need light fixture repaired overhead ceiling light outside of back entrance to Cafeteria. Need overhead light repaired for children of Y-care to enter back door of Cafeteria. | 10/23/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need 2 cases of stock #10237 to repair lights in front lobby here at Macon Hall Elementary. Need delivered asap | 10/23/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need 2 cases of Stock # 46807 delivered to Macon Hall Elementary to replace builds in overhead hole fixtures. | 10/23/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need delivered to Macon Hall Elementary 1=case of 10250 and 1-case of 10255 to replace lights. | 10/23/13 | Hallway/Corridor | | Electrical |

| | | | | | |
|-------------------------|---|----------|------------------|--|------------|
| Macon-Hall ES (0118) 2A | Need delivered to Macon Hall Elementary 30 Of stock # 10365 to replace bulbs. | 10/23/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need delivered to Macon Hall Elementary 6 ea of Stock #s 10460 /10531 and 10533 for replacement of bulbs. | 10/23/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 10 ea. of stock# 10237 to replace 4 pin fluorescent twin tube lights up front before Open House. Ordered 2 boxes and got 2-bulbs. | 11/1/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need stabilizer clips for fluorescent bulbs to hang in front lobby / Need electrician to look at clips to order. | 11/1/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Please unwire old water heaters and wire the new water heaters for the kitchen. | 11/5/13 | | | Electrical |
| Macon-Hall ES (0118) 2A | Panel up front showing low battery in portable # 182 / Alarm keeps going off/ Battery needs replaced | 11/6/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need outside lights repaired outside in back of Cafeteria. Y=care stated that it is too dark out there to be safe in the morning. There are the lights that are in the ceiling. | 11/14/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Please repair Master Clock in the cafeteria | 11/18/13 | Cafetorium | | Electrical |

| | | | | | |
|-------------------------|---|----------|------------------|--|------------|
| Macon-Hall ES (0118) 2A | Need Exit light repaired #21 in Cafeteria / found during Fire Marshall inspection | 12/5/13 | Cafeteria | | Electrical |
| Macon-Hall ES (0118) 2A | Need Exit light #18 repaired by entrance #7 / found during Fire Marshall inspection | 12/5/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need exit light repaired in library entrance door / found during Fire Marshall inspection | 12/5/13 | Library | | Electrical |
| Macon-Hall ES (0118) 2A | Need exit light repaired in office administration hallway across from sick room. Found during Fire Marshall inspection // | 12/5/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need emergency lighting repaired in portables #603 across from 604. / and 617 and 618. These were found during Fire Marshall inspection | 12/5/13 | Portables | | Electrical |
| Macon-Hall ES (0118) 2A | Need motion detector repaired going into emerald hallway from 100 hallway into 500 hallway hanging down by the wires. | 12/6/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Checking for recept for heater in sprinkler room / found breaker #34 on LPF panel on left-hand side thrown. Tried to reset but kept tripping/ located in electrical room across classroom 530 / | 12/6/13 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 10 ea. of stock# 10531 for out side lights. | 12/11/13 | Cafeteria | | Electrical |

| | | | | | |
|-------------------------|---|----------|----------------|--|------------|
| Macon-Hall ES (0118) 2A | Need wall receipt repaired by milk cooler in Kitchen at Macon Hall Elementary | 12/11/13 | Kitchen | | Electrical |
| Macon-Hall ES (0118) 2A | Urgent! Need lights repaired under loading dock for kitchen. No lighting for kitchen personnel in the morning | 12/19/13 | Kitchen | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order catalog order #10460 - 10 each for replacement of bulbs for gym and outside lights | 12/19/13 | Athletic Field | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 10 each of stock #10531/outside wall canopy lights | 12/19/13 | Athletic Field | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 10 each of stock # 10257 / for outside under canopy lights | 12/19/13 | Athletic Field | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 20 each of stock#(from lighting source)F13BX/SPX35/8352P for outside lights under canopy around building and loading dock. | 12/19/13 | Athletic Field | | Electrical |
| Macon-Hall ES (0118) 2A | Need socket replaced for 2-pin fluorescent light fixture/ Located at back door of Cafeteria that Y-Care uses. | 12/19/13 | Athletic Field | | Electrical |
| Macon-Hall ES (0118) 2A | room 205 heat not coming on at all per Mr. Gamble 759-4530 | 1/7/14 | | | Electrical |

| | | | | | |
|-------------------------|--|---------|------------------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | Need to replace porch light on portable 618 due to vandalism/completely broken off wall outside ,but wiring looks good. | 1/8/14 | Portables | | Electrical |
| Macon-Hall ES (0118) 2A | Need to order 2- cases of stock#10220 (fluorescent lamps F 40/CW) / for Macon Hall Elementary. Need for overhead fluorescent lights in classrooms and offices. | 1/10/14 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need ballast replaced in fluorescent light fixture in front of yellow hallway. Have already changed out bulbs and fixture is marked with note. | 1/16/14 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | Need exhaust fan repaired on range hood in kitchen.Found on inspection. | 1/23/14 | Hallway/Corridor | | Electrical |
| Macon-Hall ES (0118) 2A | NEED THE ZONE BOX OPEN IN MAIN OFC SO PLANT MGR CAN CONTROL AIR IN ZONES-PLANT MGR GAMBLE 759-4530 KLR | 6/30/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C IN RM 532-NOT COMING ON-SBE GAMBLE 759-4530 KLR | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C (ON) for 72 hours starting 26th of July areas: Library and conference room first. Then classrooms 101/103/ 310/ 401/403/405/407/409/411/413/408/ 410/412 . Need A/C (ON) for carpet tp dry. | 7/25/13 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in classroom 206 / not working at all | 7/26/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need HVAC repaired in Kitchen/ showing unit is running but kitchen is over 83 degrees. | 7/26/13 | Kitchen | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in classroom 527 / No A/C at all roof top unit not working. | 8/1/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | RTU - THAT COVERS RM 527 - NOT COMING ON - PM/GAMBLE 759-4530 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | RTU IN KITCHEN AREA-NOT COMING ON-SBE GAMBLE 759-4530 KLR | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 205 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 206 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 303 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 402 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | A/C IN EMERALD HALL RM 552- NOT COOLING-SBE GAMBLE 756-4530 KLR | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C unit in Portable #610 repaired / Not Cooling | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON PORT-610 PLANT MGR-MICHAEL/759.4533 | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | 2-UNITS NOT COMING ON IN RM-108, 104 . PLANT MGR-MICHAEL/759.4533 | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need condensation leak repaired in classroom 101 red hall/ Water is coming down from supply vent. | 8/9/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNITS NOT COOLING IN RM-205 GREEN HALL, LIBRARY RIGHT SIDE PLANT MGR-MICHAEL/759.4531 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC roof top unit repaired to classroom 108. No A/C. | 8/12/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in classroom 205 / Rooftop unit not working at all. | 8/13/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-205 PLANT MGR-MICHAEL/759.4527 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in classroom 406/ RTU not working | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Room 406 a/c not running per Michael Gamble 759-4530 | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C RTU repaired to classroom 209/Checked breaker unit not running | 8/16/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit NOT COMING ON in Rm. 209 per Mr. Michael Gamble, Plant Mgr. 901.759.4530. | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C IN RM 209 1ST FLR-NOT COMING ON-SBE GAMBLE 759-4530 KLR | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | room 402 not cooling per Mr. Gamble 759-4530 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT in ROOM 402 is NOT HEATING per Mr. Gamble, Plant Mgr. 416.4530 | 1/31/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | Unit in ROOM 413 on YELLOW HALL is NOT HEATING per Michael Gamble, Plant Mgr. 759.4530 | 2/3/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Urgent!! Need leak repaired from HVAC unit in classroom 206 Blue Hall. The teacher has been putting buckets under Hvac unit to catch rain coming in unit. Is there a panel missing? | 2/7/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT HEATING IN RM-413 PLANT MGR-GAMBLE/759.4532 | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT HEATING IN RM-53 PLANT MGR-GAMBLE/759.4533 | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 413 YELLOW HALL- NOT HEATING-PLANT MGR GAMBLE 759-4530 KLR | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT HEATING IN RM-413 YELLOW HALL. PLANT MGR-GAMBLE/759.4530 | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT HEATING IN RM-530 EMERALD HALL PLANT MGR-GAMBLE/759.4527 | 2/12/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 534-NOT HEATING- PLANT MGR GAMBLE 759-4530 KLR | 2/13/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | per mr gamble 759-4530 room 413 is blowing cold air | 2/18/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 rooms 100 thru rooms 113 there is no hvac working at all | 2/20/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in these classrooms #1. Cafeteria #2. classroom 111 #3. Classroom 521 #4. Classroom 528 / Checked thermostats and gas lines. | 3/5/14 | 1st Floor | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 111 BLUE HALL, 407, 411, 413, 521, 528, & CAFE-ALL NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 3/5/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | portables 605, 607, 610 have no heat per michael gamble 759-4530 | 3/5/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN LAWN-MOW AREA PLANT MGR-GAMBLE/759.4527 | 3/5/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per mr gamble 759-4530 room 534 (emerald hall) is blowing cold | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | RTU-EMERALD HALL -COVERS (13 RMS) - ALL BLOWING COLD AIR - PM/GAMBLE 759-4530 | 3/18/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|--|--|--|
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 computer room #105 a/c not coming on at all | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C units are NOT COMING ON down the ENTIRE 100 HALLWAY(ROOMS 100-113) per Mr. Gambell, Plant Mgr. 759.4530 | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per gamble 759-4530 room 524 unit not coming on at all | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C IN 617 & 618 - BLOWING BUT NOT COOLING - PM/GAMBLE 759-4530 | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | 2-UNITS NOT COMING ON IN RM-102,104 & ZONE 5,6,8 PLANT MGR-GAMBLE/759.4533 | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 402, 104, & 106-ALL NOT COOLING-PLANT MGR GAMBLE 759-4530 KLR | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per michael gamble room 401 has no a/c not coming on and they are having walk a thon in building today | 4/11/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 402 YELLOW HALL-NOT COMING ON-PLANT MGR GAMBLE 756-4530 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | A/C BLUE HALL ABOUT (13) RMS ALL NOT COMING ON-PLANT MGR GAMBLE 756-4530 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT is NOT COOLING in ROOM 402 down the YELLOW HALL per Mr. Gamble, Plant Mgr. 759.4530 | 4/15/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | RTU - LIBRARY - NOT COMING ON - GAMBLE 759-4530 | 4/17/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | URGENT!! Need roof top unit leak repaired for classroom 411 /Leak coming from return air grill every time it rains. | 4/17/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | PORTABLE A/C UNIT IN PORT 603 -BLOWING BUT NOT COOLING - PM/GAMBLE 759-4530 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C UNIT is NOT COOLING in PORTABLE 618 per Mr. Gamble, Plant Mgr. 759.4530 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C UNIT is NOT COMING ON in ROOM 204 down GREEN HALL per Mr. Gamble, Plant Mgr. 759.4530 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C BLUE HALL ABOUT (13) RMS ALL NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 4/28/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|----------------|---------------------------------------|
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 portable 618 blowing hot air | 4/29/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-306 RED HALL PLANT MGR-GAMBLE/759.4527 | 4/30/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-106 BLUE HALL PLANT MGR-GAMBLE/756.2388 | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 101-NOT COOLING- PLANT MGR GAMBLE 759-4530 KLR | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 401 YELLOW HALL & RM 213 GREEN HALL-BOTH NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Change filters whole building | 5/30/14 | | Whole building | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 402 / A/C not working | 8/19/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-406 PLANT MGR-MICHAEL/759.4533 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|--------------|---------------------------------------|
| Macon-Hall ES (0118) 2A | PM units on whole school | 8/20/13 | | Whole school | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-402 YELLOW HALL. PLANT MGR-MICHAEL/756.2388 | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Cafeteria a/c is not working per Mr. Gamble 759-4530 | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-402 K-RM PLANT MGR-GAMBLES/759.4527 | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT IS LEAKING WATER IN RM-407. PLANT MGR-GAMBLE/759.4527 | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 402 / Unit isn't even blowing any air. | 8/27/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-402 PLANT MGR-GAMBLE/756.2388 | 8/27/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COOLING IN -410 YELLOW HALL PLANT MGR-GAMBLE/759.4527 | 8/28/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | Need HVAC (ON) in all of building on October 17th from 5:30 P.M. until 7:30 P.M. for Parent Academy. | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 410 YELLOW HALL-NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 411 YELLOW HALL-LEAKING-PLANT MGR GAMBLE 759-4530 KLR | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | room 401 a/c not working at all per Gamble 759-4530 | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNITS NOT COOLING IN RM-206,204 PLANT MGR-GAMBLE/759.4533 | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C PORT 610-NOT COOLING-PLANT MGR GAMBLE 759-4530 KLR | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Teacher is requesting a dehumidifier for her classroom in classroom 204 green hall. She is stating that everything is soaking wet with the humidity in her room. | 9/11/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C RM 206-NOT COOLING-PLANT MGR GAMBLE 759-4530 KLR | 9/12/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|----------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | A/C RM 13-NOT COMING ON- PLANT MGR GAMBLE 759-4530 KLR | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | No HVAC in classroom 213/ No air moving / Not cooling | 9/12/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 room 410 not cooling | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 410 // no A/C | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in library. | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM-431 PLANT MGR-GAMBLE/759.4533 | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in classroom 531 (Emerald hall) unit is not working at all. | 9/26/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Have water leak coming from supply vent on both corners / Believe that condensation pan is full and leaking. | 10/16/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|-----------|--------------|---------------------------------------|
| Macon-Hall ES (0118) 2A | Still need the A/C repaired in the library on the left-hand side. It is cooling on the right-hand side but has been requested to be repaired on left-hand side. | 10/16/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | A/C LIBRARY-NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 10/24/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN CONFER RM & MAIN OFFICES . PLANT MGR-GAMBLE/756.2387 | 10/24/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired to classroom 204 / Checked breakers all OK | 10/29/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | 2-UNITS NOT COOLING IN RM-204,206. PLANT MGR-GAMBLE/759.4527 | 11/1/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNITS NOT COMING ON IN RM-111,113. PLANT MGR-GAMBLE/759.4527 | 11/6/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need to leave HVAC (ON) at Macon Hall Elementary until 8:30P.M. for book fair and school program. Need all of School on. | 11/12/13 | 1st Floor | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | WORK ORDER FOR BOOK FAIR IS THURSDAY NIGHT, NOV 14, 2013 | 11/12/13 | | WHOLE SCHOOL | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|-----------|-----------|---------------------------------------|
| Macon-Hall ES (0118) 2A | Need HVAC (ON) in all of school until 8:30 P.M. on the 13th of November for book fair. | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN PORT-610 PLANT MGR-GAMBLE/759.4533 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RMS 412 & 527-BOTH NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Service heat in portables | 11/20/13 | | Portables | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit in Room 527 NOT COMING ON per Mr. Gammon, Plant Mgr. 759.4530. | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need the heat repaired in portable 610 / No heat at all in portable | 11/25/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON RM-413 PLANT MGR-GAMBLE/759.4533 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | room 315 and the entire yellow hallway rooms heat not coming on per michael gamble 759-4530 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|----------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | Need heat repaired in classroom 102 / not working | 12/3/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT HEATING IN PORT-601 PLANT MGR-GAMBLE/759.4533 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit in Rooms #211 and #310 are NOT HEATING per Mr. Dorsey, Plant Mgr. 759.5900 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT HEATING IN RM-310 RED HALL PLANT MGR-GAMBLE/759.4533 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT PORT 610-NOT HEATING- PLANT MGR GAMBLE 759-4530 KLR | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN PORT-617 PLANT MGR-GAMBLE/759.4533 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per Michael Gamble 759-4530 room 111 has no heat blowing cold | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 109 in blue hall at Macon Hall. fan blowing only | 12/10/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|----------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | Need HVAC repaired in classroom 211 / no heat. | 12/11/13 | Kitchen | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 524-NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit in ROOM 107 is NOT HEATING per Mr. Gamball, Plant Mgr. 759.4530 | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 305 ART RM-NOT HEATING-PLANT MGR GAMBLE 759-4530 KLR | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | room 111 blows cold per Michael Gamble 759-4530 | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 310-NOT COMING ON-PLANT MGR GAMBLE 759-4530 KLR | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need heat repaired in portable #601 / Tech left but never returned. | 12/13/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | room 211 blowing cold per Michael Gamble 759-4530 | 12/13/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|----------|-----------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | RTU - COVERS RM 211 - BLOWING COLD AIR - PM/GAMBLE 759-4530 | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HEAT repaired to portable # 601 / NO HEAT!! / Checked breaker and is OK. | 1/6/14 | Portables | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit is NOT COMING ON in PORTABLE 601 per Michael Gammon, Plant Mgr. 759.4230. | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need heat repaired in classroom 107 / No heat / Need repaired for small children | 1/6/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit is NOT COMING ON in Room 107 per Mr. Gambel, Plant Mgr. 759.4530 | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need heat repaired in classroom 205 green hall/ no heat at all. | 1/7/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need the HEAT repaired in portable 603 and 604 at Macon Hall Elementary. | 1/7/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Units in PORTABLES #603 and #604 ARE NOT HEATING per Mr. Gambel, Plant Mgr. 759.4530 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|--|--------|---------------------------------------|
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 room 402 not coming on at all | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Replace heat exchanger | 1/9/14 | | Rm 101 | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Replace heat exchanger | 1/9/14 | | Rm 202 | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Replace ignition control | 1/9/14 | | Rm 402 | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT PORT 610-NOT HEATING- PLANT MGR GAMBLE 759-4530 KLR | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 room 101 in blue hall unit not coming on at all | 1/10/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit is NOT COMING ON in the LIBRARY per Mr. Gamble, Plant Mgr. 759.4530 | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | RTU - RM 413- NOT COMING ON - PM/GAMBLE 759-4530 | 1/21/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|--|-----------------|---------------------------------------|
| Macon-Hall ES (0118) 2A | per michael gamble 759-4530 in the cafeteria one of the units is not running | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Check heat in cafe | 1/24/14 | | Cafe | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | HEAT RM 113-NOT HEATING-PLANT MGR GAMBLE 759-4530 KLR | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Replace heat exchanger in room 113 | 1/27/14 | | Room 113 | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Replace heat exchanger in cafe north unit | 1/28/14 | | Cafe north unit | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT KEEP SHUTTING OFF IN RM-209 PLANT MGR-GAMBLE/759.4533 | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | in the lawn mower shed the hanging gas heater is not working at all per michael gamble 759-4530 | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Unit in Room 405 is NOT HEATING per Mr. Gamble , Plant Mgr. 759.4530 | 1/29/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|------------------|--------------|---------------------------------------|
| Macon-Hall ES (0118) 2A | EMERGENCY! Need heat repaired in classroom 402 at Macon Hall Elementary, blowing cold air. | 1/29/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | EMERGENCY!!Need A/C repaired in offices up front/ Principal on down in all other offices. Zone 20 | 7/24/13 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Program whole school for GCA cleaning and waxing | 7/22/13 | | Whole school | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need HVAC roof unit repaired/2nd board switch #4 / zone#20 this is for main office in front lobby. No A/C | 7/23/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need filters changed out on roof top units/ Dust blowing out vents even after changing out ceiling tiles. | 7/17/13 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT NOT COMING ON IN RM 308. SBE GAMBLE 756-4530 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Kitchen a/c not working per Michael Gamble 759-4530 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need #2 roof top unit repaired in library/ Used thermostat and mercury does not show contact when pushed down past 70 degrees. | 7/29/13 | Grounds | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|------------------|--|---------------------------------------|
| Macon-Hall ES (0118) 2A | RTU NOT COMING ON KITCHEN. PLANT MGR-MICHAEL/759.4530 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT IN RM 303 IS NOT COMING ON. SBE GAMBLE 794-9530 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNITS ARE NOT COMING IN RMS 308,402,303,206,205. SBE GAMBLE 759-4530 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | UNIT IS NOT COOLING IN RM 527. SBE GABMLE 7 59-4530 | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need A/C repaired in classroom 308 / Unit not working | 7/26/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need rooftop unit repaired for classroom 532/ got on roof and unit is not working. Checked breaker and is not tripped | 8/6/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Macon-Hall ES (0118) 2A | Need grey paint painted on walls half way up in halls and restrooms / several areas look really bad in the hallways. | 2/3/14 | Hallway/Corridor | | Painting |
| Macon-Hall ES (0118) 2A | GRAFFITI - OUTSIDE ON BRICK WALL ON THE EAST WALL BY PLAYGROUND BY PORT 618 - PM/GAMBLE - 759-4530 | 4/21/14 | | | Painting |

| | | | | | |
|-------------------------|--|---------|------------------|--|----------|
| Macon-Hall ES (0118) 2A | Please remove graffiti sprayed on rear of building | 5/2/14 | | | Painting |
| Macon-Hall ES (0118) 2A | per gamble 759-4530 graffiti on portable #617 spray painted | 5/14/14 | | | Painting |
| Macon-Hall ES (0118) 2A | Need 1- gallon of the grey paint that is painted half way up the wall through out the hallways. Hallways looking bad. if you can't deliver then give me the formula to mix up the paint. | 1/30/14 | Hallway/Corridor | | Painting |
| Macon-Hall ES (0118) 2A | Please show plant manager plumbing and gas shut off valves. Also show them problem areas of sewers. | 7/12/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Monthly grease trap inspection. | 7/16/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Need 2 faucets repaired in yellow hallway | 7/23/13 | Restroom (Boys) | | Plumbing |
| Macon-Hall ES (0118) 2A | Need 2 faucets repaired in red hallway | 7/23/13 | Restroom (Girls) | | Plumbing |
| Macon-Hall ES (0118) 2A | A/C IN RM 101 1ST FLR BLUE HALL-LEAKING-SBE GAMBLE 416-4530 KLR | 8/8/13 | | | Plumbing |

| | | | | | |
|-------------------------|---|---------|---------------------|--|----------|
| Macon-Hall ES (0118) 2A | Need 2 water fountains repaired in the yellow hall . It seems that the water needs turned back on to the fountains and adjusted. | 2/4/14 | Hallway/Corridor | | Plumbing |
| Macon-Hall ES (0118) 2A | COMMODE TEACHER'S LOUNGE ACROSS FROM RED HALL-CONSTANTLY LEAKING-PLANT MGR GAMBLE 759-7530 KLR | 3/20/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Need commode in Emerald hall restroom in girl's repaired / Keeps running and having to unstick valve. | 3/24/14 | Administration Area | | Plumbing |
| Macon-Hall ES (0118) 2A | Install 2 boiler certificates. | 3/27/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | URGENT!! Need to replace the flush valve on the commode in the first stall in the girl's restroom in the emerald hallway(500) area. Commode has water shut-off and door has been locked and sign put up. Please replace / Several complaints about sticking | 4/3/14 | Restroom (Girls) | | Plumbing |
| Macon-Hall ES (0118) 2A | Need commode flush valve repaired in first commode in Boy's restroom in (green) 200 hallway. Have shut water off | 4/14/14 | 1st Floor | | Plumbing |
| Macon-Hall ES (0118) 2A | Need main shut-off valves to restrooms repaired in ceiling / Due to leaking and rust. | 4/14/14 | 1st Floor | | Plumbing |
| Macon-Hall ES (0118) 2A | URGENT!! Need flush valve repaired on commode in girl's restroom on Emerald hallway. First stall on the right / have sign on it and water si shut-off. | 4/14/14 | 1st Floor | | Plumbing |

| | | | | | |
|-------------------------|---|---------|------------------|--|----------|
| Macon-Hall ES (0118) 2A | Emergency!! Need flush valves repaired in girl's restroom 1st stall in Emerald hallway (500 area) / Can't stop from flushing water running on floor/ Shut water off | 4/23/14 | Restroom (Girls) | | Plumbing |
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need flush valves repaired in girl's restroom in (red) Hallway / 1st stall / Have water shut-off / Can't stop water from running | 4/23/14 | Restroom (Girls) | | Plumbing |
| Macon-Hall ES (0118) 2A | Need faucet repaired (Hot side) in boy's restroom in green hall / can't shut off water | 4/25/14 | Restroom (Boys) | | Plumbing |
| Macon-Hall ES (0118) 2A | SUPPLY WATER LINE 200 GREEN HALL-LEAKING-MAY BURST PER SBE-PLANT MGR GAMBEL 759-4530 KLR | 5/7/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Assist zone-4 with installing new water shut-offs, Randy Jowers. June 12 /13 | 6/4/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Assist zone with installing water shut-off valves | 6/26/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Repair A/C leak in ceiling | 6/30/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | COMMODE G RR RED HALL 3RD STALL-FLUSH VALVE CONSTANTLY LEAKING, CAN'T CUT OFF OR CONTAIN-PLANT MGR GAMBLE 759-4530 KLR | 8/27/13 | | | Plumbing |

| | | | | | |
|-------------------------|--|----------|------------------|--|----------|
| Macon-Hall ES (0118) 2A | Need commode repaired in girl's restroom red hall/ Commode is leaking from water feed tube coming from flush valve. 3rd stall in center. | 8/27/13 | Restroom (Girls) | | Plumbing |
| Macon-Hall ES (0118) 2A | URGENT!! Need commodes repaired in girl's restroom in red hall / Water is gushing out each time the commodes are flushed. Students can't use restroom. | 9/12/13 | Restroom (Girls) | | Plumbing |
| Macon-Hall ES (0118) 2A | Need center water fountain adjusted in yellow hall it sprays over to the floor causing slip accident. Located in front of restrooms. | 9/27/13 | Hallway/Corridor | | Plumbing |
| Macon-Hall ES (0118) 2A | Install certificate with following TN # T10740. | 10/2/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Install certificate with following TN # T51592. | 10/2/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Install certificate with following TN # T10739. | 10/2/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Need all 3 water fountains adjusted in yellow hallway / spraying on floor. | 10/4/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | EMERGENCY!!Need repair of Hot Water tank in boiler room / Tank looks as though bottom has busted out | 10/15/13 | Mechanical Room | | Plumbing |

| | | | | | |
|-------------------------|--|----------|----------------------|--|----------|
| Macon-Hall ES (0118) 2A | Repair RP 302892 1 1/4" 909 Watts Science storage room | 10/16/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Fountain is flooding, water wont shut off in yellow hall. PLANT MGR-GAMBLE/759.4533 | 10/16/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Need water fountain repaired / leaking can't get to shut-off/ located in yellow hallway. | 10/16/13 | Hallway/Corri dor | | Plumbing |
| Macon-Hall ES (0118) 2A | Please test the following RP. Serial # 302892 1 1/4" 909 Watts Science storage room | 10/21/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Please test the following RP. Serial # 412821 3/4" 909 Watts Science storage room | 10/21/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Please test the following RP. Serial # 166164 4" 909 Watts Kitchen Dock Mechanical Room | 10/21/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Please test the following RP. Serial # 184542 4" 909 Watts Kitchen Dock Mechanical Room | 10/21/13 | | | Plumbing |
| Macon-Hall ES (0118) 2A | Have commode leaking at bottom of commode running into floor drain./ Located in Boy's restroom 1st stall / red hall | 1/27/14 | Restroom (Boys) | | Plumbing |

| | | | | | |
|-------------------------|--|---------|------------------|--|----------|
| Macon-Hall ES (0118) 2A | water dripping through ceiling | 1/29/14 | | | Plumbing |
| Macon-Hall ES (0118) 2A | URGENT!!Need water fountain repaired in Red Hall the handle is broken and is a hazard to the children. Have put do not use sign on it. | 1/30/14 | Hallway/Corridor | | Plumbing |
| Macon-Hall ES (0118) 2A | Need roof leak repaired in classroom 206/ 2 leaks coming from next to supply vents from HVAC | 8/5/13 | Classroom | | Roof |
| Macon-Hall ES (0118) 2A | URGENT!! Need roof leak repaired in portable # 610 Leaking on left-side of portable behind promethan board, this is a serious leak with damage to equipment. | 2/5/14 | Portables | | Roof |
| Macon-Hall ES (0118) 2A | NEED LEAK REPAIRED IN PORTABLE #603 ON LEFT-HAND SIDE BY COMPUTER SATELLITE (BLACK BOX) | 2/6/14 | Portables | | Roof |
| Macon-Hall ES (0118) 2A | Urgent!! Need water leak repaired on right-hand corner in ceiling by boy's restroom by custodial closet. Ceiling tile is white and 35 gal barrel under it. | 4/21/14 | | | Roof |
| Macon-Hall ES (0118) 2A | URGENT!! Need roof leak repaired in ceiling by entrance of Boy's restroom in green hallway // facing restroom on right-hand side corner. | 4/21/14 | | | Roof |
| Macon-Hall ES (0118) 2A | EMERGENCY!! Need Sprinkler head repaired in Library located over the 5 computers at Macon Hall Elementary. The sprinkler head is leaking. | 5/27/14 | | | Roof |

| | | | | | |
|-------------------------|---|----------|------------------|--|-------------|
| Macon-Hall ES (0118) 2A | Need roof leak repaired in classroom 206 (green hall) | 11/22/13 | | | Roof |
| Macon-Hall ES (0118) 2A | URGENT! Need roof leak repaired in 413 / it is coming from the supply vent in center of classroom. Have large barrel under leak | 1/13/14 | Hallway/Corridor | | Roof |
| Macon-Hall ES (0118) 2A | Roof leak in kitchen in the serving area 2 leaks coming down . I suspect that it is the sprinkler system that is causing this. | 1/28/14 | Kitchen | | Roof |
| Macon-Hall ES (0118) 2A | Emergency!! Need leak repaired in kitchen it seems to start around 1:00 P.M./ Need repaired due to leak being in the serving area and hitting the children or their food, | 1/29/14 | Cafeteria | | Roof |
| Macon-Hall ES (0118) 2A | vent new water heaters | 11/4/13 | | | Sheet Metal |
| Macon-Hall ES (0118) 2A | Please vent the new water heaters for the kitchen. | 11/5/13 | | | Sheet Metal |
| Macon-Hall ES (0118) 2A | Need down spouts repaired up front under the eave / Tried to access but found no way on roof. Need repaired due to flooding out front down walk way. | 12/19/13 | Athletic Field | | Sheet Metal |
| Macon-Hall ES (0118) 2A | Need down spouts repaired on portables and gutter is missing causing leaks in portables. | 12/19/13 | Athletic Field | | Sheet Metal |

| | | | | | |
|-------------------------|--|----------|----------------|--|-------------|
| Macon-Hall ES (0118) 2A | EMERGENCY! Need mailbox put back on wooden platform at Macon Hall Elementary. It was knocked off of standing platform. | 12/19/13 | Athletic Field | | Sheet Metal |
|-------------------------|--|----------|----------------|--|-------------|

| Count of Craft | Craft | | | | | | | | | |
|------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| ance Whse-OPS (8 | 11 | 8 | 71 | 54 | 39 | 29 | 63 | 2 | 15 | 292 |
| Grand Total | 11 | 8 | 71 | 54 | 39 | 29 | 63 | 2 | 15 | 292 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|--------------------------------|---|----------------|------|--------------|-------------|----------|
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT / MATERIAL (APRIL 2014) | 4/9/14 | | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B |) | 2/12/14 | | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT / MATERIAL (MARCH 2014) | 3/7/14 | | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT / MATERIAL (NOVEMBER 2013) | 11/4/13 | | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT / MATERIAL (JANUARY 2013) | 1/9/14 | | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT / MATERIAL (SEPT. 2013) | 8/5/13 | | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | remove carpet and install floor tile | 8/13/13 | | front office | | Asbestos |

| | | | | | |
|--------------------------------|---|---------|---------------------|--|----------|
| Maintenance Whse-OPS (8220) 2B | replace floor tile in administration area | 7/3/13 | Administration Area | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT/MATERIAL (JULY 2013) | 7/12/13 | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT/MATERIAL (JULY 2013 THRU JUNE 2014) | 9/16/13 | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | DRAW EQUIPMENT / MATERIAL (OCTOBER 2013) | 10/4/13 | | | Asbestos |
| Maintenance Whse-OPS (8220) 2B | Work order for acquiring safety material | 6/18/14 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | repair of the large box truck back door # 591 -- Fund this from budget 2922 | 4/24/14 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | Project management for Access DNSI to perform Maintenance Repair of Network Cabling in various SCS locations (E-RATE) PHASE 1 - WO#424033 PO REQ#439707 | 3/24/14 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | Project management for Access DNSI to perform Maintenance Repair of Network Cabling in various SCS locations (E-RATE) PHASE 2 - WO#424037 PO REQ#439720 | 3/24/14 | | | Cabling |

| | | | | | |
|--------------------------------|---|----------|--|---------------------------------|-----------|
| Maintenance Whse-OPS (8220) 2B | Project management for Access DNSI to perform Maintenance Repair of Network Cabling in various SCS locations (E-RATE) PHASE 3 - WO#424037 PO REQ#439720 | 3/24/14 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | Provide Paper for HP Design jet 500 PS Plotter for special projects. | 3/26/14 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | Facilitate the purchase and provision of Auto CAD 2014 software 2014 for Network installation projector mangers. Approved by Eddie Miller | 12/13/13 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | create business cards for all SCS trucks which will display contacts for emergencies situations (Request Network Cabling Installation Support). | 7/25/13 | | | Cabling |
| Maintenance Whse-OPS (8220) 2B | PURCHASE TOOL KIT FOR BRIAN SHIPP-REQUESTED BY M TRIPLETT KLR | 10/14/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | PURCHASE STAGE LADDERS-REQUESTED BY M TRIPLETT KLR | 5/19/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Special cut ceiling tiles needed in that area | 6/26/14 | | administrative front area | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Special cut ceiling tiles near Brian Shipp office | 6/26/14 | | Hallway near Brian Shipp office | Carpentry |

| | | | | | |
|--------------------------------|---|---------|--|--------------------------------|-----------|
| Maintenance Whse-OPS (8220) 2B | Special cut ceiling tiles in hallway near Mr. Tutton office | 6/26/14 | | Hallway near Mr. Tutton office | Carpentry |
| Maintenance Whse-OPS (8220) 2B | I need 1 case of ceiling towels | 6/19/14 | | plant manager desk | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Weld bumper back on to truck 2228. | 6/5/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Clean up and organize old furnace room for part and equipment storage. | 6/16/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | NEED ELECTRICAL TAPE- REQUESTED BY BRIAN SHIPP KLR | 5/29/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Dumpster mover trailer need new trailer hitch installed by welders. | 5/2/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Weld ramp back on to Grounds Equipment Trailer | 5/6/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Welder to install Weedeater, Blower racks, gorilla lifts and repair Rear gate | 5/7/14 | | | Carpentry |

| | | | | | |
|------------------------------------|--|----------|--|-------------------|-----------|
| Maintenance Whse- OPS (8220) 2B | Grounds Equipment Trailer #11 - rods that hold up ramps are bent | 5/12/14 | | | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Weld and repair Herbicide spray rig - Kirkwood | 5/13/14 | | | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Repair bumper on truck 333 | 11/19/13 | | | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Tack weld spray boom | 11/22/13 | | | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Repair overhead door | 11/22/13 | | Carpenter Shop | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Weld rod coupling on 1/2" iron pipe | 4/9/14 | | | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Cut & thread 1/2" iron pipe 5-ft (4 peices) | 4/9/14 | | | Carpentry |
| Maintenance Whse- OPS (8220) 2B | Have Zone welder to repair Scag # 4 Zero-turn mower deck | 4/10/14 | | | Carpentry |

| | | | | | |
|--------------------------------|---|---------|--|--|-----------|
| Maintenance Whse-OPS (8220) 2B | Repair trailer in shop Friday. Grounds trailer replace boards. | 4/24/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Trailer ID#371721 Need welder to replace gorilla lifts and straighten jack | 4/24/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Trailer ID#368016 Need welder to replace gorilla lifts | 4/24/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Repair trailer. | 4/25/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Grounds Equipment Trailer # 3 - Welder to install Blower racks, weedeatre racks, and new front jack | 4/25/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | DOOR CAN'T SECURE, BY AUTO SHOP PLANT MGR-BOYKINS/416.5550 | 4/28/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Trailer # 2004 Jerry Tucker - need Gorilla lifts, weedeater racks, blower racks and boards replaced | 4/29/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Truck # 2317 - Need welder to weld side of stake bed truck back on | 4/30/14 | | | Carpentry |

| | | | | | |
|--------------------------------|---|---------|--|--|-----------|
| Maintenance Whse-OPS (8220) 2B | Fabricate a fence stretcher. | 4/30/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Make repairs to zone three tilt trailer. | 5/1/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | REPLACE DRILL FOR TOM FORD-IT'S BEYOND REPAIR-REQUESTED BY M TRIPLETT | 1/28/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | repair roll up door by zone 2 | 1/29/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | repair roll up door by filters going to back parking lot | 1/29/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Install/weld jack stand to zone 1 trailer. | 2/5/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Provide plywood for Truck # 2317 for rear panel. | 2/10/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Truck # 2318 - Tailgate repair | 2/13/14 | | | Carpentry |

| | | | | | |
|--------------------------------|--|---------|--|--|-----------|
| Maintenance Whse-OPS (8220) 2B | REPLACE HAMMERDRILL FOR CLAY RUDOLPH-REQUESTED BY O SCHLAFER KLR | 2/19/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Grounds Roll-up door- lift bar is broken and coming out of track | 2/19/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Danny Walker welded baseball base anchors for Grounds Dept. | 3/11/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | FABRICATE FIVE SETS OF SLIDES FOR GROUNDS WHIRLS | 3/21/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Deliver truck #1407 to Aerial Trucks in Olive Branch, MS. for a repair quote for damage received in accident on Friday 3/24/2014 per Jerry Rudolf of Risk Management and return written quote. | 3/25/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Weld tailgate back on to Corea Yates - Grounds equipment Trailer | 4/2/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Re-weld chute on Grounds leaf vac. James Beadle | 4/3/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Weld ramp lock bars on Grounds Equipment Trailer #2004 | 4/7/14 | | | Carpentry |

| | | | | | |
|--------------------------------|---|----------|--|--|-----------|
| Maintenance Whse-OPS (8220) 2B | Provide wood to make ramps for zero-turn mowers | 4/9/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Weld and repair tailgate on Grounds Truck # 2317 | 10/22/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Repair wench. | 11/1/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Order, cut, paint and install Expand metal on sides of new Trane HVAC. | 11/4/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Epping Way/ James Rd. Property- gate to secure entrance is down, need welders to repair | 11/6/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Weld and repair leaf blower mount on Grounds equipment trailer | 12/19/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Need welder to tack weld nuts on bleachers located in the Grounds Maint. area. See Bill Spitznas | 1/9/14 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Relocate time card racks that are beside Z2 offices and place one outside the A.V. shop and the other by the clock at the front office.jd | 1/21/14 | | | Carpentry |

| | | | | | |
|--------------------------------|--|---------|---------|--|-----------|
| Maintenance Whse-OPS (8220) 2B | Truck # 4250- weld & repair herbicide spray rig | 7/23/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Please repair trailer #5. Thank you. | 8/5/13 | Grounds | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Purchase tool boxes for truck 1460 | 8/7/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Need welder to weld Mower deck Landpride #2 | 8/14/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Need welder to weld gear box bracket Scag mower #10-12 | 8/14/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Re-weld tailgates on Truck #2318 | 7/8/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Re-weld frame on herbicide sprayer tractor | 7/9/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Grounds trailer #2 - Install gorilla lift, weedeater racks, weld jack on and repair rear gate. | 8/26/13 | | | Carpentry |

| | | | | | |
|--------------------------------|--|---------|---------|--|-----------|
| Maintenance Whse-OPS (8220) 2B | Tractor # 1003 cut bolt off bat-wing mower - Lonnie | 8/26/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | PURCHASE FLOOR TILE MACHINE FOR SHOP AREA-REQUESTED BY B SHIPP KLR MT | 8/28/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | REPLACE DECKING ON TRAILER FROM WOOD TO METAL | 9/4/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Fence at the scrapyard has a hole cut in it, needs repair, per Ken White. | 9/4/13 | Grounds | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Scag # 6 Mower - weld front fork | 9/5/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Paint A/C guard | 9/10/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Grounds Equipment Trailer - Jerry Tucker- weld bars under trailer back up.(This is the one Lonnie repaired for Ed Hawkins)Thanks!!! | 9/11/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Need Carpentry shop, to fix northeast, outside door, next to roll-up door, either out of alignment, or panic bar is faulty...See Mr.Charles White Maint. Supervisor... | 9/26/13 | | | Carpentry |

| | | | | | |
|--------------------------------|--|---------|-------------|--------------------|------------|
| Maintenance Whse-OPS (8220) 2B | repair parts for band saw located in welding shop-os | 10/1/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Order, cut and paint (black) expand metal to cover sides and end of NEW Trane HVAC unit. | 10/3/13 | Parking Lot | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Repair gates at the lumber cage. | 10/4/13 | | | Carpentry |
| Maintenance Whse-OPS (8220) 2B | Blown lights inside supply cage (fixtures over 12 ft | 6/26/14 | | inside supply cage | Electrical |
| Maintenance Whse-OPS (8220) 2B | I'm ordering 2 cases of fluorescent light bulbs 36 to a case. | 6/19/14 | | Plant manager desk | Electrical |
| Maintenance Whse-OPS (8220) 2B | Clean up and organize old furnace room for part and equipment storage. | 6/16/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair wiring. | 5/29/14 | | Paint boot | Electrical |
| Maintenance Whse-OPS (8220) 2B | Exhaust fan in Small Engine Shop is not working | 5/5/14 | | | Electrical |

| | | | | | |
|--------------------------------|--|----------|------------------|-----------|------------|
| Maintenance Whse-OPS (8220) 2B | Exhaust Fan on back wall of Small Engine shop- is not working | 5/8/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair and/or replace light. | 5/9/14 | Restroom (Girls) | Bay 4 | Electrical |
| Maintenance Whse-OPS (8220) 2B | LIGHTS TOOLCAGE WAREHOUSE AREA- SPARKED FIRE WHEN TURNED ON- REQUESTED BY M TRIPLETT KLR | 5/14/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Main entry overhead door stuck open, have power will not operate. | 5/14/14 | | Auto Shop | Electrical |
| Maintenance Whse-OPS (8220) 2B | 3 case of t8 lamps | 11/26/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | SMALL ENGINE SHOP: Repair 4-ft. exhaust fan on North wall | 4/11/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | 50 amp breaker is tripping at air compressor for sprinkler system. | 4/14/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Check exhaust vent-a-hood in sheet metal shop. possible bad belt. see Gary Moore. | 4/15/14 | | | Electrical |

| | | | | | |
|--------------------------------|--|---------|---------------------|--------------------|------------|
| Maintenance Whse-OPS (8220) 2B | Bill Spitznas Office - two sets of flourescent lights out | 4/16/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Replace wench battery | 4/17/14 | | White Lift Trailer | Electrical |
| Maintenance Whse-OPS (8220) 2B | Wire new hvac equipement. | 4/23/14 | Administration Area | Ed Hawkins Office | Electrical |
| Maintenance Whse-OPS (8220) 2B | NO HOT WATER IN KITCHEN AREA & LADIES RR IN THE FRONT OFC AREA-REQUESTED BY K RICHMOND KLR | 1/30/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair Switch handle on the combonation starter on the Hydraulic brake in the sheetmetal shop. | 2/3/14 | Machine Shop | | Electrical |
| Maintenance Whse-OPS (8220) 2B | lights out in Small Engine Repair Shop | 2/20/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Check and/or repair exhaust fan in ladies restroom at the office kitchen. | 4/2/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | REP/REPL LIGHTS IN FILING AREA-REQUESTED BY K RICHMOND | 4/3/14 | | | Electrical |

| | | | | | |
|--------------------------------|--|----------|---------------------|-------------------|------------|
| Maintenance Whse-OPS (8220) 2B | Check lights on the eastside from the second to the forth bays. | 4/4/14 | | O.S. Security Lts | Electrical |
| Maintenance Whse-OPS (8220) 2B | Make necessary changes to electrical equipment for welding shop remodel. | 10/16/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | AUTOSHOP needs several lights repaired/replaced inside the shop and one light on outside of shop | 10/17/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | change breaker for air compressor-os | 12/23/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Truck #2226, clean up and organize tools and materials. | 1/3/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Air compressor in the Zone three bay area motor locked up and caught fire. Please repair. See William Stephens or Ed Hawkins for lock key. | 1/8/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair Emergency/Night light in the foryer between the front breakroom and fingerprinting. | 1/22/14 | Administration Area | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair or replace lamps or ballast in the light fixtures in the sheet metal shop. | 1/23/14 | | | Electrical |

| | | | | | |
|--------------------------------|---|---------|---------------------|-----------------------|------------|
| Maintenance Whse-OPS (8220) 2B | Parts for temp. chiller | 7/23/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Wire temp. chiller in warehouse | 7/23/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Checkout air compessor, paintshop having trouble with spraybooth. | 7/24/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | replace lay in light fixtures in mens rest room up front-os | 8/19/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair or replace lights. | 8/21/13 | | Font break room | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair or replace lights. | 8/21/13 | Administration Area | Secretary office area | Electrical |
| Maintenance Whse-OPS (8220) 2B | Replace damaged L.V. light switch adjacent to whse. aisleway entry. | 8/21/13 | Administration Area | Secretary office area | Electrical |
| Maintenance Whse-OPS (8220) 2B | repair battery charger. | 8/29/13 | | | Electrical |

| | | | | | |
|--------------------------------|---|---------|-----------------|-----------------|------------|
| Maintenance Whse-OPS (8220) 2B | Replace wheel on trailer. | 8/30/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Replace power cord on the Pittsburg/Acme machine. See Gary Moore | 9/5/13 | | Sheetmetal shop | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair light in M. Tuttons office. | 9/5/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Need Electric shop, to change out bulbs or could be ballast,in cubical,located in Mr. Theo Harris office... | 9/6/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Repair light in restroom located in the welding shop. | 9/12/13 | Restroom (Boys) | | Electrical |
| Maintenance Whse-OPS (8220) 2B | REPL FLUORESCENT BULBS IN SUPPLY TOOL CAGE-(BAY #3)REQUESTED BY M TRIPLETT KLR | 9/19/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | REPL FLUORESCENT BULBS IN FILTER CAGE BY CARPENTER SHOP (BAY #4)-REQUESTED BY M TRIPLETT KLR | 9/19/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | REPL FLUORESCENT BULBS IN FILTER CAGE BY LUMBER CAGE (BAY #3)REQUESTED BY M TRIPLETT KLR | 9/19/13 | | | Electrical |

| | | | | | |
|--------------------------------|--|----------|--|--|------------|
| Maintenance Whse-OPS (8220) 2B | REPL FLUORESCENT BULBS IN SCAFFOLD CAGE BY (BAY #2)REQUESTED BY M TRIPLETT KLR | 9/19/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Changeover trucks 356 to 721, and setup. | 9/25/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Purchase tool for Christopher Garrett electrician | 11/13/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Purchase tools for Samuel Word electrician | 11/13/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Replace batteries in office UPS. | 11/1/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Material for truck 2817 | 4/9/14 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Material for truck 2817 | 12/4/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | Replace batteries in office UPS. | 6/18/14 | | | Electrical |

| | | | | | |
|--------------------------------|---|---------|--|--|---------------------------------------|
| Maintenance Whse-OPS (8220) 2B | Get material quotes for CNC maintenance area electrical power. CNC to purchase. | 12/5/13 | | | Electrical |
| Maintenance Whse-OPS (8220) 2B | REPLACE DRILL FOR MARVIN ROBINSON-IT'S BEYOND REPAIR-REQUESTED BY M TRIPLETT | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Air Cond. out in Grounds Small Engine Office | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | laser and sensor upgrade | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | truck 2201 needs new tires | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | repair unit in grounds dept. | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | band shop a/c not working | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | MONTHLY DRAW FOR MATERIALS/SUPPLIES FOR JUNE 2014 KLR | 5/30/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|--|---------|--|--|---------------------------------------|
| Maintenance Whse-OPS (8220) 2B | no a/c truck 9810 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Repair unit over FIM | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | COMPUTER FOR LARRY RUCKER | 5/14/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | replace unit in conference room | 4/11/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | purchase mini split | 4/11/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | ice machine in the autoshop area is not working properly | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | repair heat for paint shop | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | purchase new trailer to replace stolen one | 1/31/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|----------|--|--|---------------------------------------|
| Maintenance Whse-OPS (8220) 2B | replace heat strips in unit | 2/5/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Purchase training material. And fan motor for unit by bathroom | 2/27/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Clean ice machine in zone 3 | 10/31/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Oil Lube & Belt-Maintenance Warehouse - Refer to PM schedule details. | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Auto Shop-- 3 Heaters are out/not working and 1 heater is buzzing. | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 121 - Maint Whse - Refer to PM schedule details. | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 125 - Maint Whse - Refer to PM schedule details. | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 188 - Maint Whse - Refer to PM schedule details. | 12/17/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|----------|--|--|---------------------------------------|
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 189 - Maint Whse - Refer to PM schedule details. | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Filter-Maintenance Warehouse - Refer to PM schedule details. | 12/24/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | drain pan stopped up leaking on elec. masters desk | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | DRAW MATERIAL = JULY 2013 | 7/1/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Change oil and service truck #1301 | 7/3/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | truck 2715 fan motor not blowing | 7/11/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | repair band shop and key shop a/c's | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Reference materials | 9/27/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|---------|--|--|---------------------------------------|
| Maintenance Whse-OPS (8220) 2B | Change cond for key shop | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Filter-Maintenance Wharehouse - Refer to PM schedule details. | 8/27/13 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Filter-Maintenance Wharehouse - Refer to PM schedule details. | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 121 - Maint Whse - Refer to PM schedule details. | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 125 - Maint Whse - Refer to PM schedule details. | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 188 - Maint Whse - Refer to PM schedule details. | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Air Compressor 189 - Maint Whse - Refer to PM schedule details. | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| Maintenance Whse-OPS (8220) 2B | Monthly - Oil Lube & Belt-Maintenance Warehouse - Refer to PM schedule details. | 6/17/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|---------|--|--|----------|
| Maintenance Whse-OPS (8220) 2B | May 2014 workorder for supplies/etc for painter and bricklayers | 5/1/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | June 2014 - Draw workorder for painters and bricklayers | 6/2/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Paint grounds trailer tongue and back lift gate. | 5/15/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | paint metal plate for door. | 6/12/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | paint goal and back board for gymnasium | 6/13/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Paint (black) grounds trailer. Support Danny. | 5/19/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | paint wall case for audio equipment | 4/30/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Clear coat wall plate | 2/18/14 | | | Painting |

| | | | | | |
|--------------------------------|--|----------|--|------------------------------|----------|
| Maintenance Whse-OPS (8220) 2B | Paint plywood for Sharpe Elm. see Tom Ford. | 10/31/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | paint floor in new band area | 11/6/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | pickup new barrels for paint shop | 11/6/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | paint doors | 12/9/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Open/draw for supplies/misc for Painters/Brick Masons for Jan 2014 | 1/7/14 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Paint sheetmetal for locker ends See Gary Moore. | 1/23/14 | | White Station Sr. (2780) Z2A | Painting |
| Maintenance Whse-OPS (8220) 2B | WATER BLAST PARKING LINES IN FRONT OF BLDG. | 7/18/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Paint 14 stall doors for Scenichills Elem. TOM FORD | 7/24/13 | | | Painting |

| | | | | | |
|--------------------------------|--|---------|--|--|----------|
| Maintenance Whse-OPS (8220) 2B | Paint window guards for Cherokee Elm. (Lonnie Grimes). | 7/25/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Painting/Brick Mason--Supplies/Miscellaneous for August 2013 | 8/5/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | PAINT NEW LINES IN FRONT OF WHSE | 8/9/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | a/c straps prime only | 8/14/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | paint walls in main office complex | 8/15/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | DRAW MATERIAL/EQUIPMENT (JULY,'13) PAINTING | 7/9/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Texture paint exterior plywood for portable ramps. Coleman Elm. Mike Carmony | 8/16/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Paint trailer frame | 9/9/13 | | | Painting |

| | | | | | |
|--------------------------------|---|----------|--|-----------|----------|
| Maintenance Whse-OPS (8220) 2B | Open WorkOrder for September-supplies/materials | 9/10/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Two doors painted (Treadwell Mid.) Ty Allen | 9/23/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Prep and paint expand metal (black) for new HVAC unit on parking lot. D. Walker | 10/9/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Paint gates for douglass sr (Tom Ford). | 10/10/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | Stain seat bottoms for Treadwell Mid. auditorium(Tom Ford). | 7/15/13 | | | Painting |
| Maintenance Whse-OPS (8220) 2B | PURCHASE PORTA-JOHN'S FOR PUBLIC AUCTION-REQUESTED BY M TRIPLETT KLR | 10/29/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair drink fountain. | 6/26/14 | | Breakroom | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair air compressor in zone 3 area. | 12/5/13 | | | Plumbing |

| | | | | | |
|--------------------------------|---|---------|---------------------|-------------------|----------|
| Maintenance Whse-OPS (8220) 2B | WATER COOLER FRONT BREAKRM-CONSTANTLY RUNNING WATER FROM SPOUT, CAN'T CUT OFF-KLR | 6/18/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | A/C TOP OF FIM OFC-DRAINPAN STOPPED UP & LEAKING-REQUESTED BY LB RUCKER KLR | 6/20/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | PIPE BEHIND CUSTODIAL STORAGE CLOSET-SHOOTING WATER OUT, CAN'T CUT OFF-REQUESTED BY LINDA KLR | 6/4/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Unstop area drains | 6/9/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | COMMODE MEN'S RR FRONT BREAKRM AREA-CONSTANTLY OVERFLOWING, CAN'T CUT OFF-REPORTED BY ERICA KLR | 6/9/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | ICE MACHINE TOOLCAGE AREA-DRAIN STOPPED UP & WATER ALL OVER FLR-REQUESTED BY M TRIPLETT KLR | 5/28/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Calibrate/check back flow meter. | 5/29/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Hook-up condensate new hvac equipment. | 5/8/14 | Administration Area | Ed Hawkins Office | Plumbing |

| | | | | | |
|--------------------------------|--|----------|--|------------------|----------|
| Maintenance Whse-OPS (8220) 2B | Check batteries on the big blue scissor lift. | 5/14/14 | | Scissor Lift #12 | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Unstop area drain outside FIM office | 5/15/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Pump not working on sewer ejector outside custodial room office. | 5/15/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Servive unit heaters in customer service parts area. | 11/20/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Material for truck 2946 | 11/26/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Service wash truck | 4/14/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Sump pit over flowing, pump may be bad. | 4/22/14 | | Auto Shop | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Unstop storm sewer | 4/25/14 | | | Plumbing |

| | | | | | |
|--------------------------------|---|---------|---------------------|---------------------------|----------|
| Maintenance Whse-OPS (8220) 2B | Replace hose heads | 4/29/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Change water filter cartage. | 4/29/14 | Kitchen | By ladies office restroom | Plumbing |
| Maintenance Whse-OPS (8220) 2B | toilet stopped up.Front bathroom by breakroom. | 5/1/14 | Restroom (Boys) | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Replace hot water heater for Brian's and ladies' restrooms. | 2/6/14 | Administration Area | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair pump on wash truck | 2/18/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair sewer truck | 2/21/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Calibrate test kit for back flow | 3/5/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Water filter on Grounds Ice machine has froze and busted | 3/5/14 | | | Plumbing |

| | | | | | |
|--------------------------------|--|----------|-----------------|-----------------|----------|
| Maintenance Whse-OPS (8220) 2B | Toilet leaking, needs to be replaced. | 3/21/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Toilet stoppedup. | 3/27/14 | Restroom (Boys) | Front breakroom | Plumbing |
| Maintenance Whse-OPS (8220) 2B | remove non- working drinking fountain in F.I.M. office beside Craig Evans office-os | 4/4/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Install auto bleeder on the upright air compressor that supplies the sprinkler system. per. O.S. | 4/4/14 | | By Zone3 Office | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Replacing wall hung sink. | 10/15/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Urinal leaking and will not shut off. | 10/25/13 | Restroom (Boys) | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | PAPER TOWEL HOLDER LADIES RR OFF KITCHEN AREA-FALLING OFF WALL. KLR | 11/5/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Blockage on two toilets. | 11/8/13 | Restroom (Boys) | | Plumbing |

| | | | | | |
|--------------------------------|---|----------|--|--|----------|
| Maintenance Whse-OPS (8220) 2B | REPAIR WASH TRUCK-REQUESTED BY K WENZLER KLR | 11/12/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Toilet leak | 1/3/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Water Faucet popped off in freezing weather- Grounds Ice house | 1/8/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need to purchase new sewer machine to replace old spartan machine. | 1/15/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Replace ice machine zone 1 | 1/21/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Change over/set plumbing truck , exchanged truck with Z2A need swing boom.jd | 1/22/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Install ice machine | 1/24/14 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need Plumber shop,at 1384 Farmville at the Mallory warehouse print shop,bldg. women restroom (front),toilet leaks when flushed... | 7/16/13 | | | Plumbing |

| | | | | | |
|--------------------------------|---|---------|---------------------|--|----------|
| Maintenance Whse-OPS (8220) 2B | Assist Holmes Services with pumping grease traps in Zone-3A | 7/23/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair condensate pan leak. | 8/1/13 | Administration Area | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Grounds ice machine out (machine on the left) | 8/8/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Restroom in front break room, flush valve in second stall runs continuously. | 8/13/13 | Restroom (Boys) | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need Plumber shop,,to fix leak,coming,from top of urinal,(second from left)entering men"s restroom,in Maint.Warehouse lounge(Up FRONT)... | 8/14/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need Plumber shop,to fix ,automatic eye,on commode,in ladies restroom,located,in automotive shop area,commode will not flush... | 7/2/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Change out water filter in large Ice Machine- Grounds Ice house | 7/2/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need Plumber shop,to fix,second urinal to the right,in men's restroom,located in employee"s lounge,urinal still,leaking,(See G.C.A.,lead person)... | 8/19/13 | | | Plumbing |

| | | | | | |
|--------------------------------|--|---------|-----------------|--|----------|
| Maintenance Whse-OPS (8220) 2B | Need Roof,shop, to fix roof leak,water leaking into conference room,near directors office,leak to the right as you enter room,Please! See G.C.A.,lead person... This is a condensate pan not | 8/19/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair Pump on sewer wash truck | 8/20/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | AC leak in large conference room. | 9/4/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | repair lock trailer | 9/9/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Sink backingup in the new office break area. | 9/24/13 | Kitchen | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Replace filter at icemachine at zone 2 office. | 9/25/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Repair condensate leak on RTU at zone 2 office. | 9/25/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Sink stoppedup men's r.r. in large breakroom. | 10/9/13 | Restroom (Boys) | | Plumbing |

| | | | | | |
|--------------------------------|--|----------|--|--|-------------|
| Maintenance Whse-OPS (8220) 2B | AUTOMATED COMMODE LADIES RR AUTO SHOP AREA-NOT FLUSHING-REQUESTED BY VICKI KLR | 10/9/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need Plumber shop,to fix,toilet not flushing,in women's restroom,on east end of Maint.Warehouse(Print shop)... | 8/15/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Need Plumber shop,to fix,toilet leaking,in women's restroom(front office),in Maint.Warehouse (Print Shop)... | 8/15/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | Replace wench on truck 2407. | 11/13/13 | | | Plumbing |
| Maintenance Whse-OPS (8220) 2B | ROOF LEAK IN ASSET MAIN OFFICE @ INVENTORY CONTROL. SUPV-BRADEN/416.4116 | 2/4/14 | | | Roof |
| Maintenance Whse-OPS (8220) 2B | September Open WorkOrder for Roofing material/supplies | 9/11/13 | | | Roof |
| Maintenance Whse-OPS (8220) 2B | FABRICATE FENDERS FOR DUMPSTER HAULER | 6/18/14 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | Weld metal plates together that cover old auto lift stations in zone 3 work area that are not in use. | 5/27/14 | | | Sheet Metal |

| | | | | | |
|--------------------------------|---|----------|--|--|-------------|
| Maintenance Whse-OPS (8220) 2B | Repair truck box | 11/20/13 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | Fabricate fountain handles | 11/20/13 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | We need some brackets for the music risers. | 4/17/14 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | cut metal for window guards | 4/22/14 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | cut paint shields for painters | 4/23/14 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | NEED CABINET BUILT FOR CORROSIVE WATER CHEMICAL TREATMENT-REQUESTED BY M TRIPLETT KLR | 4/23/14 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | Repair roll up door in zone 3 shop area. | 4/29/14 | | | Sheet Metal |
| Maintenance Whse-OPS (8220) 2B | Please assist with repairs of Van 2804 - damaged from accident, ticketed driver did not have insurance. | 10/31/13 | | | Sheet Metal |

| | | | | | |
|------------------------------------|--|----------|---------|--|-------------|
| Maintenance Whse- OPS (8220) 2B | Cleanup isle adjacent to sheetmetal shop. | 10/21/13 | | | Sheet Metal |
| Maintenance Whse- OPS (8220) 2B | make sheet metal repairs to saw dust collector as needed-os | 11/6/13 | | | Sheet Metal |
| Maintenance Whse- OPS (8220) 2B | Fabricate bracket for bearing mounts for unit vents at various locations. | 1/8/14 | | | Sheet Metal |
| Maintenance Whse- OPS (8220) 2B | Weld motor for small engines. | 9/11/13 | Grounds | | Sheet Metal |
| Maintenance Whse- OPS (8220) 2B | Please built a cover over spray tank motor to protect from weather. Tank is on truck # 2104 | 9/30/13 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | |
|--------------------|---------|-----------|------------|------|----------|----------|------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| dry Whse-OPS (815) | 2 | 7 | 25 | 31 | 1 | 9 | 2 | 77 |
| Grand Total | 2 | 7 | 25 | 31 | 1 | 9 | 2 | 77 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|----------------------------|--|----------------|------|-------------|-------------|-----------|
| Mallory Whse-OPS (8153) 2B | Belt broken on a HP Design Jet 500 PS Plotter. | 9/20/13 | | | | Cabling |
| Mallory Whse-OPS (8153) 2B | Draw Equipment/Materials for Truck Stock. | 9/23/13 | | | | Cabling |
| Mallory Whse-OPS (8153) 2B | White copy paper | 6/30/14 | | | | Carpentry |
| Mallory Whse-OPS (8153) 2B | LIBRARY SERVICES DOOR CLOSURE IS BROKEN AND NEEDS TO BE REPAIRED. | 7/24/13 | | | | Carpentry |
| Mallory Whse-OPS (8153) 2B | Check roll up door east side of building. | 1/23/14 | | | | Carpentry |
| Mallory Whse-OPS (8153) 2B | Install tool box on truck # 2233. | 2/19/14 | | | | Carpentry |
| Mallory Whse-OPS (8153) 2B | per ms armstrong 416-5382 in library services the ceiling in caving in | 3/6/14 | | | | Carpentry |

| | | | | | |
|----------------------------|---|----------|-----------------|--|------------|
| Mallory Whse-OPS (8153) 2B | Replace roll up door | 3/7/14 | | | Carpentry |
| Mallory Whse-OPS (8153) 2B | Mens office install paper towel holder. | 4/14/14 | Restroom (Boys) | | Carpentry |
| Mallory Whse-OPS (8153) 2B | Need light bulbs replaced in the office of Textbooks-(Asset Management end of warehouse). | 4/30/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | I'm ordering 2 case of fluorescent light bulbs 36 to each case. | 6/19/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | A/C IN MAIL RM-NOT COOLING-CALLED IN BY R BRADEN 416-6484 KLR | 8/9/13 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Print shop ac down. | 8/19/13 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | A/C NOT COMING ON IN PRINT SHOP AREA-WILL NEED IN ORDER TO VENTILATE AREA WITH THE CHEMICALS THEY USE-REQUESTED BY R BRADEN KLR | 9/11/13 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Breaker in the electrical panel box trips every time we attempt to reset it. The breaker is for a whole row of lights. | 10/16/13 | | | Electrical |

| | | | | | |
|----------------------------|--|----------|--|--|------------|
| Mallory Whse-OPS (8153) 2B | CHECK OUTSIDE LIGHTS AROUND BUILDING. ALL LIGHTS TO BE WORKING CONDITION. | 11/12/13 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Inventory Control - heat is not working not coming on per Robert Braden 64116 | 12/3/13 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | HEAT INVENTORY CTRL AREA- NOT COMING ON-CALLED IN BY R BRADEN KLR | 12/19/13 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Replace lamps in print room front office. See Ken White for bulbs. | 1/3/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Please have an electrician check all the electric heaters in the pump houses @ 1384 Farmville first thing tomorrow morning | 1/6/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | HEAT ASSET MGMT-NOT COMING ON-CALLED IN BY C BROWN KLR Office on west end of building | 1/8/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Section of lights will not come on. Warehouse area on east end of building. Located next to administrative area east end. | 1/23/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | HEAT INVENTORY CTRL AREA- NOT COMING ON-CALLED IN BY R BRADEN KLR | 1/30/14 | | | Electrical |

| | | | | | |
|----------------------------|---|---------|--|------------|------------|
| Mallory Whse-OPS (8153) 2B | BREAKER FRONT OFC AREA- MAY BE TRIPPED-HALF THE LIGHTS AND HALF OF THE OFC RECEPTACLES HAVE NO POWER-CALLED IN BY S PORTER KLR | 2/21/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | HEAT PRINT SHOP AREA-NOT COMING ON-CALLED IN BY S PORTER KLR | 2/24/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Fire alarm show trouble. | 2/24/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Power outage. | 2/24/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Replace 12 light bulbs are blown. | 2/25/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Please wire the valve switches for the new valve that was installed in the first pump house Zone #7. Please be sure to call monitoring company to put system in test before wiring. Sprinkler Co. will come back out to set switches after they have been wired. | 3/19/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Continuation of light fixture replacement of six inoperative lamps in the warehouse. | 3/26/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | Circuit breaker #57 in Electrical Panel 3-PS Sec #2 keeps on tripping causing air compressor not to function. | 3/26/14 | | Print Shop | Electrical |

| | | | | | |
|----------------------------|---|---------|---------------------|--|---------------------------------------|
| Mallory Whse-OPS (8153) 2B | Continuation of light fixture replacement. Six (T-8)new lights. | 4/7/14 | 1st Floor | | Electrical |
| Mallory Whse-OPS (8153) 2B | Provide electric support for new overhead door installation. DOORPRO to install new door Tuesday. | 4/11/14 | | | Electrical |
| Mallory Whse-OPS (8153) 2B | On the Asset Management end of the warehouse, we need the lights on the dock looked at; they are not coming on. | 10/7/13 | Administration Area | | Electrical |
| Mallory Whse-OPS (8153) 2B | Air condition in the MAILROOM is not working; need attention ASAP. | 7/11/13 | Administration Area | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Monthly - Filter-Mallory Wharehouse - Refer to PM schedule details. | 4/18/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | library services and film/video units --- get model and serial number , manufactor | 9/30/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | TEXT BOOKS AREA - RTU - BLOWING NOT COOLING - ROBERT BRADEN | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | per joann 416-5382 in library services (1384 Farmville) a/c not cooling | 5/12/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| Mallory Whse-OPS (8153) 2B | LIBRARY SERVICES --- CLEAN COIL AND VACUUM WATER OUT OF PAN | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | No A/C print shop | 7/25/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | UNIT IN THE LIBRARY SERVICES IS MAKING A LOUD NOISE. | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Monthly - Filter-Mallory Wharehouse - Refer to PM schedule details. | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | A/C IN MAILRM-NOT COOLING-CALLED IN BY ROBERT BRADEN KLR | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Monthly - Oil Lube & Belt-Mallory Warehouse - Refer to PM schedule details. | 8/24/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | clean coils on mail rm | 9/5/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Monthly - Air Compressors-Mallory Whse - Refer to PM schedule details. | 9/20/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|----------|--|--|---------------------------------------|
| Mallory Whse-OPS (8153) 2B | c/o to heat | 10/22/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | A/C LIBRARY SERVICES OFC- NOT COMING ON-REQUESTED BY M MONTGOMERY KLR | 10/22/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | take parts off unit and put in storage | 10/23/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Boiler on north end needs belts and motor for exhaust fan | 11/8/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | HEAT INVENTORY CTRL AREA- NOT HEATING-CALLED IN BY R BRADEN 6114 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | CHECK HEAT IN MAIN OFFICE. COLD IN KEN WHITE OFFICE. | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Monthly - Filter-Mallory Warehouse - Refer to PM schedule details. | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | west end furnace not firing | 12/17/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| Mallory Whse-OPS (8153) 2B | check furnace | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | ASSET MGMT AREA TAMMY BRADFORD'S AREA-NOT HEATING-CALLED IN BY C BROWN KLR | 1/13/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | HEAT INVENTORY CTRL-NOT HEATING-CALLED IN BY R BRADEN KLR | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | HEAT LIBRARY SERVICES- AFTER POWER CAME BACK UP, IT STARTED POPPING ON & OFF-CALLED IN BY J ARMSTRONG KLR | 2/21/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | install heater in library services | 2/27/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | replace cordless drill --- for Brad Smith | 3/6/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | not heating | 3/18/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Monthly - Air Compressors-Mallory Whse - Refer to PM schedule details. | 3/21/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|------------|---------------------------------------|
| Mallory Whse-OPS (8153) 2B | Monthly - Oil Lube & Belt-Mallory Warehouse - Refer to PM schedule details. | 3/22/14 | | | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | HVAC vent is blowing out black partical debris onto print shop equipment. | 3/26/14 | | Print Shop | Heating/Ventilation /Air Conditioning |
| Mallory Whse-OPS (8153) 2B | Paint (1) new hollow metal door, gray. to support Jim Goudy loc. Carver High. | 2/18/14 | | | Painting |
| Mallory Whse-OPS (8153) 2B | A/C LIBRARY SERVICES CONFERENCE AREA-LEAKING-CALLED IN BY J ARMSTRONG 416-5365 KLR | 6/3/14 | | | Plumbing |
| Mallory Whse-OPS (8153) 2B | A/C UNIT is LEAKING in TEXTBOOKS Department per Robert Braden, Plant Mgr. 416.4116 | 6/20/14 | | | Plumbing |
| Mallory Whse-OPS (8153) 2B | GAS SMELL ON THE INVENTORY CTRL END-CALLED IN BY R BRADEN KLR | 8/26/13 | | | Plumbing |
| Mallory Whse-OPS (8153) 2B | Change filter on ice machine. (Located by mail room). Machine will not run at present. | 9/17/13 | | | Plumbing |
| Mallory Whse-OPS (8153) 2B | Womens RR north end of building toilet stuck flushing. | 2/10/14 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|------------------|--|----------|
| Mallory Whse-OPS (8153) 2B | Reoar Womens RR at north end stuck in flushing mode. | 2/11/14 | | | Plumbing |
| Mallory Whse-OPS (8153) 2B | Replace broken handle in Womens RR south end ; I. control. | 2/11/14 | | | Plumbing |
| Mallory Whse-OPS (8153) 2B | Library service smell in bathroom. | 3/6/14 | Library | | Plumbing |
| Mallory Whse-OPS (8153) 2B | West end womens restroom sink handle broken. | 4/14/14 | Restroom (Girls) | | Plumbing |
| Mallory Whse-OPS (8153) 2B | ROOF LIBRARY SERVICES-LEAKING-CALLED IN BY R BRADEN KLR | 12/9/13 | | | Roof |
| Mallory Whse-OPS (8153) 2B | On the west end (library service) roof leak. There are two areas that 2x4 lay in tiles are damaged by water. Ref. WO-420881. | 3/7/14 | Library | | Roof |

| Count of Craft | Craft | | | | | | | | | |
|------------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Line Smith Steam (2200 | 2 | 5 | 20 | 29 | 19 | 10 | 29 | 9 | 7 | 130 |
| Grand Total | 2 | 5 | 20 | 29 | 19 | 10 | 29 | 9 | 7 | 130 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|---------------------------------|--|----------------|------------------|------------------|----------|
| Maxine Smith Steam (2200) 2A | Please wrap condensating pipes outside of cafe and hall, this is creating a slip and fall hazard. Thanks! Plant Manger | 8/13/13 | Hallway/Corridor | 1st FL | Asbestos |
| Maxine Smith Steam (2200) 2A | Please clean surface of court, add coating to floor. Thanks! Plant Manger. | 10/1/13 | Gym | Basketball Court | Asbestos |
| Maxine Smith Steam (2200) 2A | Please provide ethernet connection for the Johnson EMS panel in boiler room. (Request Network Cabling Project Management). | 8/5/13 | Mechanical Room | | Cabling |
| Maxine Smith Steam (2200) 2A | Please have tect check or replace LSM drop in the boiler room. Thanks Plant Manger (Request Network Cabling Project Management). | 8/5/13 | Mechanical Room | boiler room | Cabling |
| Maxine Smith Steam (2200) 2A | 4009- I D Net, corroded cable, corroded battery. Please replace, Thanks Plant Manger.(Request Network Cabling Maintenance Repair). (SCS Network Cabling and Electronics Dept. Response) | 8/5/13 | Data Closet | 2nd floor | Cabling |
| Maxine Smith Steam (2200) 2A | Bad drop MDF-1. Thanks! Plant Manger(Request Network Cabling Maintenance Repair). | 8/19/13 | Classroom | 109 | Cabling |
| Maxine Smith Steam (2200) 2A | There are two bad data ports in Mr Franklin's room- The port numbers are 102-3 and 102-6, per Mr McKim (the IT guy). Please correct. Thanks! Plant Manager. | 12/2/13 | Classroom | 102 | Cabling |

| | | | | | |
|---------------------------------|--|---------|------------------|--|-----------|
| Maxine Smith Steam (2200) 2A | Please place door stop behind restroom door. Wall has been repaired, there's no way to keep the door from hitting the wall. Thanks! Plant Manager. | 6/23/14 | Restroom (Boys) | 1st floor south | Carpentry |
| Maxine Smith Steam (2200) 2A | Plant Manager is requesting special cuts for replacement damage ceiling tiles. Thanks! Plant Manager. | 6/24/14 | Hallway/Corridor | 1st-2nd-3rd Floors | Carpentry |
| Maxine Smith Steam (2200) 2A | Please repair broken window. Thanks Plant Manager. | 5/5/14 | 1st Floor | West Main Entrance | Carpentry |
| Maxine Smith Steam (2200) 2A | Request tank be remove out of the boiler room. | 5/6/14 | | | Carpentry |
| Maxine Smith Steam (2200) 2A | Request to paint trim. | 5/8/14 | | | Carpentry |
| Maxine Smith Steam (2200) 2A | Please repair sprung door or hinges. Thanks! Plant Manager. | 6/11/14 | 1st Floor | Boys and Girls restrooms north and south | Carpentry |
| Maxine Smith Steam (2200) 2A | Request sign be made for the front of the school with new name. (MAXINE SMITH STEAM ACADEMY) | 6/5/14 | | | Carpentry |
| Maxine Smith Steam (2200) 2A | WINDOW BANDRM STORAGE RM-BROKEN OUT-SAFETY ISSUE-PLANT MGR KING 416-9508 KLR | 5/21/14 | | | Carpentry |

| | | | | | |
|---------------------------------|---|---------|------------------|-----------------|-----------|
| Maxine Smith Steam (2200) 2A | Please replace rotten wood, in the southwest corner. Next to window. Thanks! Plant Manager. | 4/3/14 | Classroom | 123 | Carpentry |
| Maxine Smith Steam (2200) 2A | Please reattach toilet stall wall to pole. Thanks! Plant Manager. | 2/3/14 | Restroom (Boys) | 1st fl south | Carpentry |
| Maxine Smith Steam (2200) 2A | Please have welder to reweld broken gate. due to ware. Thanks! Plant Manager. | 2/3/14 | Parking Lot | North gate | Carpentry |
| Maxine Smith Steam (2200) 2A | ROOF IS LEAKING WATER IN GYM FLR. PLANT MGR-KING/205.8663 This is not a roof leak. Leaking through HVAC duct. | 2/4/14 | | | Carpentry |
| Maxine Smith Steam (2200) 2A | per mr king 416-9508 room 308 handle on door is off | 2/12/14 | | | Carpentry |
| Maxine Smith Steam (2200) 2A | Railing is loose from the wall. Please repair. Thanks Plant Manger | 7/26/13 | Hallway/Corridor | Across from 104 | Carpentry |
| Maxine Smith Steam (2200) 2A | Please repair door handle. Thanks Plant Manger | 7/31/13 | Library | 218A | Carpentry |
| Maxine Smith Steam (2200) 2A | Please replace broken door closer. Thanks! Plant Manger | 8/14/13 | Gym | West Entrance | Carpentry |

| | | | | | |
|---------------------------------|--|----------|------------------|-----------------|------------|
| Maxine Smith Steam (2200) 2A | Please deliver 2 bundles of fire rated ceiling titles. Thanks! Plant Manger | 8/21/13 | Hallway/Corridor | Ceiling | Carpentry |
| Maxine Smith Steam (2200) 2A | Bolts on the picnic table tops, have broken off. Please repair as soon as possible. Thanks! Plant Manger. | 9/26/13 | Grounds | North Side | Carpentry |
| Maxine Smith Steam (2200) 2A | Please deliver 2(two) bundles of hard fire rated ceiling titles. Thanks! Plant Manger. | 10/11/13 | Hallway/Corridor | ceiling | Carpentry |
| Maxine Smith Steam (2200) 2A | Please reattach partition wall in between urinals, see Plant Manager for the wall. Thanks! Plant Manager. | 12/3/13 | Restroom (Boys) | 1st floor North | Carpentry |
| Maxine Smith Steam (2200) 2A | Please replace Simplex 4009 I D Net battery-fault is making alarm sound. | 7/1/13 | Data Closet | 2nd Floor | Electrical |
| Maxine Smith Steam (2200) 2A | PARTIAL POWER OUTAGE PLANT MGR-KING/205.8663 | 4/28/14 | | | Electrical |
| Maxine Smith Steam (2200) 2A | Please check batteries in emergency lights. Thanks! Plant Manager. | 4/28/14 | Cafeteria | south wall | Electrical |
| Maxine Smith Steam (2200) 2A | disconnect electrical lb from power pole (no power to bldg.) to small portable (MORGAN) bldg. Grounds will make bldg. go away. -os | 5/21/14 | | | Electrical |

| | | | | | |
|---------------------------------|--|---------|---------------------|----------------------------|------------|
| Maxine Smith Steam (2200) 2A | Please replace 5 blown light bulbs(PL-T 42W/35/4P), will need 12 bulbs of listed number above. Thanks! Plant Manager. | 4/2/14 | Gym | Outside lighting | Electrical |
| Maxine Smith Steam (2200) 2A | Please replace blown light bulbs,(Quartz 500 watts-120 volts bulbs please send 10 bulbs. Attention: Richard Powell. Thanks! Plant Manager. | 4/21/14 | Auditorium | North wall lights | Electrical |
| Maxine Smith Steam (2200) 2A | UV IS SMOKING IN RM-118 PLANT MGR-KING/416.4536 | 1/8/14 | | | Electrical |
| Maxine Smith Steam (2200) 2A | Plant Manager is requesting repair of 12 light fixtures, which are not operating. Please repair. Thanks! Plant Manager. (west,north,east) | 2/4/14 | Parking Lot | Outside Lighting | Electrical |
| Maxine Smith Steam (2200) 2A | Please reconnect wiring to fire damper duct. Wiring was pulled from junction box. Thanks! Plant Manager. | 2/13/14 | Gym | Boys Locker room | Electrical |
| Maxine Smith Steam (2200) 2A | Please repair outside entrance lights. Thanks! Plant Manager. | 2/21/14 | 1st Floor | Main entrance west/outside | Electrical |
| Maxine Smith Steam (2200) 2A | Please reset clocks for up coming daylight savings time.Thanks! Plant Manager. | 2/21/14 | Administration Area | 2nd fl | Electrical |
| Maxine Smith Steam (2200) 2A | Please correct time to clock, bells are ringing on the P.M. time. Thanks! Plant Manager. | 3/19/14 | Data Closet | 2nd | Electrical |

| | | | | | |
|---------------------------------|---|---------|-----------|--------------|------------|
| Maxine Smith Steam (2200) 2A | Outlet on the west wall has no power, please repair. Thanks Plant Manger | 7/26/13 | Custodial | 118 | Electrical |
| Maxine Smith Steam (2200) 2A | UV-B1 RM 103 SOUTH (130), UV-B1 RM 103 CTR (130) & UV-B1 RM 103 NORTH (130)-ALL NOT COMING ON-SBE KING 416-9508 KLR | 8/5/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | UV RM 230 & CAFE-ALL NOT COMING ON-PLANT MGR KING 416-9508 KLR | 8/28/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | Unit Vent 1-4, North east unit. No power, Per Bobby Barlow. Thanks! Plant manger | 9/5/13 | Cafeteria | Dinning Area | Electrical |
| Maxine Smith Steam (2200) 2A | Unit Vent 1-3 North west unit. Fan will not work. Per Bobby Barlow. Thanks! Plant Manger | 9/5/13 | Cafeteria | Dinning Area | Electrical |
| Maxine Smith Steam (2200) 2A | Unit Vent 1-7 South east unit. Fan will not work. Thanks! Plant Manger | 9/5/13 | Cafeteria | Dinning Area | Electrical |
| Maxine Smith Steam (2200) 2A | AHU NOT COMING ON IN RM-202B PLANT MGR-KING/416.4536 | 9/12/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | Please check electrical socket, for fault. North Wall. Thanks! Plant Manger. | 10/8/13 | Classroom | 314 | Electrical |

| | | | | | |
|---------------------------------|---|----------|-----------|-----------------------|------------|
| Maxine Smith Steam (2200) 2A | Please check electrical socket, no power. Thanks! Plant Manger. | 10/8/13 | Gym | southwest wall | Electrical |
| Maxine Smith Steam (2200) 2A | HAS A COMPLETE POWER OUTAGE-PLANT MGR KING KLR | 11/1/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | LIGHTS -1ST FLR SOUTH - ENTIRE SECTION IS OUT - PM/KING 416-9508 | 11/4/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | Please change out 84 blown ballast, on the south wing. Electricians have addressed this problem. Thanks! Plant Manager. | 11/4/13 | Classroom | 1st floor South (All) | Electrical |
| Maxine Smith Steam (2200) 2A | entire school without power per Mr. King 416-9508 | 11/6/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | Please repair or replace light clips, bulb will not stay in place. Thanks! Plant Manager. | 11/11/13 | Elevator | overhead lights | Electrical |
| Maxine Smith Steam (2200) 2A | LOOP PUMP-2 MECH RM-NOT COMING ON-PLANT MGR KING 416-9060 KLR | 11/25/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | HEAT RM 132-NOT COMING ON-PLANT MGR KING 416-9508 KLR | 12/9/13 | | | Electrical |

| | | | | | |
|---------------------------------|--|----------|--|--|---------------------------------------|
| Maxine Smith Steam (2200) 2A | RTU NOT COMING ON IN RM-322 PLANT MGR-KING/205.8663 | 12/10/13 | | | Electrical |
| Maxine Smith Steam (2200) 2A | UNIT NOT COOLING IN RM-230 PLANT MGR-KING/205.8663 | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | RTU - RM 216 - ADMIN OFC - BLOWING NOT COOLING - PM/KING 416-9508 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | A/C RM 216 ADMINISTRATION OFC-NOT COOLING-PLANT MGR KING 416-9508 KLR | 6/20/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | RTU -COVERS RM 216 - NOT COMING ON - PM/KING 416-9508 | 6/5/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | PUMP#5 IS MAKING NOISE IN BOILER RM PLANT MGR-KING/205.8663 | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | Monthly - Air Compressor - Fairview Middle - Refer to PM schedule details. | 1/14/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------------------|--|---------|--|--|--|
| Maxine Smith Steam (2200) 2A | Monthly - Oil Lube & Belt- Fairview Middle - Refer to PM schedule details. | 1/20/14 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | Monthly - Air Compressor - Fairview Middle - Refer to PM schedule details. | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | rm 131 ID113076, 77, 78 no power to a/c rm 112 id113089, 87 no power rm 114 id113070 no power | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | AHU-7 ROOF BEHINC BALCONY SERVES RMS 301 & 302-NOT COOLING-SBE KING 416-9508 KLR | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | AHU RMS 202, 203, & 118-ALL NOT COOLING-PLANT MGR KING 416-9508 KLR | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | RTU NOT COOLING IN KITCHEN PLANT MGR-KING/416.4536 | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | 2-AHU NOT COOLING IN RM- 202B, & IN RM-118 PLANT MGR-KING/416.4536 | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | RTU-7 SERVES RM 322 ADMIN OFC-NOT COOLING-PLANT MGR KING 416-9508 KLR | 9/25/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------------|---|----------|---------------------|-------------------|--|---------------------------------------|
| Maxine Smith Steam (2200) 2A | Monthly - Filter-Fairview Middle - Refer to PM schedule details. | 10/8/13 | | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | Loop pump 2 has frozen up, please repair. Thanks! Plant Manager. | 11/11/13 | Mechanical Room | basement | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | Monthly - Filter-Fairview Middle - Refer to PM schedule details. | 6/10/14 | | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | Monthly - Filter-Fairview Middle - Refer to PM schedule details. | 2/11/14 | | | | Heating/Ventilation /Air Conditioning |
| Maxine Smith Steam (2200) 2A | Wall on the south side of the office, needs to be touch up. thanks Plant Manger | 7/3/13 | Administration Area | Office/322C | | Painting |
| Maxine Smith Steam (2200) 2A | Please have painters touch up walls. Thanks Plant Manger. | 7/3/13 | 1st Floor | North/South Halls | | Painting |
| Maxine Smith Steam (2200) 2A | Please replaster crack wall on south side. Thanks! Plant Manager. | 12/11/13 | Library | 218A | | Painting |
| Maxine Smith Steam (2200) 2A | Plant Manager is requesting for the entire first floor and cafe, to be painted (per new principal for STEAM). Thanks Plant Manager. | 3/27/14 | Hallway/Corridor | 1st floor | | Painting |

| | | | | | |
|---------------------------------|---|---------|---------------------|------------------|----------|
| Maxine Smith Steam (2200) 2A | Please paint trim, in the southwest corner. Thanks! Plant Manager. | 5/8/14 | Classroom | 123 | Painting |
| Maxine Smith Steam (2200) 2A | Please have painters to paint doors, paint is on site. Thanks! Plant Manager. | 6/4/14 | 1st Floor | North fire doors | Painting |
| Maxine Smith Steam (2200) 2A | Please repair very large hole in the wall, behind restroom door. Thanks! Plant Manager. | 6/4/14 | Restroom (Boys) | South | Painting |
| Maxine Smith Steam (2200) 2A | Please paint over peeling paint surfaces. See Plant Manager for paint. Thanks! Plant Manager. | 1/23/14 | Administration Area | 216 | Painting |
| Maxine Smith Steam (2200) 2A | paint walls in room 324 | 9/11/13 | | | Painting |
| Maxine Smith Steam (2200) 2A | paint walls and trim in classroom 324 | 9/24/13 | | | Painting |
| Maxine Smith Steam (2200) 2A | Repair drain. | 5/28/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Flush sewer main | 5/5/14 | | | Plumbing |

| | | | | | | |
|---------------------------------|---|---------|-----|--|----------------|----------|
| Maxine Smith Steam (2200) 2A | PIPE is LEAKING in 3RD FLOOR HALL N. per Mr. King, Plant Mgr. 416.9508 | 6/12/14 | | | | Plumbing |
| Maxine Smith Steam (2200) 2A | UNIT VENTS -RM 115 & RM 109 CRACK DRAIN PANS LEAKING - PM/KING 416-9508 | 6/5/14 | | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Repair sewer & flush lines | 6/9/14 | | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Please replace stripped hot water faucet, on the hand sink. Thanks! Plant Manager. | 5/14/14 | Gym | | Girls restroom | Plumbing |
| Maxine Smith Steam (2200) 2A | Flush sewer lines | 5/20/14 | | | | Plumbing |
| Maxine Smith Steam (2200) 2A | rm 112 id113086 a/c leaking rm 115 id113068 a/c leaking per mr. king | 7/30/13 | | | | Plumbing |
| Maxine Smith Steam (2200) 2A | per mr king 416-9508 in the gym all the drains are backing up | 4/10/14 | | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Please have plumber, repair broken outside cleanout drains. On the north side of the gym. Thanks! Plant Manager. | 4/10/14 | Gym | | Grounds | Plumbing |

| | | | | | |
|---------------------------------|--|---------|-----------|------------------------------|----------|
| Maxine Smith Steam (2200) 2A | GAS LINE KITCHEN AREA- LEAKING PER SBE-PLANT MGR KING 416-9508 KLR | 1/9/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Sewer drain backing up. | 2/11/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Unstop Main Sewer | 2/12/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | 2-COM SINK HOT WATER CONTINUES TO RUN, CANT SHUT OFF IN KITCHEN PLANT MGR-KING/416.4536 | 2/25/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Please have outside cleanouts cleaned, to prevent backup, for upcoming events. Thanks! Plant Manager. | 3/17/14 | Gym | Clean outs | Plumbing |
| Maxine Smith Steam (2200) 2A | PUMP-6 MECH RM-SEAL HAS BROKEN AND WATER EVERYWHERE, CAN'T CONTAIN-PLANT MGR KING 416-9508 KLR | 3/24/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Unstop main drain to gym | 7/10/13 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Drain line is leaking outside of cafeteria. Second leake main hall west ceiling. Thanks Plant Manger | 7/26/13 | 1st Floor | 120/cafe/1st fl hall west | Plumbing |

| | | | | | |
|---------------------------------|--|---------|------------------|-----------------|----------|
| Maxine Smith Steam (2200) 2A | WATER LINE FROM HOT WATER TANK IN 1ST FLR CUST CLOSET-LEAKING-SBE KING 416-9508 KLR | 8/1/13 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | RM 11 UNIT DRAIN PAN IS LEAKING. SBE KING 416-9508 | 8/7/13 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Please replace or repair toilet seats. Thanks! Plant Manger | 8/8/13 | Restroom (Girls) | 1st floor-south | Plumbing |
| Maxine Smith Steam (2200) 2A | GAS LEAK FROM OVEN KITCHEN PLANT MGR-KING/416.9508 | 8/21/13 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Request back flow test. | 9/5/13 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Unit Vent 1-5 Center Unit. No water flow. Per Bobby Barlow Thanks! Plant Manger | 9/5/13 | Cafeteria | Dinning Area | Plumbing |
| Maxine Smith Steam (2200) 2A | Unit Vent 1-8 No water flow. Per Bobby Barlow. Thanks! Plant Manger. | 9/5/13 | Custodial | Room 118 | Plumbing |
| Maxine Smith Steam (2200) 2A | Please replace broken toilet seat, second stall. Thanks! Plant Manger | 9/20/13 | Restroom (Girls) | 1st floor north | Plumbing |

| | | | | | |
|---------------------------------|---|----------|-----------------|----------------------|----------|
| Maxine Smith Steam (2200) 2A | Please replace crack toilet. Thanks! Plant Manger | 9/20/13 | Restroom (Boys) | 2nd fl south | Plumbing |
| Maxine Smith Steam (2200) 2A | There is a pedestal hydrant on the north side of the roof, no water pressure. please repair. Thanks! Plant Manager. | 11/20/13 | 3rd Floor | Roof | Plumbing |
| Maxine Smith Steam (2200) 2A | Request backhoe support to repair a drain. | 5/28/14 | | | Plumbing |
| Maxine Smith Steam (2200) 2A | Please install roof drains on the south side and southwest corner of the building, water is sitting 2 to 3 inches. Thanks! Plant Manager. | 6/30/14 | 3rd Floor | Roof | Roof |
| Maxine Smith Steam (2200) 2A | Please have roofer to clean drains or pump water off north- south roof of cafeteria. No access, have to use ladder.Thanks! Plant Manager. | 6/13/14 | Cafeteria | Roof North- South | Roof |
| Maxine Smith Steam (2200) 2A | Please check roof for leak, above room 303 hall. Thanks! Plant Manager. | 6/16/14 | 3rd Floor | Roof | Roof |
| Maxine Smith Steam (2200) 2A | ROOF IS LEAKING WATER IN GYM FLR PLANT MGR-KING/416.4536 | 6/9/14 | | | Roof |
| Maxine Smith Steam (2200) 2A | Please repair ceiling leakes. Thanks! Plant Manager. | 4/4/14 | Classroom | 123 | Roof |

| | | | | | |
|---------------------------------|--|---------|-------------|--------------------------|-------------|
| Maxine Smith Steam (2200) 2A | Please repair roof leake. Thanks! Plant Manager. | 4/4/14 | Gym | Lobby | Roof |
| Maxine Smith Steam (2200) 2A | Please repair ceiling leake on the south side. Thanks! Plant Manager. | 4/4/14 | Cafeteria | Dinning area | Roof |
| Maxine Smith Steam (2200) 2A | Have leake in the main lobby, when it rains hard or storm. Please repair. Thanks! Plant Manager. | 2/3/14 | Gym | Lobby | Roof |
| Maxine Smith Steam (2200) 2A | Roof leake entrance to lobby. Please repair or patch. Thanks Plant Manger | 7/26/13 | Gym | | Roof |
| Maxine Smith Steam (2200) 2A | Please repair broken hinge on the gate, located on the north side on central. Thanks! Plant Manager. | 6/3/14 | Parking Lot | GATE | Sheet Metal |
| Maxine Smith Steam (2200) 2A | Request pan be repaired in the unit in room #115. | 6/6/14 | | | Sheet Metal |
| Maxine Smith Steam (2200) 2A | Please repair damage railing on the east side of the main building, near the cafeteria. Thanks Plant Manger | 7/26/13 | Grounds | Outside Railing | Sheet Metal |
| Maxine Smith Steam (2200) 2A | There is a section of railing that has been bent, please repair. Thanks! plant Manger | 8/14/13 | Grounds | Railing East Entrance | Sheet Metal |

| | | | | | |
|---------------------------------|---|---------|-----------|-------------|-------------|
| Maxine Smith Steam (2200) 2A | Drain pans are leaking on the floor. Please clear drain lines. Thanks! Plant Manger | 8/20/13 | Classroom | 109-112 | Sheet Metal |
| Maxine Smith Steam (2200) 2A | Please have RTU-4 fire damper in the gym and 1st floor pull station west entrance checked. Thanks! Plant Manger. | 9/21/13 | Gym | fire damper | Sheet Metal |
| Maxine Smith Steam (2200) 2A | Plant Manager is asking for two ladders to be installed, on the north and south landings of the cafeteria. No access to roof drains. Would like to have ladders installed from the main roof. Thanks! Plant Manager | 6/24/14 | 3rd Floor | Roof | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|----------------------|----------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| | Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| Melrose HS (2493) 24 | | 3 | 6 | 67 | 103 | 27 | 7 | 97 | 2 | 312 |
| Grand Total | | 3 | 6 | 67 | 103 | 27 | 7 | 97 | 2 | 312 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|--|----------------|------------------|---------------------------|---------------------------------------|
| Melrose Stadium 184-2B | door knob on pressbox is coming off, please repair | 8/3/13 | Athletic Field | | Carpentry |
| Melrose Stadium 184-2B | Please replace blown 20amp fuses in Homeside (Pressbox Side) Concession Stand fuse box. Lights were out Friday and we swapped a fuse to replace blown 20amp light fuse. Please replace | 10/8/13 | Concession Stand | | Electrical |
| Melrose Stadium 184-2B | no lights working in women's restroom. | 5/5/14 | Restroom (Girls) | | Electrical |
| Melrose Stadium 184-2B | no power in the pressbox | 5/5/14 | Restroom (Girls) | | Electrical |
| Melrose Stadium 184-2B | the lights in the homeside concession stand room (concession stand on pressbox side) are not working, please repair | 8/22/13 | Athletic Field | | Electrical |
| Melrose Stadium 184-2B | northwest corner bank of pole lights on home field (pressbox) side of stadium are not working, please repair. could be connected to home side concession stand light issue | 8/22/13 | Athletic Field | | Electrical |
| Melrose Stadium 184-2B | need elect. to assist Master elect. -os | 7/24/13 | | | Electrical |
| Melrose Stadium 184-2B | PANEL SHOWING TROUBLE, LOUD NOISES, BEEP SOUND | 4/2/14 | Mechanical Room | BOILER ROOM - LOWER LEVEL | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|------------------|--------------------|----------|
| Melrose Stadium 184-2B | commodes 1st/3rd stopped up | 5/6/14 | 2nd Floor | boy's rr west-hall | Plumbing |
| Melrose Stadium 184-2B | de-winterize and fix leaking pipes. | 3/18/14 | Concession Stand | | Plumbing |
| Melrose Stadium 184-2B | sink in women's restroom is leaking and creating a huge puddle on the floor, please repair | 3/25/14 | Restroom (Girls) | | Plumbing |
| Melrose Stadium 184-2B | urinal in men's restroom is continuing to run, please repair | 3/25/14 | Restroom (Boys) | | Plumbing |
| Melrose Stadium 184-2B | Pressure wash restrooms | 1/16/14 | | | Plumbing |
| Melrose Stadium 184-2B | check plumbing through out stadium, first game friday night. | 8/26/13 | | | Plumbing |
| Melrose Stadium 184-2B | sink in the concession stand is jammed up, please repair, we have play offs this Friday | 11/12/13 | Athletic Field | | Plumbing |
| Melrose Stadium 184-2B | Stadiums were winterized in late fall, please bring the water back online for the upcoming soccer and track & field season. Track Season starts March 1, 2014 and Soccer Season starts February 27, 2014. CHECK WEATHER REPORT & HEATERS | 2/24/14 | Athletic Field | | Plumbing |
| Melrose Stadium 184-2B | PIPE FRONT OF STADIUM-HAS BURST, WATER COMING UP THRU GROUND-PLANT MGR JEFFERSON KLR | 1/14/14 | | | Plumbing |

| Count of Craft | Craft | | | | |
|---------------------|-----------|------------|------|----------|-------------|
| Location | Carpentry | Electrical | HVAC | Plumbing | Grand Total |
| Elrose Stadium 184- | 1 | 6 | 1 | 9 | 17 |
| Grand Total | 1 | 6 | 1 | 9 | 17 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|--|----------------|------------------|---------------------------|--|
| Melrose Stadium 184-2B | door knob on pressbox is coming off, please repair | 8/3/13 | Athletic Field | | Carpentry |
| Melrose Stadium 184-2B | Please replace blown 20amp fuses in Homeside (Pressbox Side) Concession Stand fuse box. Lights were out Friday and we swapped a fuse to replace blown 20amp light fuse. Please replace | 10/8/13 | Concession Stand | | Electrical |
| Melrose Stadium 184-2B | no lights working in women's restroom. | 5/5/14 | Restroom (Girls) | | Electrical |
| Melrose Stadium 184-2B | no power in the pressbox | 5/5/14 | Restroom (Girls) | | Electrical |
| Melrose Stadium 184-2B | the lights in the homeside concession stand room (concession stand on pressbox side) are not working, please repair | 8/22/13 | Athletic Field | | Electrical |
| Melrose Stadium 184-2B | northwest corner bank of pole lights on home field (pressbox) side of stadium are not working, please repair. could be connected to home side concession stand light issue | 8/22/13 | Athletic Field | | Electrical |
| Melrose Stadium 184-2B | need elect. to assist Master elect. -os | 7/24/13 | | | Electrical |
| Melrose Stadium 184-2B | PANEL SHOWING TROUBLE, LOUD NOISES, BEEP SOUND | 4/2/14 | Mechanical Room | BOILER ROOM - LOWER LEVEL | Heating/Ventilation / Air Conditioning |

| | | | | | |
|------------------------|---|----------|------------------|--------------------|----------|
| Melrose Stadium 184-2B | commodes 1st/3rd stopped up | 5/6/14 | 2nd Floor | boy's rr west-hall | Plumbing |
| Melrose Stadium 184-2B | de-winterize and fix leaking pipes. | 3/18/14 | Concession Stand | | Plumbing |
| Melrose Stadium 184-2B | sink in women's restroom is leaking and creating a huge puddle on the floor, please repair | 3/25/14 | Restroom (Girls) | | Plumbing |
| Melrose Stadium 184-2B | urinal in men's restroom is continuing to run, please repair | 3/25/14 | Restroom (Boys) | | Plumbing |
| Melrose Stadium 184-2B | Pressure wash restrooms | 1/16/14 | | | Plumbing |
| Melrose Stadium 184-2B | check plumbing through out stadium, first game friday night. | 8/26/13 | | | Plumbing |
| Melrose Stadium 184-2B | sink in the concession stand is jammed up, please repair, we have play offs this Friday | 11/12/13 | Athletic Field | | Plumbing |
| Melrose Stadium 184-2B | Stadiums were winterized in late fall, please bring the water back online for the upcoming soccer and track & field season. Track Season starts March 1, 2014 and Soccer Season starts February 27, 2014. CHECK WEATHER REPORT & HEATERS | 2/24/14 | Athletic Field | | Plumbing |
| Melrose Stadium 184-2B | PIPE FRONT OF STADIUM-HAS BURST, WATER COMING UP THRU GROUND-PLANT MGR JEFFERSON KLR | 1/14/14 | | | Plumbing |

| Count of Staff | Grade | | | | | | | | Grand Total |
|------------------|-----------|---------|-----------|------------|------|---------|----------|------|-------------|
| | Admission | Cooking | Carpentry | Electrical | Auto | Welding | Shumbing | Boat | |
| Black CTC (2021) | 2 | 2 | 8 | 73 | 44 | 3 | 27 | 3 | 162 |
| Grand Total | 2 | 2 | 8 | 73 | 44 | 3 | 27 | 3 | 162 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-----------------------|--|----------------|---------------------|---------------------------|-----------|
| Messick CTC (2494) 2A | I need the gym floor done | 10/2/13 | Gym | bldg-C / basketball court | Asbestos |
| Messick CTC (2494) 2A | we have steam coming out of the floor on the first floor in the main building | 2/4/14 | Administration Area | | Asbestos |
| Messick CTC (2494) 2A | The wall outlet for the telephone and computer need repaired. | 9/4/13 | Administration Area | bldg-C/ 102/ offices | Cabling |
| Messick CTC (2494) 2A | The cable wiring to the smart board speaker is broken off. It needs to be replaced with a new cable. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 9/30/13 | Classroom | bldg-C / 102 | Cabling |
| Messick CTC (2494) 2A | On the west side where the panel box behind the pipe a hole is in the wall and birds are coming in. | 5/19/14 | Basketball Court | Gym | Carpentry |
| Messick CTC (2494) 2A | NEED BOLT CUTTERS FOR LOCKS-REQUESTED BY REED KLR | 10/4/13 | | | Carpentry |
| Messick CTC (2494) 2A | we have a center bar on B build need fixing asap | 10/9/13 | | | Carpentry |

| | | | | | |
|-----------------------|---|----------|---------------------|---------------------|------------|
| Messick CTC (2494) 2A | I need a bulletin board 4 x 8 installed on the wall in front of the desk | 10/18/13 | Administration Area | bldg-C / 102-office | Carpentry |
| Messick CTC (2494) 2A | Pick-up ac units from Pope'S Supply. | 10/31/13 | | | Carpentry |
| Messick CTC (2494) 2A | I need the ceiling tiles replace, I need a lift to reach them | 4/30/14 | Administration Area | Bldg-D | Carpentry |
| Messick CTC (2494) 2A | I need two bulletin board (3x6)and other (4x8). | 8/15/13 | Hallway/Corridor | bldg-B / 1st floor | Carpentry |
| Messick CTC (2494) 2A | have a broken hand rail in bldg A by the main door on the first floor | 8/28/13 | Hallway/Corridor | | Carpentry |
| Messick CTC (2494) 2A | check the ac in the cafeteria two are not working | 5/21/14 | Cafeteria | | Electrical |
| Messick CTC (2494) 2A | A/C RM 207 & CAFE (2) UNITS-ALL NOT COMING ON-PLANT MGR WHITE 416-4840 KLR | 6/9/14 | | | Electrical |
| Messick CTC (2494) 2A | 5-UNITS NOT COMING ON IN RM- A303,C303,C306,C201, A205 PLANT MGR-WHITEHEAD/619.2334 | 6/16/14 | | | Electrical |

| | | | | | |
|-----------------------|---|----------|------------------|--|------------|
| Messick CTC (2494) 2A | outlet out in room 303 in build C | 5/7/14 | Classroom | | Electrical |
| Messick CTC (2494) 2A | need two ballast in room 200 in build C | 10/10/13 | Hallway/Corridor | | Electrical |
| Messick CTC (2494) 2A | need a ballast on the hallway by the lunch room | 10/10/13 | | | Electrical |
| Messick CTC (2494) 2A | I need some lights keys the only one I have broke can I get about five keys also can you put them in a envelope address to mr.white p.s need both types of keys | 10/14/13 | | | Electrical |
| Messick CTC (2494) 2A | need a ballast in room 102 Build C office | 10/15/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | Can so one check the lights on the 2nd floor in build B it is dark on the hallway asap (emergency) | 10/15/13 | Hallway/Corridor | | Electrical |
| Messick CTC (2494) 2A | A/C not working in the main office. | 7/23/13 | | | Electrical |
| Messick CTC (2494) 2A | RECEPTACLE - IN THE CAFE - NONE ARE WORKING - PM/DEMON 416-4048 | 7/30/13 | | | Electrical |

| | | | | | |
|-----------------------|--|---------|---------------------|--------|------------|
| Messick CTC (2494) 2A | need a ballaster in room 201 in bldg c | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | need a light ballaster in room 203 in bldg c | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | need a ballaster in room 207 in bldg c | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | need a ballaster in room 306 in bldg c | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | In bldg c in room 102 the ends on the lights are bad | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | the outside light by the c bldg and a bldg keep going in and out the one on a bldg and the one on c bldg | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | The light under the walk way by the main office need a ballaster | 8/12/13 | | | Electrical |
| Messick CTC (2494) 2A | The main clock/ master clock need to be set. | 3/18/14 | Administration Area | Bldg-A | Electrical |

| | | | | | |
|-----------------------|---|---------|-----------|-------------|------------|
| Messick CTC (2494) 2A | I need the outside light fixed, it will not come on. | 3/19/14 | | Gym | Electrical |
| Messick CTC (2494) 2A | Install new highbay light fixtures. (25) | 3/24/14 | Gym | | Electrical |
| Messick CTC (2494) 2A | The window A/C unit is brokedand will not run. | 4/2/14 | Classroom | Bldg-A/ 205 | Electrical |
| Messick CTC (2494) 2A | per ms denman 416-4840 gym main front office lights won't come on breaker bad | 4/2/14 | | | Electrical |
| Messick CTC (2494) 2A | FIRE ALARM IS IN TROUBLE PLANT MGR-DENAMN/416.5028 | 4/4/14 | | | Electrical |
| Messick CTC (2494) 2A | Please give me 4 boxes of 4ft light tubes used for classrooms | 4/25/14 | | | Electrical |
| Messick CTC (2494) 2A | need lamps f32T8/ADV841/EW need 108 lights | 8/15/13 | 1st Floor | | Electrical |
| Messick CTC (2494) 2A | WINDOW UNIT NOT COOLING IN RM-105B PLANT MGR-DENMAN/416.4840 | 8/19/13 | | | Electrical |

| | | | | | |
|-----------------------|--|---------|---------------------|----------------------|------------|
| Messick CTC (2494) 2A | Lights out on main floor, need a 12 foot ladder. | 8/23/13 | Administration Area | bldg-D/ main offices | Electrical |
| Messick CTC (2494) 2A | we have two lights need ballaster in the file room in bldg d | 8/23/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | can i get 9 case if light 32t8/adv841/ew | 8/23/13 | Custodial | | Electrical |
| Messick CTC (2494) 2A | the ac in the principal office do not work the #012-038 | 8/27/13 | Administration Area | | Electrical |
| Messick CTC (2494) 2A | no ac in room 306 in bldg C #101127 | 8/28/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | BLDG B room 203 need two ballaster | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | room 204 need a light cover | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | 204 in bldg B need 12 lights ballaster | 8/30/13 | Classroom | | Electrical |

| | | | | | |
|-----------------------|--|---------|------------------|--|------------|
| Messick CTC (2494) 2A | room 207 in bldg B need 4 ballaster | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | room 213 in bldg b need 4 ballaster | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | room 214 need 4 ballaster | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | room 215 need 2 ballaster bldg b | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | room 215 in bldg b need 2 ballaster | 8/30/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | boys restroom in bldg b on the 2nd floor need ballaster | 8/30/13 | Restroom (Boys) | | Electrical |
| Messick CTC (2494) 2A | girls restroom in bldg b need a ballaster | 8/30/13 | Restroom (Girls) | | Electrical |
| Messick CTC (2494) 2A | light cover need fixing by the girls restroom on thr 1st floor | 8/30/13 | Hallway/Corridor | | Electrical |

| | | | | | |
|-----------------------|--|---------|------------------|--|------------|
| Messick CTC (2494) 2A | the office in the bldg b need two ballaster office 102 | 8/30/13 | 1st Floor | | Electrical |
| Messick CTC (2494) 2A | men restroom in bldg b on the 1st floor need a ballaster | 8/30/13 | Restroom (Boys) | | Electrical |
| Messick CTC (2494) 2A | the library in bldg b need 8 ballaster | 8/30/13 | Library | | Electrical |
| Messick CTC (2494) 2A | lights in the b bldg on the stairway to tall do not have a tall ladder | 8/30/13 | Hallway/Corridor | | Electrical |
| Messick CTC (2494) 2A | have five lights out in bldg D to tall ceiling | 9/5/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | I need lamp the side i need is f96t8.sp41 I need the lamps on the fast track ASAP the shop worker can not see in the electrical shop need about five case thank you | 9/9/13 | Machine Shop | | Electrical |
| Messick CTC (2494) 2A | need 22 ballaster in the shop in the B bldg the shop teacher check all the lamps he said the ballaster are bad need the lights fix ASAP can not see in the electrical shop | 9/10/13 | Machine Shop | | Electrical |
| Messick CTC (2494) 2A | Window unit is NOT COMING ON in Bldg. C, RM 205 per Ms. Denman, Plant Mgr. 416.4048 | 9/11/13 | | | Electrical |

| | | | | | |
|-----------------------|---|----------|---------------------|---------------------------|------------|
| Messick CTC (2494) 2A | I have lights out on the park lot by the Aud. and teacher's parking lot. | 9/13/13 | Administration Area | bldg-C/parking lot by Aud | Electrical |
| Messick CTC (2494) 2A | EXPOSE WIRES COMING FROM EXIT LIGHT ON 2ND FLR C-BLDG PLANT MGR- DENMAN/416.4840 | 9/23/13 | | | Electrical |
| Messick CTC (2494) 2A | The outside lights on the building B at the greer side at the flower pot. and the front and side of the gym | 9/23/13 | Administration Area | bldg-gym / Bldg-B | Electrical |
| Messick CTC (2494) 2A | need six ballaster in the D building | 9/23/13 | | | Electrical |
| Messick CTC (2494) 2A | need a light ballaster in room 307 in the build C | 9/23/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | need a ballaster in room 206 C building | 9/25/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | need a ballaster in the room 104 in building A in the jatc office | 9/26/13 | | | Electrical |
| Messick CTC (2494) 2A | steam boiler not coming on in building A per martha denman 416-4048 | 11/13/13 | | | Electrical |

| | | | | | |
|-----------------------|--|----------|-----------------|------------|------------|
| Messick CTC (2494) 2A | check the lights in the gym lobby all the center light are not working | 11/21/13 | Gym | | Electrical |
| Messick CTC (2494) 2A | need a basllast in the boys restroom in the gym in the lobby | 11/27/13 | Restroom (Boys) | | Electrical |
| Messick CTC (2494) 2A | outlet out in room 201 building A need to be fix | 12/16/13 | Classroom | | Electrical |
| Messick CTC (2494) 2A | The outlet in the wall donot work, there is no power. | 12/18/13 | Classroom | bldg-A/201 | Electrical |
| Messick CTC (2494) 2A | Building "B" in the Shop room unit is NOT COMING ON per Ms. Denman, Plant Mgr. 416.4048. | 1/6/14 | | | Electrical |
| Messick CTC (2494) 2A | per martha denman 416-4840 Room 102C in the back office the wall socket has no power it is the only one in the room and it is for the computer | 1/28/14 | | | Electrical |
| Messick CTC (2494) 2A | UNIT NOT COMING ON IN C-BLDG 1ST FLR PLANT MGR-WHITE/619.3234 | 1/29/14 | | | Electrical |
| Messick CTC (2494) 2A | In build B some if the outlet on the 1floor is out i check the box on the 2nd floor look good can we get some one to look at the outlet in build B | 1/29/14 | Annex | | Electrical |

| | | | | | |
|-----------------------|---|---------|--------------------|--------------|--|
| Messick CTC (2494) 2A | RTU - GYM - IN CLASS RM - NOT COMING ON - PM/DEMON 416-4048 | 2/14/14 | | | Electrical |
| Messick CTC (2494) 2A | The pull station 128 need to be reseted. | 2/17/14 | Mechanical Room | bldg-A | Electrical |
| Messick CTC (2494) 2A | need a basllast in the C Build office | 2/17/14 | Annex | | Electrical |
| Messick CTC (2494) 2A | Repair light in the gym. | 2/19/14 | | | Electrical |
| Messick CTC (2494) 2A | need a basllast in room B213 in build B | 2/26/14 | Classroom | | Electrical |
| Messick CTC (2494) 2A | The class need the lights repaired, the bulbs have been replaced, but the light fixtures are still out. This is the whole shop. | 8/15/13 | Machine Shop | bldg-B / 105 | Electrical |
| Messick CTC (2494) 2A | the two ac unit do not work in room 201 in build C | 5/7/14 | Classroom | | Heating/Ventil ation /Air Conditioning |
| Messick CTC (2494) 2A | the ac do work in room 306 in build C | 5/7/14 | Classroom | | Heating/Ventil ation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|-----------|--|---------------------------------------|
| Messick CTC (2494) 2A | the ac outlet do not work in build A in room 303 | 5/7/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | air handler unit 3 and 4 not cooling | 6/13/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | WINDOW UNIT RM 305- NOT COOLING-PLANT MGR DENMAN 416-4840 KLR | 6/18/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | WINDOW UNIT RM 300- WON'T STAY RUNNING, KEEPS CUTTING OFF- PLANT MGR DENMAN 416-4840 KLR | 6/18/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | repair Zeno's A/C | 7/12/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Window Unit Not Working Blowing Hot Air Main Office in back Martha Denman 416-4840 | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Monthly - Oil Lube & Belt- Messick VoTech - Refer to PM schedule details. | 7/19/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Building A Rm 203 Window Unit is not working (equip# 101112) per Ms Denman | 7/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|-----------|------------------------|---------------------------------------|
| Messick CTC (2494) 2A | WINDOW UNIT NOT COOLING IN RM-105 BLDG-A(040). PLANT MGR-DENMAN/416.3000 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | WINDOW A/C UNIT 3RD FLR RM 301-NOT COOLING-SBE DENMAN 416-4840 KLR | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the ac unit in room 300 bldg c not work need fixing | 8/12/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | 2 window units quit working Building C rm 203 and 301 per Ms. Denman 416-4048 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | No heat from the ceiling heater | 3/27/14 | Classroom | Bldg-B / 105 back room | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the ac unit don't work in room 205 in build A it is hot in the room | 3/28/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the ac unit in room 302 in build A not working | 8/20/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|----------|-----------|--|---------------------------------------|
| Messick CTC (2494) 2A | WINDOW A/C UNIT C BLDG RM 306-NOT COMING ON-SBE DENMAN 416-4840 KLR | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the ac unit in room 303 in bldg A need to be FIX keep freezing up | 8/26/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the ac in room 214 in bldg B blowing hot air | 8/29/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the ac will not turn off in build | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | building D no heat per martha denman 416-4048 blowing cold | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILERS - BLDG A & BLDG D - BOTH ARE NOT COMING ON - PM/DEMMONS 416-4048 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILER A BLDG, BOILER B BLDG & TRAINING CTR- ALL NOT COMING ON- CALLED BY CUST SUPV G DEAN 606-2780 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Unit is NOT COMING ON in "A" building per Juanita Sullivan, Plant Mgr. 416.4840 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|-----------|--|---------------------------------------|
| Messick CTC (2494) 2A | Unit is NOT COMING ON in "B" building, Rooms 207 & 213 per Juanita Sullivan, Plant Mgr. 416.4840 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILER A BLDG-NOT COMING ON-PLANT MGR WHITE 416-4840 KLR | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILER A BLDG-NOT COMING ON-PLANT MGR DENMAN 416-4840 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | HEAT A BLDG RMS 100, 101, 200, 201, 202, 300, 301, & 302-ALL NOT HEATING-PLANT MGR DENMAN 416-4840 KLR | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILER A BLDG-MALFUNCTIONING-STEAM AND SMOKE FILLED THE BLDG PER SBE-PLANT MGR DENMAN 416-4840 KLR | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | replace heater in bldg electric shop area | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | the 3rd floors or over heating in build A and C | 1/10/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Replace rooftop #1 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|--|--|---------------------------------------|
| Messick CTC (2494) 2A | Replace rooftop #2 | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | we had a big noise coming from the boiler room on the first floor by the main office put in a emergency call | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | A build and C build over heating on the 2nd and 3rd floors | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILER NOT COMING ON IN A-BLDG PLANT MGR-DENMAN/416.4840 | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | BOILER MECH RM A BLDG-NOT COMING ON-PLANT MGR WHITE 416-4840 KLR | 2/14/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | install new preasure releif valve on boiler in "A" bldg.-os | 2/20/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Monthly - Oil Lube & Belt-Messick VoTech - Refer to PM schedule details. | 2/21/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Monthly - Filter-Messick VoTech - Refer to PM schedule details. | 11/12/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|----------|---------------------|--|---------------------------------------|
| Messick CTC (2494) 2A | Monthly - Filter-Messick VoTech - Refer to PM schedule details. | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | Monthly - Filter-Messick VoTech - Refer to PM schedule details. | 3/18/14 | | | Heating/Ventilation /Air Conditioning |
| Messick CTC (2494) 2A | can we get some one to look at the office in the D build need to be painting the 2nd office for the end | 10/8/13 | Administration Area | | Painting |
| Messick CTC (2494) 2A | the boys restroom in the B bldg on the 2nd floor need paint on the wall graffiti on the wall | 9/13/13 | Restroom (Boys) | | Painting |
| Messick CTC (2494) 2A | paint walls in hallway | 11/21/13 | | | Painting |
| Messick CTC (2494) 2A | stop up toilet in the boys restroom in build C first floor | 6/11/14 | Restroom (Boys) | | Plumbing |
| Messick CTC (2494) 2A | the toilet in the library will not flush | 6/19/14 | Restroom (Boys) | | Plumbing |
| Messick CTC (2494) 2A | DRAIN THE BOILER RM IS BACKING UP. SBE 416-4840 | 7/5/13 | | | Plumbing |

| | | | | | |
|-----------------------|--|----------|------------------|-------------------|----------|
| Messick CTC (2494) 2A | The flush valve need to be repaired. | 10/18/13 | Restroom (Boys) | bldg-D / | Plumbing |
| Messick CTC (2494) 2A | we have two toilet one on the 3rd floor and 2nd floor in build A will not flush in the men restroom | 10/23/13 | Restroom (Boys) | | Plumbing |
| Messick CTC (2494) 2A | Hotwater tank is out, the water is leaking out. | 11/7/13 | Restroom (Girls) | bldg-A/ 1st floor | Plumbing |
| Messick CTC (2494) 2A | SEWAGE PIPE IS LEAKING WATER IN B/RR & G/RR C-BLDG 1ST FLR. SBE-DENMAN/416-4448 | 7/23/13 | | | Plumbing |
| Messick CTC (2494) 2A | FAUCET IN MOP CLOSET 2ND FLR-RUNNING AT A STREAM AND WATER IS GOING DOWN INTO OFC UNDERNEATH PER SBE-CAN'T CUT OFF-SBE DENMAN 416-4840 KLR | 8/8/13 | | | Plumbing |
| Messick CTC (2494) 2A | The toilet seat need to be repaired. | 3/19/14 | Restroom (Girls) | Bldg-D | Plumbing |
| Messick CTC (2494) 2A | I need the water fountains fixed. Ms. Denman & Mr. White, Please go around and check each water fountain on the campus. Please document which of these fountains do not work and put in a request | 4/14/14 | Hallway/Corridor | Bldg-C/ B | Plumbing |
| Messick CTC (2494) 2A | I need the sinks resealed around the walls | 4/30/14 | Restroom (Boys) | Gym | Plumbing |

| | | | | | |
|-----------------------|---|----------|------------------|---------------|----------|
| Messick CTC (2494) 2A | The toilet is cracked ,and need to be charge out. | 5/6/14 | | back restroom | Plumbing |
| Messick CTC (2494) 2A | toilet seats need fixing in the boys and girls restrooms on the 2nd floor in the bldg B | 8/30/13 | Restroom (Girls) | | Plumbing |
| Messick CTC (2494) 2A | no hot water in the C bldg office can some check the hot water in the office | 9/4/13 | 1st Floor | | Plumbing |
| Messick CTC (2494) 2A | Request back flow test. | 9/5/13 | | | Plumbing |
| Messick CTC (2494) 2A | the hot water heater in the main build in build a need fixing no hot water in the restroom | 11/12/13 | | | Plumbing |
| Messick CTC (2494) 2A | GAS SMELL BETWEEN B BLDG & AUDITORIUM PER SBE-PLANT MGR DENMAN 416-4840 KLR | 11/18/13 | | | Plumbing |
| Messick CTC (2494) 2A | Preform back flow test. | 12/23/13 | | | Plumbing |
| Messick CTC (2494) 2A | Building "C" Toilet in the Boy's RR on 3rd floor is leaking in Classroom per Ms. Denman, Plant Mgr. 416.4048. | 1/6/14 | | | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------------|--------|----------|
| Messick CTC (2494) 2A | Men restroom urine need a flush valve. | 1/22/14 | Restroom (Boys) | Bldg-D | Plumbing |
| Messick CTC (2494) 2A | The men restroom the urinal need the flush valve repaired. | 2/5/14 | Restroom (Boys) | Bldg-D | Plumbing |
| Messick CTC (2494) 2A | the toilet on the third floor is leaking on the 2nd floor ceiling in build C need it fix asap | 2/5/14 | Restroom (Boys) | | Plumbing |
| Messick CTC (2494) 2A | have a leak in the boys restroom in build b on the 1st floor toilet | 2/25/14 | Restroom (Boys) | | Plumbing |
| Messick CTC (2494) 2A | Request loop be repair on pipe. | 2/27/14 | | | Plumbing |
| Messick CTC (2494) 2A | The flush valve donot work in the restroom | 2/28/14 | Restroom (Boys) | Bldg-D | Plumbing |
| Messick CTC (2494) 2A | the toilet in the main build on the 1st floor will not flush men restroom | 2/28/14 | Restroom (Boys) | | Plumbing |
| Messick CTC (2494) 2A | the woman restroom on the 2nd floor the last toilet will not fush | 2/28/14 | Restroom (Girls) | | Plumbing |

| | | | | | |
|-----------------------|--|----------|---------------------|-----------------|------|
| Messick CTC (2494) 2A | I need the roof drains unstopped, they have leaves in the roof drains. | 3/19/14 | Gym | | Roof |
| Messick CTC (2494) 2A | I have a roof leaked in the classroom 1 | 9/24/13 | Administration Area | bldg-gym / rm-1 | Roof |
| Messick CTC (2494) 2A | have a ceiling leaking in room 201 in build C a big leak | 12/12/13 | Classroom | | Roof |

| Count of Craft | Craft | | | | | | | | Grand Total |
|-----------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Mt. Pisgah MS (0140)2 | 1 | 21 | 68 | 61 | 6 | 23 | 8 | 1 | 189 |
| Grand Total | 1 | 21 | 68 | 61 | 6 | 23 | 8 | 1 | 189 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|-------------------------|--|----------------|-----------|-------------|-------------|-----------|
| Mt. Pisgah MS (0140) 2A | Need gym floor scheduled for refinishing on October the 17th / | 9/25/13 | Gym | | | Asbestos |
| Mt. Pisgah MS (0140) 2A | Requested by Principal / Wanting 8 - bulletin boards installed through out school and cafeteria. See Mrs. LaVonda R. Jones for sizes and locations. | 6/24/14 | | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need Basketball banner hung in gym for coach. It's the one from the tournament. | 5/13/14 | Gym | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need white floor tile replaced in corner of classroom 214. | 5/28/14 | 2nd Floor | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need 2 rain down spouts cleaned out / looks as though stopped up at bottom of drain. By classroom 131 and 133 | 5/29/14 | 1st Floor | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need maintenance to put snap hooks on with sections of cable and crimped for flags. 2 flag hooks missing / Can't fly flags. | 12/16/13 | | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need shelves built in book store on left-hand facing entrance door located across from classroom 112. Mrs. Lim is asking for 3 simple shelves to show merchandise. | 12/18/13 | | | | Carpentry |

| | | | | | |
|-------------------------|--|---------|------------------|------------|-----------|
| Mt. Pisgah MS (0140) 2A | A key has broken off in the lock so the room cannot be opened. This is a regular classroom. We need this opened ASAP as the teachers' materials etc. are locked in it. See Principal John Gilmer | 1/13/14 | Classroom | room 213 | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need entrance door to classroom 121 repaired / can't open door from inside. | 1/15/14 | 1st Floor | | Carpentry |
| Mt. Pisgah MS (0140) 2A | URGENT!! Need broken cafeteria door glass replaced / Have cardboard taped over door window. 1st one on North end of cafeteria. Can't secure building. | 2/6/14 | Cafeteria | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need speaker wire and basketball Banner reattached to wall in gym. See coach Jayjock | 3/21/14 | Gym | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Make 4 wood stands to hold top up for condensor coil replacement | 3/24/14 | | Aaon units | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need panic bar repaired on exit door going out on North end of gym. Doors facing back of rear doors of school building. Very hard to open . Already used WD 40 | 3/27/14 | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | URGENT!! Need glass pane replaced in door that is going into concession area in the gym. Door has cardboard taped on it that is damaged. | 4/11/14 | Concession Stand | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need glass replaced in concession area on the outside. Cracked real bad but not broken out. | 4/22/14 | Classroom | | Carpentry |

| | | | | | |
|-------------------------|--|----------|------------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need flag pole cable replaced/ fraying badly / Cut fingers this morning. | 8/30/13 | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need Basketball goal pads installed on Main goals #1 and #2 Old WO# submitted was # 250410 for request. | 7/22/13 | Gym | | Carpentry |
| Mt. Pisgah MS (0140) 2A | URGENT!! Need ceiling repaired in girl's restroom upstairs by classroom 218 / Ceiling has been damaged and will need painting and mud-work. Have called Emergency services for leak. | 8/5/13 | Restroom (Girls) | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need stricker plate adjusted to classroom 211/ can't secure door won't catch when closed. | 8/12/13 | Classroom | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need automatic closures on classroom doors in 100 and 200 hallways they are not self-closing . Found on Fire Marshall's inspection | 12/5/13 | | | Carpentry |
| Mt. Pisgah MS (0140) 2A | URGENT!!!Need removal of cones thrown on top of metal awning on the back entrance. Principal requested this to be done A.S.A.P. due to more vandalism occurring. | 5/12/14 | Classroom | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Need ceiling repaired in #2. girl's restroom upstairs by classroom 218 that needs the ceiling mudded out and then painted. It was damaged in August 2013 by a condensation leak. WO#378752 8-27-13 | 10/16/13 | Restroom (Girls) | | Carpentry |
| Mt. Pisgah MS (0140) 2A | Smoke detector in the cafeteria near the serving line double door entrance is missing, we believe it may be causing the panel top alarm | 11/20/13 | Cafetorium | | Electrical |

| | | | | | |
|-------------------------|--|----------|------------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need outside bell repaired for kitchen, See Mrs. Dodson | 11/25/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need electrical short repaired in score board. Having to wiggle switch around to get to work. | 11/25/13 | Gym | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need over-head light replaced in gym. Far right-hand corner/ bulb in Plant managers office. | 11/25/13 | Gym | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in classroom 210 / Bulbs have been replaced/ Fluorescent fixture marked with note. | 5/28/14 | 2nd Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need to order 5 cases of Fluorescent bulbs F32T8 Stock# Catalog # 10221 | 5/28/14 | 2nd Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 2 ballasts replaced in classroom 221 / Need 3 ballasts replaced in classroom 224 / All are marked with note | 5/28/14 | 2nd Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 2-ballasts replaced in classroom 232 / Need 3- ballasts replaced in classroom 230 /Need 3- ballasts replaced in classroom 228 / 1- ballast in 225 / 2 - ballasts replaced in 226 All lights are marked with notes and bulbs have been replaced. | 5/29/14 | 2nd Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Getting ALARM from panel showing Zone 002 / Battery low | 6/2/14 | | | Electrical |

| | | | | | |
|-------------------------|--|---------|----------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need ballasts replaced in classrooms/ 1- in 134 / 3-137 / and 1-127 / Bulbs have been changed out. | 6/2/14 | 1st Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballasts replaced in these classrooms at Mount Pisgah / 1- in classroom 107 / 1-classroom 115 / 1- in classroom 119 / and 1- in classroom 120. All bulbs have been replaced and are marked with note. | 6/9/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need wall pack light outside repaired by science lab #2 / located on west side of building. | 12/6/13 | Athletic Field | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in light fixture in classroom 134/ light fixture marked with note/ | 1/2/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in classroom 132 / fixture marked with note attached to fixture. | 1/2/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in classroom 131 / Light fixture is marked with note. | 1/2/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Classroom 120 needs a ballast in a light fixture/ Fixture is marked with a note / | 1/3/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in classroom 119 / Fixture marked with a note hanging down./ | 1/3/14 | Classroom | | Electrical |

| | | | | | |
|-------------------------|--|---------|------------------|--------|------------|
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in classroom 118 / Light fixture marked with a note | 1/3/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 3- ballasts replaced in 3- fluorescent light fixtures in classroom 117 / All are marked with notes | 1/3/14 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Wire the new aquastat on the water heater in the kitchen. | 1/3/14 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need to order 4 cases of stock# 10221 (F32T8) for replacement of fluorescent bulbs. Deliver to Mount Pisgah Middle. | 1/14/14 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast in light fixture replaced in boy's restroom in concession area in gym. It is the one strobe lighting. | 1/14/14 | Concession Stand | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in light fixture in (GIRL"S) restroom in concession area in gym. It is flashing also / got tournament next week. | 1/14/14 | Concession Stand | | Electrical |
| Mt. Pisgah MS (0140) 2A | Repair wire for unit | 1/15/14 | | Rm 120 | Electrical |
| Mt. Pisgah MS (0140) 2A | Need repair of fluorescent light fixture on stairwell landing on East side stairwell. Can't get cover off to change out bulbs. | 2/7/14 | Hallway/Corridor | | Electrical |

| | | | | | |
|-------------------------|--|---------|----------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need 2 pole lights repaired outside of main back entrance (west side) | 2/13/14 | Athletic Field | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 3 outside pack lights repaired / 1- in front of main entrance on library side and next one down on library side out front. 1- in back between gym and back doors of main building | 2/24/14 | 1st Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need repair of simplex clock in hallway near classroom 135 / Showing 11:15 all the time. | 2/25/14 | 1st Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need to order 18 ea. of stock # 10257 for outside pack lights. It takes 2 per light. | 3/20/14 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need one can light on main back entrance repaired in foyer outside of main back entrance. | 3/25/14 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballasts replaced in light fixture in kitchen over by dishwasher. Changed out bulbs. Speak to Mrs. Dodson | 4/1/14 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need battery replaced in Exit light upstairs by center stairwell entrance across from elevator./ Need battery replaced by double doors facing North by North stairwell. | 4/3/14 | 2nd Floor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need battery replaced in Exit light in classroom 134 / Need battery replaced in Exit light in classroom 137 inside faing doors on right-hand side. | 4/3/14 | 1st Floor | | Electrical |

| | | | | | |
|-------------------------|---|---------|------------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need ballast replaced or repaired in fluorescent light fixture in classroom 117 / Light fixture is marked with sign and bulbs replaced. | 4/10/14 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 2 round wall lights repaired between classrooms 100 and 102 and by 129 / 42 watt PL-T 35 4 pin | 9/6/13 | Athletic Field | | Electrical |
| Mt. Pisgah MS (0140) 2A | Requesting system check on security panel and all sensors and contacts. Getting too many alarms | 9/9/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need ballast replaced in fluorescent light fixture upstairs by classroom 218 in hallway. Fixture is marked with note/ | 9/10/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need repair of Primex base unit(not displaying) also need to change bell schedule. | 9/11/13 | Library | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 2- ballasts replaced in classroom 119 / Both are marked with note hanging from fluorescent light fixtures. | 9/25/13 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need battery replaced in Exit light in classroom 134 on right-hand side. | 10/1/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need battery replaced in Exit light in classroom 137 / 1st door on left // found on PM | 10/1/13 | Classroom | | Electrical |

| | | | | | |
|-------------------------|---|----------|------------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need Exit and EMERGENCY light repaired in Cafeteria by dishwasher doors over top of hallway. Found on P.M. | 10/1/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 2-EXIT and EMERGENCY lights repaired in kitchen over entrance doors to check-outs lines inside of kitchen. | 10/1/13 | Kitchen | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need EXIT and EMERGENCY light repaired in kitchen / located on Right-hand side of kitchen by center door by sink. next to womens restroom. | 10/1/13 | Kitchen | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need EXIT and EMERGENCY light repaired in gym by concession area outside/ facing concession area on left-hand side with cage on it. Found on P.M. | 10/1/13 | Gym | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need EXIT and EMERGENCY light repaired inside of concession area in gym / located on right-hand side by girl's restroom up front in concessionarea. Found on P.M. | 10/1/13 | Gym | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need pack wall light repaired on outside wall between classrooms 109 and 111 | 10/15/13 | Athletic Field | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need wall pack light repaired at main back entrance / Located on left-hand column . | 10/15/13 | Athletic Field | | Electrical |
| Mt. Pisgah MS (0140) 2A | unwire and rewire pump for removal | 10/15/13 | | | Electrical |

| | | | | | |
|-------------------------|---|----------|------------------|--|------------|
| Mt. Pisgah MS (0140) 2A | Need 2 cases of F32T8/T1741 fluorescent bulbs at Mount Pisgah Middle to change out some bulbs. Please Update your work order with warehouse stock# or the vendor/supplier name with their part #. warehouse cannot fill the order without this information. Thanks, Danny | 10/21/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need 2 ballasts replaced in classroom 125 | 11/1/13 | Classroom | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need to order 3-boxes of fluorescent bulbs for bulb replacement. Stock# 10221 | 11/1/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Verify data base in burglar alarm panel. | 11/1/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need clocks repaired through out school and gym. Some clocks did not reset atomically as scheduled. Located on bottom and top floor. Also need time reset on security key board did not reset. | 11/5/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | A light in the gym is not burning. To replace the bulb you will need the lift. See Mr. Gamble or Coach Jayjock or Coach Perkins if necessary. | 11/18/13 | Gym | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need motion detector repaired in hallway by back doors next to classroom 137. / Detector is giving off alarm and then resetting within 2 seconds. Several alarms this weekend | 7/15/13 | Hallway/Corridor | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need the repair of zone 2 we keep getting a fire trouble on zone 002. Believe that the alarm is coming from PIV on the South end of campus. | 7/15/13 | | | Electrical |

| | | | | | |
|-------------------------|---|---------|-----------|--|------------|
| Mt. Pisgah MS (0140) 2A | Please run Test. Level 2 Facilities ETSS annual load test NFPA 110 | 7/16/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Please remove the light in the upstairs girls restroom. | 8/5/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need card readers repaired or reset for all entrance doors for Mount Pisgah Middle | 8/6/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need Exit light repaired upstairs going into center stairwell across from elevator. Found during P.M. | 8/9/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need Exit repaired to entrance of Cafeteria hallway next to dishwasher doors. Found during P.M. | 8/9/13 | Cafeteria | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need Exit and Emergency light repaired on right-hand side of serving line inside of kitchen. Found during P.M. | 8/9/13 | Cafeteria | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need Exit and Emergency light repaired in Kitchen by exit door by lavatory(SINK) heading to dock. Found during P.M. | 8/9/13 | Kitchen | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need Exit and Emergency light repaired in concession area in gym , located by girl's restroom. Found during P.M. | 8/9/13 | Gym | | Electrical |

| | | | | | |
|-------------------------|--|----------|------------------|----------|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | Urgent!! Need ballast replaced in restroom fluorescent light (only one) in TWA across from 132. | 8/27/13 | Restroom (Girls) | | Electrical |
| Mt. Pisgah MS (0140) 2A | Need two ballast replaced and one light fixture repaired. | 7/19/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | UNIT IN THE LIBRARY IS NOT COMING ON. SBE GAMBLE 756-2386 | 8/2/13 | | | Electrical |
| Mt. Pisgah MS (0140) 2A | UNIT IN RM 219 IS NOT COMING ON. SBE GAMBLE | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | The blower is once again blowing cold air at a constant rate. Last week someone was out here to fix it, and indeed, the blower ceased for a couple of days but the problem has returned. | 11/20/13 | 2nd Floor | room 210 | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | North and South Aeon's are not heating. | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | main office area (principal's office) heat not working per michael gamble 756-2386 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | room 210 not heating per michael gamble 756-2386 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|-----|-------------------|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | Change filters whole school | 5/30/14 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need west side HVAC unit outside to gym repaired / Not working at all. Gym inside is very cold. | 12/10/13 | Gym | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | ROOM 120 IS OFF LINE | 1/14/14 | | ROOM 120 | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC unit repaired for gym outside facing North. Unit is only blowing cold air. Checked gas line | 3/3/14 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | THE AAON 2-STORY EAST UNIT IS OFF LINE | 3/6/14 | | AAON 2 STORY EAST | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Replaced condensor coil | 3/21/14 | | S.E Aaon | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Replaced condensor coil | 3/21/14 | | Lower roof Aaon | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | ROOM 137 (ART) IS OFF LINE | 4/1/14 | | ROOM 137 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|-----|--------------|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | room 125 unit not coming on (computer lab) per gamble 756-2386 | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need broken slide thermostat replaced in gym on South side of gym. / On Right-hand side facing stage | 4/25/14 | Gym | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | A/C LIBRARY NOT COOLING-PLANT MGR GAMBLE 756-2386 KLR | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | A/C IN 113-NOT COOLING-PLANT MGR GAMBLE 756-2386 KLR | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | library a/c not cooling per Gamble 756-2386 | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | EMERGENCY!! Smelling burnt rubber in classroom 135 / More so when A/C unit is coming on. Belts may be rubbing. | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | ROOM 137 ART IS OFF LINE | 9/11/13 | | ROOM 137 ART | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | A/C KITCHEN AREA-NOT COOLING-PLANT MGR GAMBLE 756-2386 KLR | 9/16/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|------------------|----------|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | UNIT NOT COOLING IN RM-125 PLANT MGR-GAMBLE/756.2387 | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need A/C (ON) in gym from 5:00P.M. until 8:00P.M. on Tuesdays and Thursdays for girl's basketball practice. | 7/19/13 | Gym | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | THE GYM, CAFE AND SINGLE STORY ARE OFF LINE | 7/23/13 | | EMS | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Gym north is not cooling. | 10/17/13 | Gym | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Check no heat in gym | 11/8/13 | | Gym unit | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need to repair water cooler in gym | 11/11/13 | | Gym | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | room 210 no heat per Michael Gamble 756-2386 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need heat repaired in classroom 104 (ISS) and need cold air turned off they are freezing in there. | 11/13/13 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|-----------|-----------------|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | HEAT 2ND FLR RM 210-NOT HEATING-PLANT MGR NEWSOM 756-2386 KLR | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | HEAT 1ST FLR RMS 116, 115, 117, & 118-ALL ARE OVERHEATING-TEMP IS OVER 80-PLANT MGR NEWSOM 756-2386 KLR | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 205 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | THE AAON 2 STORY NORTH UNIT IS NOT PRODUCING COLD AIR | 7/19/13 | | AAON2STORYNORTH | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | THE AAON 2 STORY SOUTH UNIT IS NOT PRODUCING COLD AIR | 7/19/13 | | AAON2STORYSOUTH | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | THE AAON SINGLE STORY UNIT IS NOT PRODUCING COLD AIR | 7/19/13 | | AAONSINGLESTORY | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | ROOM 116 IS GETTING WARMER - THE DISCHARGE TEMP ON THE UNIT IS 62.3 DEGREES | 8/8/13 | | ROOM 116 | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | A/C IN KITCHEN AREA-NOT COMING ON-SBE GAMBLE 759-4527 KLR | 8/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|---------|-----------|----------------|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | UNIT NOT COMING ON IN RM-116. . PLANT MGR-MICHAEL/756.2386 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Change filters check belts | 8/19/13 | | Whole building | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | A/C IN RM 107 BLUE HALL-NOT COOLING-PLANT MGR GAMBLE 459-4930 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | UNIT NOT COMING ON IN KITCHEN. PLANT MGR-GAMBLE/759.4527 | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in Library / No A/C | 7/17/13 | Library | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 219 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Rm 137 off line | 7/3/13 | | Rm 137 | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Rm 219 off line | 7/3/13 | | Rm 219 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|-------------------------------------|---------|------------------|--|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | HVAC not working in classroom 116 | 7/17/13 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | HVAC not working in classroom 119 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | HVAC not working in classroom 231 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 220 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 214 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 210 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 211 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 207 | 7/17/13 | Classroom | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|------------------|-----|---------------------------------------|
| Mt. Pisgah MS (0140) 2A | Need A/C repaired in bandroom (Classroom 134) No A/C | 7/23/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | EMERGENCY!! Need HVAC repaired in library, Principal needs for meetings, also for carpet cleaning when scheduled. | 7/24/13 | Library | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | CHECK BATTERY CIRCUIT AND UPS ON EMS MASTER | 7/25/13 | | EMS | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | No HVAC in library / Needs repair | 7/22/13 | Library | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | Need HVAC repaired in classroom 219 upstairs/ No A/C | 7/22/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | UNIT IN RM 211 IS NOT COOLING. SBE GAMBLE 756-2386 | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | UNIT IN THE GIRLS RSTRM ON THE 2ND FLOOR IS LEAKING. SBE 756-2386 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Mt. Pisgah MS (0140) 2A | EMERGENCY!! Need HVAC unit condensation repaired over girl's restroom upstairs by classroom 218. Ceiling about to fall through. Called and WO# is 370634 | 8/5/13 | Restroom (Girls) | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|------------------|-----------------------|----------|
| Mt. Pisgah MS (0140) 2A | Need ceiling repaired in boy's restroom by 218 / Need fixed due to HVAC UNIT having a condensation leak a while back. The ceiling will need re-floated and re-painted | 8/27/13 | Restroom (Boys) | | Painting |
| Mt. Pisgah MS (0140) 2A | This problem occurred on the first day of school but has never been repaired. The ceiling in the girls restroom was damaged when an AC unit leaked. The ceiling needs mudding and painting. Two painters came to look at it in late August but no work was ever done. | 11/18/13 | Restroom (Girls) | 2nd floor near rm 218 | Painting |
| Mt. Pisgah MS (0140) 2A | Need restroom stall doors in all restrooms re-varnished / Have sanded all of graffiti off of stall doors in all restrooms. | 6/9/14 | Restroom (Boys) | | Painting |
| Mt. Pisgah MS (0140) 2A | URGENT!! Principal is requesting a fresh coat of paint in the Principal's office before she moves in this coming Monday the 30th of June. | 6/25/14 | Cafeteria | | Painting |
| Mt. Pisgah MS (0140) 2A | Need the first 5 parking spaces near the front door painted with RESERVE on them and the rest with VISITOR painted on them. This is requested by Principal. (Mrs. Jones) | 6/4/14 | | | Painting |
| Mt. Pisgah MS (0140) 2A | Need all stall doors varnished where Plant Manager has sanded to remove graffiti in all boys and girls restrooms in building. | 7/12/13 | Restroom (Boys) | | Painting |
| Mt. Pisgah MS (0140) 2A | EMERGENCY!!The water line that was run for the gentleman behind the school is leaking very badly over by the pipe next to his house. He is going to have to shut his water off. | 8/2/13 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | There is part of the sewer drain cover that is missing at the east end of the soccer field. | 11/26/13 | Athletic Field | | Plumbing |

| | | | | | |
|-------------------------|--|----------|---------|-----------------|----------|
| Mt. Pisgah MS (0140) 2A | Need 3- sewer caps 4 1/2 " replaced by classroom 114 and 1-6 inch cap by library and 1-6 inch cap by classroom 137 on corner. | 11/26/13 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | URGENT!! Need pipe leak repaired in classroom 102 in ceiling. Ceiling tile has been removed back to see where pipe is leaking. | 6/9/14 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Test the following RP Serial # 433955 1 1/2" 909 Watts | 1/15/14 | | Science Lab | Plumbing |
| Mt. Pisgah MS (0140) 2A | Test the following RP Serial # 182048 3" 909 Watts | 1/15/14 | | Mechanical Room | Plumbing |
| Mt. Pisgah MS (0140) 2A | Test the following RP Serial # 181906 3" 909 Watts | 1/15/14 | | Mechanical Room | Plumbing |
| Mt. Pisgah MS (0140) 2A | The drainage hole is backed up on serving line. | 1/27/14 | Kitchen | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Test RP Serial # 433955 | 1/27/14 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Test RP Serial # 182048 | 1/27/14 | | | Plumbing |

| | | | | | |
|-------------------------|---|---------|-----------------|--------------|----------|
| Mt. Pisgah MS (0140) 2A | Test RP Serial # 181906 | 1/27/14 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Repair leak on sink in kitchen. | 1/27/14 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | In the back of the gym where there are 2 water fountains the PVC plumbing needs repaired real bad. The drain between the fountains has been broken. | 2/3/14 | Gym | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Need P-trap repaired for center lavatory in boy's locker room in gym. | 2/6/14 | Restroom (Boys) | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Need repair of sink fixture in upstairs restroom in TWA/ Faucet and handles are very loose in the right-hand restroom upstairs. | 3/28/14 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | toilet is stopped up | 4/1/14 | Kitchen | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Need sink unstopped in classroom 135 / have used plunger several times but keeps stopping up. | 4/21/14 | Classroom | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Check mop sink drain upstairs custodial closet above room 102 | 4/25/14 | | Above rm 102 | Plumbing |

| | | | | | |
|-------------------------|--|---------|-----------|--|----------|
| Mt. Pisgah MS (0140) 2A | C V pumps are leaking again in Sprinkler room between gym and back of new building. | 10/2/13 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Water heater leaking in boiler room located behind cafeteria. Found on P.M. | 11/5/13 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Fire alarm panel shows trouble. | 7/12/13 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Monthly grease trap inspection. | 7/16/13 | | | Plumbing |
| Mt. Pisgah MS (0140) 2A | Need water fountain repaired in gym/ located by boy's locker room / See coach Jayjock | 8/23/13 | Gym | | Plumbing |
| Mt. Pisgah MS (0140) 2A | URGENT!! Need roof leak repaired in fluorescent light fixture in cafeteria/ leaking in 3rd fixture on North-East corner of Cafeteria. The one that has all the water stains. | 1/14/14 | Cafeteria | | Roof |
| Mt. Pisgah MS (0140) 2A | Need roof leaks repaired in kitchen. 1- in kitchen office and the other near the pan shelving area. See Mrs. Dodson | 2/5/14 | Kitchen | | Roof |
| Mt. Pisgah MS (0140) 2A | Need roof leak repaired in fluorescent light fixture in cafeteria. It keeps blowing the bulbs and is leaving red color all over the floor from out of fluorescent fixture. | 2/5/14 | Cafeteria | | Roof |

| | | | | | |
|-------------------------|--|----------|------------------|--|-------------|
| Mt. Pisgah MS (0140) 2A | Have 2-roof leaks side by side in hallway between the cafeteria and gym in the back. The leaks have 2-30 gal. barrels under them | 2/5/14 | Hallway/Corridor | | Roof |
| Mt. Pisgah MS (0140) 2A | URGENT! Need roof repaired A.S.A.P. leaking very badly in area hallway behind gym and Cafeteria. Last rain floor got flooded. | 3/27/14 | | | Roof |
| Mt. Pisgah MS (0140) 2A | ROOF LEAK RM-102 PLANT MGR-GAMBLE/756.2386 | 4/22/14 | | | Roof |
| Mt. Pisgah MS (0140) 2A | Need repair of roof leak located behind double back doors of gym beside electrical closet/ leaking from around light fixture. | 8/5/13 | Gym | | Roof |
| Mt. Pisgah MS (0140) 2A | Need roof leak repaired in kitchen office due to it leakin directly over computer and it was probably damaged during the rain storm. | 8/9/13 | | | Roof |
| Mt. Pisgah MS (0140) 2A | Need basketball goal repaired (Goal #4 WEST MAIN END) Need bolt and nut replaced. | 11/25/13 | Gym | | Sheet Metal |

| Count of Craft | Craft | | | | | | Grand Total |
|-----------------------|-----------|------------|------|----------|----------|------|-------------|
| Location | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| mentary Schools Dist. | 6 | 16 | 9 | 1 | 12 | 2 | 46 |
| Grand Total | 6 | 16 | 9 | 1 | 12 | 2 | 46 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|---|--|---------------|---------------------|---|------------|
| North Elementary Schools Dist. (8216) 2B | Need to have a cubicle desk station disassembled from one office and reinstalled in the new directors office. SEE Plant Manager | 7/8/13 | Administration Area | Director's Office (Mr. James Alldinger) | Carpentry |
| North Elementary Schools Dist. (8216) 2B | Ceiling tile need fixing or replacing in Ms Douglas's office | 10/10/13 | Administration Area | Directors office | Carpentry |
| North Elementary Schools Dist. (8216) 2B | secure brake room windows | 10/24/13 | | Brake room | Carpentry |
| North Elementary Schools Dist. (8216) 2B | Director ask if she can have her windows rewrapped with plastic to keep air from coming in. | 12/9/13 | Administration Area | Directors office | Carpentry |
| North Elementary Schools Dist. (8216) 2B | Install weather stripping to 4 doors to keep cold weather out | 1/29/14 | Administration Area | 4 outside doors | Carpentry |
| North Elementary Schools Dist. (8216) 2B | Replace pull wire on flag pole | 2/20/14 | Grounds | Flag pole | Carpentry |
| North Elementary Schools Dist. (8216) 2B | office #37 outlets not working per ms cox 416-5904 | 3/18/14 | | | Electrical |

| | | | | | |
|---|--|----------|---------------------|---|------------|
| North Elementary Schools Dist. (8216) 2B | Bad Ballast | 7/18/13 | | work area in back near Rm 37 | Electrical |
| North Elementary Schools Dist. (8216) 2B | bad ballast. light flickers | 9/11/13 | Administration Area | outside conference rm | Electrical |
| North Elementary Schools Dist. (8216) 2B | Replace 4 non working Exit lights | 4/14/14 | Administration Area | | Electrical |
| North Elementary Schools Dist. (8216) 2B | Att: Richard Powell Bad Ballasts | 5/1/14 | Administration Area | Mrs Douglas office | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad ballast | 5/14/14 | Administration Area | outside office 12&14 | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad ballast | 5/16/14 | Administration Area | main lobby | Electrical |
| North Elementary Schools Dist. (8216) 2B | Need 3 cases of T8 light bulbs | 6/10/14 | Administration Area | NAO | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad ballast on light outside the mens restroom in the rear of the building. It flickers from time to time | 11/13/13 | | right outside mens restroom in rear of the buildin | Electrical |

| | | | | | |
|---|---|----------|---------------------|---|--|
| North Elementary Schools Dist. (8216) 2B | Bad ballast | 11/15/13 | Administration Area | Admin Secretary office | Electrical |
| North Elementary Schools Dist. (8216) 2B | 2 Emergency lights out and 1 Exit light out | 11/21/13 | Administration Area | | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad ballast | 11/21/13 | | Ladies restroom in front outside conference room | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad ballast | 1/21/14 | Administration Area | office 29 | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad ballast | 1/27/14 | Administration Area | Office 7 & hallway | Electrical |
| North Elementary Schools Dist. (8216) 2B | Bad Ballast | 2/10/14 | Administration Area | office 39 | Electrical |
| North Elementary Schools Dist. (8216) 2B | BREAKER BOX KEEPS TRIPPING FRONT OF BLDG PLANT MGR-COX/416.5763 | 6/17/14 | | | Electrical |
| North Elementary Schools Dist. (8216) 2B | RTU - #1, #2 & #3 - ALL ARE BLOWING - NOT COOLING - PM/COX 416-5904 | 6/2/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---|---|----------|--|--|--|
| North Elementary Schools Dist. (8216) 2B | UNIT NOT COMING ON THRU ENTIRE BLDG. PLANT MGR-COX/416.4222 | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | RTU-1 FRONT PORTION OF BLDG-NOT COMING ON- PLANT MGR COX 416-5904 KLR | 2/24/14 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | RTU - 1,2,3 - BLOWING NOT COOLING - PM/COX 416- 5904 | 6/6/14 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | RTU-1 SERVES CTR WING OF BLDG-NOT COMING ON- PLANT MGR COX 416-4264 KLR | 6/9/14 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | Monthly - Filter-North Elementary School District - Refer to PM schedule details. | 10/13/13 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | Monthly - Filter-North Elementary School District - Refer to PM schedule details. | 2/16/14 | | | Heating/Ventilation /Air Conditioning |
| North Elementary Schools Dist. (8216) 2B | Monthly - Filter-North Elementary School District - Refer to PM schedule details. | 6/15/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---|--|----------|---------------------|--|----------|
| North Elementary Schools Dist. (8216) 2B | Offices need painting 5,6,11,12,14,15,16,17,24,26,27,28,29 | 10/10/13 | | Rm's 5,6,11,12,14,15,16,17,24,26,27,28,29 | Painting |
| North Elementary Schools Dist. (8216) 2B | Sink in men's restroom that's located in the back of the building,will not shut off. | 2/24/14 | Administration Area | mens restroom | Plumbing |
| North Elementary Schools Dist. (8216) 2B | Replace flush value and also it leaks around the pipes | 3/4/14 | Administration Area | Front ladies restroom | Plumbing |
| North Elementary Schools Dist. (8216) 2B | back flow test. | 8/8/13 | | | Plumbing |
| North Elementary Schools Dist. (8216) 2B | Hand sink faucet will not turn off in the Men's restroom | 4/22/14 | | Men's restroom In front of building | Plumbing |
| North Elementary Schools Dist. (8216) 2B | RTU - FRONT OF BLDG - LEAKING INTO LIGHT FIXTURES - PM/COX 416-5904 | 6/2/14 | | | Plumbing |
| North Elementary Schools Dist. (8216) 2B | ROOF DRAIN STOPPED UP- PLANT MGR COX 416-5950 KLR | 6/2/14 | | | Plumbing |
| North Elementary Schools Dist. (8216) 2B | FLR DRAIN IS BACKING UP IN MEN/RR BACK. PLANT MGR-COX/596.2039 | 11/20/13 | | | Plumbing |

| | | | | | |
|---|--|----------|---------------------|-----------------------------|----------|
| North Elementary Schools Dist. (8216) 2B | ladies restroom floor drain backing up in front of building per Ms. Cox 416-4264 | 11/20/13 | | | Plumbing |
| North Elementary Schools Dist. (8216) 2B | The Water Fountain near the Men's restroom is leaking | 1/27/14 | Administration Area | Rear of the building | Plumbing |
| North Elementary Schools Dist. (8216) 2B | per ms cox 416-5904 toilet in men's restroom in front of building is backing up | 1/29/14 | | | Plumbing |
| North Elementary Schools Dist. (8216) 2B | SINK IS BACKING UP IN LADIES/RR FRONT AREA PLANT MGR-COX/596.2039 | 2/5/14 | | | Plumbing |
| North Elementary Schools Dist. (8216) 2B | Toilet continues to run | 6/17/14 | Administration Area | front restroom | Plumbing |
| North Elementary Schools Dist. (8216) 2B | Roof leaking into light fixture and has ceiling tiles saturated | 8/8/13 | | Gragg building | Roof |
| North Elementary Schools Dist. (8216) 2B | Roof leaking down into the Men's restroom in the rear of the building | 10/3/13 | Restroom (Boys) | In the rear of the building | Roof |

| Count of Craft | Craft | | | | | | |
|---------------------------|---------|-----------|------------|------|----------|------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Plumbing | Roof | Grand Total |
| Heast Prep Academy (2822) | 3 | 27 | 41 | 26 | 25 | 4 | 126 |
| Grand Total | 3 | 27 | 41 | 26 | 25 | 4 | 126 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|----------------------------------|---|----------------|---------------------|----------------------------|-----------|
| Northeast Prep Academy (2822) 2B | Northeast Prep- WO 375299-- The security at this school have a printer that needs programming and hooking up. (Request Network Cabling Maintenance Repair). "REQUEST RECEIVED".and will receive support as soon as we | 8/15/13 | | security | Cabling |
| Northeast Prep Academy (2822) 2B | Provide project management to develop computer lab including contractor installing electrical -- customer desires for this to be a title one project. | 1/15/14 | | | Cabling |
| Northeast Prep Academy (2822) 2B | There is a wall jack thats not working they need it working for the printer to connect with other teachers computers. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") IT Tech person | 12/18/13 | Administration Area | main office | Cabling |
| Northeast Prep Academy (2822) 2B | The GLASS in the window in the BOY'S RR on the 2nd Floor has been KNOCKED OUT per Christopher Harper, Plant Mgr. 416.2132 | 12/4/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | The window in the BOY'S RR on the 1st Floor will NOT close per Christopher Harper, Plant Mgr. 416.2132 | 12/4/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | The metal piece is coming up and is loose we have pregnant ladies over here and don't won't no one to fall. | 12/16/13 | Stairway | stairwell by boys restroom | Carpentry |
| Northeast Prep Academy (2822) 2B | On the backside of this portable the walk way is loose and it needs attention before someone gets hurt. | 12/16/13 | Portables | 233 | Carpentry |

| | | | | | |
|-------------------------------------|--|---------|-----------------|------------------------------|-----------|
| Northeast Prep Academy (2822) 2B | The railing in the stairwell is loose and needs re tightening before it comes off. | 8/22/13 | Stairway | the railing in the stairwell | Carpentry |
| Northeast Prep Academy (2822) 2B | There are ceiling tiles falling in this classroom needs attention don't won't a accident to happen. | 8/27/13 | Classroom | on first floor rm 101 | Carpentry |
| Northeast Prep Academy (2822) 2B | LATCH ON WINDOW IN RM 200 2ND FLR-IS BROKEN-SECURITY ISSUE PER SBE-PLANT MGR HARPER 416-2132 KLR | 8/30/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | There is aleake coming in the windows in this classroom when it rains needs attention. | 2/4/14 | Classroom | Rm 201 | Carpentry |
| Northeast Prep Academy (2822) 2B | The windows are loose in this classrooms need attention . | 2/12/14 | Classroom | Rm 101 | Carpentry |
| Northeast Prep Academy (2822) 2B | Window needs seal put around it its very loose. | 2/20/14 | Classroom | 201 | Carpentry |
| Northeast Prep Academy (2822) 2B | Theres some screws missing in the door handles and hardware. | 3/20/14 | Restroom (Boys) | downstairs | Carpentry |
| Northeast Prep Academy (2822) 2B | There are 2 peices of wood on the ramp that lead up two the door on the back side of portable thats broke in peices and I am afraid that someone is going to slip through that hole needs serious attention. | 4/8/14 | Portables | Room 233 | Carpentry |

| | | | | | |
|-------------------------------------|--|----------|---------------------|-----------------------|-----------|
| Northeast Prep Academy (2822) 2B | The knob that opens the bathroom door keeps getting stuck and they are having problems getting in to go needs attention. | 4/8/14 | Administration Area | main office | Carpentry |
| Northeast Prep Academy (2822) 2B | Ceiling tile need to be replace in hallways, cafe, and even the Principal's Office. The tile is very loose and can cause serious damage to a student, faculty, or staff. | 7/11/13 | Hallway/Corridor | ceiling tile | Carpentry |
| Northeast Prep Academy (2822) 2B | Remove and replace sheetmetal underpinning on portable for security and city animal services. | 7/15/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | Restroom will not lock at all needs attention when useing want lock. | 9/6/13 | Cafeteria | in cafeteria restroom | Carpentry |
| Northeast Prep Academy (2822) 2B | HOLE IN FLOOR INSIDE PORT 233 PER SBE A STUDENT STEPPED IN IT-PLANT MGR HARPER KLR | 9/18/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | room 101 the window has fallen out per Mr. Harper 416-2132 | 11/12/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | WINDOW 1ST FLR B RR-NOT CLOSING OR LOCKING-PLANT MGR HARPER 416-2132 KLR | 11/13/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | WINDOW RMS 101, 206, & 200- ALL ARE FALLING OUT & IT'S EASY FOR SOMEONE TO COME THRU PER SBE-WON'T BE ABLE TO SECURE-PLANT MGR HARPER 416-2132 KLR | 11/13/13 | | | Carpentry |

| | | | | | |
|-------------------------------------|--|----------|---------------------|--|------------|
| Northeast Prep Academy (2822) 2B | DOOR LATCH HAS BROKEN, CANT SECURE IN PORT-233 PLANT MGR-HARPER/834.2397 | 11/22/13 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | WINDOW FROM LIBRARY , CANT SECURE 2ND FLR PLANT MGR-HARPER/834.2397 | 1/16/14 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | Window cracked in this classroom on second floor air is coming in needs attention. | 1/29/14 | Classroom | Rm 203 | Carpentry |
| Northeast Prep Academy (2822) 2B | The rail on the portable needs attention it is leaning and its about to fall. | 5/7/14 | Portables | 318 | Carpentry |
| Northeast Prep Academy (2822) 2B | WINDOW PRIN'S OFC-HAS COME COMPLETELY OUT- WON'T BE ABLE TO SECURE- PLANT MGR HARPER 416-2132 KLR | 5/21/14 | | | Carpentry |
| Northeast Prep Academy (2822) 2B | There are ceiling tiles falling out the ceiling needs attention safety issue. | 8/22/13 | Cafeteria | caferia classrooms ,main hallway | Carpentry |
| Northeast Prep Academy (2822) 2B | The cafeteria has some missing tile its the small square tiles . needs attention. | 8/2/13 | Cafeteria | all over cafeteria | Carpentry |
| Northeast Prep Academy (2822) 2B | As I change bulbs in the light fixture the bulbs have blewout quick in the light fixture and also a popping noise comes with that fixture. | 12/18/13 | Administration Area | storage room in main office | Electrical |

| | | | | | |
|-------------------------------------|---|---------|---------------------|-----------------|------------|
| Northeast Prep Academy (2822) 2B | There is a receptacle on the wall that needs to be redone its very loose and wires could come out needs attention. | 8/22/13 | Hallway/Corridor | main entrance | Electrical |
| Northeast Prep Academy (2822) 2B | UNIT NOT COMING ON IN RM-206 PLANT MGR-HARPER/416.2132 | 8/26/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | Principal needs bells reset so one can ring later and one can ring earlier for lunch. needs attention. | 8/26/13 | Administration Area | main office | Electrical |
| Northeast Prep Academy (2822) 2B | Lights in class has blown a ballast in the light fixture.needs attention. its a 2 bulb light fixture and a t 8 ballast. | 8/27/13 | Classroom | upstairs | Electrical |
| Northeast Prep Academy (2822) 2B | per mr harper 416-2132 room 201 unit is not coming on very cold | 2/4/14 | | | Electrical |
| Northeast Prep Academy (2822) 2B | The ballast has blown in these classrooms it is a T8 ballst 2 bulb needs attention. | 2/12/14 | Classroom | rm 206 201 | Electrical |
| Northeast Prep Academy (2822) 2B | the lights are out in the back parkinglot they need attention the workers have to clean the portables in the back so they need the light for safety purposes. | 2/20/14 | Parking Lot | back parkinglot | Electrical |
| Northeast Prep Academy (2822) 2B | F.A. showing trouble. | 2/24/14 | | | Electrical |

| | | | | | |
|-------------------------------------|--|---------|---------------------|-----------------------|------------|
| Northeast Prep Academy (2822) 2B | The fire alarm keeps going off on the weekend and its reading bookstore once again needs attention. | 3/9/14 | 1st Floor | main office | Electrical |
| Northeast Prep Academy (2822) 2B | The main clock in the main office needs setting for daylight savings time. | 3/17/14 | Administration Area | main office | Electrical |
| Northeast Prep Academy (2822) 2B | The main clock in the front office needs resetting the bells are not ringing needs attention. | 4/7/14 | 1st Floor | main office | Electrical |
| Northeast Prep Academy (2822) 2B | Cord on metal detector is split and need to be repaired. | 7/2/13 | 1st Floor | metal detector cord | Electrical |
| Northeast Prep Academy (2822) 2B | Lights in cafe dining need to be change. Ceiling is over 10ft. | 7/15/13 | Cafetorium | dining area | Electrical |
| Northeast Prep Academy (2822) 2B | Bell need to be change for new school time. | 7/29/13 | Administration Area | Main Office | Electrical |
| Northeast Prep Academy (2822) 2B | Ms. Adil - NE Prep electrical wiring in front of main office has been knocked off wall needs repairing. 416-2132 | 7/30/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | The lights are out and to high to reach. Needs attention. | 8/2/13 | Cafeteria | in the front and back | Electrical |

| | | | | | |
|-------------------------------------|--|---------|------------------|--------------------------|------------|
| Northeast Prep Academy (2822) 2B | Bells keep going on and off per christopher Harper 416-2132 - need electrician deferred by Leslie Ratliff | 8/8/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | There are 2 lights out in the stairwell on the first floor by the boys restroom the ballast is out it is a 1 bulb light fixture. | 8/8/13 | Hallway/Corridor | Stairwell on first floor | Electrical |
| Northeast Prep Academy (2822) 2B | PORT 233-A/C NOT COMING ON-SBE HARPER KLR | 8/12/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | The light fixture in the main hallway is missing the light cover off it . single light fixture.needs attention. | 8/19/13 | Hallway/Corridor | main hallway | Electrical |
| Northeast Prep Academy (2822) 2B | UV RM 201-MAKING NOISES & MOTOR BURNING PER SBE-PLANT MGR HARPER 416-2132 KLR | 9/6/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | light blinking ballast about to go out needs attention. | 9/10/13 | Portables | portable 318 | Electrical |
| Northeast Prep Academy (2822) 2B | There are two lights out needs attention to high to reach. | 9/12/13 | Cafeteria | in the back | Electrical |
| Northeast Prep Academy (2822) 2B | Unit Ventilator is NOT COMING ON in ROOM 201 per Chistopher Harper, Plant Mgr. 416.2132 | 9/18/13 | | | Electrical |

| | | | | | |
|-------------------------------------|--|----------|---------------------|--|------------|
| Northeast Prep Academy (2822) 2B | CLOCKS RINGING OFF SCHEDULE DUE TO POWER OUTAGE-PLANT MGR HARPER 416-2132 KLR | 9/23/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | The bells were set the other day in the office but now they are off and after one rings the other one goes off and rings more than it should. | 9/26/13 | Administration Area | main office | Electrical |
| Northeast Prep Academy (2822) 2B | Bells are NOT RINGING per Christopher Harper, Plant Mgr. 416.2132 | 9/27/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | the light fixture has a short in it and the switch also has a short in it to.needs attention. | 10/18/13 | Cafeteria | over the first table in back of the cafeteria | Electrical |
| Northeast Prep Academy (2822) 2B | Bells are NOT RINGING per Christopher Harper, Plant Mgr. 416.2132 | 10/24/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | Need main clock in office set for daylight savings time | 11/4/13 | Administration Area | main office | Electrical |
| Northeast Prep Academy (2822) 2B | portable 318 there are wires hanging and no lights per Mr. Hubbard 416-2132 | 11/12/13 | | | Electrical |
| Northeast Prep Academy (2822) 2B | Fire box needs wires clamped to pole .Needs Attention. | 11/12/13 | Portables | 318 | Electrical |

| | | | | | |
|-------------------------------------|--|----------|---------------------|-------------|------------|
| Northeast Prep Academy (2822) 2B | The ballast has burned in out in the light fixture in room 206 needs attention. | 11/18/13 | Classroom | Rm 206 | Electrical |
| Northeast Prep Academy (2822) 2B | The fire alarm system keeps beeping and the message the pops up is ground fault error needs attention. | 1/16/14 | Administration Area | main office | Electrical |
| Northeast Prep Academy (2822) 2B | Unit is NOT COMING ON in PORTABLE 176 per Christopher Harper, Plant Mgr., 416.2132 | 1/27/14 | | | Electrical |
| Northeast Prep Academy (2822) 2B | UNIT COMING ON IN PORT-176 PLANT MGR-PARKER/834.2397 | 5/8/14 | | | Electrical |
| Northeast Prep Academy (2822) 2B | F/A tripped over winter break, smoke dectector in hallway in front of the bookstore bad, will not reset. | 1/3/14 | | | Electrical |
| Northeast Prep Academy (2822) 2B | UV NOT COMING ON IN RM-202, 100 PLANT MGR-HARPER/834.2397 | 1/8/14 | | | Electrical |
| Northeast Prep Academy (2822) 2B | CLASS BELLS CONTINUOUS to RING per Christopher Harper, Plant Mgr. 416.2132 | 6/24/14 | | | Electrical |
| Northeast Prep Academy (2822) 2B | need bells set to ring for summer school time for classes. | 6/10/14 | Administration Area | main office | Electrical |

| | | | | | |
|-------------------------------------|--|----------|--|--|--|
| Northeast Prep Academy (2822) 2B | A/C RM C107-NOT COOLING- PLANT MGR HARPER 416-2132 KLR | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UNIT NOT COOLING IN RM-107, PORT-117 PLANT MGR-HARPER/834.2397 | 6/9/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | replace comp in port 332 | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | per mr harper 416-2132 portable 176 unit not coming on | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | Monthly - Filter-Northeast Prep Academy - Refer to PM schedule details. | 5/9/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UNIT NOT COMING ON IN PORT- 233 PLANT MGR-HARPER/834.2397 | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | Monthly - Filter-Northeast Prep Academy - Refer to PM schedule details. | 1/10/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | Unit NOT COMING ON in ROOMS 201, 203, AND 206 per Christopher Harper, Plant Mgr. 416.2132 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------------|---|----------|--|--|---------------------------------------|
| Northeast Prep Academy (2822) 2B | HEAT RM 104 & LIBRARY-BOTH NOT HEATING-PLANT MGR HARPER 416-2132 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UNIT NOT HEATING IN RM-202 PLANT MGR-HARPER/834.2397 | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UV NOT COOLING IN LIBRARY. PLANT MGR-HARPER/416.2132 | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UNIT in PORTABLE 318 is NOT HEATING per Christopher Harper, Plant Mgr. 416.2132 | 2/26/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | BOILER NOT COMING ON PLANT MGR-HARPER/834.2397 | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UNIT ARE NOT COOLING IN RM 105,202. SBE ADIL 416-2132 | 7/17/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | PORT 318-NOT COOLING-SBE HARPER 416-2132 KLR | 8/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------------|---|---------|--|--|--|
| Northeast Prep Academy (2822) 2B | FCU 2ND FLR LIBRARY EAST- NOT COOLING-SBE HARPER 416-2132 KLR | 8/15/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | A/C PORT 318-NOT COOLING- PLANT MGR HARPER 416-2132 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | room 201 a/c not cooling per harper 416-2132 | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | UV NOT COOLING IN RM-100. PLANT MGR-HARPER/416.2132 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | Room 201 a/c leaking per Mr. Harper 416-2132 | 9/30/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | A/C PORT 233-NOT COOLING- PLANT MGR HARPER 416-2132 KLR | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | HEAT RM 202-NOT HEATING- PLANT MGR HARPER 416-3900 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | HEAT RM 100-NOT HEATING- PLANT MGR HARPER 416-2132 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------------|---|---------|-----------------|--------------------------------|---------------------------------------|
| Northeast Prep Academy (2822) 2B | Monthly - Filter-Northeast Prep Academy - Refer to PM schedule details. | 9/6/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | Monthly - Oil Lube & Belt-Macon High Academy - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Prep Academy (2822) 2B | There is a sink up stairs in the boys restroom in the custodial closet that's stopped up and the water is fowel needs attention could'nt get it down. | 8/28/13 | Restroom (Boys) | upstairs in closet of restroom | Plumbing |
| Northeast Prep Academy (2822) 2B | UV RM 201-LEAKING-PLANT MGR HARPER 416-2132 KLR | 9/4/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | SINK in the KITCHEN is BACKED UP and the WATER will NOT get HOT per Christopher Harper, Plant Mgr. 416.2132 | 2/6/14 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | There is water leaking from boys restroom upstairs into restroom downstairs needs attention. | 2/6/14 | Restroom (Boys) | 2nd floor boys | Plumbing |
| Northeast Prep Academy (2822) 2B | COMMODE B RR PORT 330-NOT FLUSHING AND IT HAS FECES IN IT-STARTING TO SMELL- PLANT MGR HARPER 416-2132 KLR | 2/21/14 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | There is a sink in the rest room when you turn it on it shoots water out needs attention. | 2/26/14 | Portables | 318 | Plumbing |

| | | | | | |
|-------------------------------------|--|---------|-----------|---------------------|----------|
| Northeast Prep Academy (2822) 2B | test back flow device -os | 7/2/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | UNIT IN RM 200 IS LEAKING SBE ADIL 416-2132 | 7/17/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | Pilot needs lit on serving line steam table per Ms. Adil 416-2132 | 7/30/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | FCU 2ND FLR RM 200-LEAKING AND WATER GOING DOWN INTO RM 103 PER SBE-SBE HARPER 416-2132 KLR | 8/7/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | FCU 2ND FLR RM 201-LEAKING & IT'S GOING DOWN INTO RM BELOW-SBE HARPER 416-2132 KLR | 8/13/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | Theres a water fountain that needs fixing nobs are off and its not working. | 8/20/13 | Cafeteria | on the side wall | Plumbing |
| Northeast Prep Academy (2822) 2B | UV IS RUNNING WATER IN RM- 105 PLANT MGR-HARPER/416.2132 | 8/22/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | The sink in the back of the kitchen leakes and needs attention | 9/17/13 | Cafeteria | in the back | Plumbing |

| | | | | | |
|----------------------------------|---|----------|------------------|-----------|----------|
| Northeast Prep Academy (2822) 2B | There is a toilet handle broken in the restroom in portable 218 needs attention. | 9/19/13 | Portables | 218 | Plumbing |
| Northeast Prep Academy (2822) 2B | The flush valve broke off in toilet in portable 318 needs attention. | 9/26/13 | Portables | 330 | Plumbing |
| Northeast Prep Academy (2822) 2B | A/C unit is LEAKING in the Facilities office in the Library per Christopher Harper, Plant Mgr. 416.2132 | 9/27/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | pilot on steam table needs to be lit per Mr. Harper 416-2132 | 9/30/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | FOUNTAIN HAS COLORED WATER IN CAFE. PLANT MGR-HARPER/834.2397 | 10/31/13 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | There is discolored water in the sink in this classroom. | 11/22/13 | Classroom | D111 | Plumbing |
| Northeast Prep Academy (2822) 2B | There is a pipe leaking in he boys restroom on the firs floor. | 1/10/14 | Restroom (Boys) | 1s floor | Plumbing |
| Northeast Prep Academy (2822) 2B | The girls restroom on the second floor is out of order he stalls are not working. | 1/10/14 | Restroom (Girls) | 2nd floor | Plumbing |

| | | | | | |
|-------------------------------------|---|----------|-----------|--|----------|
| Northeast Prep Academy (2822) 2B | TOILET is OVERFLOWING and will NOT STOP (downstairs Boy's RR) per Mr. Harper, Plant Mgr. 416.2132 | 4/21/14 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | GAS SMELL KITCHEN AREA- PLANT MGR HARPER 416-2136 KLR | 5/1/14 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | COMMODE PORT 330-NOT FLUSHING & THEY ARE HAVING CLASSES IN AREA-PLANT MGR HARPER 416-2182 KLR | 6/18/14 | | | Plumbing |
| Northeast Prep Academy (2822) 2B | There is a leake in portable 176 and its was leaking this morning. | 12/18/13 | Portables | 176 | Roof |
| Northeast Prep Academy (2822) 2B | There is aleake at the back door at the parking lot needs attention. | 2/4/14 | | | Roof |
| Northeast Prep Academy (2822) 2B | The roof is leaking in the back and on the side by the water fountain. | 8/12/13 | Cafeteria | in the back and on the side by waterfountain | Roof |
| Northeast Prep Academy (2822) 2B | Tile falling from the roof the tile is loose needs attention. | 11/18/13 | Classroom | Rm 206 | Roof |

| Count of Craft | Craft | | | | |
|------------------------------|------------|------|----------|------|-------------|
| Location | Electrical | HVAC | Painting | Roof | Grand Total |
| theast Regional Office (8731 | 6 | 3 | 1 | 6 | 16 |
| Grand Total | 6 | 3 | 1 | 6 | 16 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|--|---|----------------|---------------------|-------------|---------------------------------------|
| Northeast Regional Office (8731) 2B | there is a bad ballast in the superintendent office. | 4/24/14 | Administration Area | | Electrical |
| Northeast Regional Office (8731) 2B | BALLAST IS OUT IN THE OFFICE 37. SBE COX 416-4264 (should be North ELM. District Office). | 7/19/13 | | | Electrical |
| Northeast Regional Office (8731) 2B | AC is down (not running). | 9/4/13 | | | Electrical |
| Northeast Regional Office (8731) 2B | Air not coming on, RTS,s not running. | 9/9/13 | | | Electrical |
| Northeast Regional Office (8731) 2B | THERE IS TWO BAD LIGHT BALLAST IN THE NORTHEAST REGION BUILDING I HAVE CHANGE THE BULBS. | 9/17/13 | | | Electrical |
| Northeast Regional Office (8731) 2B | THERE IS A BAD BALLAST IN THE TRUANCY OFFICE. | 10/2/13 | | | Electrical |
| Northeast Regional Office (8731) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--|--|----------|---------------------|--|---------------------------------------|
| Northeast Regional Office (8731) 2B | Repair rooftop | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Northeast Regional Office (8731) 2B | Air out in whole bldg | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Northeast Regional Office (8731) 2B | COULD THE EXTERIOR DOORS BE PAINTED. | 11/25/13 | | | Painting |
| Northeast Regional Office (8731) 2B | THERE IS A ROOF LEAK IN ROOM A1 NEAR THE WALL. | 2/6/14 | | | Roof |
| Northeast Regional Office (8731) 2B | THERE IS A ROOF LEAK IN THE MEETING ROOM WITH THE TV INSIDE OF IT. | 4/24/14 | | | Roof |
| Northeast Regional Office (8731) 2B | THERE IS A BAD ROOF LEAK IN THE MEETING ROOM | 5/21/14 | Administration Area | | Roof |
| Northeast Regional Office (8731) 2B | THERE IS A BAD ROOF LEAK IN THE PARENT ROOM IN THE BUILDING. | 9/20/13 | | | Roof |
| Northeast Regional Office (8731) 2B | THERE IS A LARGE ROOF LEAK IN THE ROOM WITH TV MONITED ON WALL IT IS RAINING RIGHT IN FRONT OF THE TV. | 9/20/13 | | | Roof |

| | | | | | |
|--|---|---------|--|--|------|
| Northeast Regional Office (8731) 2B | THERE IS A ROOF LEAK IN OFFICE A-1 IN NORTHEAST REGION OFFICE | 11/1/13 | | | Roof |
|--|---|---------|--|--|------|

| Count of Craft | Craft | | | | | | | | | |
|---------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Artlett Meadows (25 | 1 | 1 | 17 | 64 | 55 | 3 | 20 | 3 | 1 | 165 |
| Grand Total | 1 | 1 | 17 | 64 | 55 | 3 | 20 | 3 | 1 | 165 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|--------------------------------|---|---------------|---------------|-----------------------------------|-----------|
| Ral-Bartlett Meadows (2597) 2B | Several floor tiles are lose, need replacing. | 7/24/13 | Portables | portable 213 | Asbestos |
| Ral-Bartlett Meadows (2597) 2B | Ral-bartlett Meadows WO-441717 - The flag cable is broken and wheel at the top of the pole is broken. Need repair or replacing. (SCS Network Cabling and Electronics dept. does not support this type of request. "Please See Journal Note") | 6/17/14 | Grounds | Flag Pole | Cabling |
| Ral-Bartlett Meadows (2597) 2B | Boiler room door cover braces need replacing , old ones are broken. PER OTTO | 12/15/13 | 1st Floor | Boiler room | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Insibe panel on door need repair or replace | 10/31/13 | Portables | 198 | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Need 3 cork boards fabricated and install. | 11/11/13 | 1st Floor | area 2 resource rm DR. ROBERTS | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | need a cork board fabricated and install 4ft X 8ft | 11/22/13 | 1st Floor | area 2 Esl, Mcfall | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Need a cork board fabricated and install 4ft long and 3ft wide. | 9/30/13 | 1st Floor | principal office | Carpentry |

| | | | | | |
|--------------------------------|---|----------|-----------|------------------------------|-----------|
| Ral-Bartlett Meadows (2597) 2B | Need 3 cork boards fabricated and install, 6 ft long 5 ft wide, 6ft long 40" wide, 6ft long 54" wide. | 9/30/13 | 1st Floor | Conference room | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Need a door for stall #2 | 10/16/13 | 1st Floor | Area 2 girls restrm | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Office entrance door will not close secure, door keep opening on it on. Need repair. | 7/15/13 | 1st Floor | Main office | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Need weather stripping on door to keep small animals out. | 7/18/13 | | Area 3 outside entrance door | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Need a latch install on kitchen rear door for the safety of cafeteria staff. | 7/31/13 | Kitchen | Kitchen | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | The swinging gate has seprated from the wall and hinges. Need repair for safety! | 9/4/13 | 1st Floor | Main office | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | All 6 classrms doors need weather stripping to keep the cold out, to keep mice out. | 1/28/14 | 1st Floor | Area 1 Classrms | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Door closer need replacing.Old one broken. | 1/29/14 | Portables | Portable 189 | Carpentry |

| | | | | | | |
|--------------------------------|---|----------|-----------|----------------------|--|------------|
| Ral-Bartlett Meadows (2597) 2B | DOOR IS JAMMED WONT OPEN IN PORT-199 PLANT MGR-BASKERVILLE/605.2703 | 4/4/14 | | | | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | Several floor tile need replacing | 5/30/14 | Portables | 213 | | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | The wood fence that seperates the school property from the naborhood is rotten and no longer standing. Need replacing. | 6/17/14 | Grounds | Behind Portables | | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | New floors were install in all portables and the weather stripping was remove from doors and not put back on doors. Need new weathers stripping on all doors. | 8/6/13 | Portables | 198,199,213,243,244 | | Carpentry |
| Ral-Bartlett Meadows (2597) 2B | pumps not working at all per baskerville 416-8556 | 12/5/13 | | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | There are 19 section of lights in the serving line area, 16 of the out. Bulbs were changed 2 weeks ago. Perhaps the ballasts need replacing. | 12/8/13 | Cafeteria | SERVING LINE | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Section of light is out. Ballast need replacing. | 8/6/13 | 1st Floor | Area 2 Dr Roberts rm | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | ALL PUMPS MECH RM & COOLING TOWER-ALL ARE NOT COMING ON-PLANT MGR BASKERVILLE 416-8556 KLR | 10/30/13 | | | | Electrical |

| | | | | | |
|--------------------------------|---|----------|-----------|---------------------|------------|
| Ral-Bartlett Meadows (2597) 2B | guidance office all receptacles are not working per Mr. Baskerville 416-8556 and he checked breaker | 11/8/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | 3 sections of lights are out. Ballast need replacing. | 11/21/13 | Kitchen | serving line | Electrical |
| Ral-Bartlett Meadows (2597) 2B | A/C PORT 199-NOT COMING ON-PLANT MGR BASKERVILLE 416-8556 KLR | 9/9/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | in kitchen, steam table receptacle is shooting fire per baskerville 416-8556 | 9/17/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | NO POWER TO LIGHTS IN AREA-2 HALL, & FIRE SHOOTING FROM LIGHT SWITCH PLANT MGR-BAKERVILLE/605.2703 | 9/23/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | 4 section of lights are out. Ballast need replacing. | 9/24/13 | 1st Floor | Area 1 prek rm | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Need 5 clocks repaired or replace. Clocks are not working and all have a different time. | 9/26/13 | 1st Floor | area 1,2 and 3 hall | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Need 1 full case of 24" bulbs for serving line. | 10/14/13 | 1st Floor | cafeteria | Electrical |

| | | | | | |
|--------------------------------|---|----------|-----------|---------------------------|------------|
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out. Ballast need replacing. | 10/14/13 | 1st Floor | Area 2 cluerm Dr Roberts | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Section of light is out . Ballast need replacing. | 10/15/13 | 1st Floor | Area 2 hall | Electrical |
| Ral-Bartlett Meadows (2597) 2B | RECEPTACLE KITCHEN FOR OVENS- HAS NO POWER-SBE HAS CHECKED BREAKER-PLANT MGR BASKERVILLE 416-8556 KLR | 10/24/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Section of light is out. Ballast need replacing | 10/25/13 | 1st Floor | area 1 kk room cunningham | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two section of lights are out. Ballast need replacing. | 8/5/13 | 1st Floor | Area 3 hall | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Need 3 light fixture covers, old ones are broken. | 7/15/13 | 1st Floor | hallway area 1 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out. Ballast need replacing. | 7/19/13 | Cafeteria | Cafeteria | Electrical |
| Ral-Bartlett Meadows (2597) 2B | UNIT IN RM 6 & 3 ARE NOT COMING ON SBE BASS 416-3336 | 7/22/13 | | | Electrical |

| | | | | | |
|--------------------------------|--|---------|-----------|---------------|------------|
| Ral-Bartlett Meadows (2597) 2B | 5 sections of lights are out. Ballasts need replacing. | 7/23/13 | 1st Floor | area 2 rm 8 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | 6 sections of lights are out. Ballast need replacing. | 7/23/13 | Cafeteria | Cafeteria | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Several light bulbs need replacing, cannot be reach with ladder. | 7/23/13 | Cafeteria | cafeteria | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Portable 244 - per Mr. Baskerville 416-4336 a/c not working | 7/24/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | 5 section of lights are out. Ballast need replacing. One of the children that will be in this room is partly blind so light will help. | 7/29/13 | 1st Floor | Area 2 rm 8 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Need bells to ring. Bell system need repair or replace. | 7/31/13 | 1st Floor | Main office | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Section of light is out. Baallast need replacing | 8/13/13 | 2nd Floor | Area 3 room 3 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | 5-UV NOT COMING ON IN AREA-3 ART RM, TWO-5TH GRADE CLASS, FACILITATOR RM, & GUIDANCE RM PLANT MGR-BASKERVILLE/416.4336 | 8/14/13 | | | Electrical |

| | | | | | |
|--------------------------------|--|----------|-------------|----------------|------------|
| Ral-Bartlett Meadows (2597) 2B | Section of light is out. Ballast need replacing. | 8/19/13 | 1st Floor | computer lab | Electrical |
| Ral-Bartlett Meadows (2597) 2B | UNIT HAS A BURNING SMELL IN PORT 244. PLANT MGR-BASKERVILLE/416.8556 | 8/20/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | 3 sections of lights are out. Ballast need replacing. | 9/3/13 | Kitchen | kitchen | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Outside safety lights are out need repair. | 12/30/13 | Parking Lot | walk way north | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out. Ballast need replacing. | 1/6/14 | 1st Floor | Area 2 hall | Electrical |
| Ral-Bartlett Meadows (2597) 2B | HEAT PORT 199-NOT COMING ON- PLANT MGR BASKERVILLE 416-8856 KLR | 1/7/14 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Unit is NOT COMING ON in PORTABLE 213 per Mr. Baskerville, Plant Mgr. 416.8556 | 1/7/14 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | HEAT PRE-K RM AREA 1 OPEN SPACE NOT COMING ON-PLANT MGR BASKERVILLE 416-8556 KLR | 1/8/14 | | | Electrical |

| | | | | | |
|--------------------------------|--|---------|---------------------|---------------------------|------------|
| Ral-Bartlett Meadows (2597) 2B | There are 3 sections of lights out. Ballast need replacing | 1/22/14 | 1st Floor | kk, area 1 Ms Jones | Electrical |
| Ral-Bartlett Meadows (2597) 2B | NEED 3 BOXES OF BULBS, #46807 | 1/22/14 | 1st Floor | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | There are 3 section of lights out. Ballast need replacing. | 1/24/14 | 1st Floor | Area 3 classrm ms kimmons | Electrical |
| Ral-Bartlett Meadows (2597) 2B | POWER OUTAGE - COMPLETE OUTAGE- PM/BASKERVILLE 416-8556 | 1/27/14 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Magnetic door holder coming out of the wall. | 1/29/14 | 2nd Floor | Door top of stairs E. | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Outside safety lights donot work need repair. | 2/14/14 | | covered walk n. w. | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out. Ballast need replacing. | 2/20/14 | Grounds | covered side walk n. w. | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Set Master clock of DLS time. | 3/10/14 | Administration Area | | Electrical |

| | | | | | |
|--------------------------------|---|----------|-----------|---------------------------|------------|
| Ral-Bartlett Meadows (2597) 2B | One stain ceiling tile need replacing , there is an exit light mounted to the tile. Need electrician to remove light so tile can be replaced. A TEACHER SAY THE STAIN TILE SMELL LIKE MOLD! | 4/23/14 | 1st Floor | Parent Resource Rm | Electrical |
| Ral-Bartlett Meadows (2597) 2B | per baskerville 416-8556 UV not coming on in the plant manager's office | 5/7/14 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | EXIT SIGN PORT 199-HANGING FROM CEILING BY WIRES-PLANT MGR BASKERVILLE 416-8556 KLR | 5/8/14 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | HEAT AREA 1 PRE-K RM & ART RM- BOTH NOT HEATING-PLANT MGR BASKERVILLE 416-4336 KLR | 12/11/13 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Section of light is out. Ballast need replacing. | 12/12/13 | 1st Floor | area 1 kk room cunningham | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Section of light is out. Ballast need replacing. | 3/25/14 | 1st Floor | area 3 room5 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of light are out. Ballast need replacing. | 4/2/14 | Portables | 199 portable | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out, Ballast need replacing. | 4/9/14 | 1st Floor | Area 1- Ccunningham | Electrical |

| | | | | | |
|--------------------------------|---|---------|-----------|----------------------|------------|
| Ral-Bartlett Meadows (2597) 2B | Two section of lights are out. Ballast need replacing | 4/16/14 | 1st Floor | Area 3 ms Kimmons | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out . Ballast need replacing. | 4/16/14 | 1st Floor | Area 3 Math Lab | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Emergency light do not work and need to be reinstall it just hanging by one thin wire. Area 1 emergency light do not work Ms Chaney room. | 4/16/14 | 1st Floor | Area 1 Art room | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two section of lights are out. Ballast need replacing. Section of light is flickering Ballast need replacing ,area 3 Ms West rm | 4/16/14 | 1st Floor | Area 3 Ms Wallace rm | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Three sections of lights are out . Ballast need replacing. | 4/17/14 | Portables | portable 198 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two section of lights are out. Need bucket lift to reach. | 6/16/14 | 1st Floor | cafeteria | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two sections of lights are out. Ballast need replacing. Portable 243, portable 213, prtible 198 , 1 section of light out. Ballast need replacing. | 6/16/14 | Portables | 244 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | The only light in the restrm is out. Ballast need replacing. | 6/18/14 | 1st Floor | Area 3 lounge restrm | Electrical |

| | | | | | |
|--------------------------------|---|----------|-----------|-----------------|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | Five section of lights are out. Ballast need replacing. | 6/19/14 | 1st Floor | Area 1 MS Jones | Electrical |
| Ral-Bartlett Meadows (2597) 2B | A/C UNIT IN PORT #199 - NOT COMING ON - PM/BASKERVILLE 416-8556 | 6/26/14 | | | Electrical |
| Ral-Bartlett Meadows (2597) 2B | Two section of light are out . Cannot be reach with ladder. | 10/25/13 | Cafeteria | cafeteria | Electrical |
| Ral-Bartlett Meadows (2597) 2B | The exit light has come unmounted it is located over the front door and everytime the door is slammed it comes loose. | 4/28/14 | Portables | 199 | Electrical |
| Ral-Bartlett Meadows (2597) 2B | A/C MAIN OFC AREA-NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | per mr baskerville 416-8556 the a/c is blowing hot in area 3 | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C MAIN OFC-NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C MAIN OFC-NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 5/5/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|---------|--|---------|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | per baskerville 416-8556 area 2 and area 3 are not cooling | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | per baskerville 416-8556 main office area blowing hot | 4/29/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | COOLING TOWER is NOT COOLING per Mr. Baskerville, Plant Mgr. 416.8556 | 5/23/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Check Unit Ventilators for proper outside air operation and damper control. | 4/25/14 | | Area #3 | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Filter-Raleigh Bartlett Elementary - Refer to PM schedule details. | 8/4/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Filter-Raleigh Bartlett Elementary - Refer to PM schedule details. | 12/1/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | HEAT PRE-K RM OPEN SPACE AREA- NOT HEATING-PLANT MGR BASKERVILLE 416-4336 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C in kitchen not cooling per Baskerville 416-8556 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|--|----------|--|--|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | A/C IN GUIDANCE OFC-NOT COOLING: SBE BASKERVILLE 416-8556 KLR | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | HEAT AREA 1 OPEN SPACE ABOUT (7) CLASSRMS-ALL ARE NOT HEATING- PLANT MGR BASKERVILLE 416-8556 KLR | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | office blowing cold air per baskerville 416- 8556 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | BOILER-NOT HEATING ENTIRE BLDG- PLANT MGR BASKERVILLE 416-4336 KLR | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | RTU NOT HEATING IN MAIN OFFICE PLANT MGR-BASKERVILLE/493.4593 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | 3-UV NOT COOLING IN FACILITATOR, GUIDANCE, & CONFERENCE OFFICES PLANT MGR-BASKERVILLE/416.5556 | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C PRE-K RM AREA 2 & FAC/GUID OFCS-ALL NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Unit Ventilator unit in the Pre-K Room is NOT COMING ON per Baskerville, Plant Mgr. 416.8556 | 9/27/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|--|---------|--|--|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | A/C PRE-K RM OPEN SPACE AREA 1- NOT COOLING-PLANT MGR BASKERVILLE KLR | 10/3/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UV AREA 1 SE WALL SOUTH SERVES ART RM-NOT COOLING-SBE BASKERVILLE 416-8556 KLR | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | (Chiller down) Per Bassville, SBE at 416.4336 | 7/5/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Oil Lube & Belt-Raleigh Bartlett Elem. - Refer to PM schedule details. | 7/14/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UNIT IN ART IN RM IS NOT COOLING. SBE BASKERVILLE 416-8556 | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UV NOT COOLING IN RM-8, AREA-1. PLANT MGR-BASERVILLE/416.8556 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | AHU'S MAIN OFC, PRIN'S OFC, FACILITATOR'S OFC, ART RM, & GUIDANCE OFC-ALL NOT COOLING-SBE BASKERVILLE 416-8566 KLR | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C IN PORT 244-NOT COOLING-SBE BASKERVILLE 416-8556 KLR | 8/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|--|---------|--|--|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | UV NOT COOLING IN AREA-3 (9RM). PLANT MGR-BASERVILLE/ | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Air Comp-Mech Rm N. Wall W.- Ral Bart EI - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Air Comp-Boilr Rm W. Wall N.- Ral Bart EI - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | AREA 3 FACILITATOR'S OFC, GUIDANCE OFC, COMPUTER LAB & (2) CLASSRMS-ALL NOT COOLING- SBE BASKERVILLE 416-8556 KLR | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | RTU CONFERENCE RM-NOT COMING ON-PLANT MGR BASKERVILLE 416- 8556 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UV NOT COOLING IN FACILITATORS RM PLANT MGR-COLEMAN/416.8556 | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | RTU NOT COOLING IN MAIN OFFICE PLANT MGR-BASKERVILLE/416.8556 | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UV NOT COMING ON IN KITCHEN. PLANT MGR-BASKERVILLE/416.8556 | 9/3/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|----------|--|--|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | RTU NOT COMING ON MAIN OFFICE. PLANT MGR-BASKERVILLE/493.4593 | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Unit is NOT HEATING in the MAIN OFFICE per Mr. Baskerville, Plant Mgr. 416.8556 | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | BOILER MECH RM-NOT COMING ON-PLANT MGR BASKERVILLE 416-8556 KLR | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Oil Lube & Belt-Raleigh Bartlett Elem. - Refer to PM schedule details. | 2/16/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Air Comp-Mech Rm N. Wall W. Ral Bart El - Refer to PM schedule details. | 2/18/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Air Comp-Boilr Rm W. Wall N. Ral Bart El - Refer to PM schedule details. | 2/18/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UV AREA 3 RM 2-COVER DAMAGED BY TEACHER TRYING TO WORK ON UNIT PER SBE-PLANT MGR BASKERVILLE 416-4336 KLR | 2/25/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C FACILITATOR'S OFC, GUIDANCE OFC, COMPUTER LAB, & AFTERCARE OFC-ALL NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------------|---|----------|--|--|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | UNIT NOT COOLING IN FACILITATOR RM, GUIDANCE OFFICE, AFTER CARE OFFICE, ART RM, COMPUTER RM PLANT MGR-BASKERVILLE/605.2703 | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | boiler not running per Baskerville 416-8556 | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | BOILER MECH RM-NOT COMING ON- PLANT MGR BASKERVILLE 416-8556 KLR | 3/26/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | HEAT MAIN OFC AREA-NOT HEATING- PLANT MGR BASKERVILLE 416-8556 KLR | 3/26/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C PORT 213-NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C PORT 213-NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 4/10/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | A/C PORT 213-NOT COOLING-PLANT MGR BASKERVILLE 416-8556 KLR | 4/17/14 | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | UNIT IN THE GUIDANCE OFFICE IS NOT COOLING. SBE BASKERVILLE 416-8556 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|--------------------------------|--|----------|-----------------|-------------|--|---------------------------------------|
| Ral-Bartlett Meadows (2597) 2B | Yearly - Oil Samples-Raleigh-Egypt Elementary - Refer to PM schedule details. | 9/7/13 | | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Monthly - Filter-Raleigh Bartlett Elementary - Refer to PM schedule details. | 3/30/14 | | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Yearly - Cooling TowersSTRAINER-Ral Bartlett Mead - Refer to PM schedule details. | 3/18/14 | | | | Heating/Ventilation /Air Conditioning |
| Ral-Bartlett Meadows (2597) 2B | Wall across from handwashing sink need painting. PER PRINCIPAL LEWIS! | 7/16/13 | 1st Floor | Area 2 hall | | Painting |
| Ral-Bartlett Meadows (2597) 2B | Wall across from restrm need painting before the start of school. PER PRINCIPAL LEWIS! | 8/6/13 | 1st Floor | AREA 2 | | Painting |
| Ral-Bartlett Meadows (2597) 2B | Wall by resource room across from handwashing sinks need painting 10ft x 6ft. Honors program is Tuesday 11-18-13 9:30am. If at all possible Principal Lewis would like this small area painted before the program. Second request. | 11/12/13 | 1st Floor | Area 2 hall | | Painting |
| Ral-Bartlett Meadows (2597) 2B | Test and repair RP Devices per MLG&W. | 10/10/13 | Mechanical Room | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Three (3) compartment sink in the KITCHEN is STOPPED UP per Mr. Baskerville, Plant Mgr. 416.8556 | 10/15/13 | | | | Plumbing |

| | | | | | |
|--------------------------------|--|----------|-----------|---------------------|----------|
| Ral-Bartlett Meadows (2597) 2B | Commode in stall 1 and 4 are stopped up . Use plunger and snake and the water still over flows. | 10/16/13 | 1st Floor | Girls restrm area 3 | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Commode in stall 3 is stopped up. Commode cannot be use. | 10/16/13 | 1st Floor | Area 2 girls restrm | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Handwashing sink do not work . Need repair. | 10/18/13 | 1st Floor | Area 2 hall | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Handwashing sink outside boys rest room does not work. Kids cannot wash their hands. | 8/5/13 | 1st Floor | Area 2 hall | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Commode #3 is stopped up cannot be flush, using the snake does no good . Need repair or replacing. | 8/12/13 | 1st Floor | Girls Restrm Area 1 | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | 3-COMPARTMENT SINK KITCHEN-ALL (3) SIDES STOPPED UP PER SBE-SBE BASKERVILLE 416-8556 KLR | 8/14/13 | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | repair busted water main-os | 12/16/13 | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Broken WATER MAIN per Mr. Baskerville, Plant Mgr. 416.8556 | 12/16/13 | | | Plumbing |

| | | | | | |
|--------------------------------|--|----------|-----------|---------------------|----------|
| Ral-Bartlett Meadows (2597) 2B | WATER IS LEAKING FROM FLR IN RESOURCE RM PLANT MGR-BASKERVILLE/416.4336 | 1/15/14 | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Commode has to be flush many many time before everything goes down. Flush handle and stopped up | 2/5/14 | 1st Floor | Boys restrm area 3 | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Commode will not flush at all. | 2/5/14 | 1st Floor | Girls area 3 | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | (Commode number 2) Commode is stopped up , cannot be flush. | 2/14/14 | 1st Floor | Area 3 girls restrm | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | (Commode against the wall) Commode has to flush many times before the water and the body waste goes down. Need repair. | 2/14/14 | 1st Floor | Area 3 Boys restrm | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | NO HOT WATER IN KITCHEN PLANT MGR-BASKERVILLE/605.2703 | 4/28/14 | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Commode in stall 2 when flushed leak from the flush handle. Need repair. | 12/13/13 | 1st Floor | Girls restrm area 3 | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | COOLING TOWER PIPE IS LEAKING WATER . PLANT MGR-BASKERVILLE/605.2703 | 4/16/14 | | | Plumbing |

| | | | | | | |
|--------------------------------|---|----------|-----------|--------------------------------------|--|-------------|
| Ral-Bartlett Meadows (2597) 2B | FAUCET HANDLE HAS CAME OFF IN KITCHEN PLANT MGR-BASKERVILLE/605.2703 | 4/29/14 | | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | Sewer Gas smell in AREA 2 per Mr. Baskerville, Plant Mgr. 416.8556 | 12/11/13 | | | | Plumbing |
| Ral-Bartlett Meadows (2597) 2B | When it rain water leak in from the roof to the ceiling to the floor. | 2/5/14 | Portables | 199 | | Roof |
| Ral-Bartlett Meadows (2597) 2B | A leak in the area of the door around the exit light. Need repair. | 4/23/14 | 1st Floor | parent Resource Rm | | Roof |
| Ral-Bartlett Meadows (2597) 2B | There is at the entrance of area 3. | 4/23/14 | 1st Floor | Area 3 entrance | | Roof |
| Ral-Bartlett Meadows (2597) 2B | All portables got new floors during the summer. The weather stripping was removed from the doors and was not put back. All portables need weather stripping put back to keep snakes, etc from getting in. | 7/29/13 | Portables | Portables 198, 199, 213, 243, 244 | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|-----------------------|----------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| | Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal |
| Richland ES (2600) 2B | 3 | 3 | 57 | 69 | 72 | 2 | 58 | 5 | 2 | 271 |
| Grand Total | 3 | 3 | 57 | 69 | 72 | 2 | 58 | 5 | 2 | 271 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|-----------------------|---|----------------|------------------|----------------------|-----------|
| Richland ES (2600) 2B | abate T.S.I. in boiler rm. 26 ft. ft. | 10/3/13 | Mechanical Room | boiler rm. | Asbestos |
| Richland ES (2600) 2B | remove floor tile in hallway in front of girls and boys restroom | 3/25/14 | Hallway/Corridor | | Asbestos |
| Richland ES (2600) 2B | abate floor tile outside of restrooms on 2nd floor | 6/6/14 | Hallway/Corridor | | Asbestos |
| Richland ES (2600) 2B | Richland ES- WO#370737- need network drop repaired for Plant Manager's office- no Internet or Telephone access(Request Network Cabling Maintenance Repair). | 8/5/13 | Cafeteria | custodial break room | Cabling |
| Richland ES (2600) 2B | “REQUEST RECEIVED” internet drops not responding, or phone service | 9/7/13 | | | Cabling |
| Richland ES (2600) 2B | NCE staff -requested to survey and inspect low voltage and or network cabling being performed at Richland EI as a result of ongoing EMS project. Give daily or periodic email reports of finding to Mr. Ratliff and to the General Services | 2/13/14 | | | Cabling |
| Richland ES (2600) 2B | there is a jagged piece of metal hanging down on the bottom of portable (27) front door, making it difficult to open and close, need repairing | 10/8/13 | Portables | portable 27 | Carpentry |

| | | | | | |
|-----------------------|--|----------|-----------|---------------|-----------|
| Richland ES (2600) 2B | Pick-up toilet and floor tiles. | 10/15/13 | | | Carpentry |
| Richland ES (2600) 2B | Install fence around the boiler. | 10/22/13 | | | Carpentry |
| Richland ES (2600) 2B | Re-install window. | 10/22/13 | | | Carpentry |
| Richland ES (2600) 2B | entrance/exit door won't secure (room 110) per ms. macon 416-4128 | 10/29/13 | | | Carpentry |
| Richland ES (2600) 2B | portable #27 has crumbled tiles, tripping hazard, need replacing | 11/6/13 | Portables | portable # 27 | Carpentry |
| Richland ES (2600) 2B | window has fallen out of frame southeast breezeway per Ms. Macon 416-2148 | 11/7/13 | | | Carpentry |
| Richland ES (2600) 2B | OUTSIDE EXIT DOOR NORTHEAST BREEZEWAY WONT LATCH, CANT SECURE PLANT MGR- MACON/416.2148 | 11/18/13 | | | Carpentry |
| Richland ES (2600) 2B | there are several crumbled floor tiles in portable 27 that need replacing, tripping hazard | 11/18/13 | Portables | portable # 27 | Carpentry |

| | | | | | |
|-----------------------|--|----------|------------------|---------------------------------|-----------|
| Richland ES (2600) 2B | there are several crumbled floor tiles in portable #5 that need replacing, tripping hazard | 11/18/13 | Portables | portable # 5 | Carpentry |
| Richland ES (2600) 2B | fence needs to be put around outside boiler unit ASAP, hot pipes, safety issue | 12/2/13 | Grounds | back northeast side of building | Carpentry |
| Richland ES (2600) 2B | cafeteria door by/on office side coming off hinges, need repairing | 12/11/13 | Cafetorium | cafeteria | Carpentry |
| Richland ES (2600) 2B | cable on flag pole jammed, can't bring down flag, need repairing | 12/16/13 | Grounds | flag pole | Carpentry |
| Richland ES (2600) 2B | floor tiles in southwest breezeway loose and broken, tripping hazard, need replacing | 1/2/14 | Hallway/Corridor | breezeway | Carpentry |
| Richland ES (2600) 2B | floor tiles in southeast breezeway loose and broken, tripping hazard, need replacing | 1/2/14 | Hallway/Corridor | southeast breezeway | Carpentry |
| Richland ES (2600) 2B | exit door in room 110 hard to open, safety hazard, need repairing | 7/25/13 | 1st Floor | room 110 | Carpentry |
| Richland ES (2600) 2B | front door of portable # 27 is rotted out across the bottom, large gap (bottom opening) in door need replacing | 1/7/14 | Portables | portable 27 | Carpentry |

| | | | | | |
|-----------------------|--|--------|-----------|---------------|-----------|
| Richland ES (2600) 2B | room 115 has crumbled tiles in front door, tripping hazard, need replacing | 1/7/14 | Classroom | room 115 | Carpentry |
| Richland ES (2600) 2B | need flag pole bracket put up in room 128 (Mrs. Hood) room | 8/9/13 | 1st Floor | room 112 | Carpentry |
| Richland ES (2600) 2B | need flag pole bracket put up in room 112 (Ms. Viglietti) | 8/9/13 | 1st Floor | room 112 | Carpentry |
| Richland ES (2600) 2B | PORT 7-HARDWARE DAMAGED-WON'T BE ABLE TO SECURE-PLANT MGR JEFFERSON KLR | 9/4/13 | | | Carpentry |
| Richland ES (2600) 2B | steps to portable (#7) has come loose,very shaky, need repairing | 8/5/13 | Portables | Portable # 7 | Carpentry |
| Richland ES (2600) 2B | back steps on portable 5 falling apart, need repairing | 8/5/13 | Portables | portable # 5 | Carpentry |
| Richland ES (2600) 2B | shelf on back wall need replacing/repairing in portable # 90 | 8/5/13 | Portables | portable # 90 | Carpentry |
| Richland ES (2600) 2B | ramp got hit by tractor has come off support block/beam need repairing | 8/5/13 | Portables | portable #90 | Carpentry |

| | | | | | |
|-----------------------|---|---------|---------------------|----------------------------|-----------|
| Richland ES (2600) 2B | teacher request cork board to be hung in portable #90 | 8/5/13 | Portables | portable #90 | Carpentry |
| Richland ES (2600) 2B | several floor tiles have come up in portable 287, tripping hazard, need replacing | 8/8/13 | Portables | portable 287 | Carpentry |
| Richland ES (2600) 2B | Threshold plate in portable #287 has come up from floor, need replacing | 8/8/13 | Portables | portable 287 | Carpentry |
| Richland ES (2600) 2B | need to be secured | 9/7/13 | Administration Area | front entrance window west | Carpentry |
| Richland ES (2600) 2B | windows north/south need to be secured, entry can be gain through areas | 9/7/13 | 1st Floor | breezeways north/south | Carpentry |
| Richland ES (2600) 2B | cafeteria door on northwest hall too hard/heavy for children to push open, need repairing | 9/12/13 | Cafeteria | northwest hallway | Carpentry |
| Richland ES (2600) 2B | third window leaks rain inside, need sealing/repairing | 9/23/13 | Portables | portable #5 | Carpentry |
| Richland ES (2600) 2B | window won't close in northwest breezeway, need repairing | 9/23/13 | Hallway/Corridor | north west breezeway | Carpentry |

| | | | | | |
|-----------------------|--|---------|------------------|------------------------|-----------|
| Richland ES (2600) 2B | DOOR WONT OPEN IN TEACHERS' LOUNGE 1ST FLR (TEACHER IS STUCK IN THIS RM) PLANT MGR- MACON/416.2148 | 9/23/13 | | | Carpentry |
| Richland ES (2600) 2B | wood floor board in front of portable 9 front door (outside) is very weak, sinks in when stepped on, need replacing | 1/17/14 | Portables | portable 9 | Carpentry |
| Richland ES (2600) 2B | rear entry porch missing bolt where deck attaches to leg, porch pulled away from building need repairing | 1/24/14 | Portables | portable # 228 | Carpentry |
| Richland ES (2600) 2B | several pieces of floor tiles have come loose/up in the southwest breezeway, tripping hazard, need replacing | 1/28/14 | Hallway/Corridor | southwest breezeway | Carpentry |
| Richland ES (2600) 2B | several pieces of floor tiles have come loose/up in the northwest breezeway, tripping hazard, need replacing | 1/28/14 | Hallway/Corridor | northwest breezeway | Carpentry |
| Richland ES (2600) 2B | exterior stairwell landing through out all wings have steel railing columns that has rusted out, making railing unsafe, need repairing | 1/30/14 | Stairway | outside back northwest | Carpentry |
| Richland ES (2600) 2B | door latch on portable 228 is broken, door won't stay closed, need repairing | 2/3/14 | Portables | portable 228 | Carpentry |
| Richland ES (2600) 2B | broken floor tiles throughout entire portable, tripping hazard need replacing (12x12) | 2/19/14 | Portables | portable #196 | Carpentry |

| | | | | | |
|-----------------------|---|---------|-----------|----------------|-----------|
| Richland ES (2600) 2B | glass broken out of classroom 204 window, needs replacing | 3/18/14 | Classroom | room 204 | Carpentry |
| Richland ES (2600) 2B | Cover the man on the south end of the BLDG. | 3/20/14 | | | Carpentry |
| Richland ES (2600) 2B | face plate inside front door is rotted out and loose, need repairing | 3/26/14 | Portables | portable #90 | Carpentry |
| Richland ES (2600) 2B | front door will not close by it self, has to be pulled/pushed up, need repairing | 3/26/14 | Portables | portable #90 | Carpentry |
| Richland ES (2600) 2B | The EXIT DOOR in ROOM 202 HANDLE is BROKEN per Ms. Macon, Plant Mgr. 416.4128 | 6/26/14 | | | Carpentry |
| Richland ES (2600) 2B | door handle (inside) in room 202 (southeast wing) is hanging off, need repairing/replacing | 6/23/14 | Classroom | rm 202 | Carpentry |
| Richland ES (2600) 2B | portable #9 has worn/torn carpet that needs to be removed/replaced, it's also a tripping hazard | 6/25/14 | Portables | portable #9 | Carpentry |
| Richland ES (2600) 2B | repair existing handrails (2) in southwest wing courtyard | 5/23/14 | Courtyard | southwest wing | Carpentry |

| | | | | | |
|-----------------------|---|---------|------------|----------------|-----------|
| Richland ES (2600) 2B | patch concrete steps in northeast wing courtyard | 5/23/14 | Courtyard | northeast wing | Carpentry |
| Richland ES (2600) 2B | WINDOW BROKEN IN PORT-27 PLANT MGR- MACON/416.2148 | 6/17/14 | | | Carpentry |
| Richland ES (2600) 2B | Repair the floor the portable #90. | 4/3/14 | | portable 90 | Carpentry |
| Richland ES (2600) 2B | Request trash be remove out side of the boiler room. | 4/10/14 | | | Carpentry |
| Richland ES (2600) 2B | OUTSIDE DOOR CAN'T SECURE ASSIST PRIN OFFICE PLANT MGR- MACON/416.2148 | 4/11/14 | | | Carpentry |
| Richland ES (2600) 2B | METAL is sticking OUT OF DOOR in PORTABLE 9 per Ms. Macon, Plant Mgr. 416.4128 | 4/21/14 | | | Carpentry |
| Richland ES (2600) 2B | board/step to portable #7 on front side has come up, tripping hazard need repairing | 4/23/14 | Portables | portable #7 | Carpentry |
| Richland ES (2600) 2B | the pulley system for stage curtains doesn't work, can't/won't open/close curtains need repairing | 1/2/14 | Cafetorium | stage | Carpentry |

| | | | | | |
|-----------------------|--|----------|---------------------|---------------------------|------------|
| Richland ES (2600) 2B | power went out last week master clock need resetting, per principle's request | 10/1/13 | Administration Area | main office | Electrical |
| Richland ES (2600) 2B | ballast out in light fixture on southeast side of hallway, need repairing | 10/1/13 | 1st Floor | southeast hallway | Electrical |
| Richland ES (2600) 2B | fire panel box in alarm beeps, saying "MAINT ALERT" SMOKE DETECTOR N.W. SMOKE DOORS WEST advised by Mr. Albert Herman to put on schooldude under electrical need repairing | 10/9/13 | Administration Area | main office | Electrical |
| Richland ES (2600) 2B | Hook-up power to temp boiler. | 10/15/13 | | | Electrical |
| Richland ES (2600) 2B | LIGHTS RM 205-NOT COMING ON AT ALL-VERY DARK IN RM PER SBE-PLANT MGR MACON 416-2148 KLR | 10/22/13 | | | Electrical |
| Richland ES (2600) 2B | room 213 has ballast out, changed bulbs ballast need replacing | 10/24/13 | Classroom | northwest wing rm. 213 | Electrical |
| Richland ES (2600) 2B | NO POWER IN ASSIS PRIN OFFICE. PLANT MGR- MACON/416.2148 | 10/28/13 | | | Electrical |
| Richland ES (2600) 2B | ballast out in Library, replaced bulbs need repairing | 10/28/13 | Library | | Electrical |

| | | | | | |
|-----------------------|---|----------|---------------------|------------------------|------------|
| Richland ES (2600) 2B | portable #27 has ballast out, changed bulbs need replacing | 10/28/13 | Portables | portable 27 | Electrical |
| Richland ES (2600) 2B | master clock in main office need resetting for daylight saving time. | 11/5/13 | Administration Area | main office | Electrical |
| Richland ES (2600) 2B | UV NOT COMING ON IN RM-201. PLANT MGR- MACON/416.2148 | 11/13/13 | | | Electrical |
| Richland ES (2600) 2B | there are only two lights working on stage,music classes are held on stage daily need lights replaced (flood) before stage goes completely dark | 11/26/13 | Cafetorium | stage | Electrical |
| Richland ES (2600) 2B | portable 228 is dark and turn switch on and no lights come on per Ms. Macon 416-4128 (they have special needs children in portable) | 12/3/13 | | | Electrical |
| Richland ES (2600) 2B | NO POWER TO PRIN/RR PLANT MGR- MACON/416.2148 | 12/20/13 | | | Electrical |
| Richland ES (2600) 2B | ASST. PRINC OFFICE RM IS COMPLETE DARK BREAKER TRIPPED. SBE MACON 416- | 7/22/13 | | | Electrical |
| Richland ES (2600) 2B | outside light fixture (front entrance) is blown and making humming noise, need repairing | 7/22/13 | Administration Area | outside front entrance | Electrical |

| | | | | | |
|-----------------------|---|---------|-----------------|-----------------------------|------------|
| Richland ES (2600) 2B | exhaust fan in assistant principals restroom not working need repairing | 7/22/13 | Restroom (Boys) | assistant principals office | Electrical |
| Richland ES (2600) 2B | ballast out in room 10 first floor (east end) need replacing | 7/22/13 | 1st Floor | room # 10 | Electrical |
| Richland ES (2600) 2B | 20-BALLAST ARE OUT IN RM-6, 13, 209, 213, 215, 115, 116, 114, 113, 11, 201, 202, 204, 205, 206, 208, 107, 108, 106, 102. SBE-MACON/416-2148 | 7/22/13 | | | Electrical |
| Richland ES (2600) 2B | alarm panel showing trouble per Ms. Macon 416-2148 | 1/13/14 | | | Electrical |
| Richland ES (2600) 2B | ballast out in portable #27, replaced bulbs still no lights, need repairing | 8/12/13 | Portables | portable #27 | Electrical |
| Richland ES (2600) 2B | UV-53 SERVING LINE-NOT COMING ON-SBE MACON 416 4128 KLR | 8/13/13 | | | Electrical |
| Richland ES (2600) 2B | ballast out in computer lab, (rm. 8) need replacing | 8/13/13 | 1st Floor | room 8, computer lab | Electrical |
| Richland ES (2600) 2B | ballast out in back hallway light fixture, need replacing | 8/13/13 | 1st Floor | back hallway by rm. #8 | Electrical |

| | | | | | |
|-----------------------|--|---------|-----------|-------------------------|------------|
| Richland ES (2600) 2B | NO POWER TO RECEPTACLES IN RM 207 & IN RM 110-RECEPTACLE FROM CEILING IS HUMMING & SMOKING PER PLANT MGR. PLANT MGR MACON 416-2148 KLR | 8/20/13 | | | Electrical |
| Richland ES (2600) 2B | POWER OUTAGE IN RM-107,207 PLANT MGR- MACON/416.2148 | 8/28/13 | | | Electrical |
| Richland ES (2600) 2B | need elect. to remove power from boiler-os | 8/28/13 | | | Electrical |
| Richland ES (2600) 2B | can't get flag up or down daily, cable seems to be stuck won't release to raise or lower flag. Tried several times no luck. need repairing | 8/30/13 | Grounds | flag pole | Electrical |
| Richland ES (2600) 2B | need more security lighting on poles,area to dark at night entry purpose (If exsisting lights are working that's good enough). OS | 9/4/13 | Grounds | rear parking lot | Electrical |
| Richland ES (2600) 2B | need flouresent light bulbs for hallways, classrooms,portables,etc..... throughout building | 7/31/13 | Classroom | all throughout building | Electrical |
| Richland ES (2600) 2B | LIGHT - SW WING G RR - VERY DARK - PM/MACON 416-2148 | 8/5/13 | | | Electrical |
| Richland ES (2600) 2B | ballast out in portable #196, need repairing | 8/5/13 | Portables | portable #196 | Electrical |

| | | | | | |
|-----------------------|---|--------|---------------------|-------------|------------|
| Richland ES (2600) 2B | master clock needs programing for new start time | 8/6/13 | Administration Area | main office | Electrical |
| Richland ES (2600) 2B | Girl's RR in S.E. wing (Kindergarten wing) totally darkest (balances are out) per Ms. Macon, Plant Mgr. - 901.416.2148. | 8/7/13 | | | Electrical |
| Richland ES (2600) 2B | NO POWER TO LIGHT IN G/RR NORTH-WEST WING. PLANT MGR- MACON/416.2148 | 8/9/13 | | | Electrical |
| Richland ES (2600) 2B | no security lighting | 9/7/13 | Portables | rm.07 | Electrical |
| Richland ES (2600) 2B | no security lights | 9/7/13 | Portables | rm.198 | Electrical |
| Richland ES (2600) 2B | no security lights | 9/7/13 | Portables | rm.196 | Electrical |
| Richland ES (2600) 2B | no security lights | 9/7/13 | Portables | rm.15 | Electrical |
| Richland ES (2600) 2B | no security lights | 9/7/13 | Portables | rm.228 | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|------------------------|------------|
| Richland ES (2600) 2B | no security lights | 9/7/13 | Portables | rm.04 | Electrical |
| Richland ES (2600) 2B | security lights attached each side of building not working | 9/7/13 | Grounds | security lights | Electrical |
| Richland ES (2600) 2B | cord need re-threaded | 9/7/13 | Administration Area | flag-pole | Electrical |
| Richland ES (2600) 2B | repair lights,more security | 9/7/13 | Portables | rm.90 | Electrical |
| Richland ES (2600) 2B | lights out on each side of building out back by portables safety issue at night, need replacing/repairing | 9/12/13 | Parking Lot | back of building | Electrical |
| Richland ES (2600) 2B | ballast out in room 213 (northwest wing) replaced bulbs need repairing | 9/23/13 | Classroom | room 213 | Electrical |
| Richland ES (2600) 2B | ballast out in room 208, (northeast wing) changed light bulbs need repairing | 9/24/13 | Classroom | northeast wing rm. 208 | Electrical |
| Richland ES (2600) 2B | outlet in cafeteria manager's office dosen't work, need repairing | 1/16/14 | Cafeteria | manager's office | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|-----------------------|------------|
| Richland ES (2600) 2B | magnetic doors will not stay open when connected to strip, fire panel in main office reads: TROUBLE, S.E. Smoke doors East was told to put on schooldude per Mr. Albert Herman's directions, need repairing | 1/27/14 | Administration Area | main office | Electrical |
| Richland ES (2600) 2B | need fluorescent light bulbs for hallways and classrooms etc.... 3 boxes if possible. | 1/31/14 | Administration Area | through out building | Electrical |
| Richland ES (2600) 2B | handle/knob? broke off thermostat, has to use paper clip to operate it, need replacing/repairing | 1/31/14 | Portables | portable #287 | Electrical |
| Richland ES (2600) 2B | light globe missing outside light south - east front of bldg.-os | 2/3/14 | | | Electrical |
| Richland ES (2600) 2B | light fixture in room 3 has bad ballast that need replacing | 2/13/14 | Classroom | room 3 | Electrical |
| Richland ES (2600) 2B | ballast out in portable #15, changed bulbs need replacing | 2/26/14 | Portables | portable #15 | Electrical |
| Richland ES (2600) 2B | clock in office need resetting per daylight saving time | 3/21/14 | Administration Area | main office | Electrical |
| Richland ES (2600) 2B | two (2) 400 watt pole lights (back parking lot by the portables) are on all day, need repairing/replacing so they only come on at night | 3/28/14 | Parking Lot | back lot by portables | Electrical |

| | | | | | |
|-----------------------|---|---------|-----------|------------------|------------|
| Richland ES (2600) 2B | FIRE ALARM MAIN OFC- SHOWING TROUBLE-PLANT MGR MACON 416-2148 KLR | 6/10/14 | | | Electrical |
| Richland ES (2600) 2B | 2-WINDOW UNITS NOT COOLING PORT-7 PLANT MGR- MACON/416.2166 | 4/21/14 | | | Electrical |
| Richland ES (2600) 2B | balance need replacing in portable #9, changed bulbs still don't work | 4/23/14 | Portables | portable # 9 | Electrical |
| Richland ES (2600) 2B | balance need replacing in portable #228 on both sides of room (partioned off) changed bulbs still don't work | 4/23/14 | Portables | portable #228 | Electrical |
| Richland ES (2600) 2B | wall receptacles don't work on one side of room (portable 228) checked braker, not tripped, need repairing | 4/24/14 | Portables | portable #228 | Electrical |
| Richland ES (2600) 2B | ballast out in room 101, need replacing | 4/24/14 | Classroom | room 101 | Electrical |
| Richland ES (2600) 2B | room 104 has ballast out, need replacing | 4/24/14 | Classroom | room 104 | Electrical |
| Richland ES (2600) 2B | classrooms 201 & 202 has ballast out, need replacing | 4/24/14 | Classroom | rooms 201,202 | Electrical |

| | | | | | |
|-----------------------|---|---------|---------------------|--------------------|---------------------------------------|
| Richland ES (2600) 2B | classrooms 111,113,114 has ballast out, need replacing | 4/24/14 | Classroom | rooms 111,113,114, | Electrical |
| Richland ES (2600) 2B | room 116 has ballast out, need replacing | 4/24/14 | Classroom | room 116 | Electrical |
| Richland ES (2600) 2B | room 116 has hanging light fixture cover that won't stay closed, need repairing | 4/24/14 | Classroom | room 116 | Electrical |
| Richland ES (2600) 2B | parking lot has poor security lighting | 9/7/13 | Parking Lot | security poles | Electrical |
| Richland ES (2600) 2B | flagpole need a cord repair,not able to raise flag | 9/4/13 | Administration Area | flagpole | Electrical |
| Richland ES (2600) 2B | A/C PORT 287-MAKING LOUD NOISES-PLANT MGR MACON 416-2148 KLR | 4/25/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C PORT 287-NOT COOLING- PLANT MGR MACON 416-2148 KLR | 5/21/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UNIT NOT COOLING IN PORT- 287 PLANT MGR- MACON/416.2148 | 5/9/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | A/C PORT 27 & 287-BOTH NOT COOLING-PLANT MGR MACON 416-2148 KLR | 6/19/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C UNIT is NOT COOLING in FACILITATOR'S OFFICE across from MAIN OFFICE per Ms. Macon, Plant Mgr. 416.4128 | 6/26/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | per Ms. Macon 416-2148 rooms 103 and 110 are blowing cold air | 1/15/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Replace Port. 196 a/c | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Replace Port. 195 a/c | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Replace Port. 194 a/c | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Unit Ventilator NOT COOLING in ROOM 208 per Ms. Macon, Plant Mgr. 416.4128 | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 2-UV NOT COOLING IN COMPUTER LAB RM PLANT MGR- MACON/416.2148 | 10/3/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|---------------------|-----------------|---------------------------------------|
| Richland ES (2600) 2B | per Ms. Macon 416-4128 room 110 a/c not cooling | 10/3/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | the west wing of school has no heat per Ms. Macon 416-4128 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RM 104-LEAKING OIL & NOT HEATING-PLANT MGR MACON 416-2148 KLR | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RM 105-GAS SMELL & LEAKING OIL PER SBE- PLANT MGR MACON 416-2148 KLR | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | east wing rooms 204, 206, 106 and west wing rooms 209, 211, 109 are blowing cold air per ms. Macon 416-2148 also rooms 107 and 101 a/c is on but need to be turned off (per em) | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 3-UV NOT HEATING IN RM-209,109,COMPUTER LAB PLANT MGR- MACON/416.2148 | 11/18/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | TEMPORARY BOILER-NOT COMING ON-AFFECTS THE ENTIRE BLDG-PLANT MGR MACON 416-2148 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | need assistant/training in resetting portable boiler for building ASAP | 11/25/13 | Administration Area | portable boiler | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|--|--|---------------------------------------|
| Richland ES (2600) 2B | HEAT RMS 106, 105, 107, 108, & 103-ALL NOT HEATING-PLANT MGR MACON 416-2148 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UNIT HEATING IN PORT-287 PLANT MGR-MACON/416.2148 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | entire building cold, portable boiler is in alarm per Ms. Macon 416-4128 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Unit Ventilators are NOT HEATING in ROOMS 210 & 211 per Ms. Macon, Plant Mgr. 416.2148 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Unit Ventilator is NOT HEATING in Room 109 per Ms. Macon, Plant Mgr. 416.2148 | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RMS 109, 209, 210, 211, 212, & 208-ALL NOT HEATING-PLANT MGR MACON 416-2148 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RM 110-NOT HEATING-PLANT MGR MACON 416-2148 KLR | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 21-UV NOT COOLING THRU ENTIRE NORTH-WING. SBE-MACON/416-2148 | 7/3/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | HEAT COMPUTER LAB, NO RM NUMBER PER SBE-NOT HEATING-PLANT MGR MACON 416-2148 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT LIBRARY AREA-NOT HEATING-PLANT MGR MACON 416-2148 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Units are NOT HEATING in the CAFETERIA and in Room 215 per Ms. Macon, Plant Mgr. 416.4128 | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RMS 104, 106, 206, 204, 202, 201, 113, 215, 213, PORT 27, & LIBRARY-ALL NOT HEATING-PLANT MGR MACON 416-2148 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RM 110-NOT HEATING-PLANT MGR MACON 416-2148 KLR | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | make repairs to piping in room 106, & computer lab-os | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UNIT NOT COOLING IN RM-203. PLANT MGR- MACON/416.2166 | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV-24 RM 209 & UV-21 RM 1150-BOTH NOT COOLING-SBE MACON 416-2148 KLR | 8/12/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | 3-UV NOT COOLING IN RM-101(080) RM-103(082) RM-105(088) PLANT MGR- MACON/416.2148 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV-35 LIBRARY SOUTH-NOT COOLING & LEAKING-SBE MACON 416-2148 KLR | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C IN RM 211-NOT COOLING & A/C IN RM 109-NOT COOLING & LEAKING-SBE MACON 416-2148 KLR | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV RM 103-NOT COOLING-SBE MACON 416-2148 KLR | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV RM 208-NOT COOLING-PLANT MGR MACON 416-2148 KLR | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV RMS 204, 209, 208, & 3-ALL NOT COOLING-PLANT MGR MACON 416-2148 KLR | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C RM 109-NOT COOLING-PLANT MGR MACON 416-2148 KLR | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 3-UV NOT COOLING IN RM-107, LIBRARY, RM-214 PLANT MGR- MACON/416.2148 | 8/28/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | A/C UNIT RM 209-NOT COOLIING-PLANT MGR MACON 416-2148 KLR | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | remove old boiler for spare parts-os | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 7-UV NOT COOLING IN RM-104,106,107,204,202,215,LIBRARY PLANT MGR-DAWSON/416.3940 | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C IN PORT 196-NOT COOLING-SBE MACON 416-2148 KLR | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C RM 215-NOT COOLING-PLANT MGR JEFFERSON KLR | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 3-UV NOT COOLING IN RM-216,204,LIBRARY, TEACHERS' LOUNGE PLANT MGR-MACON/416.2148 | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C ASST PRIN'S OFC-NOT COOLING-PLANT MGR MACON 416-2148 KLR | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Room 109 unit ventilator not cooling per Ms Macon 416-2148 | 9/11/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | UV NOT COOLING IN RM-110 PLANT MGR- LINCOLN/416.2148 | 9/12/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Monthly - Oil Lube & Belt- Richland Elem - Refer to PM schedule details. | 9/13/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | 3-UV NOT COOLING IN RM- 101, GUIDANCE OFFICE, 104. PLANT MGR- MACON/416.2148 | 9/18/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | A/C unit in Room 210 is LEAKING per Ms. Macon, Plant Mgr. 416.4128 | 9/19/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV NOT HEATING IN RM-208 PLANT MGR- MACON/416.2148 | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT PORT 90-NOT HEATING. PLANT MGR MACON 416- 2148 KLR | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UNIT NOT HEATING IN KITCHEN PLANT MGR- MACON/416.2148 | 1/27/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UNIT NOT HEATING IN CAFE PLANT MGR- MACON/416.2148 | 1/28/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | UNIT NOT HEATING IN RM-102. PLANT MGR- MACON/416.2148 | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UNIT NOT HEATING IN RM-202 PLANT MGR- MACON/416.2148 | 2/5/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | UV NOT HEATING IN RM-101,TEACHERS' LOUNGE PLANT MGR- MACON/416.2148 | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT RM 215-NOT HEATING- PLANT MGR MACON 416- 2148 KLR | 2/26/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | HEAT PORT 287-NOT HEATING-PLANT MGR MACON 416-2148 KLR | 3/7/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | WINDOW UNIT NOT COOLING IN PORT-7. PLANT MGR-MACON416.2148 | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Remove portable boiler, remove pumps bring to shop for storage | 3/31/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Richland ES (2600) 2B | UNITS in PORTABLES #7 & #15 are NOT COOLING per Ms. Macon, Plant Mgr. 416.2148 | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Monthly - Oil Lube & Belt-Richland Elem - Refer to PM schedule details. | 4/18/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Monthly - Filter-Richland Elementary - Refer to PM schedule details. | 3/31/14 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Monthly - Filter-Richland Elementary - Refer to PM schedule details. | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Monthly - Filter-Richland Elementary - Refer to PM schedule details. | 12/2/13 | | | Heating/Ventilation /Air Conditioning |
| Richland ES (2600) 2B | Graffiti on storage bin out back Ms. Macon 416-2148 | 7/16/13 | | | Painting |
| Richland ES (2600) 2B | GRAFFITI ON 2-DUMPSTERS PLANT MGR- MACON/416.2148 | 8/28/13 | | | Painting |
| Richland ES (2600) 2B | SINK IS STOPPED UP & CANT SHUT WATER OFF IN B/RR 5TH GRADE WING PLANT MGR- MACON/416.2148 | 9/27/13 | | | Plumbing |

| | | | | | |
|-----------------------|---|----------|------------------|---------------------|----------|
| Richland ES (2600) 2B | sink in teacher's lounge restroom is split, need replacing | 10/3/13 | 1st Floor | teacher's lounge | Plumbing |
| Richland ES (2600) 2B | TOILET IS OVER FLOWING IN G/RR SOUTH-EAST PLANT MGR- MACON/416.2148 | 10/3/13 | | | Plumbing |
| Richland ES (2600) 2B | drain cover in boys restroom (downstairs) has come up/off tripping hazard need replacing | 10/16/13 | Restroom (Boys) | southeast wing | Plumbing |
| Richland ES (2600) 2B | handle on sink in boys restroom stripped, won't turn off water constantly running, need repairing | 10/17/13 | Restroom (Boys) | northeast wing | Plumbing |
| Richland ES (2600) 2B | sink in girls restroom leaks in two places from bottom, has bucket underneath, need repairing | 10/17/13 | Restroom (Girls) | northeast wing | Plumbing |
| Richland ES (2600) 2B | TOILET IS OVERFLOWING IN B/RR SOUTH-EAST WING 2ND FLR PLANT MGR- MACON/416.2148 | 10/18/13 | | | Plumbing |
| Richland ES (2600) 2B | 2-STEAM TABLES & STOVES NEEDS TO BE LIT IN CAFE PLANT MGR- MACON/416.2148 | 10/21/13 | | | Plumbing |
| Richland ES (2600) 2B | grease trap in kitchen has grease coming out of it, need cleaning | 10/28/13 | Kitchen | grease trap by sink | Plumbing |

| | | | | | |
|-----------------------|--|----------|------------------|-----------------------------|----------|
| Richland ES (2600) 2B | girls restroom northeast wing upstairs toilet overflowing per Ms. Macon 416-4128 | 10/31/13 | | | Plumbing |
| Richland ES (2600) 2B | flush valve in girls restroom northeast wing down stairs leaks when flused keeping floor wet, slipping hazard need repairing | 11/7/13 | Restroom (Girls) | northeast wing | Plumbing |
| Richland ES (2600) 2B | sw wing room 212 unit has bad valve and leaking per Ms. Macon 416-2148 | 11/13/13 | | | Plumbing |
| Richland ES (2600) 2B | SINK IS STOPPED UP IN G/RR SOUTHWEST WING. PLANT MGR- MACON/416.2148 | 11/20/13 | | | Plumbing |
| Richland ES (2600) 2B | toilet in second restroom in teacher's lounge leaks from bottom when flushed, needs repairing | 12/2/13 | Restroom (Girls) | teachers lounge | Plumbing |
| Richland ES (2600) 2B | hose bib leaking in girls restroom in northeast wing, need repairing | 12/3/13 | Restroom (Girls) | northeast wing | Plumbing |
| Richland ES (2600) 2B | urinal southwest boys rest room won't/don't flush, need repairing | 12/11/13 | Restroom (Boys) | 1st gr. boys southwest wing | Plumbing |
| Richland ES (2600) 2B | urinal in 4th grd, boys restroom (southwest wing) stopped up, need repairing | 12/11/13 | Restroom (Boys) | 4TH GR. BOYS | Plumbing |

| | | | | | |
|-----------------------|--|----------|---------------------|-----------------------------|----------|
| Richland ES (2600) 2B | Preform back flow test. | 12/23/13 | | | Plumbing |
| Richland ES (2600) 2B | faucet in girls restroom next to rm. 106 (southeast end) won't turn off, need repairing | 7/22/13 | Restroom (Girls) | southeast area | Plumbing |
| Richland ES (2600) 2B | UV IS LEAKING WATER IN RM 101(080). SBE-MACON/416-2148 | 7/22/13 | | | Plumbing |
| Richland ES (2600) 2B | sink in custodial closet (1st. fl. south end) stopped up, plunger don't/ won't help need repairing | 7/25/13 | Custodial Closet | southend, 1st floor | Plumbing |
| Richland ES (2600) 2B | sink in principal's restroom running continuously, need repairing | 7/25/13 | Administration Area | principal's office restroom | Plumbing |
| Richland ES (2600) 2B | PIPE BOILER RM-HAS BURST. PLANT MGR MACON 416-2148 KLR | 1/8/14 | | | Plumbing |
| Richland ES (2600) 2B | URINAL B RR SW WING-OVERFLOWING, CAN'T CONTAIN PER SBE-PLANT MGR MACON 416-2148 KLR | 1/9/14 | | | Plumbing |
| Richland ES (2600) 2B | boys toilet in northwest wing (next to rm. 216) stopped up plunger don't help, need repairing | 8/12/13 | Restroom (Boys) | northwest wing | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------------|----------------|----------|
| Richland ES (2600) 2B | sink in northwest wing (next to rm. 216) stopped up plunger don't help, need repairing | 8/12/13 | Restroom (Boys) | northwest wing | Plumbing |
| Richland ES (2600) 2B | COMMODE KINDERGARTEN WING G RR-CONSTANTLY FLUSHING AND LEAKING WATER OUT, CAN'T CONTAIN OR CUT OFF PER SBE-PLANT MGR MACON 416-2148 KLR | 8/26/13 | | | Plumbing |
| Richland ES (2600) 2B | UV IS LEAKING IN RM-214 PLANT MGR-MACON/416.2148 | 8/27/13 | | | Plumbing |
| Richland ES (2600) 2B | third stall toilet stopped up, plunger won't/don't help need repairing | 8/29/13 | Restroom (Girls) | southeast wing | Plumbing |
| Richland ES (2600) 2B | FCU IS LEAKING WATER IN LIBRARY CARPET PLANT MGR-JEFFERSON/416.2166 | 9/3/13 | | | Plumbing |
| Richland ES (2600) 2B | A/C UNIT LIBRARY-LEAKING-PLANT MGR JEFFERSON KLR | 9/3/13 | | | Plumbing |
| Richland ES (2600) 2B | COMMODE IN THE BOYS RSTRM ON THE WESTWING IS CONSTANTLY RUNNING AND OVERFLOWING. SBE MACON 416-2148 | 7/29/13 | | | Plumbing |
| Richland ES (2600) 2B | Cafeteria sink the hot water is going everywhere and cannot cut off per Ms. Macon 416-2148 | 8/5/13 | | | Plumbing |

| | | | | | |
|-----------------------|--|--------|-----------|--------------------------------|----------|
| Richland ES (2600) 2B | leak coming from light fixture in portable #90, need repairing | 8/5/13 | Portables | portable # 90 | Plumbing |
| Richland ES (2600) 2B | hall sink leaking in front of Asst Principal's office, need repairing | 8/7/13 | 1st Floor | across from Asst. Prin. office | Plumbing |
| Richland ES (2600) 2B | COMMODE 1ST GR WING G RR-1ST STALL CONSTANTLY FLUSING AND LEAKING WATER OUT-CAN'T CONTAIN-SBE MACON 416-2148 KLR | 8/7/13 | | | Plumbing |
| Richland ES (2600) 2B | sink leaking in girls restroom (1st grade wing) need repairing | 8/7/13 | 1st Floor | 1st grade wing | Plumbing |
| Richland ES (2600) 2B | girls restroom in/on 1st grade wing, toilet (second stall) leaks around flush valve when flushed, need repairing | 8/7/13 | 1st Floor | 1st grade wing | Plumbing |
| Richland ES (2600) 2B | middle toilet(southwest wing) by room 110, leaks at flush valve when flushed, need repairing | 8/9/13 | 1st Floor | by room 110 | Plumbing |
| Richland ES (2600) 2B | water fountain in/on southeast wing hallway leaking, need repairing | 8/9/13 | 1st Floor | southeast wing | Plumbing |
| Richland ES (2600) 2B | commode not working | 9/7/13 | 1st Floor | boy's restroom east | Plumbing |

| | | | | | |
|-----------------------|--|---------|------------------|---------------------------|----------|
| Richland ES (2600) 2B | commode not working | 9/7/13 | 1st Floor | lower level boy's | Plumbing |
| Richland ES (2600) 2B | sink in kitchen (by window) leaks when water goes out, need repairing | 9/10/13 | Kitchen | kitchen | Plumbing |
| Richland ES (2600) 2B | toilet seat broken need replacing in girls restroom/on southeast wing next to rm. 102 | 9/12/13 | Restroom (Girls) | next to room 102 | Plumbing |
| Richland ES (2600) 2B | COMMODE B RR 4TH GR WING SW-CONSTANTLY OVERFLOWING, CAN'T CUT OFF OR CONTAIN PER SBE-PLANT MGR MACON 416-2148 KLR | 1/16/14 | | | Plumbing |
| Richland ES (2600) 2B | flush valve on boys urinal in upstairs southwest wing restroom leaks when flushed, need repairing | 2/7/14 | Restroom (Boys) | southwest wing (upstairs) | Plumbing |
| Richland ES (2600) 2B | TOILET IS OVERFLOWING IN MAIN OFFICE PLANT MGR- MACON/416.2166 | 3/18/14 | | | Plumbing |
| Richland ES (2600) 2B | both urinals in southwest boys restroom is stopped up. plunger don't help, need repairing | 3/19/14 | Restroom (Boys) | southwest wing | Plumbing |
| Richland ES (2600) 2B | FLOOR DRAIN B/G RR'S 4TH GR AREA SW WING-WHEN USING SINKS IN RR'S, WATER COMING UP THRU FLOOR DRAIN-PLANT MGR MACON 416-2148 KLR | 3/19/14 | | | Plumbing |

| | | | | | |
|-----------------------|--|---------|---------------------|---------------------------|----------|
| Richland ES (2600) 2B | pipe leaking from ceiling in boys restroom (southwest wing) need repairing | 3/21/14 | Restroom (Boys) | southwest wing downstairs | Plumbing |
| Richland ES (2600) 2B | 4-SINKS ARE OVERFLOWING IN B/RR-G/RR NORTHEAST WING 2ND FLR. PLANT MGR- MACON/416.2148 | 3/28/14 | | | Plumbing |
| Richland ES (2600) 2B | toilet leaks when flushed (2nd toilet) in girls restroom up stairs in northwest wing | 5/13/14 | Restroom (Girls) | northwest wing up stairs | Plumbing |
| Richland ES (2600) 2B | down spout in/on front of building stopped up, floods entry way when it rains, need repairing | 5/16/14 | Grounds | front of building | Plumbing |
| Richland ES (2600) 2B | toilet won't/don't flush in Assistant Principal's office, need repairing | 6/19/14 | Administration Area | asst. principal's office | Plumbing |
| Richland ES (2600) 2B | down spout on front of building (northeast end) stopped up need flushing out, floods front entrance of building when it rains. | 5/1/14 | Grounds | front of school building | Plumbing |
| Richland ES (2600) 2B | FLOOR DRAIN B RR SE WING BACKING WATER WHEN URINALS ARE FLUSHED- PLANT MGR MACON 416-2148 KLR | 4/1/14 | | | Plumbing |
| Richland ES (2600) 2B | Remove pumps and motors. | 4/9/14 | | | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------|-------------------------|-------------|
| Richland ES (2600) 2B | bottom of water valve blocking water flow for ice machine, per repairman's findings, need repairing | 8/9/13 | Cafetorium | kitchen | Plumbing |
| Richland ES (2600) 2B | room 201 has leak in ceiling possibly roof, need repairing | 10/7/13 | 1st Floor | room 201 southeast wing | Roof |
| Richland ES (2600) 2B | portable #90 has three (3) leaks from roof (in different spots), need repairing | 2/5/14 | Portables | portable 90 | Roof |
| Richland ES (2600) 2B | portable #287 has roof leak in several spots, need repairing | 2/5/14 | Portables | portable #287 | Roof |
| Richland ES (2600) 2B | portable #27 has roof leak by front door, need repairing | 2/5/14 | Portables | portable #27 | Roof |
| Richland ES (2600) 2B | portable #15 has two (2) leaks coming from ceiling on left side, need repairing | 4/28/14 | Portables | portable #15 | Roof |
| Richland ES (2600) 2B | down spout on side of portable 4 is loose and banging against building, very annoying and disruptive to class, need repairing/replacing | 1/17/14 | Portables | portable 4 | Sheet Metal |
| Richland ES (2600) 2B | close up opening above door to old boiler room-os (sheet metal) Gary Moore | 4/22/14 | | | Sheet Metal |

| Count of Craft | Craft | | | | | Grand Total |
|------------------------|-----------|------------|------|----------|------|-------------|
| Location | Carpentry | Electrical | HVAC | Plumbing | Roof | Grand Total |
| Riverwood ES (2717) 2A | 25 | 28 | 22 | 23 | 2 | 100 |
| Grand Total | 25 | 28 | 22 | 23 | 2 | 100 |

| Location | Request Description | Submittal Date | Area | Descript | Area Number | Craft |
|------------------------|--|----------------|-----------|----------|-------------|-----------|
| Riverwood ES (2717) 2A | Sound panel has falling off the wall. | 5/20/14 | Cafeteria | | | Carpentry |
| Riverwood ES (2717) 2A | FRONT ENTRANCE DOOR will NOT CLOSE per Ms. Jones, Plant Mgr. 416.9034 | 5/22/14 | | | | Carpentry |
| Riverwood ES (2717) 2A | install caution tape in back of school to warn of deep ditch-os | 6/12/14 | | | | Carpentry |
| Riverwood ES (2717) 2A | There is a need for a petition to be put up in the clinic also on kindergarden hallway,we have the petition here at Riverwood. | 6/23/14 | | | | Carpentry |
| Riverwood ES (2717) 2A | Replace baseboard. | 6/24/14 | 2nd Floor | E-211 | | Carpentry |
| Riverwood ES (2717) 2A | Door closer broken. | 6/24/14 | 2nd Floor | E-214 | | Carpentry |
| Riverwood ES (2717) 2A | There is a need for Fire Extinguisher to be hung in pre -k class room....Per fire inspection. | 9/9/13 | 1st Floor | PRE-K | | Carpentry |

| | | | | | |
|------------------------|--|----------|-----------|----------|-----------|
| Riverwood ES (2717) 2A | There is a need for a cable core for Flag.(Need buckle truck) | 9/19/13 | | outside | Carpentry |
| Riverwood ES (2717) 2A | front door will not open, won't unlock per Ms. Jones 416-9430 | 10/29/13 | | | Carpentry |
| Riverwood ES (2717) 2A | Replace door handle (broken) | 11/5/13 | 1st Floor | Music | Carpentry |
| Riverwood ES (2717) 2A | FRONT DOOR CANT SECURE. PLANT MGR-JONES/416.3781 | 11/13/13 | | | Carpentry |
| Riverwood ES (2717) 2A | ENTRANCE DOOR KINDERGARTEN HALL- HARDWARE DAMAGED, CAN'T OPEN PER SBE-PLANT MGR JONES 416-3781 KLR | 11/15/13 | | | Carpentry |
| Riverwood ES (2717) 2A | Stall door will NOT openand boys restroom. | 11/19/13 | 1st Floor | Restroom | Carpentry |
| Riverwood ES (2717) 2A | front entrance door will not push open per ms. jones 416-9034 | 2/4/14 | | | Carpentry |
| Riverwood ES (2717) 2A | Replcace floor tile. (broken) | 2/18/14 | 2nd Floor | | Carpentry |

| | | | | | |
|------------------------|--|---------|-------------|------------|-----------|
| Riverwood ES (2717) 2A | Repair fence in front of the building. | 3/26/14 | | | Carpentry |
| Riverwood ES (2717) 2A | Shelby County School bus driver knocked down two no parking sign down need to be replaced. | 4/8/14 | Parking Lot | Outside | Carpentry |
| Riverwood ES (2717) 2A | Vents in gym and cafeteria needs cleaning. (need buckle truck) | 4/8/14 | Gym | | Carpentry |
| Riverwood ES (2717) 2A | Gate on East side parking lot latch need replacing gate want stay open. | 4/9/14 | Parking Lot | outside | Carpentry |
| Riverwood ES (2717) 2A | Ceiling tile need replacing.(need a lift) | 4/9/14 | Cafeteria | | Carpentry |
| Riverwood ES (2717) 2A | WINDOW BROKEN OUT IN MAIN HALL. BLDG CANNOT BE SECURED. SBE JONES 416-9460 | 7/1/13 | | | Carpentry |
| Riverwood ES (2717) 2A | There is a need for dry eraser board in these rooms. | 7/22/13 | 1st Floor | C101. E214 | Carpentry |
| Riverwood ES (2717) 2A | Ceiling tile need to be replace in main hallway (water leak) | 8/1/13 | 1st Floor | | Carpentry |

| | | | | | |
|------------------------|---|---------|-----------|---------------|------------|
| Riverwood ES (2717) 2A | Front entrance door will not close and can't secure per Ms. Jones 4162310 | 8/7/13 | | | Carpentry |
| Riverwood ES (2717) 2A | A iron pole sticking out of the ground on East side of the building need to be remove. (HAZARD) | 8/8/13 | | | Carpentry |
| Riverwood ES (2717) 2A | Replace ballast West side of building. | 5/2/14 | 2nd Floor | girl restroom | Electrical |
| Riverwood ES (2717) 2A | Repair lights in the stairwell. | 6/4/14 | | | Electrical |
| Riverwood ES (2717) 2A | Clock on tower time incorrect. | 6/17/14 | | | Electrical |
| Riverwood ES (2717) 2A | Outside canopy on East side of building need ballast. | 8/21/13 | Courtyard | outside | Electrical |
| Riverwood ES (2717) 2A | Breakbox in the Kitchen Area keep tripping the stove off per Priscilla Jones, Plant Mgr. @ 901.416.9034 | 8/27/13 | | | Electrical |
| Riverwood ES (2717) 2A | BREAKER KITCHEN AREA- KEEPS TRIPPING KNOCKING POWER OUT TO AREA-PLANT MGR JONES 416-2067 KLR | 8/28/13 | | | Electrical |

| | | | | | |
|------------------------|---|----------|-------------|-----------------------------|------------|
| Riverwood ES (2717) 2A | RTU NOT COMING ON IN RM-D217 PLANT MGR-JONES/416.3781 | 9/3/13 | | | Electrical |
| Riverwood ES (2717) 2A | Replace lights in front entrance stairway and South entrance stairway .(Need Lifter) | 9/6/13 | 1st Floor | stairway | Electrical |
| Riverwood ES (2717) 2A | A/C RM B108 & B139-BOTH NOT COMING ON-PLANT MGR JONES 416-2067 KLR | 9/6/13 | | | Electrical |
| Riverwood ES (2717) 2A | Simplex performed fire alarm inspections at the following schools and some deficiencies were identified: Riverwood Elem – Audio/Visual failed 2nd flor near D209 This Device needs to be | 9/26/13 | | | Electrical |
| Riverwood ES (2717) 2A | Ballast out | 10/9/13 | 1st Floor | A-109 Kindergarten Restroom | Electrical |
| Riverwood ES (2717) 2A | Clock outside need to be set to daylight saving time. | 10/29/13 | | | Electrical |
| Riverwood ES (2717) 2A | RTU NOT COMING ON IN RM-D217 PLANT MGR-JONES/416.2067 | 12/10/13 | | | Electrical |
| Riverwood ES (2717) 2A | Parking lot lights out, also lights around the building are out.(need buckle truck) | 12/19/13 | Parking Lot | outside | Electrical |

| | | | | | |
|------------------------|---|---------|-----------|---------------|------------|
| Riverwood ES (2717) 2A | HEAT RM E209 & A106-BOTH NOT COMING ON-PLANT MGR JONES 416-2310 KLR | 1/8/14 | | | Electrical |
| Riverwood ES (2717) 2A | HEAT RM A105-NOT COMING ON-PLANT MGR JONES 416-2310 KLR | 1/8/14 | | | Electrical |
| Riverwood ES (2717) 2A | Unit is NOT COMING ON in ROOM A118 per Ms. Jones, Plant Mgr. 416.9034 | 1/27/14 | | | Electrical |
| Riverwood ES (2717) 2A | UNITS NOT COMING ON IN RM-A103,A114 PLANT MGR-JONES/416.2067 | 1/29/14 | | | Electrical |
| Riverwood ES (2717) 2A | HEAT LIBRARY-NOT COMING ON-PLANT MGR 416-9034 KLR | 1/30/14 | | | Electrical |
| Riverwood ES (2717) 2A | Pull station not working at front entrance door. | 2/12/14 | 1st Floor | main entrance | Electrical |
| Riverwood ES (2717) 2A | Fire alarm showing trouble in room.A-104 | 2/20/14 | | | Electrical |
| Riverwood ES (2717) 2A | OVEN KITCHEN AREA-QUIT WORKING-PER SBE, RECEPTACLE TO IT HAS NO POWER-PLANT MGR JONES KLR | 2/21/14 | | | Electrical |

| | | | | | |
|------------------------|--|---------|--|---------|---------------------------------------|
| Riverwood ES (2717) 2A | Clock on tower need setting to day light saving. | 3/7/14 | | outside | Electrical |
| Riverwood ES (2717) 2A | PIV by E Building has fire alarm panel trouble. Please repair. | 3/7/14 | | | Electrical |
| Riverwood ES (2717) 2A | NO POWER IN CAFE & MAIN ENTRY HALL PLANT MGR-JONES/416.2310 | 3/17/14 | | | Electrical |
| Riverwood ES (2717) 2A | Clock on tower time is incorrect. | 3/18/14 | | | Electrical |
| Riverwood ES (2717) 2A | RTU NOT COMING ON IN MAIN OFFICE (NO ID) PLANT MGR-JONES/416-2310 | 7/26/13 | | | Electrical |
| Riverwood ES (2717) 2A | BREAKER BOX KEEPS TRIPPING. PLANT MGR-JONES/416.9034 | 8/1/13 | | | Electrical |
| Riverwood ES (2717) 2A | ROOFTOP UNIT is TOO HOT in ROOM B121 per Ms. Jones, Plant Mgr. 416.9034 | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | A/C RM B121-BLOWING TOO COLD, TEMP IS 58-PLANT MGR JONES 416-9034 KLR | 4/22/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|-----------|--------|---------------------------------------|
| Riverwood ES (2717) 2A | Rm B121 Principal says room is over cooling | 4/29/14 | 1st Floor | rm 121 | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | Per Ms. Jones 416-9034 a/c room A105 is not cooling | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | per Mr. Ervin 416-7360 main office and principal's office unit is blowing cold air | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | main office area is too hot per Mr. Erving 416-7340 | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | RTU IS OVERHEATING IN RM-B144 PLANT MGR-JONES/416.2067 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | HEAT RM B121-NOT HEATING-PLANT MGR JONES 416-2310 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | RTU NOT HEATING IN RM-B134, & RTU IS OVERHEATING IN RM-B144 PLANT MGR-JONES/416.2067 | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | RTU NOT COMING ON IN RM-B134, & UNIT IS OVERHEATING IN RM-B141 PLANT MGR-JONES/416.2067 | 1/28/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Riverwood ES (2717) 2A | per ms jones 416-9034 the library is blowing cold air | 2/5/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | per ms jones 416-9034 in the main office the principal's office unit is blowing cold air and also room B120 blowing cold | 2/13/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | HEAT RM B121-OVERHEATING-THERMOSTAT NOT WORKING, CAN'T TELL WHAT TEMP IS PER SBE-PLANT MGR JONES 416-2067 KLR | 2/18/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | per ms jones 416-9034 room A114 and D215 too hot t'stat reads 86 degrees | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | RTU NOT COOLING IN CAFE (NO ID) PLANT MGR-JONES/416-2310 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | 9-RTU NOT COOLING IN RM-A104,A105,B121,A111,A118,A123,A124,A125,MAIN OFFICE. PLANT MGR-JONES/416.9034 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|------------------------|--|----------|-----------|---------------------|--|---------------------------------------|
| Riverwood ES (2717) 2A | A/C IN B121-NOT COOLING-SBE JONES KLR | 8/15/13 | | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | Monthly - Filters - Riverwood Elementary - Refer to PM schedule details. | 8/16/13 | | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | Monthly - Filters - Riverwood Elementary - Refer to PM schedule details. | 4/18/14 | | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | Monthly - Filters - Riverwood Elementary - Refer to PM schedule details. | 12/13/13 | | | | Heating/Ventilation /Air Conditioning |
| Riverwood ES (2717) 2A | Search property for drainage problems, neighbor complaint | 5/5/14 | | | | Plumbing |
| Riverwood ES (2717) 2A | A/C leaking in cafeteria and gym. | 5/9/14 | Gym | | | Plumbing |
| Riverwood ES (2717) 2A | Water constanly dripping,est side of the building,. | 5/12/14 | 1st Floor | restroom | | Plumbing |
| Riverwood ES (2717) 2A | Sink in room a125 stopped up also sink in teacher lounge on first floor. | 6/24/14 | 1st Floor | A125-Teacher lounge | | Plumbing |

| | | | | | |
|------------------------|---|----------|-----------|-----------|----------|
| Riverwood ES (2717) 2A | water constanly running upstairs on both boys restrooms East and West. | 9/25/13 | 2nd Floor | restrooms | Plumbing |
| Riverwood ES (2717) 2A | Water leaking from faucet in Teacher Lounge. | 10/9/13 | 1st Floor | | Plumbing |
| Riverwood ES (2717) 2A | PER SBE PIPE LEAKING IN CEILING OF CAFE-PLANT MGR JONES KLR | 10/31/13 | | | Plumbing |
| Riverwood ES (2717) 2A | room 217 and 218 unit leaking per ervin 416-7340 | 10/31/13 | | | Plumbing |
| Riverwood ES (2717) 2A | Water fountatn not working. | 11/20/13 | 1st Floor | A-108 | Plumbing |
| Riverwood ES (2717) 2A | Boys urinal keep over flowing when you flush. | 11/25/13 | 1st Floor | BOYS | Plumbing |
| Riverwood ES (2717) 2A | SINK 3RD GR HALL WEST END-COVER HAS BEEN TAKEN OFF CAUSING WATER TO LEAK OUT PER SBE-PLANT MGR JONES 416-2310 KLR | 11/25/13 | | | Plumbing |
| Riverwood ES (2717) 2A | Water fountain not working in classroom. | 12/2/13 | 1st Floor | A-110 | Plumbing |

| | | | | | |
|------------------------|--|----------|------------------|-----------------|----------|
| Riverwood ES (2717) 2A | Flush valve broken and girls restroom. | 12/19/13 | Restroom (Girls) | 2nd floor | Plumbing |
| Riverwood ES (2717) 2A | Preform back flow test. | 12/23/13 | | | Plumbing |
| Riverwood ES (2717) 2A | Toilet seat broken in second stall. | 1/9/14 | Restroom (Girls) | 1 grade hallway | Plumbing |
| Riverwood ES (2717) 2A | Girl restroom second stall is constanly running. | 2/18/14 | | | Plumbing |
| Riverwood ES (2717) 2A | Toilet in teacher lounge stopped up. | 2/26/14 | 2nd Floor | Teacher Lounge | Plumbing |
| Riverwood ES (2717) 2A | Water constanly dripping from back of commode. | 3/19/14 | Restroom (Girls) | | Plumbing |
| Riverwood ES (2717) 2A | 3-COM SINK IS LEAKING WATER IN KITCHEN. PLANT MGR-JONES/416.2310 | 3/19/14 | | | Plumbing |
| Riverwood ES (2717) 2A | Video storm Sewer | 3/25/14 | | | Plumbing |

| | | | | | |
|------------------------|---|---------|--------------------|-------------------------------|----------|
| Riverwood ES (2717) 2A | water leaking from stall. | 4/3/14 | Restroom (Boys) | B hallway | Plumbing |
| Riverwood ES (2717) 2A | Boys restroom second urinal water constanly running. | 4/12/14 | Restroom (Boys) | B- hallway | Plumbing |
| Riverwood ES (2717) 2A | UNIT IN THE MAIN HALL IS LEAKING.SBE JONES 416-2310 | 7/29/13 | | | Plumbing |
| Riverwood ES (2717) 2A | Main - Entrance roof leaking. | 3/18/14 | 1st Floor | main - entrance ceiling | Roof |
| Riverwood ES (2717) 2A | Roof leaking | 4/9/14 | Cafetorium | | Roof |

| Count of Craft | Craft | | | | | | | |
|---------------------|----------|---------|-----------|------------|------|----------|------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Plumbing | Roof | Grand Total |
| ea Isle ES (2637) 2 | 4 | 3 | 35 | 37 | 39 | 21 | 2 | 141 |
| Grand Total | 4 | 3 | 35 | 37 | 39 | 21 | 2 | 141 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|-----------------------|--|---------------|------------------|----------------------|-----------|
| Sea Isle ES (2637) 2B | Need to have this room checked for possible mold on the walls. | 8/12/13 | 1st Floor | 164/ speech | Asbestos |
| Sea Isle ES (2637) 2B | There are three cracked 9in tiles in this area. | 11/15/13 | 2nd Floor | In front of elevator | Asbestos |
| Sea Isle ES (2637) 2B | Need to have the wall looked at on the Southwest end of the Library for possible mold. | 8/21/13 | Library | 122 | Asbestos |
| Sea Isle ES (2637) 2B | There are three broken 9in tiles in front of room 226(copy room) that needs to be replaced. | 8/22/13 | 2nd Floor | HALL/ 226 | Asbestos |
| Sea Isle ES (2637) 2B | Request for this room to be wired for computers. This room is being converted to a computer lab. | 6/4/14 | 2nd Floor | NCLB/232 | Cabbling |
| Sea Isle ES (2637) 2B | The Internet will not work in these two rooms. | 9/16/13 | 2nd Floor | 205,207 | Cabbling |
| Sea Isle ES (2637) 2B | Request for the laminator to be repaired. Will not power up.. Ultima 65 #295171 | 10/2/13 | Library | Work room | Cabbling |
| Sea Isle ES (2637) 2B | ENTRANCE DOOR SOUTHEAST SIDE FOR CAR RIDERS- LATCH NOT CATCHING. WON'T BE ABLE TO SECURE- PLANT MGR HARDMAN 416-2140 KLR | 4/28/14 | | | Carpentry |
| Sea Isle ES (2637) 2B | Request for a diaper changing shelf to be mounted in this classroom. shelf is in room. | 5/1/14 | 1st Floor | 183 | Carpentry |

| | | | | | |
|-----------------------|---|---------|-----------------|-------------------------|-----------|
| Sea Isle ES (2637) 2B | The door knob will not work and random on the inside of this room. Needs to be replaced. | 11/8/13 | 2nd Floor | 220 | Carpentry |
| Sea Isle ES (2637) 2B | The metal non skid plate attached to the 5th step in this stairwell is becoming loose off the concrete. | 2/4/14 | 1st Floor | West end stairwell | Carpentry |
| Sea Isle ES (2637) 2B | Need this window corked around the edge. It has shifted creating a draft. | 2/12/14 | 2nd Floor | 248 | Carpentry |
| Sea Isle ES (2637) 2B | per hardman 416-2104 room 220 the door knob keeps falling off and locking people in room | 3/6/14 | | | Carpentry |
| Sea Isle ES (2637) 2B | Request for a do not enter sign to be installed at the main entry to the admin parking. This is will be the parking area on Sea Isle. | 3/25/14 | Parking Lot | Main entry parking area | Carpentry |
| Sea Isle ES (2637) 2B | There is a piece of tile that needs to be replaced just outside the boys restroom. It's a half piece that acts as a walk off tile leaving the restroom. | 3/28/14 | Restroom (Boys) | 112 | Carpentry |
| Sea Isle ES (2637) 2B | The door to the this stall needs to be reattached. See Plant manager for door. | 4/8/14 | Restroom (Boys) | Next to sbe office | Carpentry |
| Sea Isle ES (2637) 2B | This room needs a new door closure. It is bent. | 4/17/14 | 1st Floor | 163 | Carpentry |
| Sea Isle ES (2637) 2B | DOOR - ENTRY - HANDLE AND LOCK BROKEN OFF - CAN'T SECURE- PM/HARDMAN 416-2104 | 4/21/14 | | | Carpentry |
| Sea Isle ES (2637) 2B | The door to the stall needs to be reattached. Plant manager has the door. | 4/22/14 | Restroom (Boys) | 108/ next to sbe office | Carpentry |

| | | | | | |
|-----------------------|--|---------|-----------|-------------------------|-----------|
| Sea Isle ES (2637) 2B | Door will not secure. Latch will become stuck when you turn the handle for entry or exit. | 4/23/14 | 2nd Floor | 220 | Carpentry |
| Sea Isle ES (2637) 2B | The stall door needs to be reattached in this area. It is falling off. | 9/9/13 | 2nd Floor | Girls restroom/236 | Carpentry |
| Sea Isle ES (2637) 2B | Need a new door knob installed. Door will open randomly. | 9/11/13 | 2nd Floor | 215 | Carpentry |
| Sea Isle ES (2637) 2B | Need a new door knob installed to this room. Old one is stripped. | 9/11/13 | 2nd Floor | 220 | Carpentry |
| Sea Isle ES (2637) 2B | Request for tack strips to be installed. Plant Manager has tack strips. | 9/24/13 | 1st Floor | Main hall | Carpentry |
| Sea Isle ES (2637) 2B | The handrail is loose in this stairwell. | 9/26/13 | 1st Floor | Stairwell/ 143 | Carpentry |
| Sea Isle ES (2637) 2B | Need to have door adjusted. Its sticking when opened or closed. | 8/15/13 | 2nd Floor | 247 | Carpentry |
| Sea Isle ES (2637) 2B | The latch on the panic bar needs a new spring. When outside door on right side is opened. It will not secure on its own. | 8/21/13 | 1st Floor | Stairwell/nxt to rm 163 | Carpentry |
| Sea Isle ES (2637) 2B | Need tack strips installed for the art rooms. See plant manager for locations. | 8/2/13 | 1st Floor | See sbe | Carpentry |
| Sea Isle ES (2637) 2B | Request for the door knob and lock to be installed on the door. Last one was removed by maintenance. | 8/6/13 | 2nd Floor | 243 | Carpentry |

| | | | | | |
|-----------------------|--|----------|---------------------|------------------------|-----------|
| Sea Isle ES (2637) 2B | This door will not close when opened. Needs to be adjusted. | 8/9/13 | Cafeteria | Back door/ eating area | Carpentry |
| Sea Isle ES (2637) 2B | The door knob needs to be replaced to this room. Its broken on this inside of the room. | 10/7/13 | 2nd Floor | 204 | Carpentry |
| Sea Isle ES (2637) 2B | Need the door knob fixed to this room.The door will lock you inside randomly. | 10/24/13 | 2nd Floor | 220 | Carpentry |
| Sea Isle ES (2637) 2B | The door closure will pop off randomly when door is opened. | 10/31/13 | Cafeteria | Door/ Northeast exit | Carpentry |
| Sea Isle ES (2637) 2B | stairwell outside door next to room 163 panic bar broken and can't secure per Mr. Hardman 416-2104 | 12/4/13 | | | Carpentry |
| Sea Isle ES (2637) 2B | Request for a block to be Installed for a pencil sharpner. | 12/9/13 | 2nd Floor | 215 | Carpentry |
| Sea Isle ES (2637) 2B | Request a new door knob for this room. Current knob is falling off when used. | 12/17/13 | 2nd Floor | 204 | Carpentry |
| Sea Isle ES (2637) 2B | BACK ENTRY DOOR CANT SECURE, DOOR CLOSER HAS BROKE. PLANT MGR-HARDMAN/416.2104 | 12/19/13 | | | Carpentry |
| Sea Isle ES (2637) 2B | The window to the classroom needs a new seal on It to the left. The glass has shifted. | 1/17/14 | 2nd Floor | 209 | Carpentry |
| Sea Isle ES (2637) 2B | The door knob to this room is broken on the outside. Needs to be repaired. | 1/21/14 | Administration Area | Teacher lounge | Carpentry |

| | | | | | |
|-----------------------|---|----------|---------------------|----------------------|------------|
| Sea Isle ES (2637) 2B | The door knob to this room needs to be repaired. The knob will turn randomly and will not allow entry. | 1/23/14 | 2nd Floor | 220 | Carpentry |
| Sea Isle ES (2637) 2B | EXIT CAFE DOOR, CANT SECURE PLANT MGR-HARDMAN/416.2104 | 1/27/14 | | | Carpentry |
| Sea Isle ES (2637) 2B | The door knob to this room will fall off randomly. Will not stay tightened. | 2/18/14 | 2nd Floor | 220 | Carpentry |
| Sea Isle ES (2637) 2B | Request for the wall clocks In these areas to be set to the correct time. (SCS Network Cabling and Electronics dept.--Response – Please have electrician to service this request first, let us know if our help is needed to assist. Leslie Ratliff 301-2661 | 5/28/14 | Hallway/Corridor | 1st floor walls | Electrical |
| Sea Isle ES (2637) 2B | Followup to check electrical equipement, there was a power outage over the weekend. | 4/1/14 | | | Electrical |
| Sea Isle ES (2637) 2B | Request for the school clock to be fixed. It Is just blinking. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") defer to Electrician | 4/1/14 | Administration Area | Main office | Electrical |
| Sea Isle ES (2637) 2B | Request for a light ballast to be changed in this room. | 5/1/14 | 1st Floor | 174 | Electrical |
| Sea Isle ES (2637) 2B | The breaker keeps flipping when the school copier is used In this room. | 5/1/14 | 2nd Floor | 226 | Electrical |
| Sea Isle ES (2637) 2B | UV NOT COMING ON IN RM-240 PLANT MGR-WHARWOOD/416.2104 | 11/26/13 | | | Electrical |
| Sea Isle ES (2637) 2B | Request for the light ballast to be changed. Plant manager has the bulbs. | 11/15/13 | 1st Floor | Notrtheast stairwell | Electrical |

| | | | | | |
|-----------------------|--|----------|---------------------|----------------------------|------------|
| Sea Isle ES (2637) 2B | HEAT RM 240-MOTOR HAS LOCKED UP PER SBE-PLANT MGR HARDMAN 416-2130 KLR | 11/21/13 | | | Electrical |
| Sea Isle ES (2637) 2B | Need two light ballast changed In this area. | 2/5/14 | Cafeteria | Prep area/ Kitchen | Electrical |
| Sea Isle ES (2637) 2B | The light ballast is very loose from the ceiling due to water damage. It needs to be remounted. | 2/5/14 | Restroom (Boys) | 230 | Electrical |
| Sea Isle ES (2637) 2B | The light ballast needs to be changed In this area. Bulbs will just blink. | 2/5/14 | Stairway | Northeast stairwell 1st Fl | Electrical |
| Sea Isle ES (2637) 2B | Set Master clock of DLS time. | 3/10/14 | Administration Area | | Electrical |
| Sea Isle ES (2637) 2B | Request for the electrical outlet to be checked or changed behind the vending machine. It will not work and the breaker is on. | 3/24/14 | 1st Floor | Teachers lounge | Electrical |
| Sea Isle ES (2637) 2B | Need the light ballast changed In this area. | 3/28/14 | 1st Floor | Outside cafeteria | Electrical |
| Sea Isle ES (2637) 2B | Request for a light ballast to be changed In this room. | 3/31/14 | 1st Floor | 175 | Electrical |
| Sea Isle ES (2637) 2B | There are two light ballast that stopped working In this room. | 4/22/14 | 1st Floor | 169 | Electrical |
| Sea Isle ES (2637) 2B | Request a box of lamps for lighting to be changed. (F32T8/ADV841/EW) | 4/23/14 | Administration Area | Throughout building | Electrical |

| | | | | | |
|-----------------------|--|---------|---------------------|--------------------------|------------|
| Sea Isle ES (2637) 2B | Request for the exterior light bulbs to be changed around the building. | 9/6/13 | Grounds | parking lot/ front entry | Electrical |
| Sea Isle ES (2637) 2B | Sea Isle--WO382670 - The school bells will not ring. Needs to be re programmed. (NEW REQUEST) NEED TO BE DEFFERED TO zone COORDINATOR | 9/11/13 | Administration Area | Main office | Electrical |
| Sea Isle ES (2637) 2B | The electrical clock In the kitchen area needs to be set to correct time. | 9/11/13 | Cafeteria | Prep area | Electrical |
| Sea Isle ES (2637) 2B | A/C RM 240-NOT COMING ON-PLANT MGR HARDMAN 416-2104 KLR | 9/13/13 | | | Electrical |
| Sea Isle ES (2637) 2B | Request a box of bulbs for lighting to be changed. (F32T8/ADV841/EW) | 10/1/13 | 2nd Floor | Hallway/ classrooms | Electrical |
| Sea Isle ES (2637) 2B | AHU NOT COMING ON IN CAFE(113) PLANT MGR-WHARWOOD/416.2104 | 8/21/13 | | | Electrical |
| Sea Isle ES (2637) 2B | need clock in main office reset after a power serge | 7/2/13 | Administration Area | | Electrical |
| Sea Isle ES (2637) 2B | Request for exterior lighting bulbs to be changed. See plant manager for locations. | 8/6/13 | Grounds | School campus | Electrical |
| Sea Isle ES (2637) 2B | Request for a light ballast to be changed In this area. | 8/7/13 | 1st Floor | Northeast hall | Electrical |
| Sea Isle ES (2637) 2B | Unit Ventilator, ID#053-022 in Rm 202 making noise per Mr. Craig Hardman, Plant Mgr. 901.416.6175 | 8/7/13 | | | Electrical |

| | | | | | |
|-----------------------|--|----------|---------------------|--------------------|------------|
| Sea Isle ES (2637) 2B | The light ballast needs to be changed in front of this room. Bulbs have been changed | 8/9/13 | Hallway/Corridor | In front of 223 | Electrical |
| Sea Isle ES (2637) 2B | UNIT IS MAKING NOISE IN RM-175 PLANT MGR-HARDMAN/416.2104 | 10/3/13 | | | Electrical |
| Sea Isle ES (2637) 2B | The wall outlet for the micropohone has a short In it. | 10/3/13 | Cafeteria | Front of stage | Electrical |
| Sea Isle ES (2637) 2B | Need a light ballast changed In this area. | 10/24/13 | Elevator | Inside elevator | Electrical |
| Sea Isle ES (2637) 2B | Request for a light ballast to be changed. | 10/25/13 | 2nd Floor | 220 | Electrical |
| Sea Isle ES (2637) 2B | Request for three light ballast to be changed. See plant manager for locations. | 1/14/14 | 2nd Floor | main hall | Electrical |
| Sea Isle ES (2637) 2B | Request for the light ballast to be changed in this area. There are new lamps In fixure. | 1/23/14 | Cafeteria | Above Serving line | Electrical |
| Sea Isle ES (2637) 2B | Need bulbs In the ceiling changed In this area. (F32T8/ADV841/EW) | 8/7/13 | Cafeteria | Eating area | Electrical |
| Sea Isle ES (2637) 2B | The school bells will not ring. | 10/3/13 | Administration Area | Main office | Electrical |
| Sea Isle ES (2637) 2B | A/C UNIT 2ND FLR RM 220-HAS NO POWER TO IT PER SBE SBE HARDMAN 416-6175 KLR | 8/8/13 | | | Electrical |

| | | | | | |
|-----------------------|---|----------|--|--|---------------------------------------|
| Sea Isle ES (2637) 2B | Monthly - Filter-Sea Isle Elementary - Refer to PM schedule details. | 9/2/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | UNIT NOT COMING ON IN RM-141. PLANT MGR-WHARWOOD/416.8980 Running not heating Rm is accully 241.jd | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 5/30/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | A/C RM 245-LEAKING & IT'S GOING DOWN INTO THE RM BELOW-PLANT MGR HARDMAN 416-2104 KLR | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | WALL UNIT NOT HEATING IN NURSE RM-166 PLANT MGR-WHARWOOD/416.2104 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | UV RM 209 & 213-BOTH NOT HEATING-PLANT MGR HARDMAN 416-2130 KLR | 2/5/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | UNIT NOT HEATING IN RM-209,213. PLANT MGR-HARDMAN/416.2104 | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | FCU LIBRARY OFC-NOT HEATING-PLANT MGR HARDMAN 416-2130 KLR | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | repair boiler | 2/12/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|--|--|---------------------------------------|
| Sea Isle ES (2637) 2B | Monthly - Oil Lube & Belt-Sea Isle Elementary - Refer to PM schedule details. | 3/25/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | UNIT NOT COOLING IN RM-219(038). PLANT MGR-HARDMAN/416.2104 | 9/4/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | A/C RM 219-NOT COOLING-PLANT MGR HARDMAN 416-2136 KLR | 10/3/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Rm 236, 220, 202 not cooling per Mr. Hardman 416-2136 is 053007, 053104, 053022 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - Oil Lube & Belt-Sea Isle Elementary - Refer to PM schedule details. | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | AHU RM 164-NOT COOLING & FCU RM 219-NOT COOLING-SBE HARDMAN 416-2104 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Per Mr. Hardman Room 242 ID#053003 a/c is blowing hot air | 8/27/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | 8-A/c NOT COOLING IN RM-102, 204,215,220,221,239,240,243. FILL IN SBE-OLLIE/315-1387 | 7/19/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | 2-AHU NOT COOLING IN RM-175(047, 048), RM-241 (018) PLANT MGR-BROWN/416.2104 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | A/C UNIT 1ST FLR RM 163, 1ST FLR RM 169, 2ND FLR RM 202, & 1ST FLR RM 122 WEST-ALL NOT COOLING-SBE HARDMAN 416-2104 KLR | 8/6/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|--|--|---------------------------------------|
| Sea Isle ES (2637) 2B | BOILER NOT COMING ON. PLANT MGR-HARDMAN/416.2104 | 10/24/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | 2-UNITS NOT HEATING IN RM-243,123 PLANT MGR-WHARWOOD/416.2104 | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | BOILER NOT COMING ON PLANT MGR-WHARWOOD/652.4926 | 12/20/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | HEAT RM 175B, 112A, & 154 B-ALL NOT HEATING-PLANT MGR HARDMAN 416-2104 KLR | 1/14/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | UNIT NOT HEATING IN RM-209. PLANT MGR-HARDMAN/416.2104 | 1/21/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | A/C UNIT 2ND FLR RM 202-NOT COOLING-SBE HARDMAN 416-6175 KLR | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 11/29/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - Filter-Sea Isle Elementary - Refer to PM schedule details. | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Yearly - Boiler - Sea Isle Elem - Refer to PM schedule details. | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|----------|--|--|---------------------------------------|
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 10/4/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 11/1/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - Filter-Sea Isle Elementary - Refer to PM schedule details. | 12/30/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 1/3/14 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | Monthly - 1' Filters (Monthly)- Sea Isle Elem - Refer to PM schedule details. | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Sea Isle ES (2637) 2B | UNIT IS LEAKING WATER FROM IDF RM 2ND FLR plant mgr-HARDMAN/416.8980 | 6/19/14 | | | Plumbing |

| | | | | | |
|-----------------------|--|----------|------------------|---------------------------|----------|
| Sea Isle ES (2637) 2B | The sink will not drain in this closet. | 2/27/14 | Custodial Closet | Next to rm 109 | Plumbing |
| Sea Isle ES (2637) 2B | The sink is leaking from below at the elbow. | 11/15/13 | Cafeteria | Prep area | Plumbing |
| Sea Isle ES (2637) 2B | COMMODOE KINDERGARTEN RM 181-KEEPS LEAKING FROM NECK-PLANT MGR HARDMAN 416-2130 KLR | 2/10/14 | | | Plumbing |
| Sea Isle ES (2637) 2B | The spray hose for the dishwasher will leak from the wall when used. | 3/19/14 | Cafeteria | dish washing station | Plumbing |
| Sea Isle ES (2637) 2B | The last commode to the right will not flush. | 3/28/14 | Restroom (Girls) | across from rm.123 | Plumbing |
| Sea Isle ES (2637) 2B | The pipe is leaking from two areas under the triple sink. The stopper will not work as well. | 3/28/14 | Cafeteria | prep area | Plumbing |
| Sea Isle ES (2637) 2B | The water will come from both faucets when you turn one side on. | 3/28/14 | Cafeteria | Steam kettle water faucet | Plumbing |
| Sea Isle ES (2637) 2B | The second stall from the left will not flush. Have to hold down for toilet to complete cycle. | 9/9/13 | Restroom (Boys) | 2nd fl/ 236 | Plumbing |
| Sea Isle ES (2637) 2B | The second commode from the left will not flush. Have to keep pushing to complete cycle. | 9/9/13 | Restroom (Girls) | 2nd floor/220 | Plumbing |
| Sea Isle ES (2637) 2B | The water fountain to the right across from this room will clog and drain very slow when used. | 9/10/13 | 2nd Floor | 234 | Plumbing |

| | | | | | |
|-----------------------|---|----------|------------------|-----------------------|----------|
| Sea Isle ES (2637) 2B | The sink is leaking from underneath . Its the middle sink in this restroom. | 9/24/13 | Restroom (Girls) | Main hall | Plumbing |
| Sea Isle ES (2637) 2B | The A/c leaks when turned on. | 10/3/13 | Classroom | 112 | Plumbing |
| Sea Isle ES (2637) 2B | UV IS LEAKING IN RM/245(015). PLANT MGR-HARDMAN/416.2104 | 8/16/13 | | | Plumbing |
| Sea Isle ES (2637) 2B | There is water leaking from the ceiling in this room. | 8/28/13 | 1st Floor | 183 | Plumbing |
| Sea Isle ES (2637) 2B | AHU IS LEAKING WATER IN RM-242(003). SBE-BROWN/416-2104 | 7/1/13 | | | Plumbing |
| Sea Isle ES (2637) 2B | Request for a new toilet seat for the bathroom in this room. | 10/15/13 | Classroom | Rm 183/ Special needs | Plumbing |
| Sea Isle ES (2637) 2B | The second commode from the right needs to have the toilet seat replaced. | 1/8/14 | Restroom (Boys) | Next to rm 110 | Plumbing |
| Sea Isle ES (2637) 2B | The toilet will leak when flushed from the neck in this room. | 1/9/14 | 1st Floor | k-1 / 181 | Plumbing |
| Sea Isle ES (2637) 2B | UNIT IS LEAKING WATER IN RM-166 PLANT MGR-HARDMAN/416.2104 | 1/30/14 | | | Plumbing |
| Sea Isle ES (2637) 2B | The toilet sprays water from the neck when its flushed in this room. | 1/30/14 | 1st Floor | rm 181 | Plumbing |

| | | | | | |
|-----------------------|---|--------|-----------------|-----|------|
| Sea Isle ES (2637) 2B | This roof is leaking above the emergency window exit. | 6/9/14 | 2nd Floor | 205 | Roof |
| Sea Isle ES (2637) 2B | The roof hatch will leak water down the walls and throughout this bathroom when it rains. | 2/5/14 | Restroom (Boys) | 230 | Roof |

| Count of Craft | Craft | | | | | | |
|--------------------------|---------|-----------|------------|------|----------|------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Plumbing | Roof | Grand Total |
| Shady Grove ES (2640) 2A | 1 | 12 | 31 | 24 | 18 | 4 | 90 |
| Grand Total | 1 | 12 | 31 | 24 | 18 | 4 | 90 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|--------------------------|--|---------------|---------------------|----------------------------|-----------|
| Shady Grove ES (2640) 2A | rooms 103,106, and 119 network ports not working need repairing | 9/11/13 | 1st Floor | rooms 103,106,and 119 | Cabling |
| Shady Grove ES (2640) 2A | MAIN ENTRANCE DOOR WILL NOT CLOSE. SBE MACON 416-1456 | 7/2/13 | | | Carpentry |
| Shady Grove ES (2640) 2A | principal requests five (5) bulletin boards to be put up in hallways in different areas of the building. | 7/12/13 | Hallway/Corridor | hallways throughout school | Carpentry |
| Shady Grove ES (2640) 2A | financial secretary's desk drawer has come off, can't lock it, need repairing | 4/25/14 | Administration Area | main office | Carpentry |
| Shady Grove ES (2640) 2A | floor tile by front door in portable #136 is crumbling and coming loose, tripping hazard, need replacing | 4/7/14 | Portables | portable #136 | Carpentry |
| Shady Grove ES (2640) 2A | portable door has to be pulled/pushed to close up, need repairing | 12/9/13 | Portables | portable 165 | Carpentry |
| Shady Grove ES (2640) 2A | heater unit has come loose on left side (room 104) can't pull it together to put screw in it has fallen completely off, need repairing | 1/31/14 | Classroom | room 104 | Carpentry |

| | | | | | | |
|--------------------------|--|---------|-----------|---------------|--|------------|
| Shady Grove ES (2640) 2A | FRONT DOOR will NOT CLOSE COMPLETELY (CANNOT BE SECURED) per Ms. Macon, Plant Mgr. 416.1456 | 2/11/14 | | | | Carpentry |
| Shady Grove ES (2640) 2A | back porch steps to/on portable 165 has nails sticking out from it, teacher stepped on one, need repairing | 2/21/14 | Portables | portable #165 | | Carpentry |
| Shady Grove ES (2640) 2A | steps that goes to landing (on playground) is rotted out/rusted, children play under it, can get fingers caught, need repairing | 2/21/14 | Grounds | play area | | Carpentry |
| Shady Grove ES (2640) 2A | door has large gap/opening at bottom, insects/pests entrance need repairing | 8/30/13 | Portables | portable #2 | | Carpentry |
| Shady Grove ES (2640) 2A | WOOD PLANKS ARE SINKING IN FRONT ENTRY PORT-136. PLANT MGR- MACON/416.2166 | 11/4/13 | | | | Carpentry |
| Shady Grove ES (2640) 2A | classroom door to room 105 gets stuck when trying to open it. door seems to be swollen making it hard to open, safety hazard, need repairing | 11/6/13 | Classroom | rm. 105 | | Carpentry |
| Shady Grove ES (2640) 2A | row of lights flickering in hallway next to boiler room, changed bulbs no help, ballast going/gone out, need replacing | 6/2/14 | 1st Floor | hallway | | Electrical |
| Shady Grove ES (2640) 2A | 5-RECEPTACLES HAVE NO POWER IN RM-108 PLANT MGR- MACON/416.2166 | 5/2/14 | | | | Electrical |

| | | | | | |
|--------------------------|---|----------|---------------------|----------------------|------------|
| Shady Grove ES (2640) 2A | ballast out in Facilitator's Office, changed bulbs, need replacing | 5/20/14 | Administration Area | Facilitator's Office | Electrical |
| Shady Grove ES (2640) 2A | clock in office need resetting per daylight saving time | 3/21/14 | Administration Area | office | Electrical |
| Shady Grove ES (2640) 2A | ballast gone out in classroom#5 whole row of lights out, need replacing | 4/1/14 | Classroom | room #5 | Electrical |
| Shady Grove ES (2640) 2A | lights out in front of room, changed bulbs bad ballast need repairing | 12/5/13 | 1st Floor | rm. 117 | Electrical |
| Shady Grove ES (2640) 2A | ballast out in guidance counselor's office, changed bulbs, ballast need replacing | 12/13/13 | Administration Area | guidance office | Electrical |
| Shady Grove ES (2640) 2A | middle row of lights out in room 112, ballast need changing | 1/9/14 | Classroom | room 112 | Electrical |
| Shady Grove ES (2640) 2A | classroom 105 has middle row of lights out, ballast out, need replacing | 1/14/14 | Classroom | room 105 | Electrical |
| Shady Grove ES (2640) 2A | RECEPTACLE IS SHOOTING OUT FIRE FOR FREEZER IN KITCHEN(076). PLANT MGR-MACON/416.2166 | 7/29/13 | | | Electrical |

| | | | | | |
|--------------------------|--|---------|---------------------|---------------------|------------|
| Shady Grove ES (2640) 2A | room #5 has broken/ burned out socket on east side of wall, need repairing | 7/31/13 | 1st Floor | room 5(Mrs. Norman) | Electrical |
| Shady Grove ES (2640) 2A | RECEPTACLE HAS NO POWER TO REFRIGERATOR IN KITCHEN . PLANT MGR- MACON/416.2148 | 8/5/13 | | | Electrical |
| Shady Grove ES (2640) 2A | BALLAST IN THE MAIN HALL AND IT DARK. SBE MACON 416-1456 | 8/5/13 | | | Electrical |
| Shady Grove ES (2640) 2A | master clock needs programing for new start time: | 8/6/13 | Administration Area | main office | Electrical |
| Shady Grove ES (2640) 2A | one whole row of lights are out in room 105 (ballast) need repairing | 8/7/13 | 1st Floor | room 105 | Electrical |
| Shady Grove ES (2640) 2A | RECEPTACLE HAS A BURNING SMELL IN CAFE. PLANT MGR- MACON/416.2166 | 8/9/13 | | | Electrical |
| Shady Grove ES (2640) 2A | portable #136 has burned out ballast, need replacing | 8/15/13 | Portables | portable 136 | Electrical |
| Shady Grove ES (2640) 2A | ballast out in hallway by room 105 three (3) sets of lights out need replacing | 8/28/13 | 1st Floor | hallway by rm.105 | Electrical |

| | | | | | |
|--------------------------|---|---------|---------------------|---------------|------------|
| Shady Grove ES (2640) 2A | ballast out replaced bulbs still no lights, need repairing | 8/30/13 | Portables | portable #2 | Electrical |
| Shady Grove ES (2640) 2A | main office has ballast out by counter, replaced bulbs need repairing | 9/10/13 | Administration Area | main office | Electrical |
| Shady Grove ES (2640) 2A | twelve (12) light fixtures in portable 136 are missing need replacing per principal's request | 9/12/13 | Portables | portable #136 | Electrical |
| Shady Grove ES (2640) 2A | requesting T8 light bulbs for use throughout school building | 9/16/13 | Administration Area | main office | Electrical |
| Shady Grove ES (2640) 2A | cafeteria manager requesting receptacle for ice cream box to be installed | 9/17/13 | Cafeteria | serving area | Electrical |
| Shady Grove ES (2640) 2A | cable from flagpole has come down need replacing | 9/19/13 | Grounds | flagpole | Electrical |
| Shady Grove ES (2640) 2A | ballast out in room 112 whole row of lights out need repairing | 9/20/13 | Classroom | room 112 | Electrical |
| Shady Grove ES (2640) 2A | ballast out in room 113 whole row of lights out need repairing | 9/20/13 | Classroom | room 113 | Electrical |

| | | | | | |
|--------------------------|---|----------|-----------|------------------------|---------------------------------------|
| Shady Grove ES (2640) 2A | A/C unit is NOT COMING ON per Ms. Macon, Plant Mgr. 416.1456 | 10/2/13 | | | Electrical |
| Shady Grove ES (2640) 2A | four (4) sets of lights in a row are out downstairs by room 117, ballast need replacing | 10/21/13 | 2nd Floor | down stairs by rm. 117 | Electrical |
| Shady Grove ES (2640) 2A | ballast out in room 104, need replacing | 10/31/13 | | room 104 | Electrical |
| Shady Grove ES (2640) 2A | PARTIAL POWER OUTAGE IN RM-102. PLANT MGR- MACON/416.2166 | 11/6/13 | | | Electrical |
| Shady Grove ES (2640) 2A | RECEPTACLES HAVE NO POWER THRU ENTIRE MAIN HALL PLANT MGR- MACON/416.2166 | 11/22/13 | | | Electrical |
| Shady Grove ES (2640) 2A | FAN SWITCH is NOT BLOWING ON HIGH per Ms. Macon, Plant Mgr. 416.1456 | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | ROOFTOP UNIT is NOT COOLING in the CAFETERIA per Ms. Macon, Plant Mgr. 416.1456 | 5/22/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | 2-UNITS NOT COOLING THRU ENTIRE BLDG (HAVING AN EVENT TODAY) PRIN-/416.2166 | 5/22/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|--|--|---------------------------------------|
| Shady Grove ES (2640) 2A | CHILLER NOT COMING ON PLANT MGR - HARRIS/416.2166 | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | A/C RM 117, 118, & 120-ALL NOT COOLING-PLANT MGR: MACON 416-1456 KLR | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | UNIT NOT COOLING IN KITCHEN PLANT MGR- MACON/416.2166 | 5/14/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | BOILER-2 MECH RM- MAKING LOUD NOISES- PLANT MGR MACON 416- 2166 KLR | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | UNIT NOT COOLING IN KITCHEN PLANT MGR- MACON/416.2166 | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | 6-UNITS NOT HEATING IN RM- 119,120,121,122,123,124. PLANT MGR- MACON/416.2166 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | BOILER NOT COMING. PLANT MGR- MACON/416.2148 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|----------|--|--|---------------------------------------|
| Shady Grove ES (2640) 2A | BOILER-NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR MACON 416-1456 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | per Ms. Macon 416-1456 room 114 is blowing cold air | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | HEAT PORT 165-NOT HEATING-PLANT MGR MACON 416-2166 KLR | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | UNIT NOT HEATING IN PORT-165 PLANT MGR-MACON/416.2148 | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | UNIT IN THE CAFE & IN PORTABLE#2 IS NOT COOLING. PRINC. SCHNACKE 416-2166 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | Monthly - Oil Lube & Belt-Shady Grove Elementary - Refer to PM schedule details. | 8/4/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | UV NOT COOLING IN FACILITATOR RM(082) PLANT MGR-MACON/416.2166 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | room 117 blowing cold air per Ms. Macon 416-4128 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|---------|-------------------------|---------------------------------------|
| Shady Grove ES (2640) 2A | UNITS NOT HEATING THRU WEST, KK BLDG 1ST FLR PLANT MGR- MACON/416.2166 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | Monthly - Oil Lube & Belt- Shady Grove Elementary - Refer to PM schedule details. | 3/2/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | Monthly - Filter-Shady Grove Elementary - Refer to PM schedule details. | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | Monthly - Filter-Shady Grove Elementary - Refer to PM schedule details. | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | Monthly - Filter-Shady Grove Elementary - Refer to PM schedule details. | 7/22/13 | | | Heating/Ventilation /Air Conditioning |
| Shady Grove ES (2640) 2A | Unstop sewer | 5/29/14 | | | Plumbing |
| Shady Grove ES (2640) 2A | (3) COMMODES AND FLOOR DRAIN B RR WEST WING-ALL ARE STOPPED UP-WATER STANDING IN FLR-PLANT MGR MACON 416-1456 KLR | 5/20/14 | | | Plumbing |
| Shady Grove ES (2640) 2A | base of sink in kitchen closet leaking, slip hazard, need repairing | 3/7/14 | Kitchen | hot water heater closet | Plumbing |

| | | | | | |
|--------------------------|--|----------|------------------|------------------|----------|
| Shady Grove ES (2640) 2A | toilet in cafeteria constantly running, flush valve seems to be stuck, need repairing | 3/21/14 | Cafeteria | kitchen | Plumbing |
| Shady Grove ES (2640) 2A | Flush sewer | 3/31/14 | | | Plumbing |
| Shady Grove ES (2640) 2A | toilet in teacher's lounge won't flush, need repairing | 11/25/13 | Restroom (Girls) | teacher's lounge | Plumbing |
| Shady Grove ES (2640) 2A | Flush main sewer | 12/20/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | Preform back flow test. | 12/23/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | Kitchen sink is shooting water from the faucets per Ms. Macon, Plant Mgr. 416.1456 | 1/6/14 | | | Plumbing |
| Shady Grove ES (2640) 2A | WATER TANK NOT RELEASING ANT HOT WATER IN KITCHEN, & BROWN WATER COMING FROM THE SINKS IN KITCHEN. PLANT MGR- MACON/416.2148 | 8/8/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | PIPE IS LEAKING WATER IN BOILER RM PLANT MGR- MACON/416.2166 | 8/8/13 | | | Plumbing |

| | | | | | |
|--------------------------|--|----------|------------------|--------------------------|----------|
| Shady Grove ES (2640) 2A | bottom of water valve blocking water flow for ice machine, per repairman's findings, need repairing for Shady Grove mistakenly put on request for Richland Elem. please void | 8/9/13 | Cafetorium | kitchen | Plumbing |
| Shady Grove ES (2640) 2A | west wing water fountain (1st fl.)won't turn off, need repairing | 8/13/13 | 1st Floor | 1st fl. | Plumbing |
| Shady Grove ES (2640) 2A | water fountain on 1st floor hallway is going crazy and can't cut off. water is going everywhere per Ms. Jones 416-1456 | 8/22/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | A/C IN HALLWAY FRONT OF PRIN'S OFC-LEAKING PER SBE-PLANT MGR JEFFERSON 416-2166 KLR | 9/6/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | FOUNTAIN IS LEAKING WEST HALL PLANT MGR- JEFFERSON/416.2166 | 9/9/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | WATERCOOLER in the CAFETERIA is OVERFLOWING per Ms. Macon, Plant Mgr. 416.1456 | 10/4/13 | | | Plumbing |
| Shady Grove ES (2640) 2A | flush valve leaks in toilet (girls) next to handicap stall every times its flushed, need repairing | 10/23/13 | Restroom (Girls) | downstairs northwest end | Plumbing |
| Shady Grove ES (2640) 2A | room 102 has leak coming from ceiling, need repairing | 5/22/14 | Classroom | room 102 | Roof |

| | | | | | |
|--------------------------|--|---------|-----------|----------|------|
| Shady Grove ES (2640) 2A | room 103 has roof leak, need repairing | 5/9/14 | 1st Floor | room 103 | Roof |
| Shady Grove ES (2640) 2A | room 107 has roof leak, need repairing | 5/9/14 | 1st Floor | room 107 | Roof |
| Shady Grove ES (2640) 2A | room 107 has several leaks coming from ceiling, possibly leaking from roof, need repairing | 7/29/13 | 1st Floor | room 107 | Roof |

| Count of Craft | Craft | | | | | | | Grand Total |
|--------------------|----------|--------|-----------|------------|------|----------|----------|-------------|
| Location | Asbestos | Cabins | Carpentry | Electrical | HVAC | Painting | Plumbing | Grand Total |
| Shore ES (2550) 2B | 2 | 1 | 17 | 33 | 16 | 1 | 28 | 98 |
| Grand Total | 2 | 1 | 17 | 33 | 16 | 1 | 28 | 98 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|---------------------|---|----------------|-----------|-------------|-------------------------|-----------|
| Sharpe ES (2650) 2B | requesting classroom bathroom to be treated for mold on pipes and walls. | 10/18/13 | 1st Floor | | rm 10 | Asbestos |
| Sharpe ES (2650) 2B | ceiling flooded cause tiles with asbestos to fall in classroom. health hazard. please advise!!!!!! | 6/19/14 | 1st Floor | | classroom 12 | Asbestos |
| Sharpe ES (2650) 2B | requesting a outlet to be installed for computers. (SCS Cabling and Electronics dept.-- "Please See Journal Notes") | 2/25/14 | 1st Floor | | cafeteria | Cabling |
| Sharpe ES (2650) 2B | fence is turn down need to be repaired. | 2/27/14 | Grounds | | back of school building | Carpentry |
| Sharpe ES (2650) 2B | fence behind building has been torn down and needs to be repaired. | 7/16/13 | Grounds | | back play area | Carpentry |
| Sharpe ES (2650) 2B | requesting cork boards to be installed inside and outside art room for exhibits. (tac strips os) | 8/6/13 | 2nd Floor | | rm 20 | Carpentry |
| Sharpe ES (2650) 2B | cabinet doors need hinges to rehang doors [4] each. | 1/16/14 | Kitchen | | sewing line area | Carpentry |

| | | | | | |
|---------------------|--|----------|-----------|-----------------|-----------|
| Sharpe ES (2650) 2B | classroom door will not close, can not secure this room. | 1/31/14 | 2nd Floor | rm 24 | Carpentry |
| Sharpe ES (2650) 2B | replace base bords that are missing in hallway. | 2/25/14 | 2nd Floor | hall way | Carpentry |
| Sharpe ES (2650) 2B | stall door broken off need to be rehanged. | 8/26/13 | 1st Floor | a hall girls rr | Carpentry |
| Sharpe ES (2650) 2B | BROKEN WINDOW IN CAFE. PLANT MGR-FISHER/416.5020 | 9/4/13 | | | Carpentry |
| Sharpe ES (2650) 2B | requisting old chalk bord to be replaced with new white bord. this portable is a new second grade class. | 10/3/13 | Portables | 160 music | Carpentry |
| Sharpe ES (2650) 2B | repair holes in the wall. | 10/22/13 | Portables | p/e 360 | Carpentry |
| Sharpe ES (2650) 2B | floor tiles are missing and need to be replaced. | 11/15/13 | Portables | p/e | Carpentry |
| Sharpe ES (2650) 2B | boys stall door broken needs repairing. | 11/15/13 | Annex | boys rr | Carpentry |

| | | | | | |
|---------------------|---|---------|-----------|-------------------------|------------|
| Sharpe ES (2650) 2B | door closure is broken and needs to be replaced. safty hazord | 5/12/14 | 1st Floor | main entrance | Carpentry |
| Sharpe ES (2650) 2B | FENCE HAS FALLEN DOWN BACK OF BLDG PLANT MGR-KNOTS/416.5020 | 6/9/14 | | | Carpentry |
| Sharpe ES (2650) 2B | glass broken in classroom need to be replaced. [Safty hazord] | 8/6/13 | 1st Floor | rm A-02 | Carpentry |
| Sharpe ES (2650) 2B | part of fence has been torn down needs to be repaired. | 1/8/14 | Grounds | back of school | Carpentry |
| Sharpe ES (2650) 2B | fence is turn down need to be repaired. | 2/27/14 | Grounds | back of school building | Carpentry |
| Sharpe ES (2650) 2B | light fixture is out need balast replaced | 4/14/14 | 2nd Floor | rm 27 | Electrical |
| Sharpe ES (2650) 2B | light fixture is out balast need to be replaced. need fixed for t- cap testing. | 4/24/14 | 1st Floor | rm 19 | Electrical |
| Sharpe ES (2650) 2B | light fixturs out need balast replaced in these rooms for T-Cap testing. | 4/24/14 | 2nd Floor | rm 26,27 | Electrical |

| | | | | | |
|---------------------|---|----------|-----------|--------------|------------|
| Sharpe ES (2650) 2B | light fixture is out, balast need to be replaced. can not see | 5/2/14 | 1st Floor | main hallway | Electrical |
| Sharpe ES (2650) 2B | Teachers Lounge unit ventilator burning smell per Mr. Fisher 416-0763 | 7/24/13 | | | Electrical |
| Sharpe ES (2650) 2B | hallway heaters are not working need new motors. | 12/3/13 | Annex | hallway | Electrical |
| Sharpe ES (2650) 2B | Music Portable #160 unit is blowing cold air per mr fisher 416-5020 | 12/9/13 | | | Electrical |
| Sharpe ES (2650) 2B | requisting an outlet to be installed for computers in this area. | 12/18/13 | 1st Floor | cafeteria | Electrical |
| Sharpe ES (2650) 2B | boys restroom heater is not working, moter needs to be replaced or repaired. | 1/14/14 | Annex | boys rr | Electrical |
| Sharpe ES (2650) 2B | VENT-A-HOOD KITCHEN AREA- NOT WORKING AT ALL-WILL NEED- PLANT MGR FISHER 416-5000 KLR | 1/16/14 | | | Electrical |
| Sharpe ES (2650) 2B | door magnet to fire door is damaged and will not hold door open. | 1/31/14 | 2nd Floor | stairwell | Electrical |

| | | | | | |
|---------------------|---|---------|-----------------|---------------|------------|
| Sharpe ES (2650) 2B | Power outage over the weekend. plant manger needs assistance in resetting some main breakers, and check some hvac equipement. | 2/3/14 | Mechanical Room | | Electrical |
| Sharpe ES (2650) 2B | unit ventalater motor is bad needs to be replaced not working | 2/6/14 | Annex | lounge | Electrical |
| Sharpe ES (2650) 2B | light fixture is out balast is bad need to be replaced. | 2/6/14 | Annex | class room 6A | Electrical |
| Sharpe ES (2650) 2B | There is a light out with a bad ballast in cafetorium | 2/10/14 | Cafetorium | | Electrical |
| Sharpe ES (2650) 2B | balast is bad needs to be changed. | 2/18/14 | Cafeteria | dinning area | Electrical |
| Sharpe ES (2650) 2B | light fixture is out need balast replaced. | 2/19/14 | Annex | rm 1A | Electrical |
| Sharpe ES (2650) 2B | light fixture is out balast need to be replaced. | 8/7/13 | 1st Floor | annex hall | Electrical |
| Sharpe ES (2650) 2B | light fixture is out need balast replaced. | 8/16/13 | 2nd Floor | rm 28 | Electrical |

| | | | | | |
|---------------------|--|----------|---------------------|------------------|------------|
| Sharpe ES (2650) 2B | light fixture is out need balast replaced. | 8/22/13 | 2nd Floor | rm 23 | Electrical |
| Sharpe ES (2650) 2B | light fixture is out need balast replaced. | 8/26/13 | 1st Floor | rm 11 | Electrical |
| Sharpe ES (2650) 2B | light fixture is out need ballast replaced. | 8/30/13 | Cafeteria | dinning area | Electrical |
| Sharpe ES (2650) 2B | requisting 3 outlets to be replaced that are not working. | 9/19/13 | Portables | music | Electrical |
| Sharpe ES (2650) 2B | wall outlet need to be replaced due to bad connection caused it to burn out. | 10/14/13 | Administration Area | principal office | Electrical |
| Sharpe ES (2650) 2B | light fixture out need balast replaced. | 10/14/13 | 1st Floor | cafeteria | Electrical |
| Sharpe ES (2650) 2B | A/C PORT 160-NOT COMING ON-PLANT MGR FISHER 416-5020 KLR | 10/21/13 | | | Electrical |
| Sharpe ES (2650) 2B | VENT-A-HOOD KITCHEN AREA-NOT COMING ON-PLANT MGR FISHER 416-0763 KLR | 11/12/13 | | | Electrical |

| | | | | | |
|---------------------|---|---------|-----------|------------|---------------------------------------|
| Sharpe ES (2650) 2B | fire door will not stay open due to malfunction of door magnet. | 5/20/14 | 2nd Floor | stair well | Electrical |
| Sharpe ES (2650) 2B | lights out in dining area 6 fixtures out. | 6/4/14 | 1st Floor | cafiera | Electrical |
| Sharpe ES (2650) 2B | light fixture is out, balast is bad needs to be replaced. | 6/19/14 | Annex | library | Electrical |
| Sharpe ES (2650) 2B | requisting security lights in the hallway we don t have any. | 6/19/14 | Annex | hallway | Electrical |
| Sharpe ES (2650) 2B | Power outage, check equipment. | 6/27/14 | | | Electrical |
| Sharpe ES (2650) 2B | requisting 30 day bright lamps to replace lights that need to be replaced in hallway. | 6/27/14 | 1st Floor | hallway | Electrical |
| Sharpe ES (2650) 2B | A/C PORT 160-NOT COOLING-PLANT MGR FISHER 416-0783 KLR | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Yearly - Cooling Towers(STRAINERS)-Sharpe Elem - Refer to PM schedule details. | 3/23/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|----------|--|--|---------------------------------------|
| Sharpe ES (2650) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Library a/c not cooling per Mr. Fisher 416-0763 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | UNIT IN PORTABLE#312 IS NOT COOLING. SBE FISHER 416-0763 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Unit Ventilator, ID#055-018 is smoking in Rm 2A per Mr. Fisher, Plant Mgr. at 901.416.0763. | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | CHILLER NOT COMING ON. PLANT MGR-FISHER/416.5020 | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Monthly - Oil Lube & Belt-Sharpe Elementary - Refer to PM schedule details. | 8/31/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Boiler is NOT COMING ON per Mr. Fisher, Plant Mgr. 416.0763 | 10/23/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | per mr fisher 416-0763 portable 160 the a/c is blowing hot | 5/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---------------------|---|----------|-----------|---------|---------------------------------------|
| Sharpe ES (2650) 2B | Monthly - Filter-Sharpe Elementary - Refer to PM schedule details. | 7/14/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Monthly - Filter-Sharpe Elementary - Refer to PM schedule details. | 3/16/14 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Monthly - Oil Lube & Belt-Sharpe Elementary - Refer to PM schedule details. | 3/29/14 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Yearly - Boiler - Sharpe Elem - Refer to PM schedule details. | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Monthly - Filter-Sharpe Elementary - Refer to PM schedule details. | 11/17/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | Yearly - Oil Samples-Sharpe Elementary - Refer to PM schedule details. | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Sharpe ES (2650) 2B | paint plywood panels for portable | 11/4/13 | | | Painting |
| Sharpe ES (2650) 2B | the 3 compartment sink is leaking and need to be repaired. | 3/28/14 | Cafeteria | kitchen | Plumbing |

| | | | | | |
|---------------------|---|----------|-----------|---------|----------|
| Sharpe ES (2650) 2B | sewage is backing up out side the portable due to tree roots. | 3/21/14 | Portables | p/e | Plumbing |
| Sharpe ES (2650) 2B | Fill cooling tower and check out for cooling season. | 4/3/14 | | | Plumbing |
| Sharpe ES (2650) 2B | toilet will not stop running, need to be repaired | 4/11/14 | 2nd Floor | boys rr | Plumbing |
| Sharpe ES (2650) 2B | 3 compartment sink stoped up.need to be repaired. | 4/22/14 | Cafeteria | kitchen | Plumbing |
| Sharpe ES (2650) 2B | two compartment sink stoped up can not use. | 5/1/14 | Cafeteria | kitchen | Plumbing |
| Sharpe ES (2650) 2B | 2-COM SINK IS STOPPED UP IN KITCHEN PLANT MGR-FISHER/416.5020 | 5/2/14 | | | Plumbing |
| Sharpe ES (2650) 2B | Library unit ventilator stopped up and leaking water per Mr. Fisher 416-0763 | 7/26/13 | | | Plumbing |
| Sharpe ES (2650) 2B | p trap on water fountain need to be replaced or repaired water leaking badly. | 12/11/13 | 1st Floor | A hall | Plumbing |

| | | | | | |
|---------------------|---|---------|-----------|----------|----------|
| Sharpe ES (2650) 2B | toilet is broken can not use ,need to be replaced. | 2/5/14 | Annex | girls rr | Plumbing |
| Sharpe ES (2650) 2B | UV LEAKING WATER IN RM-4A ANNEX(013). PLANT MGR-FISHER/416.5020 | 8/8/13 | | | Plumbing |
| Sharpe ES (2650) 2B | 2-UV ARE LEAKING WATER IN RM-20(046) RM-5A(014). PLANT MGR-FISHER/416.5020 | 8/8/13 | | | Plumbing |
| Sharpe ES (2650) 2B | UV leaking, drain pain stoppedup. | 8/12/13 | Library | | Plumbing |
| Sharpe ES (2650) 2B | Per Mr. Fisher 416-0763 water from grease trap in kitchen is dumping water onto floor | 8/12/13 | | | Plumbing |
| Sharpe ES (2650) 2B | UV ANNEX LIBRARY-LEAKING DUE TO DRAINPAN STOPPED UP-SBE FISHER 416-0763 KLR | 8/12/13 | | | Plumbing |
| Sharpe ES (2650) 2B | 3-COMPARTMENT SINK KITCHEN- ALL (3) SIDES STOPPED UP-SBE FISHER 416-0763 KLR | 8/16/13 | | | Plumbing |
| Sharpe ES (2650) 2B | toilet will not stop running. | 8/28/13 | 2nd Floor | girls rr | Plumbing |

| | | | | | |
|---------------------|--|----------|-----------------|----------|----------|
| Sharpe ES (2650) 2B | Girls restroom - commode continuously running | 9/12/13 | 1st Floor | | Plumbing |
| Sharpe ES (2650) 2B | toilet will not stop runing. | 9/12/13 | 1st Floor | girls rr | Plumbing |
| Sharpe ES (2650) 2B | faucet is continuing to run,stim or washer need to be changed. | 10/8/13 | | | Plumbing |
| Sharpe ES (2650) 2B | Test and repair RP Devices per MLG&W. | 10/29/13 | Mechanical Room | | Plumbing |
| Sharpe ES (2650) 2B | COMMODOE PORT 322-CONSTANTLY OVERFLOWING, SBE CAN'T CUT OFF-PLANT MGR FISHER 416-5020 KLR | 11/5/13 | | | Plumbing |
| Sharpe ES (2650) 2B | Video & washout sanitary sewer | 11/13/13 | | | Plumbing |
| Sharpe ES (2650) 2B | toilet cutoff valve need to be replaced due to handle being stripped,can not shut off or on. | 11/13/13 | Portables | p/e 360 | Plumbing |
| Sharpe ES (2650) 2B | toilet is stoped up backing up on the outside of the portable. We are having fild day. | 5/20/14 | Portables | p/e | Plumbing |

| | | | | | |
|---------------------|--|---------|--|--|----------|
| Sharpe ES (2650) 2B | BUSTED PIPE OUTSIDE LEADING TO B/RR PLANT MGR-FISHER/416.5020 | 5/21/14 | | | Plumbing |
| Sharpe ES (2650) 2B | Unstop sewer | 5/29/14 | | | Plumbing |
| Sharpe ES (2650) 2B | WTR FOUNTAIN - FLOODED THE 2ND FLR - AND RUNNING DOWN TO THE 1ST FLR - CAN'T SHUT OFF - PM/KNOX 416-5028 | 6/4/14 | | | Plumbing |

| Count of Craft | Craft | | | | | | | | |
|--------------------------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Shelby Oaks ES (2680) 2A | 1 | 43 | 38 | 60 | 4 | 46 | 3 | 2 | 197 |
| Grand Total | 1 | 43 | 38 | 60 | 4 | 46 | 3 | 2 | 197 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|--------------------------|--|----------------|------------------|----------------|-----------|
| Shelby Oaks ES (2680) 2A | Leslie Ratliff- need Drop20 repaired in room 128- PO PHASE 8- 1517835 | 4/17/14 | Classroom | 128 | Cabling |
| Shelby Oaks ES (2680) 2A | door # 3 - door on left want open. exit door | 5/21/14 | Hallway/Corridor | door #3 | Carpentry |
| Shelby Oaks ES (2680) 2A | tile needs repair. tile breaking up, floor uneven. | 5/21/14 | Portables | 237 A&B | Carpentry |
| Shelby Oaks ES (2680) 2A | Request Floor tiles be repaired. | 5/27/14 | | portable 328 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Request floor tiles be repaired. | 5/27/14 | | portable 328 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Request Ceiling be repaired | 5/27/14 | | portable 334 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Secure three white boards against the wall, they are about to fall off the wall. | 9/11/13 | Classroom | room123 | Carpentry |
| Shelby Oaks ES (2680) 2A | ceiling has hole in it, letting rain and wasp into classroom. ceiling about to fall in. location: left side corner | 4/1/14 | Portables | 334 | Carpentry |

| | | | | | |
|--------------------------|--|---------|------------------|----------------------|-----------|
| Shelby Oaks ES (2680) 2A | The roof is leaking very badly in portable #334 need to be repaired. | 4/2/14 | | portable #334 | Carpentry |
| Shelby Oaks ES (2680) 2A | have multiple crawl space covers missing on portables behind school. wild animals have been spotted under some of them. need repair. | 4/4/14 | Portables | | Carpentry |
| Shelby Oaks ES (2680) 2A | Rain gutter coming away from portable 334-B. Wooden support dry rotted. | 4/10/14 | Portables | 334-B | Carpentry |
| Shelby Oaks ES (2680) 2A | need hydraulic closer on access door to attic in electrical closet 1A. metal door fell on my head while exiting attic. | 4/17/14 | | electrical closet 1A | Carpentry |
| Shelby Oaks ES (2680) 2A | need cage put over outlet for milk box. electrical cover too small for original hole and plug keeps falling out. | 4/24/14 | Kitchen | milk box outlet | Carpentry |
| Shelby Oaks ES (2680) 2A | Request grate over the drain be replaced. (1 1/2" X 14" X 35") | 1/15/14 | | | Carpentry |
| Shelby Oaks ES (2680) 2A | Floor tiles are coming up and crackin throughout this portable. | 2/14/14 | Portables | 327 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Portable wall has a big hole. | 2/14/14 | Portables | 334 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Girls restroom stall stuck and hard to open. | 2/28/14 | Restroom (Girls) | 4 grade hall | Carpentry |

| | | | | | |
|--------------------------|--|---------|------------------|--------------------|-----------|
| Shelby Oaks ES (2680) 2A | I need special cut ceiling tiles throughout the hallways | 2/28/14 | Hallway/Corridor | | Carpentry |
| Shelby Oaks ES (2680) 2A | repair hold in the floor near teachers desk. | 3/12/14 | | | Carpentry |
| Shelby Oaks ES (2680) 2A | Wood underneath gutter is dry rotten and falling.gutter is very loose. | 3/17/14 | Portables | 334 | Carpentry |
| Shelby Oaks ES (2680) 2A | SIDE ENTRANCE DOOR #3 OFF PARKING LOT-NOT CLOSING ALL THE WAY-WON'T BE ABLE TO SECURE-PLANT MGR BOYKINS 416-4305 KLR | 3/21/14 | | | Carpentry |
| Shelby Oaks ES (2680) 2A | Boys restroom wall has a hole | 7/24/13 | Restroom (Boys) | 1st. grade hallway | Carpentry |
| Shelby Oaks ES (2680) 2A | Install 3 black boards | 8/12/13 | | kitchen/cafeteria | Carpentry |
| Shelby Oaks ES (2680) 2A | Door will lock but will not stay closed,you can pull it right open even when locked. | 8/13/13 | Classroom | 129 | Carpentry |
| Shelby Oaks ES (2680) 2A | Door will lock but you can pull it open even when locked. | 8/13/13 | Kitchen | | Carpentry |
| Shelby Oaks ES (2680) 2A | ENTRY CAFE' DOOR CANT SECURE PLANT MGR-BOYKIN/416.4306 | 8/14/13 | | | Carpentry |

| | | | | | |
|--------------------------|---|---------|-----------|-------|-----------|
| Shelby Oaks ES (2680) 2A | Door not catching when open/ close, also interior door,knob is loose | 8/19/13 | Portables | 328 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Entrance door not catching when open / close,also interior door is not shutting properly. | 8/19/13 | Portables | 338 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Floor tiles broken throughout the classroom, | 8/19/13 | Portables | 338 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Door not catching when open/ close. also broken floor tiles throughout the classroom | 8/19/13 | Portables | 338 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Broken floor tiles throughout the classroom, and a hole in the floor. | 8/19/13 | Portables | 327 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Door not catching when open/ close | 8/19/13 | Portables | 327 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Missing and broken floor tiles throughout classroom. | 8/19/13 | Portables | 327 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Classroom floor has a big hole and broken floor tiles throughout . | 8/19/13 | Portables | 334 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Door not catching when open/ close | 8/19/13 | Portables | 334 A | Carpentry |

| | | | | | |
|--------------------------|---|----------|------------------|---------------------------------------|-----------|
| Shelby Oaks ES (2680) 2A | use new tile purchased by us to replace all water stained tiles(sprinkler heads, exit lights, any other missing tiles which need to be cut) plan on doing this the week of fall break. Ost 7th thru 11th-os | 9/24/13 | | | Carpentry |
| Shelby Oaks ES (2680) 2A | Fire door bar and handler broken | 9/24/13 | Hallway/Corridor | near door 3 or near multi purpose rm. | Carpentry |
| Shelby Oaks ES (2680) 2A | Request water damaged ceiling tile in room 128 be replaced. | 10/16/13 | | | Carpentry |
| Shelby Oaks ES (2680) 2A | Sheet Rock need patching ,the ceiling | 10/23/13 | Hallway/Corridor | near door 4 | Carpentry |
| Shelby Oaks ES (2680) 2A | DOOR - FRONT ENTRY - NOT CLOSING TO SECURE - PM/BOYKINS 416-4305 | 12/17/13 | | | Carpentry |
| Shelby Oaks ES (2680) 2A | Hole in the ceiling | 8/19/13 | Portables | 334 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Broken floor tiles throughout the classroom, holes in the wall. | 8/19/13 | Portables | 328 B | Carpentry |
| Shelby Oaks ES (2680) 2A | Broken floor tiles throughout the classroom | 8/19/13 | Portables | 328 A | Carpentry |
| Shelby Oaks ES (2680) 2A | Need 5 cases of ceiling tiles | 8/12/13 | | Plant Manager Office | Carpentry |

| | | | | | |
|--------------------------|---|---------|-----------|-------------------------------|------------|
| Shelby Oaks ES (2680) 2A | unable to hear fire allarm bells in portables | 5/19/14 | Portables | all | Electrical |
| Shelby Oaks ES (2680) 2A | Ceiling unit at door # 2 making loud noise. unit # 034-148 | 5/21/14 | | ac unit in ceiling at door #2 | Electrical |
| Shelby Oaks ES (2680) 2A | Replace missing receptacle cover | 8/19/13 | Portables | 328 A | Electrical |
| Shelby Oaks ES (2680) 2A | I'm placing a order for 4 boxes of light bulbs Lamp,Flr. Rapid Start 30/bx. 32 wa.(lamp size) | 9/12/13 | | | Electrical |
| Shelby Oaks ES (2680) 2A | ballast out in room 168 | 4/3/14 | Classroom | 168 | Electrical |
| Shelby Oaks ES (2680) 2A | need three (3) cases or 90 F32T8/ADV841/XLL 28 watt lamps. need lights for TCAP | 4/11/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | Power outage at the portables. | 4/15/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | A/C RM 197-HAS NO POWER TO IT-PLANT MGR WILLIAMS KLR | 4/25/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | ceiling a/c unit # 034-148 @ door 2. a/c unit want turn on, connected to 2 units. | 4/30/14 | 1st Floor | unit in ceiling by rm 197 | Electrical |

| | | | | | |
|--------------------------|--|---------|-----------|----------------------------|------------|
| Shelby Oaks ES (2680) 2A | UV IS MAKING NOISE IN RM-182. PLANT MGR-BOYKINS/347.5164 | 1/23/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | Blown ballast | 1/27/14 | Classroom | rooms 174 and 175 | Electrical |
| Shelby Oaks ES (2680) 2A | Blown ballast | 1/30/14 | Kitchen | pantry | Electrical |
| Shelby Oaks ES (2680) 2A | Light bulbs (sizeF40/CMX) or F40/CWX) 6 bulbs | 1/30/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | Clocks are not operating at the correct time. | 2/10/14 | | Throughout the building | Electrical |
| Shelby Oaks ES (2680) 2A | per ms boykins 416-4305 the garbage disposal smokes when on | 2/12/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | Exit light hanging off the wall. | 2/14/14 | Portables | 327 B | Electrical |
| Shelby Oaks ES (2680) 2A | UNIT HAS BURNING SMELL IN PORT- 338A PLANT MGR- BOYKINS/373.2644 | 2/18/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | 4 lights out in muliti purpose room. ceiling over 12 ft. high | 2/20/14 | | Muliti Purpose room | Electrical |

| | | | | | |
|--------------------------|--|---------|-----------|---------------------|------------|
| Shelby Oaks ES (2680) 2A | per ms boykins 416-4305 room 125 not coming on at all | 3/4/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | HAS A COMPLETE POWER OUTAGE-PLANT MGR BOYKINS 416-4305 KLR | 3/12/14 | | | Electrical |
| Shelby Oaks ES (2680) 2A | I'm ordering 3 cases of philips fluoresent light bulbs.28 watt. 147348001 here's another #F32T8/ADV841/EW | 3/17/14 | Portables | 334 | Electrical |
| Shelby Oaks ES (2680) 2A | Replace all blown pole lights around the entire school parking lot. | 3/18/14 | | outside pole lights | Electrical |
| Shelby Oaks ES (2680) 2A | COOLING TOWER NOT COMING ON . PLANT MGR-BOYKIN/416.4305 | 7/29/13 | | | Electrical |
| Shelby Oaks ES (2680) 2A | One light switch won't turn off when teacher is using the docucam. | 8/2/13 | | classroom 127 | Electrical |
| Shelby Oaks ES (2680) 2A | All clocks in the entire building need to be set to the right time. | 8/7/13 | | entire building | Electrical |
| Shelby Oaks ES (2680) 2A | wires hanging low by the cafeteria loading dock and trucks and buses can't get under them per Ms. Boykins 416-4305 | 8/19/13 | | | Electrical |
| Shelby Oaks ES (2680) 2A | Exit light haning from the wall in classroom | 8/19/13 | Portables | 334 B | Electrical |

| | | | | | |
|--------------------------|--|----------|------------------|------------------------|------------|
| Shelby Oaks ES (2680) 2A | RECEPTACLES ON THE MILKBOX WALL--8/20/13 ALL HAVE NO POWER INCLUDING MILKBOX-SBE BOYKINS 416-4305 KLR | | | | Electrical |
| Shelby Oaks ES (2680) 2A | One electrical outlet not working in rm.197 | 8/21/13 | Classroom | 197 | Electrical |
| Shelby Oaks ES (2680) 2A | Set master clock. | 8/26/13 | | | Electrical |
| Shelby Oaks ES (2680) 2A | AN ELECTRICAL BURNING SMELL IN RM 128 PER SBE-PLANT MGR BOYKINS 416-4305 KLR | 9/18/13 | | | Electrical |
| Shelby Oaks ES (2680) 2A | Blown ballasts | 10/28/13 | Hallway/Corridor | throughout hallways | Electrical |
| Shelby Oaks ES (2680) 2A | I'm ordering 2 cases of sylvania small 4 prong light bulbs description of some that I took down.13W USA CF13DDE841 u619 | 10/28/13 | Hallway/Corridor | throughout hallways | Electrical |
| Shelby Oaks ES (2680) 2A | Ordering 15 incandescent 75 or 100 watt light bulbs (screw in type) | 10/28/13 | Classroom | | Electrical |
| Shelby Oaks ES (2680) 2A | Replace blown light on poles throughout the entire parking lot. | 11/6/13 | Parking Lot | | Electrical |
| Shelby Oaks ES (2680) 2A | Replace or repair blown lights outside on cafeteria dock. | 11/6/13 | Cafeteria | cafeteria dock | Electrical |

| | | | | | |
|--------------------------|--|----------|------------------|---------------------|---------------------------------------|
| Shelby Oaks ES (2680) 2A | Repair blown ballast on small 4 prong 13 watts lights throughout hallways. | 11/6/13 | Hallway/Corridor | throughout hallways | Electrical |
| Shelby Oaks ES (2680) 2A | 3 sets of blown ballast. | 12/23/13 | Classroom | 134 | Electrical |
| Shelby Oaks ES (2680) 2A | UNIT NOT COOLING IN MAIN OFFICE PLANT MGR-WILLIAMS/356.6249 | 5/21/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Monthly - Oil Lube & Belt-Shelby Oaks Elementary - Refer to PM schedule details. | 6/7/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Monthly - Air Compressor -Shelby Oaks Elementary - Refer to PM schedule details. | 6/7/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | A/C CONFERENCE RM-NOT COOLING-PLANT MGR WILLIAMS 416-4305 KLR | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | rooms 175, 167, 125 a/c not cooling per Ms. Boykins 416-4305 | 9/5/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | replace chemicals in cooling tower | 4/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|---------|--|--|---------------------------------------|
| Shelby Oaks ES (2680) 2A | UNIT IS OVER COOLING IN RM-170 PLANT MGR-WILLIAMS/347.5164 | 4/10/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER MECH RM-IN ALARM-PLANT MGR WILLIAMS 416-0835 KLR | 4/17/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLERS IS IN ALARM. PLANT MGR-WILLIAMS/347.5164 | 4/24/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | HEAT PORT 338B-NOT HEATING-PLANT MGR BOYKINS 416-4305 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | HEAT MULTIPURPOSE RM-NOT HEATING-PLANT MGR BOYKINS 416- 4305 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | HEAT RMS 121 & 131-BOTH NOT HEATING-PLANT MGR BOYKINS 416- 4305 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | per Ms. Boykins 416-4305 room 184 is blowing cold | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | HEAT RM 135, 143, 151, & 182-ALL NOT HEATING-PLANT MGR BOYKINS 416- 4305 KLR | 1/8/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | 2-BOILERS NOT COMING ON. PLANT MGR-BOYKINS/416.4305 | 1/13/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--|---------------------------------------|
| Shelby Oaks ES (2680) 2A | 3-UV NOT HEATING IN RM-153,170,135. PLANT MGR-BOYKINS/347.5164 | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | HEAT PORT 338 A/B-NOT HEATING- PLANT MGR BOYKINS 416-4305 KLR | 1/27/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | HEAT MULTI-PURPOSE RM- OVERHEATING, TEMP IS 84-PLANT MGR BOYKINS 416-4305 KLR | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | UNIT in PORTABLE 338A is NOT HEATING per Ms. Boykins, Plant Mgr. 416.4305 | 2/5/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | per ms boykins 416-4305 cafeteria and room 135 blowing cold air | 3/4/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | per ms boykins 416-4305 boiler #2 has gas smell | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Chiller down per EMS 7.2.13 | 7/14/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | UV NOT COOLING IN RM-125.. SBE-BOYKIN/416-4305 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | 3-UV NOT COOLING IN RM- 170,174,PORT-334B . PLANT MGR-BOYKIN/416.4305 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--|---------------------------------------|
| Shelby Oaks ES (2680) 2A | 4-UV NOT COOLING IN RM-174 , PORT-328A,328B, 121. PLANT MGR-BOYKINS/416.4305 | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | A/C IN PORT 327A-NOT COOLING-SBE BOYKINS 416-4305 KLR | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER NOT COMING ON PLANT MGR-DAWSON/416.3940 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | UV'S RM 180, RM 121, RM 151, RM 157, RM 144, & FCU CAFE EAST STORERM-ALL NOT COOLING-SBE BOYKINS 416-4305 KLR | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER NOT COMING ON. PLANT MGR-BOYSKIN/416.4305 | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | A/C IN RM 167-NOT COOLING-SBE BOYKINS 416-4305 KLR | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | UV NOT COOLING IN RM-125 PLANT MGR-BOYSKIN/416.4305 | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | A/C RMS 135 & 145-BOTH NOT COOLING-PLANT MGR BOYKINS 416-4305 KLR | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | chiller is down per Ms. Boykins 416-4305 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|----------|--|--|---------------------------------------|
| Shelby Oaks ES (2680) 2A | In the CLINIC in the Main Office the unit is NOT COOLING per Ms. Boykins, Plant Mgr. 416.4305. | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Unit in Room 128 making a LOUD NOISE per Ms. Boykins, Plant Mgr. 416.4305. | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER NOT COMING ON PLANT MGR-BOYKINS/416.4305 | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | chiller down per Ms Boykins 416-4305 | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | chiller down per Ms. Boykins 416-4305 | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | chiller will not come on after being reset per Ms. Boykins 416-4305 | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | A/C unit in ROOM 171 is LEAKING per Ms. Boykins, Plant Mgr. 416.4305 | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | A/C unit in the Multi-Purpose is NOT COOLING per Ms. Boykins, Plant Mgr. 416.4305 | 10/4/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER NOT COMING ON-PLANT MGR BOYKINS 416-4305 KLR | 10/14/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|--|--|---------------------------------------|
| Shelby Oaks ES (2680) 2A | CHILLER IN ALARM-PLANT MGR BOYKINS 416-4305 KLR | 10/15/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | chiller is down per Ms. Boykins 4164503 | 10/16/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER IN ALARM-PLANT MGR BOYKINS 416-4305 KLR | 10/22/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | chiller down per Ms. Boykins 416-4305 | 10/30/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | CHILLER NOT COMING ON. PLANT MGR-BYERS/347.5164 | 10/31/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Monthly - Oil Lube & Belt-Shelby Oaks Elementary - Refer to PM schedule details. | 11/9/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | UNIT NOT HEATING IN PORT- 334,338,328. PLANT MGR-BOYKINS/416-4305 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Monthly - Air Compressor -Shelby Oaks Elementary - Refer to PM schedule details. | 12/7/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | PORT 338D & RM 166- BOTH ARE COMING ON BUT NO HEATING - PM/BOYKINS 416-4305 | 12/17/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--------------|---------------------------------------|
| Shelby Oaks ES (2680) 2A | Monthly - Filter-Shelby Oaks Elementary - Refer to PM schedule details. | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Monthly - Filter-Shelby Oaks Elementary - Refer to PM schedule details. | 1/3/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Yearly - Oil Samples-Shelby Oaks Elementary - Refer to PM schedule details. | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Yearly - Boiler 008-Shelby Oaks El-Blr Rm 161 N - Refer to PM schedule details. | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Yearly - Boiler 009 - Shelby Oaks El-Blr Rm 161S - Refer to PM schedule details. | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Monthly - Filter-Shelby Oaks Elementary - Refer to PM schedule details. | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Yearly - Cooling Towers-STRAINER-Shelby Oaks Elem - Refer to PM schedule details. | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Daily - Shelby Oaks Elem Level 1 Water Treatment - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| Shelby Oaks ES (2680) 2A | Paint all hallways | 8/19/13 | | All hallways | Painting |

| | | | | | |
|--------------------------|--|----------|------------------|----------------|----------|
| Shelby Oaks ES (2680) 2A | Ceiling need to be mudd and painted. | 9/13/13 | Hallway/Corridor | near cafeteria | Painting |
| Shelby Oaks ES (2680) 2A | hallways and base board needs painting | 3/27/14 | 1st Floor | hallways | Painting |
| Shelby Oaks ES (2680) 2A | paint walls in classroom 128 | 10/22/13 | | | Painting |
| Shelby Oaks ES (2680) 2A | no water flow to sink | 5/21/14 | Classroom | 184 | Plumbing |
| Shelby Oaks ES (2680) 2A | WATER COMING FROM BEHIND WALL ON THE KK HALL. PATTON | 6/23/14 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | Flush area drains | 5/5/14 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | FCU# 2 backed up. water running from under FC unit. | 5/13/14 | | 195 | Plumbing |
| Shelby Oaks ES (2680) 2A | 1st. urinal stop up and over flows when flush | 9/11/13 | Restroom (Boys) | near door #6 | Plumbing |
| Shelby Oaks ES (2680) 2A | flush pipe on toilet burst. flooding bathroom | 3/31/14 | Restroom (Girls) | by SBE office | Plumbing |

| | | | | | |
|--------------------------|--|---------|------------------|---------------------------------|----------|
| Shelby Oaks ES (2680) 2A | constant water leak coming from actuator, in front of 3rd grade boys bathroom. unit # 034-139. leak from copper piping, in front of 5th grade boys bathroom. unit #034-172. ceiling units. | 4/8/14 | Hallway/Corridor | | Plumbing |
| Shelby Oaks ES (2680) 2A | Hot water valves both bathrooms. Sink need new valves, broken. | 4/10/14 | Kitchen | bathrooms | Plumbing |
| Shelby Oaks ES (2680) 2A | Water leaking into the hallway. | 4/14/14 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | condensing pump # 034-013 is leaking | 4/17/14 | | boiler room | Plumbing |
| Shelby Oaks ES (2680) 2A | water cooler coming off wall and leaking water. across from rm 198 heading outside. | 4/17/14 | | water cooler across from rm 198 | Plumbing |
| Shelby Oaks ES (2680) 2A | urinal and toilet leaking boys bathroom. toilet sticks and runs continuously. | 4/23/14 | 1st Floor | bathroom boys by SBE office | Plumbing |
| Shelby Oaks ES (2680) 2A | water cooler #034-066 leaking underneath. | 4/23/14 | 1st Floor | water cooler by room 198 | Plumbing |
| Shelby Oaks ES (2680) 2A | unit #034-133 leaking water from pipe. had to turn water off at unit. unit controls classrooms. located in ceiling at door 4. | 4/29/14 | 1st Floor | door 4 | Plumbing |
| Shelby Oaks ES (2680) 2A | PIPES KITCHEN AREA TO RR & SINKS- HAVE BURST & WATER EVERYWHERE- PLANT MGR BOYKINS 416-4305 KLR | 1/8/14 | | | Plumbing |

| | | | | | |
|--------------------------|---|---------|------------------|---------------------------|----------|
| Shelby Oaks ES (2680) 2A | Outside below the kitchen dock ,drain stop up. | 1/8/14 | | outside kitchen dock | Plumbing |
| Shelby Oaks ES (2680) 2A | GAS SMELL IN BOILER RM. PLANT MGR-BOYKINS/416.4305 | 1/10/14 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | PIPES HAVE BUSTED IN CAFE/RR, WASHER RM OUTSIDE ON DOCK, & EMPLOYEES/RR PLANT MGR-BOYKINS/416.4305 | 1/24/14 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | Ceiling leaking | 1/27/14 | Classroom | 123 | Plumbing |
| Shelby Oaks ES (2680) 2A | Toilet won't flush sometimes and handle is loose. | 2/19/14 | | Teacher's lounge restroom | Plumbing |
| Shelby Oaks ES (2680) 2A | Leak in the faucet on the porch but it's not coming from the spigot. I can't turn it off. | 2/20/14 | Kitchen | back porch dock | Plumbing |
| Shelby Oaks ES (2680) 2A | 2 toilets stop up 1st. and 3rd. stalls | 2/24/14 | Restroom (Girls) | across from rm.169 | Plumbing |
| Shelby Oaks ES (2680) 2A | 1st. urinal water running on the floor when flush. and girls near door #3 toilet stop up 3rd. stall | 2/24/14 | Restroom (Boys) | near door #3 | Plumbing |
| Shelby Oaks ES (2680) 2A | test back flow device-os | 7/2/13 | | | Plumbing |

| | | | | | |
|--------------------------|---|---------|-----------------|---------------------------|----------|
| Shelby Oaks ES (2680) 2A | Toilet near urnials when flush water runs into teachers work area. | 7/24/13 | Restroom (Boys) | 1st. grade hallway | Plumbing |
| Shelby Oaks ES (2680) 2A | SEWAGE BACKING UP IN THE GIRLS AND BOYS RSTRMS. LEAD- GRIFFIN 416-4305 | 8/5/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | UV IS LEAKING WATER IN RM- 121. PLANT MGR-BOYKINS/416.4305 | 8/8/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | Outside drain stop up | 8/13/13 | | outside kitchen back door | Plumbing |
| Shelby Oaks ES (2680) 2A | Room 189 a/c leaking per Ms. Boykins 416-4305 | 8/16/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | GARBAGE DISPOSAL KITCHEN- STOPPED UP-SBE BOYKINS 416-4305 KLR | 8/20/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | 3-COMPARTMENT SINK KITCHEN- LEAKING FROM BOTTOM-SBE BOYKINS 416-4305 KLR | 8/20/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | UV IS LEAKING IN RM-140 PLANT MGR-BOYSKIN/416.4305 | 8/20/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | Classroom sink is not working when turn on there is barely a drip coming out of it. | 8/21/13 | Classroom | 184 | Plumbing |

| | | | | | |
|--------------------------|--|----------|------------------|-------------------------|----------|
| Shelby Oaks ES (2680) 2A | 2nd stall toilet won't stop flushing | 8/27/13 | Restroom (Boys) | kindergarden hallway | Plumbing |
| Shelby Oaks ES (2680) 2A | A/C RM 151 LEAKING-PLANT MGR BOYKINS 416-4305 KLR | 8/28/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | Toilet stop up I tried plunging. | 8/29/13 | Restroom (Boys) | near door #2 | Plumbing |
| Shelby Oaks ES (2680) 2A | Girls restroom across from room167 handicap stall stop up | 9/24/13 | Restroom (Girls) | | Plumbing |
| Shelby Oaks ES (2680) 2A | Urinal stop up in boys restroom across from room167 | 9/24/13 | Restroom (Boys) | | Plumbing |
| Shelby Oaks ES (2680) 2A | Handicap stall toilet stop up and the set of urinals in the same restroom stop up. | 9/24/13 | Restroom (Boys) | near door 3 | Plumbing |
| Shelby Oaks ES (2680) 2A | Request push bar be replaced on water fountain near room 128. (The push bar is missing) | 10/16/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | sprinkler head in ceiling leaking near 3rd and 4th grade hallway per Ms. Boykins 416- 4305 | 10/29/13 | | | Plumbing |
| Shelby Oaks ES (2680) 2A | Unclogged floor drain on 3rd & 4th grade hall. (boys restroom) | 11/7/13 | Restroom (Boys) | 3rd & 4th grade hall | Plumbing |

| | | | | | |
|--------------------------|--|----------|------------------|----------------------|-------------|
| Shelby Oaks ES (2680) 2A | 2nd stall toilet stop up (Plant Manager tried and couldn't unstop. | 11/8/13 | Restroom (Boys) | 3rd & 4th grade hall | Plumbing |
| Shelby Oaks ES (2680) 2A | 3 toilet stop up and plunging is not working | 11/12/13 | Restroom (Girls) | across from room 167 | Plumbing |
| Shelby Oaks ES (2680) 2A | Pipe leaking from ceiling over hand sink on 1st. grade hall | 12/17/13 | Hallway/Corridor | across from room 167 | Plumbing |
| Shelby Oaks ES (2680) 2A | Sink in rm 125 is very clogged, water will not go down drain at all. | 12/19/13 | Classroom | 125 | Plumbing |
| Shelby Oaks ES (2680) 2A | Ceiling leaking | 2/5/14 | Portables | 327 A | Roof |
| Shelby Oaks ES (2680) 2A | Ceiling leaking | 2/5/14 | Portables | 334 A | Roof |
| Shelby Oaks ES (2680) 2A | Roof leaking over hand sink across from room 167 | 12/5/13 | Hallway/Corridor | 1st. grade hall | Roof |
| Shelby Oaks ES (2680) 2A | Install shield on fresh air intake at hot water outside kitchen | 1/27/14 | | | Sheet Metal |
| Shelby Oaks ES (2680) 2A | Replace broken gutter over entrance of the portable | 8/19/13 | Portables | 334 B | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|---------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Herwood ES (2665) 2 | 1 | 6 | 37 | 68 | 30 | 3 | 49 | 4 | 3 | 201 |
| Grand Total | 1 | 6 | 37 | 68 | 30 | 3 | 49 | 4 | 3 | 201 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|-----------------------|--|---------------|---------------------|----------------|----------|
| Sherwood ES (2665) 2A | *ATTN.Maurice Tutton*Request to have the 3rd floor hallway replaced due to breaking and cracking of 8" by 8"brown asbestos tiles. | 1/29/14 | 3rd Floor | hallway | Asbestos |
| Sherwood ES (2665) 2A | Request to install thirty internet IDF drops inside the cafeteria for the before and aftercare students to have access to computers. (Request Network Cabling Project Management). | 8/1/13 | Cafeteria | | Cabling |
| Sherwood ES (2665) 2A | "REQUEST RECEIVED" We would Request to replace all phones lines inside all classrooms to data lines.(Request Network Cabling Project Management). (SCS Network Cabling and Electronics dept.--Response – "Please See Journal Notes") | 8/1/13 | Classroom | ALL CLASSROOMS | Cabling |
| Sherwood ES (2665) 2A | Request to install internet IDF drops for room 218. (Request Network Cabling Project Management). "REQUEST RECEIVED" We have received your request for service and support. We would appreciate your patience as we are in the midst of | 8/1/13 | Classroom | room 218 | Cabling |
| Sherwood ES (2665) 2A | Request to adjust time control center to new SCS elementary schedule for 9a.m. to 4p.m.(Request Network Cabling Installation Support). | 8/7/13 | Administration Area | Main office | Cabling |
| Sherwood ES (2665) 2A | Request to install thirty internet IDF drops inside the cafeteria for the before and aftercare students to have access to computers.(Request Network Cabling Project Management). | 8/1/13 | Cafeteria | | Cabling |
| Sherwood ES (2665) 2A | Request to install thirty internet IDF drops inside the cafeteria for the before and aftercare students to have access to computers. (Request Network Cabling Project Management). | 8/1/13 | Cafeteria | | Cabling |

| | | | | | |
|-----------------------|--|----------|------------------|----------------|-----------|
| Sherwood ES (2665) 2A | Request to have the carpenters help me hang a large framed picture in the main hallway by the main office. | 5/13/14 | 1st Floor | by main office | Carpentry |
| Sherwood ES (2665) 2A | FLR IS SINKING IN PORT-58. SEC-MOORE/416-6620 | 7/2/13 | | | Carpentry |
| Sherwood ES (2665) 2A | Request to repair broken stall door inside girls restroom. | 7/17/13 | Restroom (Girls) | by room 217 | Carpentry |
| Sherwood ES (2665) 2A | Request to install wood panels along the side of railing*find SBE for reason of request* | 10/16/13 | Stairway | main hallway | Carpentry |
| Sherwood ES (2665) 2A | Request to replace one door closer on front door of the main entrance,the door is not latching and may be a security issue. | 10/24/13 | | main entrance | Carpentry |
| Sherwood ES (2665) 2A | UNITS SEAL NEEDS TO BE RECAULK BECAUSE WASP ARE GETTING IN RM-211,209,207,218. PLANT MGR-OLLIE/220.7773 | 10/29/13 | | | Carpentry |
| Sherwood ES (2665) 2A | DOOR IS COMING OFF HINGES IN FRONT ENTRY FOR CHILDCARE. PLANT MGR-WHARWOOD/652.4926 | 11/6/13 | | | Carpentry |
| Sherwood ES (2665) 2A | Request to install 19 cork boards outside all classrooms upstairs,the boards are for students creative work and teachers do not have anywhere to display them. | 11/19/13 | 2nd Floor | all classrooms | Carpentry |

| | | | | | |
|-----------------------|--|----------|------------------|--------------|-----------|
| Sherwood ES (2665) 2A | Request to replace one basketball rim inside the gym.The rim is here at the school | 11/19/13 | Basketball Court | gym | Carpentry |
| Sherwood ES (2665) 2A | Request to repair custodial door in main hallway/main lobby,the door will not close or lock. | 11/22/13 | 1st Floor | main hallway | Carpentry |
| Sherwood ES (2665) 2A | Request air conditional be replaced in portable. | 1/14/14 | | | Carpentry |
| Sherwood ES (2665) 2A | Request to rehang one stall door. | 1/14/14 | Restroom (Boys) | by room 325 | Carpentry |
| Sherwood ES (2665) 2A | Request to install a large piece of board,plexi, or lexan on the north wall inside mop closet to keep the weather elements from coming in. | 1/27/14 | Kitchen | mop closet | Carpentry |
| Sherwood ES (2665) 2A | Request to replace/repair door threshold inside P-61,the threshold is very loose causing the door not to close properly. | 1/29/14 | Portables | P-61 | Carpentry |
| Sherwood ES (2665) 2A | request 2 X 4 be painted Hunter Green. | 2/19/14 | | | Carpentry |
| Sherwood ES (2665) 2A | Request to install one stall door inside girls restroom. | 8/1/13 | Restroom (Girls) | by gym | Carpentry |

| | | | | | |
|-----------------------|---|---------|-----------|-------------------------|-----------|
| Sherwood ES (2665) 2A | FRONT PORCH HAS BROKEN IN PORT-218, BACK PORCH IS BENDING. ASSIST PRIN-TERRA/416.4864 | 8/8/13 | | | Carpentry |
| Sherwood ES (2665) 2A | Request to repair old,unstable and unsafe handrails on portable P61. | 8/15/13 | Portables | P61 | Carpentry |
| Sherwood ES (2665) 2A | 6 benches and 4 trash cans Brian Shipp will handle | 8/19/13 | | | Carpentry |
| Sherwood ES (2665) 2A | Request to replace portable 61 stairs with an ADA compliance ramp. | 8/22/13 | Portables | P61 | Carpentry |
| Sherwood ES (2665) 2A | Request to replace broken and missing tiles inside of room 106,102,207,212,218,214,325,221. | 9/6/13 | | 1st and 2nd floor | Carpentry |
| Sherwood ES (2665) 2A | Request to repair front door of the building,the door is not latching/unlatching properly. | 9/18/13 | 1st Floor | front door/main lobby | Carpentry |
| Sherwood ES (2665) 2A | Request to repair outside double doors leading to the cafeteria,the doors are not closing and locking properly. | 10/1/13 | 1st Floor | space next to cafeteria | Carpentry |
| Sherwood ES (2665) 2A | Request to replace old wood on stairs of portable 58. | 7/18/13 | Portables | P- 58 | Carpentry |

| | | | | | |
|-----------------------|---|---------|-----------|---------------------|-----------|
| Sherwood ES (2665) 2A | Request to replace 10 missing floor tiles inside of room 209. | 7/23/13 | 2nd Floor | Room 209 | Carpentry |
| Sherwood ES (2665) 2A | Request to replace 8 missing floor tiles inside of room 207. | 7/23/13 | 2nd Floor | Room 207 | Carpentry |
| Sherwood ES (2665) 2A | Request to replace four missing floor tiles inside room 206. | 7/23/13 | 2nd Floor | Room 206 | Carpentry |
| Sherwood ES (2665) 2A | Request to replace eight missing floor tiles inside of room 216 | 7/23/13 | 2nd Floor | Room 216 | Carpentry |
| Sherwood ES (2665) 2A | Request to replace seven missing floor tiles inside of room 218. | 7/23/13 | 2nd Floor | Room 218 | Carpentry |
| Sherwood ES (2665) 2A | Request to replace fifteen missing floor tiles inside of room 320. | 7/23/13 | 3rd Floor | Room 320 | Carpentry |
| Sherwood ES (2665) 2A | Request to have four cases of ceiling tiles sent to the school. | 7/23/13 | | For entire building | Carpentry |
| Sherwood ES (2665) 2A | Request to change lock to the opposite side of door so you can lock the door from the inside. | 7/24/13 | Kitchen | Front door | Carpentry |

| | | | | | |
|-----------------------|--|---------|-----------|-------------------|------------|
| Sherwood ES (2665) 2A | Request to repair a loose wooden walkway to front door of the portable. | 3/17/14 | Portables | P217 | Carpentry |
| Sherwood ES (2665) 2A | Request to repair one door closer inside P218. | 3/17/14 | Portables | P218 | Carpentry |
| Sherwood ES (2665) 2A | Request to repair broken door going inside elevator landing by room 118. | 4/4/14 | 1st Floor | by room 118 | Carpentry |
| Sherwood ES (2665) 2A | Request to repair a very loose handrail outside of portable 60. | 4/25/14 | Portables | P-60 | Carpentry |
| Sherwood ES (2665) 2A | Request to put door stoppers on bottom of doors of all main entrances way. | 7/17/13 | | main entrances | Carpentry |
| Sherwood ES (2665) 2A | Request to install a extra outlet inside her office. | 3/7/14 | Cafeteria | managers office | Electrical |
| Sherwood ES (2665) 2A | Request to replace ballast inside room 209 | 5/1/14 | Classroom | room 209 | Electrical |
| Sherwood ES (2665) 2A | Request to deliver three boxes of fluorescent lamps to the school. | 5/19/14 | | for entire school | Electrical |

| | | | | | |
|-----------------------|---|----------|---------------------|------------------|------------|
| Sherwood ES (2665) 2A | POWER OUTAGE - COMPLETE OUTAGE - PM/OLLIE 416-4864 | 6/9/14 | | | Electrical |
| Sherwood ES (2665) 2A | Request to replace one broken receptacle inside kitchen. | 6/12/14 | Cafeteria | kitchen area | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside the principal office. | 6/13/14 | Administration Area | principal office | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of P-59. | 10/16/13 | Portables | P-59 | Electrical |
| Sherwood ES (2665) 2A | Request to replace 3 ballast inside room 206 | 10/21/13 | 2nd Floor | room 206 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 127. | 10/24/13 | Classroom | room 127 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 116. | 10/24/13 | Classroom | room 116 | Electrical |
| Sherwood ES (2665) 2A | Request to replace three ballast inside of room 206. | 10/24/13 | Classroom | room 206 | Electrical |

| | | | | | |
|-----------------------|--|----------|---------------------|--------------|------------|
| Sherwood ES (2665) 2A | Request to replace cord on one of the school metal detectors,one of the prongs has broken off. | 10/24/13 | | | Electrical |
| Sherwood ES (2665) 2A | LIGHTS HAVE NO POWER IN HALL NORTH SIDE 2ND FLR . PLANT MGR-OLLIE/220.7773 | 10/30/13 | | | Electrical |
| Sherwood ES (2665) 2A | The electrical outlet on the southwest wall will not work. | 11/5/13 | 2nd Floor | 218 | Electrical |
| Sherwood ES (2665) 2A | Need the portable bulbs to be changed. Need four Phillips alto 134/835/2p bulbs. | 11/6/13 | Grounds | Portables | Electrical |
| Sherwood ES (2665) 2A | Request to help replace bulbs inside serving line,has a large cover over lights and will need assistance. | 11/7/13 | Cafeteria | serving line | Electrical |
| Sherwood ES (2665) 2A | Request to replace ballast/bulbs in stairwell by room 118/218,will need a lift or extremely long ladder. | 11/7/13 | Stairway | by room 218 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 213. | 11/7/13 | 2nd Floor | room 213 | Electrical |
| Sherwood ES (2665) 2A | *Results for the 2013-14 Annual UL functional test*Location #145-heat detector mechanical room auditorium not working. | 11/7/13 | Administration Area | | Electrical |

| | | | | | |
|-----------------------|--|----------|---------------------|----------------|------------|
| Sherwood ES (2665) 2A | *Results for the 2013-14 Annual UL functional test**Location #203-need batteries in stopper. | 11/7/13 | Administration Area | | Electrical |
| Sherwood ES (2665) 2A | Request to repair outlet inside of room 218,checked all the breaker boxes to see if it was tripped but was unsuccessful. | 11/14/13 | 2nd Floor | room 218 | Electrical |
| Sherwood ES (2665) 2A | Request to replace 3 ballast inside of room 205. | 11/14/13 | 2nd Floor | room 205 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside stairwell by 101. | 11/18/13 | Stairway | by room 101 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 320. | 11/19/13 | 3rd Floor | room 320 | Electrical |
| Sherwood ES (2665) 2A | Request to replace 3 ballast inside room 203 | 11/19/13 | Classroom | Room 203 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of p-61 | 11/19/13 | Portables | P-61 | Electrical |
| Sherwood ES (2665) 2A | Request to replace six spot/flood lights in front of the stage. | 11/19/13 | Cafeteria | Front of stage | Electrical |

| | | | | | |
|-----------------------|--|----------|------------------|----------------------------------|------------|
| Sherwood ES (2665) 2A | Request to replace one ballast inside boys restroom. | 11/22/13 | Restroom (Boys) | by 101 | Electrical |
| Sherwood ES (2665) 2A | Request to replace 3 ballast inside of room 223. | 11/22/13 | 2nd Floor | room 223 | Electrical |
| Sherwood ES (2665) 2A | Request to replace 4 ballast inside the cafeteria. | 12/10/13 | Cafeteria | | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 209. | 1/10/14 | Classroom | room 209 | Electrical |
| Sherwood ES (2665) 2A | Request to replace/repair ballast/fixtures inside of girls restroom by room 205,lights was working one day and off the next,checked breaker boxes. | 1/10/14 | Restroom (Girls) | by room 205 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of boys restroom. | 1/14/14 | Restroom (Boys) | by room 218 | Electrical |
| Sherwood ES (2665) 2A | Request to have 2 boxes of fluorescent and 20 regular 60 watts incandescent bulbs sent to Sherwood Elem. | 1/23/14 | | for the use of the entire school | Electrical |
| Sherwood ES (2665) 2A | Request to replace one broken exit light by back door. | 1/28/14 | Auxiliary Gym | Basement | Electrical |

| | | | | | |
|-----------------------|---|---------|------------------|---------------------------|------------|
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 211. | 1/28/14 | Classroom | Room 211 | Electrical |
| Sherwood ES (2665) 2A | Request to replace/repair one broken receptacle in hallway by room 323. | 1/28/14 | Hallway/Corridor | By room 323 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside stairwell. | 1/29/14 | Annex | 2nd floor back stairwells | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside room 105. | 1/29/14 | Classroom | Room 105 | Electrical |
| Sherwood ES (2665) 2A | HEAT PORT 218-NOT COMING ON-PLANT MGR OLLIER 416-4684 KLR | 2/3/14 | | | Electrical |
| Sherwood ES (2665) 2A | Request outlet be repaired in room 218. | 2/14/14 | | | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of boys restroom | 2/19/14 | Restroom (Boys) | next to room 218 | Electrical |
| Sherwood ES (2665) 2A | request to replace lamps inside the outside fixtures. | 2/19/14 | Portables | 218 | Electrical |

| | | | | | |
|-----------------------|--|---------|---------------------|-------------|------------|
| Sherwood ES (2665) 2A | Request to change time control center to the correct time due to daylight saving time. | 2/24/14 | Administration Area | main office | Electrical |
| Sherwood ES (2665) 2A | POWER OUTAGE IN CAFE PLANT MGR-OLLIE/315.1387 | 2/24/14 | | | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside P-58. | 2/25/14 | Portables | P-58 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 220. | 8/1/13 | 2nd Floor | room 220 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside boys restroom by room 222. | 8/6/13 | Restroom (Boys) | By room 222 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 116. | 8/9/13 | Classroom | 116 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 206. | 8/23/13 | 2nd Floor | room 206 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside the main office. | 8/23/13 | Administration Area | main office | Electrical |

| | | | | | |
|-----------------------|---|---------|-----------|----------------|------------|
| Sherwood ES (2665) 2A | Request to replace one ballast in stairwell by room 213. | 8/23/13 | Stairway | by room 213 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast in stairwell by room 206. | 8/23/13 | Stairway | by room 206 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside the kitchen area. | 9/4/13 | Kitchen | | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 104. | 9/11/13 | 1st Floor | room 104 | Electrical |
| Sherwood ES (2665) 2A | Request to replace two ballast inside of P-217. | 9/11/13 | Portables | P-217 | Electrical |
| Sherwood ES (2665) 2A | Power outage in the CAFETERIA per Mr. Olive, Plant Mgr. 416.4864 | 9/17/13 | | | Electrical |
| Sherwood ES (2665) 2A | Request to have 3 boxes of fluorescent bulbs sent to Sherwood Elem. | 9/18/13 | | for the school | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside teacher lounge. | 9/25/13 | | teacher lounge | Electrical |

| | | | | | |
|-----------------------|--|---------|-----------|---------------------------------|------------|
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 103. | 9/25/13 | Classroom | room 103 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 225. | 7/18/13 | Classroom | rm.225 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 206. | 7/18/13 | Classroom | room 206 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 322. | 7/18/13 | Classroom | room 322 | Electrical |
| Sherwood ES (2665) 2A | Request to replace three missing light covers inside of the cafeteria. | 7/23/13 | Cafeteria | | Electrical |
| Sherwood ES (2665) 2A | Request to replace all outside lights in back of the school,it is extremely dark at night and may allow criminal activity. | 3/17/14 | | back of school around portables | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 116. | 4/17/14 | Classroom | room 116 | Electrical |
| Sherwood ES (2665) 2A | Request to replace one ballast inside of room 106 | 4/25/14 | Classroom | room 106 | Electrical |

| | | | | | |
|-----------------------|--|----------|-----------------|-----------------|---------------------------------------|
| Sherwood ES (2665) 2A | Request to replace two ballast inside boys restroom. | 4/25/14 | Restroom (Boys) | 1st floor annex | Electrical |
| Sherwood ES (2665) 2A | Request to repair leaking air handling unit inside the cafeteria | 4/30/14 | Cafeteria | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | replace/repair system pump | 2/27/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | UNITS NOT COOLING IN RM-214,215 PLANT MGR-OLLIE/220.7773 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Monthly - Oil Lube & Belt-Sherwood Elementary - Refer to PM schedule details. | 6/13/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | A/C PORT 217-NOT COOLING- PLANT MGR OLLIE 416-4864 KLR | 10/24/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Monthly - Filter-Sherwood Elementary - Refer to PM schedule details. | 11/10/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to replace pump one motor inside main boiler room by cafeteria,motor is not working. | 11/12/13 | | boiler room | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|----------|-----------------|--------------------------|---------------------------------------|
| Sherwood ES (2665) 2A | BOILER - NOT COMING ON -- PM/OLLIE 416-7758 | 11/14/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Monthly - Oil Lube & Belt-Sherwood Elementary - Refer to PM schedule details. | 11/15/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to check/repair room 218,209,121 and 103,the rooms are extremely hot and reading well above the set temperature on the thermostat. | 11/19/13 | Classroom | Room 218,209,121 and 103 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | repair boilers | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | AC WINDOW UNIT PORT 58 & PORT 59-BOTH NOT COMING ON-PLANT MGR OLLIE 416-4864 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to service two boilers, boilers have to be reset 1 or 2 times daily causing the building to be very cold often. | 1/12/14 | Mechanical Room | boiler room | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | ENTIRE BLDG IS COLD PER PRIN-DON'T KNOW IF BOILER IS WORKING OR NOT-CALLED IN BY PRIN T MILLER 416-4864 KLR | 1/13/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to repair one leaking fan coil unit inside the teacher lounge. | 1/27/14 | 1st Floor | teacher's lounge | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|--|---------|-----------|----------|---------------------------------------|
| Sherwood ES (2665) 2A | BOILER MECH RM-NOT COMING ON PER FIN SEC-CALLED IN BY FIN SEC LESSURE 416-4864 KLR | 2/5/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to repair one leaking fan coil unit inside of room 121. | 8/1/13 | 1st Floor | room 121 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to repair one leaking fan coil unit inside of room 123. | 8/1/13 | 1st Floor | room 123 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to repair one leaking fan coil unit inside of room 218. | 8/1/13 | Classroom | room 218 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | 6-FCU NOT COOLING IN RM-101,207,211,212,215,221 PLANT MGR-OLLIE/416.4864 | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to repair one leaking fan coil unit inside of room 210. | 8/14/13 | 2nd Floor | room 210 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to replace one broken digital thermostat inside of room 210,its not showing any numbers. | 8/30/13 | Classroom | room 210 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | A/C RMS 215 & 211-BOTH NOT COOLING-PLANT MGR OLLIE 416-4864 KLR | 9/3/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-----------------------|---|---------|-----------|------------------------|---------------------------------------|
| Sherwood ES (2665) 2A | Request to replace one broken digital thermostat inside of room 211, its not showing any numbers. | 9/12/13 | Classroom | room 211 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | A/C RM 211-NOT COOLING-PLANT MGR OLLIE 416-4870 KLR | 9/19/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | CHILLERS ARE NOT COMING ON./ SBE OLLIE 416-4864 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to repair one leaking fan coil unit inside of room 221. | 7/24/13 | 2nd Floor | Room 221 | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to have seasonal changeover done from heat to air. | 4/4/14 | | entire building | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Monthly - Filter-Sherwood Elementary - Refer to PM schedule details. | 7/7/13 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Monthly - Filter-Sherwood Elementary - Refer to PM schedule details. | 3/9/14 | | | Heating/Ventilation /Air Conditioning |
| Sherwood ES (2665) 2A | Request to pressure wash the exterior of the school. | 10/4/13 | | exterior of the school | Painting |

| | | | | | |
|-----------------------|--|---------|------------------|----------------------|----------|
| Sherwood ES (2665) 2A | Request to spot paint interior of the school. | 7/17/13 | | entire building | Painting |
| Sherwood ES (2665) 2A | Request to paint interior of the school. | 10/4/13 | | interior of building | Painting |
| Sherwood ES (2665) 2A | URINAL B RR 2ND GR AREA-CONSTANTLY FLUSHING AND LEAKING PER PRIN-PRIN T MILLER 416-4864 KLR | 4/30/14 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to repair broken water nozzle behind school/boiler room. | 5/6/14 | | | Plumbing |
| Sherwood ES (2665) 2A | 3-COMPARTMENT SINK KITCHEN AREA-FAUCET RUNNING AT MEDIUM FORCE, CAN'T CUT OFF-PLANT MGR OLLIE 416-4684 KLR | 5/16/14 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to replace one flush valve on comode inside girls restroom by rm.217 | 7/17/13 | Restroom (Girls) | by rm217 | Plumbing |
| Sherwood ES (2665) 2A | Request to repair two comodes inside boys restroom,not flushing properly | 7/17/13 | Restroom (Boys) | by rm 325 | Plumbing |
| Sherwood ES (2665) 2A | Per Mr. Ollie 416-4864, there is a grease trap in boiler room backing up and inside the mop closet in the kitchen floor drain stopped up | 10/7/13 | | | Plumbing |

| | | | | | |
|-----------------------|---|----------|---------------------|-----------------------|----------|
| Sherwood ES (2665) 2A | Flush sewer from grease trap | 10/14/13 | | | Plumbing |
| Sherwood ES (2665) 2A | GREASE TRAP STOPPED UP- PLANT MGR OLLIE 416-4864 KLR | 10/25/13 | | | Plumbing |
| Sherwood ES (2665) 2A | grease trap backing upt | 10/30/13 | | | Plumbing |
| Sherwood ES (2665) 2A | There Is a leak coming off the pipe on the south wall In this room . | 11/4/13 | 1st Floor | Rm 100 | Plumbing |
| Sherwood ES (2665) 2A | There Is a leak behind the third commode In this restroom. | 11/6/13 | Restroom (Boys) | Main hall at entrance | Plumbing |
| Sherwood ES (2665) 2A | Request to repair a leaking two compartment sink inside the kitchen area. | 11/19/13 | Cafeteria | kitchen | Plumbing |
| Sherwood ES (2665) 2A | Request to repair leaking comode inside girls restroom,the comode is leaking from the back. | 11/19/13 | Restroom (Girls) | by room 211 | Plumbing |
| Sherwood ES (2665) 2A | Request to repair one clogged comode inside pre-k classroom(room118) | 12/10/13 | 1st Floor | Room 118 | Plumbing |

| | | | | | |
|-----------------------|---|---------|----------------------|-------------------------|----------|
| Sherwood ES (2665) 2A | TOILET HAS OVERFLOW FLOODED IN B/RR 3RD FLR PLANT MGR-OLLIE/315.1387 | 1/8/14 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to repair comode inside girls restroom by room 211,the comode has a steady leak coming from the wall. | 1/10/14 | Restroom (Girls) | by room 211 | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog floor drain inside mop closet inside the kitchen. | 1/16/14 | Kitchen | mop closet | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog one water fountain by cafeteria. | 1/23/14 | Hallway/Corri dor | by cafeteria/breezeway | Plumbing |
| Sherwood ES (2665) 2A | Request to replace broken commode inside the boys restroom,the commode has a 3" to 4" crack in the front and everytime you flush water gets on the floor. | 1/27/14 | Annex | 1st floor boys restroom | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog one water fountain in hallway by room 218. | 1/28/14 | Hallway/Corri dor | By room 218 | Plumbing |
| Sherwood ES (2665) 2A | FLR DRAIN IS BACKING UP IN CAFE PLANT MGR-OLLIE/416.315.1387 | 1/29/14 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog one water fountain in hallway by room 102. | 2/7/14 | 1st Floor | by room 102 | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------------|------------------------------------|----------|
| Sherwood ES (2665) 2A | Request to unclog one water fountain in cafeteria. | 2/19/14 | Cafeteria | | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog one sink inside of room 118. | 8/1/13 | 1st Floor | inside of room 118 | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog one hand sink outside of girls restrooms by room 215. | 8/1/13 | 2nd Floor | outside girls restroom by room 215 | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog mop sink inside custodial closet, tried using the auger but was unsuccessful. | 8/23/13 | Custodial Closet | behind the kitchen | Plumbing |
| Sherwood ES (2665) 2A | Request to repair water fountain that is not coming on. | 8/23/13 | 1st Floor | by elevators/room 118 on 1st floor | Plumbing |
| Sherwood ES (2665) 2A | Request to replace/repair leaking and condensation fan coil unit and pipes inside of rooms 106,101,204,207,208,209,212,214,216,325,220,123,121,221. | 9/6/13 | | 1st and 2nd floor | Plumbing |
| Sherwood ES (2665) 2A | 3RD GRADE HALL SINK IS RUNNING CONTINUOUSLY, CANT CONTROL PLANT MGR-OLLIE/416.4864 | 9/10/13 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to repair one clogged mop sink, use the plunger and was unsuccessful. | 9/12/13 | Custodial Closet | behind the kitchen | Plumbing |

| | | | | | |
|-----------------------|---|---------|------------------|-------------|----------|
| Sherwood ES (2665) 2A | Request to unclog one floor drain in mop closet inside the kitchen. | 9/12/13 | Kitchen | mop closet | Plumbing |
| Sherwood ES (2665) 2A | TOILET FLUSH VALVE IS LEAKING WATER FROM 2ND FLR INTO 1ST FLR LOBBY . PLANT MGR-OLLIE/315.1387 | 9/18/13 | | | Plumbing |
| Sherwood ES (2665) 2A | Kitchen sink is stopped up per Ms. Miller. | 9/20/13 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to replace one leaking flush valve in restroom inside room 118. | 9/25/13 | Classroom | room 118 | Plumbing |
| Sherwood ES (2665) 2A | FLOOR DRAIN STOPPED UP KITCHEN MOP CLOSET-CALLED IN BY PRIN MILLER 416-4864 KLR | 9/27/13 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to replace one comode seat. | 7/18/13 | Restroom (Girls) | by room 222 | Plumbing |
| Sherwood ES (2665) 2A | Request to repair fan coil unit inside of room 207, the unit has a steady leak and is ruining the waxed floors. | 7/23/13 | Classroom | 207 | Plumbing |
| Sherwood ES (2665) 2A | Request to bolt down one very loose commode inside of boys restroom. | 7/23/13 | Restroom (Boys) | By room 325 | Plumbing |

| | | | | | |
|-----------------------|--|---------|-----------|-----------------|----------|
| Sherwood ES (2665) 2A | Request to repair leaking fan coil unit inside of the teachers lounge,the unit is leaking and has destroyed one large shelving unit. | 7/23/13 | 1st Floor | Teachers lounge | Plumbing |
| Sherwood ES (2665) 2A | Back flow test. | 7/24/13 | | | Plumbing |
| Sherwood ES (2665) 2A | HOT WATER TANK NOT RELEASING ANY HOT WATER THRU BLDG. PLANT MGR.-OLLIE/416-4864 | 7/26/13 | | | Plumbing |
| Sherwood ES (2665) 2A | FLR DRAIN IS BACKING UP IN CAFE PLANT MGR-OLLIE/220-7773 | 3/17/14 | | | Plumbing |
| Sherwood ES (2665) 2A | per mr ollie 416-4864 no hot water in the kitchen | 3/20/14 | | | Plumbing |
| Sherwood ES (2665) 2A | Basement sewer backing-up | 3/21/14 | | | Plumbing |
| Sherwood ES (2665) 2A | per Ms. harrison (Asst Principal) in girls restroom water pouring from ceiling (pipe) and last time it flooded classrooms | 4/2/14 | | | Plumbing |
| Sherwood ES (2665) 2A | FOUNTAIN PIPE IS LEAKING WATER BY G/RR 1ST FLR PLANT MGR-OLLIE/315.1387 | 4/2/14 | | | Plumbing |

| | | | | | |
|-----------------------|---|----------|------------------|--------------------------|-------------|
| Sherwood ES (2665) 2A | TOILET CONTINUES TO RUN IN B/RR 5TH GRADE HALL PRIN-MILLER/416.4864 | 4/11/14 | | | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog mop sink inside custodial closet by cafeteria. | 4/25/14 | Custodial Closet | by cafeteria | Plumbing |
| Sherwood ES (2665) 2A | Request to unclog one comode inside girls restroom. | 4/25/14 | Annex | 2nd floor girls restroom | Plumbing |
| Sherwood ES (2665) 2A | Request to repair leaking roof by room 207,the ceiling is leaking in the hallway. | 3/7/14 | 2nd Floor | hallway by 207 | Roof |
| Sherwood ES (2665) 2A | Request to check/repair side room inside the cafeteria.The ceiling has a crack in it and has a steady leak after every rain. | 10/24/13 | 1st Floor | cafeteria | Roof |
| Sherwood ES (2665) 2A | Request to repair leaking ceiling inside of portable p-59.The ceiling is leaking and causing a potential mold problem. | 11/18/13 | Portables | p-59 | Roof |
| Sherwood ES (2665) 2A | Request to repair leak inside of room 116.Workorder number 400345 indicates it has been completed but the same leaks(and now new ones)still exists. | 1/10/14 | Classroom | room 116 | Roof |
| Sherwood ES (2665) 2A | Request repairs be made on portables #217 | 3/17/14 | | portable #217 | Sheet Metal |

| | | | | | |
|-----------------------|--------------------------------------|---------|--|--|-------------|
| Sherwood ES (2665) 2A | request panel be painted. | 3/19/14 | | | Sheet Metal |
| Sherwood ES (2665) 2A | Request decking material be painted. | 3/24/14 | | | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|----------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| South Park ES (2695) | 1 | 1 | 12 | 33 | 24 | 2 | 24 | 5 | 102 |
| Grand Total | 1 | 1 | 12 | 33 | 24 | 2 | 24 | 5 | 102 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|-------------------------|--|---------------|------------------|---------------|-----------|
| South Park ES (2695) 2B | reinsulate the air seperator | 11/4/13 | | | Asbestos |
| South Park ES (2695) 2B | Inter come system in side of the parent resource office 100 L ESL mentor is not working. submitt to Leslie ratliff cscs net work cabling and electronice dept. urgent. | 11/25/13 | 1st Floor | Main office | Cabling |
| South Park ES (2695) 2B | front entry door, cant secure because of lock PLANT MGR- JACKSON/502.4238 | 3/26/14 | | | Carpentry |
| South Park ES (2695) 2B | Glass in side of class room door is broken. urgent. | 8/22/13 | 1st Floor | Time out room | Carpentry |
| South Park ES (2695) 2B | Repair wall in boys restroom. | 9/23/13 | | | Carpentry |
| South Park ES (2695) 2B | front of GYM baseboard needs replace | 9/23/13 | Gym | hallway | Carpentry |
| South Park ES (2695) 2B | The door to the rest room in side the main office is hard to open. urgent. | 10/29/13 | 1st Floor | Main office | Carpentry |

| | | | | | |
|-------------------------|--|----------|-------------|----------------|------------|
| South Park ES (2695) 2B | Door handle on the class room door is broken need to be replaced. urgent. | 10/30/13 | 1st Floor | Band room | Carpentry |
| South Park ES (2695) 2B | There is a hole in the wall need to be repaired. the rest room is on the pre k hall way. urgent. | 11/21/13 | 1st Floor | Boys rest room | Carpentry |
| South Park ES (2695) 2B | The front right out side door is hard to closed. urgent. | 12/17/13 | 1st Floor | Front door | Carpentry |
| South Park ES (2695) 2B | Window scream on room 231 has been put apart (probable attempt to break- in)need reattach. Thanks for your help in this matter. | 6/18/14 | Classroom | 231 | Carpentry |
| South Park ES (2695) 2B | The door to the cafeteria is hard to open. the door is by room 305. urgent. | 4/8/14 | 1st Floor | Cafeteria | Carpentry |
| South Park ES (2695) 2B | Door to room 126 will not lock | 4/22/14 | 1st Floor | Room 126 | Carpentry |
| South Park ES (2695) 2B | The ceiling title in the cafeteria need to be change out, because water leak on the ceiling title. urgent. | 8/1/13 | | cafeteria | Carpentry |
| South Park ES (2695) 2B | Replace parking lot lighting with LED fixtures. | 2/27/14 | Parking Lot | | Electrical |

| | | | | | |
|-------------------------|--|---------|-----------|-------------|------------|
| South Park ES (2695) 2B | The clock fell off the wall because a ball hit the clock, need to be replaced. urgent. | 3/31/14 | 1st Floor | Cafeteria | Electrical |
| South Park ES (2695) 2B | UNIT IN THE MAIN OFFICE COMING ON . SBE JACKSON 416-5024 | 7/12/13 | | | Electrical |
| South Park ES (2695) 2B | The bells in the school are not working. urgent. ID number 057 100. | 7/24/13 | 1st Floor | Main office | Electrical |
| South Park ES (2695) 2B | FIRE ALARM IS MAKING NOISE (101). PLANT MGR-JACKSON/416-5024 | 7/31/13 | | | Electrical |
| South Park ES (2695) 2B | FCU-2 RM 217, FCU-1 RM 218, & FCU-1 RM 234-ALL NOT COMING ON-SBE JACKSON 416-5024 KLR | 8/1/13 | | | Electrical |
| South Park ES (2695) 2B | Fire alarm is showing trouble per Mr. Jackson, Plant Mgr. at 901.416.4488. | 8/6/13 | | | Electrical |
| South Park ES (2695) 2B | Fire alarm is showing trouble per Mr. Jackson, Plant Mgr. at 901.416.4488 | 8/6/13 | | | Electrical |
| South Park ES (2695) 2B | Need 5 cases of fluoresent lights for the class rooms. urgent. | 8/7/13 | 1st Floor | sbe office | Electrical |

| | | | | | |
|-------------------------|---|---------|-----------|----------------|------------|
| South Park ES (2695) 2B | FCU NOT COMING ON IN RM-230 PLANT MGR- JACKSON/416.5024 | 8/23/13 | | | Electrical |
| South Park ES (2695) 2B | Fan Coil unit in room 231 is not working (motor humming)per Mr. Jackson 416-5024 | 8/28/13 | | | Electrical |
| South Park ES (2695) 2B | FCU NOT COMING ON IN RM-115. PLANT MGR- JACKSON/416.5024 | 8/30/13 | | | Electrical |
| South Park ES (2695) 2B | FCU NOT COMING ON IN RM-232 PLANT MGR- JACKSON/416.5024 | 9/3/13 | | | Electrical |
| South Park ES (2695) 2B | BURNING SMELL COMING FROM RM-124 PLANT MGR- JACKSON/416.5024 | 9/10/13 | | | Electrical |
| South Park ES (2695) 2B | replace 10 stage lights | 9/23/13 | 1st Floor | Front Entrance | Electrical |
| South Park ES (2695) 2B | needs lights replace | 9/25/13 | 1st Floor | center hallway | Electrical |
| South Park ES (2695) 2B | OUTLET in the MAIN OFFICE is SMOKING and has a BURNING SMELL per Mr. Jackson, Plant Mgr. 416.5024 | 10/4/13 | | | Electrical |

| | | | | | |
|-------------------------|--|----------|-----------|----------------------|------------|
| South Park ES (2695) 2B | UV NOT COMING ON IN RM-211. PLANT MGR-MILLS/416.2128 | 11/6/13 | | | Electrical |
| South Park ES (2695) 2B | Emergency light is broken need to be replaced. urgent. | 11/21/13 | 1st Floor | Cafeteria | Electrical |
| South Park ES (2695) 2B | AHU-1 SERVES RMS 232 - 305-NOT COMING ON-PLANT MGR JACKSON 416-5024 KLR | 12/17/13 | | | Electrical |
| South Park ES (2695) 2B | Emergency light by the principals office is not working. urgent. | 1/6/14 | 1st Floor | Main office | Electrical |
| South Park ES (2695) 2B | Emergency light by the boys rest room by the main office is not working. urgent. | 1/6/14 | 1st Floor | BY the boys rest rm. | Electrical |
| South Park ES (2695) 2B | Emergency light is not working. urgent. | 1/6/14 | 1st Floor | By room 231 | Electrical |
| South Park ES (2695) 2B | Emergency light is not working. urgent. | 1/6/14 | 1st Floor | By room 221 | Electrical |
| South Park ES (2695) 2B | Emergency light in side the library is not working, on the left side of the front door. urgent | 1/10/14 | 1st Floor | Library | Electrical |

| | | | | | |
|-------------------------|---|---------|-------------|---------------------|------------|
| South Park ES (2695) 2B | Emergency lights by rooms 113 108 is not working. urgent. | 1/10/14 | 1st Floor | By room 113 108 | Electrical |
| South Park ES (2695) 2B | Emergency light in side room 217 is not working. urgent. | 1/10/14 | 1st Floor | Room 217 | Electrical |
| South Park ES (2695) 2B | Emergency light is not working, and also the emergency light in the cafe front lobby area is not working. urgent. | 1/10/14 | 1st Floor | Cafe kitchen | Electrical |
| South Park ES (2695) 2B | Emergency light is not working, and also the emergency in side the nurses station is not working. urgent. | 1/10/14 | 1st Floor | By main office door | Electrical |
| South Park ES (2695) 2B | per mcfarland room 115 a/c not coming on | 5/13/14 | | | Electrical |
| South Park ES (2695) 2B | FIRE ALARM IS IN TROUBLE DUE TO RTU. PRIN -REBECCA/416.5024 | 6/3/14 | | | Electrical |
| South Park ES (2695) 2B | 2 lamp in date closet need ballast replacing. Thanks for your help in this matter. | 6/19/14 | Data Closet | 222 | Electrical |
| South Park ES (2695) 2B | 4-UNITS NOT COMING ON IN RM-115,117,123,220 PLANT MGR- JACKSON/416.5024 | 4/29/14 | | | Electrical |

| | | | | | |
|-------------------------|---|---------|--|--|--|
| South Park ES (2695) 2B | UNIT NOT COOLING IN RM-115,117 PLANT MGR- JACKSON/416.5024 | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Monthly - Filter-South Park Elementary - Refer to PM schedule details. | 5/10/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | per mcfarland 837-2167 room 130 blowing hot | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Monthly - Filter-South Park Elementary - Refer to PM schedule details. | 1/11/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | HEAT MECH RM-NOT COMING ON-PLANT MGR JACKSON 416-5024 KLR | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | FCU RM 123-MAKING NOISES-PLANT MGR JACKSON 416-5024 KLR | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Monthly - Oil Lube & Belt-South Park Elementary - Refer to PM schedule details. | 2/21/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Monthly - Oil Lube & Belt-South Park Elementary - Refer to PM schedule details. | 7/26/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|--|--|---------------------------------------|
| South Park ES (2695) 2B | FCU-2 RM 211, FCU-2 RM 213, FCU-2 RM 215, FCU-2 RM 209, FCU-1 RM 221, FCU-1 RM 229 SOUTH (LIB), VAV RM 232, VAV RM 130, FCU-2 RM 203, & FCU-2 RM 205-ALL NOT COOLING-SBE JACKSON 416-5024 KLR | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Monthly - Filter-South Park Elementary - Refer to PM schedule details. | 9/7/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | RTU NOT COMING ON IN CAFE PLANT MGR- JACKSON/416.5024 | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | AHU-1 & AHU-2-BOTH NOT COOLING-PLANT MGR JACKSON 416-5024 KLR | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | (2) UV MAIN OFC-BOTH NOT COMING ON-PLANT MGR JACKSON 416-5024 KLR | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | RELOCATED THERMOSTAT- PLANT MGR JACKSON 416-5024 KLR | 10/8/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | WTR CIRCULATING PUMP - LEAKING IN THE BOILER RM - PM/DANIEL 282-6675 | 10/23/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | HEAT RMS 221 & 115-ARE OVERHEATING-TEMP IS 81 PER SBE-PLANT MGR JACKSON 416-5024 KLR | 11/13/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|---|----------|-----------|-------------|--|
| South Park ES (2695) 2B | RTU in cafeteria 1 not running AHU #1 won't come on per mr jackson 416-5024 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | RTU in cafeteria 3 are not heating per mr jackson 416- 5024 | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | (4) RTU'S CAFE & AHU-1 CTRLS RMS 232 - 305-ALL NOT COMING ON-PLANT MGR JACKSON 416-5024 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Replace 4 RTU units for cafe/multi -purpose. | 12/18/13 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | Air handle number one in side the boiler room will not come on. urgent. | 12/19/13 | 1st Floor | Boiler room | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | HEAT KITCHEN AREA-NOT HEATING-PLANT MGR JACKSON 416-5024 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | replace coil in rooftop | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| South Park ES (2695) 2B | CONDENSER UNIT NOT COOLING IN Asst.Prin.OFFICE. PLANT MGR- MCFARLAND/416.5024 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------|--|---------|-----------|-----------------|----------|
| South Park ES (2695) 2B | The time room by room 117 need to be painted. urgent. | 4/8/14 | 1st Floor | Time out room | Painting |
| South Park ES (2695) 2B | paint wall in the parry rm | 9/30/13 | | | Painting |
| South Park ES (2695) 2B | Girls rest room by room 226 has two commode in side the rest room that is bad, one commode the flush value is not working the other one is leaking water from the bottom of the commode. urgent. | 3/21/14 | 1st Floor | Girls rest room | Plumbing |
| South Park ES (2695) 2B | GAS SMELL BY MECH RM & RM 305-PLANT MGR JACKSON 416-5024 KLR | 1/29/14 | | | Plumbing |
| South Park ES (2695) 2B | Hand sink has come has been pull down from the wood fram. urgent. | 2/13/14 | 1st Floor | Boys rest room | Plumbing |
| South Park ES (2695) 2B | ICE MACHINE IS LEAKING WATER IN KITCHEN PLANT MGR- JACKSON/416.1250 | 2/25/14 | | | Plumbing |
| South Park ES (2695) 2B | Water fountain has been pull from the wall. urgent. water fountain does not have a id number. | 7/22/13 | 1st Floor | cafeteria | Plumbing |
| South Park ES (2695) 2B | Need a commode seat in side girl rest room by room 117. urgent. | 8/20/13 | 1st Floor | Girls rest room | Plumbing |

| | | | | | |
|-------------------------|--|---------|-----------|------------------|----------|
| South Park ES (2695) 2B | Sink in side of boys rest room the pipe is leaking water. the boys rest room is by the main office. urgent. | 9/3/13 | 1st Floor | Boys rest room | Plumbing |
| South Park ES (2695) 2B | URINAL B RR BY RM 226- HAS BEEN PULLED FROM WALL-SBE HAS WTR CUT OFF, BUT IT'S STILL LEAKING- PLANT MGR JACKSON 416-5024 KLR | 9/13/13 | | | Plumbing |
| South Park ES (2695) 2B | Need a commode seat for the girls rest room by room 115. urgent. | 9/17/13 | 1st Floor | Girls rest room | Plumbing |
| South Park ES (2695) 2B | dish drain leaking from floor | 9/23/13 | Cafeteria | 1st Floor | Plumbing |
| South Park ES (2695) 2B | Girl restroom last sink no running water | 9/25/13 | 1st Floor | front entrance | Plumbing |
| South Park ES (2695) 2B | toilet out of order | 9/25/13 | 1st Floor | Pre -K Hallway | Plumbing |
| South Park ES (2695) 2B | toilet seat needs replace | 9/25/13 | 1st Floor | Principal Office | Plumbing |
| South Park ES (2695) 2B | The commode in side of the girls rest room the flush vaule is broken need to be replaced. urgent. | 10/1/13 | 1st Floor | Pre k hallway | Plumbing |

| | | | | | |
|-------------------------|--|----------|-----------|--------------------|----------|
| South Park ES (2695) 2B | The boys rest room by the main office the urinal is stop up. urgent. | 10/1/13 | 1st Floor | Boys rest room | Plumbing |
| South Park ES (2695) 2B | The urinal in side the boys rest room the flush vaule is broken need to be replaced. urgent. | 11/13/13 | 1st Floor | By the main office | Plumbing |
| South Park ES (2695) 2B | gas smell in rooms 115, 117 per Principal Ms. Dapper 416-5024 (principal said feeling strange) | 12/2/13 | | | Plumbing |
| South Park ES (2695) 2B | The water faucet in the courtyard is not working need to be repaired. urgent. | 5/22/14 | Courtyard | By the main office | Plumbing |
| South Park ES (2695) 2B | FCU - IN TCHR'S WORK RM IN THE MAIN OFC - LEAKING - PM/JACKSON 416-5024 | 5/9/14 | | | Plumbing |
| South Park ES (2695) 2B | FCU TEACHER'S WORKRM- LEAKING-PLANT MGR 416-5024 KLR | 5/7/14 | | | Plumbing |
| South Park ES (2695) 2B | The urinal in side the boys rest room by room 117 is stop up. urgent. | 4/9/14 | 1st Floor | Boys rest room | Plumbing |
| South Park ES (2695) 2B | Flush vaule on commode is broken in side the boys rest room by room 117. urgent. | 4/9/14 | 1st Floor | Boys rest room | Plumbing |

| | | | | | |
|-------------------------|---|---------|-----------|----------------|----------|
| South Park ES (2695) 2B | Boys rest room by room 117 has 3 sink with broken faucet need to be replaced. | 4/22/14 | 1st Floor | boys rest room | Plumbing |
| South Park ES (2695) 2B | The urinal in side the boys rest room by the main office is stop up. urgent. | 5/22/14 | 1st Floor | Boys rest room | Plumbing |
| South Park ES (2695) 2B | Water is leaking from the roof. urgent. | 3/31/14 | 1st Floor | Cafeteria | Roof |
| South Park ES (2695) 2B | Water is leaking from the roof. Urgent. | 7/31/13 | 1st Floor | Main hall way | Roof |
| South Park ES (2695) 2B | Water is leaking from the roof of the cafeteria. urgent. | 8/1/13 | 1st Floor | Cafeteria | Roof |
| South Park ES (2695) 2B | roof leaking in front entrance way soon you walk in the cafeteria / safety hazard | 9/23/13 | Cafeteria | 1st floor | Roof |
| South Park ES (2695) 2B | roof leaking in front entrance way soon you walk in the cafeteria / safety hazard | 9/23/13 | Cafeteria | 1st floor | Roof |

| Count of Craft | Craft | | | | | | | | |
|-----------------|----------|---------|-----------|------------|------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Plumbing | Roof | Sheet Metal | Grand Total |
| ring Academy-Ad | 2 | 3 | 20 | 54 | 41 | 20 | 10 | 1 | 151 |
| Grand Total | 2 | 3 | 20 | 54 | 41 | 20 | 10 | 1 | 151 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|---|---|----------------|---------------------|-----------------------------|-----------|
| Teaching/Learning Academy-Admin (8217) 2B | possible "AMG" in a couple of areas. | 1/22/14 | Administration Area | | Asbestos |
| Teaching/Learning Academy-Admin (8217) 2B | There is a pipe dripping on the electrical panel need to be wrap per Mr. Bo Hurbers, this is for MR. M. Tutton. | 6/12/14 | 1st Floor | TCC TV Studio | Asbestos |
| Teaching/Learning Academy-Admin (8217) 2B | The cabling drop need to be repaired per (Mr. Leslie Ratliff) the customer is Pam Haney. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 2/19/14 | Administration Area | TLA Uppper Level | Cabling |
| Teaching/Learning Academy-Admin (8217) 2B | Computer jack has come out of the wall need to be repaired | 9/16/13 | 1st Floor | Plant Manager Office | Cabling |
| Teaching/Learning Academy-Admin (8217) 2B | Board Work Session Support. (Request Network Cabling Installation Support). | 7/23/13 | | | Cabling |
| Teaching/Learning Academy-Admin (8217) 2B | The rear door to the back parking lot will not secure , have to pull up on it to close it securely. (TCC Building). | 3/19/14 | 1st Floor | Telecommunication Center | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | One of the stall restroom door is not closing properly, it hard to close. | 3/31/14 | Restroom (Girls) | Telecommunication Center | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The No Smoking sign has been vandalize need to be repaired, By the back entrance & the Plant Manager office. | 4/2/14 | | Back Entrance Main Building | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | In the auditorium the threshold plate is coming up, might cause an accident or a tripping fall. (By the storage room.) | 2/17/14 | Auditorium | By the storage room | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The folding doors are loose again in the Auditorium. | 2/24/14 | Auditorium | Folding Doors | Carpentry |

| | | | | | |
|---|---|----------|---------------------|---------------------------------------|-----------|
| Teaching/Learning Academy-Admin (8217) 2B | The Radio Station 88.5 need to have the ceiling tiles replace before the Superintendent comes on 4-4-14 to be on the air, Plant Manager do not have any to replaces them. | 3/12/14 | 2nd Floor | 88.5 Radio Area Ceiling | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The partition in W115 & W116 have come aloose again, you can not close the partitions to separate rooms , it might fall or hurt somebody. | 12/13/13 | 1st Floor | W115 & W116 | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | TEACHER RESOURCE CENTER-CEILING HAS CAVED IN DUE TO A/C LEAK-CALLED IN BY RECEPTIONIST DOUGLASS 416-5930 KLR | 8/2/13 | | | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | CEILING TILE HAS FALLEN IN RM-W109, DUE TO UNIT LEAK . PLANT MGR-MCNEARY/416.5930 | 8/5/13 | | | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The partitions in this room is coming apart, it might fall on someone. (Security purpose). | 10/18/13 | 1st Floor | W115 & W116 | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The threshold need to be repair to prevent the rodent from coming in the building of the Telecommunication Center. | 11/7/13 | 1st Floor | Rear EntranceTelecommunication Center | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The door closure in the radio studio area is broken. | 12/2/13 | 2nd Floor | Radio Area | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The threshold has come off in this room. | 12/5/13 | | Lower level L11 | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The back door to the TV studio need to be weather strip to prevent rodent from coming into the building TV Studio. | 6/9/14 | 1st Floor | TV STUDIO Telecommunication Center | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The Handicap stall door do not close good, lobby area women restroom. Telecommunication Center. | 5/28/14 | Restroom (Girls) | Lobby Restroom Handicap stall | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The desk drawer not closing properly, to secure files. | 2/7/14 | Administration Area | Desk drawer | Carpentry |

| | | | | | |
|---|---|---------|---------------------|---|------------|
| Teaching/Learning Academy-Admin (8217) 2B | A Plank on the dumpster fence has come off, it need to be put back on . | 4/16/14 | Grounds | Dumpster Fence | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The wood molding has come aloose at the bottom, see the Plant Manager for the part. | 6/16/14 | Auditorium | On the side by the chiller side in side | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The front columns are eaten by tremite, the molden at the top of building between the roof & wood trim have rotten out of the building. | 6/16/14 | | TLA Front Entrace | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | Mr. Otto Schlafer, this is from Mrs. Lanza, to have the furniture move from E105 to E101 for Minor Construction office to do it. I was told to do a work order on it an it would be directed t the right place on member. | 9/12/13 | 1st Floor | E101 & E105 | Carpentry |
| Teaching/Learning Academy-Admin (8217) 2B | The bulb has broken in the light fixture, Plant Manager can not get it out to change it. | 3/19/14 | 1st Floor | Custodial Closet | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Ballast out in the storage room. | 3/24/14 | 1st Floor | W113 | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Ballast out in this area @ the door entrance to this .room | 3/31/14 | Administration Area | (1) floor Telecommunication Center | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Ballast out very dark over the desk area, customer can not see in this area. | 4/8/14 | 1st Floor | E104 | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The canopy lights facing Union Ave. Side are not working, very dark, also the light in the back of the building is out too dark for entrance (security reasons). | 2/14/14 | Parking Lot | Telecommunication Center Canopy lights | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The front entrance lights on the porch will not come on, have new bulbs on them and it will not work. | 2/14/14 | 1st Floor | Front Entrance of Union Ave. TLA | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The stairsway has light out, to high to reach by Plant Managers, a ballast in Radio area, very dark in this area. | 2/17/14 | 2nd Floor | Telecommunication Center | Electrical |

| | | | | | |
|---|--|----------|---------------------|-------------------------------------|------------|
| Teaching/Learning Academy-Admin (8217) 2B | The light switch in the room will not cut off at times you can cut the switch off, but the lights still on at times. | 2/19/14 | 2nd Floor | computer room | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | (1). Need a ballast in that light, (2). Main level by coffee machine the recess light keep going out Plant Manager has change (2) lights, time I put the new bulb it blew, it may have a bad connection. | 3/11/14 | Administration Area | Upper Level Ms. Donna Bohannan area | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | A/C TELECOMM DIRECTOR'S OFC-NOT COMING ON-PLANT MGR McNEARY 416-3426 KLR | 9/11/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The outside light on the northeast side of the Auditorium is out very dark need a bulb replace for security reason. | 9/12/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The pole light is out need a bulb in it, need the bucket truck to reach, right in front of the entrance of the building. | 9/13/13 | | Crular Driveway | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | FCU OVER RECEPTIONIST AREA-NOT COMING ON-PLANT MGR McNEARY 416-3426 KLR | 12/11/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The 88.5 signage need some lights in the signage to be seen, will need the bucket truck to reach. | 12/16/13 | | Telecommunication signage | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The lobby lights in the Telecommunication are out in several places, will need u-shape tubes to replace, the ceiling is very tall, will need a lift to reach. | 12/16/13 | | Telecommunication Lobby | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Unit is NOT COMING ON in the Telecommunication Center Lobby per Ms. McNeary, Plant Mgr. 416.3426 | 1/6/14 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | HEAT TELECOMM BLDG RM 211-NOT COMING ON-PLANT MGR McNEARY 416-3426 KLR | 1/8/14 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Ballast out by the Multipurpose room. Very dark in this area. | 7/12/13 | 1st Floor | lower level | Electrical |

| | | | | | |
|---|--|---------|---------------------|--|------------|
| Teaching/Learning Academy-Admin (8217) 2B | Need a reciprocal electrical outlet cover in that area. | 7/19/13 | 1st Floor | W110 west side onMain level | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The canopy light in the front entrance of the Telecommunication Center is out, need a bucket Truck to reach. | 8/7/13 | | Telecommunication Center | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The spot light on the front of the building has a bulb out, need to be replaced. | 8/9/13 | | front driveway by the trees the building | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Remove MCS signs from grounds and off the buildings, need a bucket van. | 8/15/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need ballast replace in the multipurpose room & the upper level office area. | 8/28/13 | | Lower level & Upper | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need light to go on all 3 floors special order, that numbers is 50R30/FL (2423390) (0340/0121/0209) the product are Flood Lights. Need 40 or 50 of the items (lights). | 8/28/13 | | Through out the building | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | FCU NOT COMING ON IN RM-E102 PLANT MGR-NEARY/416.5930 | 8/29/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need a reciprocal electrical outlet covers on the wall (west side) of the room by the windows. | 8/30/13 | 1st Floor | W115 | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Light in vending machine area need ballast, very dark in that area. | 9/23/13 | 1st Floor | Vending Area | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need a ballast in front of the receptionist area dark in this area. | 9/25/13 | 1st Floor | Receptionist area | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The light need a ballast it is on the 2nd floor by the fax machine. | 9/27/13 | Administration Area | Upper Level by the Fax machine | Electrical |

| | | | | | |
|---|---|----------|------------|--|------------|
| Teaching/Learning Academy-Admin (8217) 2B | 2nd request, The northeast side of the Auditorium, outside facing the chiller, they came out last week but it is still not working, very dark in this area. | 9/30/13 | Auditorium | Northeast side of the building | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The light in the front of the signage of the Telecommunication Center need a bulb in it. | 10/4/13 | Auditorium | The frontof the Telecommunication Center | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The ballast is out in room E108. | 10/7/13 | 1st Floor | E108 | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | One of the hook on the Flag Pole has broken, so you can't hang the Flag out. Will need the bucket truck to reach. | 11/4/13 | | Flag Pole | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | NO POWER TO RECEPTACLES IN RM 210 2ND FLR-WILL NEED-PLANT MGR McNEARY 416-3426 KLR | 11/13/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | There are Emergency Lights out though out the both buildings. See (Plant Manager) for the location of the lights. | 12/4/13 | | 2 Buildings all floors | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | in the room where the call center is, 1/2 of the room has no power and no calls can come in per Ms. McNarry 416-3426 | 12/4/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | PHONE CTR RM W111-HAS NO POWER TO RECEPTACLES ON ONE WALL-WILL NEED-PLANT MGR McNEARY 416-3426 KLR | 12/5/13 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need tubes lights (3) diffierent kind of tubes, T12, T8 18 inches F18T8 watts18 K24, U tubes, these are the lights that at the TLA and the other buildings. | 6/9/14 | | All Areas of the (3) Building | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Ballast out in this room, dark at the front of the room. | 5/15/14 | 1st Floor | Lower Level L11 | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | A/C ATTIC AREA SERVES UPPER LEVEL ADMIN AREA-NOT COMIING ON-PLANT MGR McNEARY 416-3426 KLR | 5/21/14 | | | Electrical |

| | | | | | |
|---|--|---------|---------------------|--------------------------|------------|
| Teaching/Learning Academy-Admin (8217) 2B | Need a ballast in light over the desk area of Ms. Amy Nelson in E107. Main Level | 5/30/14 | 1st Floor | E107 by Amy Nelson | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need (2) case of the Fluorescent Lights the number is #F32T8/ADV841/EW- 28 watt - 147348001 | 5/6/14 | 1st Floor | SBE Office | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The emergency light in the hallway upper level across from the Director office is not working. | 4/30/14 | 2nd Floor | Emergency light | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The outlet is shorten out in this room. | 4/30/14 | 1st Floor | W111 | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The Emergency Lights through out the building on both floors need repairs per Risk Management, also the Auditorium too. | 4/31/14 | 1st Floor | Telecommunication Center | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The Ballast out in the area, dark in this area also. | 4/16/14 | Administration Area | Upper Level | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Power lines are down secure equipment and barricade any area of danger. | 4/29/14 | | | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The Emergency Lights are not working it is (3) of them on the upper level area. | 4/29/14 | Administration Area | Upper Level TLA | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Ballast out on the stairsway dark on the steps. | 4/29/14 | Stairway | Northwest side | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The back parking lot, has a light out on the first row near the fence row, will need a bucket truck to reach, or see the Plant Manager for location. | 6/24/14 | Parking Lot | Rear Parking Lot | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | The light is out on the elevator, & the Plant Manager do not have any tubes to change it, it is very dark & for Security purpose too. Telecommunication Center Building. | 6/25/14 | Elevator | Telecommunication Center | Electrical |

| | | | | | |
|---|--|---------|--|---------------------------|---------------------------------------|
| Teaching/Learning Academy-Admin (8217) 2B | Need (3) cases of T12 | 6/17/14 | | All areas | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need (3) cases T8 inches F18T8 watts 18 K24 | 6/17/14 | | All Areas of the Building | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | Need (3) cases of the U- shape lights | 6/17/14 | | All Areas of the Building | Electrical |
| Teaching/Learning Academy-Admin (8217) 2B | A/C RM 112-BLOWING TOO COLD, TEMP IS 68 AND THERMOSTAT IS SET ON 75-PLANT MGR McNEARY 416-3426 KLR | 4/29/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | RTU is NOT COOLING in ROOM W114 per Ms. McNeary, Plant Mgr. 416.3426 | 5/2/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | BOILER is NOT COMING ON per Brenda McNeary, Plant Mgr. 416.3426 | 6/23/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | AHU-5, AHU-6, & AHU-7 UPPER LEVEL-ALL NOT COOLING-PLANT MGR McNEARY 416-3426 KLR | 6/25/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | per ms mcneair 416-3426 the "Pink" building a/c not cooling | 5/1/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | A/C UNIT is NOT COOLING IN THE TELECOMMUNICATION DIRECTOR'S OFFICE per Brenda McNeary, Plant Mgr. 416.3426 | 5/23/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | per ms mcneair 416-3426 room L10 is not cooling (actuator out) | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | UNIT NOT COOLING IN DIRECTOR'S OFFICE PLANT MGR-MCNEARY/416.5930 | 6/2/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---|--|----------|--|-----------------|---------------------------------------|
| Teaching/Learning Academy-Admin (8217) 2B | FAN COIL UNIT is NOT COMING ON in E108 per Ms. McNeary, Plant Mgr. 416.3426 | 6/13/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | FAN COIL UNIT is NOT COOLING in E104 per Ms. McNeary, Plant Mgr. 416.3426 | 6/13/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | FCU NOT COMING ON IN COMPUTER AREA; PLANT MGR-MCNEARY/416.5930 | 12/11/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | The entire buildings need to have the filters change, it has been longer than (3) months, since they have been change. | 1/15/14 | | Entire Building | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | per Brenda 416-3426 the multi-purpose room is overheating | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | per ms mcneary 416-3426 in the lower level multi-purpose room the 2 AHU are blowing too hot (very hot air) | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | per ms mcneary 416-3426 administration part of building upper level is really hot | 3/19/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | UNIT NOT COOLING THRU 2ND FLR PLANT MGR-BANKS/416.5930 | 3/11/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | CHILLER NOT COMING ON. PLANT MGR-MCNEARY/416.5930 | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | HEAT RECEPTIONIST AREA-NOT HEATING PLANT MGR McNEARY 416-3426 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---|--|----------|--|--|---------------------------------------|
| Teaching/Learning Academy-Admin (8217) 2B | CHILLER NOT COMING ON-PLANT MGR McNEARY 416-3426 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | ENTIRE 2ND FLOOR AND TELECOMMUNICATION RM 211 IS NOT COOLING. SBE MCNEARY 416-3426 | 7/3/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | UNIT IN RM E101 IS NOT COOLING. SBE MCNEARY 416-3426 | 7/10/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | 3rd floor administrative dept very hot, no a/c blowing Brenda McNerry 416-3426 | 7/16/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | RTU SERVES RMS 110, 111, 112, & 114-ALL NOT COOLING-SBE McNEARY 416-3426 KLR | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | a/c not cooling in the telecommunications radio area per Ms. McNairy 416-3426 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | A/C ADMINISTRATION AREA-BLOWING TOO COLD-TEMP IS SHOWING 80 PER SBE PLANT MGR McNEARY 416-3426 KLR | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | RTU#10 for rm W111 and AHU#5 heat not working per Ms. McNairy 416-3426 | 10/23/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | HEAT RM W109-NOT HEATING-PLANT MGR McNEARY 416-3426 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | RTU IS OVERHEATING IN RM-W112, & NOT HEATING IN RM-W111 PLANT MGR-MCNEARY/416.5930 | 12/4/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | CHILLER NOT COMING ON-BLDG OVERHEATING-PLANT MGR McNEARY 416-3426 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---|--|---------|-----------|----------------------|---------------------------------------|
| Teaching/Learning Academy-Admin (8217) 2B | CEILING PIPE IS LEAKING WATER IN BREAK RM. PLANT MGR-MCNEARY/416.5953 | 5/28/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | UNIT NOT COMING ON IN TV STUDIO, DIRECTOR OFFICE 2ND FLR PLANT MGR-MCNEARY/416.5930 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | A/C TELECOMM OBSERVATION RM-NOT COOLING-PLANT MGR McNEARY 416-3426 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | The Roof Top Unit #10 is making excesses noise, this unit control 6 rooms | 2/7/14 | 1st Floor | West Side on the TLA | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | THERMOSTAT RM W112-NOT WORKING, CANT CONTROL AIR FLOW-TOO COLD IN RM NOW-PLANT MGR McNEARY 416-3426 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | BOILER is NOT COMING ON per Ms. McNeary, Plant Mgr. 416.3426 | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | Monthly - Filter-Teaching/Learning Academy - Refer to PM schedule details. | 5/24/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | Monthly - Filter-Teaching/Learning Academy - Refer to PM schedule details. | 9/21/13 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | Monthly - Filter-Teaching/Learning Academy - Refer to PM schedule details. | 1/25/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | Monthly - Oil Lube & Belt-Teching Learning Acad. - Refer to PM schedule details. | 4/11/14 | | | Heating/Ventilation /Air Conditioning |
| Teaching/Learning Academy-Admin (8217) 2B | Monthly - Oil Lube & Belt-Teching Learning Acad. - Refer to PM schedule details. | 9/6/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|---|--|----------|------------------|----------------------------|----------|
| Teaching/Learning Academy-Admin (8217) 2B | The drain outside the boiler room is stopped up. | 7/12/13 | 1st Floor | Boiler Room | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | Toilet will not stop flushing. | 7/12/13 | Restroom (Boys) | Lower Level | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | PIPE LEAKING IN MULTIPURPOSE RM ON WIRES AND WATER STANDING IN FLR-LEAD REED 416-3426 KLR | 8/1/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | TEACHER RESOURCE CENTER-A/C LEAKING CAUSED CEILING TO CAVE IN-CALLED IN BY RECEPTIONIST DOUGLASS 416-5930 KLR | 8/2/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | FCU IS LEAKING WATER IN RM-W109 . PLANT MGR-MCNEARY/416.5930 | 8/5/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | Test and/or repair RP devices per MLGW. | 8/21/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | The water in the water fountain is coming out the spout very low unable to get any drinking water from the fountain. | 10/9/13 | | Water Fountain 1st floor | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | The toilet will not stop flushing, it keep running. It is the Handicap stall. | 10/16/13 | Restroom (Girls) | 1st floor (Handicap stall) | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | per Ms. McNairy 416-3426 in the girls restroom the only stall will not flush | 10/25/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | TOILET WONT FLUSH IN LADIES/RR. PLANT MGR-MCNEARY/416.5930 | 10/30/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | COMMODE MENS' RR TCC BLDG-ONLY ONE IN RR-HANDLE BROKE, CAN'T FLUSH- PLANT MGR McNEARY 416-3426 KLR | 11/20/13 | | | Plumbing |

| | | | | | |
|---|---|----------|------------------|------------------------|----------|
| Teaching/Learning Academy-Admin (8217) 2B | Winterize RP device . | 11/22/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | mens restroom toilet can't flush in telecommunications building per Ms. McNerry 416-3426 | 12/2/13 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | PIPE IS LEAKING WATER IN TELLER COMMUNICATION CTR TV STUDIO PLANT MGR-MCNEARY/416.5930 | 6/12/14 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | CONDENSATION LEAKING IN TELECOMM TV STUDIO CAUSING TILE TO FALL-PLANT MGR McNEARY 416-3426 KLR | 5/13/14 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | Need the sprinkler system turn on. | 5/30/14 | Grounds | Sprinkler | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | The toilet in the handicap stall is lose at the base and the floor it need to be repaired. | 1/31/14 | Restroom (Girls) | 1st floor | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | The outside drains are stopped up, need to be cleaned out, so the water will not come back in the building. | 2/4/14 | | Outside drain | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | The handicap toilet is flushing very slowly & the urinal keep flushing. | 2/5/14 | Restroom (Boys) | Lower Level | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | The drain outside the boiler room is stopped up. | 1/31/14 | | | Plumbing |
| Teaching/Learning Academy-Admin (8217) 2B | Leaking in the Hallway on the carpet on the west side of the building. | 2/21/14 | 1st Floor | By W111 in the Hallway | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | It is leaking in the Building on the west side by the window The (middle one). | 7/19/13 | 1st Floor | West side W115 window | Roof |

| | | | | | |
|---|---|----------|-----------|---|-------------|
| Teaching/Learning Academy-Admin (8217) 2B | Roof leak in the Telecommunication center radio area. | 8/9/13 | | | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | WATER COMING FROM WALL IN NORTH-EAST HALL, & STAIRWAY CAUSING TILE FLR TO COME UP IN THIS AREA. PLANT MGR-MCNEARY/416.5930 | 10/16/13 | | | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | It is leaking in 2 area of this room. | 10/16/13 | 1st Floor | Edit room of the Telecommunication Center | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | It is leaking on the stairways from the ceiling. | 11/4/13 | Stairway | Northwest | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | CEILING IS LEAKING WATER ONTO FLR IN GALLERY LOBBY 1ST FLR PLANT MGR-MCNEARY/416.5930 | 6/13/14 | | | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | CEILING IS LEAKING WATER ONTO FLR IN GALLERY LOBBY 1ST FLR PLANT MGR-MCNEARY/416.5930 | 6/13/14 | | | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | ROOF IS LEAKING WATER IN STUDIO EQUIPMENT RM PLANT MGR-BANKS/416.5930 | 6/10/14 | | | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | roof leak in the media room leaking all onto the equipment per Ms. McNeary 416-3426 | 2/4/14 | | | Roof |
| Teaching/Learning Academy-Admin (8217) 2B | The wall heater front cover is broken, need to be replace, can not cover the heater to secure or to prevent injury. | 2/19/14 | 1st Floor | Front entrance Telecommunication Center | Sheet Metal |

| Count of Craft | Craft | | | | | | | | |
|------------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| Treadwell El (2715) 2B | 2 | 6 | 14 | 29 | 62 | 10 | 43 | 3 | 169 |
| Grand Total | 2 | 6 | 14 | 29 | 62 | 10 | 43 | 3 | 169 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|---|----------------|------------------|-------------|----------|
| Treadwell EI (2715) 2B | PIPE IN ROOM 100A IS LEAKING AND NEED TO BE WRAP. | 9/25/13 | | | Asbestos |
| Treadwell EI (2715) 2B | there is a leak look like it coming from around the pipe in ceiling. it is in the annex near front door. Plumber has checked out, some insulation is missing and the pipe appears to be sweating and needs to be insulated. | 6/2/14 | | | Asbestos |
| Treadwell EI (2715) 2B | Provide support and services to Charles White and Security by installing access control on the doors exiting the Elementary side into the cafeteria and on the door from the cafeteria into the middle school. | 9/25/13 | | | Cabling |
| Treadwell EI (2715) 2B | room 86 is having problem with ports. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 10/16/13 | | | Cabling |
| Treadwell EI (2715) 2B | Treadwell EI-- WO379975-- Broken telephone port -- emailed request from teacher Ms feifler (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 8/31/13 | | | Cabling |
| Treadwell EI (2715) 2B | THEY NEED A TELEPHONE IN ROOM 200 IN NURSE STATIONS. | 1/15/14 | | | Cabling |
| Treadwell EI (2715) 2B | THE PHONE IN THE TEACHER LOUNGE NEED TO BE REPAIRED OR REPLACE DOES NOT WORK. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 2/13/14 | | | Cabling |

| | | | | | |
|------------------------|---|---------|-----------------|-----------------------|-----------|
| Treadwell EI (2715) 2B | THE ELEM. SCHOOL NEED 32 INCH TV HUNG IN HALL NEAR OFFICE. (SCS Network Cabling and Electronics dept. does not support this type of request -- "Please See Journal Note") | 2/13/14 | | | Cabling |
| Treadwell EI (2715) 2B | Replace or repair paper towel holder | 7/29/13 | 1st Floor | Girls R/R | Carpentry |
| Treadwell EI (2715) 2B | Replace or repair papertowel holder | 7/29/13 | 2nd Floor | Boys R/R | Carpentry |
| Treadwell EI (2715) 2B | Replace bad tile in front of main office (3 piece) | 7/30/13 | 1st Floor | In front of office | Carpentry |
| Treadwell EI (2715) 2B | Replace missing ceiling tile | 7/30/13 | Cafeteria | Cafe | Carpentry |
| Treadwell EI (2715) 2B | Stall door need be install | 8/5/13 | Restroom (Boys) | 1st Floor | Carpentry |
| Treadwell EI (2715) 2B | THE BOTTOM PART OF THE WOOD DOOR NEED TO BE REPAIRED. | 2/4/14 | Classroom | | Carpentry |
| Treadwell EI (2715) 2B | THE BOTTOM PART OF THE WOOD DOOR IN ROOM 305 NEED TO BE REPAIRED. | 2/4/14 | Classroom | | Carpentry |

| | | | | | |
|------------------------|--|----------|-----------|--|------------|
| Treadwell EI (2715) 2B | THE HANDRAIL IN STAIRWELL ON FIRST FLOOR IS COMMING FROM WALL. | 2/26/14 | | | Carpentry |
| Treadwell EI (2715) 2B | THE FRONT DOOR CLOSURE ON SECURITY DOOR IS BROKEN.IT WILL NOT LET DOOR CLOSE PROPERLY. | 5/1/14 | | | Carpentry |
| Treadwell EI (2715) 2B | THE DOOR FRAME TO A TOILET STALL IS FALLING DOWN. IT NEED TO BE RE ATTACH TO DOOR. | 5/1/14 | | | Carpentry |
| Treadwell EI (2715) 2B | THE BOYS RESTROOM ON THE SECOND FLOOR STALL DOOR NEED REPAIRE | 5/1/14 | | | Carpentry |
| Treadwell EI (2715) 2B | REPLACE THE PLEXIGLASS AT ANNEX BUILDING. | 6/10/14 | | | Carpentry |
| Treadwell EI (2715) 2B | MAIN DOORS GLASS NEED TO BE REPLACED WITH WINDOW TO SEE OUT. | 6/10/14 | | | Carpentry |
| Treadwell EI (2715) 2B | THE FRONT ENTRANCE DOOR IS NOT CLOSING ALL THE WAY.SECURITY DOORS | 5/9/14 | | | Carpentry |
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST IN THESE ROOMS IN THE ANNEX BUILDING ROOM 86 85 90 93 AND 96. | 11/12/13 | Classroom | | Electrical |

| | | | | | |
|------------------------|---|----------|-----------|--|------------|
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST IN THE HALL ON THIRD FLOOR IN ELEM.SCHOOL. THERE IS 1 IN STAIRWELL. | 11/12/13 | | | Electrical |
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST IN THE HALL ON THIRD FLOOR IN ELEM.SCHOOL. THERE IS 1 IN STAIRWELL. | 11/12/13 | 3rd Floor | | Electrical |
| Treadwell EI (2715) 2B | I NEED TWO CASES OF ENERGY EFFICIENT LAMP F32T8. | 11/21/13 | | | Electrical |
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST IN ROOM 107. | 10/30/13 | Classroom | | Electrical |
| Treadwell EI (2715) 2B | THE CLOCKS AT ELEM. SCHOOL NEED TO BE RESET. | 11/4/13 | | | Electrical |
| Treadwell EI (2715) 2B | PARTIAL OUTAGE- RECEPTACLES THRU OUT BLDG HAVE NO POWER PER SBE-PLANT MGR CAIN- 416-6100 KLR | 9/23/13 | | | Electrical |
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST IN ROOM 313.I HAVE CHANGE BULBS. | 10/15/13 | | | Electrical |
| Treadwell EI (2715) 2B | C AN THE CEILING FAN IN ROOM 313 BE REPAIRED IT WANT RUN. *(If the switch on the wall is bad,replace otherwise no).jd | 9/11/13 | | | Electrical |

| | | | | | |
|------------------------|---|----------|-----------|--|------------|
| Treadwell EI (2715) 2B | please repair all clocks in elem.building.they are not working. | 8/21/13 | | | Electrical |
| Treadwell EI (2715) 2B | THERE IS 3 LIGHT FIXTURE IN ROOM 107 THAT IS HANGING NEED TO BE REATTACHED. | 9/4/13 | | | Electrical |
| Treadwell EI (2715) 2B | one of the light ballast in room 107 is bad i have put new bulb in still nothing. | 9/5/13 | | | Electrical |
| Treadwell EI (2715) 2B | TWO CLASSROOM IN THE ANNEX BUILDING DO NOT HAVE POWER TO THE COMPUTERS THEY ARE 96 AND98 CLASSROOM. | 1/7/14 | Classroom | | Electrical |
| Treadwell EI (2715) 2B | BAD BALLAST IN ROOM 83 | 1/15/14 | Classroom | | Electrical |
| Treadwell EI (2715) 2B | UNIT NOT COMING ON RM-87 PLANT MGR-CAIN/416.6100 | 12/3/13 | | | Electrical |
| Treadwell EI (2715) 2B | HEAT ANNEX RM 84-NOT COMING ON-PLANT MGR CAIN 416-6130 KLR | 12/11/13 | | | Electrical |
| Treadwell EI (2715) 2B | THE BALLAST IN THE TEACHER LOUNGE NEED A BALLAST. | 2/12/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|-----------|--|------------|
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST IN ROOM 97 CLOSET. | 2/24/14 | Classroom | | Electrical |
| Treadwell EI (2715) 2B | BAD BALLAST IN ROOM 206 | 3/6/14 | | | Electrical |
| Treadwell EI (2715) 2B | THE FIRE ALARM WENT OFF LAST NIGHT AT ELEM.SAYING WATER SENSOR ON SECOND FLOOR.IT NEED TO BE CHECK OUT. (Water sensor?????? Please | 4/3/14 | | | Electrical |
| Treadwell EI (2715) 2B | NEED A BALLAST IN ROOM 308 | 4/24/14 | | | Electrical |
| Treadwell EI (2715) 2B | NEED A BALLAST IN ROOM 308 | 4/24/14 | | | Electrical |
| Treadwell EI (2715) 2B | bad ballast in room 312 | 4/24/14 | | | Electrical |
| Treadwell EI (2715) 2B | THERE IS A BAD BALLAST ON FIRST FLOOR HALL NEAR ASSIST. PRINCIPAL OFFICE IT IS SMELLING THE WHOLE HALL. | 4/25/14 | | | Electrical |
| Treadwell EI (2715) 2B | A/C ADMINISTRATIVE OFC- NOT COMING ON-PLANT MGR McCAIN 416-6130 KLR | 5/5/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|---------------------|--|---------------------------------------|
| Treadwell EI (2715) 2B | A/C RM 88 & 301-BOTH NOT COMING ON-PLANT MGR McCAIN 416-6130 KLR | 5/7/14 | | | Electrical |
| Treadwell EI (2715) 2B | THE ALARM PANEL IS READING TROUBLE AND KEEP GOING OFF. | 5/7/14 | Administration Area | | Electrical |
| Treadwell EI (2715) 2B | NEED POWER POLES IN ROOM 95 REMOVE THEY ARE STILL HOT. | 5/7/14 | Classroom | | Electrical |
| Treadwell EI (2715) 2B | classroom 84 in the annex heat is not coming on. | 12/9/13 | | | Electrical |
| Treadwell EI (2715) 2B | UNITS are NOT COOLING in the ANNEX per William Cain, Plant Mgr. 416.6130 | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C ENTIRE ANNEX ABOUT (16) RMS-ALL NOT COOLING-PLANT MGR TODD 416-6130 KLR | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR UNIT IN ROOM 301 FAN WILL NOT TURN. | 5/7/14 | 3rd Floor | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR IS NOT WORKING IN THE OFFICE | 6/16/14 | Administration Area | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|------------------|--|---------------------------------------|
| Treadwell EI (2715) 2B | THE OVER HEAD COOLING UNIT IN HALL NEAR STAIRWELL IS LEAKING BADLY. | 4/11/14 | Hallway/Corridor | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Monthly - AirCompress #054 Blr rm Treadwell Elm - Refer to PM schedule details. | 6/7/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | change filters in elem annex | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Monthly - Filter-Treadwell Elementary - Refer to PM schedule details. | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE UNIT ON THE FIRST FLOOR NERE STAIRWELL BY EXIT DOOR TO MIDDLE SCHOOL IS LEAKING WATER ON THE FLOOR. | 4/7/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT ANNEX BLDG-NOT HEATING-PLANT MGR CAIN 416-6130 KLR | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | INDUSTRIAL FANS FOR GYM PER B.SHIPP | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C RM 111-NOT COMING ON-PLANT MGR McCAIN 416-6100 KLR Electricans checked it's running not cooling. | 9/10/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|-----------------|--|---------------------------------------|
| Treadwell EI (2715) 2B | A/C units are NOT COMING ON in the Annex Building, ROOMS 81, 83, 84, 94, 96 and Library per William Cane, Plant Mgr. 416.6130 | 9/27/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C ANNEX ALL CLASSRMS- NOT COOLING-PLANT MGR CAIN 416-6130 KLR | 10/30/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE ASST.PRINCIPAL OFFICE ROOM 113 HAS A BAD LEAK COMING FROM THE DUCT IN CEILING.I HAVE LARGE BUCKET UNDER LEAK. | 11/7/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Monthly - Oil Lube & Belt-Treadwell Elem - Refer to PM schedule details. | 11/9/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT ANNEX BLDG-NOT HEATING-PLANT MGR CAIN 416-6130 KLR | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE STATE BOILER INSPECTOR SAID THAT THE EXPANSION TANK NEED TO BE DRAIN IN THE ANNEX. | 11/15/13 | Mechanical Room | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | BOILER-NOT HEATIG-AFFECTS ENTIRE BLDG-PLANT MGR TODD 416-6100 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C RM 308, 111, & MAIN OFC CONFERENCE RM-ALL NOT COOLING-PLANT MGR CAIN 416-6100 KLR | 9/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Treadwell EI (2715) 2B | UNIT NOT COOLING IN MAIN & PRIN OFFICES. PLANT MGR-CAIN/416.6100 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C IN RMS 94 & 95-BOTH NOT COOLING-PLANT MGR CAIN 416-6130 KLR | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C ANNEX RMS 81, 83, & 84-ALL NOT COOLING-PLANT MGR CAIN 416-6100 KLR | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C units are NOT COOLING in ROOMS 111, 308, and three inside the (3) ROOMS IN THE CONFERENCE AREA per William Cane, Plant Mgr. 416.6130 | 9/27/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | ROOM 109 HAS A BIG LEAK COMING FROM THE AIR UNIT PIPE IN THE CEILING. | 9/30/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | A/C RM 308 & CONFERENCE RM-BOTH NOT COOLING-PLANT MGR McCAIN 416-6100 KLR | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | annex not cooling (entire area) per William Cain 416-6130 | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE ROOM CEILING UNIT IS LEAKING ON THE FLOOR IN CLASS ROOM 109. | 9/16/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Treadwell EI (2715) 2B | A/C RM 308-NOT COOLING- PLANT MGR McCAIN 416- 6130 KLR | 9/18/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Room 303, 313 not cooling per William Cain 416-6100 | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Per William Cain 416-6100 no a/c entire school | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR IN THE ASSISTANT PRINCIPAL IS NOT WORKING. | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR IS NOT WORKING IN THE CONFERENCE ROOM. | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE CONFERENCE ROOM AIR IS NOT WORKING.IT WAS NOT COOLING. | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | wire book closets for a/c to be turned into offices | 8/23/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR IN THE CONFERENCE ROOM IS NOT WORKING AGAIN IT IS RUNNING BUT NOT COOLING. | 9/4/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|--|--|---------------------------------------|
| Treadwell EI (2715) 2B | THE AIR IN ROOM 111 IS NOT COOLING IT IS RUNNING BUT NOT COOLING. | 9/4/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT RM 309 AND LIBRARY ANNEX-BOTH NOT HEATING-PLANT MGR CAIN 416-6130 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Units are NOT HEATING in ROOM 107 and in the CONFERENCE ROOM per Mr. Cain, Plant Mgr. 416.6130 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT LIB OFC 80A-NOT HEATING-PLANT MGR CAIN 416-6130 KLR | 1/15/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | room 83 and 87 blowing cold air per mr cain 416-6130 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | 2-UNITS NOT HEATING IN RM-86,83 PLANT MGR-CAIN/416.6100 | 12/3/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT ANNEX BLDG-NOT HEATING-PLANT MGR TODD 416-61340 KLR | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT LIBRARY-NOT COMING ON-PLANT MGR TODD 416-61340 KLR | 12/5/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|-------|--|--|
| Treadwell EI (2715) 2B | Monthly - AirCompress #054 Blr rm Treadwell Elm - Refer to PM schedule details. | 12/7/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT ANNEX BLDG ABOUT (18) RMS-ALL NOT HEATING-PLANT MGR CAIN 416-6100 KLR | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | UNIT VENT - RM 88 - BLOWING BUT NOT HEATING - PM/CAIN 416- 6100 | 1/21/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | HEAT PRIN'S OFC-UNIT MAKING NOISES-PLANT MGR CAIN 416-6130 KLR | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | the heat in the breakroom is not working.it is not coming on. | 1/24/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE HEATER IN THE PRINCIPAL OFFICE IS MAKING LOUD NOISE AGAIN. | 1/27/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE HEATER IN THE LIBRARY OFFICE 80A IS BLOWING COLD AIR. | 1/28/14 | Annex | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE HEAT IN THE SMALL GYM NEED TO BE FIX .IT IS VERY COLD . | 1/28/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|---------------------|--|---------------------------------------|
| Treadwell EI (2715) 2B | THE HEAT IN THE FINANCE SECRETARY OFFICE IS NOT COMMING ON. | 2/12/14 | Administration Area | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE HEATER IN THE GIRLS RESTROOM ON THE FIRST FLOOR MOTOR SOUND LIKE IT IS LOCKING UP. | 2/27/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR IN THE CLASSROOM 98 IS NOT WORKING PROPERLY THE FAN IS NOT BLOWING STRONG EVAN ON HIGH. THE TEACHER SUFFER FROM ASTHMA IN THAT ROOM. | 4/8/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE AIR IN ROOM 90 IS BLOWING BUT NOT COLD. | 4/10/14 | Annex | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | NEED AIR TURN ON AT ELEM. SCHOOL AND ANNEX TURN ON. | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Monthly - Oil Lube & Belt-Treadwell Elem - Refer to PM schedule details. | 6/7/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Monthly - Filter-Treadwell Elementary - Refer to PM schedule details. | 1/20/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|---------------------|--|---------------------------------------|
| Treadwell EI (2715) 2B | Yearly - Boiler - Treadwell EI - Boiler Rm - Refer to PM schedule details. | 3/30/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | Monthly - Filter-Treadwell Elementary - Refer to PM schedule details. | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell EI (2715) 2B | THE RESTROOM IN THE ANNEX NEED TO BE PAINTED. | 3/19/14 | | | Painting |
| Treadwell EI (2715) 2B | PAINT THE ENTIRE ELEM. SCHOOL OFF WHITE. | 6/10/14 | | | Painting |
| Treadwell EI (2715) 2B | NEED ADDRESS PAINTED ON FRONT OF BUILDING 3538 GIVEN. | 6/10/14 | | | Painting |
| Treadwell EI (2715) 2B | PAINT THE ENTRANCE /EXIT DOORS PAINTED RED. PAINT ENTRANCE DOORS TO AUDITORIUM RED. | 6/10/14 | | | Painting |
| Treadwell EI (2715) 2B | WE NEED PARKING STRIPES NEAR CAFETERIA FOR CARS PARKING. | 11/13/13 | Parking Lot | | Painting |
| Treadwell EI (2715) 2B | NEED TOUCH UP PAINTING ON WALL IN OFFICE. | 10/28/13 | Administration Area | | Painting |

| | | | | | |
|------------------------|---|----------|---------------------|----------------|----------|
| Treadwell EI (2715) 2B | Pipe leaking water,pipe need to be insulated. | 7/30/13 | Administration Area | Principal Off. | Painting |
| Treadwell EI (2715) 2B | Restripe parking lot, and assign principal, 2 asst principal parking,plant manager | 7/30/13 | Grounds | Grounds | Painting |
| Treadwell EI (2715) 2B | NEED PLACES ON PARKING LOT IN FRONT OF ELEM.BUILDING MARK FOR ADMINSTRATOR PARKING. | 8/14/13 | | | Painting |
| Treadwell EI (2715) 2B | WE NEED PARKING LOT AREA STRIPE ONE FOR PRINCIPAL ONE FOR VICE PRINCIPAL AND TWO FOR RESERVE. | 6/26/14 | | | Painting |
| Treadwell EI (2715) 2B | THE BOYS RESTROOM IN THE ANNEX HAVE 2 URINALS NOT FLUSHING. | 11/7/13 | Restroom (Boys) | | Plumbing |
| Treadwell EI (2715) 2B | THERE IS A WATER FOUNTAIN ON SECOND FLOOR WHEN YOU PUSH FOR WATER IT COMES OUT JUST HIGH ENOUGH TO WET FLOOR. | 11/7/13 | Hallway/Corridor | | Plumbing |
| Treadwell EI (2715) 2B | FOUNTAIN IS LEAKING WATER IN 1ST FLR HALL. PLANT MGR-CAIN/416.6100 | 11/8/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE SMALL URINAL IN BOYS RESTROOM SECOND FLOOR IS STOP UP. | 11/18/13 | Restroom (Boys) | | Plumbing |

| | | | | | |
|------------------------|--|----------|------------------|-----------|----------|
| Treadwell EI (2715) 2B | THE WATER FOUNTAIN IS NOT DRAINING. | 11/20/13 | Hallway/Corridor | | Plumbing |
| Treadwell EI (2715) 2B | need plumber at the elem. school water from water fountain running in hall | 11/4/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE OUTSIDE CLOSET NEXT TO CAFETERIA ENTRANCE HOT WATER WANT CUT OFF THE HANDLE IS STRIPED. | 10/3/13 | | | Plumbing |
| Treadwell EI (2715) 2B | OVER IN THE ANNEX BUILDING THE BOYS RESTROOM THE SMALLEST URINAL IN RESTROOM IS STOP UP. | 10/15/13 | | | Plumbing |
| Treadwell EI (2715) 2B | ONE OF THE SINKS IN GIRLS RESTROOM IS STOP UP. I HAVE TRYED THE PLUNGER BUT STILL STOP UP. | 10/23/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE SUNK PUMP IN THE BOILER ROOM DO NOT WORK PROPERLY IT DOES NOT RUN WHEN IT SHOULD AT TIMES. | 9/11/13 | | | Plumbing |
| Treadwell EI (2715) 2B | Tiolet stop up | 7/1/13 | 1st Floor | Girls R/R | Plumbing |
| Treadwell EI (2715) 2B | 3rd toilet from the wall,leaking from base of toilet | 7/22/13 | Restroom (Boys) | 2nd Floor | Plumbing |

| | | | | | |
|------------------------|---|---------|-------|----------|----------|
| Treadwell EI (2715) 2B | Flaucet in boys restroom continue to run,will not cut off. | 7/22/13 | Gym | Boys R/R | Plumbing |
| Treadwell EI (2715) 2B | Urinal leaking | 7/29/13 | Annex | Boys R/R | Plumbing |
| Treadwell EI (2715) 2B | ROOM 109 HAS A ROOF LEAK IT SEEMS TO BE COMING FROM BATHROOM ABOVE CLASSROOM. | 8/9/13 | | | Plumbing |
| Treadwell EI (2715) 2B | a/c 2nd and 3rd floor and cafeteria has no a/c per William Cain 416-6100 (called in Monday but couldn't get w/o at that time) | 8/13/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE GIRLS RESTROOM ON FIRST FLOOR HAS A BROKEN SEAT AND TWO SINKS IS NOT WORKING NO WATER. | 8/15/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE GIRLS AND BOYS RESTROOM ON SECOND FLOOR SINKS IS NOT WORKING NO WATER. | 8/15/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE BOYS RESTROOM ON FIRST FLOOR HAS YWO SINKS NOT WORKING. | 8/15/13 | | | Plumbing |
| Treadwell EI (2715) 2B | one of the toilets in the girls restroom on first floor is leaking. the toilet is cracked. | 8/20/13 | | | Plumbing |

| | | | | | |
|------------------------|---|----------|------------------|--|----------|
| Treadwell EI (2715) 2B | ONE OF THE BOYS URINAL IN THE ANEX AREA IS LEAKING WHEN FLUSH. | 8/21/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE WATER FOUNTAN ON FIRST FLOOR AND SECOND FLOOR IS STOP UP. | 8/23/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE BOYS RESTROOM ON SECOND FLOOR THE LAST TOILET ON RIGHT NEED TO BE REPAIRED QUICKLY.IT HAS BEEN USED AND NO WATER IS COMING INTO THE TOILET. | 12/17/13 | Restroom (Boys) | | Plumbing |
| Treadwell EI (2715) 2B | the water fountain on second floor is leaking bad. | 12/13/13 | Hallway/Corridor | | Plumbing |
| Treadwell EI (2715) 2B | IN THE GIRLS RESTROOM ON SECOND FLOOR THE TOILETS NEED TO BE BOLTED TO FLOOR STALL 2 AND 4. BOLTS ARE BROKEN. | 12/13/13 | Restroom (Girls) | | Plumbing |
| Treadwell EI (2715) 2B | ONE OF THE TOILET IN THE GIRLS RESTROOM IS LEAKING WATER ON THE FLOOR IT NEED TO BE ATTACH TO THE FLOOR. | 1/27/14 | Restroom (Girls) | | Plumbing |
| Treadwell EI (2715) 2B | Fountain leaking can't cut off. | 2/12/14 | 3rd Floor | | Plumbing |
| Treadwell EI (2715) 2B | ONE OF THE TOILETS IN BOYS RESTROOM NEED A FLUSH KIT. | 2/24/14 | Annex | | Plumbing |

| | | | | | |
|------------------------|--|---------|------------------|--|----------|
| Treadwell EI (2715) 2B | THE FAUCET IN BOILER ROOM NEXT TO CAFETERIA WANT CUT OFF. | 2/27/14 | | | Plumbing |
| Treadwell EI (2715) 2B | THE WATER FOUNTAIN ON THE FIRST FLOOR WANT CUT OFF. | 3/17/14 | 1st Floor | | Plumbing |
| Treadwell EI (2715) 2B | THE GIRLS RESTROOM ON FIRST FLOOR HAS TWO SINK STOP UP. | 4/7/14 | Restroom (Girls) | | Plumbing |
| Treadwell EI (2715) 2B | ONE OF THE TOILET IN THE BOYS RESTROOM IN THE ANNEX NEED A FLUSH KIT. | 3/19/14 | | | Plumbing |
| Treadwell EI (2715) 2B | ONE OF THE SINKS ON FIRST FLOOR GIRLS RESTROOM IS STOP UP. | 5/1/14 | | | Plumbing |
| Treadwell EI (2715) 2B | THE WATER FOUNTAIN ON SECOND FLOOR IS STOP UP. | 5/7/14 | | | Plumbing |
| Treadwell EI (2715) 2B | THE WATER FOUNTAIN IN THE ANNEX PUSH BUTTON IS BROKE. | 5/20/14 | Hallway/Corridor | | Plumbing |
| Treadwell EI (2715) 2B | BOTH WATER FOUNTAIN AT THE ANNEX RESTROOM IS NOT WORKING WATER IS NOT COMMING OUT. | 5/21/14 | Annex | | Plumbing |

| | | | | | |
|------------------------|---|----------|------------------|--|----------|
| Treadwell EI (2715) 2B | IN ROOM 82 IN ANNEX BUILDING THERE IS A AC DRAIN STOP UP AND IT IS GIVING OFF AND FOUL ODOR. | 6/12/14 | | | Plumbing |
| Treadwell EI (2715) 2B | CHILLER PIPE IS LEAKING WATER IN ANNEX LOBBY PLANT MGR-CAIN/416.6100 | 6/16/14 | | | Plumbing |
| Treadwell EI (2715) 2B | TWO SINKS IN GIRLS RESTROOM ON FIRST FLOOR IS STOP UP. | 5/13/14 | Restroom (Girls) | | Plumbing |
| Treadwell EI (2715) 2B | THE MOP CLOSET ON THIRD FLOOR SINK IS STOP UP. | 5/15/14 | 3rd Floor | | Plumbing |
| Treadwell EI (2715) 2B | THE GIRLS RESTROOM ON SECOND FLOOR HAS A TOILET THAT IS LEAKING WATER. | 5/14/14 | Restroom (Girls) | | Plumbing |
| Treadwell EI (2715) 2B | PIPE IN CEILING 1ST FLR HALLWAY-LEAKING WHERE CAPPED OFF AT-PLANT MGR TODD 416-6100 KLR | 11/25/13 | | | Plumbing |
| Treadwell EI (2715) 2B | THE WATER FOUNTAIN ON THIRD FLOOR NEED TO BE REPAIRED OR REPLACE IT WAS LEAKING WATER FROM UNDER THE BOTTOM SO BAD I HADE TO CUT THE WATER OFF. | 2/12/14 | | | Plumbing |
| Treadwell EI (2715) 2B | there is a leak in room 100A ROOF LEAK. | 9/13/13 | | | Roof |

| | | | | | |
|------------------------|---|---------|-------|--|------|
| Treadwell EI (2715) 2B | THERE IS A ROOF LEAK IN THE ANNEX BUILDING NEAR FRONT DOOR. | 6/2/14 | | | Roof |
| Treadwell EI (2715) 2B | THERE IS A BAD ROOF LEAK IN HALL BY ENTRANCE DOOR. | 5/12/14 | Annex | | Roof |

| Count of Craft | Craft | | | | | | | | Grand Total |
|------------------------|----------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Treadwell MS (2723) 2B | 4 | 54 | 81 | 84 | 12 | 85 | 5 | 3 | 328 |
| Grand Total | 4 | 54 | 81 | 84 | 12 | 85 | 5 | 3 | 328 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|------------------------|--|----------------|------------------|-------------------|-----------|
| Treadwell MS (2723) 2B | refinish stage | 4/17/14 | Auditorium | stage area | Asbestos |
| Treadwell MS (2723) 2B | Pipe leaking through insulation in rm 166 | 8/1/13 | 1st Floor | 166 inside rm 139 | Asbestos |
| Treadwell MS (2723) 2B | need gym floor refinished. | 9/30/13 | | | Asbestos |
| Treadwell MS (2723) 2B | NEED WALL IN ARMORY REPAIRED. | 9/30/13 | | | Asbestos |
| Treadwell MS (2723) 2B | weld legs on soccer goal | 12/13/13 | | | Carpentry |
| Treadwell MS (2723) 2B | Install metal grates on all outside first floor windows | 7/29/13 | Grounds | Outside windows | Carpentry |
| Treadwell MS (2723) 2B | FRONT ENTRANCE DOOR-LATCH NOT CATCHING-WON'T BE ABLE TO SECURE-PLANT MGR CAIN 416-6100 KLR | 8/30/13 | | | Carpentry |
| Treadwell MS (2723) 2B | NEED GLASS PUT BACK IN 3 DOORS IN GYM. | 9/5/13 | | | Carpentry |

| | | | | | |
|------------------------|---|---------|--|--|-----------|
| Treadwell MS (2723) 2B | NEED CEILING TILE GRID IN WEIGHT ROOM. | 9/5/13 | | | Carpentry |
| Treadwell MS (2723) 2B | I NEED HASP LOCK PLACE ON ACCESS DOORS IN LOCKER ROOM AND SHOWER AREA IN GYM. | 9/6/13 | | | Carpentry |
| Treadwell MS (2723) 2B | NEED TO HAVE STRIPES OF WOOD REPLACED ON BLEACHERS IN GYM. | 9/9/13 | | | Carpentry |
| Treadwell MS (2723) 2B | NEED TO HAVE 2 LONG BOARDS REATTACH TO WALL IN GYM. | 9/9/13 | | | Carpentry |
| Treadwell MS (2723) 2B | CEILING TILES NEED TO BE REPLACE IN ROOM 107 | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | THE CLASSROOM DOOR IN 315 NEED TO BE REPAIRED. | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | THERE IS 8 STAINED CEILING TILES IN ROOM. | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | CEILING TILES NEED TO BE REPLACED THEY ARE DISCOLORED. | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | 6 CEILING TILES NEED TO BE CHANGE IN ROOM 310 | 8/14/13 | | | Carpentry |

| | | | | | |
|------------------------|---|---------|---------------------|-------------------------|-----------|
| Treadwell MS (2723) 2B | REPLACE CEILING TILES IN ROOM 304. | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | REPLACE CEILING TILES IN LIBRARY STORAGE ROOM. | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | ROOM 121 NEED DRY WALL REPAIRED. | 8/16/13 | | | Carpentry |
| Treadwell MS (2723) 2B | Breakin repair windows and doors. | 8/21/13 | Cafeteria | | Carpentry |
| Treadwell MS (2723) 2B | Replace broke tile under waterfountain. | 7/31/13 | 1st Floor | By Boys R/R | Carpentry |
| Treadwell MS (2723) 2B | Replace water stain ceiling tile | 7/3/13 | Administration Area | | Carpentry |
| Treadwell MS (2723) 2B | Install view windows in doors. | 7/12/13 | 1st Floor | Room,s 123,124 | Carpentry |
| Treadwell MS (2723) 2B | Replace outside door rusted out. | 7/19/13 | Stairway | Northside 1st fir. Exit | Carpentry |
| Treadwell MS (2723) 2B | Replace Door vener damaged and the core is exposed. | 7/24/13 | 2nd Floor | Room 207 | Carpentry |

| | | | | | |
|------------------------|--|----------|---------|---------------|-----------|
| Treadwell MS (2723) 2B | Door sweeps on each exterior door that don't have one to try to keep mice and rodents out. | 8/7/13 | Grounds | Exterior Door | Carpentry |
| Treadwell MS (2723) 2B | NEED BROKEN FLOOR TILES REPLACED IN HALL AND CLASSROOMS. | 8/14/13 | | | Carpentry |
| Treadwell MS (2723) 2B | THE PRINCIPAL WANT A WALL BUILT IN THE ARMORY TO COVER GUN RANGE WALL. | 9/25/13 | | | Carpentry |
| Treadwell MS (2723) 2B | WE NEED SHEET ROCK REPAIRED AND REPLACED IN ARMORY. | 9/26/13 | | | Carpentry |
| Treadwell MS (2723) 2B | SOME OF THE WALKING AREA IN THE GYM BLEACHERS NEED TO BE REPLACED. THERE IS HOLES IN FLOOR BOARDS. | 10/1/13 | | | Carpentry |
| Treadwell MS (2723) 2B | REPAIR COVE BASE IN COACH OFFICE IN GYM. | 11/21/13 | | | Carpentry |
| Treadwell MS (2723) 2B | REPAIR OUTSIDE EXIT DOOR IN BOYS LOCKER ROOM. AND WOODEN DOOR ACROSS FROM COACH OFFICE. | 11/21/13 | | | Carpentry |
| Treadwell MS (2723) 2B | NEED KEY BOX INSTALLED IN PLANT MANGERS. | 11/21/13 | | | Carpentry |
| Treadwell MS (2723) 2B | THERE IS STILL SOME BAD SPOTS IN BLEACHERS THAT NEED TO BE REPAIRED. | 11/4/13 | | | Carpentry |

| | | | | | |
|------------------------|---|----------|------------------|--|-----------|
| Treadwell MS (2723) 2B | THERE IS A WOODEN DOOR IN GYM WITH A LARGE HOLE IN IT WHERE DOOR KNOB USED TO BE. IT NEED TO BE REPAIRED. | 11/5/13 | Gym | | Carpentry |
| Treadwell MS (2723) 2B | THE CLASSROOM DOOR TO ROOM 123 IS COMING OFF HINGE. | 11/8/13 | Hallway/Corridor | | Carpentry |
| Treadwell MS (2723) 2B | REPAIR STEPS IN GYM ON BLEACHERS. | 10/18/13 | | | Carpentry |
| Treadwell MS (2723) 2B | THE HALL IN GYM NEAR DOOR NEED BASEBOARD. | 10/18/13 | | | Carpentry |
| Treadwell MS (2723) 2B | REPLACE BROKEN WINDOW IN ROOM 137. | 1/9/14 | Classroom | | Carpentry |
| Treadwell MS (2723) 2B | REPAIR WINDOW TRACK IN ROOM 137 SO WINDOW CAN GO UP OR DOWN. | 1/9/14 | | | Carpentry |
| Treadwell MS (2723) 2B | REPLACE BROKEN WINDOW IN ROOM 129. | 1/9/14 | Classroom | | Carpentry |
| Treadwell MS (2723) 2B | REATCH WHITE BOARD TO WALL. | 1/9/14 | | | Carpentry |
| Treadwell MS (2723) 2B | NEED TO HAVE BOARDS REPAIRED IN AUDITORIUM STAGE.THEY IS GETTING READY TO REFINISH STAGE FLOOR BUT NEED SOME BAD FLOOR BOARDS REPAIRED. | 4/21/14 | Auditorium | | Carpentry |

| | | | | | |
|------------------------|--|----------|-----------|---------------------------|-----------|
| Treadwell MS (2723) 2B | WE NEED TO HAVE SAFETY MATS HUNG IN GYM BEFORE BASKETBALL START. | 9/17/13 | | | Carpentry |
| Treadwell MS (2723) 2B | THE AUDITORIUM STAGE NEED TO BE REPAIRED. THE MENS WHO IS GOING TO SAND AND RECOAT THE FLOOR SAID THAT THE WRONG FILLER WAS USED. THEY CANT DO THE FLOOR UNTIL IT IS REPAIRED WITH WOOD FILLER OR REPAIR THE | 5/12/14 | | | Carpentry |
| Treadwell MS (2723) 2B | Weld soccer goals for Grounds Dept. | 12/12/13 | | | Carpentry |
| Treadwell MS (2723) 2B | WE NEED BASE COVE IN ROOM 121 ALL AROUND THE ROOM. | 1/23/14 | | | Carpentry |
| Treadwell MS (2723) 2B | HAND RAIL HAS COME OFF WALL IN STAIRWELL ON THIRD FLOOR. | 1/28/14 | | | Carpentry |
| Treadwell MS (2723) 2B | DOOR DRAGGING FOOR | 2/20/14 | 2nd Floor | RM.221 COMPUTER LAB | Carpentry |
| Treadwell MS (2723) 2B | THERE IS A WINDOW IN THE WOOD FLOOR GYM THAT IS ABOUT TO FALL OUT. | 2/26/14 | | | Carpentry |
| Treadwell MS (2723) 2B | FRONT ENTRY DOOR, CANT SECURE PLANT MGR-TODD/416.6100 | 3/17/14 | | | Carpentry |
| Treadwell MS (2723) 2B | THE EXIT DOOR ON THE SECOND FLOOR LEADING TO THE ROOF WILL NOT CLOSE ON IT ON. | 3/28/14 | | | Carpentry |

| | | | | | |
|------------------------|---|---------|---------------------|---------------|------------|
| Treadwell MS (2723) 2B | one of the window frame in room 107 is about to come completely out. | 4/2/14 | Classroom | | Carpentry |
| Treadwell MS (2723) 2B | THE WOODEN DOOR IN THE GYM NEED TO BE REPAIRED SO IT CAN LOCK. | 4/7/14 | | | Carpentry |
| Treadwell MS (2723) 2B | Window glass in rm#130 is completely broken out | 7/15/13 | | | Carpentry |
| Treadwell MS (2723) 2B | 30 Door Stops for middle school) per principal request) | 8/7/13 | Administration Area | Plant Manager | Carpentry |
| Treadwell MS (2723) 2B | THE DOORS ON THE NORTH SIDE OF BUILDING IS RUSTED AND ROTTEN AND NEED TO BE REPLACED. | 9/18/13 | | | Carpentry |
| Treadwell MS (2723) 2B | A/C RM 135 1ST FLR-NOT COMING ON-PLANT MGR CAIN 41606100 KLR | 8/30/13 | | | Electrical |
| Treadwell MS (2723) 2B | CLOCK NOT WORKING IN GYM 1 AND GYM 2. | 9/5/13 | | | Electrical |
| Treadwell MS (2723) 2B | NEED HIGH CEILING LIGHTS IN BOYS LOCKER AND SHOWER ROOM. | 9/5/13 | | | Electrical |
| Treadwell MS (2723) 2B | need 4 cases of light bulbs some to complete the project in the gym. | 9/6/13 | | | Electrical |

| | | | | | |
|------------------------|--|---------|------------------|----------------|------------|
| Treadwell MS (2723) 2B | NEED EXIT LIGHTS REPAIRED IN GYM. | 9/6/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE CLOCK IN THE CAFETERIA IS NOT WORKING NEED TO BE REPAIRED. | 8/19/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHTS ON STAGE IN THE THEATER ARE BURNED OUT AND NEED TO BE REPLACED. | 8/27/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHTS IN THE ELEVATOR NEED TO BE REPAIRED. | 8/28/13 | | | Electrical |
| Treadwell MS (2723) 2B | Disconnect wiring from boilers to be repaired. | 8/28/13 | Mechanical Room | | Electrical |
| Treadwell MS (2723) 2B | UV NOT COMING ON IN RM-129(158). PLANT MGR-MURDOCK/416.6100 | 7/29/13 | | | Electrical |
| Treadwell MS (2723) 2B | UNIT IN THE MAIN OFFICE IS NOT COMING ON .SBE MURDOCK 416-6100 | 7/29/13 | | | Electrical |
| Treadwell MS (2723) 2B | Restroom light will not come on,ballast bad. | 7/29/13 | 2nd Floor | Teacher Lounge | Electrical |
| Treadwell MS (2723) 2B | Lights out just pass main foyer. | 7/11/13 | Hallway/Corridor | | Electrical |

| | | | | | |
|------------------------|---|---------|------------------|--|------------|
| Treadwell MS (2723) 2B | Carpenters repairing seats can not turn the lights on. | 7/12/13 | Auditorium | | Electrical |
| Treadwell MS (2723) 2B | Light switch in hall near principal office will not turn on or off ,it was repaired last week | 7/15/13 | | | Electrical |
| Treadwell MS (2723) 2B | Make necessary repairs to address Ms McBride's safety concerns in science labs. per os | 7/16/13 | | | Electrical |
| Treadwell MS (2723) 2B | Install hasps for pad locks on all electrical panel not already so equiped. Also on any chase panels. | 7/16/13 | | | Electrical |
| Treadwell MS (2723) 2B | Fire alarm panel is in trouble. | 7/16/13 | | | Electrical |
| Treadwell MS (2723) 2B | Check clocks repair or replace with battery clocks. | 7/18/13 | Hallway/Corridor | | Electrical |
| Treadwell MS (2723) 2B | Install two battery clocks in Auditorium. | 7/18/13 | | | Electrical |
| Treadwell MS (2723) 2B | Repair or replace lights in both gyms as needed. | 7/22/13 | | | Electrical |
| Treadwell MS (2723) 2B | Exhaust fan on the northend westside of main gym not running, make necessary repairs. | 7/22/13 | | | Electrical |

| | | | | | |
|------------------------|--|----------|--|--|------------|
| Treadwell MS (2723) 2B | BREAKER BOX FAILURE IN BOILER RM. PLANT MGR-CAIN/416.6100 | 8/12/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHT IN ROOM 146 HAS A BAD BALLAST. | 9/20/13 | | | Electrical |
| Treadwell MS (2723) 2B | NEED TWO CASES OF ENERGY EFFICIENT T8. | 9/20/13 | | | Electrical |
| Treadwell MS (2723) 2B | PARTIAL OUTAGE-RECEPTACLES THRU OUT BLDG HAVE NO POWER PER SBE-PLANT MGR CAIN-416-6100 KLR | 9/23/13 | | | Electrical |
| Treadwell MS (2723) 2B | A/C NOT COMING ON FROM PLANT MGR'S OFC TO RM 129 1ST FLR PER SBE-PLANT MGR CAIN-416-6100 KLR | 9/23/13 | | | Electrical |
| Treadwell MS (2723) 2B | 1st floor on left side of hallway rooms 124 - 146 a/c is not working at all per Mr. Cain 416-6100 | 9/23/13 | | | Electrical |
| Treadwell MS (2723) 2B | a/c not working in cafeteria per Mr. Cain 416-6100 | 9/23/13 | | | Electrical |
| Treadwell MS (2723) 2B | attendance office a/c not coming on per Mr. Cain 416-6100 | 9/30/13 | | | Electrical |
| Treadwell MS (2723) 2B | boiler in gym mechanical room - there is smoke or steam coming from it per William Cain 416-6100 | 11/14/13 | | | Electrical |

| | | | | | |
|------------------------|--|----------|-----------|--|------------|
| Treadwell MS (2723) 2B | Need an electrician to assist in speak/strobe repair in the gym. | 11/14/13 | | | Electrical |
| Treadwell MS (2723) 2B | Need an electrician to assist in relocation of a smoke detector and repair of Speaker/Strobe Units in Gym. (Eric Gooch) | 11/14/13 | | | Electrical |
| Treadwell MS (2723) 2B | NEED TWO CASES OF F32T8 ENERGY EFFICIENT LAMPS | 11/21/13 | | | Electrical |
| Treadwell MS (2723) 2B | THERE IS A BAD BALLAST IN ROOM 110. | 11/21/13 | Classroom | | Electrical |
| Treadwell MS (2723) 2B | THERE IS A BAD LIGHT SWITCH IN ROOM 309. IT WORKS SOMETIMES AND SOME TIMES IT WANT. | 11/21/13 | Classroom | | Electrical |
| Treadwell MS (2723) 2B | THE CLOCKS AT THE SCHOOL NEED TO BE RESET. | 11/4/13 | | | Electrical |
| Treadwell MS (2723) 2B | WE NEED TIME CLOCK IN GYM AND REG.CLOCKS REPAIRED. WE HAVE A GAME ON THE 18TH. | 11/6/13 | Gym | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHT BALLAST IN SECOND FLOOR HALL HAVE A BAD END. | 10/16/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHT IN STAIRWELL SECOND FLOOR HAS A BAD BALLAST. | 10/16/13 | | | Electrical |

| | | | | | |
|------------------------|---|----------|-----------------|--|------------|
| Treadwell MS (2723) 2B | THE LIGHT IN BOYS RESTROOM ON FIRST FLOOR NEED A BALLAST. | 10/18/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHT SWITCH IN THE AUDITORIUM IS NOT TURNING OFF THE LIGHTS. | 10/23/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHT IN CONCESSION AREA NEED TO BE REPAIRED. THE ENDS ARE BROKEN | 10/29/13 | Gym | | Electrical |
| Treadwell MS (2723) 2B | ONE OF THE POLES IN CAFETERIA THAT COVER THE WIREING NEED TO BE SECURED THE PANEL HAVE FALLING OFF EXPOSEING THE WIREING. | 10/29/13 | Cafeteria | | Electrical |
| Treadwell MS (2723) 2B | Disconnect electrical on boilers for pipe fitters. | 10/10/13 | Mechanical Room | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHT SWITCH IN HALL NEAR ROOM 112 IS NOT WORKING. | 10/14/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE BALLAST IN THE BOYS RESTROOM IS BAD. I HAVE CHANGE THE BULBS. | 10/14/13 | | | Electrical |
| Treadwell MS (2723) 2B | THERE IS NO POWER TO THE SWITCH THAT OPEN UP THE CURTAINS AND CLOSE THEM. | 12/17/13 | Auditorium | | Electrical |
| Treadwell MS (2723) 2B | UNIT is NOT COMING ON in ROOM 104 per Mr. Cain, Plant Mgr. 416.6100 | 4/21/14 | | | Electrical |

| | | | | | |
|------------------------|---|----------|-----------|----------|------------|
| Treadwell MS (2723) 2B | PARTIAL POWER OUTAGE PLANT MGR-KING/205.8663 | 4/28/14 | | | Electrical |
| Treadwell MS (2723) 2B | Wire new rooftop unit. | 4/28/14 | Classroom | Bandroom | Electrical |
| Treadwell MS (2723) 2B | CHILLER NOT COMING ON PLANT MGR-CAIN/416.6100 | 4/21/14 | | | Electrical |
| Treadwell MS (2723) 2B | ROOM 102 HAS A BAD BALLAST. | 4/23/14 | Classroom | | Electrical |
| Treadwell MS (2723) 2B | NEED A BREAKER LOCK OUT ON ELECTRICAL PANEL BOX IN GYM. | 6/11/14 | | | Electrical |
| Treadwell MS (2723) 2B | Check out window units clean filter if necessary. | 6/16/14 | Kitchen | | Electrical |
| Treadwell MS (2723) 2B | REPAIR DAMAGE ELECTRICAL OUTLETS. | 6/18/14 | Cafeteria | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHTS IN ROOM 201 WILL NOT COME ON I HAVE CHECK THE BREAKERS. | 6/26/14 | | | Electrical |
| Treadwell MS (2723) 2B | THE FIRE ALARM NEED TO BE INSPECTED. IT WENT OFF SUNDAY MID DAY CALLING FIRE DEPT. | 11/26/13 | | | Electrical |

| | | | | | |
|------------------------|---|----------|-----------|--|------------|
| Treadwell MS (2723) 2B | ROOM 217 HAS A BAD BALLAST. PUT IN NEW BULBS. | 11/26/13 | Classroom | | Electrical |
| Treadwell MS (2723) 2B | THERE IS A BAD BALLAST IN ROOM 103 | 11/27/13 | Classroom | | Electrical |
| Treadwell MS (2723) 2B | armory - room 121 - heat is not coming on at all per Mr. Cain 416-6100 | 12/5/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE FIRE ALARM IS READING AUDITORIUM REAM BEAM DETECTOR. NEED TO BE REPAIRED. | 12/9/13 | | | Electrical |
| Treadwell MS (2723) 2B | HEAT AUDITORIUM-NOT HEATING PLANT MGR CAIN 416-6100 KLR | 12/11/13 | | | Electrical |
| Treadwell MS (2723) 2B | THE LIGHTS IN THE AUDITORIUM WILL NOT CUT OFF. | 12/13/13 | | | Electrical |
| Treadwell MS (2723) 2B | THERE IS A BAD BALLAST IN HALL ON FIRST FLOOR NEAR GIRLS RESTROOM. | 1/13/14 | | | Electrical |
| Treadwell MS (2723) 2B | UNIT NOT COMING ON RM-106 PLANT MGR-CAIN/416.6100 | 1/16/14 | | | Electrical |
| Treadwell MS (2723) 2B | UNIT VENT - RM 106 - NOT COMING ON - PM/CAIN 416-6100 | 1/21/14 | | | Electrical |

| | | | | | |
|------------------------|--|---------|---------------------|--|------------|
| Treadwell MS (2723) 2B | ROOM 301 HAS A BAD BALLAST. | 1/27/14 | Classroom | | Electrical |
| Treadwell MS (2723) 2B | HAVE A BAD BALLAST IN HALLWAY ON THIRD FLOOR. | 1/27/14 | 3rd Floor | | Electrical |
| Treadwell MS (2723) 2B | HAVE A BAD BALLAST IN ROOM 301. | 1/27/14 | | | Electrical |
| Treadwell MS (2723) 2B | Check out heating equipment, had a power outage this weekend. | 3/4/14 | | | Electrical |
| Treadwell MS (2723) 2B | Set masterclock for DLS Time. | 3/5/14 | Administration Area | | Electrical |
| Treadwell MS (2723) 2B | Fire alarm panel is in trouble. | 3/24/14 | | | Electrical |
| Treadwell MS (2723) 2B | THE ALARM PANEL IS READING SECOND FLOOR ELEVATOR LOBBY SMOKE DETECTOR TROUBLE. | 4/2/14 | | | Electrical |
| Treadwell MS (2723) 2B | Clean or replace dirty smoke detector | 4/3/14 | | | Electrical |
| Treadwell MS (2723) 2B | I NEED BALLAST IN ROOM 205 201 301 AND HALLWAY ON THIRD FLOOR. | 4/4/14 | | | Electrical |

| | | | | | |
|------------------------|---|---------|------------|-------------------|---------------------------------------|
| Treadwell MS (2723) 2B | THE FIRE ALARM WAS IN TROUBLE MODE IT WAS READING SMOKE DETECTOR IN AUDITORIUM. | 4/7/14 | | | Electrical |
| Treadwell MS (2723) 2B | CHANGE BURN OUT LIGHTS IN CAFETERIA. | 4/8/14 | Cafeteria | | Electrical |
| Treadwell MS (2723) 2B | CHANGE BURN OUT LIGHTS IN AUDITORIUM. | 4/8/14 | Auditorium | | Electrical |
| Treadwell MS (2723) 2B | blown lights,15ct. | 4/16/14 | Auditorium | ceiling | Electrical |
| Treadwell MS (2723) 2B | BLOWN LIGHT,RIGHT SIDE | 4/16/14 | Auditorium | FRONT RIGHT LIGHT | Electrical |
| Treadwell MS (2723) 2B | UNIT is NOT COOLING in the CAFETERIA per Mr. Cain, Plant Mgr. 416.6100 | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR UNIT IN 137 AND 107 IS BLOWING BUT NOT COOLING. | 4/21/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER NOT COMING ON PLANT MGR-CAIN/416.6100 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER - NOT COMING ON - PM/CAIN 416-6100 | 4/24/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Treadwell MS (2723) 2B | WE NEED THE AIR UNIT ON THE BAND ROOM COMPLETED AND TURN ON. | 4/24/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER - NOT COMING ON - PM/CAIN 416-6100 | 4/25/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLERS are in ALARM per William Cane, Plant Mgr. 416.6100 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | AIR HANDLER UNIT is NOT COOLING in the CAFETERIA per William Cane, Plant Mgr. 416.6100 | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER IS IN ALARM - PM/CAIN 416-6100 | 4/30/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | AHU IN CAFE - BLOWING BUT NOT COOLING - PM/CAIN 416-6100 | 4/30/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | per mr cain 416-6100 chiller is in alarm | 5/1/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR IN ROOM 309 IS OVER COOLING IT IS EXTREMELY COLD IN THE CLASSROOM. | 5/1/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER IS IN ALARM - PM/CAIN 416-6100 | 5/5/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|---------------------|--|---------------------------------------|
| Treadwell MS (2723) 2B | CHILLER-1 & CHILLER-2-BOTH ARE IN ALARM-PLANT MGR TODD 416-6100 KLR | 4/29/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C AUDITORIUM AREA-NOT COOLING-THEY WILL BE HAVING PROGRAMS ALL WEEK-PLANT MGR McCAIN 416-6100 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | 2-CHILLERS ARE IN ALARM PLANT MGR-CAIN/416.6100 | 6/2/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER-1 & CHILLER-2-BOTH ARE IN ALARM-PLANT MGR McCAIN 416-6100 KLR | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR IN THE ATTENDANCE OFFICE IS NOT WORKING. | 5/19/14 | Administration Area | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | CHILLER IS IN ALARM - PM/CAIN 416-6100 | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | start up band room rooftop | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR UNIT IN ROOM 106 IS NOT COMING ON AT ALL. | 5/7/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C ATTENDANCE OFC-NOT COMING ON-PLANT MGR TODD 416-6100 KLR | 10/15/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|--|--|---------------------------------------|
| Treadwell MS (2723) 2B | replace band room rooftop unit | 10/30/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UNIT NOT HEATING IN RM-315 PLANT MGR-CAIN/416.6100 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UNIT NOT COMING ON THRU ENTIRE 2ND FLR & PLANT MGR OFFICE. PLANT MGR-CANE/416.6100 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | AHU 104-005 RM 143B & FCU104- 168 RM 35 BOTH ARE LEAKING - PM/MURDOCK 416-6100 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UV NOT COMING ON IN BAND RM(NO ID), & UV IN RM-302(124) PLANT MGR-MURDOCK/416-6130 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C IS NOT COOLING in band room | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Chiller down | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C RM 219 2ND FLR-NOT COOLING-PLANT MGR CAIN 41606100 KLR | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR UNIT IN ROOM 315 IS LEAKING WATER ON FLOOR. | 9/3/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|--|--|---------------------------------------|
| Treadwell MS (2723) 2B | A/C RM 219-NOT COOLING- PLANT MGR McCAIN 416-6100 KLR | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C IN ROOM 201 IS NOT COOLING. | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | repair boilers to have on line by heating season. (busted tubes)-os | 8/27/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UV NOT COOLING ON IN TEACHERS' LOUNGE(158) PLANT MGR-MURDOCK/416-6130 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | The following rooms do not have proper air flow. Mr. Murdock was told by Brian Shipp to put this on w/o 304, 217, 218, Library | 7/31/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Rm#212 A/C leaking | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Attendance officee the air isnt working | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Band room a/c not working | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Rm#222 the a/c not working | 7/15/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|---------|--|--|---------------------------------------|
| Treadwell MS (2723) 2B | Rm#130 a/c not working | 7/15/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Monthly - Oil Lube & Belt-Treadwell Middle - Refer to PM schedule details. | 7/19/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Repair auditorium a/c | 7/19/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Room 201, 202, 204 not cooling per William Cain 416-6100 | 8/9/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | per william cain 416-6100 no a/c entire school | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR IN THE LIBRARY IS NOT WORKING AT ALL. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THERE IS A LEAK COMING FROM A ROUND PIPE. | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | REPAIR A/C IN ROOM 129 | 8/14/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C ENTIRE 2ND FLR, 3RD FLR, & AUDITORIUM-ALL NOT COOLING-PLANT MGR CAIN 416-6100 KLR | 9/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|----------|-----------|--|---------------------------------------|
| Treadwell MS (2723) 2B | 2-UNITS NOT COOLING IN RM-139,141. PLANT MGR-CAIN/416.6100 | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C unit in Auditorium is NOT COOLING per William Cain, Plant Mgr. 416.6100 | 9/25/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C RM 135-NOT COOLING- PLANT MGR CAIN KLR | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR IN ROOM 313 IS OVER COOLING THE ROOM IS VERY COLD. | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | HEAT CAFE-OVERHEATING-SBE DOESN'T KNOW THE TEMP- PLANT MGR TODD 416-6100 KLR | 11/19/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | RTU NOT COOLING IN CAFE. PLANT MGR-CANE/416.6100 | 10/31/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | room 103 in middle school first floor is cold. too cold teacher and kids complaining. | 11/12/13 | Classroom | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UNIT NOT COMING ON IN RM-106, BAND RM PLANT MGR-CAIN/416.6100 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR ON THE SECOND AND THIRD FLOOR IS TO COLD FOR THE TEMPERATURE OUTSIDE.CLASSROOM ARE COLD. | 10/21/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|---------|-----------------|--|---------------------------------------|
| Treadwell MS (2723) 2B | auditorium is not cooling per Mr. Cain 416-6100 | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | ROOM 107 IS OVER COOLING IT IS TOO COLD IN THE CLASSROOM. | 10/2/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | ROOM 304 IS OVER COOLING. | 10/3/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | BOILER 2 DONT SEEM TO BE ON.COLD IN BUILDING. | 1/7/14 | Mechanical Room | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | BOILER-1 & BOILER -2-BOTH NOT HEATING-REQUESTED BY B SHIPP KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | A/C IN RMS 123 - 129-ALL NOT COOLING-PLANT MGR McCAIN 416-6100 KLR | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Unit in Cafeteria is NOT COOLING per Mr. Cain, Plant Mgr. 416.6100 | 9/16/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UNIT NOT COOLING IN AUDIT. PLANT MGR-CANE/416.6100 | 9/18/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UNIT NOT COOLING IN ATTENDANCE, PLANT MGR, GUIDANCE OFFICES PLANT MGR-CAIN/416.6100 | 5/12/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|---|----------|-----------|--|---------------------------------------|
| Treadwell MS (2723) 2B | CHILLER MECH RM-IN ALARM- PLANT MGR McCAIN 416-6100 KLR | 6/10/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | auditorium is blowing cold air per mrcain 416-6100 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THERE IS TWO BAD LEAKS IN BOILER ROOM IT LOOK LIKE IT IS COMING FROM SEALS. | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | UNIT NOT HEATING IN RM-103,304 PLANT MGR-CAIN/416.6100 | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE CAFETERIA IS OVER HEATING IT IS VERY HOT INSIDE. | 1/24/14 | Cafeteria | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | per william cain 416-6100 no heat in the cafeteria | 1/30/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | the heater is blowing cold air in room 219 | 2/3/14 | Classroom | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Monthly - Oil Lube & Belt-Treadwell Middle - Refer to PM schedule details. | 2/21/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | THE AIR UNIT IN THE BAND ROOM NEED TO BE CONNECTED.I DONT THINK THE NEW UNIT WAS COMPLETED CONNECTED. | 3/31/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|------------------------|--|---------|-----------|-----|---------------------------------------|
| Treadwell MS (2723) 2B | CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | NEED AIR AT THE MIDDLE SCHOOL TURN ON. | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | ONE OF THE SEALS IN ONE OF THE PUMP IS LEAKING WATER ALL OVER THE FLOOR. | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Monthly - Filter-Treadwell Middle - Refer to PM schedule details. | 1/12/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Monthly - Filter-Treadwell Middle - Refer to PM schedule details. | 5/18/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Yearly - Cooling Towers STRAINERS Treadwell Middle - Refer to PM schedule details. | 3/25/14 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Yearly - Oil Samples - Treadwell Middle - Refer to PM schedule details. | 9/13/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Monthly - Filter-Treadwell Middle - Refer to PM schedule details. | 9/15/13 | | | Heating/Ventilation /Air Conditioning |
| Treadwell MS (2723) 2B | Holes in the wall in front of stage, very noticeable | 7/30/13 | 1st Floor | 116 | Painting |

| | | | | | |
|------------------------|---|----------|-----------|--------|----------|
| Treadwell MS (2723) 2B | Large hole in classroom 116 need to be repair. | 7/30/13 | 1st Floor | Rm 116 | Painting |
| Treadwell MS (2723) 2B | THE LOCKER IN THE HALLS NEED TO BE PAINTED. | 10/2/13 | | | Painting |
| Treadwell MS (2723) 2B | COULD THE EXTERIOR DOORS BE PAINTED. | 11/25/13 | | | Painting |
| Treadwell MS (2723) 2B | paint lines on football field | 9/6/13 | | | Painting |
| Treadwell MS (2723) 2B | paint lines on football field | 7/30/13 | | | Painting |
| Treadwell MS (2723) 2B | THE WALL AT EXIT DOOR NEAR ROOM124 NEED TO BE PAINTED. | 9/25/13 | | | Painting |
| Treadwell MS (2723) 2B | Finish and paint new sheetrock wall in the old ROTC armory and old walls that have been repaired. | 11/15/13 | | | Painting |
| Treadwell MS (2723) 2B | PAINT DOOR AT GIRL LOCKER ROOM. | 10/18/13 | | | Painting |
| Treadwell MS (2723) 2B | GANG GRAFFITI GYM ON WOODEN DOORS & G RR GYM AREA ON BLOCK WALL-PLANT MGR CAIN 416-6100 KLR | 10/29/13 | | | Painting |

| | | | | | |
|------------------------|--|----------|--|--|----------|
| Treadwell MS (2723) 2B | paint lines on football field | 5/22/14 | | | Painting |
| Treadwell MS (2723) 2B | THE NEW WALL IN THE ARMORY IS READY TO BE MUD AND PAINTED. | 11/26/13 | | | Painting |
| Treadwell MS (2723) 2B | some showers in practice gym is not working. | 9/5/13 | | | Plumbing |
| Treadwell MS (2723) 2B | GIRLS LOCKER ROOM SINK IS NOT WORKING. | 9/5/13 | | | Plumbing |
| Treadwell MS (2723) 2B | GIRLS LOCKER ROOM PIPE IS BROKEN ON ONE TOILET AND TWO STALLS IS LEAKING. | 9/5/13 | | | Plumbing |
| Treadwell MS (2723) 2B | I HAVE 6 STALLS IN GIRLS RESTROOM ON THIRD FLOOR NOT WORKING. | 9/6/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THERE IS 7 TOILET IN GIRLS RESTROOM ON THIRD FLOOR THE WATER RISE TO TOP EVERYTIME THEY ARE FLUSH. | 9/9/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THE GIRLS RESTROOM ON FIRST FLOOR SINK DRAIN PIPE IS RUSTED OUT AND LEAKING BADLY ON FLOOR. | 9/11/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THE GIRLS RESTROOM ON THIRD FLOOR HAS TWO STALLS WHERE THE TOILET OVER FLOWS EVERYDAY.I USED THE PLUNGER BUT IT ONLY WORKS FOR A FEW DAYS. | 8/19/13 | | | Plumbing |

| | | | | | |
|------------------------|--|---------|---------------------|-----------|----------|
| Treadwell MS (2723) 2B | the girls restroom on third floor have a plumbing problem i have close it off for now. the toilets over flows every day with the least amount of tissue. | 8/22/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THERE IS WATER LEAKING FROM AIR UNIT ONTO THE FLOOR IN CLASSROOM 315. | 8/23/13 | | | Plumbing |
| Treadwell MS (2723) 2B | Ice machine leaking. | 8/23/13 | Administration Area | | Plumbing |
| Treadwell MS (2723) 2B | ONE OF THE GIRLS TOILET ON THIRD FLOOR IS STOP UP. IT IS THE FIRST ONE ON THE LEFT. | 8/23/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THE WATER FOUNTAIN ON THE THIRD FLOOR IS LEAKING ON FLOOR. | 8/29/13 | | | Plumbing |
| Treadwell MS (2723) 2B | Unit leaking on ceiling Prin. and assist Prin. Office. | 7/26/13 | Administration Area | | Plumbing |
| Treadwell MS (2723) 2B | Unit leaking | 7/26/13 | 2nd Floor | Rm.221 | Plumbing |
| Treadwell MS (2723) 2B | Clean gutters | 7/29/13 | Grounds | Big walls | Plumbing |
| Treadwell MS (2723) 2B | Faucet not working in boy restroom. | 8/6/13 | Auditorium | Boys R/R | Plumbing |

| | | | | | |
|------------------------|---|---------|-----------|---------|----------|
| Treadwell MS (2723) 2B | Facuet in girls restroom on first floor will not turn on or off | 7/15/13 | | | Plumbing |
| Treadwell MS (2723) 2B | Make necessary repairs to address Ms McBride's safety concerns in science labs. per os | 7/16/13 | | | Plumbing |
| Treadwell MS (2723) 2B | Unit ventalator leaking in science lab on the 2nd flr. | 7/16/13 | | | Plumbing |
| Treadwell MS (2723) 2B | Unit vent leaking | 7/19/13 | Classroom | Rm 121 | Plumbing |
| Treadwell MS (2723) 2B | Waterfountian leaking from around spout, by custodial closet. | 8/7/13 | 3rd Floor | Hallway | Plumbing |
| Treadwell MS (2723) 2B | Pipe burst and running into the hallway. | 8/9/13 | 3rd Floor | | Plumbing |
| Treadwell MS (2723) 2B | THE GIRLS RESTROOM ON THIRD FLOOR THE TOILETS KEEP FLOODING. I HAVE USE THE PLUNGER BUT IT IS NOT WORKING IT IS 4 STALLS STOP UP. | 9/13/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THERE IS ONLY ONE WORKING SINK IN THE GIRLS RESTROOM ON THE SECOND FLOOR. | 9/13/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THE SINK IN THE TEACHER WORK ROOM IS STOP UP I HAVE TRY THE PLUNGER BUT IT DID NOT WORK ROOM 124. | 8/12/13 | | | Plumbing |

| | | | | | |
|------------------------|--|----------|------------------|--|----------|
| Treadwell MS (2723) 2B | THERE IS A LEAK FROM AIR UNIT IN ROOM 137. | 9/30/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THE HEATING UNITS IN THE PRACTICE GYM IS BLOWING BUT NOT HEATING. | 11/14/13 | Gym | | Plumbing |
| Treadwell MS (2723) 2B | THE HEAT IS NOT WORKING IN PRACTICE GYM BATHROOM AND OFFICE. | 11/14/13 | Gym | | Plumbing |
| Treadwell MS (2723) 2B | ONE OF THE HOT WATER PIPES AT THE CEILING SHAKES REAL BAD IT NEED TO BE MORE SECURE FROM CEILING.it is NEAR EXIT 4 | 11/21/13 | Hallway/Corridor | | Plumbing |
| Treadwell MS (2723) 2B | Test and repair RP Devices per MLG&W. | 10/30/13 | Mechanical Room | | Plumbing |
| Treadwell MS (2723) 2B | Drains in boiler room stopped up. | 11/6/13 | | | Plumbing |
| Treadwell MS (2723) 2B | TWO TOILETS IN BOYS RESTROOM ON THIRD FLOOR IS BACKING UP. | 10/15/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THERE IS BROKEN TOILETS SEATS IN BOYS LOCKER ROOM.I HAVE TRIED TO GET THEM OFF. | 10/23/13 | Restroom (Boys) | | Plumbing |
| Treadwell MS (2723) 2B | B&G pump leaking, erpair or replace. | 10/10/13 | | | Plumbing |

| | | | | | |
|------------------------|--|----------|--|--|----------|
| Treadwell MS (2723) 2B | TWO TOILETS IN BOYS RESTROOM ON THIRD FLOOR IS LEAKING FROM PIPES. | 10/14/13 | | | Plumbing |
| Treadwell MS (2723) 2B | TOILETS IN BOYS LOCKER AND RESTROOM IS LEAKING IN GYM. | 10/14/13 | | | Plumbing |
| Treadwell MS (2723) 2B | THE GIRLS RESTROOM ON THE THIRD FLOOR TOILETS OVERFLOWS AND FLOOD THE FLOOR OUT INTO HALL. | 10/15/13 | | | Plumbing |
| Treadwell MS (2723) 2B | sink in classroom 318 is stop up. | 1/2/14 | | | Plumbing |
| Treadwell MS (2723) 2B | per Mr. Cain 416-6100 in the mechanical room in the gym there is a valve broken off of a pipe and water going everywhere | 1/8/14 | | | Plumbing |
| Treadwell MS (2723) 2B | repair leak on chiller | 5/7/14 | | | Plumbing |
| Treadwell MS (2723) 2B | NEED FAUCETS ON BUILDING REPAIRED. | 5/7/14 | | | Plumbing |
| Treadwell MS (2723) 2B | NEED A BROKEN TOILET SEAT IN COACH WILLIAM OFFICE IN THE GYM REPLACE. | 4/25/14 | | | Plumbing |
| Treadwell MS (2723) 2B | Plesae replace water hydrant outside courtyard. The handle is gone. | 4/23/14 | | | Plumbing |

| | | | | | |
|------------------------|--|---------|---------------------|-----------------|----------|
| Treadwell MS (2723) 2B | THE AUDITORIUM BOYS RESTROOM DRAIN IS FLOWING BACK WATER UP FROM FLOOR DRAIN | 4/23/14 | Auditorium | | Plumbing |
| Treadwell MS (2723) 2B | NEED THE WATER FAUCETS OUTSIDE OF BUILDING REPAIRED. | 5/8/14 | | | Plumbing |
| Treadwell MS (2723) 2B | SEWAGE SMELL, BY COURT OUTSIDE AREA PLANT MGR-CAIN/416.6100 | 5/8/14 | | | Plumbing |
| Treadwell MS (2723) 2B | ONE OF THE TOILET IN GIRLS RESTROOM ON THIRD FLOOR IS STOPPED UP. | 4/30/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THE URINALS IN BOYS RESTROOM IN THE AUDITORIUM NEED REPAIRS. ONE WILL NOT FLUSH THE OTHER ONE LEAKS. | 5/12/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THERE IS A LEAK AROUND ONE OF THE PIPES IN THE CEILING IN SUPPLY ROOM. | 5/14/14 | Administration Area | | Plumbing |
| Treadwell MS (2723) 2B | THE GARBAGE DISPOSAL HAS BEEN REPAIRED,NEED TO REINSTALL. | 6/12/14 | Kitchen | | Plumbing |
| Treadwell MS (2723) 2B | THE WATER FOUNTAIN IN THE GYM HAS FALLING FROM WALL ON THE FLOOR. | 5/19/14 | Gym | | Plumbing |
| Treadwell MS (2723) 2B | Leak at the mop sink. | 6/2/14 | Gym | Mechanical room | Plumbing |

| | | | | | |
|------------------------|---|----------|------------------|--------------------|----------|
| Treadwell MS (2723) 2B | HEAT GYM AREA & LOCKER RMS- BOTH NOT HEATING-PLANT MGR CAIN 416-6100 KLR | 11/25/13 | | | Plumbing |
| Treadwell MS (2723) 2B | PIPE IN CEILING OF KITCHEN- LEAKING PER SBE-PLANT MGR CAID 416-6100 KLR | 12/13/13 | | | Plumbing |
| Treadwell MS (2723) 2B | NEED PLUMBER TO HOOK UP NEW STEAMER ALL READY AT SCHOOL. | 12/13/13 | Kitchen | | Plumbing |
| Treadwell MS (2723) 2B | THEY NEED NEW STEAM OVEN CONNECTED. | 1/22/14 | Cafeteria | | Plumbing |
| Treadwell MS (2723) 2B | ONE OF THE BOYS URINAL ON SECOND FLOOR NEED A NEW KIT. THE URINAL KEEP FLUSHING. | 1/27/14 | Restroom (Boys) | | Plumbing |
| Treadwell MS (2723) 2B | THE TOILET IN THE GIRLS RESTROOM ON THE FIRST FLOOR IS STOP UP I HAVE PLUNGS IT. | 2/5/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THE FLOOR DRAIN IS NOT DRAINING IN THE GIRLS RESTROOM ON FIRST FLOOR. | 2/5/14 | Restroom (Girls) | | Plumbing |
| Treadwell MS (2723) 2B | Sink by dishwasher clogged and/or drains slowly. | 2/18/14 | Cafeteria | | Plumbing |
| Treadwell MS (2723) 2B | WATER LEAKING AROUND FIXTURE, VALVE | 2/20/14 | 1st Floor | GIRL'S RESTROOM | Plumbing |

| | | | | | |
|------------------------|--|---------|------------------|-----------------|----------|
| Treadwell MS (2723) 2B | REPAIR TOILETS, SPILLING OVER 3CT. | 2/21/14 | 1st Floor | GIRL'S RESTROOM | Plumbing |
| Treadwell MS (2723) 2B | REPAIR FIXTURE, COMMODOE LEAKING 4TH STALL | 2/21/14 | 1st Floor | BOY'S RESTROOM | Plumbing |
| Treadwell MS (2723) 2B | DRAINS are BACKING UP in the KITCHEN AREA per William Cane, Plant Mgr. 416.6100 | 2/24/14 | | | Plumbing |
| Treadwell MS (2723) 2B | I NEED A PLUMBER THE GIRLS RESTROOM ON THE FIRST FLOOR IS COMPLETELY OUT OF ORDER. THE STALLS ARE CLOG UP AND WATER IS COMING BACK UP THROUGH FLOOR DRAIN. THERE IS SEVERAL OTHERS | 2/25/14 | | | Plumbing |
| Treadwell MS (2723) 2B | REST ROOM WITH PROBLEMS I NEED A PLUMBER THE FIRST FLOOR GIRLS RESTROOM IS OUT OF SERVICE. EVERY TIME U FLUSH A TOILET THEY ALL RUNS OVER. | 2/27/14 | Restroom (Girls) | | Plumbing |
| Treadwell MS (2723) 2B | main sewer stopped-up | 3/10/14 | | | Plumbing |
| Treadwell MS (2723) 2B | COMMODOE ASST PRIN'S OFC RR- OVERFLOWS WHEN FLUSHED- PLANT MGR CAIN 416-6100 KLR | 3/11/14 | | | Plumbing |
| Treadwell MS (2723) 2B | per cain 416-6100 broken hot water pipe in kitchen | 3/17/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THE SINK IN THE CAFETERIA NEXT TO DISHWASHER IS STOP UP. | 3/19/14 | Cafeteria | | Plumbing |

| | | | | | |
|------------------------|---|---------|---------------------|--|----------|
| Treadwell MS (2723) 2B | THE MOP SINK IN THE BOOKROOM ON THE FIRST FLOOR IS STOP UP. | 3/25/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THERE IS A BOOK STORE ROOM ON THE FIRST FLOOR WITH A MOP SINK AND TOILET. THEY ARE BOTH STOP UP. THEY HAVE A BAD ORDOR IN HALL. | 3/26/14 | | | Plumbing |
| Treadwell MS (2723) 2B | per Mr. Cain 416-6100 in the mechanical room in the gym replace valve and filter to the domestic hot water. | 3/31/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THE GARBAGE DISPOSAL IS NOT WORKING.AND ONE OF THE FAUCET NEED A WASHER. | 4/1/14 | Kitchen | | Plumbing |
| Treadwell MS (2723) 2B | Fill cooling tower and check out for cooling season. | 4/3/14 | | | Plumbing |
| Treadwell MS (2723) 2B | per mr cain 416-6100 brownish water coming up out of water fountain and all over floor on 2nd floor by elevator | 4/4/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THE RESTROOM NEAR PRINCIPAL OFFICE IS BROKEN NEED REPAIR. | 4/8/14 | Administration Area | | Plumbing |
| Treadwell MS (2723) 2B | SEWAGE IS RUNNING BETWEEN GYM & CAFE PLANT MGR-CANE/416.6100 | 4/10/14 | | | Plumbing |
| Treadwell MS (2723) 2B | THE FLOOR DRAIN IN THE KITCHEN IS STOPPED UP AGAIN UNDER THE DISH WASHER TABLE | 4/11/14 | Kitchen | | Plumbing |

| | | | | | |
|------------------------|--|----------|-----------------|-----------------------|----------|
| Treadwell MS (2723) 2B | WATER FOUNTAINS NOT WORKING | 4/16/14 | 1st Floor | WATER FOUNTAIN CENTER | Plumbing |
| Treadwell MS (2723) 2B | Make repairs to oil cooler on chiller #2 water linr leaking. | 4/16/14 | Mechanical Room | Chiller room | Plumbing |
| Treadwell MS (2723) 2B | PUMP IS LEAKING WATER IN BOILER RM PLANT MGR- JEFFERSON/416.6100 | 4/17/14 | | | Plumbing |
| Treadwell MS (2723) 2B | AHU 104-005 - RM143B - LEAKING - PM/MURDOCK 416-6100 (see wo 371808) | 8/7/13 | | | Plumbing |
| Treadwell MS (2723) 2B | NOT WORKING CUT - OFF | 2/20/14 | 1st Floor | WATER FOUNTAIN 112 | Plumbing |
| Treadwell MS (2723) 2B | NOT WORKING,CUT OFF | 2/20/14 | 1st Floor | WATER FOUNTAIN 139 | Plumbing |
| Treadwell MS (2723) 2B | THERE IS A LEAK IN ROOM 222. | 10/16/13 | | | Roof |
| Treadwell MS (2723) 2B | THERE IS A BAD ROOF LEAK IN ROOM 121' | 4/28/14 | | | Roof |
| Treadwell MS (2723) 2B | THERE IS TWO LEAKS IN THE KITCHEN. | 12/5/13 | Cafeteria | | Roof |

| | | | | | |
|------------------------|---|---------|---------------------|-----------------|-------------|
| Treadwell MS (2723) 2B | THERE IS TWO LEAKS IN THE KITCHEN. | 12/5/13 | Cafeteria | | Roof |
| Treadwell MS (2723) 2B | THERE IS A ROOF LEAK IN ROOM 307. | 1/27/14 | | | Roof |
| Treadwell MS (2723) 2B | Repair gutters, water coming in from outside wall. | 7/29/13 | Grounds | Outside Bldg | Sheet Metal |
| Treadwell MS (2723) 2B | Make necessary modifications to lockers to be secured with padlocks. | 7/11/13 | | | Sheet Metal |
| Treadwell MS (2723) 2B | Fabricate and install cover plate between sink and mirror in the office restroom. | 3/19/14 | Administration Area | Guidance Office | Sheet Metal |

| Count of Craft | Craft | | | | | | | | | |
|-------------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Hills Station ES (2745) | 7 | 1 | 63 | 73 | 34 | 11 | 44 | 8 | 7 | 248 |
| Grand Total | 7 | 1 | 63 | 73 | 34 | 11 | 44 | 8 | 7 | 248 |

| Location | Request Description | Submittal Dat | Area Description | Area Number | Craft |
|-------------------------------|---|----------------------|-------------------------|--|--------------|
| Wells Station ES (2745) 2B | please repair, strip, & refinish stage floor. | 5/13/14 | Administration Area | cafeteria | Asbestos |
| Wells Station ES (2745) 2B | Repair or replace broken blinds in these areas. | 8/8/13 | Cafeteria | Cafeteria, and Annex 1st floor hall | Asbestos |
| Wells Station ES (2745) 2B | Replace cove base that will not stay on bottom of walls. | 9/18/13 | | Library, Annex upstairs and down stairs | Asbestos |
| Wells Station ES (2745) 2B | Replace old and rusty toilets tissue holders with jumbo toilet tissue holders. old toilet tissue holders very old rusty and unsafe. | 9/18/13 | | Girls and Boys restrooms | Asbestos |
| Wells Station ES (2745) 2B | Wrap pipes that has insulation exposed. | 7/29/13 | Hallway/Corridor | Main hall, North hall, Middle hall, Annex building | Asbestos |
| Wells Station ES (2745) 2B | Possible A&G on ceiling tile in storage closet. | 1/31/14 | Portables | 329A | Asbestos |
| Wells Station ES (2745) 2B | possible AMG in restroom. | 3/31/14 | Administration Area | asst principal rest room | Asbestos |

| | | | | | |
|-------------------------------|---|----------|------------------|-----------------------------------|-----------|
| Wells Station ES (2745) 2B | Install network drop for new copiers. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes") | 12/12/13 | | Main office, and Work room/Lounge | Cabling |
| Wells Station ES (2745) 2B | Door closure on double doors leading out to portables has been broken. | 10/2/13 | Annex | Downstairs hall | Carpentry |
| Wells Station ES (2745) 2B | Floor tile very loose on floor and holes are in the floor under the tile. | 10/2/13 | Portables | 317B | Carpentry |
| Wells Station ES (2745) 2B | Concrete stall wall is very loose on wall repair due to safety reasons. | 10/16/13 | Restroom (Boys) | Annex downstairs | Carpentry |
| Wells Station ES (2745) 2B | Double doors leading to stair well is coming off the hinges. Hinges broken. | 10/16/13 | Annex | Downstairs | Carpentry |
| Wells Station ES (2745) 2B | Stall door in girls restroom fell off hinges. Replaced because door is very old. | 10/22/13 | Restroom (Girls) | North hall | Carpentry |
| Wells Station ES (2745) 2B | Replace all stall doors in girls and boys resr rooms. They are very old and hold lots of splinters. Very unsafe. | 10/22/13 | | Rest rooms | Carpentry |
| Wells Station ES (2745) 2B | STALL DOOR HAS PIECES OF WOOD STICKING OUT IN G/RR MAIN HALL. PLANT MGR- BANKS/416.2172 | 10/22/13 | | | Carpentry |

| | | | | | |
|-------------------------------|--|----------|-----------|-----------|-----------|
| Wells Station ES (2745) 2B | WINDOW PORT 317A- BROKEN OUT-WON'T BE ABLE TO SECURE-PLANT MGR BANKS 416-2172 KLR | 11/5/13 | | | Carpentry |
| Wells Station ES (2745) 2B | WINDOWS ARE VERY LOOSE IN PORT-329B, CANT SECURE. PLANT MGR-BANKS/416- 2172 | 11/12/13 | | | Carpentry |
| Wells Station ES (2745) 2B | ANNEX DOOR CANT SECURE. PLANT MGR- BANKS/416.6020 | 12/9/13 | | | Carpentry |
| Wells Station ES (2745) 2B | Repair floors in portable 317A & B. | 1/6/14 | | | Carpentry |
| Wells Station ES (2745) 2B | Please install threshold and weather stripping on door. | 1/15/14 | Portables | 329 A & B | Carpentry |
| Wells Station ES (2745) 2B | please install weather strip on both doors. | 1/15/14 | Portables | 148 | Carpentry |
| Wells Station ES (2745) 2B | please repair floor in portable. | 1/15/14 | Portables | 156 | Carpentry |
| Wells Station ES (2745) 2B | please repair door knob on cafeteria door (south entry). | 1/17/14 | Cafeteria | main hall | Carpentry |

| | | | | | |
|-------------------------------|---|---------|------------------|---|-----------|
| Wells Station ES (2745) 2B | please replace door handle on stall door. | 1/22/14 | Restroom (Girls) | north hall by rm. 201 | Carpentry |
| Wells Station ES (2745) 2B | please send 2 cases of ceiling tile. | 1/24/14 | Custodial | plant managers office | Carpentry |
| Wells Station ES (2745) 2B | install new panic bar-os | 8/20/13 | | | Carpentry |
| Wells Station ES (2745) 2B | Chain link fence around playground part of it has fallen on the ground per Brenda Banks 416-2172 | 9/3/13 | | | Carpentry |
| Wells Station ES (2745) 2B | Replace ceiling tiles that are special cut through out building. | 7/29/13 | | Main hall, North hall, Cafeteria, Middle hall, Anne | Carpentry |
| Wells Station ES (2745) 2B | Install lockers in room 108 | 7/30/13 | Classroom | Room 108 | Carpentry |
| Wells Station ES (2745) 2B | Install dividers around PE teacher and supplies to create an office environment in the back of cafeteria. | 7/11/13 | Cafeteria | PE area back of cafeteria | Carpentry |
| Wells Station ES (2745) 2B | Replace broken tile in these areas. | 7/15/13 | | North hall, room #305, 304,6 ,,, | Carpentry |

| | | | | | |
|-------------------------------|--|----------|---------------------|--------------------------|-----------|
| Wells Station ES (2745) 2B | Door closure broken on these double doors 2 down stairs, and 2 upstairs. | 7/15/13 | Annex | Down stairs, upstairs | Carpentry |
| Wells Station ES (2745) 2B | Door is separating from frame, boys restroom and double door in annex hallway. | 7/15/13 | Annex | Down stairs | Carpentry |
| Wells Station ES (2745) 2B | Replace broken tiles in these areas North hall and portable 156. | 7/24/13 | | North hall, Portable 156 | Carpentry |
| Wells Station ES (2745) 2B | Install marker boards. | 7/29/13 | Classroom | 108 | Carpentry |
| Wells Station ES (2745) 2B | Please install 4 barrel on 4 doors. | 3/19/14 | Courtyard | main hall | Carpentry |
| Wells Station ES (2745) 2B | Fence that surrounds the play ground equipment were forced down by an automobile. It is unsafe for the children to play in the area. | 12/17/13 | Grounds | Play ground | Carpentry |
| Wells Station ES (2745) 2B | Install new door with wood at the bottom and glass at the top of door. Old door is very old. | 7/11/13 | Administration Area | Main Office | Carpentry |
| Wells Station ES (2745) 2B | Remove dividers from these areas and place them in room#305 to make two rooms with separate doors. | 7/11/13 | Classroom | 200,201,and202 | Carpentry |

| | | | | | |
|-------------------------------|---|---------|---------------------|-----------------------|-----------|
| Wells Station ES (2745) 2B | Please replace broken floor tile. | 2/26/14 | Annex | rm.3 | Carpentry |
| Wells Station ES (2745) 2B | Please install a closet and shelves in boy's restroom. | 2/27/14 | Restroom (Boys) | main hall | Carpentry |
| Wells Station ES (2745) 2B | Please install a closet and shelves in girl's restroom. | 2/27/14 | Restroom (Girls) | main hall | Carpentry |
| Wells Station ES (2745) 2B | please repair door closure on hall. | 2/3/14 | Annex | hall | Carpentry |
| Wells Station ES (2745) 2B | please install a 4ft. bulletin board. | 2/6/14 | 1st Floor | westside rm. 7 | Carpentry |
| Wells Station ES (2745) 2B | please repair hole in the wall. | 2/10/14 | Portables | 148 | Carpentry |
| Wells Station ES (2745) 2B | please install weather strip at the bottom of door. | 2/12/14 | Hallway/Corridor | north hall by rm. 104 | Carpentry |
| Wells Station ES (2745) 2B | please install 4 door sweep. | 2/13/14 | Administration Area | front entry | Carpentry |

| | | | | | |
|-------------------------------|--|---------|---------------------|--------------------------|-----------|
| Wells Station ES (2745) 2B | please repair floor it seperated from wall. | 2/21/14 | Classroom | 110 | Carpentry |
| Wells Station ES (2745) 2B | please repair door closure across from classroom 1. | 2/24/14 | Annex | across from rm 1 | Carpentry |
| Wells Station ES (2745) 2B | please repair broken hinge on door in last stall. | 4/16/14 | Restroom (Girls) | north hall | Carpentry |
| Wells Station ES (2745) 2B | Please install a 4ft. dry eraser board in asst. principal's office. | 4/21/14 | Administration Area | asst. principal's office | Carpentry |
| Wells Station ES (2745) 2B | please install large bulletin board that is already on site. | 4/22/14 | Portables | 329B | Carpentry |
| Wells Station ES (2745) 2B | please install 8ft. dry eraser board. | 4/25/14 | Administration Area | ESL classroom | Carpentry |
| Wells Station ES (2745) 2B | please weld chain to gate on playground. | 4/30/14 | Grounds | playground | Carpentry |
| Wells Station ES (2745) 2B | per mr lee 416-2172 1st floor annex bldg exterior door leading to portables the hardware has come off and can't secure | 5/7/14 | | | Carpentry |

| | | | | | |
|-------------------------------|--|---------|------------------|--------------------------|-----------|
| Wells Station ES (2745) 2B | please replace missing baseboard. | 4/2/14 | Library | across from rm. 206 | Carpentry |
| Wells Station ES (2745) 2B | missing floor tile. | 4/4/14 | Classroom | rm. 112 | Carpentry |
| Wells Station ES (2745) 2B | please repair broken door knob. | 4/8/14 | Annex | 1st. floor back stairway | Carpentry |
| Wells Station ES (2745) 2B | please install a closet in boy's restroom. | 4/8/14 | Restroom (Boys) | north hall | Carpentry |
| Wells Station ES (2745) 2B | please install closet in girl's restroom. | 4/8/14 | Restroom (Girls) | north hall | Carpentry |
| Wells Station ES (2745) 2B | please install glass in office window & A.V. rm also door. | 4/15/14 | Library | AV rm. & office area | Carpentry |
| Wells Station ES (2745) 2B | please repair broken hinge on stall door. | 4/16/14 | Restroom (Girls) | main hall | Carpentry |
| Wells Station ES (2745) 2B | WINDOW BROKEN & SCREEN IN PORT-156,& PORT-329A SCREEN PLANT MGR-LEE/416.2172 | 5/19/14 | | | Carpentry |

| | | | | | |
|-------------------------------|---|---------|---------------------|---|-----------|
| Wells Station ES (2745) 2B | please install 2 tac strips in office. | 5/23/14 | Administration Area | asst. principal office | Carpentry |
| Wells Station ES (2745) 2B | door is not closing, please adjust door closure. | 5/23/14 | Hallway/Corridor | 1st floor annex across from portable 317A | Carpentry |
| Wells Station ES (2745) 2B | please remove counter in main office, also install missing floor tile. | 6/6/14 | Administration Area | main office | Carpentry |
| Wells Station ES (2745) 2B | Install a larger window in the door (Main Entry) having trouble seeing children in the hallway when the door is opened. | 6/12/14 | Administration Area | Main Office | Carpentry |
| Wells Station ES (2745) 2B | Please install a dry eraser board in classroom. | 6/27/14 | 1st Floor | rm. 303 | Carpentry |
| Wells Station ES (2745) 2B | please install cork strip by each classroom. | 6/27/14 | Classroom | in each hall | Carpentry |
| Wells Station ES (2745) 2B | Please install 8 ft. dry eraser board that's all ready at the location. | 5/29/14 | Annex | rm. 1 | Carpentry |
| Wells Station ES (2745) 2B | Please remove smart board from wall & reinstall board on north wall. | 5/28/14 | Classroom | rm. 5 | Carpentry |

| | | | | | |
|-------------------------------|---|----------|-------------|-------------------|------------|
| Wells Station ES (2745) 2B | room 1 there is no power in any of the receptacles per ms. bates 416-2172 | 10/14/13 | | | Electrical |
| Wells Station ES (2745) 2B | UNIT NOT COMING ON IN PORT-148,150 . PLANT MGR- BANKS/416.2172 | 10/21/13 | | | Electrical |
| Wells Station ES (2745) 2B | UNIT NOT COMING ON IN PORT-148 . PLANT MGR- BANKS/416.2172 | 11/8/13 | | | Electrical |
| Wells Station ES (2745) 2B | We have 13 light fixtures not working. | 11/12/13 | Cafeteria | Cafeteria | Electrical |
| Wells Station ES (2745) 2B | Need 3 cases of Flourescent bulbs 32 watts | 11/12/13 | Cafeteria | Plant mgrs office | Electrical |
| Wells Station ES (2745) 2B | Some lights out in parking lot and on front porch of the building. | 11/20/13 | | | Electrical |
| Wells Station ES (2745) 2B | Repair or replace exterior lights parking lot was very dark last night per Princ. and there will be people voting tomorrow night. | 11/20/13 | Parking Lot | | Electrical |
| Wells Station ES (2745) 2B | Check security hardware at main entry. | 12/2/13 | | | Electrical |

| | | | | | |
|-------------------------------|---|---------|---------------------|----------------------|------------|
| Wells Station ES (2745) 2B | HEAT PORT 150-NOT COMING ON-PLANT MGR LEE 416-2172 KLR | 1/8/14 | | | Electrical |
| Wells Station ES (2745) 2B | please send 3 cases of florecent bulbs. | 1/10/14 | Custodial | plant manager office | Electrical |
| Wells Station ES (2745) 2B | clock is not working. | 1/27/14 | Administration Area | main office | Electrical |
| Wells Station ES (2745) 2B | Repair all exit lights in these areas not working at all. | 8/13/13 | Hallway/Corridor | Main hall, Cafeteria | Electrical |
| Wells Station ES (2745) 2B | Bells are not ringing at the right time. Equipment #063- 041. | 8/13/13 | Administration Area | | Electrical |
| Wells Station ES (2745) 2B | Clocks are not working through out building. | 8/13/13 | | Through out building | Electrical |
| Wells Station ES (2745) 2B | A/C IN PORT 148-NOT COMING ON-SBE BANKS KLR | 8/16/13 | | | Electrical |
| Wells Station ES (2745) 2B | Partial power outage in teachers lounge, no plant manager Princ. request assistance. | 8/27/13 | | | Electrical |

| | | | | | |
|-------------------------------|--|---------|---------------------|------------------------|------------|
| Wells Station ES (2745) 2B | A/C IN PORTABLES 150 & 156-BOTH NOT COMING ON- PLANT MGR BANSK 416-2172 KLR | 9/10/13 | | | Electrical |
| Wells Station ES (2745) 2B | Light switch will not stay off when its cut off. | 9/18/13 | Classroom | Room 305 | Electrical |
| Wells Station ES (2745) 2B | FCU NOT COMING ON IN RM-2(060,061) PLANT MGR- BANKS/416.2172 | 8/6/13 | | | Electrical |
| Wells Station ES (2745) 2B | Set master clock for school time this year equipment #063-041. | 7/27/13 | Administration Area | Main Office | Electrical |
| Wells Station ES (2745) 2B | please repair bad light switch. | 3/6/14 | Annex | rm. 5 | Electrical |
| Wells Station ES (2745) 2B | please repair bad light switch in classroom. | 3/6/14 | Classroom | rm. 110 | Electrical |
| Wells Station ES (2745) 2B | Please send 3 cases of florecent bulbs. | 3/18/14 | Cafeteria | plant manager's office | Electrical |
| Wells Station ES (2745) 2B | light switch won't cut off in restroom. | 3/18/14 | Classroom | rm 109 | Electrical |

| | | | | | |
|-------------------------------|---|---------|---------------------|------------------|------------|
| Wells Station ES (2745) 2B | Need to install a protective cover over the fire alarm pull station in the Cafeteria/Gym area. The plant manager can show you the exact location. | 3/19/14 | | | Electrical |
| Wells Station ES (2745) 2B | Please repair bad receptcle. | 3/24/14 | Administration Area | Teacher's Lounge | Electrical |
| Wells Station ES (2745) 2B | please replace 2 clocks in cafeteria no working properly. | 3/25/14 | Cafeteria | by main hall | Electrical |
| Wells Station ES (2745) 2B | please replace clock in teacher's lounge thats not properly working. | 3/25/14 | Administration Area | teacher's lounge | Electrical |
| Wells Station ES (2745) 2B | pleasereplace battery in emergency light. | 3/26/14 | Administration Area | main hall | Electrical |
| Wells Station ES (2745) 2B | lease replace battery in emergency light. | 3/26/14 | Classroom | south rm. 108 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Cafeteria | south east wall | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | | by rm 102 | Electrical |

| | | | | | |
|-------------------------------|--|---------|------------------|---------------------|------------|
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Hallway/Corridor | by rm.104 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Hallway/Corridor | behind cafeteria | Electrical |
| Wells Station ES (2745) 2B | ease replace battery in emergency light. | 3/26/14 | 1st Floor | north by rm. 301 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Stairway | west 2nd floor | Electrical |
| Wells Station ES (2745) 2B | ease replace battery in emergency light. | 3/26/14 | Annex | 2nd floor by rm. 10 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Annex | 2nd floor by rm. 6 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Stairway | east 2nd floor | Electrical |
| Wells Station ES (2745) 2B | please replace battery emergency light. | 3/26/14 | Annex | lobby near portable | Electrical |

| | | | | | |
|-------------------------------|--|---------|------------------|------------------|------------|
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Annex | by rm. 5 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Annex | by rm. 1 | Electrical |
| Wells Station ES (2745) 2B | please replace battery in emergency light. | 3/26/14 | Stairway | west 1st floor | Electrical |
| Wells Station ES (2745) 2B | fire door not closing. | 3/26/14 | Hallway/Corridor | north by rm. 302 | Electrical |
| Wells Station ES (2745) 2B | please replace or repair vent hood. | 3/26/14 | Kitchen | | Electrical |
| Wells Station ES (2745) 2B | please install a emergency exit light in portable. | 3/26/14 | Portables | 156 | Electrical |
| Wells Station ES (2745) 2B | Please replace broken clock. | 3/28/14 | Annex | 2nd fl. rm. 8 | Electrical |
| Wells Station ES (2745) 2B | unit portable# 148 & 150 are not coming on. SBE BANKS 416-2172 | 7/8/13 | | | Electrical |

| | | | | | |
|-------------------------------|--|---------|---------------------|------------------------------|------------|
| Wells Station ES (2745) 2B | HEAT PORT 150-NOT COMING ON-PLANT MGR LEE 416-1157 KLR | 2/26/14 | | | Electrical |
| Wells Station ES (2745) 2B | clock making loud noise. | 2/27/14 | Classroom | rm 303 | Electrical |
| Wells Station ES (2745) 2B | Portable has 2 bad ballast. | 1/30/14 | Portables | 156 | Electrical |
| Wells Station ES (2745) 2B | bad ballast. | 2/18/14 | Stairway | 2nd floor annex | Electrical |
| Wells Station ES (2745) 2B | please replace broken clock in classroom. | 2/21/14 | Classroom | 103 & 114 | Electrical |
| Wells Station ES (2745) 2B | please set clock up 1 hour [daylight saving time]. | 2/24/14 | Administration Area | main office | Electrical |
| Wells Station ES (2745) 2B | please replace missing cover for light fixture. | 4/24/14 | Cafeteria | by plant manager's office | Electrical |
| Wells Station ES (2745) 2B | Bad ballast. | 4/25/14 | Classroom | 201 | Electrical |

| | | | | | |
|-------------------------------|---|---------|---------------------|-----------------|------------|
| Wells Station ES (2745) 2B | Please replace broken clock. | 4/28/14 | Annex | rm. 7 | Electrical |
| Wells Station ES (2745) 2B | A/C MAIN OFC-NOT COMING ON-PLANT MGR LEE 416-2172 KLR | 5/9/14 | | | Electrical |
| Wells Station ES (2745) 2B | Please replace 2 lights out in front of school. | 4/1/14 | Administration Area | front of school | Electrical |
| Wells Station ES (2745) 2B | Lights out in Cafeteria. Also please send 3 cases of florecent bulbs. | 4/1/14 | Cafeteria | by y main hall | Electrical |
| Wells Station ES (2745) 2B | please replace broken clock. | 4/2/14 | Library | across from 206 | Electrical |
| Wells Station ES (2745) 2B | bad switch. | 4/4/14 | Classroom | rm. 112 | Electrical |
| Wells Station ES (2745) 2B | please reset master clock it's 1 hr. ahead the bell is ringing early. | 4/7/14 | Administration Area | main office | Electrical |
| Wells Station ES (2745) 2B | Please replace clock in classrooms not working. | 4/11/14 | Classroom | rm 200 & rm.5 | Electrical |

| | | | | | |
|-------------------------------|--|---------|---------------------|--------------|------------|
| Wells Station ES (2745) 2B | please replase 6 bad ballast. | 5/14/14 | Cafeteria | by main hall | Electrical |
| Wells Station ES (2745) 2B | POWER OUTAGE - COMPLETE OUTAGE - PM/LEE 416-2172 | 5/27/14 | | | Electrical |
| Wells Station ES (2745) 2B | UNIT NOT COMING ON IN PORT-317B,329,150,156 PLANT MGR-LEE/416.2172 | 6/6/14 | | | Electrical |
| Wells Station ES (2745) 2B | please repair 8 bad ballast. | 6/10/14 | Classroom | 105 | Electrical |
| Wells Station ES (2745) 2B | please replace broken light switch cover. | 6/20/14 | Portables | 150 | Electrical |
| Wells Station ES (2745) 2B | bad ballast. | 5/13/14 | Cafeteria | kitchen | Electrical |
| Wells Station ES (2745) 2B | please install additional electrical outlets on main hall. | 6/26/14 | Administration Area | main hall | Electrical |
| Wells Station ES (2745) 2B | please install additional electrical outlets on hall. | 6/26/14 | 1st Floor | north hall | Electrical |

| | | | | | |
|-------------------------------|---|----------|--|--|---------------------------------------|
| Wells Station ES (2745) 2B | Electrician is needed to repair bell on outside of the building so that the teachers in the portables can hear for class change. We have sent this to Jim since Otto is currently absent ...call Leslie Ratiiff for more details if needed | 1/30/14 | | | Electrical |
| Wells Station ES (2745) 2B | per mr lee 416-2172 room 114 not cooling | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | A/C UNIT IN PORT #148 - BLOWING NOT COOLING = PM/LEE 416-2172 | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | AIR HANDLER UNIT is NOT COOLING in the CAFETERIA per Gerald Lee, Plant Mgr. 416.2172 | 5/21/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | UNIT IS MAKING NOISE IN PORT-148 PLANT MGR-LEE/416.6020 | 5/22/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | CHILLER in ALARM per Gerald Lee, Plant Mgr. 416.2172 | 5/27/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Units are NOT HEATING in ROOMS 104 and 200, and in the CAFETERIA per Brenda Banks, Plant Mgr. 416.2172 | 12/10/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Monthly - Filter-Wells Station Elementary - Refer to PM schedule details. | 5/2/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------|--|----------|--|--|---------------------------------------|
| Wells Station ES (2745) 2B | AHU NOT HEATING IN CAFE , KITCHEN, RM-104,200 PLANT MGR- BANKS/416.2172 | 12/12/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | install new unit on portable 150 | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | PORTABLE#317 A & B & THE MAIN OFFICE IS NOT COMING ON. SBE BANKS 416-2172 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Replace Port. 150 a/c | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | BOILER NOT HEATING. PLANT MGR- BANKS/416.2172 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | HEAT CAFE-NOT HEATING- PLANT MGR BANKS 416- 2172 KLR | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | HEAT RMS 102, 103, 104, 105, & CLINIC-ALL NOT HEATING-PLANT MGR LEE KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | UNIT NOT HEATING IN RM- 200,201,104,5 PLANT MGR-LEE/416.2172 | 1/22/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------|---|---------|--|--|---------------------------------------|
| Wells Station ES (2745) 2B | per mr. lee 416-1152 room 112 is blowing cold air | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | UNIT NOT HEATING IN RM- 114,113,112,111,5,305,200,20 1,104,ASSIST PRIN OFFICE , CLINIC OFFICE & PORT- 108 PLANT MGR-LEE/416.2172 | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | CHILLER IS NOT COOLING. SBE BANKS 416-2172 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Monthly - Oil Lube & Belt- Wells Station Elem - Refer to PM schedule details. | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Replace Port. 148 a/c | 9/26/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Chiller down per EMS 7.1.13 | 7/14/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | UNIT IN RM 112 IS NOT COOLING SBE BANKS 416- 2172 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | UNIT IN THE PORTABLE # 150 & 148 IS NOT COMING ON SBE BANKS 416-2172 | 7/26/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|-------------------------------|--|---------|--|--|---------------------------------------|
| Wells Station ES (2745) 2B | HEAT RM 9-NOT HEATING- PLANT MGR LEE 416-2172 KLR | 3/6/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | CHILLER IS NOT COMING ON. SBE BANKS 416-2172 | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | A/C RM 6, 7, & 8-ALL NOT COOLING-PLANT MGR LEE KLR | 5/9/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | PORT #317A - BLOWING NOT COOLING - PM/LEE 416-2172 | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | CHILLER IS OVER COOLING (TECH IS ALREADY ON SITE) PLANT MGR-LEE/416.6020 | 4/15/14 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Monthly - Filter-Wells Station Elementary - Refer to PM schedule details. | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Monthly - Filter-Wells Station Elementary - Refer to PM schedule details. | 1/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | | |
|-------------------------------|--|---------|---------|--|-----------------------------|---------------------------------------|
| Wells Station ES (2745) 2B | Yearly - #1 Boiler 043 - Wells Sta EI-Boiler Rm N - Refer to PM schedule details. | 3/31/14 | | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Yearly - #2 Boiler 044-Wells Sta EI-Boiler Rm S - Refer to PM schedule details. | 3/31/14 | | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Monthly - Oil Lube & Belt-Wells Station Elem - Refer to PM schedule details. | 4/7/14 | | | | Heating/Ventilation /Air Conditioning |
| Wells Station ES (2745) 2B | Wells Station is having SACCS this year and we need painting inside and outside the building. Some areas are in real bad shape inside and outside. | 7/11/13 | | | | Painting |
| Wells Station ES (2745) 2B | All doors leading into building need power washed and painting. | 7/29/13 | | | Outside around building | Painting |
| Wells Station ES (2745) 2B | please paint no parking in fire lane on driveway. | 2/26/14 | Grounds | | driveway | Painting |
| Wells Station ES (2745) 2B | Please re stripe parking lot. | 2/26/14 | | | | Painting |
| Wells Station ES (2745) 2B | Crack in wall needs to be plastered and painted. | 6/5/14 | | | Room 107 Teachers Lounge RR | Painting |

| | | | | | |
|-------------------------------|---|----------|---------------------|-----------------------|----------|
| Wells Station ES (2745) 2B | Please paint main office door. | 6/26/14 | Administration Area | main hall | Painting |
| Wells Station ES (2745) 2B | Paint stall doors for WellsStation (Tom Ford) | 11/4/13 | | | Painting |
| Wells Station ES (2745) 2B | paint door to main office | 8/1/13 | | | Painting |
| Wells Station ES (2745) 2B | Paint plywood closets just installed by carpenters. See plant manger or princ. for color. | 5/6/14 | | Boys & Girls Restroom | Painting |
| Wells Station ES (2745) 2B | Paint new closet built to secure janitorial supplies in the restroom. See princ. for any details. | 4/1/14 | Restroom (Boys) | Main Hallway | Painting |
| Wells Station ES (2745) 2B | Paint new closet built to secure janitorial supplies in the restroom. See princ. for any details. | 4/1/14 | Restroom (Girls) | Main Hallway | Painting |
| Wells Station ES (2745) 2B | pipe leaking in ceiling in annex hall per Brenda Banks 416-2172 | 10/16/13 | | | Plumbing |
| Wells Station ES (2745) 2B | water pump in room 6 is leaking per Ms. banks 416-2172 | 11/6/13 | | | Plumbing |

| | | | | | |
|-------------------------------|---|----------|-----------------|------------|----------|
| Wells Station ES (2745) 2B | FAUCET SINK KINDERGARTEN HALL- COLD WATER SIDE RUNNING AT FULL FORCE- CAN'T CUT OFF OR CONTAIN-PLANT MGR BANKS 416-2172 KLR | 11/15/13 | | | Plumbing |
| Wells Station ES (2745) 2B | We have no hot water. | 11/19/13 | Mechanical Room | | Plumbing |
| Wells Station ES (2745) 2B | Connect washer and dryer. | 11/19/13 | Mechanical Room | Cafeteria | Plumbing |
| Wells Station ES (2745) 2B | test back flow device-os | 11/22/13 | | | Plumbing |
| Wells Station ES (2745) 2B | COMMODE G RR HANDICAP RR ANNEX BLDG-LEAKING FROM PIPE & KITCHEN RR COMMODE LEAKING FROM PIPE- PLANT MGR BANKS 416- 2172 KLR | 12/9/13 | | | Plumbing |
| Wells Station ES (2745) 2B | please unstop 2 toliets in boy's restroom. | 1/9/14 | Restroom (Boys) | main hall | Plumbing |
| Wells Station ES (2745) 2B | please unstop toliet in boy's restroom. | 1/9/14 | Restroom (Boys) | north hall | Plumbing |
| Wells Station ES (2745) 2B | please unstop toliet in boy's restroom. | 1/9/14 | Restroom (Boys) | Annex hall | Plumbing |

| | | | | | |
|-------------------------------|---|---------|------------------|---------------------------------------|----------|
| Wells Station ES (2745) 2B | please unstop the urnial in the boy's restroom. | 1/9/14 | Restroom (Boys) | north hall | Plumbing |
| Wells Station ES (2745) 2B | water fountain won't cut off. | 1/15/14 | Annex | 2nd fl hall | Plumbing |
| Wells Station ES (2745) 2B | please repair water fountain not working. | 1/21/14 | Hallway/Corridor | by rm 300 | Plumbing |
| Wells Station ES (2745) 2B | Faucet in hand sink near boys rest room will not stop running. | 9/18/13 | Hallway/Corridor | North hall | Plumbing |
| Wells Station ES (2745) 2B | Six toilets in these areas are not working properly. | 9/18/13 | Restroom (Girls) | Annex upstairs, North hall, Main hall | Plumbing |
| Wells Station ES (2745) 2B | Repair or replace drinking fountain not working at all. Equipment#063-039. | 7/30/13 | | | Plumbing |
| Wells Station ES (2745) 2B | HAND SINK ON THE KK HAND SINK PIPE CAME A LOOSE & 3 COMPARTMENT SINK IS STOPPED UP. SBE BANK 416-2172 | 8/5/13 | | | Plumbing |
| Wells Station ES (2745) 2B | 2-COM SINK IS LEAKING WATER & GREASE TRAP IS BACKING UP IN KITCHEN PLANT MGR- BANKS/416.2172 | 8/6/13 | | | Plumbing |

| | | | | | |
|-------------------------------|---|----------|------------------|---------------------------------------|----------|
| Wells Station ES (2745) 2B | Work with pumping service, requested by Kirk Wenzler. | 7/23/13 | | | Plumbing |
| Wells Station ES (2745) 2B | One toilet on main hall not working properly. North hall two not working properly. North hall one toilet seat broken. | 7/28/13 | Restroom (Girls) | Main hall, North hall, upstairs annex | Plumbing |
| Wells Station ES (2745) 2B | One toilet on main hall broken on bottom. Four toilets not working properly. | 7/28/13 | Restroom (Boys) | Main hall | Plumbing |
| Wells Station ES (2745) 2B | 2-COMPARTMENT SINK KITCHEN AREA-LEAKING FROM BOTTOM-CAN'T CONTAIN-PLANT MGR LEE 416-2172 KLR | 3/6/14 | | | Plumbing |
| Wells Station ES (2745) 2B | toilet clogged up. | 3/25/14 | Classroom | south rm. 109 | Plumbing |
| Wells Station ES (2745) 2B | WATER HEATER KITCHEN AREA-PILOT MAY HAVE GONE OUT, NO HOT WATER TO KITCHEN-PLANT MGR BANKS 416-2172 KLR | 12/17/13 | | | Plumbing |
| Wells Station ES (2745) 2B | Second toilet on the left leaking from the bottom. | 12/19/13 | Restroom (Girls) | North Hall | Plumbing |
| Wells Station ES (2745) 2B | Urinal not working at all. | 12/19/13 | Restroom (Boys) | North Hall | Plumbing |

| | | | | | |
|-------------------------------|--|---------|---------------------|-------------------|----------|
| Wells Station ES (2745) 2B | toilet won't stop running. | 2/27/14 | Restroom (Boys) | kindergarten hall | Plumbing |
| Wells Station ES (2745) 2B | Please repair leaking faucet. | 2/27/14 | Administration Area | Teacher's Lounge | Plumbing |
| Wells Station ES (2745) 2B | FLR DRAIN IS STOPPED UP BY PORT-156. PLANT MGR-LEE/416.6020 | 2/4/14 | | | Plumbing |
| Wells Station ES (2745) 2B | please un stop gutter. | 2/5/14 | Annex | back parking lot | Plumbing |
| Wells Station ES (2745) 2B | drain in boy's restroom is stopped up. | 2/11/14 | Restroom (Boys) | main hall | Plumbing |
| Wells Station ES (2745) 2B | SEWAGE SMELL IN RM-9 PLANT MGR-LEE/416.6020 | 2/12/14 | | | Plumbing |
| Wells Station ES (2745) 2B | WATER CONTINUES TO RUN FROM SINK IN RM-109. PLANT MGR-LEE/416.2172 | 2/19/14 | | | Plumbing |
| Wells Station ES (2745) 2B | please repair hand sink its leaking from p trap. | 2/26/14 | Hallway/Corridor | across from 300 | Plumbing |

| | | | | | |
|-------------------------------|---|---------|------------------|---------------------------------|----------|
| Wells Station ES (2745) 2B | toilet stopped up. | 4/29/14 | Restroom (Boys) | Annex | Plumbing |
| Wells Station ES (2745) 2B | water fountain leaking. | 5/1/14 | Hallway/Corridor | by girl's restroom main hall | Plumbing |
| Wells Station ES (2745) 2B | WATER FOUNTAIN MAIN HALL BY G RR-LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF- PLANT MGR LEE 416-2172 KLR | 5/2/14 | | | Plumbing |
| Wells Station ES (2745) 2B | Check and clean storm drains | 4/4/14 | | | Plumbing |
| Wells Station ES (2745) 2B | please repair sink that's leaking. | 4/4/14 | | main hall by boy's restroom | Plumbing |
| Wells Station ES (2745) 2B | Please repair hand sink that's leaking. | 4/9/14 | Hallway/Corridor | main hall by girl's restroom | Plumbing |
| Wells Station ES (2745) 2B | floor drain is stopped up. | 6/6/14 | Restroom (Girls) | north hall by rm. 201 | Plumbing |
| Wells Station ES (2745) 2B | Please unstop toilet. | 6/11/14 | Restroom (Boys) | main hall | Plumbing |

| | | | | | |
|-------------------------------|-----------------------------------|---------|---------------------|---|----------|
| Wells Station ES (2745) 2B | leaking toilet. | 5/13/14 | Restroom (Girls) | kk hall | Plumbing |
| Wells Station ES (2745) 2B | please unstop toilet. | 5/13/14 | Restroom (Boys) | main hall | Plumbing |
| Wells Station ES (2745) 2B | please repair roof leak. | 1/13/14 | Annex | elevator | Roof |
| Wells Station ES (2745) 2B | Leaking in these areas. | 9/25/13 | | Portable #156, Cafe, #2, and Upstairs hall | Roof |
| Wells Station ES (2745) 2B | Repair roof leaks | 8/1/13 | | | Roof |
| Wells Station ES (2745) 2B | These areas are leaking. | 7/24/13 | | North hall, Cafeteria, Resource Room | Roof |
| Wells Station ES (2745) 2B | roof leaking. | 1/31/14 | Portables | 329A | Roof |
| Wells Station ES (2745) 2B | ESL classroom has a roof leak. | 4/28/14 | Administration Area | ESL classroom | Roof |

| | | | | | |
|-------------------------------|---|---------|------------|-----------------|-------------|
| Wells Station ES (2745) 2B | please repair leak in portable. | 4/14/14 | Portables | 148 | Roof |
| Wells Station ES (2745) 2B | please repair roof leak. | 5/14/14 | Library | across from 206 | Roof |
| Wells Station ES (2745) 2B | please replace gutters on back side of portable. | 4/16/14 | Portables | 148 | Sheet Metal |
| Wells Station ES (2745) 2B | please install a vent for the dryer hook up. | 1/9/14 | Cafetorium | storeroom | Sheet Metal |
| Wells Station ES (2745) 2B | please repair locker #11. | 1/23/14 | Classroom | rm 300 | Sheet Metal |
| Wells Station ES (2745) 2B | Change out the Heat/AC wall package unit. | 3/7/14 | Portables | Portable 148 | Sheet Metal |
| Wells Station ES (2745) 2B | please repair locker #9 coming apart. | 2/27/14 | Classroom | rm. 206 | Sheet Metal |
| Wells Station ES (2745) 2B | please repair locker 17 & 19. | 2/6/14 | Classroom | 202 | Sheet Metal |

| | | | | | |
|-------------------------------|---|---------|-----------|---------------|-------------|
| Wells Station ES (2745) 2B | Please repair broken handles on lockers. | 5/29/14 | 1st Floor | rm. 102 & 113 | Sheet Metal |
|-------------------------------|---|---------|-----------|---------------|-------------|

| Count of Craft | Craft | | | | | | | | |
|---------------------------|----------|---------|-----------|------------|------|----------|----------|------|-------------|
| Location | Asbestos | Cabling | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Grand Total |
| White Station ES (2777) 2 | 1 | 2 | 25 | 75 | 38 | 5 | 44 | 18 | 208 |
| Grand Total | 1 | 2 | 25 | 75 | 38 | 5 | 44 | 18 | 208 |

| Location | Request Description | Submittal Date | Area Descript | Area Number | Craft |
|----------------------------|---|----------------|---------------------|--------------------------------|-----------|
| White Station ES (2777) 2A | Request installation for a 2.5' still pipe. | 5/28/14 | | B Hallway | Asbestos |
| White Station ES (2777) 2A | The finacial secretary moved in a new office and she has no phone jack and shes having to run a phone cord from her office to the computer room and someone may trip over it she needs this matter | 8/7/13 | | Financial secretary office | Cabling |
| White Station ES (2777) 2A | White StationES- WO#- 376338-- The Financial secretary office doe'nt have a phone jack needs attention because she has aphone cord running to the computer room across the floor don't want anybody to have a | 8/20/13 | Administration Area | Financial secretaries office | Cabling |
| White Station ES (2777) 2A | Door to lounge inside main office wo'nt shut all the way needs attention keeps getting hung when shutting. | 5/7/14 | Administration Area | Teachers lounge | Carpentry |
| White Station ES (2777) 2A | the fire inspector did and inspection on the building and the doors were not latching when we close them. needs attention. | 5/19/14 | Gym | Multipurpose rm north | Carpentry |
| White Station ES (2777) 2A | These hallways need cork board replaced. per principal. | 8/1/13 | Hallway/Corridor | 1st 2nd 3rd 4th 5th grade hall | Carpentry |
| White Station ES (2777) 2A | Move lift from Chimneyrock Ele to White Station Ele. | 8/6/13 | | | Carpentry |

| | | | | | |
|----------------------------|--|----------|------------------|----------------------|-----------|
| White Station ES (2777) 2A | Back door leading to the playground will NOT OPEN (it's jammed) there's a buzzer on the door, but will NOT manually OPEN either per Christopher Harper, Plant Mgr. 901.416.8900. | 8/7/13 | | | Carpentry |
| White Station ES (2777) 2A | I need some hard mineral tile so I can change it whe it leakes in classrooms. | 8/13/13 | Classroom | | Carpentry |
| White Station ES (2777) 2A | The door on the left leading outside gets jammed and stays open needs attention so no one will just walk in. | 9/3/13 | Hallway/Corridor | 3rd grade hall | Carpentry |
| White Station ES (2777) 2A | I needs some of the hard mineral tile because I have ceiling stains about 5 boxes of it.needs Attention. | 9/25/13 | Classroom | all over | Carpentry |
| White Station ES (2777) 2A | METAL BEAM IN MAIN HALL W/LIGHT FIXTURE ATTACHED-FALLING OUT OF CEILING PER SBE-PLANT MGR 416-8900 KLR | 10/7/13 | | | Carpentry |
| White Station ES (2777) 2A | Kindergarten and 1st Grade Hall back classroom windows are shattered per Christopher Harper, Plant Mgr. 416.8900. | 10/8/13 | | | Carpentry |
| White Station ES (2777) 2A | Middle door drags and wont close properly needs attention. | 11/11/13 | | front entrance | Carpentry |
| White Station ES (2777) 2A | There are 4 cafeteria tables that don't have locks on them in the cafeteria and kids keep mashing their fingers could we get locks put on those tables. | 11/13/13 | Cafeteria | in the dinining area | Carpentry |

| | | | | | |
|----------------------------|--|---------|---------------------|---------------------------------|-----------|
| White Station ES (2777) 2A | DOOR- FRONT ENTRY - HANDLE HAS BROKEN OFF & IT WON'T LOCK - CAN'T SECURE - PM/HARPER 416-8900 | 12/4/13 | | | Carpentry |
| White Station ES (2777) 2A | 2 peices of the tile in the floor have a big crack in them on the edge needs replacing. | 7/24/13 | Gym | multipurpose room | Carpentry |
| White Station ES (2777) 2A | There is a cord in her doorway that's taped down but it still not helping the people thats entering her office for questions their tripping up and we need a strip to cover that cord needs attention. | 7/25/13 | Administration Area | Financial secretary office | Carpentry |
| White Station ES (2777) 2A | The classroom door gets hung up when its being opened.needs attention. | 9/16/13 | Classroom | C108 | Carpentry |
| White Station ES (2777) 2A | Door gets hung up when closeing it and it won't shut up. | 9/16/13 | Administration Area | Teachers lounge | Carpentry |
| White Station ES (2777) 2A | The lock on the door turns freely and won't catch when turning it with key and when putting key in it won't open. | 9/18/13 | Hallway/Corridor | door leading out to play ground | Carpentry |
| White Station ES (2777) 2A | Their is a cracked tile in multipurpose room needs attention. | 1/10/14 | Gym | in multipurpose rm | Carpentry |
| White Station ES (2777) 2A | the strips in the door way have become very loose need resealing. | 1/10/14 | Hallway/Corridor | 2nd grade and 3rd | Carpentry |

| | | | | | |
|----------------------------|--|---------|---------------------|---------------------------------|------------|
| White Station ES (2777) 2A | The cork boards in the classrooms have started coming a loose needs attention. Per principal | 1/15/14 | Classroom | C107 D111 | Carpentry |
| White Station ES (2777) 2A | Door handle is jarring away from door and is about to come off needs attention. | 3/24/14 | Hallway/Corridor | left door leading to playground | Carpentry |
| White Station ES (2777) 2A | per mr harper 416-8900 the front door to parking lot and the back door to playground the handles have broken off of the doors | 3/31/14 | | | Carpentry |
| White Station ES (2777) 2A | We have a heraring impaired sign that was taking down but we have a new that needs to be put back up.needs attention | 4/8/14 | Grounds | by curve driveway | Carpentry |
| White Station ES (2777) 2A | The computerlab and classrooms allover the building needs corkboard replaced. per Principal and Sbe | 7/26/13 | Classroom | computerlab and classrooms | Carpentry |
| White Station ES (2777) 2A | The ballast in these light fixtures need replaceng and its a T8 ballast 4 bulb. | 6/4/14 | Classroom | A102,B110 | Electrical |
| White Station ES (2777) 2A | There is a pump thats in the outdoor classroom and it runs electricity out there and the power is not working needs immediate attention and also we have the adopters working on the classroom and they need the | 6/26/14 | Grounds | outdoor garden area | Electrical |
| White Station ES (2777) 2A | There are two ballast blown in the light fixtures in the main office needs attention they are T8 ballast 4 bulbs | 5/6/14 | Administration Area | main office | Electrical |

| | | | | | |
|----------------------------|--|---------|---------------------|--|------------|
| White Station ES (2777) 2A | Emergency lights need to be replaced in these areas which is the Mechanical room Rm A131, Multipurpose rm Northeast. | 5/19/14 | Mechanical Room | classroom A131 multipurpose room NorthEast | Electrical |
| White Station ES (2777) 2A | The cubbylight is out in this classroom. | 6/3/14 | Classroom | C109 | Electrical |
| White Station ES (2777) 2A | FCU - 065-149 CAFE - NOT COMING ON - PM/HARPER 416-8900 | 7/30/13 | | | Electrical |
| White Station ES (2777) 2A | The ballast has blown in both of these areas it is a four bulb T8 ballast. needs attention. | 7/31/13 | Administration Area | mainofficeand finance office | Electrical |
| White Station ES (2777) 2A | There is a wall socket that has cracked and you can see the wires in the wall need face plate on wall so no kid can stck his or her hand in it. | 7/31/13 | Classroom | A102 | Electrical |
| White Station ES (2777) 2A | Need special light bulbs to go in front entrance also in back entrance of hallways . | 7/31/13 | | | Electrical |
| White Station ES (2777) 2A | There is a light in the main office that the ballast is flickering and about to go out needs attention. it is the light as soon as you enter the office on the right side by the door. it is a T8 ballast. | 8/1/13 | Administration Area | main office | Electrical |
| White Station ES (2777) 2A | Need a lift over here to get all the insects out the lights in the hallway to high to reach. | 8/1/13 | Hallway/Corridor | Main hallway | Electrical |

| | | | | | |
|----------------------------|--|--------|------------------|----------------------------|------------|
| White Station ES (2777) 2A | On stage there is a light that needs changing to high to reach needs attention. | 8/1/13 | Gym | multipurpose rm | Electrical |
| White Station ES (2777) 2A | I have two flickering lights that are about to go out in this classroom needs attention. and its a T8 ballast four bulb. | 8/1/13 | Classroom | A125 | Electrical |
| White Station ES (2777) 2A | There is a light fixture in this classroom that flickers and it may disturb the children needs attention.its a T8 ballst needs attention. | 8/1/13 | Classroom | D104 | Electrical |
| White Station ES (2777) 2A | These areas have blown bulbs and they are special bulbs they are plug in floresent bulbs and the size is 18WQ/3500k M-29. | 8/1/13 | Hallway/Corridor | Main hallway and restrooms | Electrical |
| White Station ES (2777) 2A | These three classrooms have a malfunction in them when you put light bulbs in three of the lights in the light fixture come on and on light does'nt needs attention. | 8/2/13 | Classroom | C106,D107,D110 | Electrical |
| White Station ES (2777) 2A | There is a light fixture in this classroom that only lights up three bulbs in the light fixture and the fourth light won't come on needs attention it is a T8 ballast. | 8/2/13 | Classroom | C108 | Electrical |
| White Station ES (2777) 2A | There is a light flickering in this classroom needs attention.it is a T8 ballast. | 8/2/13 | Classroom | D104 | Electrical |
| White Station ES (2777) 2A | There is a ballast out in the cubby area in this room.needs attention. | 8/2/13 | Courtyard | D104 | Electrical |

| | | | | | |
|----------------------------|--|---------|---------------------|------------------------------|------------|
| White Station ES (2777) 2A | The clock in this classroom is out does'nt work needs attention. | 8/3/13 | Classroom | C111 | Electrical |
| White Station ES (2777) 2A | Needs clock replaced it has stopped running needs attention. | 8/3/13 | Classroom | B101 | Electrical |
| White Station ES (2777) 2A | The assist principal office has a blown ballast.its right over his desk needs attention. its a T8 ballast 4 bulb. | 8/9/13 | Administration Area | Asst Principals Office | Electrical |
| White Station ES (2777) 2A | There is a ballast blown in the pto closet and it is a T8 Ballast. | 8/9/13 | Administration Area | in the pto closet | Electrical |
| White Station ES (2777) 2A | There is a ballast blown in the art room it is aT8 ballast. needs attention. | 8/13/13 | Classroom | Art roomA134 | Electrical |
| White Station ES (2777) 2A | There are light bulbs out in the school and I needs some so the burned out ones can be replaced.They are the slim bulbs for the T8 ballast. | 8/19/13 | | for the whole school | Electrical |
| White Station ES (2777) 2A | The electric clock on the wall has two clocks on it but the one facing the door by the drop off is not working needs attention. | 8/23/13 | | clock facing curve drieway | Electrical |
| White Station ES (2777) 2A | There are receptacles that have shot sparks out of them when the cafeteria persons plug in cords and some are loose with covers off needs attention. | 8/28/13 | Cafeteria | serving area and by milk box | Electrical |

| | | | | | |
|----------------------------|--|----------|---------------------|---|------------|
| White Station ES (2777) 2A | Ballast has blown in light fixture needs attention.it is a4 bulb T8 ballast. | 8/30/13 | Hallway/Corridor | 3rd grade hallway | Electrical |
| White Station ES (2777) 2A | The ballast in this light fixture has blown it is a 4 bulb T8 ballast needs attention. | 9/3/13 | Cafeteria | in the back by dishwasher | Electrical |
| White Station ES (2777) 2A | The lights are out in the parkinglot and it is dangerous for the principal and the employees when they leave at night needs attention. it is a safety concern. | 9/26/13 | Parking Lot | parking lot | Electrical |
| White Station ES (2777) 2A | There are lights out by cafeteria under the canopy and also on the backside of each hallway need bulbs too. | 10/7/13 | | In Front of cafeteria and on backside of hallways | Electrical |
| White Station ES (2777) 2A | The middle light on the rightside of the parkinglot is out need bulb replaced | 10/14/13 | Parking Lot | the middle light on the rightside of parkinglot | Electrical |
| White Station ES (2777) 2A | There is a ballast blown in the light fixture in this classroom over the teachers desk it is a T8 ballast four bulb | 10/15/13 | Classroom | C106 | Electrical |
| White Station ES (2777) 2A | The ballast has burned out in this light fixture and it needs attention it is a aT8 ballast 4 bulb | 10/17/13 | Classroom | music rm A133 | Electrical |
| White Station ES (2777) 2A | The main clock is off and causing classroom clocks to be off. | 10/25/13 | Administration Area | main office | Electrical |

| | | | | | |
|----------------------------|---|----------|---------------------|----------------------------|------------|
| White Station ES (2777) 2A | main clocks need to be set for daylight savings time. | 10/28/13 | Administration Area | main clock | Electrical |
| White Station ES (2777) 2A | AHU #1 and #2 on roof are not working at all per Harper 416-8900 | 10/30/13 | | | Electrical |
| White Station ES (2777) 2A | RECEPTACLES OUTSIDE INSIDE OF FENCE AREA- HAVE NO POWER PER SBE-PLANT MGR HARPER 416-8900 KLR | 11/1/13 | | | Electrical |
| White Station ES (2777) 2A | Teacher needs clock in classroom old one broke if possible I need 3 battery clocks to put up . | 11/5/13 | Classroom | C108 | Electrical |
| White Station ES (2777) 2A | the lights are out in the parking lot again and I smeled a burned smell in the breaker box needs attentio. | 11/7/13 | Parking Lot | parkinglot | Electrical |
| White Station ES (2777) 2A | The ballast has blown in the light fixture in the second and 3rd grade hall it is aT8 ballast 4 bulb | 11/8/13 | Hallway/Corridor | 2nd and 3rd gradehall | Electrical |
| White Station ES (2777) 2A | PUMP FOR CHILLER- MAKING LOUD NOISES PER SBE-PLANT MGR HARPER 416-8900 KLR | 11/11/13 | | | Electrical |
| White Station ES (2777) 2A | The outlet that they plug the hotbox into has burned out needs attention so they can continue to heat the lunches up. | 11/13/13 | Cafeteria | in the back of the kitchen | Electrical |

| | | | | | |
|----------------------------|---|----------|------------------|---------------------------------|------------|
| White Station ES (2777) 2A | There is no outlet in her office need a outlet installed for school purpose. | 11/21/13 | Library | librians office | Electrical |
| White Station ES (2777) 2A | HEAT RM A117-NOT COMING ON-PLANT MGR HARPER 416-8900 KLR | 12/10/13 | | | Electrical |
| White Station ES (2777) 2A | There is a ballast blown in this classroom and its a four bulb T8 ballast. | 12/10/13 | Classroom | A 105 | Electrical |
| White Station ES (2777) 2A | Lights flickers in these classrooms needs attention. | 7/5/13 | Classroom | C102,A125, | Electrical |
| White Station ES (2777) 2A | Ballast has blown in cubbylight and its the first light up under the cubby on the leftside. | 7/24/13 | Classroom | C108 | Electrical |
| White Station ES (2777) 2A | The clocks throughout the building are off needs to be reset The main clock. | 7/24/13 | Classroom | classrooms and hallways | Electrical |
| White Station ES (2777) 2A | There are special light bulbs needed for the front entrance and hallways and outside in front and back hallways needs attention they are out. | 7/25/13 | Hallway/Corridor | main entrance hallways doorways | Electrical |
| White Station ES (2777) 2A | There are two light fixtures in this classroom with blinking ballast needs attention.They both are T8 ballast. | 7/26/13 | Classroom | C104 | Electrical |

| | | | | | |
|----------------------------|---|---------|------------------|-----------------------------|------------|
| White Station ES (2777) 2A | I have two lights out in the 2nd and 3rd grade hall the and the ballast is burned out it is T8 ballast 4 bulb. needs attention. | 9/9/13 | Hallway/Corridor | 2ndgrade and 3rd grade hall | Electrical |
| White Station ES (2777) 2A | RTU SERVES 2ND/3RD GRADE HALLS-NOT COMING ON-PLANT MGR HARPER 416-8900 KLR | 9/9/13 | | | Electrical |
| White Station ES (2777) 2A | PUMP-1 MECH RM-NOT COMING ON-PLANT MGR HARPER 416-8900 KLR | 9/16/13 | | | Electrical |
| White Station ES (2777) 2A | Ballast is blown out in light fixture in pantry closet. it is a T8 ballast four bulb | 9/16/13 | Cafeteria | in pantry closet | Electrical |
| White Station ES (2777) 2A | Unit in A125 is NOT COMING ON per Christopher Harper, Plant Mgr. 416.8900 | 1/7/14 | | | Electrical |
| White Station ES (2777) 2A | per Mr. Harper 416-8900 Room A134 UV is not running at all | 1/7/14 | | | Electrical |
| White Station ES (2777) 2A | There is a blown ballast in this classroom needs attention. it is a four bulb T8 ballast. | 1/22/14 | Classroom | over teachers desk D102 | Electrical |
| White Station ES (2777) 2A | Ballast has burned out inside of light fixture it is a T8 ballast 4 bulb needs attention. | 1/24/14 | Classroom | B112 | Electrical |

| | | | | | |
|----------------------------|--|---------|---------------------|---|------------|
| White Station ES (2777) 2A | The clocks have gone bad in these classrooms and I some clocks to replace the bad ones | 1/29/14 | Classroom | B101 D106 B111 | Electrical |
| White Station ES (2777) 2A | per mr harper 416-8900 room A134 not coming on (no heat) | 2/3/14 | | | Electrical |
| White Station ES (2777) 2A | There is a ballast blown in this classroom needs attention | 2/4/14 | Classroom | Rm D102 | Electrical |
| White Station ES (2777) 2A | There are ballast blown in cubby lights in the classrooms on D -hall need attention. | 2/6/14 | Classroom | D hall | Electrical |
| White Station ES (2777) 2A | UNIT is NOT COMING in A117 per Christopher Harper, Plant Mgr. 416.8900 | 2/11/14 | | | Electrical |
| White Station ES (2777) 2A | There are cubbylights out in this room needs attention the ballast is blown. | 2/20/14 | Classroom | C107 | Electrical |
| White Station ES (2777) 2A | The main clock needs setting for daylight savings time. | 2/26/14 | Administration Area | main office also for avon and north east prep | Electrical |
| White Station ES (2777) 2A | There is a ballast blown in the light fixture and it is aT8 ballast 4 bulb | 3/19/14 | Hallway/Corridor | 5th grade hall | Electrical |

| | | | | | |
|----------------------------|---|---------|-----------|-----------------|------------|
| White Station ES (2777) 2A | There is a ballast blown in the coaches office needs attention . and I need about four boxes of bulbs. | 3/19/14 | Classroom | coaches office | Electrical |
| White Station ES (2777) 2A | There is a ballast blown out in the fixture in the library it is a T8 ballast .needs attention. | 3/25/14 | Library | llibrary | Electrical |
| White Station ES (2777) 2A | The ballast in this cubby light is blown out needs attention. | 3/26/14 | Classroom | C109 | Electrical |
| White Station ES (2777) 2A | 2- UNITS NOT COMING ON IN RM-D106,A134. PLANT MGR- HARPER/416.8900 | 4/4/14 | | | Electrical |
| White Station ES (2777) 2A | The ballast in the light fixture blew out and it needs to be replaced and it is a T8 ballast 4 bulb. | 4/9/14 | Clinic | nurses station | Electrical |
| White Station ES (2777) 2A | The storm knocked the clocks off and their are out of sink needs to reset main clock in office before Tcaps | 4/25/14 | Classroom | all over | Electrical |
| White Station ES (2777) 2A | This classroom has a flickering light and it needs attention before Tcaps | 4/28/14 | Classroom | C102 | Electrical |
| White Station ES (2777) 2A | The ballast has blown in the light fixture it is a T8 ballast and needs attention before Tcap | 4/28/14 | Classroom | music room A133 | Electrical |

| | | | | | |
|----------------------------|--|---------|-----------|-----------|---------------------------------------|
| White Station ES (2777) 2A | UNIT NOT COOLING IN CAFE PLANT MGR- HARPER/834.2397 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | CHILLER MECH RM- KEEPS SHUTTING DOWN- PLANT MGR HARPER 416- 8900 KLR | 5/1/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | FCU - 065-134 MAIN OFC - BLOWING NOT COOLING - PM/HARPER 416-8900 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | These classrooms have unit ventilators in them and the control knobs are broke and need replacing in them the numbers for those units are as follows B102 065-187 C105 065-206 needs attention | 8/1/13 | Classroom | B102,C105 | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Monthly - Oil Lube & Belt- White Station Elementary - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | FCU-3 RM A133 STORERM- NOT COOLING-PLANT MGR HARPER 416-8900 KLR | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | CHILLER IS IN ALARM (106) PLANT MGR- HARPER/416.8900 | 8/19/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | A/C LEAKING in Rm C105 per Christopher Harper, Plant Mgr. at 901.416.8900 | 8/21/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|-----------|------|---------------------------------------|
| White Station ES (2777) 2A | Check why chiller keeps tripping | 8/29/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | A/C unit KNOB has been BROKEN OFF and the unit cannot be turned on per Christopher Harper, Plant Mgr. 416.8900 | 11/6/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | boiler down building cold per Mr. Harper 416-8900 | 12/5/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | The control knob is missing off this unit needs new one num 065-187 unit num. | 7/5/13 | Classroom | B102 | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Chiller has went into ALARM per Mr. C. Harper, Plant Mgr. @ 901.270.4267! | 7/12/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Chiller down per EMS 7.9.13 | 7/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Chiller down per EMS 7.11.13 | 7/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Chiller down per EMS 7.17.13 | 7/20/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station ES (2777) 2A | A/C RM A133-NOT COOLING-PLANT MGR HARPER 416-8900 KLR | 9/11/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | CHILLER KEEPS SHUTTING OFF PLANT MGR-HARPER/416.8900 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | RTU on C-Hall in Room C105 is making a LOUD NOISE per Christopher Harper, Plant Mgr. 416.8900 | 9/23/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | HEAT RM B102-KNOB BROKEN OFF, CAN'T CUT OFF OR ON-PLANT MGR HARPER 416-3900 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Monthly - Oil Lube & Belt-White Station Elementary - Refer to PM schedule details. | 3/9/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | BOILER-1 & BOILER-2-BOTH NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR HARPER 416-8900 KLR | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | FRESH AIR VENTS RM B104-MAKING NOISES-PLANT MGR HARPER 416-8900 KLR | 3/19/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | boilers down per EMS | 3/24/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|------------------|----------|---------------------------------------|
| White Station ES (2777) 2A | Air Unit is making a LOUD NOISE above Classroom B105 per Christopher Harper, Plant Mgr. 416.8900 | 3/25/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | chiller not coming on PLANT MGR-HARPER/834.2397 | 4/9/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | The ceiling has a leak and it has a pipe that keeps leaking needs attention. | 4/11/14 | Hallway/Corridor | B hall | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | per mr harper 416-8900 room D101 is blowing hot | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | A/C MULTIPURPOSE RM & PRIN'S OFC-BOTH NOT COOLING-PLANT MGR HARPER 416-8900 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | White Station Elementary needs filters changed in every classroom and on the roof. | 4/15/14 | Classroom | all over | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | per mr harper 416-8900 chiller is down | 4/17/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|---------------------|----------------------------------|---------------------------------------|
| White Station ES (2777) 2A | Daily - WhiteStation Elem Level 1 Water Treatmen - Refer to PM schedule details. | 1/31/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Yearly - Oil Samples-White Station Elementary - Refer to PM schedule details. | 9/24/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Yearly - Cooling Towers-Whitestation Elementary - Refer to PM schedule details. | 3/24/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Monthly - Filter-WhiteStation Elementary - Refer to PM schedule details. | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Monthly - Filter-WhiteStation Elementary - Refer to PM schedule details. | 9/9/13 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Monthly - Filter-WhiteStation Elementary - Refer to PM schedule details. | 5/5/14 | | | Heating/Ventilation /Air Conditioning |
| White Station ES (2777) 2A | Walls in office need touching up also in second grade hall and in front of bookstore and teachers lounge . | 6/3/14 | Administration Area | assistant principals main office | Painting |
| White Station ES (2777) 2A | We have some classrooms that need touching up along with some hallways needs attention. | 6/26/14 | Classroom | classrooms and hallways | Painting |

| | | | | | |
|----------------------------|--|---------|------------------|------------------------|----------|
| White Station ES (2777) 2A | repair hole in ceiling | 5/2/14 | | | Painting |
| White Station ES (2777) 2A | If possible I need these three rooms painted. | 6/2/14 | Classroom | B102 B110 C110 | Painting |
| White Station ES (2777) 2A | Need parkinglot restriped needs attention. | 9/17/13 | Parking Lot | front parking lot | Painting |
| White Station ES (2777) 2A | when turning water off it still runs and it needs attention. | 6/20/14 | | back dock water faucet | Plumbing |
| White Station ES (2777) 2A | Pipe in ceiling has started leaking again needs attention. | 6/20/14 | Hallway/Corridor | by parkinglot door | Plumbing |
| White Station ES (2777) 2A | There are several water fountains in this area not working and the one that is working a kid put his hand in the broken side and shocked himself this needs attention. | 5/20/14 | Restroom (Boys) | water fountains | Plumbing |
| White Station ES (2777) 2A | Pipe leaking in hallway. | 5/27/14 | | | Plumbing |
| White Station ES (2777) 2A | Request back flow test. | 5/28/14 | | | Plumbing |

| | | | | | |
|----------------------------|---|---------|-----------------|--------------------------------------|----------|
| White Station ES (2777) 2A | Need side plate put on water fountain because kids keep sticking their hands in it.and also don't won't anybody to get hurt. | 7/31/13 | Restroom (Boys) | 2nd grade hallway | Plumbing |
| White Station ES (2777) 2A | Push bar on water fountain is cracked and needs replacing before anybody gets cut. needs attention. | 7/31/13 | Restroom (Boys) | 4th and 5th grade boys restroom | Plumbing |
| White Station ES (2777) 2A | There are two water fountains that are not working the numbers are 065-142 065-144 and they are located by the 2nd grade boys and girls restroom. | 8/1/13 | | | Plumbing |
| White Station ES (2777) 2A | Back flow test | 8/8/13 | | | Plumbing |
| White Station ES (2777) 2A | There are side push bars off these two water fountains dont wont kids sticking their hands in it needs attention . no numbers on them . | 8/15/13 | | 5th grde and 2nd grade boys restroom | Plumbing |
| White Station ES (2777) 2A | A/C UNIT RM C105- LEAKING-SBE HARPER 416-8900 KLR | 8/21/13 | | | Plumbing |
| White Station ES (2777) 2A | A/C UNIT RM C103- LEAKING-SBE HARPER 416-8900 KLR | 8/21/13 | | | Plumbing |
| White Station ES (2777) 2A | Fan Coil unit is leaking - it is in a closet next to room A110 per Christopher Harper 416-8900 | 8/26/13 | | | Plumbing |

| | | | | | |
|----------------------------|---|----------|-----------------|-------------------------|----------|
| White Station ES (2777) 2A | UNIT IS LEAKING WATER IN RM-D112 PLANT MGR-HARPER/416.8900 | 8/29/13 | | | Plumbing |
| White Station ES (2777) 2A | When the cafeteria manager turns on the cold water in the sink he gets hot water coming out the cold side needs attention. | 8/30/13 | Cafeteria | in the kitchen | Plumbing |
| White Station ES (2777) 2A | The push bar on the water fountain has broke off the side and front needs attention. | 9/25/13 | Restroom (Boys) | 2nd grade boys restroom | Plumbing |
| White Station ES (2777) 2A | music room A124 a/c leaking per Mr. Harper 416-8900 | 10/3/13 | | | Plumbing |
| White Station ES (2777) 2A | There is a toilet that I put the snake down it to try to fix the problem but the toilet keeps over flowing.needs attention. | 10/16/13 | Restroom (Boys) | 1st grade boys | Plumbing |
| White Station ES (2777) 2A | On the hot water tank in the boilerroom the relief valve is leaking needs attention. | 10/17/13 | Mechanical Room | hot water tank | Plumbing |
| White Station ES (2777) 2A | per Harper 416-8900 assistant principal's toilet is constantly running | 10/30/13 | | | Plumbing |
| White Station ES (2777) 2A | SINK TEACHER'S LOUNGE LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF PER SBE-PLANT MGR HARPER 416-8900 KLR | 10/30/13 | | | Plumbing |

| | | | | | |
|----------------------------|---|----------|------------------|--------------------|----------|
| White Station ES (2777) 2A | The push bar on the water fountain has come off and need attention don't won't kids sticking their hands inside the water fountain. | 11/11/13 | Restroom (Boys) | boys 5th grade | Plumbing |
| White Station ES (2777) 2A | The toilet constantly runs nonstop needs attention. | 11/15/13 | Restroom (Boys) | 5th grade | Plumbing |
| White Station ES (2777) 2A | There is a toilet in the girls restroom that constantly runs nonstop needs attention | 11/15/13 | Restroom (Girls) | 5th grade restroom | Plumbing |
| White Station ES (2777) 2A | per mr harper 416-8900 discolored water in all kindergarten rooms coming up out of sink | 11/25/13 | | | Plumbing |
| White Station ES (2777) 2A | Sewer out in the PARKING LOT has a foul odor per Christopher Harper, Mgr. 416.8900 | 12/2/13 | | | Plumbing |
| White Station ES (2777) 2A | NO HOT WATER IN KITCHEN PLANT MGR- HARPER/834.2397 | 12/3/13 | | | Plumbing |
| White Station ES (2777) 2A | The urinal in the corner of the 5th grade restroom needs attention it is leaking from the bottom | 12/4/13 | Restroom (Boys) | 5th grade | Plumbing |
| White Station ES (2777) 2A | WATER HEATER KITCHEN AREA-PILOT HAS GONE OUT, NO HOT WATER TO KITCHEN AREA-PLANT MGR HARPER 416-8900 KLR | 12/16/13 | | | Plumbing |

| | | | | | |
|----------------------------|--|----------|------------------|---------------------------|----------|
| White Station ES (2777) 2A | WATER HEATER MECH RM HAS BURST & WATER EVERYWHERE PER SBE-PLANT MGR HARPER 416-8900 KLR | 12/18/13 | | | Plumbing |
| White Station ES (2777) 2A | Assist zone with water heater | 12/20/13 | | | Plumbing |
| White Station ES (2777) 2A | WATER FOUNTAIN NEAR THE THE BOYS RSTRM ON THE 5TH GRADE HALL CANNOT BE TURNED OFF AND IS CONSTANTLY RUNNING. SBE HARPER 416-. 8900 | 7/24/13 | | | Plumbing |
| White Station ES (2777) 2A | A/C RM D111-LEAKING-PLANT MGR HARPER 416-8900 KLR | 9/10/13 | | | Plumbing |
| White Station ES (2777) 2A | The flush valve on toilet won't flush properly also hard to flush after being used.needs attention. | 1/14/14 | Restroom (Girls) | 4th and 5th grade | Plumbing |
| White Station ES (2777) 2A | The water fountain side push bar is off and broke needs new push bar | 1/22/14 | Restroom (Boys) | second grade | Plumbing |
| White Station ES (2777) 2A | Toilet needs attention out of order keeps flooding . | 1/23/14 | Restroom (Girls) | third stall on right side | Plumbing |
| White Station ES (2777) 2A | The handled has broken off the faucet on the sink in the nurses station needs attention. | 1/29/14 | Clinic | nurses station | Plumbing |

| | | | | | |
|----------------------------|--|---------|------------------|---------------------------|----------|
| White Station ES (2777) 2A | There are two faucets that keep running and won't stop needs attention. | 2/4/14 | Restroom (Boys) | | Plumbing |
| White Station ES (2777) 2A | (2) URINALS B RR 4TH GR AREA-ARE OVERFLOWING-PLANT MGR HARPER 416-8900 KLR | 2/11/14 | | | Plumbing |
| White Station ES (2777) 2A | There is a sink in this classroomthat needs unclogging it stops up everytime she runs water needs attention. | 2/18/14 | Classroom | B109 | Plumbing |
| White Station ES (2777) 2A | 2-URINALS ARE BACKING UP IN B/RR 5TH GRADE HALL PLANT MGR- HARPER/834.2397 | 2/19/14 | | | Plumbing |
| White Station ES (2777) 2A | There are several water fountains that are'nt working in the 1st and second grade boys. | 3/24/14 | Restroom (Boys) | 1stgrade and second grade | Plumbing |
| White Station ES (2777) 2A | There is aleake dripping from the water fountain in the fifth grade girls restroom. needs attention. | 4/1/14 | Restroom (Girls) | 5th girls restroom | Plumbing |
| White Station ES (2777) 2A | The faucet handle has broken of sink needs attention. | 4/10/14 | Classroom | art room | Plumbing |
| White Station ES (2777) 2A | There are leaks in these classrooms and it constantly leakes needs attention. | 5/14/14 | Classroom | C105, C106,B103B105 | Roof |

| | | | | | |
|----------------------------|--|----------|-----------|-------------------------|------|
| White Station ES (2777) 2A | All these classrooms have leakes and needs attention. | 9/24/13 | Classroom | B111,C106,D111,D110 | Roof |
| White Station ES (2777) 2A | There is aleake in this area that needs attention . | 10/16/13 | Cafeteria | in the back by venthood | Roof |
| White Station ES (2777) 2A | There are several leakes in the library after I changed the ceiling tiles they get stained from water when it rains needs attention. | 10/16/13 | Library | A128 | Roof |
| White Station ES (2777) 2A | There was a big leak in classroom C105 and it spreaded to 2 tiles also The A hallway was leaking to . | 11/1/13 | Classroom | C105,A hallway | Roof |
| White Station ES (2777) 2A | There are leakes in these classrooms and they are leaking on the computers. | 12/10/13 | Classroom | B103 D109 | Roof |
| White Station ES (2777) 2A | There are several leakes in the library some in the back right corner and on side right wall needs attention . | 7/23/13 | Library | A128 | Roof |
| White Station ES (2777) 2A | There are some leakes in this classroom needs on the right side wall needs attention. | 7/23/13 | Classroom | Music Rm A133 | Roof |
| White Station ES (2777) 2A | Roof is leaking in classroom needs attention | 1/10/14 | Classroom | B111 B105 | Roof |

| | | | | | |
|----------------------------|---|---------|-----------|---|------|
| White Station ES (2777) 2A | There are leakes in these areas and they need attention. | 2/3/14 | Classroom | B105 D112 A125 D hallway | Roof |
| White Station ES (2777) 2A | There is aleake coming down the wall in the music room.needs attention. | 2/4/14 | Classroom | music A133 | Roof |
| White Station ES (2777) 2A | There is aleake in the cafeteria bathroom needs attention. | 2/4/14 | Cafeteria | bath room in kitchen | Roof |
| White Station ES (2777) 2A | There is aleak in this office needs attention. | 2/4/14 | | coaches office | Roof |
| White Station ES (2777) 2A | there is aleake in the cafeteria by the window. needs attention. | 2/4/14 | Cafeteria | by the windowfacing the hallway | Roof |
| White Station ES (2777) 2A | There is aleak that has cause the ceiling outside to hang and have abig bubble in it needs attention. | 2/17/14 | Cafeteria | outside door in cafeteria near parkinglot | Roof |
| White Station ES (2777) 2A | All These rooms have leakes and after I have change ceiling tile it has leaked again. | 3/7/14 | Classroom | library, B103,B104,B107,B112 | Roof |
| White Station ES (2777) 2A | There is a leake in the ceiling by the windows facing the parking lot | 3/18/14 | Cafeteria | over by windows by parkinglot | Roof |

| | | | | | |
|----------------------------|---|---------|------------------|--------------------------------|------|
| White Station ES (2777) 2A | There is aleak in the roof in front of this restroom. needs attention also in the library, in classrooms tooB105 B103 | 4/28/14 | Restroom (Girls) | In front of 2nd grade restroom | Roof |
|----------------------------|---|---------|------------------|--------------------------------|------|

| Count of Craft | Craft | | | | | | | | | Grand Total |
|------------------------|----------|----------|-----------|------------|------------|-----------|------------|----------|-------------|-------------|
| Location | Asbestos | Cabing | Carpentry | Electrical | HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
| Site Station HS (2780) | 3 | 2 | 72 | 83 | 138 | 28 | 154 | 9 | 4 | 494 |
| Grand Total | 3 | 2 | 72 | 83 | 138 | 28 | 154 | 9 | 4 | 494 |

| Location | Request Description | Submittal Dat | Area Descript | Area Number | Craft |
|----------------------------|--|---------------|---------------------|---------------------------------|-----------|
| White Station HS (2780) 2A | Please replace ceiling tile in the lobby of the main gym that depicts mold stains. There is student signing on Friday, November 15, 2013 in the gym lobby for college. | 11/12/13 | Gym | | Asbestos |
| White Station HS (2780) 2A | remove carpet do to water damage and replace with tile floor | 2/11/14 | Gym | small gym / coaches office | Asbestos |
| White Station HS (2780) 2A | looks like mold stains on wall | 8/22/13 | Administration Area | freshman building / office area | Asbestos |
| White Station HS (2780) 2A | i need 4 drops in band room (Request Network Cabling Project Management). | 8/14/13 | Classroom | band room | Cabling |
| White Station HS (2780) 2A | bell need to be set they are in the fire alarm panel (Request Intercom or Electronics Repair). | 8/22/13 | | | Cabling |
| White Station HS (2780) 2A | hang banner in gym they are replacement banner that was lost , we have banner at school | 6/2/14 | Gym | | Carpentry |
| White Station HS (2780) 2A | repair wood floor in gym | 6/6/14 | Gym | small gym | Carpentry |

| | | | | | |
|----------------------------|---|---------|------------|--------------------------|-----------|
| White Station HS (2780) 2A | Please hang the clock in the Cafeteria. Building Engineer/Plant Manager has clock in the office. | 5/15/14 | Cafeteria | A102 | Carpentry |
| White Station HS (2780) 2A | DOOR- EXTERIOR (1) EAST SIDE OF FRESHMAN BLDG - (1) NE ANNEX BLDG WITH WEATHER STRIPPING - HAZARDOUS - (1) INTERIOR BY M139 G RR MAIN BLDG - CLOSER IS BROKEN. PM/CLAY 416 | 5/19/14 | | | Carpentry |
| White Station HS (2780) 2A | Please repair the chair on the northside of the auditorium. | 5/7/14 | Auditorium | Northside 1st Row Column | Carpentry |
| White Station HS (2780) 2A | Please replace combination lock on locker#1033 the unit is missing/broken can not use the locker. | 5/7/14 | Annex | 1st floor west hallway | Carpentry |
| White Station HS (2780) 2A | WINDOW - A/C UNIT REAR EAST GYM- WAS PULLED OUT LAST NIGHT - DUE TO BREAK IN - NEED TO BE BOARDED UP - CAN'T SECURE - PM/CLAY 416-8880 | 5/5/14 | | | Carpentry |
| White Station HS (2780) 2A | fix closer on outside door in gym lobby | 4/22/14 | Gym | gym/area | Carpentry |
| White Station HS (2780) 2A | NW ENTRANCE DOOR CAFE AREA-NOT CLOSING, WILL NOT BE ABLE TO SECURE BLDG- PLANT MGR CLAY 416-8880 KLR | 4/23/14 | | | Carpentry |
| White Station HS (2780) 2A | Please adjust the fire doors they are not closing properly when the alarm trips. | 4/24/14 | Annex | Freshman Building | Carpentry |

| | | | | | |
|----------------------------|---|---------|------------|----------------------|-----------|
| White Station HS (2780) 2A | repair door to closet in auditorium | 3/20/14 | Auditorium | Auditorium / lobby | Carpentry |
| White Station HS (2780) 2A | repair closer on outside doors in gym lobby | 3/21/14 | Gym | gym/ lobby | Carpentry |
| White Station HS (2780) 2A | install 2 white board in room M205 | 3/21/14 | Classroom | | Carpentry |
| White Station HS (2780) 2A | repair door closer by G103 and M222 A in main building | 3/24/14 | | | Carpentry |
| White Station HS (2780) 2A | repair face plate on door room M019 | 3/24/14 | Classroom | main building /M019 | Carpentry |
| White Station HS (2780) 2A | install 2 white board in classroom ,mo14, and 2 in m227 | 3/27/14 | Classroom | main building / M014 | Carpentry |
| White Station HS (2780) 2A | repair broken chair in back of auditorium seat 101 | 4/4/14 | Auditorium | Auditorium | Carpentry |
| White Station HS (2780) 2A | install bulletin board by room A102 have one at school | 4/7/14 | Cafetorium | cafetorium / A102 | Carpentry |

| | | | | | |
|----------------------------|---|----------|------------------|---------------------------|-----------|
| White Station HS (2780) 2A | Provide Handle in Hallway on Restroom Door: Students are locking the door by going inside the restroom custodian cannot lock the door from the hallway to prevent entry. | 4/9/14 | Restroom (Boys) | Annex E109 Adjacent to | Carpentry |
| White Station HS (2780) 2A | remove broken glass in boys restroom top floor by M234 | 4/10/14 | | main building/restroom | Carpentry |
| White Station HS (2780) 2A | screw coming out of door in cafe | 4/10/14 | Cafeteria | cafeteria/ back door | Carpentry |
| White Station HS (2780) 2A | per crutchfield 416-1880 cafeteria outside door the screen coming off hinges and lets flies, etc in | 4/14/14 | | | Carpentry |
| White Station HS (2780) 2A | Please install brackets on wall to hang screen for daily assignments for the students. | 11/12/13 | Classroom | M-132 | Carpentry |
| White Station HS (2780) 2A | Security Issue: Please repair the door it is locked but will open when pulled from the outside. | 11/15/13 | Auxiliary Gym | North East Entrance Doors | Carpentry |
| White Station HS (2780) 2A | Please install wooden back brace platform and brackets to hang the Periodic Table. | 11/23/13 | Classroom | M132 | Carpentry |
| White Station HS (2780) 2A | Please repair the handle to the girls restroom. The screws from inside of door have come loose which holds the handle in place. | 11/26/13 | Restroom (Girls) | Band Building | Carpentry |

| | | | | | |
|----------------------------|--|----------|-----------|--------------------------|-----------|
| White Station HS (2780) 2A | Please repair broken hardwood on basketball court approximately 3" long piece of wood is missing. | 12/4/13 | Gym | West Basketball Court | Carpentry |
| White Station HS (2780) 2A | Please install bulletin board in the north east corner wall. Coach Billings has board. | 12/4/13 | Gym | East Basketball Court | Carpentry |
| White Station HS (2780) 2A | Please adjust door mold and door closer. The door does not latch in the closed position. | 12/11/13 | Cafeteria | South West Entrance Door | Carpentry |
| White Station HS (2780) 2A | Please provide the small screws to replace missing screws on the face plate and plate where the latch comes out. The plant manager would be able to put the screws in place. | 12/12/13 | Classroom | All buildings | Carpentry |
| White Station HS (2780) 2A | Please replace the room sign for M240. Te sign has been removed from the outside of the classroom. | 12/16/13 | Classroom | M-240 | Carpentry |
| White Station HS (2780) 2A | install one white board in room F122 | 8/8/13 | Classroom | Freshman Bid. /F122 | Carpentry |
| White Station HS (2780) 2A | replace door closer it is leaking oil down door | 8/8/13 | Classroom | annex /E 207 | Carpentry |
| White Station HS (2780) 2A | Please reinstall the mull adjacent to the library in the main building hallway. The screws have come out of the mull. | 8/8/13 | | | Carpentry |

| | | | | | |
|----------------------------|---|---------|-----|-----------------------|-----------|
| White Station HS (2780) 2A | 2nd floor girls restroom across from E205 can't get into, door/lock messed up and it has handicap stall per Mr. Crutchfield 416-1880 | 9/3/13 | | | Carpentry |
| White Station HS (2780) 2A | OUTSIDE SMALL GYM DOOR, CANT SECURE . PLANT MGR- CRUTCHFIELD/416.1880 | 9/3/13 | | | Carpentry |
| White Station HS (2780) 2A | replace pads around back board we have pads at school ,someone could get hurt | 9/9/13 | Gym | gym area | Carpentry |
| White Station HS (2780) 2A | In the Main Large Gym: Please repair consession stand overhead doors to open close and lock. | 9/10/13 | | | Carpentry |
| White Station HS (2780) 2A | I NEED 4 HOOKS HUNG FROM WALL | 9/12/13 | Gym | EAST GYM | Carpentry |
| White Station HS (2780) 2A | Please repair door closer adjacent to the ticket booth in the Main Large Gym. The closer is miising the bolt to hold the (2) pieces together to close the door. | 9/12/13 | | | Carpentry |
| White Station HS (2780) 2A | install lock on locker room door in gym | 1/16/14 | Gym | gym /girl locker room | Carpentry |
| White Station HS (2780) 2A | OUTSIDE GYM DOOR, CANT SECURE PLANT MGR- CRUTCHFIELD/416.8880 | 1/16/14 | | | Carpentry |

| | | | | | |
|----------------------------|---|---------|---------------------|----------------------------|-----------|
| White Station HS (2780) 2A | install one white board in prin. office f117 | 1/16/14 | Administration Area | freshman building /f 117 | Carpentry |
| White Station HS (2780) 2A | GYM DOOR CANT SECURE. PLANT MGR- CRUTCHFIELD/416.8880 | 1/24/14 | | | Carpentry |
| White Station HS (2780) 2A | stall door broken boys restroom | 2/10/14 | Restroom (Boys) | East building /1floor | Carpentry |
| White Station HS (2780) 2A | PUT METAL BAR BACK UP IN STORAGE ROOM | 2/12/14 | Classroom | ROTC BUILDING | Carpentry |
| White Station HS (2780) 2A | hardware is off the door on stairwell #7 | 2/13/14 | Hallway/Corridor | east annex/ top floor | Carpentry |
| White Station HS (2780) 2A | repair hardware cant lock this door this is and inside door | 2/13/14 | Cafeteria | cafe by room | Carpentry |
| White Station HS (2780) 2A | install one white board i have one on at school, and 2 in boys locker room , and hang on in coach office have board on site | 2/18/14 | Gym | small gym / coaches office | Carpentry |
| White Station HS (2780) 2A | repair fence by scorebord on field | 2/18/14 | Athletic Field | softball field | Carpentry |

| | | | | | |
|----------------------------|---|---------|---------------------|----------------------|-----------|
| White Station HS (2780) 2A | ENTRANCE DOOR MAIN BLDG BREEZEWAY AREA-CTR MULL DAMAGED-WONT BE ABLE TO SECURE-PLANT MGR CRUTCHFIELD 416-8880 KLR | 2/26/14 | | | Carpentry |
| White Station HS (2780) 2A | DOOR LEVER IS BROKE , WONT OPEN IN RM-E300 PLANT MGR-CRUTCHFIELD/848.5746 | 2/27/14 | | | Carpentry |
| White Station HS (2780) 2A | repair fence that tree has fallen on around baseball field | 7/3/13 | Grounds | parking lot | Carpentry |
| White Station HS (2780) 2A | Carpenter needed cannot security door in Main Bldg back entrance on E. side near Gym. Per Dennis Crutchfield, Plant Mgr. at 416.1880. | 7/9/13 | | | Carpentry |
| White Station HS (2780) 2A | need 2 boxes of ceiling tile | 7/19/13 | Custodial | plant mgr. office | Carpentry |
| White Station HS (2780) 2A | door comming of fram | 7/19/13 | Cafeteria | cafe. serving line | Carpentry |
| White Station HS (2780) 2A | install bulletin board in E205 see Ms Brown | 7/25/13 | Administration Area | annex/E205 | Carpentry |
| White Station HS (2780) 2A | install white board in class room M130 | 7/26/13 | Classroom | main building / m130 | Carpentry |

| | | | | | |
|----------------------------|--|---------|------------------|----------------|-----------|
| White Station HS (2780) 2A | repair floor have 20 tile that are coming up | 7/26/13 | Portables | portables/p296 | Carpentry |
| White Station HS (2780) 2A | East annex under canopy center piece is out of door and cannot lock and secure. Per George Clay 416-8880 | 7/31/13 | | | Carpentry |
| White Station HS (2780) 2A | install 2 white board in gym lobby | 8/14/13 | Gym | Gym lobby | Carpentry |
| White Station HS (2780) 2A | change hardware out on door to stairwell cant unlock door | 8/29/13 | Hallway/Corridor | annex building | Carpentry |
| White Station HS (2780) 2A | repair bleacher in gym , have several bracket that are broken | 9/17/13 | Gym | SR. gym | Carpentry |
| White Station HS (2780) 2A | PARTITION CAFE STAGE- HAS FALLEN-PLANT MGR CRUTCHFIELD 416-8880 KLR | 9/27/13 | | | Carpentry |
| White Station HS (2780) 2A | Request Air Condition unit be install in the gym. | 9/30/13 | | | Carpentry |
| White Station HS (2780) 2A | repair or replace hardware on door to library on outside door | 10/2/13 | | | Carpentry |

| | | | | | |
|----------------------------|--|----------|------------|------------------------------|------------|
| White Station HS (2780) 2A | Please repair door closer. | 10/17/13 | Classroom | M-109 | Carpentry |
| White Station HS (2780) 2A | Please repair door closer on the south entrance door. | 10/17/13 | Auditorium | Front Entrance | Carpentry |
| White Station HS (2780) 2A | Please repair the counter overhead doors to roll up and down and lock. | 10/17/13 | Gym | Consession Stands | Carpentry |
| White Station HS (2780) 2A | Rooms #111 and #115 need screw replaced in the door locks. | 10/23/13 | Annex | Freshman Building 1st. Floor | Carpentry |
| White Station HS (2780) 2A | Please repair the side entrance door of the Auditorium to the south parking lot. The mechanism hangs up and will not release to be locked. | 10/23/13 | Auditorium | Side Entrance south | Carpentry |
| White Station HS (2780) 2A | Please install bulletin board. The Teacher has the board to be installed. | 11/6/13 | Classroom | M134 | Carpentry |
| White Station HS (2780) 2A | Request power be connected to food bar/Concession Stand in the cafeteria. | 5/27/14 | | cafeteria | Electrical |
| White Station HS (2780) 2A | CHILLER PUMP MECH RM- NOT CIRCULATING, NOT COOLING-PLANT MGR WAKEFIELD 416-8880 KLR | 6/2/14 | | | Electrical |

| | | | | | |
|----------------------------|---|---------|---------------------|--------------------------------|------------|
| White Station HS (2780) 2A | UNIT NOT COMING ON IN ANNEX BLDG PLANT MGR- CARRIE/416.8880 | 6/5/14 | | | Electrical |
| White Station HS (2780) 2A | THE FIRE ALARM ENERGY BUTTON IS OFF THE WALL | 6/9/14 | 1st Floor | E ANNEX | Electrical |
| White Station HS (2780) 2A | BLEACHERS EAST GYM AREA-MOTOR NOT WORKING, NOT COMING OUT OR IN-THEY ARE HAVING A PROGRAM IN GYM THIS MORNING PER SBE-PLANT MGR CLAY 416- 8880 416 | 5/15/14 | | | Electrical |
| White Station HS (2780) 2A | Please provide lights for the gym concession stand. | 5/16/14 | Concession Stand | GYM | Electrical |
| White Station HS (2780) 2A | LIGHTS HAVE NO POWER IN G/LOCKER RM GYM PLANT MGR- CLAY/416.8880 | 5/19/14 | | | Electrical |
| White Station HS (2780) 2A | Please replace broken light fixture. | 5/5/14 | Custodial Closet | Cafeteria #C101 | Electrical |
| White Station HS (2780) 2A | Please repair electrical receptacles in the lobby area. The units are not working. | 4/29/14 | Gym | Front Lobby Entrance | Electrical |
| White Station HS (2780) 2A | Please repair or replace the bulbs. The north parking lot has no lights. | 3/18/14 | Parking Lot | North adjacent to large gym | Electrical |

| | | | | | | |
|----------------------------|---|----------|-------------|-------------------------------------|--|------------|
| White Station HS (2780) 2A | PARTIAL ELECTRICAL OUTAGE in the MAIN OFFICE per Dennis Crutchfield, Plant Mgr. 848.5746 | 3/25/14 | | | | Electrical |
| White Station HS (2780) 2A | FIRE DOORS in FRESHMAN ACADEMY-the MAGNET is not holding the doors OPEN per Dennis Crutchfield, Plant Mgr. 416.1880 | 4/7/14 | | | | Electrical |
| White Station HS (2780) 2A | i need 2 lights replace in elevator | 4/16/14 | Elevator | new building | | Electrical |
| White Station HS (2780) 2A | per george clay 416-8880 heat not coming on in band room, cafeteria, p/m office, east building | 11/25/13 | | | | Electrical |
| White Station HS (2780) 2A | Fire Alarm panel system trouble strobe open. | 11/26/13 | 1st Floor | G103 | | Electrical |
| White Station HS (2780) 2A | per george clay 416-8880 cafeteria unit not coming on and east building keeps cutting off | 12/9/13 | | | | Electrical |
| White Station HS (2780) 2A | Please repair or replace the bulbs in the building outside light fixtures. The parking lot is dark between the gym entrance and the E-Building. | 12/12/13 | Parking Lot | Between E-Building & Small East Gym | | Electrical |
| White Station HS (2780) 2A | Please repair Fire Alarm Strobe Light Panel. The unit is hanging from the receptacle. Needs to be reinstalled with a cage to prevent being removed from wall. | 12/15/13 | Gym | North Boys Restroom | | Electrical |

| | | | | | |
|----------------------------|--|----------|-------------|--------------------------------------|------------|
| White Station HS (2780) 2A | Please repair the west side bleachers switch. The switch to open and close the bleachers is not working. | 12/17/13 | Gym | Small East Gym | Electrical |
| White Station HS (2780) 2A | E306 a/c not working at all per Dennis Crutchfield 416-1888 | 9/3/13 | | | Electrical |
| White Station HS (2780) 2A | have 4 lights out on school front of main building on corner by storm drain , 1 by port. 296, and back of school on main building over door facing baseball field, and 1 on 3 story building on wall facing north above door | 9/7/13 | Courtyard | front of school | Electrical |
| White Station HS (2780) 2A | The push button is hanging out of the wall. Please repair electrical panel to the elevator switch on the second floor. | 12/18/13 | 2nd Floor | Main Building | Electrical |
| White Station HS (2780) 2A | Contract new baseball scoreboard installation/wiring. 2942 Budget | 12/19/13 | | | Electrical |
| White Station HS (2780) 2A | Please replace outside lights not working. | 12/23/13 | Parking Lot | Main Gym & Main Building | Electrical |
| White Station HS (2780) 2A | Please repair outside lights not working. | 12/23/13 | Parking Lot | East Gym & Practice Football Field | Electrical |
| White Station HS (2780) 2A | Please repair outside lights not working. | 12/23/13 | Parking Lot | SE- Freshman Building and Auditorium | Electrical |

| | | | | | |
|----------------------------|--|----------|-------------|---------------------|------------|
| White Station HS (2780) 2A | Please replace lights the pole lights do not come on around the parking lot. | 12/23/13 | Parking Lot | North of Main GYM | Electrical |
| White Station HS (2780) 2A | CHECK TIMER FOR THE OUTSIDE LIGHTS - LIGHTS ARE NOT COMING ON - PM/CRUTCHFIELD 416-1880 | 1/6/14 | | | Electrical |
| White Station HS (2780) 2A | Unit is NOT COMING ON in the CAFETERIA per Mr. Crutchfield, Plant Mgr. 416.1880 | 1/7/14 | | | Electrical |
| White Station HS (2780) 2A | HEAT RM M110-HAS NO POWER TO IT PER SBE-PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/10/14 | | | Electrical |
| White Station HS (2780) 2A | BREAKER AUDITORIUM AREA FOR OUTSIDE LIGHTS-KEEPS TRIPPING PER SBE-PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/10/14 | | | Electrical |
| White Station HS (2780) 2A | EXPOSE WIRE IN B/RR ACROSS FROM TEACHERS' LOUNGE. PLANT MGR- CRUTCHFIELD/848.5746 | 1/14/14 | | | Electrical |
| White Station HS (2780) 2A | UNIT NOT COMING ON IN RM-M242 PLANT MGR- CRUTCHFIELD/416.8880 | 1/15/14 | | | Electrical |
| White Station HS (2780) 2A | have 3 lights out on north side of parking lot by fence that are out, have 1 light out by portables 296 that out | 1/16/14 | Parking Lot | student parking lot | Electrical |

| | | | | | |
|----------------------------|---|---------|------------------|-----------------------|------------|
| White Station HS (2780) 2A | have 3 light out on building in teacher lot , have no light in area br rotc building | 1/16/14 | Parking Lot | teacher parking lot | Electrical |
| White Station HS (2780) 2A | have 3 light out on south of building that are out , and 1 that is also out by cafe near breeze way | 1/16/14 | Parking Lot | by new building | Electrical |
| White Station HS (2780) 2A | need 1 case of light bulbs, soft white mini twist 100w bulbs | 1/16/14 | Custodial | light above doos | Electrical |
| White Station HS (2780) 2A | i have no light in stairwell | 1/22/14 | Hallway/Corridor | east annex/ stairwell | Electrical |
| White Station HS (2780) 2A | no lights in stairwell in east annex per Mr. Crutchfield 416-1880 | 1/22/14 | | | Electrical |
| White Station HS (2780) 2A | no power to the dryer in the small gym per Crutchfield 416-1880 | 1/23/14 | | | Electrical |
| White Station HS (2780) 2A | FIRE ALARM IS SHOWING TROUBLE PLANT MGR- CRUTCHFIELD/416.8880 | 1/31/14 | | | Electrical |
| White Station HS (2780) 2A | install on electrical pole in classroom | 2/18/14 | Classroom | main building / M120 | Electrical |

| | | | | | |
|----------------------------|--|---------|---------------------|-------------|------------|
| White Station HS (2780) 2A | Please change the three way switches on the north and south walls to prevent the students from cutting off the outside walkway lights. | 2/18/14 | Auditorium | | Electrical |
| White Station HS (2780) 2A | set clock for day light saving time | 2/25/14 | Administration Area | main office | Electrical |
| White Station HS (2780) 2A | Three (3) window units NOT COOLING in the small gym (COACHES OFFICE)! Per Mr. Dennis Crutchfield, Plant Mgr. @ 901.416.1880. | 7/9/13 | | | Electrical |
| White Station HS (2780) 2A | Window unit in the Senior Gym, Boy's Locker Rm NOT COMING ON per Mr. Crutchfield, Plant Mgr. at 901.416.1880! | 7/11/13 | | | Electrical |
| White Station HS (2780) 2A | No lights in football locker room (checked breakers) per Dennis Crutchfield 416-1880 | 7/22/13 | | | Electrical |
| White Station HS (2780) 2A | RECEPTACLES IN THE FIN. SEC OFFICE IS NOT WORKING. SBE CRUTHFIELD 416-8880 | 7/23/13 | | | Electrical |
| White Station HS (2780) 2A | UNIT IN THE SR GYM BOYS LOCKER RM IS NOT COMING ON SBE CRUTHFIELD 416-88880 | 7/24/13 | | | Electrical |
| White Station HS (2780) 2A | FLR UNIT NOT COMING ON IN RM-M122. SBE-CLAY/416-8850 | 7/29/13 | | | Electrical |

| | | | | | |
|----------------------------|--|---------|---------------------|---------------------------|------------|
| White Station HS (2780) 2A | UNIT VENT - RM M205 NOT COMING ON - PM/CRUTCHFIELD 416-1880 | 7/30/13 | | | Electrical |
| White Station HS (2780) 2A | Please Reset the Bell: First Bell 6:45AM. Tardy Bell 7:00AM. | 8/1/13 | Administration Area | | Electrical |
| White Station HS (2780) 2A | have light out in locker room and coach office area, and grill locker room old gym | 8/14/13 | Gym | gym /football locker room | Electrical |
| White Station HS (2780) 2A | have light out in landry room in new gym and hallaway by boys locker room | 8/14/13 | | | Electrical |
| White Station HS (2780) 2A | FIRE ALARM IS SHOWING TROUBLE IN AUDIT PLANT MGR- CRUTCHFIELD/416.1880 | 8/15/13 | | | Electrical |
| White Station HS (2780) 2A | NO POWER TO RECEPTACLES IN GYM & GYM CLASSRM PER SBE- SBE CRUTCHFIELD 416-8880 KLR | 8/16/13 | | | Electrical |
| White Station HS (2780) 2A | Please repair light fixture in the small gym in room EG111. The end filament of a light bulb is broken off in the light fixture. | 8/16/13 | | | Electrical |
| White Station HS (2780) 2A | i need 2 case of light bulds the number on box is 48918 ,2700k | 8/23/13 | Gym | boys locker room | Electrical |

| | | | | | |
|----------------------------|--|----------|---------|--------------------------|------------|
| White Station HS (2780) 2A | Power outage at the school. | 8/27/13 | | | Electrical |
| White Station HS (2780) 2A | EXIT LIGHT - EAST ANNEX BOTTOM FLR - N END OF BLDG - HANGING - WIRES ARE EXPOSED PM/CRUTCHFIELD 416- 1880 | 8/28/13 | | | Electrical |
| White Station HS (2780) 2A | EXPOSE WIRES COMING FROM SMALL GYM BLEACHERS, FRONT BOTTOM PLANT MGR- CRUTCHFIELD/416.8880 | 9/30/13 | | | Electrical |
| White Station HS (2780) 2A | have 2 ballest out in food prep area | 10/8/13 | Kitchen | kitchen /food perp area | Electrical |
| White Station HS (2780) 2A | in small gym replace light switch cant turn light on | 10/8/13 | Gym | girls locker room | Electrical |
| White Station HS (2780) 2A | have 1 ballest out in room were hot water tank is locate | 10/8/13 | Gym | girl locker room storage | Electrical |
| White Station HS (2780) 2A | Please change the burned out light in the Auditorium Lobby. | 10/9/13 | | | Electrical |
| White Station HS (2780) 2A | Please replace ballast in the Kitchen Lights. | 10/14/13 | Kitchen | | Electrical |

| | | | | | |
|----------------------------|---|----------|--------------------|---|------------|
| White Station HS (2780) 2A | UNIT VENT - RM M239 - MAKING A LOUD NOISE - PM/CLAY 416-8880 | 10/15/13 | | | Electrical |
| White Station HS (2780) 2A | Please repair the receptacle underneath the ice cream cooler. The unit is place wrong for the connection. | 10/17/13 | Cafeteria | Serving Line | Electrical |
| White Station HS (2780) 2A | Please repair the electrical receptacle on the west serving line. | 10/17/13 | Cafeteria | Serving Line | Electrical |
| White Station HS (2780) 2A | Please repair the breaker to the oven. When the oven comes on the breaker trips shutting down the oven. | 10/17/13 | Kitchen | | Electrical |
| White Station HS (2780) 2A | Please replace outside corridor lights. | 10/21/13 | Auditorium | | Electrical |
| White Station HS (2780) 2A | Install pole for overhead wiring feeding baseball scoreboard. | 10/23/13 | Athletic Field | Baseball Field | Electrical |
| White Station HS (2780) 2A | Please replace cover on electrical box. | 10/23/13 | Restroom (Boys) | Adjacent to M116 | Electrical |
| White Station HS (2780) 2A | Please replace outside lights in the south corridor walkway of the Auditorium where students enter the Cafeteria. | 10/25/13 | Auditorium | South Corridor Adjacent to Parking Lot | Electrical |

| | | | | | |
|----------------------------|--|----------|------------------|-------------------------------|------------|
| White Station HS (2780) 2A | No electrical power in the office reception area to the computers and printers. No breakers are tripped in the (2) adjacent electrical panels. | 10/25/13 | Library | Office reception area | Electrical |
| White Station HS (2780) 2A | Please provide (4') light bulbs (flourescent)for the hallways. | 10/28/13 | Hallway/Corridor | | Electrical |
| White Station HS (2780) 2A | Please provide screw in light bulbs (Compact Flourescent) type bulbs are needed. | 10/28/13 | Hallway/Corridor | | Electrical |
| White Station HS (2780) 2A | Please set the clocks back. Day Light savings time ends this weekend. | 10/30/13 | | | Electrical |
| White Station HS (2780) 2A | Please replace the electrical plug on the cooling unit located on the line. Remove broken plug inside the electrical floor receptacle. | 10/30/13 | Kitchen | | Electrical |
| White Station HS (2780) 2A | Need an electrician to locate open circuit on Auditorium NAC (located in the Auditorium lobby north storage, NAC #3). This circuit should be reading an EOL resistance of 4.7k ohms and is reading over 200k | 10/30/13 | | | Electrical |
| White Station HS (2780) 2A | Request line be tighten across drive. | 10/30/13 | | | Electrical |
| White Station HS (2780) 2A | need power for new scoreboard | 8/9/13 | Athletic Field | soccer field / baseball field | Electrical |

| | | | | | | |
|----------------------------|--|---------|-------|-------------------|--|---------------------------------------|
| White Station HS (2780) 2A | PARTIAL OUTAGE-NO POWER TO GYM AREA INCLUDING LOCKER RMS, OFC-PLANT MGR CRUTCHFIELD 416-8880 KLR | 8/29/13 | | | | Electrical |
| White Station HS (2780) 2A | UNIT VENT RM M131 - BLOWING NOT COOLING - PM/CRUTCHFIELD 416-1880 | 4/22/14 | | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN RM-E308 PLANT MGR-CLAY/416.8880 | 4/28/14 | | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C UNIT is NOT COOLING in ROOM M230 per George Clay, Plant Mgr. 416.8880 | 4/25/14 | | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please repair roof top units in the Freshman Building for the first and second floor: Energy management stating on the computer some of the units are off and the others are not cooling, and some are at the set point to cool | 4/28/14 | Annex | Freshman Building | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please repair roof top units in the Freshman Building for the first and second floor: Energy management stating on the computer some of the units are off, and the other units. Principals stated this has been going on for a while | 4/28/14 | Annex | Freshman Building | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C AUDITORIUM AREA-NOT COOLING-THEY WILL BE HAVING A PLAY TONIGHT-PLANT MGR CLAY 416-8880 KLR | 5/1/14 | | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN RM-M131 PLANT MGR-CLAY/416.8880 | 5/5/14 | | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | A/C RM M204, M215, & M242-ALL NOT COOLING-PLANT MGR CLAY 416-8880 KLR | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM M128-NOT COOLING-PLANT MGR CLAY 416-8880 KLR | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN RM-111,115, PLANT MGR-CLAY/416.8880 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN RM-E305 PLANT MGR-CLAY/416.8880 | 5/8/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENT - RM E203 - BLOWING NOT COOLING - HAVING EXAMS ALL WEEK IN THIS RM - PM/CLAY 416-8880 | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM E104-NOT COOLING-PLANT MGR CLAY 416-8880 KLR | 5/21/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C WEST SIDE OF BLDG 1ST FLR ABOUT (6) RMS-NOT COOLING-PLANT MGR CLAY 416-8880 KLR | 5/9/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C EAST ANNEX RM E308-NOT COOLING-PLANT MGR SMITH 416-8880 KLR | 6/13/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|-----------|--------|---------------------------------------|
| White Station HS (2780) 2A | A/C RM 301, 306, & 307-ALL NOT COOLING-PLANT MGR SMITH 416-8880 KLR | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | the gym is noy cooling , very hot. | 6/17/14 | Gym | sr gym | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C SR GYM AREA-NOT COOLING-PLANT MGR WAKEFIELD 416-8880 KLR | 6/20/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C EAST ANNEX RM E203-NOT COOLING-PLANT MGR SMITH 416-8880 KLR | 6/16/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN CAFE (SUMMER CLASSES) PLANT MGR-DARIUS/416.8880 | 6/17/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | the ac is not working. | 6/19/14 | Classroom | E 203 | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN GYM plant mgr-DARRIS/416.8880 | 6/19/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNITS NOT COOLING IN RM-301E,306E,307E,303E,201 (SUMMER SCHOOL) PLANT MGR-DARRIUS/416.8880 | 6/20/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|-----------|-----------|---------------------------------------|
| White Station HS (2780) 2A | Unit not cooling in cafe. Plant Mgr- Crutchfield/848.5746 | 6/18/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C UNIT is NOT COMING ON in ROOM M227 per George Clay, Plant Mgr. 416.8880 | 5/22/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | FIVE (5) A/C UNITS are LEAKING in ROOMS E202, E303, E305, E306, and E307 per Darius Wakefield, Plant Mgr. 416.8880 | 6/4/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENT -EAST BLDG RM 203 & FRESHMAN BLDG -RTU - RM 218 - BOTH ARE BLOWING NOT COOLING PM/WAKEFIELD 416-8880 | 6/5/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C UNIT LEAKING ... | 6/9/14 | Classroom | EAST #206 | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | the ac unit is not cooling. | 6/11/14 | Classroom | m226 | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | the ac unit is not cooling. | 6/11/14 | Classroom | m218 | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | the ac unit is leaking. | 6/11/14 | Classroom | m222 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | A/C ROTC BLDG-NOT COOLING-PLANT MGR CLAY 416-8880 KLR | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | room E301 a/c not cooling per Mr. Clay 416-8880 | 5/12/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per george clay 416-8880 Freshman Building rooms F117 & F122, F217, F215, F222, F218, F213, F223, F124, F128, F123, F110 all not cooling | 5/13/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per george clay 416-8880 rooms M204 and M215 are not cooling | 5/14/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C UNIT is LEAKING in the TEACHER'S LOUNGE per George Clay, Plant Mgr. 416.8880 | 5/20/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COMING ON IN RM-110,128,209,219 PLANT MGR-CLAY/416.8880 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per george clay 416-8880 room M222A is not cooling | 5/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COMING ON IN RM-M230 PLANT MGR-CLAY/416.8880 | 5/6/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | RTU RM 209-NOT COMING ON, HAS NO POWER-PLANT MGR CLAY 416-8880 KLR | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM E305 & E104-BOTH NOT COOLING-PLANT MGR CLAY 416-8880 KLR | 4/28/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM M109 & ROTC BLDG-BOTH NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNITS NOT COOLING IN RM-F111,F115,M109, ROTC PLANT MGR-CRUTCHFIELD/416.8880 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C MAIN OFC AREA-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT HEATING IN RM-M129 PLANT MGR-CRUTCHFIELD/416.1880 | 3/20/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNITS are NOT HEATING in F116, M109, and M221 per Mr. Crutchfield, Plant Mgr. 416.1880 | 3/21/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | A/C RM M222, M223, & M243-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM M119-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C 2ND FLR FRESHMEN BLDG ABOUT (18) RMS-ALL NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/2/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per crutchfield 416-1880 rooms M222, M226, M205, M109, cafeteria and library blowing hot air | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN MAIN OFFICE PLANT MGR/CRUTCHFIELD/416.8880 | 4/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Monthly - Filter-WhiteStation High - Refer to PM schedule details. | 4/4/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C AUDITORIUM, CAFE, RM M234, M222, & M219-ALL NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/11/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM M205-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/11/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|----------|-----------------|-------------------|---------------------------------------|
| White Station HS (2780) 2A | A/C RM E207-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/14/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENTS IN RM M223, M205, M234, E207 - ALL AR BLOWING NOT COOLING - PM/CRUTCHFIELD 416-1880 | 4/17/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C RM M017-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/17/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please rrepair the following RTU's in the Freshman Building. There are (6) units per Energy Management #5, #11, #12, #18, #20, & #22 that are not functioning. | 11/12/13 | Classroom | Freshman Building | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please repair the heat. There is no heat in the lobby area. | 11/12/13 | Auditorium | Front Lobby | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per george clay 416-8880 boiler is not working | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | BOILER NOT COMING ON IN ROTC BLDG. PLANT MGR-CLAY/416.8880 | 11/15/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | The building has no heat. Please reair the boiler. The pilot will not stay lit. | 11/15/13 | Mechanical Room | ROTC Building | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|----------|-----------|--------------------------|---------------------------------------|
| White Station HS (2780) 2A | 3-UNITS NOT COOLING IN RM-208,211,110 PLANT MGR-CLAY/416.8880 | 11/18/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT COOLING IN RM-M241. PLANT MGR-CLAY/416.8880 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | BOILER NOT COMING ON. PLANT MGR-CLAY/416.8880 | 11/26/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please repair the leaking condenser in the ceiling. | 12/4/13 | 1st Floor | Teachers Lounge | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per george clay 416-8880 east gym is blowing cold air | 12/9/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please repair the electrical heating unit. Please repair the unit, the Coach stated the core doesn't shut off. The unit is tripping the breaker. | 12/9/13 | Portables | Nothern Unit Portable #2 | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT RMS E100, E101, E103, & E104-ALL NOT HEATING-PLANT MGR CLAY 416-8880 KLR | 12/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | NO HEAT IN THE ROTC BLDG - FURNACE IS NOT WORKING - PM/CLAY 416-8880 | 12/16/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|--------|--|--|---------------------------------------|
| White Station HS (2780) 2A | UNITS ARE NOT COOLING IN RM 024,019,125,140,131. SBE CLAY 416-8880 | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Room F129 and F219 a/c not cooling per Dennis Crutchfield 416-8880 | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENT RM M227 - NOT COOLING - PM/CRUTCHFIELD 416-1880 | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENT RM M225 - LEAKING - PM/CRUTCHFIELD 416-1880 | 8/6/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UV NOT COOLING IN RM-F129. PLANT MGR-CRUTCHFIELD/416.8880 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C IN RMS E301, F121, & F122-ALL NOT COOLING-SBE CRUTCHFIELD 416-8880 KLR | 8/8/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Monthly - Air Compressor #024- White Station High - Refer to PM schedule details. | 9/6/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Bandroom a/c is not cooling per Dennis Crutchfield 416-1880 | 9/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | UNIT VENT - RM F129, F128, ROTC, M226, BAND RM AND MAIN GYM - ALL ARE BLOWING - NOT COOLING - PM/CRUTCFIELD 416-1880 | 9/10/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | chiller making a really strange noise per crutchfield 416-1880 | 9/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 thru wall heater blowing cold air in gym boys locker room | 1/2/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT RMS E100, E101, E103, & E104-ALL NOT HEATING-PLANT MGR CRUTCFIELD 416-8880 KLR | 1/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 main library is blowing cold air | 1/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT RMS F11, F123, F222, & F217-ALL NOT HEATING-PLANT MGR CRUTCFIELD 416-8880 KLR | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Unit in ROTC room is NOT HEATING PER Mr. Crutchfield, Plant Mgr 416.1880 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 the small gym is blowing cold air and there is a game in there this afternoon | 1/8/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | BOILER NOT HEATING IN AUDIT (HAVING A PROGRAM TONIGHT) PLANT MGR- CRUTCHFIELD/416.8880 | 1/9/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT ROTC-NOT HEATING- PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/10/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 gym is blowing cold air | 1/16/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | in the small gym and ROTC there is no heat blowing cold per Mr. Crutchfield 416-1880 | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per crutchfield 416-1880 no heat in small gym girls locker room or the coach's office | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per crutchfield 416-1880 M 212 blowing cold air | 1/23/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | per crutchfield 416-1880 the auditorium and rooms F209 and M142 blowing cold no heat | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT CAFE & AUDITORIUM-BOTH NOT HEATING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/29/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | UNITS are NOT HEATING in the ROTC ROOM AND ROOM F209 per Dennis Crutchfield, Plant Mgr. | 1/30/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | 5-UV NOT HEATING IN RM-M240,M239,M237,M236,M137 PLANT MGR- CRUTCHFIELD/416.8880 | 2/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT HEATING IN MAIN LIBRARY. PLANT MGR- CRUTCHFIELD/416.8860 | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT is NOT HEATING in the SMALL GYM inside the LOCKER ROOM per Dennis Crutchfield, Plant Mgr. 416.1880. | 2/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT NOT HEATING IN RM-M137. PLANT MGR- CRUTCHFIELD/416.8880 | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT RM M210, M206, M205, M211, M212, & M236- ALL ARE OVERHEATING, TEMP IS 75-PLANT MGR CRUTCHFIELD 416-8880 KLR | 2/20/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT is NOT HEATING in the ROTC BUILDING per Dennis Crutchfield, Plant Mgr. 416.1880 | 2/26/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | HEAT RM E305 & E300- BOTH NOT HEATING- PLANT MGR CRUTCHFIELD 416-8880 KLR | 2/27/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | HEAT PORT 207-NOT COMING ON-PLANT MGR CRUTCHFIELD 416-8880 KLR | 3/5/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | 2-UV NOT COOLING IN RM-E206,MAIN OFFICE. SBE-CRUTCHFIELD/416-8880 | 7/1/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Unit NOT COOLING in the Band Room per Dennis Crutchfield, Plant Mgr. at 416.1880. Summer Band Camp going on. | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Unit ventilators NOT COOLING in Rm. M022 and in the Gym LOBBY area per Mr. Crutchfield, Plant Mgr. at 416.1880. | 7/10/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT IN RM M109 IS NOT COOLING. SBE CLAY 416-8880 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT IN RM M109 IS NOT COOLING. CRUTHFIELD 416-8880 | 7/25/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | 5-UV NOT COOLING IN RM-E106,E206,E207,E301,E304 . PLANT MGR-CRUTCHFIELD/416.1880 | 7/29/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UV NOT COOLING IN RM-M218B. PLANT MGR-CRUTCHFIELD/416.8880 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | 2-RTU NOT COOLING IN RM-F128, ROTC RM. PLANT MGR-CRUTCHFIELD/416.8880 | 8/12/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Monthly - Oil Lube & Belt-WhiteStation High - Refer to PM schedule details. | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C IN ROTC BLDG-NOT COOLING-SBE CRUTCHFIELD 416-1990 KLR | 8/15/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C IN RM M236-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 8/16/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C IN MAIN OFC & ROTC BLDG-BOTH NOT COOLING-SBE CRUTCHFIELD 416-1588 KLR | 8/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C IN RMS M128, M119, & GYM-ALL NOT COOLING-SBE CRUTCHFIELD 416-8880 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | RTU ROTC BLDG-NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 8/22/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Unit Ventilators in Rooms E207, M212, and M219 NOT COOLING per Mr. Crutchfield, Plant Mgr. 901.416.8880 | 8/26/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station HS (2780) 2A | Unit Ventilator in Room E707 is LEAKING per Mr. Crutchfield, Plant Mgr. 901.416.8880 | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENT RM M236 & M207 - BOTH ARE RUNNING BUT NOT COOLING - PM/CRUTCHFIELD 416-1880 | 8/28/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Unit Ventilator in Rm E208 is LEAKING per Mr. Crutchfield, Plant Mgr. 416.1880 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Unit Ventilator in Rm M212 is NOT COOLING per Mr. Crutchfield, Plant Mgr. 416.1880 | 9/17/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C AUDITORIUM AREA- NOT COOLING-PLANT MGR CRUTCHFIELD 416-8880 KLR | 9/18/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | 2-UNITS NOT COOLING IN RM-E301,E104. PLANT MGR- CRUTCHFIELD/416.8880 | 9/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | RTU's NOT COOLING in ROOMS F123, F124, F128, and F129 per Dennis Crutchfield, Plant Mgr. 416.1880 | 9/25/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | A/C CAFE, RMS M140 & M224-ALL ARE LEAKING- PLANT MGR CRUTCHFIELD 416-8880 KLR | 9/26/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|----------|---------|--|---------------------------------------|
| White Station HS (2780) 2A | F122, F129, F219 a/c not cooling per Crutchfield 416-1880 | 9/27/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | RTU F124-, F123, F129, F128, F116 , F122 - ALL ARE BLOWING NOT COOLING - PM/CRUTCHFIELD 416-1880 | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please light the heater in the kitchen. The unit is blowing cold air. | 10/23/13 | Kitchen | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | RTU is NOT COOLING in ROOM A102 per George Clay, Plant Mgr. 416.8880 | 10/24/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | UNIT VENT - E BLDG 1ST FLR RM E104 BLOWING NOT COOLING - PM/CLAY 416-8880 | 10/29/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Monthly - Filter-WhiteStation High - Refer to PM schedule details. | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Yearly - Oil Samples - White Station High - Refer to PM schedule details. | 9/14/13 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Monthly - Filter-WhiteStation High - Refer to PM schedule details. | 11/29/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|----------|-----------|--|---------------------------------------|
| White Station HS (2780) 2A | Monthly - Air Compressor #024- White Station High - Refer to PM schedule details. | 3/7/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Monthly - Oil Lube & Belt- WhiteStation High - Refer to PM schedule details. | 3/8/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Yearly - Boiler - White Sta Hi- East Annex 1st Fl - Refer to PM schedule details. | 4/8/14 | | | Heating/Ventilation /Air Conditioning |
| White Station HS (2780) 2A | Please remove graffiti from stall. Main Building 2nd. floor girl's restroom across from M-239. | 11/11/13 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI -LARGE GYM OUTSIDE ON BRICK - GANG RELATED - PM/CLAY 416-8880 | 5/12/14 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI ON BLDG FRONT ENTRY PLANT MGR- CLAY/416.8880 | 5/13/14 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI - DRIVER'S TRAINING TRAILER - GANG RELATED - NORTH SIDE OF MAIN GYM - PM/CLAY 416-8880 | 5/9/14 | | | Painting |
| White Station HS (2780) 2A | Please remove graffiti from the girls and boys restrooms in the main building. | 4/28/14 | 1st Floor | | Painting |

| | | | | | |
|----------------------------|---|---------|------------------|-------------------------|----------|
| White Station HS (2780) 2A | Please remove graffiti from the boys 1st floor restroom. | 4/28/14 | Annex | 1st Floor boys restroom | Painting |
| White Station HS (2780) 2A | Please remove gang related graffiti and profanity from the drivers training trailer. | 4/30/14 | Parking Lot | North End East Gym | Painting |
| White Station HS (2780) 2A | per crutchfield 416-1880 gang graffiti and lots of profanity on the drivers training trailer that is in the parking lot north of east gym | 4/30/14 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI - EAST ANNEX BOTTOM FLR - B RR- ON WALLS & STALLS - PM/CRUTCHFIELD 416-1880 | 4/17/14 | | | Painting |
| White Station HS (2780) 2A | Graffiti on walls in the SENIOR GYM Boy's Locker Room per Mr. Crutchfield, Plant Mgr. 416.1880 | 9/12/13 | | | Painting |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 there is gang related graffiti in #4 stariwell by big gym, east annex boys restroom 2nd floor and main hallway boys restroom by teacher's lounge | 1/13/14 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI B RR FRESHMAN BLDG BOTTOM FLOOR ON STALLS & BLOCK WALLS- PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/16/14 | | | Painting |
| White Station HS (2780) 2A | repair plaster ceiling in restroom , roof leak has been fix | 1/16/14 | Restroom (Girls) | gym area | Painting |

| | | | | | |
|----------------------------|---|---------|-----|-----------|----------|
| White Station HS (2780) 2A | per crutchfield 416-1880 gang graffiti boys restroom east annex bottom floor | 1/29/14 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI IN B/RR BASEMENT MAIN ON WALLS, STALLS. PLANT MGR- CRUTCHFIELD/416.8880 | 2/11/14 | | | Painting |
| White Station HS (2780) 2A | per crutchfield 416-1880 there is gang graffiti east annex boys and girls restrooms stalls and walls also in the main building boys and girls restrooms near teacher's lounge | 2/25/14 | | | Painting |
| White Station HS (2780) 2A | refinish wood floor in small gym | 2/26/14 | Gym | small gym | Painting |
| White Station HS (2780) 2A | Graffiti on stalls and walls in the Boy's RR on the Ground Floor by Room E104 (Gang Related) per Dennis Crutchfield, Plant Mgr. at 416.1880 (Summer School is going on) | 7/8/13 | | | Painting |
| White Station HS (2780) 2A | paint lines on parking lot | 7/16/13 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI IN B/RR EAST ANNEX WALLS, STALLS. SBE-CRUTCHFIELD/416- 8880 | 7/22/13 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI IN B/RR EAST ANNEX WALLS, STALLS. SBE-CRUTCHFIELD/416- 8880 | 7/22/13 | | | Painting |

| | | | | | |
|----------------------------|--|---------|------------------|---|----------|
| White Station HS (2780) 2A | Graffiti main building top stairway north end by gym per George Clay 416-8880 | 7/31/13 | | | Painting |
| White Station HS (2780) 2A | GANG GRAFFITI IN 2ND FLR E ANNEX B RR ON STALL WALLS-PLANT MGR CRUTCHFIELD 416-8880 KLR | 8/29/13 | | | Painting |
| White Station HS (2780) 2A | GRAFFITI IN B/RR 2ND FLR EAST ANNEX PLANT MGR- CRUTCHFIELD/416.8880 | 10/2/13 | | | Painting |
| White Station HS (2780) 2A | Request support brackets be painted. | 10/2/13 | | | Painting |
| White Station HS (2780) 2A | paint bleacher boards | 11/4/13 | | | Painting |
| White Station HS (2780) 2A | E- Building Boy's restroom: Please remove graffiti from restroom walls on the 1st. and 2nd. floor. | 11/6/13 | Restroom (Boys) | | Painting |
| White Station HS (2780) 2A | Please remove graffiti on the restroom walls. | 11/7/13 | Restroom (Girls) | Main Building Adjacent to Teachers Lounge | Painting |
| White Station HS (2780) 2A | Please remove graffiti on walls and stalls in the restroom. | 11/7/13 | Restroom (Girls) | 1st Floor | Painting |

| | | | | | |
|----------------------------|---|---------|------------------|----------------------|----------|
| White Station HS (2780) 2A | SINK SR GYM BOYS' LOCKER RM-HOT WATER SIDE RUNNING AT FULL FORCE, CAN'T CUT OFF- PLANT MGR WAKEFIELD 416-8880 KLR | 6/20/14 | | | Plumbing |
| White Station HS (2780) 2A | the ac unit is leaking. | 6/19/14 | | E 201 | Plumbing |
| White Station HS (2780) 2A | UNIT IS FLOODING RM-G111 LOBBY MAIN GYM PLANT MGR-SMITH/416.8880 | 6/17/14 | | | Plumbing |
| White Station HS (2780) 2A | Repair leak on water line | 6/23/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C RM M115-LEAKING- PLANT MGR WAKEFIELD 416-8880 KLR | 6/25/14 | | | Plumbing |
| White Station HS (2780) 2A | the boys 1st toilet the seat is broken off. | 6/26/14 | Restroom (Boys) | 2nd floor e building | Plumbing |
| White Station HS (2780) 2A | the toilet seat is off of the toilet. | 6/26/14 | Restroom (Girls) | 3rd floor e building | Plumbing |
| White Station HS (2780) 2A | Assist zone with water main replacement | 6/27/14 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|-----------------|-------------|----------|
| White Station HS (2780) 2A | the urinal on the wall the water want stop running had to cut it off, pipes vibrating. | 6/30/14 | Restroom (Boys) | E 3RD FLOOR | Plumbing |
| White Station HS (2780) 2A | THE 2 ND FLOOR URINAL IS LEAKING BAD . | 6/30/14 | Restroom (Boys) | E 2ND FLOOR | Plumbing |
| White Station HS (2780) 2A | the ac unit is leaking bad. | 6/19/14 | Classroom | M 224 | Plumbing |
| White Station HS (2780) 2A | A/C CAFE AREA-LEAKING-PLANT MGR SMITH 416-8880 KLR | 6/16/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C EAST ANNEX RM E201-LEAKING-PLANT MGR SMITH 416-8880 KLR | 6/16/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C RM 128-NOT COMING ON-PLANT MGR CLAY 416-8880 KLR NOTE: RICHARD POWELL ON SITE | 5/27/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C E BLDG RM E201 & CAFE AREA-BOTH ARE LEAKING-PLANT MGR CLAY 416-8880 KLR | 5/29/14 | | | Plumbing |
| White Station HS (2780) 2A | RTU - CAFE - LEAKING - PM/CRUTCHFIELD 416-1880 | 6/2/14 | | | Plumbing |

| | | | | | |
|----------------------------|---|---------|-----------|-------|----------|
| White Station HS (2780) 2A | the ac unit is leaking bad in the cafeteria. | 6/3/14 | | | Plumbing |
| White Station HS (2780) 2A | UNIT VENT - MAIN BLDG RM M242 - LEAKING - PM/WAKEFIELD 416-8880 | 6/5/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C RM E206-LEAKING- PLANT MGR WAKEFIELD 416-8880 KLR | 6/10/14 | | | Plumbing |
| White Station HS (2780) 2A | the ac unit is leaking in the room. | 6/11/14 | Classroom | m 221 | Plumbing |
| White Station HS (2780) 2A | the ac unit is leaking in the room. | 6/12/14 | Classroom | m122 | Plumbing |
| White Station HS (2780) 2A | the ac is leaking in the room. | 6/12/14 | Classroom | m224 | Plumbing |
| White Station HS (2780) 2A | UNIT VENT - RMM206 - LEAKING - PM/CLAY 416-8880 | 5/12/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C LARGE GYM-HAS WATER POURING OUT OF IT-PLANT MGR CLAY 416-8880 KLR | 5/12/14 | | | Plumbing |

| | | | | | |
|----------------------------|---|---------|-------|--------------------------|----------|
| White Station HS (2780) 2A | per george clay 416-8880 room M206 and room M242 a/c leaking | 5/12/14 | | | Plumbing |
| White Station HS (2780) 2A | UNIT VENTILATOR is LEAKING in M123 per George Clay, Plant Mgr. 416.8880 | 5/12/14 | | | Plumbing |
| White Station HS (2780) 2A | M224 unit ventilator leaking per Dennis Crutchfield 416-8880 | 8/5/13 | | | Plumbing |
| White Station HS (2780) 2A | A/C RM E108-LEAKING- PLANT MGR CLAY 416- 8880 KLR | 5/21/14 | | | Plumbing |
| White Station HS (2780) 2A | A/C GYM AREA-LEAKING ON HARDWOOD FLR- PLANT MGR CLAY 416- 8880 KLR | 5/7/14 | | | Plumbing |
| White Station HS (2780) 2A | Please repair the leaking sink faucet on the hot waterside of the unit. | 4/30/14 | Annex | 1st floor girls restroom | Plumbing |
| White Station HS (2780) 2A | Please unstop the toilet in the boys restroom on the east side of the building. Still plugged after plunging unit. | 4/30/14 | Annex | 1st floor boys restroom | Plumbing |
| White Station HS (2780) 2A | UNIT IS LEAKING WATER IN PORT-2 PLANT MGR- CLAY/416.8880 | 4/30/14 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|-----------------|-------------------|----------|
| White Station HS (2780) 2A | UNITS ARE LEAKING WATER IN RM-E303, CAFE PLANT MGR- CRUTCHFIELD/416.8880 | 4/23/14 | | | Plumbing |
| White Station HS (2780) 2A | 2-SHOWER HEADS ARE LEAKING CONTINUOUSLY IN G/LOCKER GYM CAUSING A FLOOD PLANT MGR- CLAY/416.8880 | 3/18/14 | | | Plumbing |
| White Station HS (2780) 2A | BUSTED WATER PIPE OUTSIDE OF SMALL GYM PLANT MGR- CRUTCHFIELD/416.8880 | 3/20/14 | | | Plumbing |
| White Station HS (2780) 2A | boys restroom west end bottom floor handle off urinal | 3/21/14 | Restroom (Boys) | freshman building | Plumbing |
| White Station HS (2780) 2A | UNIT IS LEAKING WATER IN CAFE PLANT MGR- CRUTCHFIELD/416.8880 | 3/25/14 | | | Plumbing |
| White Station HS (2780) 2A | Repair faucet on the Building. | 3/26/14 | | | Plumbing |
| White Station HS (2780) 2A | per crutchfield 416-1880 room E203 unit leaking | 4/3/14 | | | Plumbing |
| White Station HS (2780) 2A | Assist zone with backflow device | 4/4/14 | | | Plumbing |

| | | | | | |
|----------------------------|--|----------|--------------------|--------------------|----------|
| White Station HS (2780) 2A | FLOOR DRAIN TEACHER'S LOUNGE MAIN HALL- BACKING UP-PLANT MGR CRUTCHFIELD 416-8880 KLR | 4/9/14 | | | Plumbing |
| White Station HS (2780) 2A | replace flush value in restroom | 4/10/14 | Cafeteria | cafetria/ restroom | Plumbing |
| White Station HS (2780) 2A | per crutchfield 416-1880 there are 2 storm drains in front by main office that are stopped up | 4/14/14 | | | Plumbing |
| White Station HS (2780) 2A | install water line for new ice machine | 4/16/14 | Gym | small gym | Plumbing |
| White Station HS (2780) 2A | STOVE NEEDS TO BE LIT IN KITCHEN PLANT MGR- CRUTCHFIELD/848.5746 | 4/17/14 | | | Plumbing |
| White Station HS (2780) 2A | Unstop area drains in front of school | 4/17/14 | | | Plumbing |
| White Station HS (2780) 2A | per mr crutchfield 416-1880 boys locker room in big gym the floor drain is backing up | 4/17/14 | | | Plumbing |
| White Station HS (2780) 2A | Please repair broken faucet. | 11/12/13 | Mechanical Room | E-109 | Plumbing |

| | | | | | |
|----------------------------|--|----------|-----------------|-----------------------------|----------|
| White Station HS (2780) 2A | Please unstop the urinals. | 11/13/13 | Gym | Large Gym Boy's Locker Room | Plumbing |
| White Station HS (2780) 2A | Please provide heat in the gym and locker rooms. | 11/13/13 | Auxiliary Gym | | Plumbing |
| White Station HS (2780) 2A | The toilet is plugged. | 11/13/13 | Auxiliary Gym | Boys Locker Room | Plumbing |
| White Station HS (2780) 2A | Toilet is plugged. | 11/13/13 | Restroom (Boys) | Basement | Plumbing |
| White Station HS (2780) 2A | SERVING LINE-PILOT OUT-WILL NEED FOR LUNCH-PLANT MGR CLAY 416-8880 KLR | 11/20/13 | | | Plumbing |
| White Station HS (2780) 2A | Please repair the toilets both units do not work in the stalls. | 11/23/13 | Restroom (Boys) | 2nd. Floor Acropss fro M239 | Plumbing |
| White Station HS (2780) 2A | Please unplug the urinals. The urinals continues to overflow. | 12/4/13 | Gym | Locker Room | Plumbing |
| White Station HS (2780) 2A | Please repair the leaking sink drain. | 12/4/13 | Kitchen | South Wall | Plumbing |

| | | | | | |
|----------------------------|---|----------|-----------------|----------------------------|----------|
| White Station HS (2780) 2A | Safety Issue: Please repair leaking heater in the Cafeteria. | 12/12/13 | Cafeteria | East Wall 1st Heater South | Plumbing |
| White Station HS (2780) 2A | Please unstop the plugged up toilets. | 12/17/13 | Restroom (Boys) | Across from M137 | Plumbing |
| White Station HS (2780) 2A | A/C UNIT LEAKING IN RM M017-LEAKING-SBE CLAY 416-8880 KLR | 8/2/13 | | | Plumbing |
| White Station HS (2780) 2A | UNIT IS LEAKING WATER IN RM-M109. PLANT MGR-CLAY/416.8880 | 8/6/13 | | | Plumbing |
| White Station HS (2780) 2A | UV IS LEAKING WATER IN CAFE. PLANT MGR-CRUTCHFIELD/416.8880 | 8/7/13 | | | Plumbing |
| White Station HS (2780) 2A | UNIT VENT - IN RM M242, M231, LEAKING & M224 & M305 LEAKING AGAIN - PM/CRUTCHFIELD 416-8880 | 8/8/13 | | | Plumbing |
| White Station HS (2780) 2A | RTU-1 CAFE AREA-LEAKING-SBE CRUTCHFIELD 416-8880 KLR | 8/9/13 | | | Plumbing |
| White Station HS (2780) 2A | RTU CAFE-LEAKING-PLANT MGR CRUTCHFIELD 416-8800 KLR | 8/30/13 | | | Plumbing |

| | | | | | |
|----------------------------|--|----------|-----------------|-------|----------|
| White Station HS (2780) 2A | the following a/c units are leaking per Dennis Crutchfield 416-1888 M207, M232, M119, M224 | 9/3/13 | | | Plumbing |
| White Station HS (2780) 2A | 2-UV ARE LEAKING WATER IN RM-M11,M22. PLANT MGR-CRUTCHFIELD/416.1880 | 9/6/13 | | | Plumbing |
| White Station HS (2780) 2A | 3-COMPARTMENT SINK LEAKING FROM THE MIDDLE BOTTOM SINK-CAN'T CONTAIN-PLANT MGR CRUTCHFIELD 416-8880 KLR | 9/6/13 | | | Plumbing |
| White Station HS (2780) 2A | Units in rooms M130, M142, M11, M211 are leaking per Dennis Crutchfield 416-1880 | 9/9/13 | | | Plumbing |
| White Station HS (2780) 2A | UNIT VENT - RM M224, M134 & M132-ALL ARE LEAKING - PM/CRUTCFIELD 416-1880 | 9/10/13 | | | Plumbing |
| White Station HS (2780) 2A | Two (2) Unit Ventilators in E208 and M139 in the main building is leaking and One (1) RTU in the CAFETERIA is leaking per Mr. Crutchfield, Plant Mgr. 416.1880 | 9/12/13 | | | Plumbing |
| White Station HS (2780) 2A | 7-UNITS ARE LEAKING WATER IN RM-E208,E303,M134,M132,M112,M117,M123. PLANT MGR-CLAY/416.8880 | 9/13/13 | | | Plumbing |
| White Station HS (2780) 2A | Please repair leaking faucet. The water supply had to be shut off. Custodial crew have no water on the 1st. floor of the E-Building. | 12/23/13 | Mechanical Room | E-109 | Plumbing |

| | | | | | |
|----------------------------|---|---------|------------------|---------------------|----------|
| White Station HS (2780) 2A | A three compartment sink is LEAKING in the CAFETERIA per Mr. Crutchfield, Plant Mgr. 416.1880 | 1/8/14 | | | Plumbing |
| White Station HS (2780) 2A | Faucet is LEAKING in the 3 compartment sink in the KITCHEN per Dennis Crutchfield, Plant Mgr. 416.1880 | 1/15/14 | | | Plumbing |
| White Station HS (2780) 2A | girls restroom toilets leaking from bottom | 1/16/14 | Restroom (Girls) | east annex/restroom | Plumbing |
| White Station HS (2780) 2A | i have to sinks stop up and can we put strainer on them kids are stuffing paper towels in them also have a water fountain not working | 1/17/14 | Restroom (Girls) | gym area | Plumbing |
| White Station HS (2780) 2A | have two sink stop up and can we get some strainer put on sink | 1/17/14 | Gym | boys locker room | Plumbing |
| White Station HS (2780) 2A | in the big gym the floor drain is backing up per Mr. Crutchfield 416-1880 | 1/22/14 | | | Plumbing |
| White Station HS (2780) 2A | SEWAGE SMELL IN B/LOCKER RM MAIN GYM PLANT MGR- CRUTCHFIELD/848.5746 | 1/22/14 | | | Plumbing |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 no hot water in the main gym | 1/23/14 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|------------------|---------------------------------|----------|
| White Station HS (2780) 2A | WATER HEATER SMALL GYM AREA-HAS BURST-PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/23/14 | | | Plumbing |
| White Station HS (2780) 2A | per Mr. Crutchfield 416-1880 in ROTC there is a leak behind urinal | 1/24/14 | | | Plumbing |
| White Station HS (2780) 2A | Please repair the urinal it continues to run. | 1/24/14 | Restroom (Boys) | Adjacent to E-109 | Plumbing |
| White Station HS (2780) 2A | boys restroom top floor will not flush | 1/27/14 | Restroom (Boys) | east wing/ top floor | Plumbing |
| White Station HS (2780) 2A | WATER LINE TO ICE MACHINE KITCHEN AREA-LEAKING, CAN'T CONTAIN-PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/27/14 | | | Plumbing |
| White Station HS (2780) 2A | water fountain stop up main hall | 1/27/14 | Hallway/Corridor | main building by teacher lounge | Plumbing |
| White Station HS (2780) 2A | Please repair leaking water fountain. The shut off valve stays on letting water continue to run. | 1/28/14 | Annex | Freshman Building 1st. Floor | Plumbing |
| White Station HS (2780) 2A | SEWER GAS SMELL GYM B LOCKER RM AREA-PLANT MGR CRUTCHFIELD 416-8880 KLR | 1/30/14 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|------------------|--------------------------------------|----------|
| White Station HS (2780) 2A | have two urnail stop up boys restroom | 1/30/14 | Gym | gym boys locker room | Plumbing |
| White Station HS (2780) 2A | i have on toilet stop up boys restroom top floor by room 242 | 1/30/14 | Restroom (Boys) | main building top floor by room m242 | Plumbing |
| White Station HS (2780) 2A | water fountain stop up | 2/6/14 | Hallway/Corridor | main hall/ by teacher lounge | Plumbing |
| White Station HS (2780) 2A | have 2 sinks stop up girls locker room big gym | 2/6/14 | Library | gym / locker room | Plumbing |
| White Station HS (2780) 2A | per crutchfield 416-1880 there is water coming up out of the asphalt on the south side at freshman academy between school and church possibly pipe burst | 2/10/14 | | | Plumbing |
| White Station HS (2780) 2A | ICE MACHINE LINE HAS A LEAK IN KITCHEN. PLANT MGR- CRUTCHFIELD/416.8880 | 2/11/14 | | | Plumbing |
| White Station HS (2780) 2A | Request three (3) yards sand delivered parking lot between the school and church (South side of the school). | 2/11/14 | | | Plumbing |
| White Station HS (2780) 2A | replace broken water fountaion in basketball locker room | 2/11/14 | Gym | big gym/ boys looker room | Plumbing |

| | | | | | |
|----------------------------|--|---------|--------------------|---------------------------------|----------|
| White Station HS (2780) 2A | water fountain stop up water leaking on floor | 2/11/14 | Courtyard | main hall by restroom | Plumbing |
| White Station HS (2780) 2A | replace flush value on Urinal | 2/11/14 | Auditorium | auditorium/boys restroom | Plumbing |
| White Station HS (2780) 2A | FLOOR DRAIN MAIN GYM B LOCKER RM-BACKING UP-PLANT MGR CRUTCHFIELD 416-88880 KLR | 2/19/14 | | | Plumbing |
| White Station HS (2780) 2A | CEILING HEATER -CAFE- LEAKING - PM/CRUTCHFIELD 416- 1880 | 2/26/14 | | | Plumbing |
| White Station HS (2780) 2A | have floor drain in showe room stop up , have a shower head that is leaking in same area, | 2/26/14 | Gym | small gym/ girls locker room | Plumbing |
| White Station HS (2780) 2A | WALL UNIT IS LEAKING WATER IN RM-E305. SBE-CRUTCHFIELD/416- 8880 | 7/3/13 | | | Plumbing |
| White Station HS (2780) 2A | toilet stop up boys restroom by room E103 | 7/3/13 | Restroom (Boys) | anex building | Plumbing |
| White Station HS (2780) 2A | Unit ventilators LEAKING in Rm. M205, M224, and M225 per Mr. Crutchfield, Plant Mgr. at 416.1880. | 7/10/13 | | | Plumbing |

| | | | | | |
|----------------------------|---|---------|------------------|------------------------------|----------|
| White Station HS (2780) 2A | toilet leaking in restroom 2nd floor by room m205 | 7/10/13 | Restroom (Girls) | anex building/girls restroom | Plumbing |
| White Station HS (2780) 2A | CEILING UNIT IS LEAKING WATER IN CAFE (NO ID). SBE-CLAY/416-8880 | 7/16/13 | | | Plumbing |
| White Station HS (2780) 2A | Replace Hot Water Storage tank for kitchen | 7/17/13 | | | Plumbing |
| White Station HS (2780) 2A | UNIT IN RM E207 IS LEAKING. SBE CRUTHFIELD 416-88880 | 7/24/13 | | | Plumbing |
| White Station HS (2780) 2A | FLOOR IN THE BOYS RSTRM EAST ANNEX GROUND FLOOR IS STOP UP. CRUTHFIELD 416-8880 | 7/25/13 | | | Plumbing |
| White Station HS (2780) 2A | RTU IS LEAKING WATER ON GYM FLR . PLANT MGR- CRUTCHFIELD/416.1880 | 7/29/13 | | | Plumbing |
| White Station HS (2780) 2A | FLR DRAIN IS BACKING UP IN KITCHEN, & UV IS LEAKING WATER IN RM-M212. PLANT MGR- CRUTCHFIELD/416.1880 | 7/29/13 | | | Plumbing |
| White Station HS (2780) 2A | Hook up copper drain in teacher lounge 1st floor | 7/30/13 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|--|--|----------|
| White Station HS (2780) 2A | UNIT VENT - RM M134 - LEAKING - PM/CRUTCHFIELD 416- 1880 | 7/30/13 | | | Plumbing |
| White Station HS (2780) 2A | UV IS LEAKING WATER IN RM-M231. PLANT MGR- CRUTCHFIELD/416.1880 | 8/1/13 | | | Plumbing |
| White Station HS (2780) 2A | 3-UV ARE LEAKING WATER IN RM-M122,E304,305. PLANT MGR- CRUTCHFIELD/416.8880 | 8/1/13 | | | Plumbing |
| White Station HS (2780) 2A | UNIT IS LEAKING WATER IN RM-M107, & RM-M122. PLANT MGR- CLAY/416.8880 | 8/1/13 | | | Plumbing |
| White Station HS (2780) 2A | WATER HEATER OLD GYM B LOCKER RM/LAUNDRY- NOT HEATING WATER- WILL NEED FOR STUDENTS TO SHOWER- SBE CRUTCHFIELD 416- 8880 KLR | 8/13/13 | | | Plumbing |
| White Station HS (2780) 2A | A/C IN MAIN GYM, RMS M232, M224, & M112-ALL ARE LEAKING-SBE CRUTCHFIELD 416-8880 KLR | 8/14/13 | | | Plumbing |
| White Station HS (2780) 2A | M018 unit ventilator leaking per Dennis Crutchfield 416- 1880 | 8/14/13 | | | Plumbing |
| White Station HS (2780) 2A | PILOTS NEED TO BE LIT ON STEAMTABLES IN SERVING LINE-WILL NEED FOR LUNCH-SBE CRUTCHFIELD 416-8880 KLR | 8/15/13 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|------------------|----------------------------------|----------|
| White Station HS (2780) 2A | commode stop up | 8/15/13 | Gym | small gym/ bfootball locker room | Plumbing |
| White Station HS (2780) 2A | UV IS LEAKING IN MAIN GYM PLANT MGR- CRUTCHFIELD/416.1880 | 8/16/13 | | | Plumbing |
| White Station HS (2780) 2A | UNIT IS LEAKING ON GYM FLR PLANT MGR- CRUTCHFIELD/416.1880 | 8/19/13 | | | Plumbing |
| White Station HS (2780) 2A | unit ventilator E201 and E305 leaking per crutchfield 416-1880 | 8/19/13 | | | Plumbing |
| White Station HS (2780) 2A | toilet stop up boys locker room | 8/19/13 | Gym | gym /boys locker room | Plumbing |
| White Station HS (2780) 2A | A/C IN RM E307-LEAKING-SBE CRUTCHFIELD 416-8880 KLR | 8/22/13 | | | Plumbing |
| White Station HS (2780) 2A | RTU CAFE AREA-LEAKING- PLANT MGR CRUTCHFIELD 416-8880 KLR | 8/22/13 | | | Plumbing |
| White Station HS (2780) 2A | toilet stop up girl restroom bottom floor annex building | 8/26/13 | Restroom (Girls) | annex/bottom floor | Plumbing |

| | | | | | |
|----------------------------|--|---------|---------------------|-------------------------------|----------|
| White Station HS (2780) 2A | their is no water in toilet and it making a noise | 8/27/13 | Administration Area | restroom in freshman building | Plumbing |
| White Station HS (2780) 2A | Outside water faucet in front of main building is leaking and can't cut off. per Dennis Crutchfield 416-1880 | 9/16/13 | | | Plumbing |
| White Station HS (2780) 2A | boys restroom top floor across from M225 on urinal a pipe has been pulled off flush valve and water is going everywhere per Mr. Crutchfield 416-1880 | 9/16/13 | | | Plumbing |
| White Station HS (2780) 2A | A/C RM M236-LEAKING-PLANT MGR CLAY 416-8880 KLR | 9/19/13 | | | Plumbing |
| White Station HS (2780) 2A | repair outside water fossest | 9/24/13 | Grounds | front of school | Plumbing |
| White Station HS (2780) 2A | water fountain by girl restroom stop up | 9/25/13 | Hallway/Corridor | main building bottom floor | Plumbing |
| White Station HS (2780) 2A | In ROOM M109 there's a LEAK in the PIPE CHASE per Mr. Crutchfield, Plant Mgr. 416.1880 | 9/26/13 | | | Plumbing |
| White Station HS (2780) 2A | PILOT NEEDS TO BE LIT ON SERVING LINE-PLANT MGR CRUTCHFIELD 416-8880 KLR | 9/27/13 | | | Plumbing |

| | | | | | |
|----------------------------|---|----------|---------------------|--|----------|
| White Station HS (2780) 2A | toilet stop up in restroom | 10/2/13 | Restroom (Girls) | main building top floor by room M234 | Plumbing |
| White Station HS (2780) 2A | water tank in locker room small gym is not heating per Dennis Crutchfield 416-1880 | 10/2/13 | | | Plumbing |
| White Station HS (2780) 2A | A/C RMS E303 & CAFE- BOTH ARE LEAKING- PLANT MGR CRUTCHFIELD 416-8880 KLR | 10/3/13 | | | Plumbing |
| White Station HS (2780) 2A | Three compartment sink is STOPPED UP in the CATETERIA per Mr. Crutchfield, Plant Mgr. 416.1880 | 10/4/13 | | | Plumbing |
| White Station HS (2780) 2A | Install outside hydrant | 10/14/13 | | | Plumbing |
| White Station HS (2780) 2A | Please unstop the plugged floor drain in the Boy's Locker Room G132 and replace the broken toilet seat. | 10/15/13 | Gym | North Main Large Gym | Plumbing |
| White Station HS (2780) 2A | Toilet continues to flush. The unit has been cut off. Please repair the toilet. | 10/18/13 | Restroom (Girls) | Main Building 1st Floor Across From T. LOUNGE | Plumbing |
| White Station HS (2780) 2A | Please replace broken toilet seat. | 10/18/13 | Restroom (Girls) | Main Building 1st floor across from T. Lounge | Plumbing |

| | | | | | |
|----------------------------|--|----------|------------------|--|----------|
| White Station HS (2780) 2A | The faucets on all the sinks are in need of repair. They have been adjusted to turn away from the bowl and are not secured tight to the sinks. | 10/18/13 | Restroom (Girls) | Main Building 1st. floor across from T. Lounge | Plumbing |
| White Station HS (2780) 2A | Please check/repair teacher states there is no hot water for classroom. | 10/18/13 | Classroom | M-237 Nutrition Classroom | Plumbing |
| White Station HS (2780) 2A | Please repair urinal in the Boy's restroom adjacent to M015. The unit does not flush. | 10/23/13 | | | Plumbing |
| White Station HS (2780) 2A | Please repair the toilet. The toilet will not flush. | 10/24/13 | Classroom | A102 Rear Restroom | Plumbing |
| White Station HS (2780) 2A | Request Back-flow test | 10/28/13 | | | Plumbing |
| White Station HS (2780) 2A | Please repair the toilet will not flush. | 11/6/13 | Restroom (Boys) | 2nd Floor By M-126 | Plumbing |
| White Station HS (2780) 2A | Please replace toilet seat. | 11/6/13 | Restroom (Girls) | 1st. Floor across from M-139 | Plumbing |
| White Station HS (2780) 2A | Please replace toilet seat. | 11/6/13 | Restroom (Girls) | 2nd Floor across from M-239 | Plumbing |

| | | | | | |
|----------------------------|--|----------|--------------------|-----------------------------|----------|
| White Station HS (2780) 2A | custodial sink faucet s stripped,problem shutting off | 11/8/13 | 1st Floor | e building custodial closet | Plumbing |
| White Station HS (2780) 2A | Please unstop(2) plugged toilets. Main Building 2nd floor girl's restroom across from M239. | 11/11/13 | | | Plumbing |
| White Station HS (2780) 2A | ROOF IS LEAKING WATER ONTO GYM FLR PLANT MGR- CRUTCHFIELD/416.8880 This is not a roof leak | 6/6/14 | | | Roof |
| White Station HS (2780) 2A | Please repair roof leak. | 5/20/14 | Cafeteria | South West Roof | Roof |
| White Station HS (2780) 2A | Please repair roof leak in the lobby area. | 4/29/14 | Gym | Front Lobby Entrance | Roof |
| White Station HS (2780) 2A | Please repair roof leak. | 11/22/13 | Restroom (Boys) | Main Gym Lobby | Roof |
| White Station HS (2780) 2A | Please repair roof leak | 11/22/13 | 1st Floor | Teacher's Lounge | Roof |
| White Station HS (2780) 2A | Please repair roof leak in EG104. Girls locker room. | 12/6/13 | Auxiliary Gym | Small East Gym | Roof |

| | | | | | |
|----------------------------|---|----------|-----------------|--------------------------|-------------|
| White Station HS (2780) 2A | Please repair roof leak. North east corner. | 1/2/14 | Cafeteria | Building Engineer Office | Roof |
| White Station HS (2780) 2A | have a roof leak boys in gym lobby | 2/5/14 | Gym | gym / boys restroom | Roof |
| White Station HS (2780) 2A | Please clean out the roof drains. | 10/17/13 | | Roof Drains | Roof |
| White Station HS (2780) 2A | Duct return air to unit in 2 classrooms. | 6/13/14 | Annex | | Sheet Metal |
| White Station HS (2780) 2A | repair side around all locker people are kicking them in and stealing out of them | 1/17/14 | Gym | gym locker room girl | Sheet Metal |
| White Station HS (2780) 2A | big gym boys locker room there is a locker that cannot be opened and child's clothes are in it per mr. Crutchfield 416-1880 | 1/27/14 | | | Sheet Metal |
| White Station HS (2780) 2A | Please repair the CO2 sheet metal vent which is leaning to the side. | 12/17/13 | Mechanical Room | ROTC Building | Sheet Metal |

| Count of Craft | Craft | | | |
|------------------------|----------|---------|-----------|------------|
| Location | Asbestos | Cabling | Carpentry | Electrical |
| Site Station MS (2783) | 3 | 2 | 30 | 35 |
| Grand Total | 3 | 2 | 30 | 35 |

| Location | Request Description | Submittal Date | Area | Description | Area Number | Craft |
|----------------------------|--|----------------|------------|-------------|-------------|-----------|
| White Station MS (2783) 2B | Gym floor need to be re-stained. | 2/26/14 | | | | Asbestos |
| White Station MS (2783) 2B | Request pipe be insulated in the library. | 5/7/14 | | | | Asbestos |
| White Station MS (2783) 2B | Ceiling Tile needs to be replace appears to be MOLDING per Ms. Adil, Plant Mgr. 416.2184 | 10/1/13 | | | | Asbestos |
| White Station MS (2783) 2B | SCS FP-3500 Network Cabling Project- Provide project management for Access DNSI to install network cabling installations and any associated electrical wiring. (Request Network) | 7/30/13 | | | | Cabling |
| White Station MS (2783) 2B | Aftercare need a phone jack install in the cafe dining area. Please see the Principal for more information. | 9/16/13 | Cafeteria | dining area | | Cabling |
| White Station MS (2783) 2B | Auditorium seats need to be repaired. They are loose and some tops are missing. | 5/27/14 | Auditorium | D101 | | Carpentry |
| White Station MS (2783) 2B | FRONT ENTRY DOOR NOT CLOSING. PLANT MGR- ADIL/416.2184 | 2/7/14 | | | | Carpentry |

| | | | | | |
|----------------------------|---|---------|---------------------|----------------------------|-----------|
| White Station MS (2783) 2B | Need a safe in the vault room bolted to the floor. | 2/13/14 | Administration Area | vault room | Carpentry |
| White Station MS (2783) 2B | The iron pole that divide the doors in the band and choir hallway has broken and need to be repair Plant Manager does not have the proper tools to repair it. | 2/18/14 | Hallway/Corridor | D-wing near band and choir | Carpentry |
| White Station MS (2783) 2B | Wood on gym floor is buckled up on one side and can be dangerous. Need to be repaired as soon as possible. | 7/15/13 | Gym | first floor main hall | Carpentry |
| White Station MS (2783) 2B | The front entrance door need to be repaired. The closure on it need to be tighten so it will not broke the glass. It closes really hard. | 9/17/13 | Hallway/Corridor | front entrance door | Carpentry |
| White Station MS (2783) 2B | The door in the boy's locker room hardware need to be replace. It coming apart and causing the key not to work. | 9/17/13 | Gym | locker room | Carpentry |
| White Station MS (2783) 2B | FRONT ENTRANCE DOOR-NOT CLOSING-WON'T BE ABLE TO SECURE BLDG-PLANT MGR 416-2184 KLR | 9/20/13 | | | Carpentry |
| White Station MS (2783) 2B | Request lift be removed from the school. | 9/27/13 | | | Carpentry |
| White Station MS (2783) 2B | Ceiling tile need to be replace in the library, due to a new ac unit being replace. | 4/2/14 | Library | ceiling tile | Carpentry |

| | | | | | |
|----------------------------|---|---------|-----------------|----------------------|-----------|
| White Station MS (2783) 2B | Door will not lock the striker will not go into the plate. | 4/3/14 | Classroom | G-201 | Carpentry |
| White Station MS (2783) 2B | Door in boy's restroom in broken and can not close. | 4/8/14 | Restroom (Boys) | 8th grade hall | Carpentry |
| White Station MS (2783) 2B | Door entering into the hallway to the Plant Manager's office is off track. | 4/15/14 | 1st Floor | Plant Manager office | Carpentry |
| White Station MS (2783) 2B | ENTRANCE DOOR EAST END OF BLDG-HINGES LOOSE CAUSING DOOR TO BE OUT OF ALIGNMENT-WON'T BE ABLE TO SECURE-PLANT MGR ADIL 416-2184 KLR | 5/2/14 | | | Carpentry |
| White Station MS (2783) 2B | Wooden cabinet door in room G228 is broken and need to be repaired. | 5/22/14 | 2nd Floor | room G228 | Carpentry |
| White Station MS (2783) 2B | IRON BAR ON WEST SIDE OF BLDG-COMING UP THRU GROUND AND SBE IS AFRAID STUDENTS MAY TRIP ON IT-SBE ADIL 416-2184 KLR | 8/8/13 | | | Carpentry |
| White Station MS (2783) 2B | Request lift be pick-up and removed for the gym. | 8/16/13 | | | Carpentry |
| White Station MS (2783) 2B | Vent cover in room B129 has come off. I have tried for days to keep it up and it will not stay. Do not want it to fall on a student. Please help. | 8/19/13 | Classroom | B129 | Carpentry |

| | | | | | |
|----------------------------|--|----------|---------------------|---------------------------|-----------|
| White Station MS (2783) 2B | Deliver lift to the school. | 8/28/13 | | | Carpentry |
| White Station MS (2783) 2B | I need a latch for a cabinet in the science lab to lock up some important information. | 10/3/13 | Classroom | science lab G227 | Carpentry |
| White Station MS (2783) 2B | Ceiling in the girls' locker room need to be replace due to a leak. Leak has been repaired. The ceiling does not have regular ceiling tile. | 10/18/13 | Gym | ceiling girls locker room | Carpentry |
| White Station MS (2783) 2B | The school has a new safe and want the old one remove, but it is bolted to the floor. Need a carpenter to help remove the old one and bolted the new one down. | 11/14/13 | Administration Area | vault room | Carpentry |
| White Station MS (2783) 2B | The Main Entrance door to Plant Manager's Office is broken. It has been pull of the henges. | 11/25/13 | Administration Area | Plant Manager's office | Carpentry |
| White Station MS (2783) 2B | main entrance door closure broken and can't secure per Ms. Adill 416-2184 (on east side of building) | 12/2/13 | | | Carpentry |
| White Station MS (2783) 2B | Ceiling tiles in these rooms need to be changed out. They are around the intercom system and they are stained, and need to be cut. | 1/2/14 | Classroom | 224,206,229, and 232 | Carpentry |
| White Station MS (2783) 2B | Need a white board put up in this classroom for a brightlink system they will be installing next week. Thanks | 1/24/14 | Classroom | D120 band room | Carpentry |

| | | | | | |
|----------------------------|---|---------|------------------|-----------------------|------------|
| White Station MS (2783) 2B | Room 161A door is stuck and makes it hard to open/close. | 6/5/14 | Classroom | 161 A | Carpentry |
| White Station MS (2783) 2B | Door closure is broken and need to be repaired. | 6/17/14 | Hallway/Corridor | 6th grade hall or G | Carpentry |
| White Station MS (2783) 2B | Need a box of ceiling tile for classroom. There was a leak and I need to change the spoil ones. | 8/2/13 | Classroom | wing G | Carpentry |
| White Station MS (2783) 2B | The girl's restroom in the gym need metal sanitary napkins containers. | 2/18/14 | Gym | girl's restroom | Carpentry |
| White Station MS (2783) 2B | The outlet in the science lab on the demo table is going bad and will not stay set. Having to keep re-setting it. | 2/5/14 | Classroom | A-138 | Electrical |
| White Station MS (2783) 2B | Computer outlet has come out the wall and need to be repaired. | 2/7/14 | Classroom | 8th gr.hall rm. F206 | Electrical |
| White Station MS (2783) 2B | Lights on the outside in the parking lot is out and need to be replace. | 2/18/14 | Parking Lot | east side of building | Electrical |
| White Station MS (2783) 2B | I need four boxes of F32T8/741/ECOMAX fluorescent lamps. Purchase # 37323. | 2/19/14 | 1st Floor | Main hall | Electrical |

| | | | | | |
|----------------------------|---|---------|------------------|-------------------|------------|
| White Station MS (2783) 2B | I need four boxes of F32T8/741/ECOMAX fluorescent lamps. Purchase # 37323 | 2/19/14 | 1st Floor | Main hall | Electrical |
| White Station MS (2783) 2B | Light cover in corridor near gym need to be mounted. The pin holders are not catching | 2/20/14 | Hallway/Corridor | corridor near gym | Electrical |
| White Station MS (2783) 2B | Balsters in room F232 has gone bad and need to be replace. | 2/24/14 | Classroom | F232 | Electrical |
| White Station MS (2783) 2B | Lights on the outside in front of building balsters are going bad, which has cause the lighting to be very dim. They need to be change as soon as possible for the safety of the staff and students | 1/27/14 | Grounds | front entrance | Electrical |
| White Station MS (2783) 2B | Lights in front of stage in auditorium need to be replace. | 1/27/14 | Auditorium | in front of stage | Electrical |
| White Station MS (2783) 2B | AHU - RMB135 - NOT COMING ON & CAFE REPAIR THERMOSTAT - PM/SIKSILKA 416-2184 | 2/3/14 | | | Electrical |
| White Station MS (2783) 2B | Flag is rapped around pole and cannot get it down. | 3/21/14 | Grounds | flag pole | Electrical |
| White Station MS (2783) 2B | Magnetic on fire door is broken and will not latch. | 4/8/14 | 2nd Floor | 7th grade hall | Electrical |

| | | | | | |
|----------------------------|--|---------|-----------|--------------------|------------|
| White Station MS (2783) 2B | Lights are out in dining area in the cafe | 4/10/14 | Cafeteria | dining area | Electrical |
| White Station MS (2783) 2B | Balster in room B113 has gone bad and need to be replace. | 3/5/14 | Classroom | B113 | Electrical |
| White Station MS (2783) 2B | Lights on the east and west side of the building is out and the lights by the cafe on the outside. | 3/6/14 | | | Electrical |
| White Station MS (2783) 2B | LIGHTS - 2ND FLR BREEZEWAY ALL ARE OUT -VERY DARK PM/LADIL 416-2184 | 8/5/13 | | | Electrical |
| White Station MS (2783) 2B | Lights in the front entrance is out on the outside. | 8/8/13 | Grounds | outside entrance | Electrical |
| White Station MS (2783) 2B | GARBAGE DISPOSAL NOT COMING ON IN KITCHEN(988). PLANT MGR-ADIL/416.2184 | 8/9/13 | | | Electrical |
| White Station MS (2783) 2B | UNIT NOT COMING ON IN RM-D116 PLANT MGR-ADIL/416.2184 | 8/13/13 | | | Electrical |
| White Station MS (2783) 2B | Balster in the girls' locker room has gone bad in the gym. | 8/14/13 | Gym | girls' locker room | Electrical |

| | | | | | |
|----------------------------|--|----------|---------------------|-------------------------|------------|
| White Station MS (2783) 2B | Balster has gone bad in boy's locker room in the gym and need to be replace. Bulbs has been changed. | 8/20/13 | Gym | boys' locker room | Electrical |
| White Station MS (2783) 2B | The garage disposal in the teachers lounge on the F-wing need to be repaired. It will not grind. | 8/26/13 | Administration Area | teacher lounge | Electrical |
| White Station MS (2783) 2B | Lights on the east and west side of the building is out and the lights by the cafe on the outside. | 10/15/13 | Grounds | outside around building | Electrical |
| White Station MS (2783) 2B | Room D120 has a balster that need to be repaired. | 10/15/13 | Classroom | band room | Electrical |
| White Station MS (2783) 2B | Lights on the stage is out and need to be replace. They are over ten feet high. | 10/21/13 | Auditorium | stage | Electrical |
| White Station MS (2783) 2B | BELLS ARE RINGING OFF SCHEDULE DUE TO CLOCKS ARE OFF- AFFECTS THE CHANGING OF CLASSES. PLANT MGR ADIL 416-2184 KLR | 11/5/13 | | | Electrical |
| White Station MS (2783) 2B | Socket in kitchen is not working properly and is continuing to blow out. | 11/12/13 | Kitchen | socket in kitchen | Electrical |
| White Station MS (2783) 2B | BREAKER KITCHEN AREA-KEEPS TRIPPING AND MAKING A POPPING NOISE PER SBE-PLANT MGR ADIL 416-2184 KLR | 11/13/13 | | | Electrical |

| | | | | | |
|----------------------------|---|----------|------------------------|----------------------|--|
| White Station MS (2783) 2B | GYM ONE SIDE BLEACHERS NOT COMING OUT-PLANT MGR ADIL 416-2184 KLR | 11/14/13 | | | Electrical |
| White Station MS (2783) 2B | Garage disposal is broken again and need to be repaired. | 12/3/13 | Kitchen | prep area | Electrical |
| White Station MS (2783) 2B | The light switch in T. Lounge men restroom on 7th grade hall is not working properly. It will come on sometime and sometime it will not. | 12/13/13 | Administration Area | Teacher's Lounge | Electrical |
| White Station MS (2783) 2B | HEAT UNIT RM A146-HAS NO POWER TO IT-PLANT MGR ADIL 416-2184 KLR | 1/7/14 | | | Electrical |
| White Station MS (2783) 2B | There are lights on the 1st and 2nd floor that need to be change that is too high for me to reach. Over 10ft. | 1/15/14 | Hallway/Corri dor | 1st and 2nd floor | Electrical |
| White Station MS (2783) 2B | String on flag pole is struck and will not come down. | 5/27/14 | Grounds | front of building | Electrical |
| White Station MS (2783) 2B | So sorry about that, but need bell change for new school time. | 7/29/13 | Administration Area | | Electrical |
| White Station MS (2783) 2B | A/C RM F223, D125, D120, D116, F207, F, 217, F232, G219, G222, & A161-ALL NOT COOLING- PLANT MGR ADIL 416- 2184 KLR | 4/23/14 | | | Heating/Ventil ation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station MS (2783) 2B | A/C RM F228, F217, F221, F229, F223-ALL NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 4/24/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C PRIN'S OFC, GYM AREA, & CAFE MGR'S OFC-ALL NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 5/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C GYM AREA-NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C PRIN'S OFC, BANDRM, CHOIR RM, & RM G222-ALL NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | COOLING TOWER IS NOT WORKING HOT IN THE ENTIRE BLDG PLANT MGR ADIL 416-2184 | 4/23/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C PRIN'S OFC-NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 6/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C CAFE AREA, RM F229, & RM F224-ALL NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 6/18/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Monthly - Oil Lube & Belt-White Station Middle - Refer to PM schedule details. | 6/3/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|---------|-----------|-------|---------------------------------------|
| White Station MS (2783) 2B | per ms adill 416-2184 Room A19 no heat | 3/4/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Monthly - Filter- WhiteStation Middle - Refer to PM schedule details. | 3/21/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | 7th grade area (F area) is not heating properly per Ms. Adell 416-2184 | 2/4/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Room A153 not cooling per Adil 416-2184 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Kitchen and Serving Area a/c not cooling per Adil 416-2184 | 8/1/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C ASST PRIN'S OFC- NOT COOLING-PLANT MGR 416-2184 KLR | 9/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | AHU - RM F222, B101, BLOWING NOT HEATING - PM/SIKSILKA 416-2184 | 2/3/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | The vent cover in room A137 is broke and need to be repaired. | 3/24/14 | Classroom | A-137 | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|---------|--|--|---------------------------------------|
| White Station MS (2783) 2B | CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR | 4/1/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | UNIT IN RM D 116 IS NOT COOLING. SBE ADIAL 416-2184 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | 6-UNIT NOT COOLING IN 2-TEACHERS' LOUNGES, RM-D118, D119,D120,B147 PLANT MGR-ADIL/416.2184 | 8/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | 2-RTU NOT COOLING IN KITCHEN, & F-WING PLANT MGR-ADIL/416.2184 | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | RTU RM F222-NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 8/26/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | A/C UNIT MAIN OFC, RMS G215, G217, G218, & F222-ALL NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 9/3/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Principal's office the a/c is not cooling per Ms. Adil 416-2184 | 9/4/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | RTU - FOR PRIN OFC - BLOWING NOT COOLING - PM/IDIL 416-2184 | 9/9/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|--|----------|--|--|---------------------------------------|
| White Station MS (2783) 2B | RTU-A164 SBE'S OFC, GYM & AUDITORIUM-ALL NOT COOLING-PLANT MGR ADIL 416-2184 KLR | 10/14/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Monthly - Oil Lube & Belt- White Station Middle - Refer to PM schedule details. | 10/29/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | UNIT NOT HEATING IN MAIN OFFICE. PLANT MGR-ADIL/416- 2184 | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | repair leaking pump for cooling tower - not to exceed \$5000 | 11/20/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | HEAT LIBRARY-NOT HEATING-PLANT MGR ADIL 416-2184 KLR | 11/25/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | 2-RTU ARE OVERHEATING IN GYM. PLANT MGR-/416.3840 | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | HEAT F WING 7TH GR HALL-NOT HEATING- PLANT MGR ADIL 416- 2184 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Units are NOT HEATING in ROOMS A153, F207, F217, and F223 per Ms. Adil, Plant Mgr. 416.2184 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|----------------------------|---|----------|------------------|-------------------------|---------------------------------------|
| White Station MS (2783) 2B | UNIT NOT HEATING IN LIBRARY PLANT MGR-ADIL/416.2184 | 1/22/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Monthly - Filter-WhiteStation Middle - Refer to PM schedule details. | 7/19/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Yearly - CoolingTowerSTRAINERS-WhiteStation Middl - Refer to PM schedule details. | 3/21/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Monthly - Coil Cleaning - White Station Mdl - Refer to PM schedule details. | 1/27/14 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Monthly - Filter-WhiteStation Middle - Refer to PM schedule details. | 11/22/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Yearly - Oil Samples - White Station Mdl - Refer to PM schedule details. | 9/13/13 | | | Heating/Ventilation /Air Conditioning |
| White Station MS (2783) 2B | Boy's and girl's restroom need to be painted on 1st and 2nd floor. | 2/26/14 | Restroom (Girls) | 1st and 2nd floor | Painting |
| White Station MS (2783) 2B | Boys and Girls restroom on 1st and 2nd floor need to be painted. | 5/22/14 | | boys and girls restroom | Painting |

| | | | | | |
|----------------------------|---|---------|----------|-------------------|----------|
| White Station MS (2783) 2B | Stairway rails on 1st and 2nd floor need to be painted. The paint is chipping really bad. | 6/20/14 | Stairway | 1st and 2nd floor | Painting |
| White Station MS (2783) 2B | touchup hallways , repair sheetrock in hallway entrance | 1/29/14 | | | Painting |
| White Station MS (2783) 2B | GRAFFITI OUTSIDE ON FRONT OF SCHOOL ON COLUMNS-PLANT MGR ADIL 416-2184 KLR | 4/1/14 | | | Painting |
| White Station MS (2783) 2B | GRAFFITI IN 8TH GR G RR 1ST FLR ON STALL WALLS-PLANT MGR ADIL 416-2184 KLR | 4/1/14 | | | Painting |
| White Station MS (2783) 2B | paint lines on football field | 5/22/14 | | | Painting |
| White Station MS (2783) 2B | paint lines on football field | 5/12/14 | | | Painting |
| White Station MS (2783) 2B | paint lines on football field | 8/26/13 | | | Painting |
| White Station MS (2783) 2B | GRAFFITI ON DUMPSTER DOOR PLANT MGR-ADIL/416.2184 | 8/29/13 | | | Painting |

| | | | | | |
|----------------------------|--|---------|------------------|------------|----------|
| White Station MS (2783) 2B | paint lines on football field | 9/5/13 | | | Painting |
| White Station MS (2783) 2B | Eyewash station in room A161 is leaking. | 2/11/14 | Classroom | A161 | Plumbing |
| White Station MS (2783) 2B | GAS SMELL IN SCIENC LAB RM F207-PLANT MGR ADIL 416-2184 KLR | 2/28/14 | | | Plumbing |
| White Station MS (2783) 2B | per ms adill 416-2184 ceiling leak in principal's office (also freezing cold possibly HVAC unit) | 3/4/14 | | | Plumbing |
| White Station MS (2783) 2B | PIPE & VALVE ON COOLING TOWER-LEAKING-PLANT MGR ADIL 416-2184 KLR | 2/21/14 | | | Plumbing |
| White Station MS (2783) 2B | WTR FAUCET -IN THE CUSTODIAL CLOSET HAS BUSTED AND FLOOD THE MAIN OFC - PM - IDAIL 416-41 | 7/22/13 | | | Plumbing |
| White Station MS (2783) 2B | Toilet in Adult restroom(Ladies) on 1st floor near band room will not flush. Flush valve has gone bad. | 7/22/13 | Restroom (Girls) | | Plumbing |
| White Station MS (2783) 2B | Girl's restroom on the A-Wing is running over when it flush. It is stopped up. | 7/24/13 | Restroom (Girls) | 1st Wing A | Plumbing |

| | | | | | |
|----------------------------|--|---------|---------------------|----------------------------|----------|
| White Station MS (2783) 2B | CEILING UNIT IS LEAKING WATER IN RM-G227. PLANT MGR-ADIL/416.2184 | 7/31/13 | | | Plumbing |
| White Station MS (2783) 2B | Toilet in Men's Restroom in T. Lounge on 8th grade hall need to be molded back to the floor. | 4/2/14 | Administration Area | restroom in teacher lounge | Plumbing |
| White Station MS (2783) 2B | Toilet in girl's restroom on B-hall seat is broken and need to be replace. | 4/3/14 | Restroom (Girls) | B hallway | Plumbing |
| White Station MS (2783) 2B | SINK B RR 6TH GR HALL- LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF-WATER EVERYWHERE- PLANT MGR ADIL 416-2184 KLR | 4/9/14 | | | Plumbing |
| White Station MS (2783) 2B | There is a leak coming from the custodial closet. | 4/15/14 | Administration Area | custodial closet | Plumbing |
| White Station MS (2783) 2B | On the B and G wing a stall in each boy's restroom is will not flush. I have tried to plunge it and it continue to run over. | 3/7/14 | Restroom (Boys) | B and G wing | Plumbing |
| White Station MS (2783) 2B | PIPE ON TOILET HAS WATER RUNNING IN B/LOCKER RM GYM . PLANT MGR-ADIL/416.2184 | 4/24/14 | | | Plumbing |
| White Station MS (2783) 2B | Toilet in boy's restroom in 2nd stall is stopped up. Plant Manager has plunged it and it is not working. | 5/2/14 | Restroom (Boys) | 1st B hall | Plumbing |

| | | | | | |
|----------------------------|---|---------|-----------|--------------------------|----------|
| White Station MS (2783) 2B | Unstop down spouts | 5/20/14 | | | Plumbing |
| White Station MS (2783) 2B | Down spouts in front of building need to flush out. | 5/7/14 | Grounds | front entrance west end | Plumbing |
| White Station MS (2783) 2B | Down sprout in front of building on the right side need to be clean | 5/16/14 | Grounds | front entrance | Plumbing |
| White Station MS (2783) 2B | Water fountain near café facing has come off and need to be replace | 5/19/14 | 1st Floor | water fountain near cafe | Plumbing |
| White Station MS (2783) 2B | 7th grade hall urinal flooding and urinal in gym won't flush per Adil 416-2184 | 8/6/13 | | | Plumbing |
| White Station MS (2783) 2B | COMMODE B RR G WING 6TH GR HALL- STOPPED UP & HAS FECES IN IT-STARTING TO SMELL REAL BAD- SBE ADIL 416-2184 KLR | 8/7/13 | | | Plumbing |
| White Station MS (2783) 2B | A/C IN RM A154- LEAKING-SBE ADIL 416-2184 KLR | 8/8/13 | | | Plumbing |
| White Station MS (2783) 2B | Back flow test. | 8/8/13 | | | Plumbing |

| | | | | | |
|----------------------------|--|---------|------------------|---------------------|----------|
| White Station MS (2783) 2B | Toilet in boy's restroom in the gym is not flushing. | 8/13/13 | Gym | boy's restroom | Plumbing |
| White Station MS (2783) 2B | Sink in girls' restroom in the gym is coming off the wall. | 8/13/13 | Gym | girl's restroom | Plumbing |
| White Station MS (2783) 2B | Urinal in boy's restroom will not flush properly, which is causing it to overflow. | 8/14/13 | Restroom (Boys) | A-wing 8th gr. hall | Plumbing |
| White Station MS (2783) 2B | STUDENTS HAVE KNOCKED WATER FOUNTAIN IN CAFE- HANGING OFF WALL & WATER IS GOING EVERYWHERE PER SBE, CAN'T CONTAIN- SBE ADIL 416.24841414 | 8/14/13 | | | Plumbing |
| White Station MS (2783) 2B | Toilet in girls' restroom on the 6th grade hall G-wing will not flush properly. | 8/20/13 | 2nd Floor | G-wing | Plumbing |
| White Station MS (2783) 2B | Per Mr. Shaun Page, Principal at 901.299.2951 or 901.416.2070. The Science Teacher said a knob has been removed from one of the lab working area and she smells an odor of soap. | 8/21/13 | | | Plumbing |
| White Station MS (2783) 2B | Water fountain on the B-wing is broken and the front cover has come off. There are pipes exposed. | 8/29/13 | Hallway/Corridor | B-wing 1st floor | Plumbing |
| White Station MS (2783) 2B | Water fountain on F wing is broken. The mouth piece is twisted and water is coming out on the floor. | 8/30/13 | Hallway/Corridor | F wing | Plumbing |

| | | | | | |
|----------------------------|--|----------|---------------------|-----------------------|----------|
| White Station MS (2783) 2B | in the girls restroom 8th grade hallway there is a toilet that continuously runs and cannot stop per Ms. Adil 416-2184 | 9/10/13 | | | Plumbing |
| White Station MS (2783) 2B | 8th grade hallway girls restroom water is too high in commode that when it is flushed it is running over per Ms. Adil 416-2184 plumber was there Tuesday but is needed again today | 9/11/13 | | | Plumbing |
| White Station MS (2783) 2B | PER SBE, PIPE LEAKING G LOCKER RM SHOWER AREA IN A LIGHT FIXTURE-PLANT MGR ADIL 416-2184 KLR | 10/16/13 | | | Plumbing |
| White Station MS (2783) 2B | Need toilet seat replace in Teacher's Lounge in the B-wing. Screw has been stripped and it will not stay tighten. | 10/18/13 | Administration Area | teacher lounge B-wing | Plumbing |
| White Station MS (2783) 2B | SEWAGE SMELL IN AUDIT. PLANT MGR-ADIL/416.2184 | 10/24/13 | | | Plumbing |
| White Station MS (2783) 2B | There is a sewer smell in the auditorium. | 10/25/13 | | | Plumbing |
| White Station MS (2783) 2B | Pipe to the cooling tower is leaking. | 10/29/13 | Mechanical Room | outside cooling tower | Plumbing |
| White Station MS (2783) 2B | Assist zone to relocate vent pipes on roof | 10/30/13 | | | Plumbing |

| | | | | | |
|----------------------------|---|----------|---------------------|----------------|----------|
| White Station MS (2783) 2B | Wash main sewer to street | 10/30/13 | | | Plumbing |
| White Station MS (2783) 2B | SEWER SMELL IN CAFE & KITCHEN AREAS- PLANT MGR ADIL 416-2184 KLR | 11/15/13 | | | Plumbing |
| White Station MS (2783) 2B | COOLING TOWER - PIPE LEAKING - PM/SIKSIKADLE 416-2184 | 11/20/13 | | | Plumbing |
| White Station MS (2783) 2B | Girls' restroom on the 8th grade hall has a toilet that is not flushing. Need to be repaired. | 11/20/13 | Restroom (Girls) | 8th grade hall | Plumbing |
| White Station MS (2783) 2B | Sink in the teacher lounge on 8th grade hall is not draining properly. | 12/3/13 | Administration Area | teacher lounge | Plumbing |
| White Station MS (2783) 2B | COOLING TOWER- WATER RUNNING FROM IT, FLOODING PARKING LOT-PLANT MGR ADIL 416-2184 KLR | 12/16/13 | | | Plumbing |
| White Station MS (2783) 2B | Sink in dining area faucet handle is broken completely off. | 12/16/13 | Cafeteria | dining area | Plumbing |
| White Station MS (2783) 2B | Two urinals in the boys' restroom will not flush. The handle is broken. | 12/27/13 | Restroom (Boys) | B wing | Plumbing |

| | | | | | |
|----------------------------|--|---------|---------------------|----------------------|----------|
| White Station MS (2783) 2B | COOLING TOWER PIPE HAVE BURST AND WATER HAS FROZEN UP. PLANT MGR ADIL 416-2184 KLR | 1/6/14 | | | Plumbing |
| White Station MS (2783) 2B | Water cooler on the 6th grade hall cover has been broken off and it is showing the inside that may be dangerous to the students. | 1/22/14 | Hallway/Corridor | Gwing/6th grade hall | Plumbing |
| White Station MS (2783) 2B | A/C RM G227-LEAKING- PLANT MGR ADIL 416-2184 KLR | 6/24/14 | | | Plumbing |
| White Station MS (2783) 2B | A/C RM G227-DRAINPAN STOPPED UP & LEAKING PLANT MGR ADIL 416-2184 KLR | 6/16/14 | | | Plumbing |
| White Station MS (2783) 2B | PIPE is LEAKING on the EXPLORATORY HALLWAY per Ms. Adil, Plant Mgr. 416.2184 | 5/23/14 | | | Plumbing |
| White Station MS (2783) 2B | Condenses line need to be connected to the new unit in the library. | 4/23/14 | Library | | Plumbing |
| White Station MS (2783) 2B | The roof is leaking in the gym on the east side. | 2/4/14 | Gym | roof | Roof |
| White Station MS (2783) 2B | Roof in front of Main Office and gym is leaking. | 4/28/14 | Administration Area | front office | Roof |

| | | | | | |
|----------------------------|---|---------|---------------------|-----------|-------------|
| White Station MS (2783) 2B | Roof is leaking in rm. F229 storage closet. | 5/14/14 | Classroom | Rm.F229 | Roof |
| White Station MS (2783) 2B | SERIOUS ROOF LEAK in the GYM per Ms. Adil, Plant Mgr. 416.2184 | 12/5/13 | | | Roof |
| White Station MS (2783) 2B | Request downspout be repaired. It is located in the front of the building. | 2/12/14 | | | Sheet Metal |
| White Station MS (2783) 2B | The down sprout in front of the building need to be repaired. It is broken. | 11/5/13 | | | Sheet Metal |
| White Station MS (2783) 2B | Need air vents in the Main Office restrooms. There is no windows or any air circulation in these restrooms. | 9/27/13 | Administration Area | restrooms | Sheet Metal |

| HVAC | Painting | Plumbing | Roof | Sheet Metal | Grand Total |
|------|----------|----------|------|-------------|-------------|
| 39 | 11 | 53 | 4 | 3 | 100 |
| 39 | 11 | 53 | 4 | 3 | 100 |

| Count of Craft | Craft | | | | | | | | |
|--------------------|----------|----------|-----------|------------|------|----------|----------|-------------|-------------|
| | Location | Asbestos | Carpentry | Electrical | HVAC | Painting | Plumbing | Sheet Metal | Grand Total |
| low Oaks ES (2800) | | 2 | 19 | 27 | 50 | 2 | 46 | 3 | 149 |
| Grand Total | | 2 | 19 | 27 | 50 | 2 | 46 | 3 | 149 |

| Location | Request Description | Submittal Date | Area Description | Area Number | Craft |
|--------------------------|--|----------------|------------------|-------------|-----------|
| Willow Oaks ES (2800) 2B | class room flooded over weekend tiles are buckeled and needs to be replaced.[Att Mr. Jim Davis]. | 6/17/14 | 1st Floor | rm d39 | Asbestos |
| Willow Oaks ES (2800) 2B | requisting cork bord strips to be placed out side class rooms for displays in hallways. | 12/19/13 | 1st Floor | hallways | Asbestos |
| Willow Oaks ES (2800) 2B | steps are in need of repair. safty hazord. | 1/21/14 | Portables | portable 64 | Carpentry |
| Willow Oaks ES (2800) 2B | Please deliver 2 foot lamps to sbe. | 2/7/14 | | | Carpentry |
| Willow Oaks ES (2800) 2B | stall door is ripped off and need to be replaced. | 3/20/14 | Annex | girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | stall door broken, needs to be rehanged. | 4/22/14 | Annex | girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | meatal plate need to be rehanged .Drivers keep knocking it down. safty hazard. | 5/8/14 | Kitchen | back door | Carpentry |

| | | | | | |
|--------------------------|--|----------|-----------|--------------------|-----------|
| Willow Oaks ES (2800) 2B | stall door broken off need to be rehanged and sharp hinges are a safty hazord. | 9/3/13 | 1st Floor | D hall girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | requisting white bords to replace old chalk bords in this class room. | 9/13/13 | 1st Floor | RM f-59 | Carpentry |
| Willow Oaks ES (2800) 2B | stall door is broken off hinges need to be rehanged. | 10/3/13 | 1st Floor | d hall girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | stall door is broken off hinges and need to be rehanged. | 10/4/13 | 1st Floor | d hall girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | requisting calking to seal hole where wall has seperated from window. | 10/16/13 | 1st Floor | southeast entrance | Carpentry |
| Willow Oaks ES (2800) 2B | requisting white bord to replace old torn up bord with new one. | 7/25/13 | 1st Floor | rm f 64 | Carpentry |
| Willow Oaks ES (2800) 2B | cealing tiles falling | 8/8/13 | 1st Floor | B hallway | Carpentry |
| Willow Oaks ES (2800) 2B | entrance door is not closing proper,needs to be adjusted for safty reasons. | 8/9/13 | 1st Floor | southeast entrance | Carpentry |

| | | | | | |
|--------------------------|---|---------|-----------|-----------------|------------|
| Willow Oaks ES (2800) 2B | safety rail in stall broken down needs to be rehanged. | 1/15/14 | 1st Floor | b hall girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | requesting cork bord strips to be placed out side class rooms for displays in hallways. | 12/4/13 | 1st Floor | hallways | Carpentry |
| Willow Oaks ES (2800) 2B | stall door torn off and need 4 tissue holder installed. | 7/31/13 | 1st Floor | d hall girls rr | Carpentry |
| Willow Oaks ES (2800) 2B | requesting 4 tissue holders to be installed. | 7/31/13 | 1st Floor | A hall | Carpentry |
| Willow Oaks ES (2800) 2B | window broken needs to be replaced. | 7/22/13 | 1st Floor | rm d41 | Carpentry |
| Willow Oaks ES (2800) 2B | window broken in classroom need to be replaced [Saftey hazord]. | 8/7/13 | 1st Floor | rm A 02 | Carpentry |
| Willow Oaks ES (2800) 2B | replace light fixture in bathroom. | 1/17/14 | 1st Floor | nurses bathroom | Electrical |
| Willow Oaks ES (2800) 2B | requesting flood lights [that are located in the ceiling] to be changed. | 2/25/14 | Cafeteria | dinning area | Electrical |

| | | | | | | |
|--------------------------|--|---------|-----------|----------|-----------------|------------|
| Willow Oaks ES (2800) 2B | AHU CAFE NE RM-NOT COMING ON-SBE FISHER 416-2244 KLR | 8/1/13 | | | | Electrical |
| Willow Oaks ES (2800) 2B | emergency lights are not working in all 3 portables. | 4/9/14 | Portables | 62,63 64 | | Electrical |
| Willow Oaks ES (2800) 2B | emergency lights not working in serving line nor in dish washing area. | 4/9/14 | Cafeteria | 62,63 64 | 64 | Electrical |
| Willow Oaks ES (2800) 2B | lights out in emergency lighting. e hall across from rm 48 f hall across from rm 57 | 4/9/14 | 1st Floor | | e hall/f hall | Electrical |
| Willow Oaks ES (2800) 2B | light fixture is out need balast replaced. | 4/11/14 | 1st Floor | | teachers lounge | Electrical |
| Willow Oaks ES (2800) 2B | per mr fisher 416-2244 half of the library outlets are not working and it is not the breaker | 5/7/14 | | | | Electrical |
| Willow Oaks ES (2800) 2B | A/C RM F56-NOT COMING ON-PLANT MGR FISHER 416-2244 KLR | 6/13/14 | | | | Electrical |
| Willow Oaks ES (2800) 2B | Air compressor that runs annex shut down and won't come back on per Mr. Fisher 416-2244 | 9/5/13 | | | | Electrical |

| | | | | | |
|--------------------------|--|----------|-----------|------------------|------------|
| Willow Oaks ES (2800) 2B | Run new circuit for air compressor. | 9/30/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | the outlet burned out to the a/c unit and need to be replaced. | 10/18/13 | Portables | rm 63 | Electrical |
| Willow Oaks ES (2800) 2B | requesting 4 security lightbulbs to be changed due to security problem. | 10/24/13 | | outside building | Electrical |
| Willow Oaks ES (2800) 2B | RECEPTACLE KITCHEN FOR FREEZER-HAS BURNED OUT-WILL NEED-PLANT MGR FISHER 416-2244 KLR | 11/1/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | UNIT IN THE CAFE IS NOT COMING ON AND THE THE UNIT IN THE ANNEX KEEP TRIPPING. SBE FISHER 416-0763 | 7/25/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | two outlets are burnt out need to be replaced. | 7/29/13 | 1st Floor | rm library | Electrical |
| Willow Oaks ES (2800) 2B | COMPRESSOR NOT COMING ON THRU ENTIRE ANNEX. PLANT MGR-FISHER/416.2196 | 8/16/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | CONDENSER UNIT NOT COMING IN CAFE, & WINDOW UNIT IN PORT-64. PLANT MGR-FISHER/416.5020 | 8/20/13 | | | Electrical |

| | | | | | |
|--------------------------|---|----------|-----------|----------------------------|------------|
| Willow Oaks ES (2800) 2B | requesting lights for these portables that are out. | 8/21/13 | Portables | p/e 63-art 64 | Electrical |
| Willow Oaks ES (2800) 2B | light fixture is out need balast replaced. | 8/26/13 | Cafeteria | serving line | Electrical |
| Willow Oaks ES (2800) 2B | A/C not working at all in the dining area per Mr. Fisher 416-4422 | 8/6/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | HEAT RM D36-NOT COMING ON-PLANT MGR FISHER 416-2244 KLR | 11/14/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | TRUCK KNOCKED DOWN WIRING-CALLED BY E HAWKINS KLR | 11/20/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | requesting light fixture to be replaced due to being damaged beyond repair. | 12/4/13 | 1st Floor | teacher lounge bathroom | Electrical |
| Willow Oaks ES (2800) 2B | HEAT RMS B13 & F59-BOTH NOT COMING ON-PLANT MGR FISHER 416-2244 KLR | 12/13/13 | | | Electrical |
| Willow Oaks ES (2800) 2B | per Mr Fisher 416-2244 the ventilator in SBE office not coming on | 1/7/14 | | | Electrical |

| | | | | | |
|--------------------------|---|---------|---------|-------------|---------------------------------------|
| Willow Oaks ES (2800) 2B | need light bulbs to be replaced in sign out front of school or balast is bad. | 1/16/14 | Grounds | marqie sign | Electrical |
| Willow Oaks ES (2800) 2B | Monthly - Filters-Willow Oaks Elem - Refer to PM schedule details. | 6/24/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT RM D36, F56, F62, & PORT 63- ALL NOT HEATING-PLANT MGR FISHER 416-2244 KLR | 1/28/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UV NOT HEATING IN RM-F56 PLANT MGR-FISHER/416.5020 | 1/29/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | per mr watkins 416-1009 room D41 (pre K) not heating | 2/10/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT RM F66-NOT HEATING-PLANT MGR WATKINS 416-8144 KLR | 2/11/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | per mr watkins 864-1009 rooms D13 and F58 are blowing cold | 2/12/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNIT VENT - RM B15 - BLOWING NOT HEATING - PM/WATKINS 864-1009 | 2/14/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--|---------------------------------------|
| Willow Oaks ES (2800) 2B | Monthly - Filters-Willow Oaks Elem - Refer to PM schedule details. | 2/25/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Monthly - Air Compressor - Willow Oaks Elem - Refer to PM schedule details. | 2/28/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | CHILLER NOT COMING ON. PLANT MGR-FISHER/416.2196 | 8/2/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT PRE-K RM D41-NOT HEATING-PLANT MGR FISHER 416-2244 KLR | 3/6/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT RM D41-NOT HEATING-PLANT MGR FISHER 416-2244 KLR | 3/17/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | A/C RM D37-HAS A STRONG ODOR COMING FROM IT-PLANT MGR FISHER 416-2196 KLR | 4/22/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | FLOOR DRAIN RM B16 & F66-BACKING UP WATER IN BOTH RMS-PLANT MGR FISHER 416-2244 KLR | 5/9/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNIT VENTILATOR is STOPPED UP in A02 per Mr. Fisher, Plant Mgr. 416.2244 | 5/12/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|----------|--|--|---------------------------------------|
| Willow Oaks ES (2800) 2B | per mr fisher 416-2244 room F56 UV water is backing up into classroom | 5/14/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UV RM B16-DRAINPAN STOPPED UP & LEAKING WATER-PLANT MGR FISHER 416-2244 KLR | 5/19/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | CHILLER - COVERS THE CAFE - BLOWING NOT COOLING AND HAVING A PROGRAM THIS MORNING @ 9:00 - PM/FISHER 416-2244 | 5/22/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Monthly - Air Compressor - Willow Oaks Elem - Refer to PM schedule details. | 8/30/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | FLOOR DRAIN BACKING UP IN RM F66B PER SBE-PLANT MGR FISHER 416-5020 KLR | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | A/C RM B13-NOT COOLING-PLANT MGR FISHER 416-5020 KLR | 10/1/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Monthly - Filters-Willow Oaks Elem - Refer to PM schedule details. | 10/22/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNIT NOT HEATING IN RM-D44. PLANT MGR-FISHER/416.2196 | 11/1/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|----------|--|--|---------------------------------------|
| Willow Oaks ES (2800) 2B | UNIT KEEPS SHUTTING OFF IN RM-A03. PLANT MGR-FISHER/416.2196 | 11/1/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT IN RMS A03, B13, & B14-ALL NOT HEATING-PLANT MGR FISHER 416-2244 KLR | 11/12/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNIT NOT HEATING IN RM-D41. PLANT MGR-FISHER/416.5020 | 11/13/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Annex not cooling. | 7/8/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | CHILLER IS NOT COMING ON. CUST. MANGER - 416-2196 | 7/10/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNTIS ARE NOT COOLING IN RM A04,B13,14,15 .D38, E WING PRIN. ALEXANDER | 7/12/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNITS ARE NOT COOLING IN RM D42, D40. SBE FISHER 416-0763 | 7/18/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | 3-AHU#2,3,4 NOT COMING ON IN 5TH, 2ND, 4TH GRADE HALLS. SBE-FISHER/416-2196 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|---|---------|--|--|---------------------------------------|
| Willow Oaks ES (2800) 2B | UV IS LEAKING WATER IN RM-B16. SBE-FISHER/416-2196 | 7/24/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNITS IN RMS A04,B08,B13,B14,B15,D37,D38,D40,D42S, F53,F59 NOT COOLING SBE FISHER 416-0763 | 7/25/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNITS ARE NOT COMING ON IN RMS F53, A03 BE FISHER 416-2196 | 7/30/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | 7-UV NOT COOLING THRU ENTIRE ANNEX BLDG, & RM-B13 PLANT MGR-FISHER/416.2196 | 8/7/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Window unit in Portable #64 is sparking fire when Mr. Fisher, Plant Mgr. 901.416.2244 turns on unit. The unit also trips the breaker. | 8/21/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | ENTIRE ANNEX NOT COOLING-SBE FISHER 416-2196 KLR | 8/5/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Unit Ventilators are NOT COMING ON in ROOMS A03, A04, and B13 per Mr. Fisher, Plant Mgr. 416.2244 | 12/4/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Unit Ventilator is NOT HEATING in ROOM D41 per Mr. Fisher, Plant Mgr. 416.2244 | 12/4/13 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|----------|--|--|---------------------------------------|
| Willow Oaks ES (2800) 2B | HEAT RMS D41 & F62-BOTH NOT HEATING-PLANT MGR FISHER 416-2244 KLR | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | portable 62 needs a new window unit. | 12/16/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UNIT VENT - RM D41 - BLOWING NOT HEATING - PM/WATKINS 864-1009 | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT ANNEX BLDG, PRE-K RM D41, & RM B13-ALL NOT COMING ON-CALLED IN BY PRIN P ALEXANDER 416-2196 KLR | 12/17/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | UV RM A04-NOT HEATING-PLANT MGR FISHER 416-2196 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | HEAT RM B13-NOT HEATING-PLANT MGR FISHER 416-2196 KLR | 1/6/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | per Mr. Fisher 416-2244 rooms B13 and A04 are blowing cold air | 1/7/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Units are NOT HEATING in Rooms D41, F62, and F64 per Mr. Fisher, Plant Mgr. 416.2244 | 1/7/14 | | | Heating/Ventilation /Air Conditioning |

| | | | | | |
|--------------------------|--|----------|---------------------|-------------|---------------------------------------|
| Willow Oaks ES (2800) 2B | filters were removed,extreamly dirty causing unit not to work properly,need to be replaced soon. All filters need to be changed. | 11/14/13 | | rms d38/d41 | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Monthly - Oil Lube & Belt-Willow Oaks Elementary - Refer to PM schedule details. | 8/3/13 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | Monthly - Oil Lube & Belt-Willow Oaks Elementary - Refer to PM schedule details. | 3/1/14 | | | Heating/Ventilation /Air Conditioning |
| Willow Oaks ES (2800) 2B | requisting touch up painting in main office. | 2/25/14 | Administration Area | main office | Painting |
| Willow Oaks ES (2800) 2B | requisting 2 spaces to be painted for new assti principlal and secretary in parking lot. | 8/28/13 | Grounds | parking lot | Painting |
| Willow Oaks ES (2800) 2B | A/C RM D42-DRAINPAN STOPPED UP & LEAKING-PLANT MGR FISHER 416-2244 KLR | 6/17/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UV RM D40-LEAKING-PLANT MGR FISHER 416-2244 KLR | 6/19/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | A/C RM A02-LEAKING-PLANT MGR FISHER 416-2244 KLR | 6/20/14 | | | Plumbing |

| | | | | | |
|--------------------------|--|---------|-----------|----------------|----------|
| Willow Oaks ES (2800) 2B | UNIT VENT - RM A03 - LEAKING - FLOODING THE FLR - PM/FISHER 416-2244 | 6/23/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IN VENT IN RM B16 IS LEAKING . SBE FISHER 416-2244 | 6/23/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | A/C RM B10, B12, 7 B16-ALL ARE LEAKING-PLANT MGR FISHER 416-2244 KLR | 6/25/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | sink foucet need stim replaced on 3 faucets. | 2/24/14 | 1st Floor | a hall | Plumbing |
| Willow Oaks ES (2800) 2B | toilet will not stop running,need to be repaired. | 3/20/14 | Annex | boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | toilet will not stop running caused flooding in bathroom. | 3/27/14 | 1st Floor | teachers loung | Plumbing |
| Willow Oaks ES (2800) 2B | urnel will not stop running. | 4/11/14 | Annex | boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IS LEAKING WATER IN RM-A02,A06 PLANT MGR-FISHER/416.5020 | 4/14/14 | | | Plumbing |

| | | | | | |
|--------------------------|---|---------|-----------|-------------------|----------|
| Willow Oaks ES (2800) 2B | boys ural is stoped up and flooding the bathroom. | 4/14/14 | Annex | boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | urnal stop up. need to be fixed. | 4/14/14 | 1st Floor | b hall boys bb | Plumbing |
| Willow Oaks ES (2800) 2B | toilet leaking flooding bathroom. | 4/14/14 | 1st Floor | f hall boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | urinal is continuously running on floor causing saftey problem. | 4/22/14 | 1st Floor | f build boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | urnal is leaking badly causing saftey problem. | 4/24/14 | 1st Floor | f hallway boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | per mr fisher 416-2244 unit in room F66 is leaking | 5/7/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | A/C RM B16-DRAIN STOPPED UP & LEAKING WATER OUT-PLANT MGR FISHER 416-2196 KLR | 5/8/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UV RM F59-LEAKING-PLANT MGR FISHER 416-2244 KLR | 6/6/14 | | | Plumbing |

| | | | | | |
|--------------------------|---|----------|-----------|-------------------|----------|
| Willow Oaks ES (2800) 2B | UNIT IS LEAKING WATER IN RM-F56 PLANT MGR-FISHER/416.5020 | 6/11/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IS LEAKING WATER IN RM-D36 PLANT MGR-FISHER/416.2196 | 6/16/14 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IS LEAKING WATER IN RM-A02. PLANT MGR-FISHER/416.5020 | 8/30/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UV IS LEAKING WATER IN RM-D42. PLANT MGR-FISHER/416.2196 | 8/30/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | Please test RP devices on site. | 9/16/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | handicapped toilet not working. | 9/19/13 | 1st Floor | D-hall boys RR | Plumbing |
| Willow Oaks ES (2800) 2B | 2-AHU ARE LEAKING WATER IN RM- F56,A5. PLANT MGR-FISHER/416.2196 | 10/15/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | WATER HEATER KITCHEN-PILOT NEED TO BE LIT-NO HOT WATER TO KITCHEN-PLANT MGR FISHER 416- 2196 KLR | 10/21/13 | | | Plumbing |

| | | | | | |
|--------------------------|---|---------|-----------|---------|----------|
| Willow Oaks ES (2800) 2B | UNITS ARE LEAKING IN A02 & A03. PRIN. ALEXANDER | 7/12/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | 2-UV ARE FLOODING IN RM-B16, D42(NO ID). SBE-FISHER/416-5020 | 7/17/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IN RM B16 IS LEAKING. SBE FISHER 416-0763 | 7/18/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | Ventilating unit leaking in rm D41 per mr. fisher 416-2196 | 7/22/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IN RM A02 & A03 IS LEAKING. SBE FISHER | 7/25/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | 3 comp. sink is leaking badly faucet needs to be replaced due to rust and corroding | 7/25/13 | 1st Floor | kitchen | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IN RM F66 IS LEAKING SBE FISHER 416-2196 | 7/30/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | AHU IS LEAKING WATER IN B-HALL . PLANT MGR-FISHER/416.5020 | 8/9/13 | | | Plumbing |

| | | | | | |
|--------------------------|--|----------|-----------|-----------------|----------|
| Willow Oaks ES (2800) 2B | AHU IS FLOODING B-HALL . PLANT MGR-FISHER/416.2196 | 8/9/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | AHU IS LEAKING IN A-HALL INTO LIGHT FIXTURE. PLANT MGR-FISHER/416.5020 | 8/12/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | E52 unit ventilator backing up and leaking per Mr. Fisher 416-2244 | 8/14/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | toilet will not stop running | 8/26/13 | 1st Floor | b-hall-girls RR | Plumbing |
| Willow Oaks ES (2800) 2B | UV IS FLOODING IN RM-F62 PLANT MGR-FISHER/416.5020 | 8/6/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | Install automatic bleed line on air compressor in the annex building. | 8/6/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UNIT IS LEAKING WATER IN RM- B114. PLANT MGR-FISHER/416.2196 | 8/6/13 | | | Plumbing |
| Willow Oaks ES (2800) 2B | UV IS LEAKING WATER IN RM-F56 PLANT MGR-FISHER/416.5020 | 11/18/13 | Classroom | | Plumbing |

| | | | | | |
|--------------------------|--|----------|-----------|-----------------------|-------------|
| Willow Oaks ES (2800) 2B | p-trap has a hole in it needs to be replaced. | 12/4/13 | 1st Floor | b hall hand wash sink | Plumbing |
| Willow Oaks ES (2800) 2B | p traps on water fountain need to be replaced or repaired. water leaking badly. | 12/11/13 | 1st Floor | A hall/ b hall | Plumbing |
| Willow Oaks ES (2800) 2B | toilet will not stop running and leaking. | 12/19/13 | 1st Floor | A hall boys rr | Plumbing |
| Willow Oaks ES (2800) 2B | requisting two grides to cover holes to prevent rats from intering building.there are two large openings in this part of building. | 8/26/13 | 1st Floor | equipment room | Sheet Metal |
| Willow Oaks ES (2800) 2B | Remove cover over chimney to porvide ventalation in basement. | 4/15/14 | | | Sheet Metal |
| Willow Oaks ES (2800) 2B | Using sheetmetal, blankoff and waterproof the OSA louver to AHU-1 thru AHU-5 serving the hallways. | 8/19/13 | | | Sheet Metal |