

Count of Craft	Craft							Grand Total
	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	
Location								
Hill, A.B. ES (2005) 1A	1	13	25	39	3	15	4	100
Grand Total	1	13	25	39	3	15	4	100

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Hill, A.B. ES (2005) 1A	Cove base coming off wall in all areas of the school.	11/4/13	1st Floor		Asbestos
Hill, A.B. ES (2005) 1A	2-DOOR HANDLES ARE BROKEN, CAN'T SECURE plant mgr- BROWN/416.7844	6/19/14			Carpentry
Hill, A.B. ES (2005) 1A	Request for the fence to be repaired in the courtyard area behind the cafeteria. There are holes cut in it.	7/26/13	Courtyard	Grounds	Carpentry
Hill, A.B. ES (2005) 1A	The second stall from the right. Needs the lock assembly adjusted. Stall will lock you in.	7/30/13	1st Floor	Teachers Lounge	Carpentry
Hill, A.B. ES (2005) 1A	Can't get door open to spinkler riser closet for inspection, key turns both ways but door handle won't turn.	9/4/13			Carpentry
Hill, A.B. ES (2005) 1A	Need the hole in the fence between the south side of the play area and the apartments repaired.	9/4/13			Carpentry
Hill, A.B. ES (2005) 1A	Stall door falling off wall in boys toilet on 1st flr. hall near cafeteria.	9/12/13			Carpentry

Hill, A.B. ES (2005) 1A	Holes in the wall outside of music classroom door need to be repaired	9/19/13	1st Floor		Carpentry
Hill, A.B. ES (2005) 1A	Replace floor tile in room TEST PURPOSE	7/11/13			Carpentry
Hill, A.B. ES (2005) 1A	Doors inside classroom n108 on 2nd fir blue hall not closing properly.	10/15/13	2nd Floor	n108	Carpentry
Hill, A.B. ES (2005) 1A	need ceiling tiles changed in the high level	3/25/14	Library	2nd fir.	Carpentry
Hill, A.B. ES (2005) 1A	Need ceiling tiles changed in stairway between the yellow hall & the green hall	3/25/14	Stairway	2nd fir.	Carpentry
Hill, A.B. ES (2005) 1A	Screw fell out of magnetic fire door holder on 2nd fir. blue hall, door won't stay open.	2/11/14	2nd Floor		Carpentry
Hill, A.B. ES (2005) 1A	Need stall door rehung in girls restroom across from library on 2nd fir.	3/18/14	Restroom (Girls)		Carpentry
Hill, A.B. ES (2005) 1A	projector screen not coming down on the stage	5/20/14	Cafetorium		Electrical

Hill, A.B. ES (2005) 1A	3-UNITS NOT COMING ON IN CAFE. PLANT MGR-JIM/497.7782	6/3/14			Electrical
Hill, A.B. ES (2005) 1A	light out in music rm.	6/9/14	Classroom	music rm.	Electrical
Hill, A.B. ES (2005) 1A	emergency lights on 1st flr. not working	6/17/14	1st Floor		Electrical
Hill, A.B. ES (2005) 1A	Rooftop unit #5 NOT COMING ON per Mr. Brown, Plant Mgr. 416.7844	12/9/13			Electrical
Hill, A.B. ES (2005) 1A	need 3 plastic classroom light cover panels	1/2/14	Custodial		Electrical
Hill, A.B. ES (2005) 1A	Program clock and bells.	7/16/13	Administration Area		Electrical
Hill, A.B. ES (2005) 1A	The four prong outlet In this room will trip If you plug a third device In.	7/26/13	2nd Floor	N-119	Electrical
Hill, A.B. ES (2005) 1A	Water pumps in boiler room no power not working #6 078111, #7 078112, #2 078109 per Mr. Hardman 416-7844	7/31/13			Electrical

Hill, A.B. ES (2005) 1A	The outlet to the milk box has a short In It. Needs to be checked.	8/1/13	Cafeteria	Serving line area	Electrical
Hill, A.B. ES (2005) 1A	milk box socket has a short, shoots fire when touched & kicks out	8/2/13	Cafeteria		Electrical
Hill, A.B. ES (2005) 1A	lights out on backside of building near cafeteria door & boiler rm. door	8/29/13			Electrical
Hill, A.B. ES (2005) 1A	Lights out in 10 units in hallway upstairs need repairing.	9/4/13	Hallway/Corridor		Electrical
Hill, A.B. ES (2005) 1A	2 POLE LIGHTS out behind building near dumpsters, need repairing.	9/4/13			Electrical
Hill, A.B. ES (2005) 1A	Lights out in main office	9/26/13	Administration Area		Electrical
Hill, A.B. ES (2005) 1A	lights out in ceiling	4/1/14	Cafetorium		Electrical
Hill, A.B. ES (2005) 1A	Vent hood not working in the kitchen	4/16/14	Cafeteria		Electrical

Hill, A.B. ES (2005) 1A	Need school bells adjusted to ring at the right time.	4/30/14	Administration Area		Electrical
Hill, A.B. ES (2005) 1A	hot box sockets in cafeteria kitchen burned out & spark fire when used	1/30/14	Cafeteria		Electrical
Hill, A.B. ES (2005) 1A	HAVE NO POWER TO LIGHTS THRU OUT BLDG PLANT MGR- BROWN/416.7844	2/24/14			Electrical
Hill, A.B. ES (2005) 1A	need clock set for daylight saving time	3/17/14	Administration Area	main ofc.	Electrical
Hill, A.B. ES (2005) 1A	Need 3bx of bulbs #46807	11/12/13	Custodial		Electrical
Hill, A.B. ES (2005) 1A	need 3bx of long bulbs #46807	10/9/13	Custodial		Electrical
Hill, A.B. ES (2005) 1A	need 50 long light bulb #46807	8/26/13	Mechanical Room		Electrical
Hill, A.B. ES (2005) 1A	need 3bx of 48" classroom tube light bulbs & 2bx of 24" tube light bulbs.	1/16/14	Custodial		Electrical

Hill, A.B. ES (2005) 1A	Has roof leak in front of stage onto floor and hardwood stage THANKS	7/15/13	Cafeteria	in front of stage	Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	RTU #3 needs new TEC --- relocate controller or insulate pipe so condensate does not leak on controller	6/3/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	RTU #2 ckt #2 possible low of charge	6/3/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	chiller down	6/6/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Monthly - Filter-A.B. Hill Elementary - Refer to PM schedule details.	6/9/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	CHILLER IS IN ALARM - NOT COMING ON - PM/BROWN 416-7844	6/23/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	cafe not cooling	6/23/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	rtu #1 ---- check point 99 -- if it reads 128 you have a bad controller. (replace it)	12/18/13			Heating/Ventilation /Air Conditioning

Hill, A.B. ES (2005) 1A	RTU #5 heat not firing -- - taking over for electrician	12/18/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	HEAT RM 121-NOT HEATING-PLANT MGR BROWN KLR	1/7/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Room S107 a/c leaking equip# 078238 per Mr. Hardman 416- 7844	7/22/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	A/C IN RM 030B-NOT COOLING-SBE BROWN 416-7844 KLR	8/2/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	UNIT NOT COOLING IN RM-S101. PLANT MGR- BROWN/416.7844	8/8/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	AIR COOLED CHILLER OUTSIDE BOILER RM-NOT COOLING-SBE BROWN 416-7844 KLR	8/9/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	rtu #5 not cooling	8/13/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	RTU MUSIC RM-NOT COOLING-PLANT MGR BROWN 416- 7844 KLR	8/23/13			Heating/Ventilation /Air Conditioning

Hill, A.B. ES (2005) 1A	chiller down	9/3/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Monthly - Filter-A.B. Hill Elementary - Refer to PM schedule details.	10/7/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Monthly - Oil Lube & Belt-A.B. Hill Elementary - Refer to PM schedule details.	7/5/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	chiller down	7/8/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	clean chiller	7/10/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	clean vents	4/3/14			Heating/Ventilation /Air Conditioning

Hill, A.B. ES (2005) 1A	Yearly - Air Cool Chillers-A.B. Hill Elementary - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	pumps in alarm	4/28/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	chiller down	5/5/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	UNIT NOT COOLING IN PLANT MGR OFFICE, CAFE , MUSIC RM PLANT MGR- BROWN/416.7844	5/9/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	UNIT is NOT COOLING in ROOM S124 per Mr. Brown, Plant Mgr. 416.7844	5/14/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	reset ems panel	5/14/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Chiller is down thank you.	5/19/14			Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	replace controller on RTU #1	1/30/14			Heating/Ventilation /Air Conditioning

Hill, A.B. ES (2005) 1A	Monthly - Oil Lube & Belt-A.B. Hill Elementary - Refer to PM schedule details.	2/7/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	per mr brown 416-7844 heat pump #6 is not blowing	2/7/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Monthly - Filter-A.B. Hill Elementary - Refer to PM schedule details.	2/10/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	AHU #5 --- purchase and replace heat exchanger	2/13/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	AHU #3 --- purchase and replace heat exchanger	2/13/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	HEAT MUSIC RM- OVERHEATING, TEMP IS 94 & HEAT SBE'S OFC-NOT HEATING- PLANT MGR BROWN 416-7844 KLR	2/26/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	UNIT is NOT HEATING in the MUSIC ROOM per Mr. Brown, Plant Mgr. 416.7844	3/6/14				Heating/Ventilation /Air Conditioning
Hill, A.B. ES (2005) 1A	Paint & plaster peeling off wall real bad in P.E. classroom	3/18/14	2nd Floor	rm. N111		Painting

Hill, A.B. ES (2005) 1A	GRAFFITI IN B/RR. PLANT MGR- BROWN/416.7844	12/12/13			Painting
Hill, A.B. ES (2005) 1A	need graffiti removed from wall in front of school	5/8/14			Painting
Hill, A.B. ES (2005) 1A	water fountain leaking on 2nd flr. next too nurses rm.	6/25/14	2nd Floor		Plumbing
Hill, A.B. ES (2005) 1A	toilet leaking in handicap stall & faucet running water on 2nd floor yellow hall	1/15/14	Restroom (Girls)		Plumbing
Hill, A.B. ES (2005) 1A	Repair roof top unit #3, leaking on stage floor.	7/15/13	Cafetorium		Plumbing
Hill, A.B. ES (2005) 1A	FCU #3 IS LEAKING IN RM-S07 (238). PLANT MGR- HARDMAN/416-7844	7/26/13			Plumbing
Hill, A.B. ES (2005) 1A	GAS SMELL IN KITCHEN AREA- PLANT MGR BROWN 416-7844 KLR	10/16/13			Plumbing
Hill, A.B. ES (2005) 1A	Water fountain on second flr. blue hall won't stop running.	10/22/13	2nd Floor		Plumbing

Hill, A.B. ES (2005) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	4/8/14			Plumbing
Hill, A.B. ES (2005) 1A	Water line to the courtyard clogged won't run.	4/25/14	Courtyard		Plumbing
Hill, A.B. ES (2005) 1A	5 FT. OF WATER STANDING IN REAR OF BLDG OFF DOCK AREA-PLANT MGR BROWN KLR	4/28/14			Plumbing
Hill, A.B. ES (2005) 1A	faucet in the boys & girls toilet on the blue hall needs to be repaired	4/28/14	2nd Floor		Plumbing
Hill, A.B. ES (2005) 1A	Unstop storm drains	4/29/14			Plumbing
Hill, A.B. ES (2005) 1A	Provide and install a hose bibb type freeze proof faucet with handle.	5/2/14	Grounds		Plumbing
Hill, A.B. ES (2005) 1A	garbage disposal clogged up	5/12/14	Kitchen		Plumbing
Hill, A.B. ES (2005) 1A	2nd wall mount urinal in boys restroom runs over real bad when flushed	1/30/14	Restroom (Boys)		Plumbing

Hill, A.B. ES (2005) 1A	Need toilet seat installed in 1st flr. teachers lounge.	2/5/14	1st Floor		Plumbing
Hill, A.B. ES (2005) 1A	roof leak in music rm.	1/9/14	1st Floor	music rm.	Roof
Hill, A.B. ES (2005) 1A	water leaking around ceiling vent fan in rm.128 inside art rm.129	8/5/13	2nd Floor	rm.128	Roof
Hill, A.B. ES (2005) 1A	roof leak in classroom, ceiling tiles falling out	3/6/14	2nd Floor	S101	Roof
Hill, A.B. ES (2005) 1A	Roof leak in library near window on north side wall.	3/10/14	Library		Roof

Count of Craft	Craft										
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Airways Middle (2010) 1A		2	2	60	96	56	7	54	3	6	286
Grand Total		2	2	60	96	56	7	54	3	6	286

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Airways Middle (2010) 1A	Insulate pipes in ceiling, hole knock in plaster	7/17/13			Asbestos
Airways Middle (2010) 1A	Gym floor needs refinished.	10/3/13	Gym	West of cafe.	Asbestos
Airways Middle (2010) 1A	Please repair internet connection in classroom.	6/25/14	Classroom	2cd fl Rm G200B	Cabbling
Airways Middle (2010) 1A	Bad computer ground .	9/12/13	Classroom	Rm 103	Cabbling
Airways Middle (2010) 1A	Please install center pole @ door entrance. Missing top bracket.	8/29/13	Auditorium	East of gym	Carpentry
Airways Middle (2010) 1A	Door missing handle	9/4/13	Auditorium	South of cafe.	Carpentry
Airways Middle (2010) 1A	Please replace plexiglas in front entrance. Glass is scratched up and smudge up. With poor visibility.	9/12/13	1st Floor	Front entrance	Carpentry

Airways Middle (2010) 1A	Please replace bad cable on flag pole.	9/12/13	Grounds	South of school	Carpentry
Airways Middle (2010) 1A	Please install a white board to replace chalk board in classroom.	9/20/13	Classroom	2cd fl Rm219	Carpentry
Airways Middle (2010) 1A	Handle needs replace/ the door by the cafeteria area outside doors	9/26/13	1st Floor	outside doors	Carpentry
Airways Middle (2010) 1A	Please install door sweeps on side entrance door to prevent bug from entering room.	8/19/13	Administration Area	Southwest Regional Office	Carpentry
Airways Middle (2010) 1A	Door will not lock.	8/19/13	Stairway	Southwest,exit door	Carpentry
Airways Middle (2010) 1A	Door dragging on floor.	7/30/13	Classroom	Rm105	Carpentry
Airways Middle (2010) 1A	Please install white boards in classrooms.	8/2/13	Classroom	Rms 205&217	Carpentry
Airways Middle (2010) 1A	Loose handicap hand rail .	8/7/13	Grounds	North of school	Carpentry

Airways Middle (2010) 1A	Magnetic door missing magnet.	8/7/13	Hallway/Corridor	West hallway@stair well	Carpentry
Airways Middle (2010) 1A	Frame up hole in ceiling	7/17/13			Carpentry
Airways Middle (2010) 1A	Door magnet missing from door.	7/29/13	Hallway/Corridor	West of plant managers office	Carpentry
Airways Middle (2010) 1A	Broken stall door in girls locker.	10/31/13	Restroom (Girls)	1st Fl South of gym	Carpentry
Airways Middle (2010) 1A	Door will not lock.	11/13/13	Classroom	2cd Fl Rm207	Carpentry
Airways Middle (2010) 1A	Broken seat .	11/21/13	Auditorium	South of Cafe	Carpentry
Airways Middle (2010) 1A	Door shuter speed is off,door closes too fast and slams when closeing.	8/22/13	Library	2cd fl north	Carpentry
Airways Middle (2010) 1A	Doors in library close too fast, door speed need adjusting. Make a slamming noise when closing.	11/21/13	Library	2cd fl north hallway	Carpentry

Airways Middle (2010) 1A	Please repair lockers 328,339,213 missing combination dial.329,353 missing handle & 442 warp door.	4/29/14	Hallway/Corridor	2cd fl hallway	Carpentry
Airways Middle (2010) 1A	Lower white boards and remove all chark boards.	6/25/14	Classroom	1st fl Rms. 107,106,105,104,103,102,101	Carpentry
Airways Middle (2010) 1A	Lower white boards and remove chark boards	6/25/14	Classroom	1st fl. Rms.112,111, G201,G200A,	Carpentry
Airways Middle (2010) 1A	Window will not close all the way down.	6/27/14	Classroom	2cd FI G200A	Carpentry
Airways Middle (2010) 1A	Install two marker board G200	6/30/14			Carpentry
Airways Middle (2010) 1A	Lower marker board G200	6/30/14			Carpentry
Airways Middle (2010) 1A	SOUTHWEST EXIT DOOR has a BROKEN PANIC BAR per James Green, Plant Mgr. 416.8423	6/30/14			Carpentry
Airways Middle (2010) 1A	Tear down partitions in classroom.	5/21/14	Classroom	G200 2cd floor Rmg200a	Carpentry

Airways Middle (2010) 1A	Please install white board in classroom.	5/22/14	Classroom	2cd fl Rm 201	Carpentry
Airways Middle (2010) 1A	Please install white board in classroom.	5/22/14	Classroom	2cd fl Rm206	Carpentry
Airways Middle (2010) 1A	Please install white board in classroom.	5/22/14	Classroom	2cd fl Rm217	Carpentry
Airways Middle (2010) 1A	Please repair damaged ceiling grid.	5/30/14	Restroom (Girls)	1st floor east of gym	Carpentry
Airways Middle (2010) 1A	Please repair door lock @ restroom in office.	6/3/14	Administration Area	Front office	Carpentry
Airways Middle (2010) 1A	Please replace door lock @ asst. principal office.	6/3/14	Administration Area	Front office	Carpentry
Airways Middle (2010) 1A	Exit door will not close properly, broken release bar.	2/24/14	Hallway/Corridor	South exit door	Carpentry
Airways Middle (2010) 1A	Missing door stop.	2/25/14	Classroom	2cd Fl Rm205	Carpentry

Airways Middle (2010) 1A	Please repair loose door stop.	2/25/14	Classroom	2cd Fl Rm203	Carpentry
Airways Middle (2010) 1A	Loose hand rail in front of building.	4/15/14	Grounds	Northeast of bldg	Carpentry
Airways Middle (2010) 1A	Door is missing panic bar and door latch.	4/22/14	Hallway/Corridor	Southwest hallway	Carpentry
Airways Middle (2010) 1A	Please install basketball goals in gym. We have the goals	1/17/14	Gym	West of cafe	Carpentry
Airways Middle (2010) 1A	Broken door closure in girls restroom.	1/23/14	Restroom (Girls)	East hallway 2cd Fl.	Carpentry
Airways Middle (2010) 1A	Loose door handle @ front entrance.	1/24/14	Gym	West of cafe	Carpentry
Airways Middle (2010) 1A	Please fix loose door on cabinet in front office.	1/28/14	Administration Area	Office	Carpentry
Airways Middle (2010) 1A	Broken stall door in restroom.	1/29/14	Restroom (Boys)	South hallway	Carpentry

Airways Middle (2010) 1A	REAR ENTRANCE SECURITY DOOR- NOT LATCHING PER SBE-WON'T BE ABLE TO SECURE-PLANT MGR GREEN 416-5006 KLR	1/29/14			Carpentry
Airways Middle (2010) 1A	Broken stall door	1/29/14	Restroom (Boys)	hallway south	Carpentry
Airways Middle (2010) 1A	broken door in office.	1/29/14	Administration Area	Office	Carpentry
Airways Middle (2010) 1A	Please repair loose center mull located @ rear of gym on the right exit door.	2/27/14	Gym	West of cafe	Carpentry
Airways Middle (2010) 1A	Loose door closure,door will not close properly.	2/28/14	Hallway/Corridor	Exit door north	Carpentry
Airways Middle (2010) 1A	Please repair broken seat in row 16.	3/6/14	Auditorium	South of cafe	Carpentry
Airways Middle (2010) 1A	Please replace missing floor tile,front right side.	3/6/14	Auditorium	South of cafe.	Carpentry
Airways Middle (2010) 1A	Door dragging on floor.	3/6/14	Classroom	1st floor Rm110	Carpentry

Airways Middle (2010) 1A	Back section missing from seat.	3/7/14	Auditorium	South of cafe	Carpentry
Airways Middle (2010) 1A	Floor tile missing @ exit.	3/7/14	Stairway	Southwest exit	Carpentry
Airways Middle (2010) 1A	Repair center mull.	3/17/14	Hallway/Corridor	East entrance door	Carpentry
Airways Middle (2010) 1A	Replace door prop.	3/17/14	Classroom	Rm 109	Carpentry
Airways Middle (2010) 1A	Please install a board on cement wall in office.	1/15/14	Administration Area	PACE office	Carpentry
Airways Middle (2010) 1A	Please install basketball rims & nets on goals	10/3/13	Gym	West of cafe	Carpentry
Airways Middle (2010) 1A	Broken bench in boys dressing room.	11/21/13	Restroom (Boys)	South of Gym	Carpentry
Airways Middle (2010) 1A	Please install mounts in classroom for projector screen.	10/2/13	Classroom	2cd fl Rm211	Carpentry

Airways Middle (2010) 1A	Lower white boards and remove all chalk boards	6/25/14	Classroom	1st fl Rms. 112, 111, G201A, G200A	Carpentry
Airways Middle (2010) 1A	Check loop pump for proper operation. Not running per energy management.	8/26/13			Electrical
Airways Middle (2010) 1A	Electric outlet causes circuit to trip when used. Under emergency exit light.	8/28/13	Hallway/Corridor	East hallway south	Electrical
Airways Middle (2010) 1A	Outside light is out.	8/29/13	Grounds	North of cafe	Electrical
Airways Middle (2010) 1A	bad clock.	9/3/13	Hallway/Corridor	2cd fl outside library	Electrical
Airways Middle (2010) 1A	Emergency light bad.	9/3/13	Kitchen	serving line north	Electrical
Airways Middle (2010) 1A	Emergency exit bad.	9/3/13	Kitchen	kitchen south wall	Electrical
Airways Middle (2010) 1A	Emergency exit light bad.	9/3/13	Cafeteria	South exit door	Electrical

Airways Middle (2010) 1A	Emergency exit light bad.	9/3/13	Administration Area	Southwest Entrance	Electrical
Airways Middle (2010) 1A	Emergency exit light bad.	9/3/13	Gym	In front of gym.	Electrical
Airways Middle (2010) 1A	Replace bad lights in gym.	9/3/13	Gym	West of cafe.	Electrical
Airways Middle (2010) 1A	Please install bulbs and repair bad bulb sockets	9/6/13	Auditorium	South of cafe	Electrical
Airways Middle (2010) 1A	Sw. cover missing in stairway.	9/12/13	Stairway	South East hallway	Electrical
Airways Middle (2010) 1A	Bad clock.	9/12/13	Hallway/Corridor	South West hallway	Electrical
Airways Middle (2010) 1A	Sw. cover missing.	9/12/13	Concession Stand	South of Gym	Electrical
Airways Middle (2010) 1A	Clock bad.	9/12/13	Hallway/Corridor	South East hallway 1st floor	Electrical

Airways Middle (2010) 1A	Bad clock.	9/12/13	Hallway/Corridor	North East hallway 2cd fl	Electrical
Airways Middle (2010) 1A	7th grade hallway light grill needs replace	9/26/13	1st Floor	Green Hallway	Electrical
Airways Middle (2010) 1A	Electrica outlet bad @ Dryer. Electric outlet cover missing on the south wall.	8/19/13	Gym	Football locker Rm	Electrical
Airways Middle (2010) 1A	Bad Light sw. Lights will not come on .	8/19/13	Classroom	Rm Gym201	Electrical
Airways Middle (2010) 1A	Clock will not keep proper time.	8/14/13	Hallway/Corridor	Across from R106	Electrical
Airways Middle (2010) 1A	NO POWER TO LIGHTS MAIN LOBBY. SBE-CAMPBELL/416- 5006	7/15/13			Electrical
Airways Middle (2010) 1A	POWER OUTAGE THRU ENTIRE BLDG. SBE-GREEN/314-8386	7/23/13			Electrical
Airways Middle (2010) 1A	Please send 50 T8 ultramax ECO XL light bulbs	7/25/13	1st Floor	North&South hallways	Electrical

Airways Middle (2010) 1A	Please set school bells.	7/29/13	Administration Area	office	Electrical
Airways Middle (2010) 1A	Please set master clock .1123-127.	7/29/13	Administration Area	office	Electrical
Airways Middle (2010) 1A	Emergency exit light bad	7/29/13	1st Floor	East of plant managers off	Electrical
Airways Middle (2010) 1A	Emergency exit light bad, across from library.	7/29/13	Hallway/Corridor	2cd floor	Electrical
Airways Middle (2010) 1A	Emergency exit light bad	7/29/13	Hallway/Corridor	East soyth of PACE office	Electrical
Airways Middle (2010) 1A	Emergency exit light bad.	7/29/13	Administration Area	PACE office	Electrical
Airways Middle (2010) 1A	Emergency exit light bad.	7/29/13	Cafeteria	South of cafe	Electrical
Airways Middle (2010) 1A	Emergency exit light bad.	7/29/13	Kitchen	North of kitchen	Electrical

Airways Middle (2010) 1A	Emergency exit light bad.	7/29/13	2nd Floor	G200 office	Electrical
Airways Middle (2010) 1A	Emergency exit light badeast hallway & west hallway	7/29/13	Hallway/Corridor	G200 hallway east	Electrical
Airways Middle (2010) 1A	Bad emergency light.	10/3/13	Administration Area	Southeast Office	Electrical
Airways Middle (2010) 1A	Emergency exit light bad.	10/3/13	Administration Area	Southeast Office	Electrical
Airways Middle (2010) 1A	Emergency lights bad @ hot water tank & @ stairways.	10/3/13	Mechanical Room	North of cafe boiler rm	Electrical
Airways Middle (2010) 1A	Bad ballasts.	10/16/13	Hallway/Corridor	1st fl east hallway	Electrical
Airways Middle (2010) 1A	Magnet will not hold doors.	10/16/13	Stairway	G200 1&2 Floor	Electrical
Airways Middle (2010) 1A	Bad ballast 2 ea. Could be bad wire connection.Lights came on but went back out.	10/17/13	Administration Area	1st fl hallway	Electrical

Airways Middle (2010) 1A	Please order 50 Phillips 13W 27 PL-S bulbs.	10/21/13	Kitchen	East of Gym	Electrical
Airways Middle (2010) 1A	Please repair bad switch that turns on the score board in gym.	10/22/13	Gym	West of cafe	Electrical
Airways Middle (2010) 1A	Please replace bad bulbs in gym.	10/24/13	Gym	gym west of cafe	Electrical
Airways Middle (2010) 1A	Bad in house light switch,will not cut lights on	10/29/13	Auditorium	South of Cafe.	Electrical
Airways Middle (2010) 1A	Bad emergency exit lights in gym,2ea. northwest of gym.	10/31/13	Gym	West of cafe.	Electrical
Airways Middle (2010) 1A	Set clocks for day lite saving time.	11/4/13	Administration Area	1st fl office	Electrical
Airways Middle (2010) 1A	Bad ballast in MDF closet.	11/7/13	Data Closet	2cd FI MDF Room	Electrical
Airways Middle (2010) 1A	5 ea bad ballast.	11/7/13	Cafeteria	1st Fl cafe	Electrical

Airways Middle (2010) 1A	Please send 12 round light covers for lights in girls locker room.	11/14/13	Restroom (Girls)	South of gym	Electrical
Airways Middle (2010) 1A	Replace bad bulbs in kitchen.	11/14/13	Kitchen	East of gym	Electrical
Airways Middle (2010) 1A	Change bad bulbs	11/14/13	Auditorium	South of cafe.	Electrical
Airways Middle (2010) 1A	Please send 50ea. 90par38qfl33 130v flood bulbs for replacement in the auditorium.	11/14/13	Auditorium	South of cafe.	Electrical
Airways Middle (2010) 1A	Some of the magnetic doors did not close during fire drill.	8/22/13	Hallway/Corridor	1st and 2cd fls	Electrical
Airways Middle (2010) 1A	Bad ballast	8/22/13	Hallway/Corridor	office	Electrical
Airways Middle (2010) 1A	Bad ballast.	8/22/13	Hallway/Corridor	East hallway	Electrical
Airways Middle (2010) 1A	Emergeny lights bad.	10/3/13	Kitchen	north&south in kitchen	Electrical

Airways Middle (2010) 1A	Emergency exit light bad @ rear door.	10/3/13	Kitchen	Rear door	Electrical
Airways Middle (2010) 1A	Emergency exit light bad @serving line north.	10/3/13	Cafeteria	serving line	Electrical
Airways Middle (2010) 1A	Goal will not let down.	10/3/13	Gym	West of cafe	Electrical
Airways Middle (2010) 1A	bad Ballasts in classrooms.	11/22/13	Classroom	2cd FI Rm209/210	Electrical
Airways Middle (2010) 1A	Emergency light bad.	12/3/13	Hallway/Corridor	2cd fl G200	Electrical
Airways Middle (2010) 1A	Emergency exit light bad @ stairways exit.	12/3/13	Hallway/Corridor	Stairways West hallway	Electrical
Airways Middle (2010) 1A	Please replace bad light switches in gym.	12/9/13	Gym	West of cafe.	Electrical
Airways Middle (2010) 1A	All fire doors did not close during fire drill.	12/20/13	Administration Area	1st&2cd floors	Electrical

Airways Middle (2010) 1A	3 emergency lights bad when check	1/7/14	Hallway/Corridor	G200 2cd floor	Electrical
Airways Middle (2010) 1A	No power @ outlet on west wall.	1/9/14	Administration Area	southwest hallway PACE	Electrical
Airways Middle (2010) 1A	Please replace bulbs on stage.	1/13/14	Auditorium	South of cafe.	Electrical
Airways Middle (2010) 1A	Bad ballast in trophy case.	12/11/13	Hallway/Corridor	hallway north of cafe	Electrical
Airways Middle (2010) 1A	No lights in pantry. Electric outlet cover missing in pantry.	12/12/13	Kitchen	East of cafe.	Electrical
Airways Middle (2010) 1A	2 boxes 4 foot classroom bulbs	4/24/14			Electrical
Airways Middle (2010) 1A	Please repair bad ballasts in classroom	6/27/14	Classroom	1st Fl Rm107	Electrical
Airways Middle (2010) 1A	Bad ballast in stairway @ G200 staiway west.	5/15/14	1st Floor	G200 stairway west	Electrical

Airways Middle (2010) 1A	Repair stage lights	6/5/14				Electrical
Airways Middle (2010) 1A	per mr green 416-8423 rooms 106 unit is not coming on	2/12/14				Electrical
Airways Middle (2010) 1A	Check fire alarm	2/20/14				Electrical
Airways Middle (2010) 1A	Please set clocks for day light saving time.	2/24/14	Administration Area	Office		Electrical
Airways Middle (2010) 1A	Bad electrical outlet@ vending machines across from PACE office.	3/28/14	Hallway/Corridor	East hallway south		Electrical
Airways Middle (2010) 1A	Bad ballasts.	4/14/14	Hallway/Corridor	north hallway		Electrical
Airways Middle (2010) 1A	Broken door magnet will not hold door.	4/22/14	Hallway/Corridor	G200 1st floor		Electrical
Airways Middle (2010) 1A	FIRE ALARM SYSTEM IN TROUBLE - CAN'T OPEN DRS - PM/GREENE 416-8423	4/23/14				Electrical

Airways Middle (2010) 1A	per Mr. Green 416-8423 the bells are constantly ringing in the G200 section of the building	1/22/14			Electrical
Airways Middle (2010) 1A	Unit NOT COMING ON in ROOM 206 per James Green, Plant Mgr. 416.8423	1/30/14			Electrical
Airways Middle (2010) 1A	Outside light is out @ side entrance.	2/5/14	Grounds	North of cafe	Electrical
Airways Middle (2010) 1A	Outside light is out.	2/5/14	Grounds	Northwest corner of bldg.	Electrical
Airways Middle (2010) 1A	Outlet cover missing, located @ rear of gym on the west wall.	2/27/14	Gym	West of cafe	Electrical
Airways Middle (2010) 1A	Clock will not keep properly time.	2/27/14	Gym	West of cafe west wall	Electrical
Airways Middle (2010) 1A	Emergency light will not come on when test. On the east wall left side.	3/6/14	Gym	West of cafe.	Electrical
Airways Middle (2010) 1A	Emergency Exit light is out when tested.	3/6/14	Kitchen	Southeast wall	Electrical

Airways Middle (2010) 1A	Emergency exit light out when tested.	3/6/14	Stairway	1st fl Westsouth exit door	Electrical
Airways Middle (2010) 1A	Clock will not keep time.	3/19/14	Hallway/Corridor	East of office	Electrical
Airways Middle (2010) 1A	Clock will not keep proper time. West wall	3/19/14	Auditorium	East of gym	Electrical
Airways Middle (2010) 1A	Please check score board, unit will no turn on.	4/23/14	Gym	West of cafe	Electrical
Airways Middle (2010) 1A	Please send 50ea T8 ultra max Eco light bulbs.	2/26/14	Grounds	hallways&classrooms	Electrical
Airways Middle (2010) 1A	Please replace all rusty light fixtures in classroom.	6/25/14	Classroom	1st fl Rms. 107,106,105,104,103,102,101	Electrical
Airways Middle (2010) 1A	Please replace all rusty light fixtures in classroom.	6/25/14	Classroom	1st fl Rms.112,111,G201A,G200A	Electrical
Airways Middle (2010) 1A	I need 40ea bulbs p/n 90par38qfl/33 130v. 20ea 60watts bulbs and 20ea 60watts bulbs	8/21/13	Auditorium	south of cafe.	Electrical

Airways Middle (2010) 1A	Scoreboard went out during the game.	12/12/13	Gym	West of Cafe	Electrical
Airways Middle (2010) 1A	Monthly - Filter-Airways Middle - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	6/6/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Provide and install controller for chemical feed.	8/20/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	CHECK CHILLER WILL NOT TRANSITION	8/26/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Monthly - Filter-Airways Middle - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Yearly - Oil samples- Airways Middle - Refer to PM schedule details.	9/1/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	FCU RM G200A-NOT COOLING-PLANT MGR GREEN 416-5006 KLR	9/6/13			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	clean coils in class rooms	9/12/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	chiller down	9/23/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	chiller down	7/31/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	room 213 no heat per Mr. Green 416-8423	10/24/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	BOILER NOT COMING ON-PLANT MGR GREEN 416-5006 KLR	10/29/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Yearly - Air Handler Cleanings-Airways Middle - Refer to PM schedule details.	11/1/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	UNIT NOT HEATING IN RM-111. PLANT MGR-GREEN/416.5006	11/13/13			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	UNIT NOT HEATING IN AUDIT, GYM, CAFE & SOUTH-EAST OFFICE PLANT MGR- GREEN/416.5006	11/15/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	boiler down	11/18/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	room 216 blowing cold air per mr. green 416- 8423	11/25/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	AHU #6 and #7 in alarm per Mr. Green 416-8423	12/2/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	please check action and operation of boiler Mixing Valve. Please correspond with EMS 416-1664	12/10/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	UNIT NOT HEATING IN RM-216 PLANT MGR- GREEN/416.5006	12/11/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	check flue on boilers --- (get with James Hammett)	12/17/13			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Monthly - Filter-Airways Middle - Refer to PM schedule details.	1/3/14			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	Monthly - Oil Lube & Belt-Airways Middle - Refer to PM schedule details.	1/4/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Yearly - Water-Cool Chiller Filter-Airways Middle - Refer to PM schedule details.	1/10/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Boilers --- slow down exhaust fan	1/13/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Monthly - Airways Middle Lvl 2 Water Treatment - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Check A/C in area office. units are not cooling	5/21/14			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Chiller is NOT COMING ON per James Green, Plant Mgr. 416.8423	5/27/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	chiller down	5/28/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Purchase fan assembly for cooling tower	5/29/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Monthly - Airways Middle Lvl 2 Water Treatment - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	supply 3 speed fans	5/30/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	install fan on cooling tower	6/4/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	UNIT NOT HEATING IN RM-206. PLANT MGR- GREEN/416-5016	2/18/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Monthly - Airways Middle Lvl 2 Water Treatment - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	CHILLER MECH RM- IN ALARM-PLANT MGR GREEN 416- 8423 KLR	4/17/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	check boiler	1/17/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	Monthly - Airways Middle Lvl 2 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Strong carbon dioxide smell when you enter the boiler room.	2/27/14	Mechanical Room	North of cafe in boiler room	Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Monthly - Airways Middle Lvl 2 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Yearly - Cooling Towers Airways Middle - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Yearly - Rod Chiller - Airways Middle - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Daily - Airways Middle Level 1 Water Treatment - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning

Airways Middle (2010) 1A	CHANGE FROM HEAT TO AIR	3/21/14				Heating/Ventilation /Air Conditioning
Airways Middle (2010) 1A	Plaster falling from ceiling in boys restroom.	7/30/13	Restroom (Boys)	2cd floor		Painting
Airways Middle (2010) 1A	Big hole in ceiling.	8/9/13	Restroom (Boys)	1st floor		Painting
Airways Middle (2010) 1A	Plaster peeling off wall in stairways east &west of Rm108.	8/13/13	Stairway	Southeast stairway		Painting
Airways Middle (2010) 1A	Paint peeling off wall.	8/15/13	Hallway/Corridor	Outside Rm112		Painting
Airways Middle (2010) 1A	Paint peeling off walls.	2/12/14	Stairway	Southeast&Southwest		Painting
Airways Middle (2010) 1A	GRAFFITI B RR 2ND FLR NW HALL ON WOODEN DOOR & STALLS-PLANT MGR GREEN 416-8423 KLR	1/15/14				Painting
Airways Middle (2010) 1A	GRAFFITI IN B/RR 2ND FLR PLANT MGR- GREEN/416.5006	1/16/14				Painting

Airways Middle (2010) 1A	CEILING UNIT IS LEAKING IN RM-211 PLANT MGR- GREEN/416.5006	8/27/13			Plumbing
Airways Middle (2010) 1A	UNIT VENT -123-067 - RM 217 - LEAKING - PM/GREEN 416-8423	8/30/13			Plumbing
Airways Middle (2010) 1A	UNIT IS LEAKING WATER IN RM-216. PLANT MGR- GREEN/416.5006	8/30/13			Plumbing
Airways Middle (2010) 1A	A/C RM 207-LEAKING- PLANT MGR GREEN 416-5006 KLR	9/3/13			Plumbing
Airways Middle (2010) 1A	A/C RM 208 & HALL OUTSIDE GYM-BOTH LEAKING PER SBE- PLANT MGR GREEN 416-5006 KLR	9/11/13			Plumbing
Airways Middle (2010) 1A	A/C RM 221 & 103- BOTH LEAKING PER SBE-PLANT MGR 416- 5006 KLR	9/11/13			Plumbing
Airways Middle (2010) 1A	Unit ventilator in RM 207 is LEAKING and Unit is LEAKING from the CEILING in from of the GYM per James Green, Plant Mgr. 416.8423.	9/12/13			Plumbing
Airways Middle (2010) 1A	Water will not drain from sink.	9/12/13	Restroom (Girls)	Girls locker room north of gym	Plumbing

Airways Middle (2010) 1A	UV IS LEAKING WATER IN FRONT CONCESSION STAND PLANT MGR- GREEN/416.5006	9/17/13			Plumbing
Airways Middle (2010) 1A	Broken toilet seat in restroom.	9/26/13	Classroom	2cd Fl rm211	Plumbing
Airways Middle (2010) 1A	Wall mounted toilet leaking from the back.	9/30/13	Classroom	2cd fl Rm211	Plumbing
Airways Middle (2010) 1A	Hand sink cracked.	9/30/13	Classroom	2cd fl Rm211	Plumbing
Airways Middle (2010) 1A	No hot water @ sinks #2&3. Sink #4 leaking.	8/15/13	Restroom (Girls)	West hallway	Plumbing
Airways Middle (2010) 1A	A/C IN MECH RM- LEAKING-SBE GREEN 416-5016 KLR	8/19/13			Plumbing
Airways Middle (2010) 1A	Water leaking from ceiling.	8/19/13	Restroom (Boys)	2cd floor north hallway	Plumbing
Airways Middle (2010) 1A	FCU-1 2ND FLR RM 207-LEAKING-SBE GREEN 416-5006 KLR	8/12/13			Plumbing

Airways Middle (2010) 1A	No water@ water coolers. 123-152 &123-153.	8/13/13	Hallway/Corridor	Southwest & Southeast of gym	Plumbing
Airways Middle (2010) 1A	FCU-4 1ST FLR CLINIC (RM 16) & FCU-1 2ND FLR RM 216 (ASST PRIN'S OFC)- BOTH LEAKING-SBE GREEN 416-5006 KLR	8/6/13			Plumbing
Airways Middle (2010) 1A	FCU IS LEAKING WATER IN RM-215 (085). PLANT MGR- GREEN/416.5006	7/26/13	Classroom		Plumbing
Airways Middle (2010) 1A	Water leaking from drain pan. Equip.#123-084.	7/30/13	Classroom	Rm 215	Plumbing
Airways Middle (2010) 1A	A/C RM 216-LEAKING- PLANT MGR GREEN 416-5006 KLR	10/3/13			Plumbing
Airways Middle (2010) 1A	Water leaking from sink in boys restroom.	10/3/13	Restroom (Boys)	2cd fl West hallway	Plumbing
Airways Middle (2010) 1A	water is leaking from ceiling from unit in room 207 per Mr. Green 416-8423	10/3/13			Plumbing
Airways Middle (2010) 1A	valves leaking out of handle.	10/3/13	Classroom	rm208	Plumbing

Airways Middle (2010) 1A	Unit Ventilator in the CAFETERIA is LEAKING from the ceiling per James Green, Plant Mgr. 416.8423	10/4/13			Plumbing
Airways Middle (2010) 1A	Broken toilet handle.	10/4/13	Restroom (Boys)	1st Fl east hallway	Plumbing
Airways Middle (2010) 1A	Repair A/C drains	10/10/13			Plumbing
Airways Middle (2010) 1A	UV RM 208-LEAKING PER SBE-PLANT MGR GREEN 416-5016 KLR	10/14/13			Plumbing
Airways Middle (2010) 1A	Urinal will not stop running in visitors boys locker room.	10/18/13	Restroom (Boys)	South of gym	Plumbing
Airways Middle (2010) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	10/31/13			Plumbing
Airways Middle (2010) 1A	Faucet leaking @ sink in girls locker room.	10/31/13	Restroom (Girls)	1st Fl South of gym	Plumbing
Airways Middle (2010) 1A	Urinal will not stop running in locker room.	10/31/13	Restroom (Boys)	1st Fl south of gym	Plumbing

Airways Middle (2010) 1A	Water leaking from the bottom of sink.	11/7/13	Restroom (Girls)	1st fl west hallway	Plumbing
Airways Middle (2010) 1A	CEILING UNIT IS LEAKING WATER IN RM-101 PLANT MGR-GREEN/416.5016	8/22/13			Plumbing
Airways Middle (2010) 1A	floor drain in kitchen is stopped up per Mr. Green 416-8423	10/2/13			Plumbing
Airways Middle (2010) 1A	Flush valve leaking @ toilet.Stall # 1.	12/11/13	Restroom (Boys)	1st Fl south of gym	Plumbing
Airways Middle (2010) 1A	Sink leaking from the bottom. Sink #2.	12/11/13	Restroom (Girls)	1st Fl Southwest hallway	Plumbing
Airways Middle (2010) 1A	Test and report on backflow prevention devices.	12/19/13			Plumbing
Airways Middle (2010) 1A	Water leaking from ventilator .	1/7/14	Classroom	2cd floor Rm216	Plumbing
Airways Middle (2010) 1A	Broken faucet @ sink.	1/10/14	Restroom (Girls)	Visiting girls locker room	Plumbing

Airways Middle (2010) 1A	Water will not stop running @ urinal.	4/29/14	Restroom (Boys)	1st fl East hallway	Plumbing
Airways Middle (2010) 1A	FLR DRAIN IS STOPPED UP IN KITCHEN & 2-COM SINK STOPPED UP PLANT MGR-GREEN/416.5006	4/30/14			Plumbing
Airways Middle (2010) 1A	Water leaking from drinking faucet.	5/1/14	Hallway/Corridor	2cd Fl southwest	Plumbing
Airways Middle (2010) 1A	Test and report on backflow prevention devices.	6/17/14			Plumbing
Airways Middle (2010) 1A	A/C UNITS is LEAKING in the ROOM 210 & 215 per Mr. Green, Plant Mgr. 416.8423	6/23/14			Plumbing
Airways Middle (2010) 1A	Loose toilet seat in restroom	5/19/14	Restroom (Girls)	1st floor	Plumbing
Airways Middle (2010) 1A	Loose toilet seat in restroom.	5/19/14	Restroom (Boys)	1st floor	Plumbing
Airways Middle (2010) 1A	floor drain backed up in kitchen per mr green 416-8423	2/18/14			Plumbing

Airways Middle (2010) 1A	Test and report on backflow prevention devices.	1/21/14			Plumbing
Airways Middle (2010) 1A	Toilet leaking when flushed.	1/24/14	Restroom (Girls)	1st floor west hallway	Plumbing
Airways Middle (2010) 1A	SINK IS SHOOTING OUT WATER IN KITCHEN PLANT MGR- GREEN/416.5016	2/7/14			Plumbing
Airways Middle (2010) 1A	Stall #2 toilet leaks when flushed.	2/12/14	Restroom (Girls)	1st fl. west hallway	Plumbing
Airways Middle (2010) 1A	HEATING UNIT RM 206-FAUCET LEAKING PER SBE- PLANT MGR GREEN KLR	3/6/14			Plumbing
Airways Middle (2010) 1A	Fitting on washing machine leaking @ hot water connection.	12/11/13	Restroom (Boys)	South of gym in basement	Plumbing
Airways Middle (2010) 1A	Water leaking from ceiling.	8/27/13	Classroom	Rm 211	Roof
Airways Middle (2010) 1A	Water leaking from ceiling in classroom.	6/23/14	Classroom	2cd fl Rm212	Roof

Airways Middle (2010) 1A	Water leaking from ceiling in Rm 221.	5/21/14	Classroom	2cd Fl Rm221	Roof
Airways Middle (2010) 1A	Replace a/c pan	8/15/13		Room 216	Sheet Metal
Airways Middle (2010) 1A	rm 202 --- R/A grill door gone	12/9/13			Sheet Metal
Airways Middle (2010) 1A	Please repair lockers on the 1st&2cd. floors.	12/9/13	Hallway/Corridor	1st&2cd floors	Sheet Metal
Airways Middle (2010) 1A	check flue on boilers --- (get with Steve French)	12/17/13			Sheet Metal
Airways Middle (2010) 1A	Please repair large hole in ceiling	1/7/14	Restroom (Boys)	1st Floor south hallway	Sheet Metal
Airways Middle (2010) 1A	Please remove combination locks from lockers in hallway. Note: lockers are to be used for kindergarten.	6/27/14	Hallway/Corridor	1st Fl west hallway	Sheet Metal

Count of Craft	Craft							
Location	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Alcy EI (2015) 1A	20	59	23	1	26	1	2	132
Grand Total	20	59	23	1	26	1	2	132

Location	Request Description	Submittal Date	Area Number	Craft
Alcy EI (2015) 1A	per ms campbell 416-7800 3rd floor exterior door on south side can't secure latch broken	2/5/14		Carpentry
Alcy EI (2015) 1A	Repair wall in restroom	3/20/14		Carpentry
Alcy EI (2015) 1A	Install bullentin board	8/29/13		Carpentry
Alcy EI (2015) 1A	locker in classroom has came on of the frame	2/21/14	306	Carpentry
Alcy EI (2015) 1A	smoke detector is beeping	6/26/14	104	Carpentry
Alcy EI (2015) 1A	tile is coming up at the front of the door as you come in the main entrance.	3/19/14		Carpentry
Alcy EI (2015) 1A	door on southend hallway leading to the thrid and first floor isn't closing propertly	3/31/14	2nd floor	Carpentry

Alcy EI (2015) 1A	door closerer needs replacing	12/11/13	teacher lounge	Carpentry
Alcy EI (2015) 1A	need lift to place ceiling tile back into ceiling . got the ceiling tile	11/6/13	ceiling	Carpentry
Alcy EI (2015) 1A	door closer not working door is hard to close	9/13/13	northside door	Carpentry
Alcy EI (2015) 1A	broken tile need replacing in of water fountain and in front middle door leaving to serving line	3/21/14		Carpentry
Alcy EI (2015) 1A	Closure not working on double doors (west side)	1/8/14	Main hall	Carpentry
Alcy EI (2015) 1A	floor tile has came up in front of air unit	8/1/13	101	Carpentry
Alcy EI (2015) 1A	clyinder in door is stripped.	1/29/14	306	Carpentry
Alcy EI (2015) 1A	Stall door need to be put back on. (see engr for door location)	1/9/14		Carpentry

Alcy EI (2015) 1A	DOOR WONT CLOSE IN GUIDANCE OFFICE 2ND FLR (HAVE T-CAPS IN THIS AREA) PLANT MGR- CAMPBELL/416.7804	4/24/14		Carpentry
Alcy EI (2015) 1A	1 cafeteria table is missing the screw that connects the bar to the leg on the bench	4/8/14	southend	Carpentry
Alcy EI (2015) 1A	1 cafeteria table is missing the screw that connects the bar to the leg on the bench	4/8/14	southend	Carpentry
Alcy EI (2015) 1A	in the lady's restroom the doors are to short they needs to be taller so no one can look over into the stalls	3/19/14	teacher lounge	Carpentry
Alcy EI (2015) 1A	there are 8 tables missing the screws that connects the bar to the leg on the folding bench	4/8/14		Carpentry
Alcy EI (2015) 1A	Monthly - Alcy Air Compressors - Refer to PM schedule details.	2/28/14		Electrical
Alcy EI (2015) 1A	Check wall packs	4/9/14		Electrical
Alcy EI (2015) 1A	Check pump for power	2/11/14		Electrical

Alcy EI (2015) 1A	UV NOT COMING ON IN MAIN OFFICE. SUPV DANIEL HURDLE	8/5/13		Electrical
Alcy EI (2015) 1A	per Ms. Campbell 416-7800 room 109 UV not coming on at all	1/24/14		Electrical
Alcy EI (2015) 1A	per ms campbell 416-7800 room 232 the outlets are not working	4/28/14		Electrical
Alcy EI (2015) 1A	per ms campbell 416-7800 room 306 and the cafeteria a/c not blowing	5/14/14		Electrical
Alcy EI (2015) 1A	per ms campbell 416-7800 power outage entire school	3/27/14		Electrical
Alcy EI (2015) 1A	LIGHT COVER is HANGING from the LIGHT FIXTURE in the CAFETERIA per Mr. Campbell, Plant Mgr. 416.7800	2/10/14		Electrical
Alcy EI (2015) 1A	1/2 of the LIGHTS are OUT in the MAIN OFFICE per Ms. Campbell, Plant Mgr. 416.7800	12/9/13		Electrical
Alcy EI (2015) 1A	HEAT RM 109-NOT HEATING-PLANT MGR PATTERSON 416-7800 KLR	1/7/14		Electrical

Alcy EI (2015) 1A	UNIT VENT RM 238 - BLOWING NOT COOLING - PM/CAMPBELL 416- 7800	5/13/14		Electrical
Alcy EI (2015) 1A	per Ms. Campbell 416- 7800 on 1st floor in kindergarten hall there is an exit light hanging with wires exposed	12/4/13		Electrical
Alcy EI (2015) 1A	Reset chiller	4/29/14		Electrical
Alcy EI (2015) 1A	Check A/C room 306	5/1/14		Electrical
Alcy EI (2015) 1A	Need 10 60 watt bulbs	5/1/14		Electrical
Alcy EI (2015) 1A	Check A/C thur-out	6/9/14		Electrical
Alcy EI (2015) 1A	Check bearing in A/C in 105	6/9/14		Electrical
Alcy EI (2015) 1A	PUMP MECH RM- SMOKING-DON'T KNOW WHICH ONE- PLANT MGR CAMPBELL 416-7800 KLR	4/15/14		Electrical

Alcy EI (2015) 1A	ballast gone bad in light fixture in the office in library	4/11/14		Electrical
Alcy EI (2015) 1A	ballasts gone bad in light fixture aslo need and cover for wall socket by ac unit.	6/26/14	237	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	11/12/13	230	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	11/12/13	235	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	11/12/13	237	Electrical
Alcy EI (2015) 1A	ballast gone bad	10/24/13	231	Electrical
Alcy EI (2015) 1A	outlets in classroom don't work . check break box still won't come on	10/21/13	231	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture wo#377224 state complete on 9-9-13 was't complete still out	10/2/13	233	Electrical

Alcy EI (2015) 1A	smoke alarm is beeping.	9/9/13	101	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	8/22/13	233	Electrical
Alcy EI (2015) 1A	there's an shortage in the light switch .so the lights in the froyer will not. stay on	8/1/13	southside wall	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	8/22/13	back hall of 2nd flr	Electrical
Alcy EI (2015) 1A	shortage in light switch for froyer w0#369829 stated complete on 9-16-13 wasn't complete still shortage	10/2/13	southside	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture in front of main office .	3/31/14	2nd floor	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture on the southend leading to the exit door	3/31/14	2nd floor	Electrical
Alcy EI (2015) 1A	need bell set to 8:00am ,2:50pm and 3:00pm when the clocks changes to daylight saving time	3/7/14		Electrical

Alcy El (2015) 1A	need clock set for daylight saving time	2/21/14		Electrical
Alcy El (2015) 1A	ballast gone bad in light wo# 377470 stated complete on 9-9-13 wasn't still out	10/2/13	main office	Electrical
Alcy El (2015) 1A	ballast gone bad in light fixture	8/22/13	front of main office	Electrical
Alcy El (2015) 1A	need bell to be set for 8:00am,2:50pm and 3:00. bell #is 115099	8/15/13	main office	Electrical
Alcy El (2015) 1A	need clock set for daylight saving time	10/22/13	main office	Electrical
Alcy El (2015) 1A	need 2 cases of 4ft t8 bulbs	11/7/13		Electrical
Alcy El (2015) 1A	ballast gone bad in light fixture	4/30/14		Electrical
Alcy El (2015) 1A	Electrical strip for computers not working	1/17/14	Room # 109	Electrical

Alcy EI (2015) 1A	Bad ballast	1/17/14	East corridor & stairwell	Electrical
Alcy EI (2015) 1A	Bad ballast in hallway	1/8/14	By engr office	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	9/13/13	side by pre-k	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture	8/22/13	teacher lounge	Electrical
Alcy EI (2015) 1A	Perimeter lights will not come on	1/17/14	Main lobby	Electrical
Alcy EI (2015) 1A	need 1 case of f26d8x/835/eco4p	12/4/13	men lounge	Electrical
Alcy EI (2015) 1A	Fire exit sign broken, need to be put back on wall	1/9/14	By computer lab	Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture by the southside of the hallway by library entrance	4/30/14	by library	Electrical

Alcy EI (2015) 1A	ballast gone bad in light fixture	5/5/14	hallway	Electrical
Alcy EI (2015) 1A	BREAKER #14-KEEPS TRIPPING KNOCKING POWER OUT TO RECEPTACLES IN COMPUTER RM 308-SBE CAMPBELL 416-7800 KLR	8/5/13		Electrical
Alcy EI (2015) 1A	RECEPTACLE IS SMOKING IN CAFE. PLANT MGR/CAMPBELL-335.2159	12/16/13		Electrical
Alcy EI (2015) 1A	need bucket trunk several lights are blown	7/30/13	exterior of bldg	Electrical
Alcy EI (2015) 1A	light bulbs need changing.need help need an ladder over 8ft	8/22/13		Electrical
Alcy EI (2015) 1A	ballast gone bad in light fixture in the principal office	12/5/13	principal office	Electrical
Alcy EI (2015) 1A	need 2 cases of f32t8 bulbs	10/29/13		Electrical
Alcy EI (2015) 1A	need (2) cases of fir rap star 30 32 watt box	8/19/13	plant manager	Electrical

Alcy EI (2015) 1A	Monthly - Filter-Alcy Elementary - Refer to PM schedule details.	5/5/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Monthly - Filter-Alcy Elementary - Refer to PM schedule details.	1/6/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Monthly - Filter-Alcy Elementary - Refer to PM schedule details.	9/9/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Monthly - Alcy Air Compressors - Refer to PM schedule details.	8/30/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Monthly - Alcy Air Compressors - Refer to PM schedule details.	11/29/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Monthly - Alcy Air Compressors - Refer to PM schedule details.	5/30/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Yearly - Air Handler Cleanings-Alcy Elementary - Refer to PM schedule details.	11/8/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Two Unit Ventilators are leaking water in Rooms 103 and 105 per Ms. Campbell, Plant Mgr. @ 901.335.2159.	7/19/13		Heating/Ventilation /Air Conditioning

Alcy EI (2015) 1A	Room 109 unit ventilator is making rattling noise per Ms. Campbell 416-7800	8/21/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	2-UV NOT COOLING IN RM-306,235. PLANT MGR-CAMPBELL/416.7804	7/29/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	librarian office --- oil bearings	5/28/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	check boiler	12/5/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	boiler down	11/12/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	clean chiller coil	4/29/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	C/O to A/C	3/21/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	chiller down	9/23/13		Heating/Ventilation /Air Conditioning

Alcy EI (2015) 1A	c/o to heat	10/17/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	chiller down	7/8/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Monthly - Oil Lube & Belt-Alcy Elementary - Refer to PM schedule details.	1/10/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	UNIT IN THE MAIN OFFICE IS NOT COOLING. SBE CAMPBELL 416-7804	8/2/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	UNIT NOT COOLING IN MAIN OFFICE. PLANT MGR- CAMPBELL/416.7800	8/20/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	UV RM 235-MAKING NOISES-PLANT MGR CAMPBELL 416-7800 KLR	9/13/13		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	CHANGE FROM HEAT TO AIR	3/21/14		Heating/Ventilation /Air Conditioning
Alcy EI (2015) 1A	Clear coat doors	3/28/14		Painting

Alcy Ei (2015) 1A	UV RM 338-LEAKING AND IT'S GOING DOWN INTO RM 238 BELOW-PLANT MGR CAMPBELL 416-7800 KLR	6/24/14		Plumbing
Alcy Ei (2015) 1A	1st toliet when flushing water comes from the pipe connected to the toliet	10/28/13	3rd floor	Plumbing
Alcy Ei (2015) 1A	per ms campbell 416-7800 in the teacher's lounge the toilet bolts are gone and it rocks	1/30/14		Plumbing
Alcy Ei (2015) 1A	WATER HEATER KITCHEN AREA-NOT HEATING WATER-NO HOT WATER TO KITCHEN-PLANT MGR PATTERSON 416-7800 KLR	1/8/14		Plumbing
Alcy Ei (2015) 1A	UV-2 3RD FLR RM 301 LEAKING-SBE CAMPBELL 416-7800 KLR	8/9/13		Plumbing
Alcy Ei (2015) 1A	FLOOR DRAIN STOPPED IN BOILER RM-SBE CAMPBELL 416-7800 KLR	8/12/13		Plumbing
Alcy Ei (2015) 1A	HAND SINK 3RD FLR- PIPE HAS COME LOOSE AND LEAKING-SBE CAMPBELL 416-7800 KLR	8/12/13		Plumbing
Alcy Ei (2015) 1A	SINK STOPPER WONT HOLD WATER IN KITCHEN PLANT MGR- CAMPBELL/416.7800	2/25/14		Plumbing

Alcy EI (2015) 1A	Replace relief valve on waterheater	5/8/14		Plumbing
Alcy EI (2015) 1A	Flush A/C line	5/14/14		Plumbing
Alcy EI (2015) 1A	Check air line for a/c	3/21/14		Plumbing
Alcy EI (2015) 1A	check A/C leak	6/6/14		Plumbing
Alcy EI (2015) 1A	water fountain is stopped up	10/22/13	south wall	Plumbing
Alcy EI (2015) 1A	WATER FOUNTAIN IS STOPPED UP ON THE KK END	4/21/14	SOUTHEND	Plumbing
Alcy EI (2015) 1A	Flush handle leaking when toilet is flushed (2)	1/9/14	Boys restroom west side	Plumbing
Alcy EI (2015) 1A	Toilet seat broken	1/17/14	Boys R/R by teachers lounge	Plumbing

Alcy EI (2015) 1A	pipe in rr is leaking were sink use to be	10/28/13	3rd floor	Plumbing
Alcy EI (2015) 1A	the flush handle sticks when flushing so water still run	1/30/14	1st floor	Plumbing
Alcy EI (2015) 1A	pipe on urial the pipe has came apart from urial	2/13/14	2nd flr	Plumbing
Alcy EI (2015) 1A	restroom toilet stopped up	2/14/14	1st fir	Plumbing
Alcy EI (2015) 1A	WATER PIPE IN 1ST FLR HALL CEILING-LEAKING-CALLED IN BY SEC PRATCHER 416-7800 KLR	8/2/13		Plumbing
Alcy EI (2015) 1A	MEN/RR SINK NOT RELEASING ANY WATER IN TEACHERS' LOUNGE PLANT MGR-CAMPBELL/416.7800	9/12/13		Plumbing
Alcy EI (2015) 1A	ALL RECEPTACLES HAVE NO POWER IN KITCHEN AREA PLANR MGR-CAMPBELL/416-7800	12/17/13		Plumbing
Alcy EI (2015) 1A	URINAL 3RD FLR B RR-LEAKING WATER DOWN INTO B RR ON 2ND FLR-PLANT MGR CAMPBELL 416-7800 KLR	2/28/14		Plumbing

Alcy EI (2015) 1A	FLR DRAIN IS STOPPED UP IN BOILER RM. PLANT MGR- CAMPBELL/416.7804	4/24/14		Plumbing
Alcy EI (2015) 1A	TOILET IS OVERFLOWING IN B/RR 2ND FLR. PLANT MGR- CAMPBELL/416.7800	1/21/14		Plumbing
Alcy EI (2015) 1A	water is leaking in classroom from the ceiling	9/25/13	301	Roof
Alcy EI (2015) 1A	Fabricate urinal cover	4/9/14		Sheet Metal
Alcy EI (2015) 1A	Install chain & lock on gate around play ground equipment	6/2/14		Sheet Metal

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Alton EI (2020) 1A	1	1	92	105	43	3	41	3	2	291
Grand Total	1	1	92	105	43	3	41	3	2	291

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Alton EI (2020) 1A	floor tile needs to be replaced in some areas	2/5/14	Cafetorium		Asbestos
Alton EI (2020) 1A	THREE DATA PORT NOT WORKING NO NETWORK CONNECTIVITY (SCS Network Cabling and Electronics dept.-- "Please See Journal")	9/13/13	Classroom	205	Cabling
Alton EI (2020) 1A	knobs missing on cabinet doors and hedges need repaired	10/28/13	Classroom	103	Carpentry
Alton EI (2020) 1A	knobs on cabinet are missing/ hedges need repaired	10/28/13	Classroom	104	Carpentry
Alton EI (2020) 1A	knobs need are missing/hinges need repaired	10/28/13	Classroom	105	Carpentry
Alton EI (2020) 1A	cabinets knobs are missing/hinges need repaired	10/28/13	Classroom	106	Carpentry
Alton EI (2020) 1A	knobs on cabinet are missing/hinges need repaired	10/28/13	Classroom	110	Carpentry

Alton EI (2020) 1A	knobs are missing /hinges need repaired	10/28/13	Classroom	112	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	114	Carpentry
Alton EI (2020) 1A	knobs on cabinet are missing/hinges are broken	10/28/13	Classroom	202	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	203	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	205	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	206	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	210	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	212	Carpentry

Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	213	Carpentry
Alton EI (2020) 1A	knobs are missing/hinges need repaired	10/28/13	Classroom	214	Carpentry
Alton EI (2020) 1A	NEED FOUR CEILING TILE CUT- INS	10/28/13	Custodial Closet	1ST FL	Carpentry
Alton EI (2020) 1A	First restroom and first stall door is hanging off the hinges need repair.	11/15/13	1st Floor	Teacher's Lounge Rm.	Carpentry
Alton EI (2020) 1A	Ceiling tiles need repair.	12/20/13	Hallway/Corridor	2nd. Flr.	Carpentry
Alton EI (2020) 1A	Ceiling tile need repair.	12/20/13	Classroom	2nd. Flr. 214	Carpentry
Alton EI (2020) 1A	Ceiling tile need replacing.	1/2/14	Hallway/Corridor	1st.Flr. Teacher Lounge	Carpentry
Alton EI (2020) 1A	counter top needs to be repaired dangerous to the students	1/14/14	Cafeteria	serving line	Carpentry

Alton EI (2020) 1A	can not secure front door will not lock	1/22/14	1st Floor		Carpentry
Alton EI (2020) 1A	need three ceiling tile cut -in	1/22/14	Classroom	212	Carpentry
Alton EI (2020) 1A	knobs are missing off cabinets in this area	1/27/14	Cafeteria	serving line	Carpentry
Alton EI (2020) 1A	four ceiling tile needs to be replaced cut -ins	1/27/14	Custodial Closet	1st fl.	Carpentry
Alton EI (2020) 1A	floor tile needs to be replaced in some areas	2/5/14	1st Floor	main hall	Carpentry
Alton EI (2020) 1A	door closer broken	2/13/14	Cafeteria		Carpentry
Alton EI (2020) 1A	broken door closer	2/13/14	Kitchen		Carpentry
Alton EI (2020) 1A	broken door hinge	2/13/14	1st Floor	girls restroom	Carpentry

Alton EI (2020) 1A	broken door closer	2/13/14	1st Floor	main hall	Carpentry
Alton EI (2020) 1A	four ceiling tile needs to be cut- ins this room.	8/13/13	Classroom	108	Carpentry
Alton EI (2020) 1A	three ceiling tile needs cut-ins in this room	8/13/13	Classroom	104	Carpentry
Alton EI (2020) 1A	need six cut -ins ceiling tile in this area	8/13/13	Restroom (Boys)	2nd fl	Carpentry
Alton EI (2020) 1A	needs five cut-ins ceiling tile	8/13/13	Restroom (Girls)	2nd fl	Carpentry
Alton EI (2020) 1A	needs five cut-ins ceiling tile	8/13/13	Restroom (Boys)	1st fl	Carpentry
Alton EI (2020) 1A	need six cut -ins ceiling tile	8/13/13	Restroom (Girls)	1st fl	Carpentry
Alton EI (2020) 1A	need four ceiling tile cut-ins	8/13/13	Restroom (Girls)	main hallway	Carpentry

Alton EI (2020) 1A	need four ceiling tile cut-ins	8/13/13	Restroom (Boys)	main hallway	Carpentry
Alton EI (2020) 1A	broken door closer	8/15/13	Hallway/Corridor	1st fl northwest	Carpentry
Alton EI (2020) 1A	broken hinges and handles on cabinets	8/23/13	Classroom	204	Carpentry
Alton EI (2020) 1A	need three stall doors installed in the this area	7/15/13	Restroom (Boys)	2nd fl	Carpentry
Alton EI (2020) 1A	need three stall doors installed in this area	7/15/13	Restroom (Boys)	1st fl	Carpentry
Alton EI (2020) 1A	need 4 bundles of ceiling	8/6/13	Custodial		Carpentry
Alton EI (2020) 1A	LIGHT FIXTURE COVERS ARE BROKEN NEEDS REPAIRED	8/28/13	Restroom (Boys)	1ST. FL	Carpentry
Alton EI (2020) 1A	CEILING TILE NEED CUT-INS	8/28/13	1st Floor	1ST. FL	Carpentry

Alton EI (2020) 1A	SBE OFFICE NEED NEEDS THREE CUT - INS	8/28/13	Administration Area	1ST. FL	Carpentry
Alton EI (2020) 1A	need four locker handles	9/9/13	Classroom	202	Carpentry
Alton EI (2020) 1A	need four locker handles installed	9/9/13	Classroom	211	Carpentry
Alton EI (2020) 1A	NEED MARKER INSTALLED BOARDS ARE AT THE SCHOOL	9/13/13	Classroom	209	Carpentry
Alton EI (2020) 1A	NEED MARKER BOARDS INSTALLED BOARDS ARE AT THE SCHOOL	9/13/13	Classroom	210	Carpentry
Alton EI (2020) 1A	need three cut-ins on ceiling tile	9/25/13	1st Floor	101	Carpentry
Alton EI (2020) 1A	need two cut-ins ceiling tile	9/25/13	1st Floor	102	Carpentry
Alton EI (2020) 1A	stall door needs repaired	10/22/13	Restroom (Girls)	2nd fl	Carpentry

Alton EI (2020) 1A	Build wall for drinking fountain	3/7/14				Carpentry
Alton EI (2020) 1A	broken stall door	4/11/14	1st Floor	restroom teacher lounge		Carpentry
Alton EI (2020) 1A	missing cabinet door	4/16/14	Classroom	202		Carpentry
Alton EI (2020) 1A	missing two cabinet doors	4/16/14	Classroom	203		Carpentry
Alton EI (2020) 1A	hole in the under cabinet	4/16/14	Classroom	104		Carpentry
Alton EI (2020) 1A	SKYLIGHT DOME G RR 2ND FLR-BROKEN AND RIGHT NOW IT'S RAINING IN RR-PLANT MGR STRICKLAND 416-7420 KLR	4/28/14				Carpentry
Alton EI (2020) 1A	CAN NOT OPEN PARTION DOORS IN THIS ROOM	4/28/14	Classroom	208		Carpentry
Alton EI (2020) 1A	MISSING FLOOR TILE	5/1/14	Hallway/Corridor	2ND FL		Carpentry

Alton EI (2020) 1A	CABINETS ON SERVING LINE DOORS WILL NOT STAY CLOSED	5/1/14	Cafeteria		Carpentry
Alton EI (2020) 1A	outside window frame needs repaired someone was trying to break-in	5/2/14	Classroom	110	Carpentry
Alton EI (2020) 1A	broken door closer	5/2/14	Custodial Closet		Carpentry
Alton EI (2020) 1A	DOOR - NE STAIRWELL - HARDWARE HAS BEEN BROKEN OFF FROM BREAKIN - PM/STRICKLAND 416-7420	5/5/14			Carpentry
Alton EI (2020) 1A	window frame needs to be replaced	5/6/14	Portables	312	Carpentry
Alton EI (2020) 1A	hole on walk-way of ramp/ floor boards loose	5/19/14	Portables	312	Carpentry
Alton EI (2020) 1A	screen door needs to be repaired	5/19/14	Kitchen		Carpentry
Alton EI (2020) 1A	door will not close properly	5/19/14	1st Floor	main entrance	Carpentry

Alton EI (2020) 1A	counter top panel broken at the bottom	6/19/14	Administration Area	main office	Carpentry
Alton EI (2020) 1A	knobs missing on cabinets in this area	6/19/14	Classroom	111	Carpentry
Alton EI (2020) 1A	cove base missing under locker	6/19/14	Classroom	104	Carpentry
Alton EI (2020) 1A	cove base missing under sink	6/19/14	Classroom	114	Carpentry
Alton EI (2020) 1A	cove base missing	6/19/14	Cafeteria	serving line	Carpentry
Alton EI (2020) 1A	cove base missing	6/19/14	Hallway/Corridor	1st fl.	Carpentry
Alton EI (2020) 1A	marker board needs to be installed already in classroom	6/19/14	Classroom	216	Carpentry
Alton EI (2020) 1A	floor tile is needs to be replaced	6/27/14	Portables	west hallway	Carpentry

Alton EI (2020) 1A	Fasten cover to curb	4/29/14			Carpentry
Alton EI (2020) 1A	NEED DOOR HANDLE INSTALLED CAN NOT CLOSE THIS DOOR	4/30/14	Restroom (Girls)	1ST FL.	Carpentry
Alton EI (2020) 1A	Door off track	4/28/14	Restroom (Girls)	1st floor	Carpentry
Alton EI (2020) 1A	BROKEN TRIM ON COUNTER TOP	5/1/14	Cafetorium	SERVING LINE	Carpentry
Alton EI (2020) 1A	PANIC BAR MISSING END CAP	5/1/14	Cafeteria		Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	MAIN HALLWAY	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Boys)	MAIN HALLWAY	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Kitchen		Carpentry

Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Boys)	1ST FL	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	1ST FL	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	2ND FL	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Boys)	2ND FL	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	1st Floor	TEACHER LOUNG	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROP	5/1/14	Administration Area	MAIN OFFICE DOOR	Carpentry
Alton EI (2020) 1A	INSTALL DOOR PROPS	5/1/14	Cafetorium	ENTRANCE DOORS	Carpentry
Alton EI (2020) 1A	repair starter for boiler pump	10/24/13			Electrical

Alton EI (2020) 1A	repair light in front of main office	10/25/13			Electrical
Alton EI (2020) 1A	Three lights out need repair.	11/8/13	Custodial Closet	1st. Floor	Electrical
Alton EI (2020) 1A	5 lights out need repair.	11/8/13	Hallway/Corridor	2nd Floor	Electrical
Alton EI (2020) 1A	3 lights out at the top of stairwell.	11/13/13	Stairway	1st. Floor	Electrical
Alton EI (2020) 1A	3 lights out at the top of stairwell.	11/13/13	Stairway	2nd. Floor	Electrical
Alton EI (2020) 1A	4 Lights out need repair.	11/15/13	Hallway/Corridor	3rd. Floor	Electrical
Alton EI (2020) 1A	Need repair lights out front entrance and back of stairway also back door entrance.	12/13/13	Stairway	2nd Flr. & 3rd Flr.	Electrical
Alton EI (2020) 1A	Lights out 6 need repair.	12/18/13	Classroom	2nd Flr. 102	Electrical

Alton EI (2020) 1A	Lights out 6 need repair.	12/18/13	Classroom	2nd Flr. 103	Electrical
Alton EI (2020) 1A	Lights out 3 need repair.	12/18/13	Classroom	2nd Flr. 104	Electrical
Alton EI (2020) 1A	Lights out 3 need repair.	12/18/13	Classroom	2nd Flr. 106	Electrical
Alton EI (2020) 1A	Lights out 4 need repair.	12/18/13	Classroom	2nd Flr. 108	Electrical
Alton EI (2020) 1A	3 lights out need repair.	12/18/13	Classroom	2nd Flr. 112	Electrical
Alton EI (2020) 1A	8 lights out need repair.	12/18/13	Classroom	2nd Flr. 113	Electrical
Alton EI (2020) 1A	2 lights out need repair.	12/18/13	Classroom	3rd Flr. 206	Electrical
Alton EI (2020) 1A	16 lights out need repair.	12/18/13	Hallway/Corridor	1st. Flr.	Electrical

Alton EI (2020) 1A	11 lights out need repair.	12/18/13	Hallway/Corridor	1st. Flr.	Electrical
Alton EI (2020) 1A	7 lights out need repair.	12/18/13	Hallway/Corridor	3rd. Flr.	Electrical
Alton EI (2020) 1A	9 lights out repair.	12/18/13	Hallway/Corridor	2nd. Flr.	Electrical
Alton EI (2020) 1A	3 lights out need repair.	12/18/13	Stairway	2nd. Flr.	Electrical
Alton EI (2020) 1A	2 Top and bottom stairwell by rm. 209 need repair.	12/18/13	Stairway	2nd. Flr. by rm.206& 209	Electrical
Alton EI (2020) 1A	5 lights out need repair.	12/18/13	Stairway	2nd. Flr. by rm. 209	Electrical
Alton EI (2020) 1A	2 lights out need repair.	12/18/13	Stairway	2nd. Flr. by rm. 214	Electrical
Alton EI (2020) 1A	4 lights out need repair.	12/18/13	Administration Area	2nd flr.Facilitator rm.	Electrical

Alton EI (2020) 1A	3 lights out in Office need repair.	12/18/13	Library	2nd flr.	Electrical
Alton EI (2020) 1A	3 Oulets need repairing.	12/18/13	Library	2nd flr.	Electrical
Alton EI (2020) 1A	16 Lights out.	12/19/13	Classroom	2nd. Flr. B 224	Electrical
Alton EI (2020) 1A	Correction on work order 404842 Multiple lights out. It's not at South Side, It's at Alton Elem.	12/19/13	Portables	312	Electrical
Alton EI (2020) 1A	need toggle switch installed	1/7/14	Cafetorium		Electrical
Alton EI (2020) 1A	need toggle switch installed	1/7/14	1st Floor	hallway	Electrical
Alton EI (2020) 1A	need toggle switch installed	1/7/14	2nd Floor	hallway	Electrical
Alton EI (2020) 1A	ballast out in this area	1/13/14	Classroom	209	Electrical

Alton EI (2020) 1A	ballast out in this area	1/13/14	Classroom	nurse office	Electrical
Alton EI (2020) 1A	ballast out in this room	1/22/14	Classroom	212	Electrical
Alton EI (2020) 1A	no power in restroom lights are out	1/27/14	Cafeteria	manager office	Electrical
Alton EI (2020) 1A	very dark two bulbs out	8/13/13	Parking Lot		Electrical
Alton EI (2020) 1A	light out on pole behind portables	8/13/13	Portables		Electrical
Alton EI (2020) 1A	two ballast out, bulbs are in fixture	8/15/13	2nd Floor	202	Electrical
Alton EI (2020) 1A	ballast out bulbs are in fixture	8/15/13	2nd Floor	204	Electrical
Alton EI (2020) 1A	two ballast out	8/26/13	Classroom	104	Electrical

Alton EI (2020) 1A	four emergency exit lights	7/24/13	Cafeteria		Electrical
Alton EI (2020) 1A	two emergency exit lights are out	7/24/13	1st Floor	main hallway	Electrical
Alton EI (2020) 1A	emergency light out	7/24/13	Hallway/Corridor	north	Electrical
Alton EI (2020) 1A	emergency lights out	7/24/13	1st Floor	hallway	Electrical
Alton EI (2020) 1A	emergency lights out	7/24/13	Hallway/Corridor	northwest	Electrical
Alton EI (2020) 1A	no emergency lights	7/24/13	Mechanical Room	boiler room	Electrical
Alton EI (2020) 1A	need 8ft f69t8/tit4 one case	7/30/13	Kitchen	main entrance	Electrical
Alton EI (2020) 1A	fourteen lights in this area	7/30/13	Cafeteria		Electrical

Alton EI (2020) 1A	CEILING UNIT NOT COMING ON IN PLANT MGR OFFICE, KITCHEN, CAFE'S MGR OFFICE, SERVING AREA. PLANT MGR-STRICKLAND/416.7420	7/30/13				Electrical
Alton EI (2020) 1A	ballast out	8/2/13	Administration Area			Electrical
Alton EI (2020) 1A	two ballast out	8/7/13	1st Floor	107		Electrical
Alton EI (2020) 1A	two ballast out	8/7/13	1st Floor	104		Electrical
Alton EI (2020) 1A	two ballast out	8/7/13	1st Floor	105		Electrical
Alton EI (2020) 1A	two ballast out	8/7/13	1st Floor	106		Electrical
Alton EI (2020) 1A	FOUR BALLAST OUT	8/28/13	Hallway/Corridor	1ST FL		Electrical
Alton EI (2020) 1A	CHILLER NOT COMING ON PLANT MGR-STRICKLAND/416.7420	9/16/13				Electrical

Alton EI (2020) 1A	two ballast out	9/27/13	Kitchen		Electrical
Alton EI (2020) 1A	two ballast out	9/27/13	Kitchen	dish room	Electrical
Alton EI (2020) 1A	ballast out	9/27/13	Classroom	110	Electrical
Alton EI (2020) 1A	ballast out	9/27/13	Classroom	103	Electrical
Alton EI (2020) 1A	need three cases of 46807 bulbs	10/16/13	1st Floor		Electrical
Alton EI (2020) 1A	need master clock reset	3/5/14	Administration Area		Electrical
Alton EI (2020) 1A	Move electrical box	3/19/14			Electrical
Alton EI (2020) 1A	no power to the p/a system	3/24/14	Cafetorium		Electrical

Alton EI (2020) 1A	exhaust fan no power	4/3/14	Kitchen		Electrical
Alton EI (2020) 1A	per mr strickland 416-7430 room 216 and 114 UV no power	4/11/14			Electrical
Alton EI (2020) 1A	need two cases of bulbs # 46807	4/14/14			Electrical
Alton EI (2020) 1A	ballast out in this area	4/16/14	Administration Area	prinicipal office	Electrical
Alton EI (2020) 1A	ballast out in this area	4/16/14	1st Floor	asst.-office	Electrical
Alton EI (2020) 1A	ballast out	4/16/14	Classroom	206	Electrical
Alton EI (2020) 1A	ballast out	4/16/14	Classroom	212	Electrical
Alton EI (2020) 1A	ballast out	4/16/14	Classroom	214	Electrical

Alton EI (2020) 1A	ballast out	4/16/14	Classroom	104	Electrical
Alton EI (2020) 1A	UNIT NOT COMING ON IN RM-209 PLANT MGR- STRICKLAND/416.743 0	5/13/14			Electrical
Alton EI (2020) 1A	UNIT NOT COMING ON IN RM-107,108,114 PLANT MGR- STRICKLAND/	5/13/14			Electrical
Alton EI (2020) 1A	light switch needs to be replaced	5/14/14	Custodial Closet	1st fl	Electrical
Alton EI (2020) 1A	Check A/C room 7,8,9	5/29/14			Electrical
Alton EI (2020) 1A	Replace motor in A/C unit	6/4/14		Room 104	Electrical
Alton EI (2020) 1A	Oil & lube A/C motor	6/4/14			Electrical
Alton EI (2020) 1A	ten bulbs out in this area	6/19/14	Cafeteria		Electrical

Alton EI (2020) 1A	two ballast out	6/19/14	1st Floor	hallway	Electrical
Alton EI (2020) 1A	ballast out bulbs are in the fixture	6/20/14	Classroom	209	Electrical
Alton EI (2020) 1A	ballast out bulbs are in the fixture	6/20/14	Classroom	206	Electrical
Alton EI (2020) 1A	tomestone needs to be replaced in four light fixture	6/20/14	Hallway/Corridor	2nd fl.	Electrical
Alton EI (2020) 1A	ten lights out in this area over 10ft.	6/20/14	Cafeteria		Electrical
Alton EI (2020) 1A	outlet needs to be replaced	6/27/14	Restroom (Boys)	main hall	Electrical
Alton EI (2020) 1A	outlet needs to be replaced	6/27/14	1st Floor	main hall	Electrical
Alton EI (2020) 1A	ballast out bulbs are in already	4/30/14	Restroom (Boys)	2nd fl	Electrical

Alton EI (2020) 1A	ballast out bulbs are un already	4/30/14	Restroom (Girls)	2nd fl	Electrical
Alton EI (2020) 1A	tomestone light fixture is broken no light	4/30/14	Restroom (Girls)	2nd fl	Electrical
Alton EI (2020) 1A	BALLAST OUT BULBS ARE IN FIXTURE	4/30/14	1st Floor	SBE OFFICE	Electrical
Alton EI (2020) 1A	Need repair 2 Security lights outside behind the Cafeteria and corner of building.	12/13/13	Grounds	Behind Building	Electrical
Alton EI (2020) 1A	no power exhaust fan	4/28/14	Restroom (Boys)	2nd fl	Electrical
Alton EI (2020) 1A	exhaust fan no power	4/28/14	Restroom (Girls)	1st fl.	Electrical
Alton EI (2020) 1A	exhaust fan no power	4/28/14	Restroom (Boys)	1st fl	Electrical
Alton EI (2020) 1A	No power exhaust fan	4/28/14	Restroom (Girls)	2nd floor	Electrical

Alton EI (2020) 1A	2 lights out need repair.	12/18/13	Classroom	3rd Flr. 212	Electrical
Alton EI (2020) 1A	Need lights in classrooms and ahallways throughout the building.	12/12/13	Classroom		Electrical
Alton EI (2020) 1A	Mr. Kenneth White, Fluorescent Bulbs are needed 46823 /25 watt / Quanity 4 boxes, at Alton Elem. School. And Wessington 6B Bulbs 25 watt / 120 volts	11/11/13			Electrical
Alton EI (2020) 1A	Mr. White, Wessington 6B Bulbs 25 watt / 120 volts / Quanity 8 Boxes. These are needed at Alton Elem. School.	11/11/13			Electrical
Alton EI (2020) 1A	need four case's of bulbs 46807	8/26/13	Cafetorium	classrooms	Electrical
Alton EI (2020) 1A	need toggle switch in this area	7/15/13	Cafeteria		Electrical
Alton EI (2020) 1A	need toggle switch in this area	7/15/13	1st Floor		Electrical
Alton EI (2020) 1A	need toggle switch in this area	7/15/13	Hallway/Corridor	2nd fl	Electrical

Alton EI (2020) 1A	Install chemical feed pump for cooling tower.	10/23/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Yearly - Air Handler Cleanings-Alton Elementary - Refer to PM schedule details.	11/10/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	boiler down	11/18/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	HEAT RMS 103, 105, 106, 107, 110, 112, 113, & 114-ALL NOT HEATING-PLANT MGR McFARLANE 416-7430 KLR	11/20/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	WALL UNITS NOT HEATING IN RM-101 THRU 109, RM-201 THRU 215 PLANT MGR-MCFARLAND/650.038 9	12/2/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	main ofc overheating	12/11/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Yearly - Water-Cool Chiller Filter-Alton Elem - Refer to PM schedule details.	12/30/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	HEAT RM 107 PRE-K RM-NOT HEATING-PLANT MGR STRICKLAND 416-7430 KLR	1/6/14			Heating/Ventilation /Air Conditioning

Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Alton Elementary Lvl 2 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Filter-Alton Elementary - Refer to PM schedule details.	2/8/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	chiller down	7/18/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Yearly - Oil Samples-Alton Elem - Refer to PM schedule details.	9/1/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	chiller is down per Strickland 416-7420	9/4/13			Heating/Ventilation /Air Conditioning

Alton EI (2020) 1A	Monthly - Oil Lube & Belt-Alton Elementary - Refer to PM schedule details.	9/9/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	chiller down	9/23/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Filter-Alton Elementary - Refer to PM schedule details.	10/5/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	c/o to heat	10/17/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Yearly - Cooling Tower(STRAINERS)-Alton Elem - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning

Alton EI (2020) 1A	display on chiller	4/2/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Alton Elementary Lvl 2 Water Treatment - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Oil Lube & Belt-Alton Elementary - Refer to PM schedule details.	4/7/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	per strickland 416-7430 room 208 unit making loud noise, kitchen not cooling	4/11/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	unit over loading dock -- - change actuator	4/22/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Alton Elementary Lvl 2 Water Treatment - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning

Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Alton Elementary Lvl 2 Water Treatment - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Filter-Alton Elementary - Refer to PM schedule details.	6/7/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	BOILER NOT HEATING . PLANT MGR- MCFARLAND/650.0389	11/12/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Daily - Alton Elementary Level 1 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Monthly - Alton Elementary Lvl 2 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning

Alton EI (2020) 1A	Yearly - Rod Chiller - Alton Elementary - Refer to PM schedule details.	3/1/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Yearly - Fire Boilers - Alton Elementary - Refer to PM schedule details.	3/1/14			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	boiler down	11/12/13			Heating/Ventilation /Air Conditioning
Alton EI (2020) 1A	Spray clear finish on stall doors	7/23/13			Painting
Alton EI (2020) 1A	GRAFFITI ON POWER BOX FRONT OF BLDG PLANT MGR- STRICKLAND/416.743 0	4/17/14			Painting
Alton EI (2020) 1A	Stain & finish doors	4/22/14			Painting
Alton EI (2020) 1A	FLR DRAIN IS BACKING UP IN KITCHEN. PLANT MGR- STRICKLAND/416.743 0	10/24/13			Plumbing
Alton EI (2020) 1A	HAND SINK KITCHEN AREA-HAS COME COMPLETELY OFF WALL-PLANT MGR STRICKLAND 416-7430 KLR	10/31/13			Plumbing

Alton EI (2020) 1A	Drain is stopped up and it has a odor from the drain.	11/13/13	Kitchen	1st. Floor	Plumbing
Alton EI (2020) 1A	in kitchen drain is backing up in floor per Ms. McFarlane 416-7430	11/14/13			Plumbing
Alton EI (2020) 1A	Unstop sewer from kitchen	11/21/13			Plumbing
Alton EI (2020) 1A	Third Fauset runs constantly will not cut off.	12/4/13	Hallway/Corridor	1st. Flr.	Plumbing
Alton EI (2020) 1A	First sink fauset is striped.	12/11/13	Hallway/Corridor	1st. Flr.	Plumbing
Alton EI (2020) 1A	3rd. Faucet handle is stripped.	12/18/13	Hallway/Corridor	2nd flr.	Plumbing
Alton EI (2020) 1A	Correction on work order404788 Portable 312 large amount of water behind portable. It's at Alton Elem. not at SOUTH Side.	12/19/13	Portables	312	Plumbing
Alton EI (2020) 1A	WATER FOUNTAIN CAFE AREA-HAS BURST PER SBE-PLANT MGR STRICKLAND 416-7430 KLR	1/6/14			Plumbing

Alton EI (2020) 1A	per strickland 416-7430 teacher's lounge the only commode in there the flush valve is broken	2/7/14				Plumbing
Alton EI (2020) 1A	toilet leaks	8/15/13	Restroom (Boys)	2nd fl		Plumbing
Alton EI (2020) 1A	flush valve needs to be replaced	7/31/13	Restroom (Girls)	1st fl		Plumbing
Alton EI (2020) 1A	flush valve needs to be replaced	7/31/13	Portables	restroom		Plumbing
Alton EI (2020) 1A	broken toilet seat	7/31/13	1st Floor	s.b.e		Plumbing
Alton EI (2020) 1A	drinking fountain leaking	8/6/13	Hallway/Corridor	2nd fl.		Plumbing
Alton EI (2020) 1A	sink has leak	8/6/13	Hallway/Corridor	1st fl		Plumbing
Alton EI (2020) 1A	2-UV ARE LEAKING WATER IN RM-204(063) RM-208(031). PLANT MGR-STRICKLAND/416.7430	8/8/13				Plumbing

Alton EI (2020) 1A	SINK TO BE REPAIRED WATER WILL NOT CUT OFF	8/28/13	Hallway/Corridor	2ND FL	Plumbing
Alton EI (2020) 1A	unit # 105-001 is leaking	9/9/13	Hallway/Corridor	main hallway	Plumbing
Alton EI (2020) 1A	Test and report on backflow prevention devices.	9/25/13			Plumbing
Alton EI (2020) 1A	water will not shut off	9/27/13	Custodial Closet	1st fl.	Plumbing
Alton EI (2020) 1A	pop -off valve needs replaced	9/30/13	Mechanical Room	1st fl.	Plumbing
Alton EI (2020) 1A	drinking fountain not working # 105-085	10/22/13	Cafeteria		Plumbing
Alton EI (2020) 1A	COMMODE B RR 2ND FLR-REP/REPL FLUSH VALVE, CONSTANTLY RUNNING & LEAKING PER SBE-PLANT MGR STRICKLAND 416-7420415	10/22/13			Plumbing
Alton EI (2020) 1A	Backflow preventer valve is leaking water. T&P relief valve on hot water tank is leaking. Water on boiler room floor.	10/23/13			Plumbing

Alton EI (2020) 1A	toilet will not flush	3/20/14	Administration Area		Plumbing
Alton EI (2020) 1A	toilet will not flush	3/21/14	Administration Area	principal office	Plumbing
Alton EI (2020) 1A	garbage disposal is making loud noise when in use	3/27/14	Kitchen		Plumbing
Alton EI (2020) 1A	two toilets in this area will not flush	3/27/14	Restroom (Girls)	1st fl	Plumbing
Alton EI (2020) 1A	sink will not stop running water	4/2/14	Clinic		Plumbing
Alton EI (2020) 1A	TOILET IS OVERFLOWING, CANT CONTROL IN G/RR 1ST FLR PLANT MGR-STRICKLAND/237.5329	4/23/14			Plumbing
Alton EI (2020) 1A	STORM DRAIN NEEDS TO BE CLEANED OUT	4/28/14	Grounds	EASTSIDE OF SCHOool	Plumbing
Alton EI (2020) 1A	SEWAGE IS BACKING UP IN KITCHEN PLANT MGR-NUNNALLY/416.7430	5/2/14			Plumbing

Alton EI (2020) 1A	roof drain stopped up	5/5/14	Administration Area	roof	Plumbing
Alton EI (2020) 1A	sewer drain needs to be cleaned out	5/5/14	Kitchen	outside kitchen door	Plumbing
Alton EI (2020) 1A	sink stopped up	5/14/14	Classroom	212	Plumbing
Alton EI (2020) 1A	sink water will not stop running	5/14/14	Administration Area	teacher lounge	Plumbing
Alton EI (2020) 1A	toilet seats needs to be repaired in this area	5/16/14	1st Floor	teacher's lounge	Plumbing
Alton EI (2020) 1A	per strickland 416-7430 there is a gas smell in the kitchen	2/25/14			Plumbing
Alton EI (2020) 1A	STOVE KITCHEN AREA-NEED PILOT LIT-WILL NEED FOR LUNCH-PLANT MGR STRICKLAND 416-7420 KLR	2/25/14			Plumbing
Alton EI (2020) 1A	leak in this area	1/7/14	Library		Roof

Alton EI (2020) 1A	crack in ceiling in this room in two different areas water comes down	4/3/14	Classroom	212	Roof
Alton EI (2020) 1A	crack in ceiling wet in this area	4/3/14	Library		Roof
Alton EI (2020) 1A	need four locker handles installed	8/8/13	Classroom	213	Sheet Metal
Alton EI (2020) 1A	can not open locker teacher needs to remove her items	5/23/14	1st Floor	105	Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Barrets Chapel ES (0010)	1	1	38	101	30	4	35	3	4	217
Grand Total	1	1	38	101	30	4	35	3	4	217

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Barrets Chapel ES (0010)	please refinish the gym wood floor, floor is starting to flake and needs refinish. Not a priority, please take care of High/Middle schools first	10/3/13	Gym		Asbestos
Barrets Chapel ES (0010)	Requesting for Intercom system to be repaired. system not working.	3/7/14			Cabling
Barrets Chapel ES (0010)	please replace loose floor tile in room 207.	6/10/14	Classroom	217	Carpentry
Barrets Chapel ES (0010)	Requesting for ply boards to be removed from over the windows to the ISS classroom in the gym.	5/28/14	Classroom		Carpentry
Barrets Chapel ES (0010)	Window in classroom 204 is cracked. need repairing.	6/3/14	Classroom	204	Carpentry
Barrets Chapel ES (0010)	Need plywood removed from window in girls locker room and replaced with glass.	4/16/14	Gym		Carpentry
Barrets Chapel ES (0010)	Requesting for a broken ceiling grid to be replaced.(cafeteria locker room)	5/20/14	Cafeteria		Carpentry

Barrets Chapel ES (0010)	Requesting for missing slide door lock latch to be replaced. Cafeteria dish room.	5/20/14	Cafeteria		Carpentry
Barrets Chapel ES (0010)	Adjust all lab tables to ADA height.	5/28/14			Carpentry
Barrets Chapel ES (0010)	Need ceiling tile cut in hallway upstairs. ceiling tile has whole in it next to room 205,214, ceiling tile need to be cut. tile is to the right of the elevator upstairs. <i>tile is unneeded</i>	1/31/14	Hallway/Corridor	upstairs	Carpentry
Barrets Chapel ES (0010)	need ceiling tile cut in gym storage room around the ceiling heating vent and around a pipe. (storage room is next to stage and pull up bars.)	1/31/14	Gym	storage room	Carpentry
Barrets Chapel ES (0010)	Need ceiling tile cut around Steimens electrical box. GIRLS restroom front lobby. (GYM)	2/3/14	Gym		Carpentry
Barrets Chapel ES (0010)	requesting for upstairs exit door to be repaired.	3/17/14	Hallway/Corridor		Carpentry
Barrets Chapel ES (0010)	Requesting for 2 stained ceiling tile to be cut and replaced. location: first floor next to room 109.	3/19/14	Hallway/Corridor		Carpentry
Barrets Chapel ES (0010)	There are spaces and holes between the metal beams in the gym. daylight is shinning threw. having terrible problems with wasp getting into gym space. have to	4/14/14	Gym		Carpentry

Barrets Chapel ES (0010)	room 112 there are two large shelves /coat rack that need to be move they are in the way please help	7/30/13	Classroom	room112	Carpentry
Barrets Chapel ES (0010)	there are 2 large shelves / coat rack in room 112 that need to be moved see me about questions	7/30/13			Carpentry
Barrets Chapel ES (0010)	Requesting for white board to be mounted to the wall in room 106. school as board in room 217. room 106 do not have a black board or corking board for white board to be	8/13/13	Classroom	106	Carpentry
Barrets Chapel ES (0010)	Requesting for a signage for the over door for the science lab. (signage to state:175.)	9/27/13	1st Floor		Carpentry
Barrets Chapel ES (0010)	Requesting signage with the name and number of the classroom. 170 music, 171 Art, 174 library, 175 Science Lab, 3 signs stating	9/27/13			Carpentry
Barrets Chapel ES (0010)	Requesting for broken glass to windows to be removed. (girls locker room)	12/16/13	Gym	locker room	Carpentry
Barrets Chapel ES (0010)	Requesting for screen hooks to be removed out of wall. large screw is stripped. drill bit will not remove screws. (GYM Stage)	12/18/13			Carpentry
Barrets Chapel ES (0010)	need ceiling tile cut around pipe and beside heating unit. Gym	1/2/14			Carpentry

Barrets Chapel ES (0010)	REQUESTING FOR CEILING TILE TO BE CUT AROUND SPRINKLER HEAD AND 2 OTHER TILE IN HALLWAY ACROSS FROM ROOM 109. (FIRST FLOOR)	1/7/14	Hallway/Corridor		Carpentry
Barrets Chapel ES (0010)	REQUESTING FOR A METAL CEILING TILE GRID TO BE CUT. NEEDED TO REPLACE GRID IN HALLWAY ACROSS FROM ROOM 103.	1/7/14	Hallway/Corridor		Carpentry
Barrets Chapel ES (0010)	REQUESTING FOR CEILING TILE TO BE CUT AROUND SMOKE DETECTOR IN MAIN HALLWAY. ACROSS FROM THE TIGER BOOKSTORE.	1/7/14	Hallway/Corridor		Carpentry
Barrets Chapel ES (0010)	REQUESTING FOR TILE TO BE CUT IN THE CAFETERIA DINNING AREA. AROUND THE (ONE) SPRINKLER HEAD AND (ONE) VENT.	1/7/14	Cafeteria		Carpentry
Barrets Chapel ES (0010)	REQUESTING FOR CEILING TILE TO BE CUT AROUND SPRINKLER HEAD. (UPSTAIRS HALLWAY ACROSS FROM ROOM 213 AND TO CUT CEILING TILE	1/8/14	Hallway/Corridor	UPSTAIRS	Carpentry
Barrets Chapel ES (0010)	REQUESTING (4) BOXES OF FIBERGLASS CEILING TILE. CLASS A.	1/8/14			Carpentry
Barrets Chapel ES (0010)	REQUESTING FOR CEILING TILE TO BE CUT AROUND SPRINKLER HEAD AND SPEAKER IN ROOM 212.	1/10/14	Classroom	212	Carpentry
Barrets Chapel ES (0010)	REQUESTING FOR CEILING TILE TO BE CUT AROUND SPRINKLER HEAD AND SPEAKER IN ROOM 212.	1/10/14	Classroom	212	Carpentry

Barrets Chapel ES (0010)	need missing floor tile replaced. room 204 and 210.	6/3/14	Classroom	204	Carpentry
Barrets Chapel ES (0010)	Requesting for broken floor tile in the cafeteria dining area to be replaced.	6/4/14	Cafeteria		Carpentry
Barrets Chapel ES (0010)	Requesting for broken floor tile to be replaced in room 175.	6/5/14	Classroom	175	Carpentry
Barrets Chapel ES (0010)	Need ply board removed from windows and glass replaced. (GIRLS) LOCKER ROOM.	2/20/14	Gym	Girls Locker Room	Carpentry
Barrets Chapel ES (0010)	Screws need to be replaced in both chin up bars. Gym floor.	2/20/14	Gym		Carpentry
Barrets Chapel ES (0010)	Requesting for window to be replaced in room 206.	6/16/14	Classroom		Carpentry
Barrets Chapel ES (0010)	Please replace broken windows in the girls locker room. (Gym)	6/19/14	Gym	Girls locker room	Carpentry
Barrets Chapel ES (0010)	Please remove ply boards from over windows in the ISS room. (gym)	6/19/14	Classroom	Gym	Carpentry

Barrets Chapel ES (0010)	Please remove Ply Boards from over the outside windows to the band room.	6/19/14		Band Room	Carpentry
Barrets Chapel ES (0010)	Please repair intercom system.	6/9/14			Electrical
Barrets Chapel ES (0010)	1st floor center stairs inside smoke detector dirty M 1-95.	4/29/14	1st Floor		Electrical
Barrets Chapel ES (0010)	Please check ballast to light fixture in Cafeteria dinning area. new bulbs is in fixture.	5/8/14	Cafeteria		Electrical
Barrets Chapel ES (0010)	Download the remote code installation.	7/15/13			Electrical
Barrets Chapel ES (0010)	Show plant manager the fans on the roof.	7/15/13			Electrical
Barrets Chapel ES (0010)	Configure burglar alarm panel to accept code changes via phone line.	7/16/13			Electrical
Barrets Chapel ES (0010)	Show plant manager all electrical panels locations and all necessary electrical switches.	7/16/13			Electrical

Barrets Chapel ES (0010)	Please repair the pole light in the parking lot located over the principles parking spot.	7/16/13			Electrical
Barrets Chapel ES (0010)	Needing cover placed over Fire Alarm Pull Station. (GIRLS LOCKER ROOM) GYM.	2/17/14	Gym	GIRLS LOCKER Room	Electrical
Barrets Chapel ES (0010)	junction box need a cover. Girls LOCKER ROOM. (GYM)	2/17/14	Gym	Girls Locker Room	Electrical
Barrets Chapel ES (0010)	Exit sign out. back door of GIRLS LOCKER ROOM. (GYM)	2/17/14	Gym	GIRLS LOCKER GYM	Electrical
Barrets Chapel ES (0010)	REQUESTING (5) 70 WATTS METAL HALIDE LAMPS. FOR BARRET'S CHAPEL ELEMENTARY. DO NOT STOCK IN THE WAREHOUSE.	1/13/14		PLANT MANAGER	Electrical
Barrets Chapel ES (0010)	REQUESTING METAL HALIDE LAMP 100 WATT,MH100/UMED CLEAR. ITEM # 10531. (5) LAMPS PLEASE DELIVER TO BARRET'S ELEMENTARY	1/13/14		PLANT MANAGER	Electrical
Barrets Chapel ES (0010)	Requesting for (3) wire light covering to be removed from light fixtures in the custodian closet. UPSTAIRS.	1/14/14	Custodial Closet		Electrical
Barrets Chapel ES (0010)	Requesting for the ballast to be replaced in lights fixture. custodian closet. new bulbs in fixture.	1/23/14	Custodial	2nd floor	Electrical

Barrets Chapel ES (0010)	two lights out outside wall pack entrance 3 and 4.	1/23/14	1st Floor	outside	Electrical
Barrets Chapel ES (0010)	Requesting for Ballast to be replaced in two light fixtures upstairs. custodian closet.	1/27/14	Custodial Closet		Electrical
Barrets Chapel ES (0010)	Panel showing trouble. dirty smoke detector corridor near RM: 108. M1-52.	1/31/14	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	ballast out to (1) light fixture in the custodian closet first floor. new bulbs in light fixture.	2/3/14	Custodial Closet		Electrical
Barrets Chapel ES (0010)	(URGENT) please check the steamers on serving line. have check breakers. steamers will not come on.	2/5/14	Cafeteria		Electrical
Barrets Chapel ES (0010)	Panel showing trouble: 2nd floor West stair inside smoke detector dirty. M-110.	2/10/14	2nd Floor		Electrical
Barrets Chapel ES (0010)	Please check the heater in the electrical room. (BACK DOCK OF THE CAFETERIA).	2/11/14	Cafeteria	electrical room	Electrical
Barrets Chapel ES (0010)	Requesting 7 boxes of bulbs to be delivered to Barret's chapel. Item # 10365 Incandescent lamps 100A-130V.	2/12/14		Plant Manager Office	Electrical

Barrets Chapel ES (0010)	Exit sign out Cafeteria serving line middle door.	2/13/14			Electrical
Barrets Chapel ES (0010)	Panel showing trouble. first floor west stair inside dirty smoke detector M-1 85.	2/14/14			Electrical
Barrets Chapel ES (0010)	Teachers having problems with the access door this morning. badges not working.	2/14/14			Electrical
Barrets Chapel ES (0010)	Requesting 10 boxes of Incandescent lamps 100Watt 100A-130V Catalog number: 10365. to be delivered to Barret's Chapel Elem.	2/28/14		Plant Manager	Electrical
Barrets Chapel ES (0010)	Check fire alarm system for proper operation	3/6/14			Electrical
Barrets Chapel ES (0010)	Check burglar alarm system for proper operation	3/6/14			Electrical
Barrets Chapel ES (0010)	Please check electrical heater (not working) in mechanical room back dock of the cafeteria.	3/6/14	Mechanical Room		Electrical
Barrets Chapel ES (0010)	Please check ballast to emergency light in hallway. (first floor)	3/6/14	Hallway/Corridor		Electrical

Barrets Chapel ES (0010)	Intercom system is not working.	3/7/14				Electrical
Barrets Chapel ES (0010)	alarm panel showing Trouble. Corridor near book room store. M-147 Smoke Detector.	3/10/14	1st Floor			Electrical
Barrets Chapel ES (0010)	Requesting a screen for light fixture in room 105.	3/10/14	Classroom	105		Electrical
Barrets Chapel ES (0010)	Please replace ballast in one light fixture. room 171. (new bulbs is in fixture, tape is on outside of screen of light fixture that need ballast replaced)	3/11/14	Classroom	171		Electrical
Barrets Chapel ES (0010)	Requesting ballast to be replaced in room 103. light fixture takes 4 bulbs. new bulbs in fixture, tape on screen of light fixture that out.	3/19/14	Classroom	103		Electrical
Barrets Chapel ES (0010)	Requesting for ballast to be replaced in room 102. light fixture takes 4 bulbs. new bulbs in fixture, tape is light fixture that bulbs is out.	3/19/14	Classroom	102		Electrical
Barrets Chapel ES (0010)	Requesting for one pole light to be replaced on the parking. located near back dock of cafeteria.	3/24/14	Parking Lot			Electrical
Barrets Chapel ES (0010)	(1) exit light out entrance doors to serving line to cafeteria.	3/27/14	Cafeteria			Electrical

Barrets Chapel ES (0010)	Requesting 7 boxes of bulbs. # 10221 Fluorescent lamps F32T8 energy efficient. deliver to Barret's chapel elementary.	3/27/14				Electrical
Barrets Chapel ES (0010)	Requesting a screen for (1) light screen cover in Girls locker Gym.	3/28/14	Gym		Girls Locker Room	Electrical
Barrets Chapel ES (0010)	Intercom system is not working. continues to call one room.	3/31/14			Front Office	Electrical
Barrets Chapel ES (0010)	Exit sign out. Library (first door)	4/1/14	Library			Electrical
Barrets Chapel ES (0010)	Flood light out to exit sign. (GYM) entrance door.	4/1/14	Gym			Electrical
Barrets Chapel ES (0010)	Light fixture uses (4) bulbs. please check ballast. new bulbs is in fixtures and tape is on screens that light is out. Room 200	4/1/14	2nd Floor		200	Electrical
Barrets Chapel ES (0010)	Intercom system has started back constantly buzzing the gym again.	4/3/14			front office	Electrical
Barrets Chapel ES (0010)	Intercom is not working properly again. it continues to buzz the gym.	4/16/14			Front Office	Electrical

Barrets Chapel ES (0010)	please ballastbad to light in stairs east end	7/23/13	Stairway	east hall	Electrical
Barrets Chapel ES (0010)	we have to ballast out on stage in gym bad	7/23/13	Gym	gym /stage	Electrical
Barrets Chapel ES (0010)	there are 3 wall pack lights out facing teacher parking	7/30/13		outside building	Electrical
Barrets Chapel ES (0010)	Requesting for the ballast to be repaired to light fixture. main hallway supply room. have changed bulbs.	8/5/13	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Requesting for the ballast to be replaced in light fixtures.(main office hallway near restroom.)	8/5/13	Administration Area		Electrical
Barrets Chapel ES (0010)	Requesting for a light hook/latch to be repaired in one of the offices. (office at the end of the hallway at the exit sign)	8/5/13	Administration Area		Electrical
Barrets Chapel ES (0010)	Exit light light out at the hallway beside the Cafeteria.	8/5/13	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Exit sign out just as you enter into the serving line of the Cafeteria.	8/5/13	Cafeteria		Electrical

Barrets Chapel ES (0010)	Exit sign out next to room 215. (upstairs)	8/5/13	2nd Floor		Electrical
Barrets Chapel ES (0010)	2 lights is out on side of building facing the playground. (lights located beside room # 203 and 3.	8/7/13		side of building	Electrical
Barrets Chapel ES (0010)	REQUESTING FOR LIGHT TO BE REPAIRED IN THE SERVING LINE OF THE CAFETERIA.	8/8/13	Cafeteria		Electrical
Barrets Chapel ES (0010)	Requesting 2 boxes of.item # 10531 metal Halide Lamp 100 watt,MH100/U Med. clear to be delivered to Barret's Chapel Elem.	8/28/13		plant Manager Office	Electrical
Barrets Chapel ES (0010)	requesting 2 boxes of bulbs.item# 10460. Lamp, Metal Halide,MVR 400/U Mogul Base. to be delivered to Barret's Chapel Elem.	8/28/13		plant manager office	Electrical
Barrets Chapel ES (0010)	Requesting 2 boxes of bulbs. item # 10257 Flourescent Lamp PLT 42W/35/4P Phillips. to be delivered to Barret's Chapel Elem.	8/28/13		plant manager office	Electrical
Barrets Chapel ES (0010)	2 boxes of bulbs.item #10221 Fluorescent Lamp F32T8 energy efficient Lamp. to be delivered to Barret's Chapel Elem.	8/28/13		Plant Manager Office	Electrical
Barrets Chapel ES (0010)	Requesting for two blown lights to be replaced. Gym floor.	9/4/13	Gym		Electrical

Barrets Chapel ES (0010)	Exit light out in gym, just as you enter into the front lobby from gym floor. (right side of gym floor)	9/4/13	Gym		Electrical
Barrets Chapel ES (0010)	Hallway time clock is not working. (clock beside room 108 computer lab, first floor.)	9/5/13			Electrical
Barrets Chapel ES (0010)	Requesting for the light switch to be repaired in the library. some of the light will not come on in the light fixture.	9/19/13			Electrical
Barrets Chapel ES (0010)	exit light out in Cafeteria serving line.	9/23/13	Cafeteria		Electrical
Barrets Chapel ES (0010)	exit light out at entrance B2.	9/23/13	1st Floor		Electrical
Barrets Chapel ES (0010)	Exit light out just as you enter into front lobby of gym.	9/23/13	Gym		Electrical
Barrets Chapel ES (0010)	Requesting for the ballast to be replaced in the light fixture. (front lobby of the gym.) also light fixture need a light cover.	10/2/13	Gym		Electrical
Barrets Chapel ES (0010)	Requesting for a broken light cover to be replaced. light fixture in the front lobby of gym.	10/9/13	Hallway/Corridor		Electrical

Barrets Chapel ES (0010)	Requesting for the ballast to be replaced in two light fixture boys rest room. (across from Library, first floor, new bulbs is in light fixture)	10/10/13	Restroom (Boys)		Electrical
Barrets Chapel ES (0010)	please check light fixture (entire frame) is pulling away from ceiling. Boys restroom across from library,first floor,and first light fixture as you enter into restroom	10/10/13	Restroom (Boys)		Electrical
Barrets Chapel ES (0010)	Requesting 13 light covers that is missing in the Coaches office. (GYM)	10/23/13		Office	Electrical
Barrets Chapel ES (0010)	Requesting 13 missing covers for light fixture in the coaches office gym	10/23/13	Gym	Office	Electrical
Barrets Chapel ES (0010)	Requesting 5 missing light covers for light fixture on gym stage.	10/23/13	Gym	Stage	Electrical
Barrets Chapel ES (0010)	Requesting for 2 missing light cover for light fixture in the hallway to locker room.	10/23/13	Gym	hallway/locker room	Electrical
Barrets Chapel ES (0010)	Verify burglar alarm data base.	10/28/13			Electrical
Barrets Chapel ES (0010)	Mark breakers to boilers on panel door	11/6/13			Electrical

Barrets Chapel ES (0010)	exit light out to entrance B2. this is hallway just outside of Cafeteria.	12/3/13	1st Floor		Electrical
Barrets Chapel ES (0010)	Exit light out in hallway. Just in front of Library. battery low.	12/3/13	1st Floor		Electrical
Barrets Chapel ES (0010)	Please replace ballast to light fixture in office. fixture is across from teachers work area. (tape is on fixture, new bulb in light fixture).	12/3/13	1st Floor		Electrical
Barrets Chapel ES (0010)	Please check light fixture in hallway FIRST FLOOR, next to room103. (new bulbs in light fixture)	12/10/13	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Please replace ballast to light fixture in the hallway next to room 105. (new bulbs in fixture)	12/16/13	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Please replace ballast to light fixture in hallway next to room 112. (new bulbs in light fixture)	12/16/13	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Please replace ballast to light fixture in HALLWAY next to RM 103.	1/2/14	1st Floor		Electrical
Barrets Chapel ES (0010)	Please check ballast to light fixture in cafeteria dinning area. new bulbs in fixture.	1/2/14	Cafeteria		Electrical

Barrets Chapel ES (0010)	trouble on fire panel. dirty smoke detector M2-51 corridor near library.	1/3/14				Electrical
Barrets Chapel ES (0010)	trouble on fire panel. dirty smoke detector M2-51 corridor near library.	1/7/14	1st Floor			Electrical
Barrets Chapel ES (0010)	Requesting for ballast to be replaced in light fixture room 104. new bulbs in fixture and tape is on the light fixture.	1/7/14	Classroom	104		Electrical
Barrets Chapel ES (0010)	Requesting for ballast to be replaced in room 108. new bulbs in fixture, tape is on light fixture.	1/7/14	1st Floor	108		Electrical
Barrets Chapel ES (0010)	REQUESTING (5) BOXES OF FLUORESCENT LAMP F32T8. ITEM # 10221. (3) BOXES OF FLUORESCENT LAMP F34T12CWRS ITEM# 10220. PLEASE	1/7/14				Electrical
Barrets Chapel ES (0010)	ALARM PANEL SHOWING TROUBLE PH. 2 LINE AND ALARM PANEL CONTINUE TO BUZZ LOUDLY.	1/8/14				Electrical
Barrets Chapel ES (0010)	REQUESTING FOR BALLAST TO BE REPLACED. NEW BULBS IN FIXTURE. TAPE IS FIXTURE SCREEN. ROOM 109.	1/8/14	Classroom	109		Electrical
Barrets Chapel ES (0010)	TROUBLE ON ALARM PANEL READING: CORRIDOR NEAR ROOM 104. SMOKE DETECTOR DIRTY M1-48.	1/10/14	Hallway/Corridor			Electrical

Barrets Chapel ES (0010)	Breaker is tripping in GYM. breakers thrown for Basketball Goal to be let down.	2/20/14	Gym		Electrical
Barrets Chapel ES (0010)	panel showing trouble. duct detector M1-12. Gym AHU2 Supply	6/23/14	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Exit sign out hallway exit door next to Cafeteria.	6/26/14	Hallway/Corridor		Electrical
Barrets Chapel ES (0010)	Both exit signs out in the gym. (over both doors leading into the front lobby)	6/26/14	Gym		Electrical
Barrets Chapel ES (0010)	Exit sign and flood light out back door of the girls locker room.	6/26/14	Gym		Electrical
Barrets Chapel ES (0010)	Exit sign out back door in the boys locker room.	6/26/14	Gym		Electrical
Barrets Chapel ES (0010)	Change filters whole building	5/30/14		Whole building	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check air conditioner unit over back door to Cafeteria. water is leaking just as you enter the back door of the dock. Cafeteria.	5/12/14	Cafeteria		Heating/Ventilation /Air Conditioning

Barrets Chapel ES (0010)	Air conditioner when in use is leaking a lot of water onto cafeteria floor. back door of cafeteria entrance.	5/27/14	Cafeteria		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Requesting for the the heating to be check. room206, 204 is cold.	2/5/14	2nd Floor		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check the front entrance door. having problems with it at times.	2/10/14			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	No heat in the Cafeteria prep area. Please check RTU.	3/6/14	Cafeteria		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Air is not coming on in the front office, plant managers office upstairs and downstairs. had power failure last week PHRASE B.	3/31/14	1st Floor		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	THE THERMOSTAT IN ROOM 110 NEEDS TO BE ADJUSTED - IT IS LOCKED	8/7/13		ROOM 110	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	(URGENT) please check unit to room 107. unit not cooling room. Sensor in room 113. is cooling all other rooms connected to sensor.	8/13/13	Classroom	107	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	(URGENT)Please repair unit to room 109. Sensor is in room 113. all other rooms is cool that is connected to that sensor.	8/13/13	Classroom	109	Heating/Ventilation /Air Conditioning

Barrets Chapel ES (0010)	A/C 1ST FLR RMS 107 & 109-NOT COOLING-SBE DOUGLASS 873-8164 KLR	8/13/13				Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check the HVAC unit in the boys restroom FIRST FLOOR ACROSS from THE LIBRARY.(please check the humidifier setting and unit)	10/10/13	Restroom (Boys)			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check roof top unit to room 215. all other classrooms on this sensor has air. (CLASSROOM IS HOT THERMOSTAT IN CLASSROOM WILL NOT COME)	10/18/13	Classroom	215		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Requesting for a cover to be placed over thermostats sensors in room 113,102, 201,217,212, TWA ROOM.	10/23/13	Classroom			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Requesting a cover over thermostat sensor in room 202.	10/23/13	Classroom	202		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Entire school is cold from offices to Cafeteria and classroom. please check roof top units.	11/14/13	Cafetorium			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	THIS WORK ORDER IS FOR ARLINGTON ELEMENTARY. Have check with Mike unit is in heat mode. Room 116 is blowing cold air 50 degrees in classroom. (URGENT)	11/14/13	Classroom			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check roof top unit to room 206. spoke with mike sensor to this and others rooms is reading 64.94. which is good. all others rooms on same sensor is not so hot. CLASSROOM	11/15/13				Heating/Ventilation /Air Conditioning

Barrets Chapel ES (0010)	(URGENT) unit is blowing colder in room 207 than in other rooms on same sensor. please check unit. Mike read temp. sensor at 64.42	11/19/13	Classroom	207	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	REPAIR/REPLACE FAULTY MASTER, COMMUNICATION PROBLEMS BECOMING MORE PROMINENT	11/20/13		EMS	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	room 206. teacher is saying room is too hot. no one is touching or adjusting thermostats. this is the same room that were too cold last week. mike read sensor for this room	11/25/13	Classroom	206	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check units to room 212 and 208. Mike read sensor for both rooms. is 64.2 rooms is very cold.no one is adjusting thermostats.	11/26/13			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check unit to room 206. room is very hot . mike reading sensor for this room is. 64.5 no one is adjusting thermostat.	11/26/13			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Replace heat exchanger	12/3/13		rm 213	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	unit is blowing cold air in the Cafeteria prep area and serving line.	12/10/13	Cafeteria		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check unit to room 115. Only room on this hall that unit is blowing cold air.	12/11/13	Classroom		Heating/Ventilation /Air Conditioning

Barrets Chapel ES (0010)	no heat in the Cafeteria PREP AREA. Unit blowing cold air.	1/6/14	Cafeteria		Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	Please check the air conditioner unit in the Principal office. air is on in other parts of the office.	6/4/14	1st Floor	office	Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	UNIT IN THE KITCHEN IS LEAKING. SBE TATE	7/17/13			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	rooms 209, 211, 213, 215, 217 no a/c very hot	7/15/13			Heating/Ventilation /Air Conditioning
Barrets Chapel ES (0010)	REQUESTING FOR THE WALL NEXT TO ROOM 107 TO BE PAINTED ALONG WITH OTHER AREAS IN THE HALLWAY. ALSO THE WALL NEXT TO ROOM 215	1/13/14	Hallway/Corridor		Painting
Barrets Chapel ES (0010)	REQUESTING FOR TO THE BOYS AND GIRLS LOCKER ROOMS AND THE HALLWAY BE PAINTED. PAINT IS PEELING. (GYM)	1/13/14	Restroom (Boys)		Painting
Barrets Chapel ES (0010)	REQUESTING FOR THE WALLS IN THE GYM FRONT LOBBY TO BE PAINTED. PAINT IS PEELING VERY BADLY.	1/13/14	Gym		Painting
Barrets Chapel ES (0010)	REQUESTING (1) GALLON CAN OF INTERIOR LATEX WALL & TRIM PREMIUM SATIN WHITE 670 PAINT. PLANT MANAGER STARTED PAINTING	1/10/14	Hallway/Corridor		Painting

Barrets Chapel ES (0010)	Please repair handle to water fountain. upstairs hall middle water fountain.	5/13/14	Hallway/Corridor		Plumbing
Barrets Chapel ES (0010)	Sewer is stopped up..	7/12/13			Plumbing
Barrets Chapel ES (0010)	WATER LEAKING FROM AROUND THE TOILET IN THE GYM FRONT LOBBY. GIRLS FIRST STALL.	1/13/14	Gym		Plumbing
Barrets Chapel ES (0010)	(Cafeteria manager is unable to do work orders at this time) dishwasher machine will not fill.	1/23/14	Cafeteria		Plumbing
Barrets Chapel ES (0010)	Cafeteria Manger is unable to send work orders at this time. THE STEAMER IS LEAKING.	1/23/14	Cafeteria		Plumbing
Barrets Chapel ES (0010)	toilet is stopped up. boys rest room downstairs. (last stall).	1/31/14	Restroom (Boys)		Plumbing
Barrets Chapel ES (0010)	Handle is sticking to toilet in Girls Restroom. First Floor Last Stall.	2/28/14	Restroom (Girls)		Plumbing
Barrets Chapel ES (0010)	Turn water to the gym off.	3/5/14			Plumbing

Barrets Chapel ES (0010)	Turn off water and turn it back on once power comes back on	3/6/14				Plumbing
Barrets Chapel ES (0010)	Requesting for middle faucet in girls restroom upstairs to be repaired.	3/26/14	Restroom (Girls)			Plumbing
Barrets Chapel ES (0010)	Requesting for toilet in boys restroom last stall to be repaired. have used snake toilet still stopped up. (Restroom next to room 170)	4/1/14	1st Floor	Boys Restroom		Plumbing
Barrets Chapel ES (0010)	Show plant manager plumbing and gas valves and sewers.	7/25/13				Plumbing
Barrets Chapel ES (0010)	Faucet to sink in the Cafeteria serving line will not turn off completely. (water dripping from faucet.	8/6/13	Cafeteria			Plumbing
Barrets Chapel ES (0010)	Per State of TN Elevator inspector: elevator pit needs cleaning/clearing out	8/13/13	Elevator			Plumbing
Barrets Chapel ES (0010)	drain out pipe has the cover missing. (this is in front of the dumpster at the kitchen back dock.)	8/22/13	Kitchen			Plumbing
Barrets Chapel ES (0010)	Requesting for toilet in the teachers work area, first floor to be repaired. (first toilet just as you enter in to TWA room)	9/5/13	1st Floor	TWA		Plumbing

Barrets Chapel ES (0010)	Requesting for the toilet in the last stall to be repaired. water continue to run.	9/19/13	Restroom (Boys)		Plumbing
Barrets Chapel ES (0010)	Please light heaters. Also repair faucet.	10/17/13		Rental house	Plumbing
Barrets Chapel ES (0010)	Install Boiler Certificate in frame. TN# T46154	10/29/13			Plumbing
Barrets Chapel ES (0010)	Install Boiler Certificate in frame. TN# 136811	10/29/13			Plumbing
Barrets Chapel ES (0010)	Please test the following RP SER. # 567004 1" 909 Watts Science Lab	11/11/13			Plumbing
Barrets Chapel ES (0010)	Please test the following RP SER. # 566560 1" 909 Watts Science Lab	11/11/13			Plumbing
Barrets Chapel ES (0010)	Please test the following RP SER. # 118156 2 1/2" 909 Watts Riser room	11/11/13			Plumbing
Barrets Chapel ES (0010)	Please test the following RP SER. # 118173 2 1/2" 909 Watts Riser room	11/11/13			Plumbing

Barrets Chapel ES (0010)	please check toilet in the GIRLS restroom next to the music room (171) water continue to run long time after toilet is flushed.)	11/12/13	Restroom (Girls)	100 hall	Plumbing
Barrets Chapel ES (0010)	please check toilet in the GIRLS restroom next to the music room (171) water continue to run long time after toilet is flushed.)	11/12/13	Restroom (Girls)	100 hall	Plumbing
Barrets Chapel ES (0010)	(URGENT) Please check if there is a project in area. Low water pressure upstairs and in Cafeteria.	11/14/13	2nd Floor		Plumbing
Barrets Chapel ES (0010)	Please repair toilet in the last stall boys restroom. have snaked, but toilet continues to over flow. (first Floor)	11/25/13	Restroom (Boys)		Plumbing
Barrets Chapel ES (0010)	Toilet drains slow.	11/26/13		Rental House	Plumbing
Barrets Chapel ES (0010)	Requesting for the toilet in the girls restroom,(First Stall) first floor to be repaired. small water leaking from around pipes.	12/10/13	Restroom (Girls)	First Floor	Plumbing
Barrets Chapel ES (0010)	dishwasher leaks and the sprayer is not working correctly	1/8/14	Cafeteria		Plumbing
Barrets Chapel ES (0010)	Please repair outside water faucet on building . Managed to turn water off and screw valve back on. valve may need replacing.	6/30/14	1st Floor	outside	Plumbing

Barrets Chapel ES (0010)	Need water turned off to faucets in locker room shower. (GIRLS LOCKERS ROOM) Locker room will be used next school year.	2/17/14	Gym	Girls Locker Room	Plumbing
Barrets Chapel ES (0010)	Requesting for water to showers to be turn off in Boys Locker Room. locker room has not been used, will be used next school year.	2/24/14	Gym		Plumbing
Barrets Chapel ES (0010)	Please replace broken shower heads in the boys locker. (gym)	6/19/14	Gym	Boys locker room	Plumbing
Barrets Chapel ES (0010)	(URGENT) water leak just as you enter into back dock door. ceiling tile continue to fill with water tile is around sprinkler and will fall may damage sprinkler head	5/9/14	Cafeteria		Roof
Barrets Chapel ES (0010)	Water leak gym floor. next to boys locker room.	4/4/14	Gym		Roof
Barrets Chapel ES (0010)	Roof leak in the gym front lobby and gym floor.	10/10/13	Gym		Roof
Barrets Chapel ES (0010)	Make metal plate for electricians	2/19/14			Sheet Metal
Barrets Chapel ES (0010)	Requesting for lockers in the boys locker room to be removed off of wall so that they can be pick up. lockers is bolted to the wall.	5/7/14			Sheet Metal

Barrets Chapel ES (0010)	requesting for a fence or cage to be placed around the LARGE METAL BRACE for ROOF TOP UNITS. Girls and Boys Locker rooms / this Metal Brace is in	2/24/14	Gym		Sheet Metal
Barrets Chapel ES (0010)	Repair gutter on old band room	7/17/13			Sheet Metal

	A	B	C	D	E	F	G	H	I	J
1	Count of Craft	Craft								
2	Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
3	Bellevue MS (2040) 1A	9	56	92	47	30	59	7	12	312
4	Grand Total	9	56	92	47	30	59	7	12	312

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Bellevue MS (2040) 1A	REPAIR/REPLACE MISSING SECTION OF ASBESTO FLOOR TILE	6/6/14	1st Floor	105	Asbestos
Bellevue MS (2040) 1A	REPAIR/REPLACE MISSING SECTION ASBESTO FLOOR TILE	6/6/14	1st Floor	106	Asbestos
Bellevue MS (2040) 1A	repair or replace broken floor tile/2 sections	5/12/14	1st Floor	106	Asbestos
Bellevue MS (2040) 1A	remove carpet repair with floor tile	5/12/14	2nd Floor	main office/student services	Asbestos
Bellevue MS (2040) 1A	repair or replace 8 sections of 9 by 9 asbesto floor tile	2/6/14	Cafeteria	center section	Asbestos
Bellevue MS (2040) 1A	repair or replace broken floor tile 2 sections	5/12/14	1st Floor	103	Asbestos
Bellevue MS (2040) 1A	REMOVE OLD DAMAGE ASBESTO FLOOR TILE AND REPLACE WITH FLOOR TILE	5/13/14	1st Floor	103	Asbestos

Bellevue MS (2040) 1A	refinish gym floors	10/2/13	Gym	recreation area	Asbestos
Bellevue MS (2040) 1A	refinish gym floor	10/2/13			Asbestos
Bellevue MS (2040) 1A	KITCHEN OUTSIDE DOOR CANT SECURE, &GYM. SBE-HILL/416-4488	7/15/13			Carpentry
Bellevue MS (2040) 1A	exterior door key not turning latch to unlock or lock door	7/16/13	2nd Floor	student services	Carpentry
Bellevue MS (2040) 1A	OUTSIDE DOOR SOUTH, CANT SECURE. PLANT MGR- HILL/416.4488	7/25/13			Carpentry
Bellevue MS (2040) 1A	DOOR LATCH STUCK INSIDE KEY CYLINDER	6/6/14	3rd Floor	303	Carpentry
Bellevue MS (2040) 1A	REPAIR OR REPLACE LOOSE COLBASE/ NOT SECURE AGAINST WALL	6/12/14	1st Floor	109	Carpentry
Bellevue MS (2040) 1A	door will not close shut/off set door	5/23/14	1st Floor	s/w exter. door main bldg	Carpentry

Bellevue MS (2040) 1A	repair or replace 3 floor tile	5/27/14	1st Floor	104	Carpentry
Bellevue MS (2040) 1A	repair/replace missing colbase tile strip	5/15/14	Auditorium	center section	Carpentry
Bellevue MS (2040) 1A	REPAIR OR REPLACE COLBASE BASE STRIPS ON FLOORS	5/21/14	Auditorium	CENTER SECTION	Carpentry
Bellevue MS (2040) 1A	repair or replace floor tile colbase torn from tile area	2/11/14	Auditorium	second floor	Carpentry
Bellevue MS (2040) 1A	repair door knob very loose/about to come off/	2/14/14	1st Floor	108	Carpentry
Bellevue MS (2040) 1A	repair or replace panic bar coming from door fame/need to be secured	2/18/14	1st Floor	south exterior door	Carpentry
Bellevue MS (2040) 1A	north exterior door off set/will not shut close	2/19/14	1st Floor	band room	Carpentry
Bellevue MS (2040) 1A	repair west exterior door door handler very loose/about to come off	2/19/14	1st Floor	main building	Carpentry

Bellevue MS (2040) 1A	ENTRANCE DOOR SOUTH END-PANIC BAR DAMGED-WON'T BE ABLE TO SECURE BLDG-PLANT MGR HILL 416-1466 KLR	3/7/14				Carpentry
Bellevue MS (2040) 1A	repair doors will not latch when close	3/17/14	1st Floor	n/w door		Carpentry
Bellevue MS (2040) 1A	adjust entrance door/will not shut close	3/22/14	Gym	boys restroom		Carpentry
Bellevue MS (2040) 1A	bolt shut 3 windows	4/1/14	Gym	s/e window sill		Carpentry
Bellevue MS (2040) 1A	replace 3 sections of floor tile	4/1/14	Cafeteria	east entrance		Carpentry
Bellevue MS (2040) 1A	WEST DOOR KEY CYLINDER WILL NOT TURN KEY	4/4/14	Gym	LOBBY		Carpentry
Bellevue MS (2040) 1A	very hard to unlock/lock door bad key cylinder	4/9/14	1st Floor	science lab		Carpentry
Bellevue MS (2040) 1A	bad door latch hard to unlock door with key	4/9/14	1st Floor	west main entrance exterior		Carpentry

Bellevue MS (2040) 1A	repair or replace swinging door attache to counter/not secured to counter	4/9/14	2nd Floor	student services	Carpentry
Bellevue MS (2040) 1A	repair or replace 9 sections of broken floor tile	4/11/14	Auditorium	stage	Carpentry
Bellevue MS (2040) 1A	repair or replace 5 sections of broken floor tile	4/14/14	Cafeteria	serving line	Carpentry
Bellevue MS (2040) 1A	repair or replace 3 pieces of broken floor tile	4/15/14	1st Floor	north hall	Carpentry
Bellevue MS (2040) 1A	replace missing floor tile	4/15/14	1st Floor	hall south	Carpentry
Bellevue MS (2040) 1A	WINDOW - GYM RM 100 - BROKEN OUT - CAN'T SECURE - PM/HILL 416-4488	4/16/14			Carpentry
Bellevue MS (2040) 1A	marker board tray has come loose from marker board/hanging	4/17/14	Gym	room 100	Carpentry
Bellevue MS (2040) 1A	COLBASE STRIPS NEED TO BE GLUE DOWN	4/30/14	Auditorium	CENTER SECTION	Carpentry

Bellevue MS (2040) 1A	EMER. DOOR CANT SECURE IN SOUTH-WEST END. PLANT MGR-HILL/416.4488	10/22/13				Carpentry
Bellevue MS (2040) 1A	door offset/metal object underneath cannot remove	10/28/13	Kitchen		south entrance	Carpentry
Bellevue MS (2040) 1A	door knob very loose/about to come off	12/11/13	3rd Floor		305	Carpentry
Bellevue MS (2040) 1A	install bullentine board on west wall	11/8/13	2nd Floor		206	Carpentry
Bellevue MS (2040) 1A	bolt window shut	11/13/13	Gym		south recreation area	Carpentry
Bellevue MS (2040) 1A	replace missing colbase on handicap ramp	12/3/13	Cafeteria		east section	Carpentry
Bellevue MS (2040) 1A	repair door knob very loose about to come off	1/22/14	2nd Floor		OFFICE SUPPLY CLOSET	Carpentry
Bellevue MS (2040) 1A	repair or replace missing floor tile/2 sections	1/23/14	Cafeteria		first floor/east entrance	Carpentry

Bellevue MS (2040) 1A	GYM WEST ENTRANCE DOOR-IS SPRUNG OPEN PER SBE-CAN'T CLOSE-PLANT MGR HILL 416-1466 KLR	1/23/14				Carpentry
Bellevue MS (2040) 1A	REPLACE MISSING COLBASE 3 FEET SECTION	1/23/14	Cafeteria		EAST ENTRANCE	Carpentry
Bellevue MS (2040) 1A	install 3 by 5 cork board on south wall/science room	1/31/14	3rd Floor		310	Carpentry
Bellevue MS (2040) 1A	door knob very loose/need to be secure to door	1/13/14	2nd Floor		main office supply closet	Carpentry
Bellevue MS (2040) 1A	cannot secure door/door off set	8/1/13	1st Floor		north custodian door	Carpentry
Bellevue MS (2040) 1A	need a bullentine board install on south wall	8/1/13	1st Floor		109	Carpentry
Bellevue MS (2040) 1A	CANNOT SECURE STUDENT SERVICES EXTERIOR DOOR/BAD CYLINDER/	8/5/13	2nd Floor		STUDENT SERVICES	Carpentry
Bellevue MS (2040) 1A	bad door lock/cylinderb teacher can not at into class room	8/5/13	1st Floor		109	Carpentry

Bellevue MS (2040) 1A	replace missing door knob/inside knob/class room door stays open to prevent children from getting locked in	9/10/13	2nd Floor	204	Carpentry
Bellevue MS (2040) 1A	BLEACHERS IN GYM NOT EXTENDING OUT SOUTH-SIDE PLANT MGR-HILL/416.1466	9/19/13			Carpentry
Bellevue MS (2040) 1A	REPAIR AND REPLACE 2 FEET SECTION OF DAMAGE COLBASE	10/3/13	2nd Floor	N/W LANDING	Carpentry
Bellevue MS (2040) 1A	REPAIR AND REPLACE DAMAGE BASEBOARD DONE BY TERMITES/AREA HAS BEEN TREATED/ REPLACE COLBASE 15 FEET SECTION	10/3/13	1st Floor	NORTH HALL	Carpentry
Bellevue MS (2040) 1A	SOUTH ENTRANCE DOOR-PANIC BAR HANGING OFF, WILL NOT BE ABLE TO SECURE BLDG- PLANT MGR HILL 416-1466 KLR	10/10/13			Carpentry
Bellevue MS (2040) 1A	bolt shut windows in room	8/15/13	Gym	room 100	Carpentry
Bellevue MS (2040) 1A	repair or replace baseboard damage by termites/ area have treated	8/20/13	1st Floor	north hall	Carpentry
Bellevue MS (2040) 1A	repair or replace 8 sections of broken floor tile	5/7/14	Auditorium	stage	Carpentry

Bellevue MS (2040) 1A	repair or replace fallen cabinet bottom and cabinet molding	11/5/13	1st Floor	home ecom	Carpentry
Bellevue MS (2040) 1A	install bullentine board/ material on campus	8/5/13	2nd Floor	north hall by 202 rm.	Carpentry
Bellevue MS (2040) 1A	need 3 boxes item 46807 light bulbs	9/3/13	1st Floor	class rooms	Electrical
Bellevue MS (2040) 1A	need 3 boxes of lamp, flr rapid start 25 --- item # 468807	7/1/13	2nd Floor	halls	Electrical
Bellevue MS (2040) 1A	DISCONNECT POWER BOX NOT WORKING	7/10/13	Mechanical Room	elevator equitment room	Electrical
Bellevue MS (2040) 1A	need 50 lamps(2 boxes) of item # 46807	7/16/13	3rd Floor	classrooms/halls	Electrical
Bellevue MS (2040) 1A	Install new CT box and conduit. Parts located in Master Electricians Office.	7/17/13			Electrical
Bellevue MS (2040) 1A	blown lamp/over 12 feet high need bucket truck	7/18/13	1st Floor	s/e gym exterior	Electrical

Bellevue MS (2040) 1A	parking lott blown lamp/over 12 feet up need bucket truck	7/18/13	1st Floor	exterior west gym	Electrical
Bellevue MS (2040) 1A	set master clock bells to ring for new school time I.D 110095	7/19/13	2nd Floor	main office	Electrical
Bellevue MS (2040) 1A	set master clock in main office for new start times I.D.110095	7/29/13	2nd Floor	main office	Electrical
Bellevue MS (2040) 1A	set clocks to turn on AHU on and off at proper time	7/29/13	2nd Floor	supply closet	Electrical
Bellevue MS (2040) 1A	set clocks to turn AHU on/off at proper time	7/29/13	1st Floor	custodian closet	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	7/30/13	2nd Floor	202	Electrical
Bellevue MS (2040) 1A	NEED 75 LAMPS/ITEM # 46807	7/31/13	3rd Floor	halls/classrooms	Electrical
Bellevue MS (2040) 1A	wall outlet come from wall/hanging	7/31/13	1st Floor	104	Electrical

Bellevue MS (2040) 1A	blade came off motor of cooling tower	6/26/14	1st Floor	cool tower	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	6/27/14	3rd Floor	north hall	Electrical
Bellevue MS (2040) 1A	POWER OUTAGE throughout the ENTIRE BUILDING per Mr. Hill, Plant Mgr. 416.4488	5/21/14			Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	5/30/14	3rd Floor	305	Electrical
Bellevue MS (2040) 1A	repair or replace breaker #7 constantly trippin	5/29/14	Kitchen	pantry	Electrical
Bellevue MS (2040) 1A	bells from master clock need resetting/per principal	5/12/14	2nd Floor	main office	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	3/31/14	3rd Floor	306	Electrical
Bellevue MS (2040) 1A	all sections of lights out/bad ballast/workers cannot see in room	2/6/14	1st Floor	custodial supply room	Electrical

Bellevue MS (2040) 1A	section of lights out/bad ballast	2/6/14	Machine Shop	south/east side	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	2/6/14	Library	LIBRARIAN OFFICE	Electrical
Bellevue MS (2040) 1A	wall outlets not working/two refrigerators and childrens computers on outlets	2/14/14	1st Floor	home ecom.	Electrical
Bellevue MS (2040) 1A	SET MASTER CLOCK TO DAYLIGHT SAVING TIME	2/21/14	2nd Floor	MAIN OFFICE	Electrical
Bellevue MS (2040) 1A	replace two missing exit sign facing	3/5/14	Gym	lobby	Electrical
Bellevue MS (2040) 1A	replace one blown lamp/need small bucket truck about 12 feet high	3/6/14	1st Floor	n/w exterior gym	Electrical
Bellevue MS (2040) 1A	repair or replace 5 sections of lights that will not come on /bad light switch	3/10/14	1st Floor	102	Electrical
Bellevue MS (2040) 1A	EXIT LIGHT OUT/REPAIR OR REPLACE	3/17/14	Kitchen	WEST EXIT ENTRANCE	Electrical

Bellevue MS (2040) 1A	WALL OUTLETS DONOT WORK	3/24/14	1st Floor	106	Electrical
Bellevue MS (2040) 1A	WALL OUTLETS NOT WORKING	3/24/14		GUIDANCE	Electrical
Bellevue MS (2040) 1A	repair or replace bad photocell over light/need bucket van over 12 feet high	4/1/14	1st Floor	N/E main bldg.exterior	Electrical
Bellevue MS (2040) 1A	southside bell donot ring when use manually/master clock	4/7/14	2nd Floor	main office	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	4/11/14	2nd Floor	205	Electrical
Bellevue MS (2040) 1A	section of lights out/ bad ballast	4/11/14	Library	office	Electrical
Bellevue MS (2040) 1A	blown lamp /need bucket van/over 12 feet up	4/21/14	1st Floor	main blgd.north exterior	Electrical
Bellevue MS (2040) 1A	bad ballast/ need replacing/section of lights out	4/22/14	1st Floor	science lab	Electrical

Bellevue MS (2040) 1A	section of light out/bad ballast	4/25/14	1st Floor	science lab	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	4/25/14	3rd Floor	room 305	Electrical
Bellevue MS (2040) 1A	HAS COMPLETE POWER OUTAGE- PLANT MGR HILL 416-4488 KLR	4/28/14			Electrical
Bellevue MS (2040) 1A	4 lamps blown/ need lift over 12 feet high/STAGE AREA IS DARK/PROBLEM WITH PROGRAMS IS HELD	4/29/14	Auditorium	stage	Electrical
Bellevue MS (2040) 1A	4 lamps blown/ need lift over 12 feet high/STAGE AREA IS DARK/PROBLEM WITH PROGRAMS IS HELD	10/18/13	Auditorium	stage	Electrical
Bellevue MS (2040) 1A	the power to the bleachers is out per hill 416-4488	10/31/13			Electrical
Bellevue MS (2040) 1A	Power outage in the entire building per Cameron Hill, Plant Mgr. 416.4488	10/31/13			Electrical
Bellevue MS (2040) 1A	change master clock daylight saving time	11/4/13	2nd Floor	main office	Electrical

Bellevue MS (2040) 1A	west wall has no power/wallout not working/breaker not tripp	11/5/13	1st Floor	guidance office	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	12/17/13	3rd Floor	301	Electrical
Bellevue MS (2040) 1A	NEED 3 CASES OF LAMPS # 46807	12/17/13	1st Floor	main bldg	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	11/6/13	3rd Floor	305	Electrical
Bellevue MS (2040) 1A	all wallouts not working/breaker is not tripp	11/6/13	1st Floor	106	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	11/8/13	2nd Floor	PRINCIPAL OFFICE	Electrical
Bellevue MS (2040) 1A	BAD BALLAST/SECTION OF LIGHTS OUT	11/13/13	Kitchen	RESTROOM	Electrical
Bellevue MS (2040) 1A	wall outlet hanging from wall/need to be secure in place. locatee on north wall	11/18/13	1st Floor	104	Electrical

Bellevue MS (2040) 1A	repair or replace broken light/cannot turn or off/please install key switch	11/21/13	Gym	BOYS LOCKER ROOM	Electrical
Bellevue MS (2040) 1A	need two cases of bulb/# 46807	12/3/13	1st Floor	main bldg	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	12/6/13	2nd Floor	principal office	Electrical
Bellevue MS (2040) 1A	wire up temp. boiler	12/10/13			Electrical
Bellevue MS (2040) 1A	wall outlets not working/ breaker not tripp	12/10/13	1st Floor	106	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT BAD BALLAST	1/22/14	Library	EAST	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	1/23/14	1st Floor	CUSTODIAL CLOSET	Electrical
Bellevue MS (2040) 1A	UNIT NOT HEATING IN G/LOCKER RM PLANT MGR-HILL/826.8480	1/28/14			Electrical

Bellevue MS (2040) 1A	section of lights /ballast bad	1/31/14	Cafeteria	northside	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	8/5/13	2nd Floor	202	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	8/5/13	Administration Area	GIRLS RESROOM	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	8/5/13	1st Floor	NORTH STAIR	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	8/5/13	3rd Floor	GIRLS RESTROOM	Electrical
Bellevue MS (2040) 1A	SECTION OF LIGHTS OUT BAD BALLAST	8/7/13	3rd Floor	BOYS RESTROOM	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/10/13	Cafeteria	southside	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/10/13	Cafeteria	northside	Electrical

Bellevue MS (2040) 1A	section of lights out/bad ballast	9/20/13	2nd Floor	204	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/20/13	1st Floor	home ecom.	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/20/13	Cafeteria	south section	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/20/13	3rd Floor	307	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/20/13	2nd Floor	202	Electrical
Bellevue MS (2040) 1A	section of lights out/bad ballast	9/20/13	Cafeteria	north section	Electrical
Bellevue MS (2040) 1A	REPLACE BLOWN LAMP/ 15 FEET HIGH NEED SMALL BUCKET TRUCK	10/8/13	Gym	S/W EXTERIOR	Electrical
Bellevue MS (2040) 1A	A/C RM 105-MAKING NOISES-PLANT MGR HILL 416-1466 KLR	10/15/13			Electrical

Bellevue MS (2040) 1A	2 section of light flicking/bad ballasts/classroom disturbances	10/16/13	3rd Floor	305	Electrical
Bellevue MS (2040) 1A	FCU NOT COMING ON IN TEACHERS' LOUNGE(028) PLANT MGR- HILL/416.4488	8/13/13			Electrical
Bellevue MS (2040) 1A	teachers lounge id# 110028 a/c not coming on per cameron hill 416-4488	8/14/13			Electrical
Bellevue MS (2040) 1A	main clock in office need bell ring time to change I.D. 110.095	8/21/13	2nd Floor	main office	Electrical
Bellevue MS (2040) 1A	blown lamp/over 12 feet up/ need bucket van	8/23/13	1st Floor	exterior s/w gym	Electrical
Bellevue MS (2040) 1A	FCU NOT COMING ON IN DATA RM(028) PLANT MGR- HILL/416.4488	8/26/13			Electrical
Bellevue MS (2040) 1A	NEED 3 CASES LAMPS ITEM #46807	8/29/13	2nd Floor	HALL/CLASSROOM	Electrical
Bellevue MS (2040) 1A	blown lamp need bucket van 12 feet high	5/7/14	1st Floor	north main bldg exterior	Electrical

Bellevue MS (2040) 1A	SEPARATE HALL BREAKER FROM GUIDANCE OFFICE BREAKER this office needs continuous power for computers	9/3/13	1st Floor	guidance office	Electrical
Bellevue MS (2040) 1A	exhaust fan not running	9/12/13	Gym	boys locker room	Electrical
Bellevue MS (2040) 1A	WALL OUTLET HANGING FROM WALL NEED TO BE SECURE IN PLACE	10/3/13	1st Floor	104	Electrical
Bellevue MS (2040) 1A	INSTALL CASE OVER WALL OUTLET THAT HAVE ELECTRICAL PLUG GOING TO IT. CHILDREN CONSTANTLY KNOCKING THE PLUG OUT THE WALL	1/16/14	1st Floor	NORTH HALL	Electrical
Bellevue MS (2040) 1A	replace broken and missing light cover shades/ need 12	3/31/14	1st Floor	hallways	Electrical
Bellevue MS (2040) 1A	POWER OUTAGE THRU ENTIRE BLDG PLANT MGR- HILL/826.8480	5/21/14			Electrical
Bellevue MS (2040) 1A	Yearly - Oil Samples- Bellevue Middle - Refer to PM schedule details.	9/2/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Chiller NOT COMING ON per Mr. Bell, Fill-in Plant Mgr. at 901.292.6530.	7/12/13			Heating/Ventilation /Air Conditioning

Bellevue MS (2040) 1A	CHILLER NOT COMING ON (049). SBE-HILL/416-4488	7/15/13				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	1/17/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	A/C UNIT is NOT COOLING in the MAIN OFFICE per Mr. Hill, Plant Mgr. 416.4488	5/28/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	2/14/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	clean cooling tour/I.D. 110-055	2/20/14	1st Floor	west main bldg		Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	2/28/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Bellevue Mid Lvl 2 WATER TRETMENTS - Refer to PM schedule details.	2/28/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Yearly - Rod Chiller - Bellevue Middle - Refer to PM schedule details.	3/3/14				Heating/Ventilation /Air Conditioning

Bellevue MS (2040) 1A	Yearly - Cooling Towers STRAINERS-Bellevue Middle - Refer to PM schedule details.	3/3/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Bellevue Mid Lvl 2 WATER TRETMENTS - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	CHILLER MECH RM- KEEPS SHUTTING DOWN-PLANT MGR HILL 416-4488 KLR	4/11/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	per mr hill 426-4488 chiller is down no air in entire bldg	4/14/14			Heating/Ventilation /Air Conditioning

Bellevue MS (2040) 1A	CHILLER - ON BUT IS BLOWING HOT AIR - PM/HILL 416-4488	4/21/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	CHILLER has SHUT DOWN per Cameron Hill, Plant Mgr. 416.4488	4/23/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	CHILLER MECH RM- HAS SHUT DOWN- PLANT MGR HILL 416-4488 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Bellevue Mid Lvl 2 WATER TRETMENTS - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Filter- Bellevue Middle - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Bellevue Mid Lvl 2 WATER TRETMENTS - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning

Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Repair Trane chiller. surge on start.	10/17/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	c/o to heat	10/23/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Yearly - Air Handler Cleanings-Bellevue Middle - Refer to PM schedule details.	11/5/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	BOILER NOT COMING ON PLANT MGR- HILL/416.4488	12/9/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	install temp boiler	12/10/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Bellevue Mid Lvl 2 WATER TRETMENTS - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Bellevue MS (2040) 1A	CLEAN COOLING TOWER/I.D.110-055	1/14/14	1st Floor	west MAIN BLDG	Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Filter-Bellevue Middle - Refer to PM schedule details.	1/5/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Yearly - Water-Cool Chiller Filter-Bellevue Middl - Refer to PM schedule details.	1/7/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	BOILER KEEPS SHUTTING OFF - HAS TO KEEP HITTING RESET & PM/HILL 416-4488	1/13/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Oil Lube & Belt-Bellevue Middle - Refer to PM schedule details.	1/14/14			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Monthly - Filter-Bellevue Middle - Refer to PM schedule details.	9/8/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	CHILLER NOT COMING ON- AFFECTS ENTIRE BLDG-PLANT MGR HILL 416-1466 KLR	10/15/13			Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Chiller is down no a/c in building per Cameron Hill 416-1466	10/16/13			Heating/Ventilation /Air Conditioning

Bellevue MS (2040) 1A	CHILLER - NOT COMING ON - PM/HILL 416-4488	5/5/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	per cameron hill 416-4488 chiller down	5/8/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	Daily - Bellevue Middle Level 1 Water Treatment - Refer to PM schedule details.	5/9/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	CHILLER IS NOT COMING ON - PM/HILL 416-4166	5/9/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	UNIT NOT COOLING IN MAIN OFFICE PLANT MGR-HILL/826.8480	5/9/14				Heating/Ventilation /Air Conditioning
Bellevue MS (2040) 1A	PAINT 2 -- 2 FEET SECTIONS/ AREA HAS BEEN REPAIR BY SHEET ROCK WORKER	2/6/14	2nd Floor	NORTH HALL		Painting
Bellevue MS (2040) 1A	PAINT 4 --- 2 FEET TO 3 FEET SECTIONS BADLY PEEL PAINT	2/6/14	1st Floor	NORTH HALL		Painting
Bellevue MS (2040) 1A	repair ceiling fallen plaster/large amount	8/8/13	Library	east ceiling		Painting

Bellevue MS (2040) 1A	plaster falling from ceiling	8/1/13	Library	east side	Painting
Bellevue MS (2040) 1A	REPAIR NORTH WALL/FALLING PLASTER	9/27/13	3rd Floor	301	Painting
Bellevue MS (2040) 1A	REPAIR NORTH WALL/FALLING PLASTER	9/27/13	3rd Floor	302	Painting
Bellevue MS (2040) 1A	plaster falling from ceiling	12/10/13	Auditorium	southside/window sill	Painting
Bellevue MS (2040) 1A	repair ceiling/plaster falling from ceiling on to windowsills north side	1/2/14	3rd Floor	302	Painting
Bellevue MS (2040) 1A	repair ceiling/falling plaster on to windowsill/north wall	1/2/14	3rd Floor	305	Painting
Bellevue MS (2040) 1A	repair falling plaster from north wall	1/14/14	3rd Floor	301	Painting
Bellevue MS (2040) 1A	repair fallen plaster from north wall	1/14/14	3rd Floor	302	Painting

Bellevue MS (2040) 1A	repair fallen plaster from north wall	1/14/14	3rd Floor	304	Painting
Bellevue MS (2040) 1A	repair falling plaster from east wall	1/14/14	3rd Floor	library	Painting
Bellevue MS (2040) 1A	repair plastering east wall	1/21/14	Auditorium	second floor	Painting
Bellevue MS (2040) 1A	repair large plaster hole in north wall	2/19/14	3rd Floor	lecture hall	Painting
Bellevue MS (2040) 1A	plaster falling into window sill/north wall	2/19/14	3rd Floor	lecture hall	Painting
Bellevue MS (2040) 1A	repair plaster falling into north window sill	2/19/14	3rd Floor	302	Painting
Bellevue MS (2040) 1A	repair plaster falling into north window sill	2/19/14	3rd Floor	303	Painting
Bellevue MS (2040) 1A	PLASTER FALLING FROM SOUTHWALL ONTO WINDOW SILLS IN TWO AREAS	2/5/14	2nd Floor	ISS AREA	Painting

Bellevue MS (2040) 1A	repair fallen plaster north window sill	3/31/14	3rd Floor	302	Painting
Bellevue MS (2040) 1A	repair fallen plaster north window sill	3/31/14	3rd Floor	304	Painting
Bellevue MS (2040) 1A	GRAFFITI NORTH-EAST OUTSIDE OF BLDG PLANT MGR-HILL/416.4488	10/18/13			Painting
Bellevue MS (2040) 1A	REPAIR EAST WALL/CEILING/FALLING PLASTER	9/27/13	Library	EAST SIDE	Painting
Bellevue MS (2040) 1A	plaster falling from west wall/window sill	12/10/13	2nd Floor	mens lounge	Painting
Bellevue MS (2040) 1A	repair fallen plaster from south wall	1/14/14	2nd Floor	auditorium	Painting
Bellevue MS (2040) 1A	repair west wall falling plaster onto windowsill	1/2/14	3rd Floor	men lounge	Painting
Bellevue MS (2040) 1A	GANG GRAFFITI B RR 3RD FLR ON HANDICAP STALL & G RR 2ND FLR ON HANDICAP STALL- PLANT MGR HILL 416-1466 KLR	1/3/14			Painting

Bellevue MS (2040) 1A	repair plaster falling from south wall	1/14/14	2nd Floor	MEN LOUNGE AREA	Painting
Bellevue MS (2040) 1A	REPAIR SOUTH WALL/FALLING PLASTER	9/27/13	2nd Floor	MEN LOUNGE AREA	Painting
Bellevue MS (2040) 1A	Paint wood trim to match	10/14/13			Painting
Bellevue MS (2040) 1A	FOURTH STALL BAD FLUSH VALVE WATER SHOOTING OUT FROM SIDE OF VALE	9/2/13	1st Floor	GIRLS RESTROOM	Plumbing
Bellevue MS (2040) 1A	install meter base and ct. d. hundle	7/25/13			Plumbing
Bellevue MS (2040) 1A	Repair underground sewer	7/25/13			Plumbing
Bellevue MS (2040) 1A	repair water main	7/29/13			Plumbing
Bellevue MS (2040) 1A	stopped up urinal/standing water	7/30/13	3rd Floor	boys restroom	Plumbing

Bellevue MS (2040) 1A	GAS LEAK IN KITC - PM/HILL 416-1466	7/31/13				Plumbing
Bellevue MS (2040) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/31/13				Plumbing
Bellevue MS (2040) 1A	Test and report on backflow prevention devices.	6/17/14				Plumbing
Bellevue MS (2040) 1A	unstop mop sink/standing water	5/28/14	Gym	lanudry room		Plumbing
Bellevue MS (2040) 1A	unstop mop sink/standing water	5/15/14	Gym	laundry room		Plumbing
Bellevue MS (2040) 1A	SEWAGE SMELL IN PRIN, MAIN, & STUDENT SERVICE OFFICES. PLANT MGR- HILL/416 4488	2/18/14				Plumbing
Bellevue MS (2040) 1A	STRONG TOXIC SMELL IN AREA	2/25/14	1st Floor	LAB		Plumbing
Bellevue MS (2040) 1A	STRONG TOXIC SMELL IN AREA	2/25/14	2nd Floor	BOYS RESTROOM		Plumbing

Bellevue MS (2040) 1A	WATER LEAK UNDERNEATH WASH SINK WATER PIPE	2/25/14	3rd Floor	BOYS RESTROOM	Plumbing
Bellevue MS (2040) 1A	REPAIR OR REPLACE SELF SHUT OFF FAUSCET CONSTANTLY RUNS WATER	2/25/14	3rd Floor	BOYS RESTROOM	Plumbing
Bellevue MS (2040) 1A	REPAIR OR REPLACE LEFT URINAL FLUSH VALE/LEAKS WATER WHEN FLUSH	2/25/14	2nd Floor	BOYS RESTROOM	Plumbing
Bellevue MS (2040) 1A	REPAIR OR REPLACE LEAKING FLUSH VALVE ON COMMODE /FOURTH STALL	2/25/14	1st Floor	BOYS RESTROOM	Plumbing
Bellevue MS (2040) 1A	REPAIR OR REPLACE LEAKING WATER FAUSCET ON WASH SINK	2/25/14	Gym	BOYS RESTROOM NW	Plumbing
Bellevue MS (2040) 1A	per mr hill 416-1466 strong sewage smell in main office, principal's office, student services	3/6/14			Plumbing
Bellevue MS (2040) 1A	repair or replace wash sink pipe drain leaking water	3/6/14	3rd Floor	boys restroom	Plumbing
Bellevue MS (2040) 1A	repair or replace urinal drain pipe onto second floor	3/6/14	3rd Floor	boys restroom	Plumbing

Bellevue MS (2040) 1A	3-COM SINK WATER CONTINUES TO RUN IN KITCHEN. PLANT MGR-HILL/416.4488	3/19/14			Plumbing
Bellevue MS (2040) 1A	can not unstop commode	3/22/14	Gym	boys locker room	Plumbing
Bellevue MS (2040) 1A	water pressure not coming up/cannot recieve drinking water	3/25/14	1st Floor	hall east by home ecom.	Plumbing
Bellevue MS (2040) 1A	un stop urinal standing water will not drain out	3/26/14	3rd Floor	boys restroom	Plumbing
Bellevue MS (2040) 1A	BUSTED PIPE IN B/RR 2ND FLR. PLANT MGR-HILL/416.4488	3/27/14			Plumbing
Bellevue MS (2040) 1A	WATER PIPE LEAKING WATER ON TILE FLOORS	4/2/14	2nd Floor	BOYS RESTROOM	Plumbing
Bellevue MS (2040) 1A	WATER COOLER LEAKING WATER AROUND BASE	4/4/14	2nd Floor	HALL BY ROOM 206	Plumbing
Bellevue MS (2040) 1A	repair or replace self cutoff knobs over wash sinks/water constantly runs	4/7/14	2nd Floor	boys restroom	Plumbing

Bellevue MS (2040) 1A	repair or replace broken water spout on water fountain caution sharp edges expose	4/16/14	3rd Floor	south hall	Plumbing
Bellevue MS (2040) 1A	repair or replace water leaking pipe on water fountain red bucket is containing	4/22/14	2nd Floor	east hall by room 206	Plumbing
Bellevue MS (2040) 1A	repair or replace leaking water pipe from water fountain on tile floors	4/25/14	2nd Floor	east hall by 206	Plumbing
Bellevue MS (2040) 1A	science lab sink stopped up/water will not drain out	10/28/13	2nd Floor	202	Plumbing
Bellevue MS (2040) 1A	mop sink shooting water out of both sides of top neck of faucet when on	10/31/13	Kitchen	kitchen	Plumbing
Bellevue MS (2040) 1A	Test and report on backflow prevention devices.	12/19/13			Plumbing
Bellevue MS (2040) 1A	REPAIR OR REPLACE BAD FLUSH VALVE/LEAKING WATER ON TILE FLOOR WHEN FLUSH	11/8/13	1st Floor	SOUTH/EAST RESTROOM	Plumbing
Bellevue MS (2040) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13			Plumbing

Bellevue MS (2040) 1A	HOOK UP NEW FOUR BURNER RANGE/ALREADY AT THE SCHOOL/ I.D#565802	12/4/13	Kitchen	kitchen	Plumbing
Bellevue MS (2040) 1A	bad flush valve commode leaking water on tile floors/first stall	12/6/13	3rd Floor	girls restroom	Plumbing
Bellevue MS (2040) 1A	broken commode seat/ fourth stall	12/6/13	3rd Floor	boys restroom	Plumbing
Bellevue MS (2040) 1A	bad flush valve commode/leaking water on tile floors/third stall	12/6/13	1st Floor	girl restroom	Plumbing
Bellevue MS (2040) 1A	2-COMPARTMENT SINK KITCHEN AREA- FAUCET HAS BROKEN ON IT-CAN'T USE, WILL NEED- PLANT MGR HILL 416-4488 KLR	1/22/14			Plumbing
Bellevue MS (2040) 1A	water cooler leaking water on tile floors/water come from the body fame of cooler I.D. # 100-100	1/23/14	1st Floor	hall east	Plumbing
Bellevue MS (2040) 1A	SEWAGE SMELL IN KITCHEN PLANT MGR- HILL/416.4488	1/29/14			Plumbing
Bellevue MS (2040) 1A	STRONG SEWER GAS SMELL COMING FROM 2ND FLR B RR- PLANT MGR HILL 416-1466 KLR	1/30/14			Plumbing

Bellevue MS (2040) 1A	REPAIR OR REPLACE LEAKING FLUSH VALVE/THIRD COMMODE	1/14/14	3rd Floor	GIRLS RESTROOM	Plumbing
Bellevue MS (2040) 1A	water pipe leaking under wash sink/on tile floors constantly/cannot contain	1/15/14	3rd Floor	girls restroom	Plumbing
Bellevue MS (2040) 1A	STOPPED UP URINAL /STANDING URINE/BAD SMELL SECOND REQUEST	8/7/13	3rd Floor	boys restroom	Plumbing
Bellevue MS (2040) 1A	wash sink water constantly running/need washer rings	9/11/13	1st Floor	science lab	Plumbing
Bellevue MS (2040) 1A	standing water in mop sink	9/11/13	Gym	equitment room	Plumbing
Bellevue MS (2040) 1A	commode stopped up cannot unstop	9/13/13	2nd Floor	girls restroom	Plumbing
Bellevue MS (2040) 1A	three lab sinks shooting water out of the top	9/13/13	1st Floor	lab	Plumbing
Bellevue MS (2040) 1A	water fountain stopped up/ I.D. 110043	9/16/13	2nd Floor	by student services	Plumbing

Bellevue MS (2040) 1A	replace or repair bad flush valva/not flushing waste completely out	10/11/13	Gym	boys locker room	Plumbing
Bellevue MS (2040) 1A	FCU 2ND FLR RM 204-LEAKING-SBE HILL 416-1466 KLR	8/8/13			Plumbing
Bellevue MS (2040) 1A	water cooler leaking water from base area I.D.110-057	8/14/13	Cafeteria	northside	Plumbing
Bellevue MS (2040) 1A	repair or replace comode flush valve/when flush water shoots out the side of the valve to the floors	8/21/13	2nd Floor	girls restroom	Plumbing
Bellevue MS (2040) 1A	REPAIR OR REPLACE SELF CUT OFF FAUSCET/WATER CONSTANTLY RUNNING	5/7/14	2nd Floor	BOYS RESTROOM	Plumbing
Bellevue MS (2040) 1A	REPLACE PRV ON MAKEUP WATER	5/9/14			Plumbing
Bellevue MS (2040) 1A	roof leaking on tile floors/ three different areas	6/12/14	1st Floor	106	Roof
Bellevue MS (2040) 1A	WATER LEAK FROM ROOF IN TWO AREAS ON TILE FLOORS	5/27/14	2nd Floor	PLANT MANAGER OFFICE	Roof

Bellevue MS (2040) 1A	ROOF LEAK	4/4/14	Gym	RECREATION WEST	Roof
Bellevue MS (2040) 1A	ROOF LEAKING IN GYM ON HARDWOOD FLOOR-PLANT MGR HILL 416-4488 KLR	4/14/14			Roof
Bellevue MS (2040) 1A	ROOF GYM AREA-LEAKING ON HARDWOOD FLR-PLANT MGR HILL 416-4488 KLR	4/28/14			Roof
Bellevue MS (2040) 1A	Roof leak in the gym per Cameron Hill, Plant Mgr. at 901.416.4488.	8/6/13			Roof
Bellevue MS (2040) 1A	ROOF LEAKING ON HARDWOOD FLRS IN GYM PER SBE-SBE HILL 416-1466 KLR	8/13/13			Roof
Bellevue MS (2040) 1A	bad door latches/cannot secure lockers 1108 and 1116	5/22/14	1st Floor	north hall	Sheet Metal
Bellevue MS (2040) 1A	locker 2196 cannot open/pencil stuck in door/student personals inside	5/12/14	2nd Floor	north hall by 203	Sheet Metal
Bellevue MS (2040) 1A	BAD LOCKER LATCHES LOCKER # 2135, 2140, 2125	2/6/14	2nd Floor	NORTH HALL	Sheet Metal

Bellevue MS (2040) 1A	LOCKER # 2087 CAN NOT SECURE LOCKER	2/6/14	2nd Floor	NORTH HALL	Sheet Metal
Bellevue MS (2040) 1A	locker #3073 cannot secure/bad door latch/repair or replace	2/18/14	3rd Floor	east hall	Sheet Metal
Bellevue MS (2040) 1A	CANNOT UNLOCK LOCKER #3131 STUDENT BOOK STUCK IN DOOR CRACK OF LOCKER	3/17/14	3rd Floor	EAST HALL	Sheet Metal
Bellevue MS (2040) 1A	locker 2089 door jam locked/student books inside/cannot open	4/29/14	2nd Floor	north hall	Sheet Metal
Bellevue MS (2040) 1A	locker 3135 bad door latch very hard to shut door	5/12/14	3rd Floor	east hall	Sheet Metal
Bellevue MS (2040) 1A	can not secure locker 3143/door off set and bad door latch	9/18/13	3rd Floor	east hall	Sheet Metal
Bellevue MS (2040) 1A	locker # 2208 cannot secure missing door latch	10/4/13	2nd Floor	noth hall	Sheet Metal
Bellevue MS (2040) 1A	locker # 2060, 2094 and 2093/ cannot secure bad door latches	10/4/13	2nd Floor	north hall	Sheet Metal

Bellevue MS (2040) 1A	lockers damage bad door latches numbers 2264, 2276, 3009 and 3011	8/23/13	2nd Floor	hall east	Sheet Metal
-----------------------	---	---------	-----------	-----------	-------------

Count of Craft	Craft										
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Bolton HS (0035)		3	2	154	325	105	17	157	43	23	829
Grand Total		3	2	154	325	105	17	157	43	23	829

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Bolton HS (0035)	please refinish the gym floor, floor is starting to flake and needs refinish for the upcoming basketball season	9/18/13	Gym		Asbestos
Bolton HS (0035)	if possible i need the gym floor resealed on oct 11 2013	9/18/13	Gym	varsity gym	Asbestos
Bolton HS (0035)	repair/replace threshold in hall by plant managers office	7/3/13	Hallway/Corridor	main building	Asbestos
Bolton HS (0035)	please check the internet cable in cafeteria serving line keeps disconnecting	2/6/14			Cabling
Bolton HS (0035)	if possible in m212 college and career center needs a telephone installed will need to be wired for phone jack .see mr. stevens for questions and answers. we are	10/25/13	Classroom	main bldg2nd floor	Cabling
Bolton HS (0035)	if possible we need 19 bundles of ceiling tiles 10291A	6/10/14		plant manager office	Carpentry
Bolton HS (0035)	please patch the hole on wall of cafeteria just as you enter on the left . there is some wire sticking out that some one could get hurt on	5/30/14	Cafeteria	cafeteria	Carpentry

Bolton HS (0035)	please repair the hole in wood colum at serving line in cafeteria	5/30/14	Cafeteria	serving line	Carpentry
Bolton HS (0035)	please repair the door knob to classroom s221 broken	1/23/14	Classroom	south221	Carpentry
Bolton HS (0035)	please patch the hole in sheet rock wall in east 241	5/30/14	Classroom	east 241	Carpentry
Bolton HS (0035)	the sheet rock outside the study hall needs to be repair it is peeling off and starting to look terrible	3/28/14		south building	Carpentry
Bolton HS (0035)	there are several baseboard in hall south 2nd floor that are loose from wall need to be reguled	3/31/14			Carpentry
Bolton HS (0035)	please repair the floor tile in home economic 1 loose from floor could be a tripping hazzard	3/31/14	Classroom	home economic 1	Carpentry
Bolton HS (0035)	please repair or replace missing floor tile in cosmostlogy back of room	4/2/14	Classroom	votech cosmostlogy	Carpentry
Bolton HS (0035)	there are several floor tile loose and some are broken in home econ#1	4/2/14	Classroom	home economic 1	Carpentry

Bolton HS (0035)	please replace window in cosmostlogy broken	4/2/14	Classroom	votech cosmostlogy	Carpentry
Bolton HS (0035)	the stairway in east building is torn and needs to be repair before someone trips . there are 2 places	4/2/14	Stairway	east building	Carpentry
Bolton HS (0035)	water is leaking from window catwalk needs to be recauked	4/4/14	2nd Floor	cat walk east building	Carpentry
Bolton HS (0035)	please repair the entrance door main building by cafeteria exiting out to main courtyard broken it still does not close all the way .	4/14/14	Hallway/Corridor	main building	Carpentry
Bolton HS (0035)	please repair the entrance /exit door votech will not close all the way and hard to unlock in morning	4/14/14	1st Floor	votech	Carpentry
Bolton HS (0035)	please repair the door to main hall by m109 will not close you have to push it hard to close it	4/23/14	Hallway/Corridor	main bldg 1st floor	Carpentry
Bolton HS (0035)	please repair the lock to restroom door in attendance office broken	4/23/14	Administration Area	attendance office	Carpentry
Bolton HS (0035)	in the old gym there are 2 broken windows that need to be replaced.	5/7/14	Gym	old gym	Carpentry

Bolton HS (0035)	please replace the broken window lobby of varsity gym entrance door	5/7/14	Gym	varsity gym lobby	Carpentry
Bolton HS (0035)	please repair the door closer to entrance door main by m109 broken	5/12/14	Hallway/Corridor	main bldg 1st floor	Carpentry
Bolton HS (0035)	please repair the cylinder to entrance door main breezeway broken about to fall out	5/19/14	Hallway/Corridor	main bldg 1st floor	Carpentry
Bolton HS (0035)	please repair the door to study hall will not lock broken	1/23/14	Classroom	study hall	Carpentry
Bolton HS (0035)	please repair the fence to softball field next to gate boken	6/20/14	Athletic Field	softball field	Carpentry
Bolton HS (0035)	if possible i need 3 bundles of ceiling tiles2910A	1/22/14		plant manager office	Carpentry
Bolton HS (0035)	please repair the entrance /exit door north 2nd floor going out to bird cage broken will not latch	1/22/14	Hallway/Corridor	north building2nd floor	Carpentry
Bolton HS (0035)	if possible i need a section of ceiling grid replaced in the old gym . i cant get my tile in without that section	1/9/14	Gym	pe gym/old gym	Carpentry

Bolton HS (0035)	pleas repair the entrance door main building dec office very hard to close it sticks	1/9/14	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	please repair the rool bar to door in old gym once the door is closed you cannot open	8/9/13	Auxiliary Gym	old gym	Carpentry
Bolton HS (0035)	room 100 main building needs a white board	8/9/13	Classroom	room 100	Carpentry
Bolton HS (0035)	north 122 needs a white board for his room	8/9/13	Classroom	north 122	Carpentry
Bolton HS (0035)	the roll bar to cafeteria going out to hall main building is broken and missing the end cap	8/9/13	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	in the south stairs an north stair i have some ceiling tiles missing . i can not reach them with my 8 ft ladder	8/9/13	Hallway/Corridor	south &north	Carpentry
Bolton HS (0035)	the end cap to roll bar is missing freshman locker room	8/12/13	Gym	varsity gym	Carpentry
Bolton HS (0035)	the roll bar is missing from door exiting from theatre to gym lobby	8/12/13	Hallway/Corridor	theatre	Carpentry

Bolton HS (0035)	please patch the hole in door to room m100	8/13/13	Classroom	m100	Carpentry
Bolton HS (0035)	i need a couple bundles of ceiling tile the numbers are 769A CORTEGA SQUARE LAY IN and 2910ARANDOM FISSURED DEFEATED	8/14/13		plant manager office	Carpentry
Bolton HS (0035)	in the north building and east building the push bar are missing the plastic covers see me for questions	8/15/13	Hallway/Corridor	north building east build	Carpentry
Bolton HS (0035)	please repair the handel to votech building keeps falling off	8/15/13	Hallway/Corridor	votech building	Carpentry
Bolton HS (0035)	the cafeteria door is broken again i have to use the chain to secure it	8/15/13		cafeteria	Carpentry
Bolton HS (0035)	please repair the push bar to entrance door north at stairs across from 129 broken will not bar down all the way	8/19/13	Hallway/Corridor	north building	Carpentry
Bolton HS (0035)	if possible i need 5 bundles of ceiling tile 769A	8/19/13	Custodial	plant manager office	Carpentry
Bolton HS (0035)	please repair entrance door main south west by room 99 does not close	8/21/13	Hallway/Corridor	main bldg	Carpentry

Bolton HS (0035)	the treshold is missing from door in main bldg by 99	8/21/13	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	the door to votech building does not close you have to push it to close it	8/21/13	Hallway/Corridor	votech building	Carpentry
Bolton HS (0035)	please repair the knotted tile in north and east stairs it is ripped and some one could get hurt see me for areas and questions	8/22/13	Stairway	north building east build	Carpentry
Bolton HS (0035)	in the cafeteria i have several stained and nasty ceiling tile i cannot reach these with my 6 ft ladder please advise	8/22/13	Cafeteria	cafeteria	Carpentry
Bolton HS (0035)	please repair the counter top in boys restroom east building 2nd floor broken	8/23/13	Restroom (Boys)	east building	Carpentry
Bolton HS (0035)	please repair the steps to portable (8) 139 behind cafeteria one is broken	8/29/13	Portables	portable139(8)	Carpentry
Bolton HS (0035)	please repair the rope on flag pole baseball field the rope is broken	8/29/13	Athletic Field	baseball field	Carpentry
Bolton HS (0035)	in sped hall main building i have ceiling tile that need to be replace i can not reach them	9/9/13	Hallway/Corridor	sped hall main bldg	Carpentry

Bolton HS (0035)	please repair the door to cosmostlogy votech building very hard to open and close	9/11/13	Classroom	cosmostlogy	Carpentry
Bolton HS (0035)	please repair the counter top in boys lockerroom freshman varsity broken	9/12/13	Gym	varsity gym	Carpentry
Bolton HS (0035)	please repair the lock to door north 229 the lock will lock but you can still pull the door open . she cannot secure the classroom	9/18/13	Classroom	north building 2nd 229	Carpentry
Bolton HS (0035)	please repair the door handle to door bottom of stairs main building south west stairs broken	9/19/13	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	need two black boards moved from portable 5 to north 125 see me for questions	1/2/14	Portables	all portables	Carpentry
Bolton HS (0035)	Cut holes in gym floor for electricians	1/8/14			Carpentry
Bolton HS (0035)	we have 3 rooms in votech that need the tile replace 1 is home economic 1 home economic 2 and storage room this was caused due to the roof leak we had that is new	8/5/13	Classroom	votech home economic 1	Carpentry
Bolton HS (0035)	there are two doors varsity gym entrance that will not close i think the hinges is broken	11/21/13	Gym	varsity gym	Carpentry

Bolton HS (0035)	please repair the door going from old gym to the north building will not latch	1/13/14	Gym	old gym	Carpentry
Bolton HS (0035)	i have a ceiling tile missing in stairs main building by m200 i can not reach and there a couple that are stained that need to be replaced i can not reach them either	1/13/14	Stairway	main bldg	Carpentry
Bolton HS (0035)	please repair the door handal to twa north building 2nd floor broken	1/15/14		north building	Carpentry
Bolton HS (0035)	please repair the hand rail to stairs in theatre stage right broken loose from wall	1/16/14	Auditorium	auditorum	Carpentry
Bolton HS (0035)	please repair the hand rail in auditorium stage left if you are standing on stage	11/21/13	Auditorium	auditorum	Carpentry
Bolton HS (0035)	please repair or replace the counter top boys restroom east 2nd floor broken	11/22/13	Restroom (Boys)	east building 2ndfloor	Carpentry
Bolton HS (0035)	please repair the roll down bar to exit door drama room 1 broken	11/22/13	Classroom	drama room1	Carpentry
Bolton HS (0035)	please repair the push bar to entrance door main bym100 south west very hard to lock does not roll out . hard to secure the building	11/25/13	Hallway/Corridor	m100	Carpentry

Bolton HS (0035)	if possible i need the large bulletin board moved from votech entrance hall to hall outside home economic1 please see me for questions	11/26/13	Hallway/Corridor	votech building	Carpentry
Bolton HS (0035)	please repair the hand rail in theatre lobby is loose from the wall	12/4/13	Auditorium	theatre lobby	Carpentry
Bolton HS (0035)	in main building stairwell i have a couple of bad ceiling tile i need to replace but i can not reach them .	12/4/13	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	please replace the wooden door frames to back door inside of portable 139 it is just falling off and breaking off	12/4/13	Portables	portable139	Carpentry
Bolton HS (0035)	if possible i need a couple bundles of ceiling tiles 2910A	12/4/13		plant manager office	Carpentry
Bolton HS (0035)	please repair the push bar to entrance doors main building by sped office broken	12/4/13	Hallway/Corridor	sped hall main bldg	Carpentry
Bolton HS (0035)	please mount the defibrillator to wall old gym lobby	12/4/13	Hallway/Corridor	old gym	Carpentry
Bolton HS (0035)	push bar to outside door drama room 1 is broken can not secure this door we have it lock but the 1st time she goes out that door it ont lock bqck	12/16/13	Classroom	main bldg	Carpentry

Bolton HS (0035)	please repair the lock to restroom door custodial lounge will not lock.	1/27/14	Restroom (Boys)	custodial lounge	Carpentry
Bolton HS (0035)	please replace the broken window to varsity gym entrance door broken	1/30/14	Gym	varsity gym lobby	Carpentry
Bolton HS (0035)	please replace the broken window entrance door to study hall south building 2nd floor	1/30/14	Classroom	study hall	Carpentry
Bolton HS (0035)	please replace the broken and damaged floor tile in catwalk	1/30/14	Hallway/Corridor	cat walk east building	Carpentry
Bolton HS (0035)	please replaced the window in study hall some one kicked it out this morning .will need to know the cost of window	2/3/14	Classroom	study hall	Carpentry
Bolton HS (0035)	please repair the latch to classroom door north 124 broken. can not close the door	2/5/14	Classroom	north 124	Carpentry
Bolton HS (0035)	please repair the door knob to room s221 broken	2/10/14	Classroom	south 221	Carpentry
Bolton HS (0035)	if possible i need 2 bundles of ceiling tile 769A	2/11/14		plant manager office	Carpentry

Bolton HS (0035)	please repair the door latch to n124 broken if you close the door you will be locked out	2/12/14	Classroom	north 124	Carpentry
Bolton HS (0035)	please replace the broken and missing tiles south building 1st floor stairs	2/12/14	Hallway/Corridor	south building	Carpentry
Bolton HS (0035)	please broken window in wrestling locker room old gym	2/19/14	Gym	old gym	Carpentry
Bolton HS (0035)	please repair the ceiling grid in hall way votech medizinne broken also i have some ceiling tile that need to be replace please see me for questions	2/19/14	Hallway/Corridor	votech medizinne	Carpentry
Bolton HS (0035)	i have a couple of ceiling grids that are damaged and need to be replaced . i can not keep the ceiling tile in place .	2/19/14	Auditorium	auditorum lobby	Carpentry
Bolton HS (0035)	please replace the broken and missing floor tile in throphy hall varsity gym	2/19/14	Gym	varsity gym lobby	Carpentry
Bolton HS (0035)	please repair the door latch to exit door from north to main broken will not close	2/21/14	Hallway/Corridor	north building 2ndfloor	Carpentry
Bolton HS (0035)	please repair the long strip that keeps you from slipping on stairs one is broken behind varsity gym north west heading to boys coaches office . i am worried that someone	2/24/14	Gym	varsity gym	Carpentry

Bolton HS (0035)	please repair the entrance door broken hard to close	2/24/14	Cafeteria	cafeteria	Carpentry
Bolton HS (0035)	if possible before the drama production thursday the door on the left leading into the theatre dosen't lock right . the handle locks but you can pulled the door open	2/26/14	Auditorium	theatre	Carpentry
Bolton HS (0035)	please repair the broken door knob to green house	2/26/14		green house	Carpentry
Bolton HS (0035)	if possible i need 4 bundles of ceiling tile (29108)	3/18/14		plant manager office	Carpentry
Bolton HS (0035)	Install countertop	3/25/14			Carpentry
Bolton HS (0035)	please repair the broken glass to room m108 broken	3/26/14	Classroom	m108	Carpentry
Bolton HS (0035)	please repair the stair tread in stairs south building is torn some one could get hurt	3/26/14	Stairway	south building	Carpentry
Bolton HS (0035)	please repair the latch to the doors main building 2nd floor to north building the bird cage it is broken .	10/31/13	Hallway/Corridor	main hall-north bldg	Carpentry

Bolton HS (0035)	if possible in the varsity gym there is a place on the ceiling that needs to be patch and painted before basketball season . it my understanding that the roof leak is fixed as if	11/1/13	Gym	varsity gym	Carpentry
Bolton HS (0035)	Remove and replace counter-tops in room 212	11/4/13			Carpentry
Bolton HS (0035)	please replace the knotted stair tread in east building stairs has come loose and has a tear in it	11/7/13	Hallway/Corridor	east building	Carpentry
Bolton HS (0035)	please repair the latch to door varsity gym lobby in handi cap ramp old gym will not stay latched	11/7/13	Gym	varsity gym	Carpentry
Bolton HS (0035)	please repair or replace the floor tile south hall 2nd floor cracked	11/7/13	Hallway/Corridor	south building	Carpentry
Bolton HS (0035)	please repair the cable to flag pole .it is broken from the strong winds	11/12/13		flag pole	Carpentry
Bolton HS (0035)	please repair the door knob to door m100 broken	11/13/13	Classroom	m100	Carpentry
Bolton HS (0035)	please repair the door closer to kitchen door broken i could fix but i don't have the screws it is the screws that are broken	11/18/13	Cafeteria	kitchen	Carpentry

Bolton HS (0035)	please repair the stair tread to the stairs in north building they are comming loose and some have already fell off .please see me	11/19/13	Hallway/Corridor	north building	Carpentry
Bolton HS (0035)	please repair the door closer to entrance from breezeway it is broken	11/19/13	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	please move the chalk boards from north 126 to n125 and replace chalk boards in n126 with white boards please see me for questions	11/20/13	Classroom	north building 126	Carpentry
Bolton HS (0035)	the stair tread in south stairs is loose from stairs and starting to tear	11/20/13	Hallway/Corridor	south stairs	Carpentry
Bolton HS (0035)	please repair the counter top in boys restroom north 1st floor it is broken	11/20/13	Restroom (Boys)	north building	Carpentry
Bolton HS (0035)	Build and install Formica counters for new wash basins to replace all Bradley type wash basins throughout the school	7/16/13			Carpentry
Bolton HS (0035)	Request for glass in new door	7/16/13			Carpentry
Bolton HS (0035)	repair broken glass in room M107	7/16/13			Carpentry

Bolton HS (0035)	please repair double doors in old gym, will not close	7/22/13			Carpentry
Bolton HS (0035)	please repair the entrance exit doors main building will not close you have to push it hard for it to lock	7/22/13			Carpentry
Bolton HS (0035)	please patch the hole in the Sheetrock wall east 241	7/23/13			Carpentry
Bolton HS (0035)	Install door in plant managers office	7/23/13			Carpentry
Bolton HS (0035)	please repair the roll down bar to entrance door main by room 100 south west	7/25/13	Hallway/Corridor	main building	Carpentry
Bolton HS (0035)	please repair the roll down bar north building very hard to lock	7/26/13	Hallway/Corridor	north building	Carpentry
Bolton HS (0035)	please repair the roll down bar to hall way door main 1st floor by plant managers office broken	7/26/13	Hallway/Corridor	main building	Carpentry
Bolton HS (0035)	please repair the roll bar in main hall by m101 the bar is broken	7/31/13	Hallway/Corridor	main building 1st	Carpentry

Bolton HS (0035)	home economic 1 in votech building needs a tack board in her room	7/31/13	Classroom	votech home economic 1	Carpentry
Bolton HS (0035)	please repair the entrance door to cafeteria .this door will not lock we have to use a chain to secure at night	8/6/13	Cafeteria	cafeteria	Carpentry
Bolton HS (0035)	need the white board mounted in m 100	8/7/13	Classroom	m100	Carpentry
Bolton HS (0035)	please repair the hand rail in south hall 2nd floor broken has pulled lose from wall	8/7/13	Hallway/Corridor	south building 2nd fl	Carpentry
Bolton HS (0035)	please repair the roll bar to entrance door main bldg very hard to roll down	8/7/13	Hallway/Corridor	main bldg	Carpentry
Bolton HS (0035)	need a roll down screen mounted i drama room2 please see me	8/8/13	Classroom	drama room	Carpentry
Bolton HS (0035)	please repair the door handal to restroom in girls locker room varsity gym broken	9/24/13	Gym	varsity gym	Carpentry
Bolton HS (0035)	please replace 3 stained windows on cat walk.	9/24/13	Hallway/Corridor	cat walk east	Carpentry

Bolton HS (0035)	please reseal around the glass window of catwalk they were leaking during the rain this morning	9/24/13	Hallway/Corridor	cat walk east	Carpentry
Bolton HS (0035)	please repair the doors east building 2nd floor cat walk . the doors do not close when we have a fire drill .	9/24/13	Hallway/Corridor	cat walk east	Carpentry
Bolton HS (0035)	please patch the hole in wall portable (139) behind cafeteria	9/25/13	Portables	portable139(8)	Carpentry
Bolton HS (0035)	please repair the wooden door frames to door in portable (139) behind cafeteria is starting to get old and breaking off . it will be hard to secured if frames not repaired	9/25/13	Portables	portable139(8)	Carpentry
Bolton HS (0035)	please repair or replace the skirt around portable 076 the wind keeps blowing them off	9/26/13	Portables	portable076	Carpentry
Bolton HS (0035)	north 125 needs 2 chalkboards	9/27/13	Classroom	north building 1st floor 125	Carpentry
Bolton HS (0035)	please repair the lock to north 231 very hard to unlock some one has broken something off in the door lock. KEY HAS BEEN BROKEN OFF IN LOCK AND	9/30/13	Classroom	north 233	Carpentry
Bolton HS (0035)	please repair door to south 117 the hinge keeps coming loose i tried to tighten it but after a few days it becomes loose again	10/1/13	Classroom	south building	Carpentry

Bolton HS (0035)	the stairs in north building knotted tread is loose and missing from stairs	10/1/13	Hallway/Corridor	north building	Carpentry
Bolton HS (0035)	please repair the lock /handal to boy restroom it just keeps spinning around	10/1/13	Restroom (Boys)	main bldg	Carpentry
Bolton HS (0035)	please repair the entrance door to votech the latch is broken causing thr door not to open very wide	10/1/13		votech building	Carpentry
Bolton HS (0035)	please replace the knotted floor thread to stairs in north building has come loose from stairs some one could get hurt	10/3/13	Stairway	north building	Carpentry
Bolton HS (0035)	please repair the wooden window ledge south building 2nd floor is broken	10/3/13	Hallway/Corridor	south building	Carpentry
Bolton HS (0035)	please repair the door by room 110 very hard to open and close	10/12/13	Hallway/Corridor	south building	Carpentry
Bolton HS (0035)	please repair the cylinder to double doors south entrance by room 118 not working	10/14/13	Hallway/Corridor	south building	Carpentry
Bolton HS (0035)	please repair the door to classroom south 117 still not closing broken	10/15/13	Classroom	south building 117	Carpentry

Bolton HS (0035)	please repair the wood gate to baseball field broken	10/18/13	Athletic Field	baseball field	Carpentry
Bolton HS (0035)	please replace the handal to greenhouse it is broken	10/18/13		green house	Carpentry
Bolton HS (0035)	please patch the hole in sheet rock in south 220	10/18/13	Classroom	south220	Carpentry
Bolton HS (0035)	please repair the entrance door to votech . they are hard to close and sometimes the latch does not catch which means it hard to secure these doors	10/25/13	Hallway/Corridor	votech building	Carpentry
Bolton HS (0035)	if possible i need several door latches for the stall boys for boys and girls restroom . some students are complaining that they can not lock the stall door when they are in	9/4/13	Restroom (Boys)	all areas	Carpentry
Bolton HS (0035)	out side the cafeteria south west the sheetrock is missing this looks really bad .i ask several times for this to be repaired please see me for questions BOGEMAN	9/4/13	Cafeteria	out cafeteria	Carpentry
Bolton HS (0035)	sorry ticket 368919 please viold	7/30/13	1st Floor	112	Carpentry
Bolton HS (0035)	if possible we have 225 plaques we need mounted in varsity gym lobby . please see me for questions	1/8/14	Gym	varsity gym lobby	Carpentry

Bolton HS (0035)	please replace the ballast to light in east 142 bad	4/3/14	Classroom	east 142	Electrical
Bolton HS (0035)	please check the breaker to lights in football field house keeps tripping will not reset	4/4/14		football field house	Electrical
Bolton HS (0035)	please replace ballast to light in kitchen bad	4/7/14	Kitchen	kitchen	Electrical
Bolton HS (0035)	please replace the ballast to light in main hall front of cafeteria bad	4/14/14	1st Floor	main building	Electrical
Bolton HS (0035)	we need the intercom portable 2(120) 3-(149) 7 (175) checked	4/21/14	Portables	portable120&149 175	Electrical
Bolton HS (0035)	wall pack light out north building north drive	4/24/14		north drive	Electrical
Bolton HS (0035)	fire alarm trouble smoke(photo) 1st floor door @room 111south building dirty 1D045	4/28/14	Hallway/Corridor	south bldg1st	Electrical
Bolton HS (0035)	please repair the electrical outlet in twa south 1st floor not working not the breaker i checked	4/28/14		twa south building	Electrical

Bolton HS (0035)	please repair the light switch north building by 129 broken	4/28/14	1st Floor	north building	Electrical
Bolton HS (0035)	please repair the light in girls restroom football concession coming loose from ceiling	4/30/14	Athletic Field	football concession restrooms	Electrical
Bolton HS (0035)	fire alarm trouble trouble control FCPS trigger open 2M118	5/5/14	Administration Area	main bldg	Electrical
Bolton HS (0035)	Ballast needs replacing in light in kitchen.	5/6/14	Cafeteria		Electrical
Bolton HS (0035)	door magnet broken north stairs 2nd floor by 236	5/9/14	Stairway	north2nd floor	Electrical
Bolton HS (0035)	please repair the door magnet to door in north building 1st floor stairs across from n129 broken	5/14/14	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	please repair the ballast to light outside varsity gym just before you enter gym bad	5/19/14	Gym	varsity gym	Electrical
Bolton HS (0035)	replace two ballast to lights in guidance storage room east building 2nd floorbad	5/20/14		guidance storage	Electrical

Bolton HS (0035)	please replace the ballast to light in hall south building 2nd floor by study hall bad	5/20/14	Hallway/Corridor	south building 2nd floor	Electrical
Bolton HS (0035)	fire alarm trouble smoke (photo) 1st floor NE stairs door north building test F 2D005	6/9/14	1st Floor	north building	Electrical
Bolton HS (0035)	motor burning smell in m202 strong	6/30/14	Classroom	m202	Electrical
Bolton HS (0035)	please check fred patrick code to alarm system his does not work	1/23/14		plant manager	Electrical
Bolton HS (0035)	door magnet to door in hall north building 1st floor broken . if possible could it be made s little longer .	1/23/14	Hallway/Corridor	north 1st floor	Electrical
Bolton HS (0035)	e are replacing the old projector in theatre we will need to have bill to disconnect and reconnect the power please refer back to ticket number392683 for reference thank you	1/23/14	Auditorium	theatre	Electrical
Bolton HS (0035)	please check the microphone jack varsity gym north side not working will need this for regional basketball tournament	1/23/14	Gym	varsity gym	Electrical
Bolton HS (0035)	if possible i need 6 lens cover for the cafeteria they are 22&78 x44.5	1/24/14	Cafeteria	cafeteria	Electrical

Bolton HS (0035)	please replace the ballast to lights in guidance storage bad please see me for area	5/30/14		guidance storage	Electrical
Bolton HS (0035)	fire alarm trouble greenhouse pull station bad	6/18/14		green house	Electrical
Bolton HS (0035)	please check the power to sprinkler on football practice field not working	6/19/14	Athletic Field	football practice field	Electrical
Bolton HS (0035)	fire alarm trouble (trouble control) strobes open 1M124	6/24/14	Administration Area	main bldg	Electrical
Bolton HS (0035)	fire alarm trouble	6/26/14	Administration Area	main bldg	Electrical
Bolton HS (0035)	fire alarm trouble smoke(photo) main north exit speed office dirty 1D028	1/22/14	Hallway/Corridor	main bldg 1st floor	Electrical
Bolton HS (0035)	please check alarm all 3 keypads read transmitt trouble	1/22/14	Administration Area	all areas	Electrical
Bolton HS (0035)	if possible i need these blubs they go to the lights in breezeway (12 each) they are WESFB-32t8741ECO 32W T8741U-BEND FLUOR.LAMP 4PIN THEY DO NOT	1/8/14		plant manager office	Electrical

Bolton HS (0035)	Move score board controller floor jack.	1/8/14			Electrical
Bolton HS (0035)	the clock in main building 2nd floor by 210 not working	1/9/14			Electrical
Bolton HS (0035)	please repair the clock in main building 2nd floor by room 210 not working	1/9/14	Hallway/Corridor	main bldg2nd floor	Electrical
Bolton HS (0035)	the clock in south building 1st floor by s117 has stopped not working	8/9/13	Hallway/Corridor	south hall	Electrical
Bolton HS (0035)	Please meet with the lighting contractor on the football field.	8/13/13			Electrical
Bolton HS (0035)	Program the master clock.	8/13/13			Electrical
Bolton HS (0035)	please repair the outlet in cosmostlogy someone broke a prong from a charger off in it	8/13/13	Classroom	cosmostlogy	Electrical
Bolton HS (0035)	wall pack light out main courtyard	8/14/13		courtyard	Electrical

Bolton HS (0035)	there are 2 outside lights out on 2nd floor across from cafeteria in courtyard	8/14/13		courtyard	Electrical
Bolton HS (0035)	please replace the ballast to light in main hall front of drama room 2 bad	8/14/13	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	if possible i need a case or 2 of the ushape light blubs pb32t8/1735/6 thanks	8/14/13	Custodial	plant manager office	Electrical
Bolton HS (0035)	i need a lens cover for light in main hall to replace the one that is brokenit is 22x22	8/14/13	1st Floor	main hall	Electrical
Bolton HS (0035)	please replace the ballast to light in varsity gym lobby bad	8/15/13	Gym	varsity gym	Electrical
Bolton HS (0035)	please replace the ballast to light in hall north building 2nd floor front of 233	8/16/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	replace the ballast to light in stairs east building by 243 bad	8/16/13	Stairway	east building	Electrical
Bolton HS (0035)	exit light #7 main building1st floor fail test	8/20/13	Hallway/Corridor	main bldg	Electrical

Bolton HS (0035)	exit light #10main building fail test	8/20/13	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	main building exit light #17 fail test 1st floor	8/20/13	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	exit light 23 guidance office fail 2nd floor main building	8/20/13	Administration Area	main bldg2nd floor	Electrical
Bolton HS (0035)	exit light #27 main 2nd floor fail test	8/20/13	Hallway/Corridor	main bldg2nd floor	Electrical
Bolton HS (0035)	exit light #30 fail test main building 2nd floor	8/20/13	Hallway/Corridor	main bldg2nd floor	Electrical
Bolton HS (0035)	exit light #5 old gym fail test	8/20/13	Auxiliary Gym	old gym	Electrical
Bolton HS (0035)	exit light #6 old gym fail test	8/20/13	Auxiliary Gym	old gym	Electrical
Bolton HS (0035)	exit /emergency light wrestling room old gym fail test	8/20/13	Auxiliary Gym	old gym	Electrical

Bolton HS (0035)	please repair the emergency light old gym lobby handicap ramp	8/20/13	Auxiliary Gym	old gym handicap	Electrical
Bolton HS (0035)	exit light #3 theatre #3 fail test	8/20/13	Auditorium	theatre	Electrical
Bolton HS (0035)	exit light #3 1st floor north building fail test	8/20/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #8 north building 1st floor fail test	8/20/13		north building	Electrical
Bolton HS (0035)	exit light #9 north building fail test	8/20/13		north building	Electrical
Bolton HS (0035)	exit light #17 main building fail test	8/20/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #22 north building fail test	8/20/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	portable 8 behind cafeteria 2 exit lights out baseball side	8/21/13	Portables	portable139	Electrical

Bolton HS (0035)	portable 139 classroom emergency /exit light fail test	8/21/13	Portables	portable139	Electrical
Bolton HS (0035)	exit light east 1st floor #3 fail test	8/21/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	please check the light switch in drama room 1 not working	8/22/13	Classroom	drama room1	Electrical
Bolton HS (0035)	please replace the ballast to light in boys restroom north 1st floor bad	8/22/13	Restroom (Boys)	north building 1st floor	Electrical
Bolton HS (0035)	please repair the light switch in main hall 2nd floor by 207 .will not stay tight keeps coming loose	8/23/13	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	please check the exhust fan mens restroom east twa not working and makes a noise	8/23/13	Restroom (Boys)	east building	Electrical
Bolton HS (0035)	Repair lights on field house	8/23/13			Electrical
Bolton HS (0035)	please check the sound system on football field .it shorted out twice friday night	8/26/13	Athletic Field	football field	Electrical

Bolton HS (0035)	please replace the ballast to light in assistant principal office bad across from cafeteria	8/26/13	Administration Area	assistant principal office	Electrical
Bolton HS (0035)	exit light #10 tractor bay fail test	8/26/13		tractor bay	Electrical
Bolton HS (0035)	exit light #6 varsity gym fail test	8/26/13	Gym	varsity gym	Electrical
Bolton HS (0035)	emergency light varsity gym top of stairs not working fail test	8/26/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light @13 varsity gym girls restroom fail test	8/26/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light # 7 varsity gym fail test	8/26/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light #20 varsity gym fail test	8/26/13	Gym	varsity gym	Electrical
Bolton HS (0035)	please replace ballast to light in hall main buld 2nd floor bad	8/27/13	Hallway/Corridor	main bldg	Electrical

Bolton HS (0035)	please replace the ballast to light in sped hall main bldg bad	8/28/13	Hallway/Corridor	sped hall main bldg	Electrical
Bolton HS (0035)	please repair clock in sped office not working also clock in south hall by s117 not working	8/28/13	Administration Area	sped office	Electrical
Bolton HS (0035)	please replace the ballast to light boys restroom north bldg 1st floor bsd	8/28/13	Restroom (Boys)	north building	Electrical
Bolton HS (0035)	Replace PIV switch	8/29/13			Electrical
Bolton HS (0035)	Replace horn on scoreboard. School has horn.	9/4/13			Electrical
Bolton HS (0035)	door magnet broken north building 2nd floor stairs by room 226	9/6/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	wall pack light out east building south end facing brunswick rd	9/9/13		east building	Electrical
Bolton HS (0035)	outside football locker room there are 2 wall pack lights out	9/9/13	Athletic Field	football field	Electrical

Bolton HS (0035)	please repair the ballast to light in m.harris office 2nd request as per mr. stevens	9/9/13			Electrical
Bolton HS (0035)	if possible i need the following light bulbs delivered to school 12 (10440)incandescent lamps60-130v 100 watt	9/10/13	Administration Area	plant manager office	Electrical
Bolton HS (0035)	Disconnect electrical on old water heater and reconnect new heater	9/16/13			Electrical
Bolton HS (0035)	please repair the clock in hall north building 1st floor not working	9/16/13	1st Floor	north building	Electrical
Bolton HS (0035)	please replace the ballast to light north building hall 1st floor bad	9/17/13	Hallway/Corridor	north building 1st floor	Electrical
Bolton HS (0035)	Adjust amplifier on football field	9/18/13			Electrical
Bolton HS (0035)	please replace the ballast to wall round wall pack lights under catwalk breezeway bad	9/20/13		breezeway	Electrical
Bolton HS (0035)	please repair the door magnet to door in north hall 1st floor by room 129 broken	12/20/13	Hallway/Corridor	north building	Electrical

Bolton HS (0035)	fire alarm trouble smoke(photo) 1st floor w stairs east building. 1D104	1/2/14	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	fire alarm trouble smoke (photo) 2nd floor door @m201 main building 1D079	1/2/14	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	Ventahood not working properly.	1/6/14	Cafeteria		Electrical
Bolton HS (0035)	please repair the light switch in hall main building 2nd floor across from 207 broken keeps coming loose from and hard to use	1/8/14		main bldg	Electrical
Bolton HS (0035)	please replace the ballast to light in hall north building 1st floor front of n133 bad	10/30/13	Hallway/Corridor	north building 1st floor	Electrical
Bolton HS (0035)	exit light /emergency light south building 2nd floor fail test	10/30/13	Hallway/Corridor	south building	Electrical
Bolton HS (0035)	exit light #10 main building 1st floor fail test	10/30/13	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	exit light #2 cafeteria fail test	10/30/13	Cafeteria	cafe	Electrical

Bolton HS (0035)	emergency light old gym weight room not working fail test	10/30/13	Gym	old gym joe branch	Electrical
Bolton HS (0035)	exit light #16 wrestling room fail test	10/30/13	Auxiliary Gym	old gym joe branch	Electrical
Bolton HS (0035)	exit light #7 varsity gym fail test	10/30/13	Gym	varsity gym	Electrical
Bolton HS (0035)	please repair the lights /timer to wall pack lights they will not turn off	7/31/13		outside lights	Electrical
Bolton HS (0035)	Change bell schedule.	8/2/13			Electrical
Bolton HS (0035)	please replace the ballast to light in main bldg lab106 chemical room bad	8/6/13	Classroom	lab106	Electrical
Bolton HS (0035)	please check the light switch in north 124 . he said when he turn on the lights he got shocked	11/21/13	Classroom	north building	Electrical
Bolton HS (0035)	wall pack light out south building south drive next to camara	11/21/13		south drive	Electrical

Bolton HS (0035)	wall pack light out main courtyard behind principal office	11/21/13		courtyard	Electrical
Bolton HS (0035)	please repair broken door magnet north building across from 129	11/21/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	please repair the electric wall heater i ticket booth varsity gym lobby. not working	1/9/14	Gym	varsity gym lobby	Electrical
Bolton HS (0035)	please repair the motion detector main building 105 hall keeps going off . i think the motion is bad . i walked the building with the sheriffs deputy and found something ok.	1/13/14	1st Floor	main bldg 1st floor	Electrical
Bolton HS (0035)	we have several codes of people that need to be deleted from security system	1/13/14	Administration Area	main bldg	Electrical
Bolton HS (0035)	please replace the ballast to light in hall east building 1st floor bad by 136	1/13/14	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	please replace the ballast to light in hall east building 2nd floor bad.please see me for location	1/14/14	Hallway/Corridor	east building 2ndfloor	Electrical
Bolton HS (0035)	i need 12 1case of blubs for the breezeway they are wescf32tttb4 14P 32w tripple twin tube41 4pin they are not in the catalog and warehouse does not	1/16/14	Administration Area	plant manager office	Electrical

Bolton HS (0035)	exit light #3 fail test	1/16/14	Hallway/Corridor	north 1st floor	Electrical
Bolton HS (0035)	exit light #4 main building 1st floor fail test	1/16/14	Hallway/Corridor	north 1st floor	Electrical
Bolton HS (0035)	exit light #7 north building fail test	1/17/14	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #22 north building 2nd floor fail test	1/17/14	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #15 east building 2nd floor fail test	1/17/14	Hallway/Corridor	east building 2nd floor	Electrical
Bolton HS (0035)	exit light #7 main building 1st floor fail test	1/17/14	Hallway/Corridor	main bldg 1st floor	Electrical
Bolton HS (0035)	exit light #9 main building fail test 1st floor	1/17/14	Hallway/Corridor	main bldg 1st floor	Electrical
Bolton HS (0035)	exit light #2 south building 1st floor fail test	1/21/14	Hallway/Corridor	south building	Electrical

Bolton HS (0035)	exit light #1 south building 1st floor fail test	1/21/14	1st Floor	south building	Electrical
Bolton HS (0035)	exit light #5 old gym fail test	1/21/14	Gym	old gym	Electrical
Bolton HS (0035)	exit light #16 old gym wrestling room fail test	1/21/14	Gym	old gym	Electrical
Bolton HS (0035)	exit light #18 old gym fail test	1/21/14	Gym	old gym	Electrical
Bolton HS (0035)	exit light #14 girls locker room varsity gym fail test	1/21/14	Gym	varsity gym	Electrical
Bolton HS (0035)	there is a lens cover to a light in the cafeteria that is about to fall i can not reach it will need a lift to get to it	1/21/14	Cafeteria	cafeteria	Electrical
Bolton HS (0035)	exit light portable (6) 038 fail test	1/21/14	Portables	portable 038(6)	Electrical
Bolton HS (0035)	portable (4) 076 exit /emergency light fail test	1/21/14	Portables	portable076(4)	Electrical

Bolton HS (0035)	exit light (1)165 fail test	1/21/14	Portables	portable 165(1)	Electrical
Bolton HS (0035)	exit light portable 149(3)fail test	1/21/14	Portables	portable149(3)	Electrical
Bolton HS (0035)	please check the electric heater in mechanical room out behind cafeteria not working.	11/21/13	Cafeteria	behind cafeteria	Electrical
Bolton HS (0035)	the clock in north building 2nd floor front of twa is not working	11/22/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	Need bulbs replaced.	11/26/13	Cafeteria		Electrical
Bolton HS (0035)	fire alarm trouble smoke (photo)2nd floor door @m208 main building 1Do68 cannot rest system until repired	12/2/13	Hallway/Corridor	main bldg2nd floor	Electrical
Bolton HS (0035)	we have 2 fire alarm troubles east building 1st floor smoke(photo) dront of elevator 2D129 also still have the one in main building also one in main building . i can not reset the	12/3/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	please check the electric wall heater in east building by room 130 not working	12/3/13	Gym	east building	Electrical

Bolton HS (0035)	if possible i need 6lens cover they are 22.5 wide	12/3/13	Hallway/Corridor	south building	Electrical
Bolton HS (0035)	emergency light main building by m105 not working	12/5/13	Hallway/Corridor	main bldg 1st floor	Electrical
Bolton HS (0035)	exit light #0 main building 1st floor fail test	12/5/13	Hallway/Corridor	main bldg 1st floor	Electrical
Bolton HS (0035)	emergency light portable 139 behind cafeteria not working	12/5/13	Portables	portable139(8)	Electrical
Bolton HS (0035)	exit light #16 wrestling room fail test	12/5/13	Gym	pe gym/old gym	Electrical
Bolton HS (0035)	exit light #21old gym fail test	12/5/13	Gym	old gym	Electrical
Bolton HS (0035)	exit light #22 main 2ndfl fail test	12/5/13	Hallway/Corridor	north building 2nd	Electrical
Bolton HS (0035)	exit light #4 main building 1st floor fail test	12/5/13	Hallway/Corridor	main bldg 1st floor	Electrical

Bolton HS (0035)	exit light #17 main building 1st floor fail test	12/5/13	Hallway/Corridor	north building 1st floor	Electrical
Bolton HS (0035)	exit light #9 north building 1st floor fail test	12/5/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #22 fail test 1st floor north building	12/5/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #7 east building 1 floor fail test	12/5/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	exit light #2 varsity gym lobby fail test	12/9/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light #3 varsity gym lobby fail test	12/9/13	Hallway/Corridor	varsity gym	Electrical
Bolton HS (0035)	exit light #6 fail test	12/9/13	Gym	varsity gym	Electrical
Bolton HS (0035)	please check the light switch in hall north building 2nd floor by 226 broken can not get key to work please see me for questions	12/12/13	Hallway/Corridor	north building	Electrical

Bolton HS (0035)	please check the light switch to lights in hall east building 1st floor front of attendance sparks when you turn it on.see me for questions	12/12/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	as per risk managment need a electrical outlet in stalled in theatre to run the production lights . right now they are using an extension cord as a peramaent they have the cord	12/12/13	Auditorium	theatre	Electrical
Bolton HS (0035)	please check the security system the key pad reads phone line trouble 1in all buildings	12/13/13	Administration Area	all areas	Electrical
Bolton HS (0035)	wall pack light out out outside home economic 1	12/17/13		votech building	Electrical
Bolton HS (0035)	wall pack light out main building south facing east see me for location	12/17/13		main bldg	Electrical
Bolton HS (0035)	there are 3 lights out in breezeway not working ballast	12/17/13		breezeway	Electrical
Bolton HS (0035)	pole light out student parking lot north 3rd pole in center from brunswick rd	12/18/13		north parking students	Electrical
Bolton HS (0035)	please replace the weather cover to outlet outside votech building broken	12/18/13		votech building	Electrical

Bolton HS (0035)	wall pack light out east building north facing the fire station on the left when you pull in the parking lot	12/19/13		east building	Electrical
Bolton HS (0035)	please repair the exhaust fan old gym restroom not working right behind girls weight room.	1/27/14	Gym	pe gym/old gym	Electrical
Bolton HS (0035)	wall pack light out courtyard behind principal office	1/28/14		main courtyard	Electrical
Bolton HS (0035)	there are 3 or 4 pole lights out south parking /bus lot	1/28/14	Parking Lot	south parking/bus lot	Electrical
Bolton HS (0035)	i need 8 exit light bulbs for 4 old style exit lights 25w/130v please see bill sharp for questions	1/28/14	Hallway/Corridor	all areas	Electrical
Bolton HS (0035)	wall pack light out east building north facing west see me for location	2/4/14		east building	Electrical
Bolton HS (0035)	please repair the microphone jack in old gym broken	2/4/14	Gym	old gym	Electrical
Bolton HS (0035)	please repair the door magnet to door in hall main 2nd floor top of stairs broken	2/6/14	Hallway/Corridor	main bldg	Electrical

Bolton HS (0035)	please repair the clock in hall north building 1st floor not working	2/6/14	Hallway/Corridor	north 1st floor	Electrical
Bolton HS (0035)	please replace the ballast to light in twa south building 1st floor bad	2/6/14		twa south building	Electrical
Bolton HS (0035)	please repair the door magnet in hall by north 129 bottom of stairs will not hold	2/7/14	1st Floor	north building	Electrical
Bolton HS (0035)	there is a second door magnet broken main building 2nd floor top of stairs .	2/7/14	2nd Floor	main bldg	Electrical
Bolton HS (0035)	please replace broken electrical outlet in north 235	2/7/14	Classroom	north building 235	Electrical
Bolton HS (0035)	if possible i need 12 incandescent lamps 150A23-130V stock number10385 delivered to plant managers office	2/7/14		plant manager office	Electrical
Bolton HS (0035)	i need a lens cover and frame for light i cafeteria 22-5/8 wide x46-5/8 long	2/13/14	Cafeteria	cafeteria	Electrical
Bolton HS (0035)	please check the pa system in varsity gym. it is making a cracking noise	2/13/14	Gym	varsity gym	Electrical

Bolton HS (0035)	please replace the ballast to light in drama room green room bad	2/14/14	Auditorium	green room	Electrical
Bolton HS (0035)	please replace the ballast to light in breezeway bad	2/14/14	Courtyard	breezeway	Electrical
Bolton HS (0035)	please check the dimmer switch to light in theatre broken	2/14/14	Auditorium	theatre	Electrical
Bolton HS (0035)	lens cover in cafeteria is about to fall i can not reach it will need a lift to get to it it is up high	2/18/14	Cafeteria	cafe	Electrical
Bolton HS (0035)	please repair the bleachers in varsity gym the small side will not roll out checked the breaker and it was ok	2/18/14	Gym	varsity gym	Electrical
Bolton HS (0035)	please replace the bulbs to light in stairway main bldg i can not reach it with my 8ft ladder	2/18/14	Stairway	main bldg	Electrical
Bolton HS (0035)	please repair the door magnet to door top of stairs north building 2nd floor by 220	2/20/14	Stairway	north building	Electrical
Bolton HS (0035)	fire alarm trouble smoke(photo) 1st floor NE stair door north building test f 2Doo5	2/21/14	Hallway/Corridor	north building 1st floor	Electrical

Bolton HS (0035)	Bleachers will not go in. Game tonight	2/24/14				Electrical
Bolton HS (0035)	please repair the broken door magnet to door south 1st floor bottom of stairs by room 121	2/28/14	Hallway/Corridor	south bldg1st		Electrical
Bolton HS (0035)	there are 3 lights out in theatre we can not reach with our 8ft ladder	2/28/14	Auditorium	theatre		Electrical
Bolton HS (0035)	please repair the broken door magnet main building top of stairs near 208	3/7/14	Hallway/Corridor	main bldg2nd floor		Electrical
Bolton HS (0035)	please repair the broken door magnet top of stairs south building 2nd floor west near 216	3/7/14	Hallway/Corridor	south building 2nd floor		Electrical
Bolton HS (0035)	wall pack light out varsity gym north side	3/7/14	Gym	varsity gym		Electrical
Bolton HS (0035)	please check the security alarm to portable (2) 120 the pad say door is missing causing the system to go into fault . so i guess the magnet is bad. i have to bypass this one	3/12/14	Portables	portable120		Electrical
Bolton HS (0035)	in study hall south building 2nd floor there are 2 lights out . both need the ballast replaced bad	3/18/14	Classroom	south building 2nd floor		Electrical

Bolton HS (0035)	please repair the pole light in main courtyard will not turn off the clock is brocken	3/19/14	Courtyard	main courtyard	Electrical
Bolton HS (0035)	exit light #6 north building 1st floor fail test	3/19/14	Hallway/Corridor	north 1st floor	Electrical
Bolton HS (0035)	exit light band room fail test	3/19/14	Hallway/Corridor	north 1st floor	Electrical
Bolton HS (0035)	emergency light top of stairs by 236 fail test does not work	3/19/14		north building 2ndfloor	Electrical
Bolton HS (0035)	emergency light north stairs by 220 fail test	3/19/14	Stairway	north building 2ndfloor	Electrical
Bolton HS (0035)	exit light #12 old gym fail test	3/19/14	Gym	old gym p.e	Electrical
Bolton HS (0035)	exit light#1girls locker room old gym fail test	3/20/14	Gym	old gym p.e	Electrical
Bolton HS (0035)	exit /emergency light girls locker room fail test	3/20/14	Gym	old gym p.e	Electrical

Bolton HS (0035)	exit light 15 wrestling room old gym fail test	3/20/14	Gym	old gym wrestling	Electrical
Bolton HS (0035)	exit light #6 old gym fail test	3/20/14	Gym	pe gym/old gym	Electrical
Bolton HS (0035)	emergency light old gym by girls locker room not working fail test	3/20/14	Gym	old gym p.e	Electrical
Bolton HS (0035)	exit light #21 old gym lobby fail test	3/20/14	Gym	old gym	Electrical
Bolton HS (0035)	exit light #4 varsity gym fail test	3/20/14	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light #10 varsity gym fail test	3/20/14	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light #7 1st floor main by m107 fail test	3/20/14	Hallway/Corridor	main building 1st floor	Electrical
Bolton HS (0035)	emergency light in hall by m105 fail test	3/20/14	Hallway/Corridor	main building 1st floor	Electrical

Bolton HS (0035)	exit light #4 cafeteria fail test	3/20/14	Cafeteria	cafeteria	Electrical
Bolton HS (0035)	exit/emergency light #13 fail test	3/20/14	Hallway/Corridor	main building 1st floor	Electrical
Bolton HS (0035)	exit light #4 theatre fail test	3/20/14		treatre	Electrical
Bolton HS (0035)	i need a lens cover to light in votech mediznne broken (22.1/4x46	3/21/14	Hallway/Corridor	votech medizinne	Electrical
Bolton HS (0035)	the exit/emergency light portable o76(4) test button is broken not able to test battery	3/21/14	Portables	portable076(4)	Electrical
Bolton HS (0035)	exit light in portable 175(7) fail test	3/21/14	Portables	portable 175 (7)	Electrical
Bolton HS (0035)	exit light portable 038 (6) fail test	3/21/14	Portables	portable 038(6)	Electrical
Bolton HS (0035)	portable 3 (149) exit light fail test	3/21/14	Portables	portable149(3)	Electrical

Bolton HS (0035)	exit light in portable 165(1) fail test	3/21/14	Portables	portable165 (1)	Electrical
Bolton HS (0035)	exit light #17 medzinne fail test	3/21/14	Hallway/Corridor	votech medzinne	Electrical
Bolton HS (0035)	exit light in wood shop fail test	3/21/14		woodshop	Electrical
Bolton HS (0035)	please repair the smoke detector east building 1st floor custodial closet bad set off alarm	3/24/14	Custodial Closet	east building	Electrical
Bolton HS (0035)	please replace the ballast to light in east building stairs 2nd floor by room 243 bad	3/24/14	Stairway	east building 2ndfloor	Electrical
Bolton HS (0035)	please check the lights in wrestling locker room some are not working we replace bulbs and nothing also one has a light that broken off in socket	11/1/13	Gym	old gym joe branch	Electrical
Bolton HS (0035)	please replace the ballast to light in cafeteria above serving line bad	11/6/13	Cafeteria	serving line	Electrical
Bolton HS (0035)	please replace the ballast to light in main hall by canteen this is the ushape blubs bad	11/6/13	Hallway/Corridor	main bldg	Electrical

Bolton HS (0035)	Mark breakers to boilers on panel door	11/6/13			Electrical
Bolton HS (0035)	wall pack light out main building south facing east also the lens is cracked	11/6/13		north building	Electrical
Bolton HS (0035)	if possible i need 12 flourescent lamps plt42w/35 /p phillips delivered to school	11/7/13	Administration Area	plant manager office	Electrical
Bolton HS (0035)	Multiple zones on the system are undefined.	11/7/13			Electrical
Bolton HS (0035)	in the old gym there is a row of lights that want come on i checked the breaker they all look ok .this is not in the gym but the entrance near girls weight room	11/8/13	Gym	pe gym/old gym	Electrical
Bolton HS (0035)	if possible i need 12 flourescent plt42w/35/4p phillips stock number 10257 delivered to school	11/12/13	Administration Area	plant manager office	Electrical
Bolton HS (0035)	please check the speaker in old gym not working	11/13/13	Gym	old gym	Electrical
Bolton HS (0035)	please check the security alarm main building can not arm they are having to by pass because of the problem	11/18/13	Administration Area	main bldg	Electrical

Bolton HS (0035)	i need 2 LL20 light switch keys if possible	11/18/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	as per mr. stevens need the electrical outlet and scoreboard outlet in varsity gym moved back about 2 or 3 feet . please see me or mr. stevens for questions	11/20/13	Gym	varsity gym	Electrical
Bolton HS (0035)	wall pack light out north building facing brunswick rd near window 127 . please see me for location	11/20/13		north building	Electrical
Bolton HS (0035)	Check for lights out on the football field and replace any that are out.	7/11/13			Electrical
Bolton HS (0035)	Please run Test. Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical
Bolton HS (0035)	Please run Test. Generator # 2 Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical
Bolton HS (0035)	Lights on the east building has a contactor burnt up.	7/15/13			Electrical
Bolton HS (0035)	Download the remote code installation for both locations.	7/15/13			Electrical

Bolton HS (0035)	Please check the speakers on the football field they keep cutting in and out.	7/15/13			Electrical
Bolton HS (0035)	Configure 3 burglar alarm panels to accept code changes via phone line.	7/16/13			Electrical
Bolton HS (0035)	East building outside lights is not turning off.	7/16/13			Electrical
Bolton HS (0035)	east building south side wall pack light out	7/25/13		outside east bldg	Electrical
Bolton HS (0035)	wall pack light east building east side is out	7/25/13		outside east bldg	Electrical
Bolton HS (0035)	please repair the timer to outside lights east building bad will not turn off	7/25/13		east building	Electrical
Bolton HS (0035)	there are 2 wall packs lights out east side south that are out	8/6/13		outside main bldg	Electrical
Bolton HS (0035)	please replace the ballast to light in ib cornator office bad	8/7/13	Administration Area	ibcornator office	Electrical

Bolton HS (0035)	need the bells schedule programed	8/8/13	Administration Area	displine office	Electrical
Bolton HS (0035)	door magnet broken north bldg 2nd floor by 226	8/8/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	we have 2 wall packs lights out north side of north building	8/8/13		outside north	Electrical
Bolton HS (0035)	we have 1 wall pack out east side of north building	8/8/13		outside north	Electrical
Bolton HS (0035)	Smoke detector has A/C unit off	8/8/13		Room 215	Electrical
Bolton HS (0035)	please replace the ballast to light in classroom east 137 bad	8/9/13	Classroom	east 137	Electrical
Bolton HS (0035)	please replace the ballast to light in attendance office bad	8/9/13	Administration Area	attendance ofice	Electrical
Bolton HS (0035)	Wire projector in band room	9/23/13			Electrical

Bolton HS (0035)	Check center pole on football field arcing in box on pole	9/23/13			Electrical
Bolton HS (0035)	please check the outlet in east building classroom e143 keep tripping breaker and blowing the blub to the parmethian projector please see me for suactans	9/23/13	Classroom	east building 143	Electrical
Bolton HS (0035)	please check the alarm to portables north side the key pad reads battery bad	9/24/13	Portables	all portables	Electrical
Bolton HS (0035)	please check the battery to alarm in portable 120 it reads low battery and keeps setting off on security panel	9/26/13	Portables	portable 120	Electrical
Bolton HS (0035)	exit light #23 guidance office not working fail test	9/27/13		guidance office	Electrical
Bolton HS (0035)	exit light #19 fail test	9/27/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	exit light #1 theatre fail test	9/27/13	Auditorium	auditorium	Electrical
Bolton HS (0035)	exit /emergency light in theatre fail test	9/27/13	Auditorium	auditorium	Electrical

Bolton HS (0035)	exit/emergency /light 3-4 theatre fail test	9/27/13	Auditorium	auditorium	Electrical
Bolton HS (0035)	please repair the conduit in north lab 233 broken see roofer	9/30/13	Classroom	north 233	Electrical
Bolton HS (0035)	exit light #2east building fail test	9/30/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	in the cafeteria there are 4 lights out i can not reach them . you will need the lift	10/1/13	Cafeteria	cafeteria	Electrical
Bolton HS (0035)	exit light #2 east building 1st floor fail test	10/1/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	exit light #8 1st floor east building fail test	10/1/13	Hallway/Corridor	east building	Electrical
Bolton HS (0035)	Speaker on football field is blown. South speaker next to fieldhouse	10/1/13			Electrical
Bolton HS (0035)	exit /emergency light #14 fail test	10/1/13	Hallway/Corridor	east building	Electrical

Bolton HS (0035)	exit /emergency light fail test	10/1/13	Hallway/Corridor	south building	Electrical
Bolton HS (0035)	south building 1st floor exit/ emergency light fail test	10/1/13	Hallway/Corridor	south building	Electrical
Bolton HS (0035)	exit/emergency light #10 fail test	10/1/13	Hallway/Corridor	south building	Electrical
Bolton HS (0035)	please repair the microphone jack in old gym joe branch gym broken cannot get get the cord out	10/2/13	Gym	joe branch gym	Electrical
Bolton HS (0035)	exit/emergency light #11 south 2nd floor fail test	10/2/13	Gym	south building	Electrical
Bolton HS (0035)	exit/emergency light#13 south 2nd floor fail test	10/2/13	Hallway/Corridor	south building	Electrical
Bolton HS (0035)	exit light #2in portable #2(120) fail test	10/2/13	Portables	#2 (120)	Electrical
Bolton HS (0035)	exit light portable 165(1) fail test	10/2/13	Portables	portable 165(1)	Electrical

Bolton HS (0035)	exit light portable (o76) (#4) fail test	10/3/13	Portables	portable076	Electrical
Bolton HS (0035)	exit/emergency light in old gym #11 fail test	10/3/13	Gym	old gym joe branch	Electrical
Bolton HS (0035)	old gym wrestling room exit/ emergency light #14 fail test	10/3/13	Gym	old gym joe branch	Electrical
Bolton HS (0035)	exit light #1 fail test varsity gym	10/3/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light#7 varsity gym fail test	10/3/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light #13 varsity gym girls locker room fail test	10/3/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light ##14 girls locker room varsity gym fail test	10/3/13	Gym	varsity gym	Electrical
Bolton HS (0035)	exit light #21 varsity gym fail test	10/3/13	Gym	varsity gym	Electrical

Bolton HS (0035)	please check the electrical outlet in cafeteria keeps tripping breaker	10/14/13	Kitchen	serving line	Electrical
Bolton HS (0035)	please replace the ballast to light in hall north building 1st floor by 133 bad	10/17/13	Hallway/Corridor	north building	Electrical
Bolton HS (0035)	please check the electrical outlet to dryer in cosmostlogy the cord sparked just need it checked before we plug in the new cord	10/18/13	Classroom	votech cosmostlogy	Electrical
Bolton HS (0035)	please check the alarm to north building was not able to arm the system . it shows trouble	10/21/13		north building	Electrical
Bolton HS (0035)	wall pack light out east building south facing brunswick rd	10/21/13		east building	Electrical
Bolton HS (0035)	please replace the broken lens cover to wall pack light outside main office	10/21/13	Administration Area	courtyard	Electrical
Bolton HS (0035)	pole light out behind varsity gym north side	10/21/13	Gym	varsity gym	Electrical
Bolton HS (0035)	wall pack light out main building south facing east building	10/21/13		main bldg	Electrical

Bolton HS (0035)	wall pack light out behind band room back of gym	10/22/13		outside north	Electrical
Bolton HS (0035)	we have 2 ballast in cafeteria that are bad	10/25/13	Cafeteria	cafe	Electrical
Bolton HS (0035)	please replace the ballast to light in hall main building front of old tv studio bad	10/25/13	Hallway/Corridor	main bldg	Electrical
Bolton HS (0035)	Verify burglar alarm data base.	10/28/13		Main Building	Electrical
Bolton HS (0035)	Verify burglar alarm data base.	10/28/13		East Building	Electrical
Bolton HS (0035)	Verify burglar alarm data base.	10/28/13		North Building	Electrical
Bolton HS (0035)	exit light portable165(1) fail test	10/29/13	Portables	portable 165(1)	Electrical
Bolton HS (0035)	emergency light portable 1(165) not working fail test	10/29/13	Portables	portable 165(1)	Electrical

Bolton HS (0035)	exit light portable 120 (2) fail test	10/29/13	Portables	portable 120	Electrical
Bolton HS (0035)	emergency light portable (2) 120 fail test	10/29/13	Portables	portable 120	Electrical
Bolton HS (0035)	exit light #16 votech medzinne fail test	10/29/13	Hallway/Corridor	votech medzinne	Electrical
Bolton HS (0035)	we are replacing the old projector in theatre we will need to have some one check the to disconnect and reconnect the power please see chad for suggestions	10/30/13	Auditorium	auditorium	Electrical
Bolton HS (0035)	wall pack light out outside cosmostlogy votech courtyard	10/30/13		votech courtyard	Electrical
Bolton HS (0035)	there are 2 wall pack lights out football field house	10/30/13	Athletic Field	football field house	Electrical
Bolton HS (0035)	A/C IN RM S215-NOT COMING ON & A/C IN CHOIR RM SMELLS LIKE MOTOR HAS BURNED OUT, NOT COMING ON-SBE TATE 873-8150 KLR	8/6/13			Electrical
Bolton HS (0035)	if possible need for someone to locate electrical lines on football they are replacing the score board some time this week see mr stevens	6/30/14	Athletic Field	football field	Electrical

Bolton HS (0035)	we have several codes we need to remove and add some new ones for security pannel.	1/9/14	Administration Area	main office north east	Electrical
Bolton HS (0035)	in m203 they need additional electrical outlets installed because of all the computers they will be using for graphics. please see mr stevens principal for questions	6/30/14	Classroom	m203	Electrical
Bolton HS (0035)	if possible we need a light mounted to the pole by dumpster outside cafeteria . this area is really dark area please see me for questions	11/21/13		behind cafeteria	Electrical
Bolton HS (0035)	as per request chad stevens if possible in the old custodial closet main building 1st floor we need a electrical outlet. this now the food pantry they would like to be able to plug in	11/20/13	Custodial Closet	main bldg	Electrical
Bolton HS (0035)	if possible i need these blubs they are not in the catalog and i never had to buy any untill now. here is the information that i have they are 3ft blubs E2ET8 this all i could	1/24/14	Hallway/Corridor	east building 2ndfloor	Electrical
Bolton HS (0035)	Repair classroom unit.	6/9/14			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in north 130-231 plant manager office blows HOT	3/31/14	Classroom	n130 n231 plant managers	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in north 129 blows hot	4/2/14	Classroom	n129	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	please check the ac in north 223 not working blows hot	4/3/14	Classroom	north 223	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in main office blows cold	4/7/14	Administration Area	main office	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	condensation leak in north 229	4/11/14	Classroom	north 229	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in east 237 blows hot	4/14/14	Classroom	east 237	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in deputy office blows hot	4/14/14			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	there is a heat/air unit north building that is making a very loud noise sounds like it about to fall through the roof it is really loud	4/15/14	Hallway/Corridor	north building 2ndfloor	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in portable (120)-2 and portable (149) -3 not working . will be taking test in these portables next week april 29-may 2	4/21/14	Portables	portable120&149	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Check ice machinin concession stand	4/23/14		concession stand	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	please check the air in band room blows hot	4/23/14	Classroom	bandroom	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in m200 not working blows hot	4/24/14	Classroom	m200	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in football concession not working	4/24/14	Athletic Field	football concession	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in plant managers office blows hot	4/29/14	Administration Area	plant manager office	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air / heat in portable 120(2) not working they are taking test in there this week and next	5/1/14	Portables	portable120	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat/ air in portable 4 (076) not working they are testing in portable this week and next	5/1/14	Portables	portable076(4)	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in twa north / assistant principal office north 2nd floor not working hot	5/5/14		twa north/assistant principal	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in north 233 not working blows hot	5/8/14	Classroom	north building	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	please check the air in main 206 not working blows hot	5/8/14	Classroom	m206	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in plant managers office blows hot	5/9/14		plant manager office	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in north 134 not working hot	5/9/14		north 134	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in hosa classroom votech not working it is HOT in there	5/9/14	Classroom	hosa votech	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in boys locker room old gym blows hot	5/12/14	Gym	pe gym/old gym	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Clean P.E and main gym units	5/21/14		Gym's	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in north building no working north 2nd floor rooms 233 235 236 at all nothing	6/30/14	Classroom	north building	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in old gym girls restroom not working it is cold in there .this is not the locker room it is the public restroom	1/24/14	Gym	pe gym/old gym	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	Need to wash cafeteria and kitchen units	6/3/14				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in varsity gym not working blows cold they do have a game tonight	1/21/14	Gym	varsity gym		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in dec office blows cold	1/22/14		DEC OFFICE		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in south 220 blows cold	1/22/14	Classroom	south220		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in south 221 blows cold	1/23/14	Classroom	south 221		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	South room 114 - a/c hot - not coming on	8/9/13				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Boys locker room in new gym blowing hot air per Randy Tate	8/9/13				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	North Bldg 220 a/c leak, north hallway a/c leak, M206 a/c leak	8/13/13				Heating/Ventilation /Air Conditioning

Bolton HS (0035)	Attendance office, old gym locker, east 136 a/c blowing hot air per Randy Tate	8/13/13				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Room 223 compressor not working per Randy Tate 873-8157	8/14/13				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Room N134 and N223 blowing hot air per Randy Tate 873-8157	8/19/13				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Teacher's Work Area main building 2nd floor a/c won't come on, boys locker old gym blows hot air, concession varsity gym blows hot air per Randy Tate 873-8157	9/5/13				Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please repair the compressor to water cooler north building 1st floor by restroom	9/13/13	Hallway/Corridor	main bldg		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in band room north building blows cold	1/6/14	Classroom	bandroom		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	north 222 heat not working blows cold	1/7/14	Classroom	n222		Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in varsity gym one is not working	1/7/14	Gym	varsity gym		Heating/Ventilation /Air Conditioning

Bolton HS (0035)	heat in portable 139 behind cafeteria not working	1/7/14	Portables	portable139(8)	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	heat in north 235 not working blows cold	1/7/14	Classroom	n235	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in in north 230 not working	1/7/14	Classroom	north230	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	m207 no heat blows cold	1/7/14	Classroom	main 207	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in m200 cold	1/7/14	Classroom	m200	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	m107 no heat blows cold	1/7/14	Classroom	m107	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in n222 not working	1/8/14	Classroom	north building 222	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in north 235 blows cold	1/16/14	Classroom	north building 235	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	please check the heat in south 221 blows cold	1/16/14	Classroom	south 221	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in chrous room not working	11/21/13	Classroom	chrous	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Service Aaon's in gym	11/21/13		Gym	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	air still not working in chrous room hot	11/22/13		chrous	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in north 226 blows cold	11/25/13	Classroom	north building	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	north 228 no heat blows cold	11/25/13	Classroom	north 228	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	north 231 north no heat blows cold	11/25/13	Classroom	north building 231	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	north 231 no heat blows cold	11/25/13	Administration Area	assistant principal office	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	please check the heat in mrs. young office votech building blows cold	11/25/13	Administration Area	assistant principal office	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in mr. stevens office cold . he said when he closes his door he gets no heat	11/25/13	Administration Area	principal office	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in vhe1 blows cold	11/25/13	Classroom	home economic 1	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in band room blows cold	11/26/13	Classroom	bandroom	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in m203 blows cold	12/9/13	Classroom	m203	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in main hall outside room 99 blows cold	12/9/13	Hallway/Corridor	main bldg 1st floor	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in hall main by drama room cold	12/9/13	Hallway/Corridor	main bldg 1st floor	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in theratre lobby blows cold	12/9/13	Hallway/Corridor	main bldg	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	please check the heat in n125 blows cold	12/9/13	Classroom	N125	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in east 136 and e130 cold . energy management has it off or it not turning it on .very cold in these roms	12/13/13	Classroom	e140 e136	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in east 142 blows cold	12/16/13	Classroom	east 142	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in portable 139 behind cafeteria not working	12/17/13	Portables	portable139(8)	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	n22o heat not working blows cold	1/24/14	Classroom	north230	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	n230 no heat blows cold not north 220 sorry	1/24/14	Classroom	north230	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in deputy office blows cold	1/24/14		deputy office	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in hall main building 1st floor blows cold	1/24/14	Hallway/Corridor	main bldg 1st floor	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	m2o4 no heat cold	1/24/14	Classroom	m204	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	portable (139) baseball locker room no heat	1/24/14	Portables	portable139(8)	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in study hall blows cold	1/28/14	Classroom	study hall	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in cafeteria blowing cold	1/29/14	Cafeteria	cafeteria	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in north 222 blows cold	1/29/14	Classroom	north building 222	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Change filters in "S" building and Vo tech	1/30/14		S building and vo tech	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Repair center hall by cafe	1/31/14			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in m109 blows cold	2/6/14	Classroom	m109	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	the hvac unit in votech medicine is making a really loud noise	2/13/14	Classroom	votech medicine	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat / air in north 123 is not working	2/19/14	Classroom	n123	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Repair heat in room 123	2/21/14		Room 123	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the air in north building it is hot	3/19/14		north building	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	please check the heat in portable (2) 120 blows cold	3/24/14	Portables	portable120	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Repair heat in varsity boy's gym locker rm	11/8/13		Varsity boy's locker	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	per randy tate 873-8157 main office, N223 and portable #2 (which is 120) no heat	11/13/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	N231 a/c leak and rattle, North hallway not working in p/m office, boys locker room blowing hot per Randy Tate 873-8150	8/8/13			Heating/Ventilation /Air Conditioning

Bolton HS (0035)	3 classrooms in mezzanine a/c not cooling per randy tate 873-8150	9/26/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	S117 a/c leaking per randy tate 873-8157	10/4/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	boys locker room in old gym not cooling and east 142 not cooling per Randy Tate 873-8157	10/4/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	a/c in the votech mezzanine is not cooling per randy tate 873-8150	10/14/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	roof leak n225 really bad back of room	10/16/13		bolton high school	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Replace condenser fan motor on water cooler D-F North 1st floor	10/23/13		D-F North 1st floor	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Room #230 North Building a/c not working per Fred Patrick 873-8157	7/31/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	replace condensing unit on portable 4	7/8/13		portable #4	Heating/Ventilation /Air Conditioning

Bolton HS (0035)	Choir Room 1st Floor North Building - T'stat gone off wall and a/c not working properly. They are cleaning carpets today and tomorrow and need a/c per Fred Patrick 873-8157	7/26/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	replaced cond motor	7/29/13		wood shop	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	per Fred Patrick - Portable 139 behind cafe no a/c Room 100 main bldg across from cafe no a/c, special ed office between main and south buildings no a/c	7/30/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Repair A/C in band room	7/25/13		Band	Heating/Ventilation /Air Conditioning
Bolton HS (0035)	Room 102 Main Building unit leaking per Fred Patrick 873-8157	7/25/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	rm 142 in east bldg no a/c per fred patrick 873-8150	7/22/13			Heating/Ventilation /Air Conditioning
Bolton HS (0035)	sheetrock has been patched, needs to be finished please patch the hole in sheet rock in south 220	10/31/13	Classroom	south220	Painting
Bolton HS (0035)	please mud and paint the hole in wall that was patch in s220	10/30/13	Classroom	south220	Painting

Bolton HS (0035)	need the door frames to portable 139 behind cafeteria chalk and painted there are 6 doors	12/20/13			Painting
Bolton HS (0035)	if possible i need all parking lot restriped	3/28/14			Painting
Bolton HS (0035)	behind varsity gym we need to paint the wheel chair ramp yellow . people keep tripping over the ramp because it has a lip tha sticks up please see me for questions	1/21/14	Gym	varsity gym	Painting
Bolton HS (0035)	please paint the wall in east 241 nasty	5/30/14			Painting
Bolton HS (0035)	please paint the wall main building by theatre .it is peeling an breaking off look really bad	1/8/14	Hallway/Corridor	main bldg	Painting
Bolton HS (0035)	if possible we have some areas that need to be painted one is mrs.young office and several places around the building	8/12/13	Administration Area	assistant principal	Painting
Bolton HS (0035)	not sure where to send this if possible we need two more handicap parking spots to accomdate our problem please see me or chad stevens for questions	8/13/13	Parking Lot	north parking	Painting
Bolton HS (0035)	if possible i need the stairs in south building painted by 121 middle landing had a roof leak there but it has been repair .but the wall could use some help	8/19/13	Stairway	south hall	Painting

Bolton HS (0035)	the assistant principal office votech needs to be painted . she is new this year and her office looks bad please advise	8/28/13	Administration Area	assistant principal office	Painting
Bolton HS (0035)	the door to cosmostlogy classroom needs to be sanded and resealed this door looks nasty .this was caused by a roof leak that has now been repaired for	9/13/13	Classroom	votech cosmostlogy	Painting
Bolton HS (0035)	if possible we need the restrooms painted with all the grafetti and everything else they are in bad shape	11/22/13	Restroom (Boys)	main&south building	Painting
Bolton HS (0035)	Please caulk and repaint all door jambs (6) on the portable behind the gym	12/19/13			Painting
Bolton HS (0035)	if possible the dugouts softball field need to be painted	2/5/14	Athletic Field	softball field	Painting
Bolton HS (0035)	need bleachers painted on baseball field we have the paint already	3/24/14	Athletic Field	baseball field	Painting
Bolton HS (0035)	if possible in the varsity gym there is a place on the ceiling that needs to be patch and painted before basketball season . it my understanding that the roof leak is fixed so if	11/8/13	Gym	varsity gym	Painting
Bolton HS (0035)	the toilet in preschool votech classroom is not working don't flush	3/31/14	Classroom	child care votech	Plumbing

Bolton HS (0035)	shower head leaking in old gym boys locker room	4/2/14	Gym	old gym	Plumbing
Bolton HS (0035)	urnial in boys restroom south 1st floor stopped up0	4/2/14	Restroom (Boys)	south building 1st floor	Plumbing
Bolton HS (0035)	Turn water on to the baseball field.	4/2/14			Plumbing
Bolton HS (0035)	Turn water on to the football field.	4/2/14			Plumbing
Bolton HS (0035)	Turn water on to the soccer field.	4/2/14			Plumbing
Bolton HS (0035)	Turn water on to the front lawn area.	4/2/14			Plumbing
Bolton HS (0035)	please repair the urinal in boys restroom south 1st floor flush valve is broken.	4/4/14	Restroom (Boys)	south building	Plumbing
Bolton HS (0035)	toilet in boys restroom main building is stopped up tried to plunge but no good	4/7/14	Restroom (Boys)	main bldg	Plumbing

Bolton HS (0035)	Toilet seat is broken.	4/10/14	Cafeteria		Plumbing
Bolton HS (0035)	Faucet will not turn off properly.	4/10/14	Cafeteria		Plumbing
Bolton HS (0035)	toilet women restroom football restroom leaks when you flush it	4/16/14	Athletic Field	concession football	Plumbing
Bolton HS (0035)	Test RP Serial # 390928	4/23/14			Plumbing
Bolton HS (0035)	Test RP Serial # 390660	4/23/14			Plumbing
Bolton HS (0035)	Test RP Serial # 485797	4/23/14			Plumbing
Bolton HS (0035)	Test RP Serial # 4021454	4/23/14			Plumbing
Bolton HS (0035)	Test RP Serial # 189028	4/23/14			Plumbing

Bolton HS (0035)	Leaking under sink.	4/29/14	Cafeteria		Plumbing
Bolton HS (0035)	Hand sink leaking under bowl.	5/2/14	Cafeteria		Plumbing
Bolton HS (0035)	please repair the down spout east building north side it is broken . the ground has eroded and cause the pipe to break . please see me for questions	5/14/14		FRONT CAMPUS	Plumbing
Bolton HS (0035)	Toilet seat is broken.	5/14/14	Cafeteria		Plumbing
Bolton HS (0035)	please repair the urinal boys restroom main 1st floor broken frush handle pulled from wall	5/19/14	Restroom (Boys)	main bldg 1st floor	Plumbing
Bolton HS (0035)	please repair the toilet in twa east will not flush	5/20/14	Restroom (Girls)	east building 2ndfloor	Plumbing
Bolton HS (0035)	please repair the urinal in boys restroom north 1st floor broken the flush valve is broken can not flush	5/21/14	Restroom (Boys)	north building	Plumbing
Bolton HS (0035)	please repair the toilet in twa east building 2nd floor has a really bad leak	5/30/14	Restroom (Girls)	east building twa	Plumbing

Bolton HS (0035)	please repair or replace the broken toilet seat boys restroom east building 2nd floor	5/30/14	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	boys restroom north building 2nd floor there are 2 urinals broken can not flush the flush valve is missing on one and the other is loose	5/30/14	Restroom (Boys)	north2nd floor	Plumbing
Bolton HS (0035)	sink leaking at the joint.	1/23/14	Cafeteria		Plumbing
Bolton HS (0035)	the urinal in boys restroom main 2ndfloor wont flush	8/9/13	Restroom (Boys)	main bldg	Plumbing
Bolton HS (0035)	there are 2 urinals in football fieldhouse stopped up	8/12/13	Athletic Field	football field house	Plumbing
Bolton HS (0035)	broken toilet seat sped office	8/14/13		sped office	Plumbing
Bolton HS (0035)	urinal in boys restroom east building 1st floor is leaking from flush valve	8/15/13	Restroom (Boys)	east building	Plumbing
Bolton HS (0035)	Per State of TN inspector--All three elevator pits need to be cleaned/cleared out	8/15/13	Elevator		Plumbing

Bolton HS (0035)	Pump water and debris from all elevator pits. Cited by State Inspector. 24 hrs to comply.	8/15/13				Plumbing
Bolton HS (0035)	the uniral in boys restroom east bldg 1st floor is leaking around flush valve	8/16/13	Restroom (Boys)	east building		Plumbing
Bolton HS (0035)	the toilet in girls restroom south bldg 1st floor is leaking	8/16/13	Restroom (Girls)	main bldg		Plumbing
Bolton HS (0035)	the handal to mop sink custodial closet main bldg is leaking 2nd floor	8/16/13	Custodial Closet	main bldg		Plumbing
Bolton HS (0035)	there is a water leak on baseball field left field warning track	8/16/13	Athletic Field	baseball field		Plumbing
Bolton HS (0035)	there 3 sprinkler heads on baseball field we will mark them	8/16/13	Athletic Field	baseball field		Plumbing
Bolton HS (0035)	water cooler main building 2nd floor not cooling	8/20/13	Hallway/Corridor	north building		Plumbing
Bolton HS (0035)	the lab sink in lab 106 is stopped up tried to plunge it but no luck	8/22/13	Classroom	lab106		Plumbing

Bolton HS (0035)	the urinal in boys restroom north 1st floor keeps running	8/22/13	Restroom (Boys)	north building	Plumbing
Bolton HS (0035)	please check the gas valve in lab 210 some are working and some are not	8/26/13	Classroom	lab210	Plumbing
Bolton HS (0035)	the sink in artroom m203 is leaking the trap is full and needs to be cleaned out	8/29/13	Classroom	m203	Plumbing
Bolton HS (0035)	urnial boys restroom east building 2nd floor is stopped up	9/3/13	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	the urinal boys restroom east building 2nd floor is leaking	9/3/13	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	the urinal boys restroom south 1st floor is stopped up	9/3/13	Restroom (Boys)	south bldg1st	Plumbing
Bolton HS (0035)	please repair the faucet to lab sink in main 210 it is leaking	9/3/13	Classroom	lab210	Plumbing
Bolton HS (0035)	please repair the eyewash station m210 one side does not open all the way	9/3/13	Classroom	lab210	Plumbing

Bolton HS (0035)	please repair 3 ball valve broken in auto shop	9/4/13		auto shop	Plumbing
Bolton HS (0035)	theb sink in lab106 main building 1st floor is stopped up	9/5/13	Classroom	lab106	Plumbing
Bolton HS (0035)	toilet in boys restroom south 1st floor last stall is leaking	9/6/13	Restroom (Boys)	south bldg1st	Plumbing
Bolton HS (0035)	toilet in boys restroom south 2nd floor is stopped up	9/6/13	Restroom (Boys)	south bldg2nd fl	Plumbing
Bolton HS (0035)	Faucet will not turn completely off.	9/6/13	Cafeteria		Plumbing
Bolton HS (0035)	the water tank north building is leaking and making a noise also has a strong smell of gas	9/10/13	Hallway/Corridor	north building 2nd	Plumbing
Bolton HS (0035)	Dishwasher is leaking from underneath the tank	9/10/13	Cafeteria		Plumbing
Bolton HS (0035)	Came in this a.m. (9/11/2013) water was all over floor in dishroom & coving a large part of cooking area	9/11/13	Cafeteria		Plumbing

Bolton HS (0035)	the urnial boys restroom south building 1st floor is leaking	9/12/13	Restroom (Boys)	south bldg1st	Plumbing
Bolton HS (0035)	the urnial boys restroom north building 2nd floor is stopped up	9/12/13	Restroom (Boys)	north building 1st floor	Plumbing
Bolton HS (0035)	the toilet in girls restroom football field is stopped up	9/12/13	Athletic Field	football field	Plumbing
Bolton HS (0035)	Faucet on dishwasher is leaking.	9/12/13	Cafeteria		Plumbing
Bolton HS (0035)	Pressure regulator leaking on dishwasher.	9/16/13	Cafeteria		Plumbing
Bolton HS (0035)	the bradley in boys restroom south keeps running will not shut off	9/16/13	Restroom (Boys)	south bldg1st	Plumbing
Bolton HS (0035)	water cooler north 1st floor not working	9/16/13	1st Floor	north building 1st floor	Plumbing
Bolton HS (0035)	the toilet in boys restroom keeps running over . i tried to plunge it but it don't help	10/30/13	Restroom (Boys)	south bldg1st	Plumbing

Bolton HS (0035)	urnial boys restroom south is stopped up	10/30/13	Restroom (Boys)	south bldg1st	Plumbing
Bolton HS (0035)	a second urinal in boys restroom south 1st floor is stopped up	10/30/13	Restroom (Boys)	south bldg1st	Plumbing
Bolton HS (0035)	please repair the toilet in attendance office will not flush	1/10/14	Administration Area	attendance office	Plumbing
Bolton HS (0035)	the faucet to sink in boys restroom old gym no water cold side	1/10/14	Gym	old gym	Plumbing
Bolton HS (0035)	sink in restroom keeps running	1/10/14	Gym	old gym	Plumbing
Bolton HS (0035)	please repair the toilet boys locker room old gym broken has a leak	1/13/14	Gym	pe gym/old gym	Plumbing
Bolton HS (0035)	urnial in boys restroom old gym stopped up	1/13/14	Gym	old gym p.e	Plumbing
Bolton HS (0035)	water cooler in cafeteria is stopped up	1/14/14	Cafeteria	cafeteria	Plumbing

Bolton HS (0035)	the toilet in theatre stage right keeps running	1/16/14	Auditorium	auditorium	Plumbing
Bolton HS (0035)	toilet in boys restroom 1st stall is leaking	1/17/14	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	if possible need to locate the water lines behind baseball field where batting cage is . they need to dig so that they can replace the plocs to batting cage	1/21/14	Athletic Field	baseball field	Plumbing
Bolton HS (0035)	the water cooler in cafeteria is stopped up	11/25/13	Cafeteria	cafeteria	Plumbing
Bolton HS (0035)	the sink in m2o7 is stopped up the trap needs to be cleaned	11/26/13	Classroom	m207	Plumbing
Bolton HS (0035)	Winterize baseball sprinkler system.	11/26/13			Plumbing
Bolton HS (0035)	Winterize Softball sprinkler system.	11/26/13			Plumbing
Bolton HS (0035)	Winterize Softball sprinkler system.	11/26/13			Plumbing

Bolton HS (0035)	please check the sink in drama room 1 making a loud noise	12/11/13	Classroom	drama room1	Plumbing
Bolton HS (0035)	please check the washing machine in old gym is backing up in to locker room	12/11/13	Gym	old gym	Plumbing
Bolton HS (0035)	the urinal boys restroom main 1st floor is stopped up	12/11/13	Restroom (Boys)	main bldg 1st floor	Plumbing
Bolton HS (0035)	the faucet to sink in girls weight room old gym is leaking	1/24/14	Restroom (Girls)	old gym	Plumbing
Bolton HS (0035)	Test RP Serial # 435989	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 102353	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 08357	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 327648	1/27/14			Plumbing

Bolton HS (0035)	Test RP Serial # 332825	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 04487	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 08373	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 304952	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 08351	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 335578	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 436039	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 309954	1/27/14			Plumbing

Bolton HS (0035)	Test RP Serial # 188185	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 187809	1/27/14			Plumbing
Bolton HS (0035)	Test RP Serial # 272754	1/27/14			Plumbing
Bolton HS (0035)	the faucet to sink in boys restroom old gym is leaking	1/28/14	Gym	old gym	Plumbing
Bolton HS (0035)	air line in tractor bay is leaking will not shut off all the way	1/30/14		tractor bay	Plumbing
Bolton HS (0035)	the mop sink in storage cafeteria is leaking	1/31/14	Cafeteria	kitchen	Plumbing
Bolton HS (0035)	Water running from under the wall again. Joe thought he had it fixed, but it is happening again.	2/6/14	Cafeteria		Plumbing
Bolton HS (0035)	please check the dishwasher in lab 210 not working	2/6/14	Classroom	lab210	Plumbing

Bolton HS (0035)	the sink in drama room 1 is making a loud noise	2/6/14	Classroom	drama room1	Plumbing
Bolton HS (0035)	the urinal boys restroom east 2n floor stopped up.	2/10/14	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	the sink in restroom of varsity gym lobby i leaking	2/11/14	Gym	varsity gym lobby	Plumbing
Bolton HS (0035)	the sink in custodial closet main building is leaking	2/11/14		custodial closet	Plumbing
Bolton HS (0035)	Video sewer in kitchen	2/13/14			Plumbing
Bolton HS (0035)	please caulk the sinks in varsity gym restroom	2/13/14	Gym	varsity gym lobby	Plumbing
Bolton HS (0035)	toilet seat in womens restroom cafeteria is broken	2/13/14	Restroom (Girls)	cafeteria	Plumbing
Bolton HS (0035)	the two toilets in custodial lounge main building keep running will not shut off.	2/21/14	Restroom (Boys)	custodial lounge	Plumbing

Bolton HS (0035)	the water cooler main building 1st floor by 106 is leaking	2/27/14	Hallway/Corridor	main bldg 1st floor	Plumbing
Bolton HS (0035)	back flow in m108 is leaking and making a noise	3/6/14	Classroom	lab108	Plumbing
Bolton HS (0035)	the sink in the restroom hosa classroom votech keeps running	3/7/14	Restroom (Girls)	hosa votech	Plumbing
Bolton HS (0035)	please repair the handal to toilet in boys restroom main 1st floor broken	3/21/14	Restroom (Boys)	main bldg 1st floor	Plumbing
Bolton HS (0035)	Sewer to the forced main is stopped up.	3/21/14			Plumbing
Bolton HS (0035)	Faucet will not turn off properly.	3/25/14	Cafeteria		Plumbing
Bolton HS (0035)	toilet in boys restroom south 1st floor is leaking.	3/26/14	1st Floor	south building	Plumbing
Bolton HS (0035)	the sink in m201 is leaking art room	11/7/13	Classroom	m201	Plumbing

Bolton HS (0035)	Please winterize the following sprinkler system Front Lawn.	11/12/13			Plumbing
Bolton HS (0035)	Please winterize the following sprinkler system Football Field.	11/12/13			Plumbing
Bolton HS (0035)	Please winterize the following sprinkler system Soccer Field.	11/12/13			Plumbing
Bolton HS (0035)	please repair the toilet in sped room 133 the student kicked the toilet loose from floor will need to be resealed and remounted	11/13/13	Classroom	north building 1st floor 133	Plumbing
Bolton HS (0035)	the urinal boys locker room old gym is leaking	11/18/13	Gym	old gym	Plumbing
Bolton HS (0035)	the urinal boys restroom main building wont flush	11/18/13	Restroom (Boys)	main bldg	Plumbing
Bolton HS (0035)	toilet in boys restroom south 2nd floor by study hall is stopped up	11/20/13	Restroom (Boys)	south building	Plumbing
Bolton HS (0035)	The faucet in the back room of lab 108 leaks when the water is running.	7/11/13			Plumbing

Bolton HS (0035)	sink in boys restroom main 1st floor keeps running	7/22/13	Restroom (Boys)	main building	Plumbing
Bolton HS (0035)	please repair the sprinkler on football field zone 1 does not pop up	7/30/13	Athletic Field	football	Plumbing
Bolton HS (0035)	the toilet in child care votech building keeps running	7/31/13	Classroom	childcare votech	Plumbing
Bolton HS (0035)	we have a serious water leak in front campus north drive close to fire station	8/7/13		FRONT CAMPUS	Plumbing
Bolton HS (0035)	the toilet in girls restroom south 1st floor next to s115 is leaking	8/8/13	Restroom (Girls)	south bldg1st	Plumbing
Bolton HS (0035)	the sink in artroom m201 is is stopped up tried to use the plunger but nothing .it might the trap	8/8/13	Classroom	m201	Plumbing
Bolton HS (0035)	please repair the turrets in lab 108 one is broken off and needs to be repaired	9/25/13	Classroom	m1o8	Plumbing
Bolton HS (0035)	the toilet in boys restroom main building is stopped up .tried to plunge not no good	9/27/13	Restroom (Boys)	main bldg	Plumbing

Bolton HS (0035)	restrooms boys both toilets are stopped up	10/1/13	Restroom (Boys)	main bldg	Plumbing
Bolton HS (0035)	toilet in boys restroom south 2nd floor is stopped up	10/1/13	Restroom (Boys)	south building	Plumbing
Bolton HS (0035)	toilet in boys restroom main building 2nd floor is stopped up	10/1/13	Restroom (Boys)	main bldg	Plumbing
Bolton HS (0035)	please repair the handles to faucet to sink in boys restroom broken will not turn off handles just keep turning.	10/3/13	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	there is a second faucet in boys restroom east building 2nd floor broken will not turn on stuck.	10/3/13	Restroom (Boys)	east building 2ndfloor	Plumbing
Bolton HS (0035)	please repair the dishwasher in kitchen has a really bad leak	10/7/13	Kitchen	kitchen	Plumbing
Bolton HS (0035)	freshman locker room varsity gym there are 2 urinals that are stopped up	10/9/13	Gym	varsity gym	Plumbing
Bolton HS (0035)	sewer backing up north building	10/16/13		outside north	Plumbing

Bolton HS (0035)	condensate leak in room 225N per randy tate 873-8156	10/17/13			Plumbing
Bolton HS (0035)	please repair broken sprinkler head on baseball field	10/18/13	Athletic Field	baseball field	Plumbing
Bolton HS (0035)	there are 2 sprinkler heads on baseball field that need to be lowered see coach for questions	10/18/13	Athletic Field	baseball field	Plumbing
Bolton HS (0035)	the toilet in girls restroom south 2nd floor by study hall is leaking	10/18/13	Restroom (Girls)	south bldg2nd fl	Plumbing
Bolton HS (0035)	the toilet in boys restroom main building 2nd floor is stopped up	10/24/13	Restroom (Boys)	main bldg	Plumbing
Bolton HS (0035)	the toilet in girls restroom south building 2nd floor is leaking	10/25/13	Restroom (Girls)	south building	Plumbing
Bolton HS (0035)	please repair the faucet in lab 108 broken . if possible need an estimate adminstraton please	10/25/13	Classroom	lab108	Plumbing
Bolton HS (0035)	Toilet not working properly.	10/25/13	Cafeteria		Plumbing

Bolton HS (0035)	please check the gas valves to lab in m108 had a smell of gas in room i checked on friday please see me for questions	10/28/13	Classroom	lab108	Plumbing
Bolton HS (0035)	please unstop the sink in auditorum back stage	10/28/13	Auditorium	auditorum	Plumbing
Bolton HS (0035)	please repair the toilet in theatre back stage broken and stopped up	10/28/13	Auditorium	auditorum	Plumbing
Bolton HS (0035)	demo plumbing in main 212	10/29/13	Classroom	lab212	Plumbing
Bolton HS (0035)	we have a roof leak in east building 2nd floor catwalk& votech hall	4/4/14	2nd Floor	cat walk east building	Roof
Bolton HS (0035)	we have a really bad roof leak in theatre lobby and also lobby of old gym and girls locker room varsity gym there are 4	5/14/14	Hallway/Corridor	theatre lobby	Roof
Bolton HS (0035)	roof leak in north 226	5/14/14	Classroom	n226	Roof
Bolton HS (0035)	please repair or replace the loose and missing shingles outside south building same ones as before	5/30/14		south building	Roof

Bolton HS (0035)	roof leak in cafeteria front of serving line	6/30/14	Cafeteria	serving line	Roof
Bolton HS (0035)	roof leak north building 223 water everywhere	6/30/14	Classroom	north building	Roof
Bolton HS (0035)	please repair the roof leak to concession on baseball field still leaks	8/29/13	Athletic Field	baseball	Roof
Bolton HS (0035)	Repair as needed	9/11/13	Gym		Roof
Bolton HS (0035)	please repair the roof leak cafeteria . and in cafeteria so that i can get the out side repaired	9/13/13	Cafeteria	out side cafeteria	Roof
Bolton HS (0035)	please replace shingles to roof south building some are missing and it is cracking looks really bad when people visit or drive by	7/31/13		south building	Roof
Bolton HS (0035)	roof leak old gym about middle ways	1/14/14	Gym	old gym	Roof
Bolton HS (0035)	roof leak theatre lobby close to stairs	1/14/14	Auditorium	theatre lobby	Roof

Bolton HS (0035)	roof leak in room s215 south building	1/14/14	Classroom	s215	Roof
Bolton HS (0035)	roof leak in child care restroom votech building	11/22/13	Classroom	childcare votech	Roof
Bolton HS (0035)	roof leak south 215	11/22/13	Classroom	south building	Roof
Bolton HS (0035)	roof leak in old gym boys locker room	12/9/13	Gym	old gym	Roof
Bolton HS (0035)	roof leak varsity gym	12/9/13	Gym	varsity gym	Roof
Bolton HS (0035)	roof leak in hall south building 2nd floor front 213	12/9/13	Hallway/Corridor	south building	Roof
Bolton HS (0035)	roof leak in n230	12/9/13	Classroom	n230	Roof
Bolton HS (0035)	roof leak north building 2nd floor front of room 223	2/5/14	Hallway/Corridor	north building 2ndfloor	Roof

Bolton HS (0035)	roof leak in north building hall 2nd floor inn front of boys restroom	2/5/14	2nd Floor	north building	Roof
Bolton HS (0035)	roof leak in hall north building 2nd floor room 228	2/5/14	2nd Floor	north building 2ndfloor	Roof
Bolton HS (0035)	we have a really bad roof leak in theatre lobby at bottom of stairs and also top of stairs	2/5/14	1st Floor	theatre lobby	Roof
Bolton HS (0035)	we have 2 roof leaks in lobby of varsity gym please see me for location	2/5/14	Gym	varsity gym lobby	Roof
Bolton HS (0035)	roof leak in votech hall right in front of cosmostlogy classroom	2/5/14	Hallway/Corridor	votech cosmostlogy	Roof
Bolton HS (0035)	roof leak in home economic 2 right above her desk	2/5/14	Classroom	home economic2	Roof
Bolton HS (0035)	roof leak in cafeteria on the south end	2/5/14	Cafeteria	cafeteria	Roof
Bolton HS (0035)	roof leak in old gym see me for location	2/5/14	Gym	old gym p.e	Roof

Bolton HS (0035)	roof leak in boys locker room old gym same as last time	2/5/14	Gym	old gym p.e	Roof
Bolton HS (0035)	roof leak in girls locker room old gym	2/5/14	Gym	old gym p.e	Roof
Bolton HS (0035)	we have roof leaks in the following areas Votech 3 in medzine hall there hosa votech hall front of cosmostlogy. South building 121-214 classroom hall	3/7/14	Classroom	several areas	Roof
Bolton HS (0035)	roof leak in home economics 2 back of classroom	10/31/13	Classroom	home economic2	Roof
Bolton HS (0035)	roof leak s215 has a roof leak front of room	11/1/13	Classroom	south building	Roof
Bolton HS (0035)	roof leak in varsity gym near equipment room	11/1/13	Gym	varsity gym	Roof
Bolton HS (0035)	roof leak old gym wrestling room	11/12/13	Gym	old gym	Roof
Bolton HS (0035)	we have several roof leaks in votech building the really bad one is in storage room and cosmostlogy . the other is in the hall just outside hosa classroom	7/23/13	1st Floor	votech building	Roof

Bolton HS (0035)	roof leak in cafeteria right by serving line	7/23/13	Cafeteria	serving line	Roof
Bolton HS (0035)	north 233 has a roof leak	9/24/13	Classroom	n233	Roof
Bolton HS (0035)	roof leak in main hall 2nd floor by 200	9/24/13	Hallway/Corridor	main hall	Roof
Bolton HS (0035)	roof leak in room n231 right above the wooden bookshelf	10/1/13	Classroom	north building	Roof
Bolton HS (0035)	roof leak varsity gym just as you walk in	10/1/13	Basketball Court	varsity	Roof
Bolton HS (0035)	roof leak girls lockroom varsity gym just as you walk in	10/1/13	Auxiliary Gym	kocker room	Roof
Bolton HS (0035)	roof leak in varsity gym	10/18/13	Gym	varsity gym	Roof
Bolton HS (0035)	please repair the fence on band practice field broken and part is laying on the ground.	5/2/14		band pratice field	Sheet Metal

Bolton HS (0035)	locker 1147 is broken the door is missing south building 2nd floor by study hall	8/23/13	Hallway/Corridor	south hall	Sheet Metal
Bolton HS (0035)	Disconnect vent on old water heater and reconnect new heater	9/16/13			Sheet Metal
Bolton HS (0035)	PLEASE REPAIR LOCKER 698 BROKEN WILL NOT LATCH SEE ME FOR QUESTIONS	12/4/13	Hallway/Corridor	main bldg2nd floor	Sheet Metal
Bolton HS (0035)	in the front campus north side near flag pole there are a couple of drains they have metal covers over them. the covers are starting to separte	12/10/13		FRONT CAMPUS	Sheet Metal
Bolton HS (0035)	if possible i need the grill to hvac in boys restrom soith building replaced . some how it was knock out and it was bent . i was able to get it back in and it	12/12/13	Restroom (Boys)	south building	Sheet Metal
Bolton HS (0035)	please repair the bleachers in varsity gym the small side will not roll out checked the breaker and it was ok	2/18/14	Gym	varsity gym	Sheet Metal
Bolton HS (0035)	please repair the railing to bleacher on football field home side it was broken by a large tree branch fell during the ice storm	3/12/14		football field	Sheet Metal
Bolton HS (0035)	please repair the fence around the tennis courtyard it was broken when a large tree branch fell from the ice storm	3/12/14	Athletic Field	tennis court	Sheet Metal

Bolton HS (0035)	please repair locker 472 main will not lock	11/6/13	Hallway/Corridor	main bldg	Sheet Metal
Bolton HS (0035)	Make metal for roofers (see Ricky Norman)	11/7/13			Sheet Metal
Bolton HS (0035)	please repair the latch to the fire extinguisher box east building the latch is broken if i had a latch i could fix it myslef	11/7/13		east building	Sheet Metal
Bolton HS (0035)	please repair locker 644 door broken	11/7/13	Hallway/Corridor	main bldg2nd floor	Sheet Metal
Bolton HS (0035)	main building 2nd floor locker number 711 will not open broken student can not get his supplies out	10/3/13	Hallway/Corridor	main bldg	Sheet Metal
Bolton HS (0035)	install aluminum pieces on back doors of cafeteria	10/14/13			Sheet Metal
Bolton HS (0035)	please repair the chain link gate down the right field side .it will not close	10/18/13	Athletic Field	baseball field	Sheet Metal
Bolton HS (0035)	please repair the gate to green house it is broken and bent . i think someone backed in to it	10/18/13		green house	Sheet Metal

Bolton HS (0035)	in the main building we have 14 lockers that are broken. please see me for locker numbers	10/23/13	Hallway/Corridor		Sheet Metal
Bolton HS (0035)	in the east building we have 1 locker that is broken please see me	10/23/13	Hallway/Corridor	north building	Sheet Metal
Bolton HS (0035)	in the south building we have 13 lockers that need repair .please see me	10/23/13	Hallway/Corridor	south building	Sheet Metal
Bolton HS (0035)	in the north building we have 3 lockers that are broken. see me	10/23/13	Hallway/Corridor	north building	Sheet Metal
Bolton HS (0035)	attention john smith would like to request 40 lockers for auto mechanic	10/24/13		auto shop	Sheet Metal
Bolton HS (0035)	please repair the fence around greenhouse . someone has backed into it	10/25/13		green house	Sheet Metal

Count of Craft	Craft							
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Bond Bldg - Admin (8805)	3	15	39	16	1	17	1	92
Grand Total	3	15	39	16	1	17	1	92

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Bond Bldg - Admin (8805)	Need bad network jack replaced. Port V066	5/20/14	2nd Floor	Renee' Dowell	Cabling
Bond Bldg - Admin (8805)	Locate and connect wiring for main DEC fax machine #416-7634. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	9/12/13	1st Floor	front office	Cabling
Bond Bldg - Admin (8805)	Move and connect TTDY phone to front office area. (416-0471)	9/12/13	Administration Area	B. Leaks	Cabling
Bond Bldg - Admin (8805)	Front main entrance door not closing properly.	9/12/13	1st Floor	Front Entrance	Carpentry
Bond Bldg - Admin (8805)	Entrance door coming off.	5/21/14	Restroom (Boys)	Large Men R/R	Carpentry
Bond Bldg - Admin (8805)	REAR ENTRANCE DOOR TO BLDG-NOT CLOSING, WON'T BE ABLE TO SECURE- PLANT MGR NEAL 416-0600 KLR	11/14/13			Carpentry
Bond Bldg - Admin (8805)	Repair damaged wall.	2/4/14	1st Floor	Breakroom	Carpentry

Bond Bldg - Admin (8805)	Repair cabinet and counter top.	2/18/14	1st Floor	breakroom	Carpentry
Bond Bldg - Admin (8805)	Repair broken door.	3/21/14	Administration Area	1st fl.	Carpentry
Bond Bldg - Admin (8805)	Replace cracked door glass.	7/10/13	1st Floor	Back entrance door	Carpentry
Bond Bldg - Admin (8805)	Plant Manager need assistance with breaking down metal shelves on the 1st floor and assemble them on 4th floor. Per Daniel Hurdle.	8/20/13	1st Floor	Clue office	Carpentry
Bond Bldg - Admin (8805)	Repair broken door hinge.	8/23/13	3rd Floor	S. Flowers	Carpentry
Bond Bldg - Admin (8805)	Repair loose base board.	8/29/13	Hallway/Corridor	Back	Carpentry
Bond Bldg - Admin (8805)	Repair damage wall.	8/29/13	Restroom (Boys)	Large Men	Carpentry
Bond Bldg - Admin (8805)	Replace bracket to hold paper towel holder on the wall in restroom.	9/3/13	Restroom (Boys)	Large restroom	Carpentry

Bond Bldg - Admin (8805)	Door not closing correctly.	10/22/13	1st Floor	Back entrance door	Carpentry
Bond Bldg - Admin (8805)	DOOR - BACK ENTRY REP HARDWARE TORN OFF - DUE TO A BREAKIN - PM/NEAL 416-0600	10/15/13			Carpentry
Bond Bldg - Admin (8805)	Repair broken door on rolling filing system. Employees can't get to Special Ed. files. Need repaired ASAP.(URGENT)	9/19/13	1st Floor	Special Ed Records Room	Carpentry
Bond Bldg - Admin (8805)	per ms neal 416-0600 2nd floor AHU making loud noise	5/5/14			Electrical
Bond Bldg - Admin (8805)	BURNING SMELL ON 2ND FLR - PM DON'T KNOW WHERE IT'S COMING FROM - PM/KNELL 416-0600	5/27/14			Electrical
Bond Bldg - Admin (8805)	Install new Emerson drive	6/4/14			Electrical
Bond Bldg - Admin (8805)	Light out bad ballast. Contractors changed light. I was told per Tony Wright to do a work order for the ballast.	1/6/14	3rd Floor	Ceiling	Electrical
Bond Bldg - Admin (8805)	HEAT ENTIRE 1ST FLR-NOT HEATING- PLANT MGR NEAL 416-0600 KLR	1/7/14			Electrical

Bond Bldg - Admin (8805)	per Ms. Gina Neal 416-0600 1st floor SE side of building is blowing cold air	1/28/14				Electrical
Bond Bldg - Admin (8805)	UNIT NOT HEATING IN BREAK-RM 1ST FLR. PLANT MGR-NEAL/416.5250	2/4/14				Electrical
Bond Bldg - Admin (8805)	HEAT ENTIRE 1ST FLR-KEEPS SHUTTING OFF- PLANT MGR NEAL 416-0600 KLR	2/10/14				Electrical
Bond Bldg - Admin (8805)	1st floor AIR HANDLER is NOT COMING ON per Gina Neal, Plant Mgr. 416.0600	3/4/14				Electrical
Bond Bldg - Admin (8805)	AHU THAT SERVES 2ND, 3RD, & 4TH FLRS-KEEPS CUTTING OFF-PLANT MGR NEAL 416-0600 KLR	3/12/14				Electrical
Bond Bldg - Admin (8805)	Repair breaker for outside lighting. Breaker will not stay on. There's no back lights working. See Plant Manger. (URGENT)	4/7/14	Parking Lot	Back parking lot		Electrical
Bond Bldg - Admin (8805)	Two lights out on one pole.	4/15/14	Parking Lot	Back lot		Electrical
Bond Bldg - Admin (8805)	per ms neal 416-0600 AHU ABB Drive not coming on	4/17/14				Electrical

Bond Bldg - Admin (8805)	Two lights out bad ballast.	7/9/13	2nd Floor	By Erica Jones	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	7/10/13	2nd Floor	By Margie Bell	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	7/22/13	3rd Floor	By Dr. Bailey	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	7/31/13	Administration Area	4th fl.	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	7/31/13	3rd Floor	3rd fl. Ms. Flowers	Electrical
Bond Bldg - Admin (8805)	burning smell in electrical closet 416-0600 per Ms. Neal	8/13/13			Electrical
Bond Bldg - Admin (8805)	Two ballast out.	9/3/13	Administration Area	4th Fl. By Ms. Orr	Electrical
Bond Bldg - Admin (8805)	Four lights bad ballast.	9/6/13	Administration Area	4th fl. Dr. Marsh Office	Electrical

Bond Bldg - Admin (8805)	Light out bad ballast.	9/30/13	Administration Area	Cathy Lane 4th Fl.	Electrical
Bond Bldg - Admin (8805)	Eleven bad ballast. Please see Plant Manager.	10/10/13	3rd Floor	3rd floor	Electrical
Bond Bldg - Admin (8805)	Light flashing off and on. Bad ballast.	11/5/13	Administration Area	4th fl. By D. Marshall	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	11/7/13	3rd Floor	By C. Wright	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	11/7/13	2nd Floor	K. Simmons	Electrical
Bond Bldg - Admin (8805)	Two lights out. High ceiling.	11/7/13	3rd Floor	ceiling	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	11/12/13	Administration Area	4th fl. Danielle Bourgeois	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	11/12/13	Administration Area	4th Fl. Dr. Johnson	Electrical

Bond Bldg - Admin (8805)	Light out bad ballast.	10/21/13	2nd Floor	large women restroom	Electrical
Bond Bldg - Admin (8805)	Three poll lights in back of building and one by back door out. One pole light in front of building out.	10/22/13	Grounds	Back and front of building	Electrical
Bond Bldg - Admin (8805)	UNIT COMING ON IN MS. MOORE 1ST FLR. PLANT MGR- NEAL/416.5250	10/25/13			Electrical
Bond Bldg - Admin (8805)	Emergency light not working.	10/29/13	Administration Area	4th fl. by K. Reed	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	10/29/13	2nd Floor	By T. Freeman	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	10/31/13	3rd Floor	By S. Collins	Electrical
Bond Bldg - Admin (8805)	Nine lights out bad ballast. All lights has been tagged after being checked. If Engineer is not available you will see tags on each light cover	11/4/13	Administration Area	North side of 1st fl.	Electrical
Bond Bldg - Admin (8805)	Light out bad ballast.	11/4/13	Administration Area	1st fl. Dr. Tormina office	Electrical

Bond Bldg - Admin (8805)	46807- Need three boxes of rapid start lamps.	8/21/13	Administration Area	Entire Building	Electrical
Bond Bldg - Admin (8805)	Need 12 75 watt light bulbs.	1/27/14	1st Floor	Plant Engineers Office	Electrical
Bond Bldg - Admin (8805)	Monthly - Filter-Bond Building - Refer to PM schedule details.	5/5/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	CHECK SOUTH CHILLER. WILL NOT START.	4/25/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	RE-WIRE SOUTH CHILLER WHERE BURNED. INSTALL NEW RESISTERS AND CONTACTORS.	5/1/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	per ms neal 416-0600 chiller needs to be reset	4/30/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	Monthly - Oil Lube & Belt-Bond Building - Refer to PM schedule details.	9/15/13			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	CHILLER-2 MECH RM- IN ALARM-PLANT MGR TODD 416-0600 KLR	6/17/14			Heating/Ventilation /Air Conditioning

Bond Bldg - Admin (8805)	Yearly - Air Handler Cleanings-Bond Building - Refer to PM schedule details.	11/17/13			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	Monthly - Filter-Bond Building - Refer to PM schedule details.	1/6/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	purchase drive	2/12/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	CHILLER-2 MECH RM- NOT COMING ON- PLANT MGR NEAL 416-0600 KLR	2/13/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	repair chiller #1	3/26/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	Monthly - Oil Lube & Belt-Bond Building - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	per ms neal 416-0600 chiller #2 not coming on	4/17/14			Heating/Ventilation /Air Conditioning

Bond Bldg - Admin (8805)	Monthly - Filter-Bond Building - Refer to PM schedule details.	9/9/13				Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	chiller is down per Ms. Gina Neal 416-0600	10/1/13				Heating/Ventilation /Air Conditioning
Bond Bldg - Admin (8805)	MUD, TAPE AND PAINT NEW SHEETROCK IN OFFICE	12/9/13				Painting
Bond Bldg - Admin (8805)	Large women restroom last stall, commode will not flush. Have to flush a lot of times before it flushes.	5/12/14	3rd Floor	Large women		Plumbing
Bond Bldg - Admin (8805)	Sink leaking.	5/20/14	1st Floor	Large women R/R		Plumbing
Bond Bldg - Admin (8805)	Second faucet broken.	11/13/13	2nd Floor	Large women		Plumbing
Bond Bldg - Admin (8805)	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13				Plumbing
Bond Bldg - Admin (8805)	Third stall running water.	1/9/14	2nd Floor	Large women R/R		Plumbing

Bond Bldg - Admin (8805)	Sink leaking.	1/17/14	Administration Area	Breakroom	Plumbing
Bond Bldg - Admin (8805)	First urinal when flush leaks water.	1/27/14	1st Floor	Large Men	Plumbing
Bond Bldg - Admin (8805)	3rd & 4th floor women's restrooms - water from sink faucet & in commode are yellow	1/31/14			Plumbing
Bond Bldg - Admin (8805)	Toilet seat broken.	2/3/14	Restroom (Boys)	4th Fl. men small R/R	Plumbing
Bond Bldg - Admin (8805)	Broken toilet seat.	2/26/14	Restroom (Boys)	4th fl small men	Plumbing
Bond Bldg - Admin (8805)	Sink leaking.	2/26/14	Restroom (Boys)	4 th fl. large men	Plumbing
Bond Bldg - Admin (8805)	Water fountain not working.	3/19/14	2nd Floor	BY RESTROOMS	Plumbing
Bond Bldg - Admin (8805)	Commode will not flush.	4/9/14	3rd Floor	Small women restroom	Plumbing

Bond Bldg - Admin (8805)	Replace flapper on commode.	4/10/14	3rd Floor	Small women R/R	Plumbing
Bond Bldg - Admin (8805)	Sink leaking.	7/31/13	2nd Floor	Large Women	Plumbing
Bond Bldg - Admin (8805)	Sink leaking.	8/28/13	Restroom (Girls)	2nd fl. Large Women	Plumbing
Bond Bldg - Admin (8805)	Commode will not flush.	10/14/13	2nd Floor	Large men	Plumbing
Bond Bldg - Admin (8805)	Roof leak.	8/1/13	Administration Area	4th fl.	Roof

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Brookmeade ES (2055) 1B	1	3	74	46	38	15	57	13	1	248
Grand Total	1	3	74	46	38	15	57	13	1	248

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Brookmeade ES (2055) 1B	replace broken floor tiles about twenty.	6/11/14	1st Floor	room127	Asbestos
Brookmeade ES (2055) 1B	provide project management for vendor to install smart boards	4/4/14			Cabling
Brookmeade ES (2055) 1B	Brookmeade -- WO 382701 - computer outlet needs replacing. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	9/11/13	1st Floor	room 112	Cabling
Brookmeade ES (2055) 1B	Install cable in Principal's office, to Mr. Ratliff (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	10/31/13	Administration Area		Cabling
Brookmeade ES (2055) 1B	Install door sweeps to prevent wind from blowing out pilot on domestic boiler.	1/22/14	1st Floor	boiler room	Carpentry
Brookmeade ES (2055) 1B	Replace door closure on front door of building, does not close when people go out causing a lack in security and safety, anyone can come in without buzzing in.	1/23/14	Administration Area	main entrance	Carpentry
Brookmeade ES (2055) 1B	WINDOW HAS CAME COMPLETELY OUT IN RM-128 PLANT MGR- JOHNSON/416.3920	2/3/14			Carpentry

Brookmeade ES (2055) 1B	Insects and other elements are coming through windows that needs to be resealed.	2/19/14	1st Floor	114- P.E. Room	Carpentry
Brookmeade ES (2055) 1B	reolace missing broken baseboard.	3/21/14	1st Floor	main hallway	Carpentry
Brookmeade ES (2055) 1B	Install bracket for window shade.	4/4/14	1st Floor	room 124	Carpentry
Brookmeade ES (2055) 1B	repair door replace hendges	4/30/14	Kitchen	kitchen storm door	Carpentry
Brookmeade ES (2055) 1B	Hang sign above front door.	7/29/13	1st Floor	outside front door	Carpentry
Brookmeade ES (2055) 1B	Cut hole on office cabinet for installation of computers wiring.	7/29/13	Administration Area	main office	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware on outside doors, for use of prek entrance and exit per fire marshall.	7/30/13	Annex	outside doors	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware for use of before and after school care entrance into building.	7/30/13	Cafeteria	room 120	Carpentry

Brookmeade ES (2055) 1B	Install 4by 4 bulletin board (1)	7/30/13	1st Floor	stage office	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware	8/9/13	Stairway	southeast hallway	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware on doors (2)	8/9/13	1st Floor	entrance to courtyard	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware	8/9/13	1st Floor	northeast hallway	Carpentry
Brookmeade ES (2055) 1B	Bolt down bike rack to side walk in front of building (located in back of school).	8/26/13	Courtyard	front of building	Carpentry
Brookmeade ES (2055) 1B	On the steps close of the undercarriage and sides of the steps to prevent children from getting under them and getting caught or hurt.	8/30/13	Courtyard	courtyard	Carpentry
Brookmeade ES (2055) 1B	BOLTS TO WINDOW 1ST FLR NE HALL RM 128-HAVE BEEN TAKEN OFF DUE TO AN ATTEMPT BREAK-IN OVER THE WEEKEND-WILL NOT BE ABLE TO SECURE-PLANT MGR JOHNSON 416-7958 KLR	9/3/13			Carpentry
Brookmeade ES (2055) 1B	Replace window, drivers can see children using restroom as they pass by.	9/5/13	Annex	boys restroom	Carpentry

Brookmeade ES (2055) 1B	Install window guards.	9/9/13			Carpentry
Brookmeade ES (2055) 1B	Repair/replace door closure.	9/11/13	1st Floor	room 135	Carpentry
Brookmeade ES (2055) 1B	Repair/replace door closure.	9/17/13	1st Floor	teachers lounge	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware on exit door.	9/18/13			Carpentry
Brookmeade ES (2055) 1B	Install a 4by 8 bulletin board for after school program use. per principal request	9/27/13	Cafeteria	Cafeteria	Carpentry
Brookmeade ES (2055) 1B	enclose steps with plywood from bottom to top of handrails	10/4/13	Courtyard	courtyard	Carpentry
Brookmeade ES (2055) 1B	per Denise Johnson 416-7958 in the courtyard the windows on main hallway are broken due to vandalism	10/28/13			Carpentry
Brookmeade ES (2055) 1B	Repair cylindar, door will not open.	11/6/13	1st Floor	room 125	Carpentry

Brookmeade ES (2055) 1B	Door not closing has dropped down please shave down to be able to close.	11/6/13	Kitchen	servicing area	Carpentry
Brookmeade ES (2055) 1B	Replace ceiling tile . special cut (1)	11/21/13	1st Floor	classroom 111	Carpentry
Brookmeade ES (2055) 1B	replace ceiling tile (1) special cut	11/21/13	1st Floor	teachers Lounge	Carpentry
Brookmeade ES (2055) 1B	Need to get restrooms stall doors adjusted. Doors do not close properly (Throughout the bldg.)	11/25/13	1st Floor	restrooms	Carpentry
Brookmeade ES (2055) 1B	Install panic hardware on exit door.	11/27/13			Carpentry
Brookmeade ES (2055) 1B	Repair stall door, broken hendge	12/9/13	1st Floor	northeast hallway girlsrestroom	Carpentry
Brookmeade ES (2055) 1B	Install a window in cafetria door, it is the entrance and exit for before and after care, no windows presently in careteria so employees cannot see person outside, safety hazard for children and employees, because it get dark outside	12/11/13	1st Floor	cafetria	Carpentry
Brookmeade ES (2055) 1B	Replace tile in room 107 it is a special cut around in speaker system.	12/16/13	1st Floor	room 107	Carpentry

Brookmeade ES (2055) 1B	Replace ceiling tile around speaker, special cut.	12/16/13	1st Floor	109	Carpentry
Brookmeade ES (2055) 1B	Replace ceiling tile around speaker, special cut.	12/16/13	1st Floor	112	Carpentry
Brookmeade ES (2055) 1B	replace and secure pane in window (2).	12/23/13	Annex	room 14	Carpentry
Brookmeade ES (2055) 1B	replace ceiling tile around drain pipe.	5/29/14	1st Floor	room111	Carpentry
Brookmeade ES (2055) 1B	replace missing coldbase.	5/29/14	1st Floor	room 111	Carpentry
Brookmeade ES (2055) 1B	Replace missing cork board surrounding new installation of smart board.	6/12/14	1st Floor	room 137	Carpentry
Brookmeade ES (2055) 1B	replace mix match cold base.	5/29/14	1st Floor	room 109	Carpentry
Brookmeade ES (2055) 1B	replace light cover discolored/stained clover	5/29/14	1st Floor	room 109	Carpentry

Brookmeade ES (2055) 1B	replace mix match cold base	5/29/14	1st Floor	room 107	Carpentry
Brookmeade ES (2055) 1B	replace cold base	5/29/14	1st Floor	teachers lounge	Carpentry
Brookmeade ES (2055) 1B	replace missing cold base under sink.	5/29/14	1st Floor	main hallway near cafeteria	Carpentry
Brookmeade ES (2055) 1B	replace cold base next to stage.	5/29/14	1st Floor	cafeteria	Carpentry
Brookmeade ES (2055) 1B	replace missing floor tile in hallway.	5/29/14	1st Floor	main hallway	Carpentry
Brookmeade ES (2055) 1B	replace damaged coldbase	5/30/14	1st Floor	124	Carpentry
Brookmeade ES (2055) 1B	replace mix matched cold base	5/30/14	1st Floor	room 125	Carpentry
Brookmeade ES (2055) 1B	Install cold base along back wall	5/30/14	Library	northeast hallway	Carpentry

Brookmeade ES (2055) 1B	replace broken and missing floor tile in hallway	5/30/14	1st Floor	northeast hallway	Carpentry
Brookmeade ES (2055) 1B	Replace broken and damaged cold base in hallway.	5/30/14	1st Floor	Nrotheast hallway	Carpentry
Brookmeade ES (2055) 1B	Replace broken and missing floor tile in classrooms.	5/30/14	1st Floor	room 133	Carpentry
Brookmeade ES (2055) 1B	repair holes in the wall (6)	5/30/14	1st Floor	room 136	Carpentry
Brookmeade ES (2055) 1B	Replace missing and damages floor tiles	5/30/14	1st Floor	room 137	Carpentry
Brookmeade ES (2055) 1B	Repair/Replace broken safety bar	6/11/14	Grounds	play ground equipment	Carpentry
Brookmeade ES (2055) 1B	Replace cork board where it is missing surrounding smartboard installation.	6/12/14	1st Floor	room 124	Carpentry
Brookmeade ES (2055) 1B	Replace missing corkboard surrounding installation of new smartboard	6/12/14	1st Floor	room 126	Carpentry

Brookmeade ES (2055) 1B	Install bulletin board strips (4) in hallway	5/23/14	1st Floor	main hallway near cafeteria	Carpentry
Brookmeade ES (2055) 1B	Replace broken door hendges in screen door of cafeteria.	5/23/14	Kitchen	kitchen	Carpentry
Brookmeade ES (2055) 1B	Replace window in 3rd window form the right	5/23/14	1st Floor		Carpentry
Brookmeade ES (2055) 1B	4 inch hole around pipe in room is allowing bees to come into classroom. Seal hole.	7/2/13	1st Floor	room 107	Carpentry
Brookmeade ES (2055) 1B	Repair panic hardware does not lock door when it closes, it is a outside door.	7/1/13	1st Floor	main hallway	Carpentry
Brookmeade ES (2055) 1B	Install 4by 8 bulletin (1)	7/17/13	1st Floor	room 112	Carpentry
Brookmeade ES (2055) 1B	Install (2) 4by 8 bulletin board on north east wall of cafeteria.	7/18/13	Cafetorium	room 120	Carpentry
Brookmeade ES (2055) 1B	Request 2 boxes of ceiling tiles	7/18/13	Custodial	plant managers office	Carpentry

Brookmeade ES (2055) 1B	Replace chalk board with bulletin board 4by 4 (1).	7/29/13	1st Floor	room 102	Carpentry
Brookmeade ES (2055) 1B	Replace shades (2) 44inches by 72 inches	7/29/13	1st Floor	room 105	Carpentry
Brookmeade ES (2055) 1B	Replace mix match cold base.	5/29/14	1st Floor	room112	Carpentry
Brookmeade ES (2055) 1B	Replace shades (1) 44by 72 inches	7/29/13	1st Floor	room 107	Carpentry
Brookmeade ES (2055) 1B	Replace shades (2) 44 by 72 inches	7/29/13	1st Floor	room 111	Carpentry
Brookmeade ES (2055) 1B	Replace shades (6) 44 by 72 inches	7/29/13	1st Floor	room 112	Carpentry
Brookmeade ES (2055) 1B	Requesting 20 pieces of plexiglass 6ft by 51/4 inches	7/2/13	1st Floor	s.b.e. office	Carpentry
Brookmeade ES (2055) 1B	Repair UV motor in room 108.	1/10/14			Electrical

Brookmeade ES (2055) 1B	Repair 2 heat units in Kitchen.	1/10/14			Electrical
Brookmeade ES (2055) 1B	Motor in UV making noise room 115.	1/10/14			Electrical
Brookmeade ES (2055) 1B	Replace ballast (2) in kitchen area above prep table.	1/23/14	Kitchen	kitchen	Electrical
Brookmeade ES (2055) 1B	UV NOT COMING ON IN RM-124 PLANT MGR- PATTERSON/416.3920	1/28/14			Electrical
Brookmeade ES (2055) 1B	HEAT KITCHEN AREA-NOT COMING ON-PLANT MGR JOHNSON 416-7958 KLR	2/10/14			Electrical
Brookmeade ES (2055) 1B	replace light fixture, due to water damage.	2/13/14	1st Floor	room 108	Electrical
Brookmeade ES (2055) 1B	repair ventahood, not working	2/24/14	Kitchen	kitchen	Electrical
Brookmeade ES (2055) 1B	PUMP NOT COMING ON IN BOILER RM, BLDG IS COLD PLANT MGR- JOHNSON/416.3920	2/24/14			Electrical

Brookmeade ES (2055) 1B	FCU NOT COMING ON IN RM-138. PLANT MGR- JOHNSON/416.3944	2/26/14			Electrical
Brookmeade ES (2055) 1B	Set clocks to daylight savings time.	3/5/14	Administration Area	main office	Electrical
Brookmeade ES (2055) 1B	Replace exit light in cafe it is not working..	3/5/14	Kitchen	kitchen	Electrical
Brookmeade ES (2055) 1B	HEAT RM 113-NOT COMING ON-PLANT MGR JOHNSON 416-7958 KLR	3/7/14			Electrical
Brookmeade ES (2055) 1B	LIGHT - LIGHT FIXTURE IN THE CAFE AT THE SERVING AREA - HANGING DOWN, WITH WIRES EXPOSED, DANGEROUS TO STUDENT - PM/JOHNSON 416-7958	3/20/14			Electrical
Brookmeade ES (2055) 1B	Replace /repair light fixtures (2)	3/20/14	Cafeteria	Cafeteria	Electrical
Brookmeade ES (2055) 1B	Replace light fixturte covers(4)	3/20/14	Cafeteria	cafeteria	Electrical
Brookmeade ES (2055) 1B	Replace ballast (2)	3/28/14	1st Floor	boys restroom	Electrical

Brookmeade ES (2055) 1B	Replace ballast (1)	4/23/14	Cafeteria	office behind stage	Electrical
Brookmeade ES (2055) 1B	AIR COOLED CHILLER OUTSIDE BOILER RM-HAS SHUT DOWN AND WON'T COME BACK UP-SBE JOHNSON 416-7958 KLR	8/9/13			Electrical
Brookmeade ES (2055) 1B	AIR COOLED CHILLER OUTSIDE BOILER RM-NOT COMING ON-SBE JOHNSON KLR	8/12/13			Electrical
Brookmeade ES (2055) 1B	UV RM 134-NOT COOLING-PLANT MGR JOHNSON 416-7958 KLR	8/27/13			Electrical
Brookmeade ES (2055) 1B	Unit Ventilator room 114 a/c unit smoking per Denise Johnson 416-7958	9/10/13			Electrical
Brookmeade ES (2055) 1B	PUMP-2 MECH RM-NOT COMING ON-PLANT MGR JOHNSON 416-7958 KLR	10/15/13			Electrical
Brookmeade ES (2055) 1B	Replace clocks (3) not working.	10/21/13	1st Floor	main hallway	Electrical
Brookmeade ES (2055) 1B	Replace ballast (2)	10/29/13	1st Floor	classroom 106	Electrical

Brookmeade ES (2055) 1B	Replast ballast (2)	10/29/13	1st Floor	girls restroom southeast hallway	Electrical
Brookmeade ES (2055) 1B	Set/repair main clock in office	10/29/13	Administration Area	main office	Electrical
Brookmeade ES (2055) 1B	Repair/Set clock for daylight savings time.	11/5/13			Electrical
Brookmeade ES (2055) 1B	Replace 5 lights in cafeteria	12/19/13	Cafeteria	cafeteria	Electrical
Brookmeade ES (2055) 1B	Replace ballast (1)	12/27/13	Administration Area	room 104	Electrical
Brookmeade ES (2055) 1B	replace ballast(1)	12/27/13	Annex	hallway	Electrical
Brookmeade ES (2055) 1B	Replace ballast (1)	12/27/13	1st Floor	room107	Electrical
Brookmeade ES (2055) 1B	Replace ballast(1)	12/27/13	Cafeteria	room 120	Electrical

Brookmeade ES (2055) 1B	Replace ballast (3)	12/27/13	1st Floor	room `134	Electrical
Brookmeade ES (2055) 1B	Replace ballast (2)	12/27/13	1st Floor	room 125	Electrical
Brookmeade ES (2055) 1B	replace ballast (1)	12/27/13	1st Floor	room 124	Electrical
Brookmeade ES (2055) 1B	replace ballast (1)	12/27/13	1st Floor	room 137	Electrical
Brookmeade ES (2055) 1B	Replace ballast (1)	12/27/13	1st Floor	room 137	Electrical
Brookmeade ES (2055) 1B	Unit is NOT COMING ON in Room 107 and CAFETERIA per Denise Johnson, Plant Mgr. 416.7958	1/6/14			Electrical
Brookmeade ES (2055) 1B	per Ms Johnson 416-7958 the following rooms are not coming on at all rm 120 which is the cafeteria, rooms, 114, 115, 15, 108, 138, 107	1/8/14			Electrical
Brookmeade ES (2055) 1B	replace electrical outlet cover and repair outlet	5/30/14	1st Floor	room125	Electrical

Brookmeade ES (2055) 1B	Repair electrical outlet	5/30/14	1st Floor	room 136	Electrical
Brookmeade ES (2055) 1B	LIGHTS HAVE NO POWER IN MAIN HALL (TECH IS ALREADY ON SITE) PLANT MGR- JOHNSON/416.3920	5/22/14			Electrical
Brookmeade ES (2055) 1B	Check/Repair u vent motor switch, not coming on room 111.	5/23/14	Classroom		Electrical
Brookmeade ES (2055) 1B	3-UV NOT COMING ON IN RM-116(004) RM-138(085) RM-129(078). SBE-JOHNSON/416-3920	7/19/13			Electrical
Brookmeade ES (2055) 1B	Requesting (4) cases of bulbs hg-lamp F32T8/ADV841/EW 25 LAMPS 28 WATTS 5 00 46677 147346	7/29/13	1st Floor	Plant manager office	Electrical
Brookmeade ES (2055) 1B	Replace defective TXV power element on chiller.	5/13/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Check out chiller both refrigeration circuits	5/7/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	FCU RM 114-UNIT IS SMOKING PLANT MGR JOHNSON 416-7958 KLR	1/22/14			Heating/Ventilation /Air Conditioning

Brookmeade ES (2055) 1B	UV NOT COMING ON IN RM-24. PLANT MGR- JOHNSON/416.3920	1/23/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	HEAT CAFE & RM 138-BOTH NOT HEATING-PLANT MGR PATTERSON 416-7958 KLR	1/29/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	UV RM 113 NE HALL-NOT HEATING-PLANT MGR JOHNSON 416-7958 KLR	1/30/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	UNIT is NOT HEATING in the MAIN OFFICE AREA per Mr. Whitelow, Plant Mgr. 416.3920	2/7/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	replace/repair themastat.	2/13/14	Kitchen	kitchen	Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	HEAT KITCHEN AREA-CONSTANTLY RUNS, NOT CYCLING OFF-PLANT MGR WHITELOW KLR	2/19/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	BOILER-1 MECH RM-POP OFF VALVE-LEAKING-PLANT MGR JOHNSON 416-3920 KLR	3/20/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning

Brookmeade ES (2055) 1B	reset chiller	4/9/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	put everything back in auto	4/14/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	chiller down	4/22/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	chiller down	5/1/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Monthly - Oil Lube & Belt-Brookmeade Elementary - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Monthly - Filter-Brookmeade Elementary - Refer to PM schedule details.	5/3/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	chiller down	5/5/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	per ms johnson 416-7958 chiller making a terrible noise and just shut down	5/5/14			Heating/Ventilation /Air Conditioning

Brookmeade ES (2055) 1B	Monthly - Filter-Brookmeade Elementary - Refer to PM schedule details.	8/31/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	PUMP # NOT COMING ON (053) FOR NORTHEAST-END PLANT MGR-JOHNSON/416.3920	9/3/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Unit Ventilator Room 116 not coming on per Ms. Johnson 416-7958	9/4/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Per Denise Johnson 416-7958 unit ventilator room 116 not cooling	9/10/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Monthly - Oil Lube & Belt-Brookmeade Elementary - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	replace or repair pump for boiler	10/24/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	install new pump	11/4/13			Heating/Ventilation /Air Conditioning

Brookmeade ES (2055) 1B	boiler down	12/23/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	Monthly - Filter-Brookmeade Elementary - Refer to PM schedule details.	1/4/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	per Denise Johnson 416-7958 pump #2 (004053) is not running therefore over 1/2 of the building is cold (NE hall - cafeteria, classrooms)	1/7/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	rms not heating	1/9/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	per patterson 416-3920 room 13 not cooling	5/7/14			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	CHILLER 004-047 -NOT COMING - SBE/JOHNSON 416-7958	7/17/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	PUMP TO THE CHILLER IS NOT COMING ON. SBE JOHNSON 416-7958	7/18/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	rm 134 adjust fan wheels	7/23/13			Heating/Ventilation /Air Conditioning

Brookmeade ES (2055) 1B	rm 115 needs motor and bearing	7/23/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	rm 138 not cooling	7/23/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	rm 116 replace motor	7/23/13			Heating/Ventilation /Air Conditioning
Brookmeade ES (2055) 1B	paint classroom	7/1/13	1st Floor	room 131	Painting
Brookmeade ES (2055) 1B	Paint room 104	7/1/13	1st Floor	room 104/conference room	Painting
Brookmeade ES (2055) 1B	Paint room	7/1/13	1st Floor	room 125	Painting
Brookmeade ES (2055) 1B	paint outside of building.	5/20/14	Grounds	outside of school building	Painting
Brookmeade ES (2055) 1B	paint restroom, remove grifeti	5/20/14	Grounds	outside of school building	Painting

Brookmeade ES (2055) 1B	Paint lines on parking lot	5/28/14	Parking Lot	parking lot	Painting
Brookmeade ES (2055) 1B	paint room some damage from water damage.	5/29/14	1st Floor	111	Painting
Brookmeade ES (2055) 1B	paint under marker board where old board was located.	6/12/14	1st Floor	room 136	Painting
Brookmeade ES (2055) 1B	Paint white 8 panels that cover existing sky lights. To support James Hammett.	1/13/14	Cafetorium		Painting
Brookmeade ES (2055) 1B	Paint/prime (silver), 6 expand metal window guards for Danny W.	9/5/13	1st Floor		Painting
Brookmeade ES (2055) 1B	health inspector noted that "wall in room has damage/waterdamage-repair/replace", requesting that room be scraped and painted due to peeling paint this is a pre k classroom.	10/22/13	Annex	room 14/16	Painting
Brookmeade ES (2055) 1B	Paint teachers lounge	7/1/13	1st Floor	teachers lounge	Painting
Brookmeade ES (2055) 1B	paint classroom	7/1/13	1st Floor	room 126	Painting

Brookmeade ES (2055) 1B	Stain new plywood for counter top in main office at Brookmeade El.	7/23/13	Administration Area		Painting
Brookmeade ES (2055) 1B	pressure wash windows	10/4/13	Courtyard	courtyard	Painting
Brookmeade ES (2055) 1B	repair drinking fountain is leaking.	1/15/14	1st Floor	northeast hallway	Plumbing
Brookmeade ES (2055) 1B	relite domestic boiler for cafeteria water.	1/22/14	Kitchen	kitchen	Plumbing
Brookmeade ES (2055) 1B	Sink stopped up	1/29/14	1st Floor	Rm. 112	Plumbing
Brookmeade ES (2055) 1B	unclog handwashing sink in pre k classroom.	1/30/14	1st Floor	classroom112	Plumbing
Brookmeade ES (2055) 1B	replace flush valve & unclog.	2/13/14	Kitchen	cafeteria staff restroom	Plumbing
Brookmeade ES (2055) 1B	Replace flush valves.	2/13/14	Kitchen	managers office	Plumbing

Brookmeade ES (2055) 1B	NO HOT WATER TO KITCHEN AREA-WILL NEED-PLANT MGR WHITELOW KLR	2/19/14			Plumbing
Brookmeade ES (2055) 1B	Light pilot hot water.	2/26/14			Plumbing
Brookmeade ES (2055) 1B	NO HOT WATER IN KITCHEN PLANT MGR- JOHNSON/416.3920	2/27/14			Plumbing
Brookmeade ES (2055) 1B	Replace broken toilet seat.	3/5/14	Annex	girls restroom	Plumbing
Brookmeade ES (2055) 1B	repair domestic boiler will not remain on the heat water for the kitchens use.	3/7/14	Kitchen	boiler room	Plumbing
Brookmeade ES (2055) 1B	flush valve sticking causing toilet to continuously flush	3/21/14	1st Floor	girls restroom northeast hallway	Plumbing
Brookmeade ES (2055) 1B	GAS SMELL KITCHEN/SERVING LINE AREA- PLANT MGR JOHNSON 416-7958 KLR	4/9/14			Plumbing
Brookmeade ES (2055) 1B	Repair toilet leaking from the bottom of toilet, third stall	4/15/14	1st Floor	boys restroom	Plumbing

Brookmeade ES (2055) 1B	GAS SMELL in the KITCHEN per Denise Johnson, Plant Mgr. 416.7958	4/21/14			Plumbing
Brookmeade ES (2055) 1B	leak in hallway	4/22/14	1st Floor	hallway outside of cafeteria	Plumbing
Brookmeade ES (2055) 1B	unclog sink	4/23/14	1st Floor	custodial closet	Plumbing
Brookmeade ES (2055) 1B	COMMODE B RR NE HALL 3RD STALL-CONSTANTLY OVERFLOWING-PLANT MGR JOHNSON 416-7958 KLR	4/24/14			Plumbing
Brookmeade ES (2055) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/30/13			Plumbing
Brookmeade ES (2055) 1B	Calibrate backflow tester.	7/31/13	Kitchen		Plumbing
Brookmeade ES (2055) 1B	PIPE LOWER LEVEL ANNEX BLDG-HAS BURST AND WATER EVERYWHERE-SBE JOHNSON 416-7958 KLR	8/6/13			Plumbing
Brookmeade ES (2055) 1B	Repair pipe under 3 carpartment sink, it is leaking.	8/8/13	Kitchen	kitchen	Plumbing

Brookmeade ES (2055) 1B	repair the handwashing sinks in the upper and lower hallway it not allowing enough water to flow so that the children can wash there hands.	8/8/13	Annex	hallway	Plumbing
Brookmeade ES (2055) 1B	3-COMPARTMENT SINK KITCHEN-ALL (3) SIDES STOPPED UP-SBE JOHNSON 416-7958 KLR	8/15/13			Plumbing
Brookmeade ES (2055) 1B	BURNER RANGE KITCHEN-PILOT KEEPS GOING OUT & THERE IS A GAS SMELL BY RANGE PER SBE-SBE JOHNSON 416-7958 KLR	8/15/13			Plumbing
Brookmeade ES (2055) 1B	Replace peeprap in handwashing sink flooding the floor.	8/26/13	1st Floor	northeast hallway	Plumbing
Brookmeade ES (2055) 1B	UV IS LEAKING WATER IN RM-133 PLANT MGR-JOHNSON/416.3920	9/10/13			Plumbing
Brookmeade ES (2055) 1B	Replace peeprap in three conpartment sink it is leaking.	9/11/13	Kitchen	kitchen	Plumbing
Brookmeade ES (2055) 1B	unclog floor drain.	9/12/13	Custodial Closet	northeast hallway	Plumbing
Brookmeade ES (2055) 1B	GAS LEAK IN KITCHEN AREA-PLANT MGR JOHNSON 416-7958 KLR	9/13/13			Plumbing

Brookmeade ES (2055) 1B	UV RM 114-LEAKING-PLANT MGR WHITELOW 416-3920 KLR	9/16/13			Plumbing
Brookmeade ES (2055) 1B	U/V in room 114 / 116 is leaking per Ms. Johnson 416-7958	9/17/13			Plumbing
Brookmeade ES (2055) 1B	COMMODE B RR 1ST FLR- FLUSH VALVE BROKEN-IT'S CONSTANTLY FLUSHING & WATER LEAKING OUT FLOODING RR PER SBE- PLANT MGR JOHNSON 416- 3944 KLR	9/18/13			Plumbing
Brookmeade ES (2055) 1B	Replace float in toilet, continuously running.	10/3/13	Kitchen	manager office	Plumbing
Brookmeade ES (2055) 1B	replace flushvalve in uniral (3rd)	10/4/13	1st Floor	boys restroom southeast hallway	Plumbing
Brookmeade ES (2055) 1B	PIPE LEAKING IN MAIN HALL AND IT'S FLOODING AREA PER SBE-CAN'T CONTAIN- PLANT MGR JOHNSON 416- 7958 KLR	10/29/13			Plumbing
Brookmeade ES (2055) 1B	Toilet seat missing	10/29/13	Restroom (Boys)	northeast hallway	Plumbing
Brookmeade ES (2055) 1B	Repair/replace cutt off valve in ceiling of girls restroom. tile is soaked causing ceiling to fall, it is a safety hazard.	12/9/13	2nd Floor	downstairs girls restroom	Plumbing

Brookmeade ES (2055) 1B	Check domestic boiler, not hot water in kitchen area.	12/16/13	1st Floor		Plumbing
Brookmeade ES (2055) 1B	Repair drinking fountain it is leaking.	12/17/13	1st Floor	northeast hallway	Plumbing
Brookmeade ES (2055) 1B	Unclog lines to drinking fountains (2).	12/18/13	Cafeteria	Cafeteria	Plumbing
Brookmeade ES (2055) 1B	Replace toilet seat .	12/18/13	1st Floor	Northeast boys restroom	Plumbing
Brookmeade ES (2055) 1B	check pilot, smell of light gas.	1/3/14	Cafeteria	serving area in kitchen	Plumbing
Brookmeade ES (2055) 1B	Pilot out in domestic boiler, no hot water in the kitchen.	1/6/14	Kitchen	boiler room	Plumbing
Brookmeade ES (2055) 1B	Drain in floor stopped up	5/9/14	1st Floor	Boiler room	Plumbing
Brookmeade ES (2055) 1B	Mop sink stopped up	6/30/14	1st Floor	Custodial closet	Plumbing

Brookmeade ES (2055) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	5/19/14			Plumbing
Brookmeade ES (2055) 1B	Test and report on backflow prevention devices.	6/17/14			Plumbing
Brookmeade ES (2055) 1B	UNIT IS LEAKING WATER IN MAIN OFFICE PLANT MGR- JOHNSON/416.3944	6/2/14			Plumbing
Brookmeade ES (2055) 1B	UNIT VENTILATOR is LEAKING in ROOM 111 per Denise Johnson, Plant Mgr. 416.7958	5/23/14			Plumbing
Brookmeade ES (2055) 1B	Toilet not flushing properly causing to back up onto floor when it is used.	7/1/13	1st Floor	teachers lounge restroom	Plumbing
Brookmeade ES (2055) 1B	Repair/Replace hand washing sink water continuously running.	7/17/13	Annex	hallway	Plumbing
Brookmeade ES (2055) 1B	Roof drainage pipe in the ceiling leaking in Rooms 108, 111, and in Room 120, which is the Cafeteria per Ms. Denise Johnson, Plant Mgr. at 901.416.7958.	7/19/13			Plumbing
Brookmeade ES (2055) 1B	Repair leak HVAC room 115.	7/19/13	1st Floor		Plumbing

Brookmeade ES (2055) 1B	Teachers Lounge the male and female restrooms the toilets will not flush	7/23/13			Plumbing
Brookmeade ES (2055) 1B	Repair faucet on sink Cannot turn off. Girls restroom main floor.	7/24/13			Plumbing
Brookmeade ES (2055) 1B	Repair bubbler fountain and sink outside custodial on main floor. (Has sign on sink)	7/25/13			Plumbing
Brookmeade ES (2055) 1B	Roof leaking	6/23/14	1st Floor	Hallway outside of cafe	Roof
Brookmeade ES (2055) 1B	roof leak in main hallway.	2/5/14	1st Floor	main hallway	Roof
Brookmeade ES (2055) 1B	roof leak in clasroom	2/5/14	1st Floor	classroom 112	Roof
Brookmeade ES (2055) 1B	Roof leak in main hallway	3/6/14	1st Floor	main hallway	Roof
Brookmeade ES (2055) 1B	roof leak in cafeteria near the front of stage.	3/6/14	Cafeteria	cafeteria/near stage	Roof

Brookmeade ES (2055) 1B	Water coming around drain in ceiling in cafeteria expects roof leak per Denise Johnson 416-7958	8/5/13			Roof
Brookmeade ES (2055) 1B	Make repairs to roof as needed	8/12/13			Roof
Brookmeade ES (2055) 1B	Roof leaking	5/9/14	1st Floor	By cafe entrance	Roof
Brookmeade ES (2055) 1B	Address leak in hallway	5/20/14	1st Floor	hallway	Roof
Brookmeade ES (2055) 1B	removed ceiling tiles to see where water was entering the room and it is a crack in the ceiling which is causing room to flood when it rains.	6/13/14	1st Floor	library-129	Roof
Brookmeade ES (2055) 1B	room flooding from drain pipe in classroom.	6/13/14	1st Floor	room 111	Roof
Brookmeade ES (2055) 1B	Roof leaking	6/23/14	1st Floor	Rms 111, 112 & 133	Roof
Brookmeade ES (2055) 1B	pressure wash out roof drains.	7/1/13	Grounds	rooftop	Roof

Brookmeade ES (2055) 1B	Fabricate and install sheetmetal covers over exsiting sky lites.	1/9/14	Cafetorium		Sheet Metal
-------------------------	--	--------	------------	--	-------------

Count of Craft	Craft								
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Brownsville EI (2057) 1B	4	11	41	50	1	30	3	1	141
Grand Total	4	11	41	50	1	30	3	1	141

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Brownsville EI (2057) 1B	Replace broken floor tile around water fountain	11/20/13	Hallway/Corridor	4th grade hall	Asbestos
Brownsville EI (2057) 1B	Replace floor tile in front of door.	11/20/13	Classroom	5TH grade Rm.133	Asbestos
Brownsville EI (2057) 1B	Need 9" floor tile replace.By each water fountain	1/24/14	Hallway/Corridor	2nd & 5th grade	Asbestos
Brownsville EI (2057) 1B	Carpet has odor due to roof leak.Bad brown stain	4/15/14	Library	By office desk	Asbestos
Brownsville EI (2057) 1B	SIDE DOOR BY 3RD GRADE WING, CANT SECURE. PLANT MGR-CALVIN/373.2602	9/13/13			Carpentry
Brownsville EI (2057) 1B	Door closer isnt working.	12/12/13	Cafeteria	back door	Carpentry
Brownsville EI (2057) 1B	Need plywood to cover up screen type window(Inside)So pipe want burst again.	1/21/14	Mechanical Room	outside W.annex blgd.	Carpentry

Brownsville EI (2057) 1B	Closer broke on door	1/22/14	Hallway/Corridor	5th grade hall	Carpentry
Brownsville EI (2057) 1B	both exit doors hard to close	2/4/14	Cafeteria	Cafe & courtyard exit door	Carpentry
Brownsville EI (2057) 1B	Exit door will not close completely	2/6/14	Hallway/Corridor	2nd grade hall across from Rm.123	Carpentry
Brownsville EI (2057) 1B	ENTRANCE DOOR GYM AREA-NOT LATCHING AND HARD TO CLOSE-WON'T BE ABLE TO SECURE-PLANT MGR KING 416-1775 KLR NOTE: CARPENTER ON SITE	2/17/14			Carpentry
Brownsville EI (2057) 1B	Stage Riser need repairing	2/21/14	Cafeteria	Stage	Carpentry
Brownsville EI (2057) 1B	Need stairway rails tighten down.4th &5th grade	8/6/13	Stairway	N.annex	Carpentry
Brownsville EI (2057) 1B	Exit door closer broke off door	5/1/14	Hallway/Corridor	4th grade hall	Carpentry
Brownsville EI (2057) 1B	Need water box welded shut.Water be everywhere over weekend.School do not use.	5/7/14	Grounds	south end of football field	Carpentry

Brownsville EI (2057) 1B	Exhaust fan don't come on.strong oder.I.D.#234-129	9/5/13	Restroom (Boys)	2nd & 3rd grade	Electrical
Brownsville EI (2057) 1B	UNIT NOT COMING ON IN RM-108 PLANT MGR-CALVIN/273.8832	9/13/13			Electrical
Brownsville EI (2057) 1B	Lights are out.Need bucket truck	10/1/13	Parking Lot	N.&W Annex also by gym	Electrical
Brownsville EI (2057) 1B	Need 4 cases of classroom blubs,-F32T8	10/2/13	Classroom	All over	Electrical
Brownsville EI (2057) 1B	Bad Ballast- 2 Lamp(7)	10/2/13	Classroom	106,107,108	Electrical
Brownsville EI (2057) 1B	Bad Ballast 2Lamp(6)	10/2/13	Classroom	103,101	Electrical
Brownsville EI (2057) 1B	Bad Ballast 2Lamp (5)	10/2/13	Cafeteria	Kitchen & Serving are	Electrical
Brownsville EI (2057) 1B	Bad ballast 2lamp (5)	10/2/13	Library	kk hall	Electrical

Brownsville EI (2057) 1B	Bad Ballast 2Lamp(4)	10/2/13	Classroom	112,113,114	Electrical
Brownsville EI (2057) 1B	Bad Ballast 2Lamp(6)	10/2/13	Hallway/Corridor	2nd & 3rd grade hall	Electrical
Brownsville EI (2057) 1B	Bad Ballast 2Lamp(3)	10/2/13	Classroom	124,126A,127	Electrical
Brownsville EI (2057) 1B	Bad Ballast 2Lamp(4)	10/2/13	Classroom	128,131	Electrical
Brownsville EI (2057) 1B	Bad Ballast 4amp (3)	10/2/13	Classroom	141,145,146	Electrical
Brownsville EI (2057) 1B	Bad Ballast 4Lamp(4)	10/2/13	Classroom	132,136,138	Electrical
Brownsville EI (2057) 1B	per Mr. King 416-1775 there is water coming out of the breaker box in plant manager's office	10/17/13			Electrical
Brownsville EI (2057) 1B	2 light fixture need 2 lamp ballast	11/14/13	Classroom	126 &128	Electrical

Brownsville EI (2057) 1B	Repair outside lights as reported by os.	11/26/13			Electrical
Brownsville EI (2057) 1B	flag pole need to be repair	12/9/13	Grounds	front entrance	Electrical
Brownsville EI (2057) 1B	Fire alarm keep going off.(dirty smoke detector)L1S01	12/9/13	Administration Area	main office	Electrical
Brownsville EI (2057) 1B	Repair/replace security light on North end of bldg.	12/17/13	Gym		Electrical
Brownsville EI (2057) 1B	Reconnect electric to the Ptact units in room 134. HVAC finished cleaning the coils.	1/15/14			Electrical
Brownsville EI (2057) 1B	Exit lights do not come on.	1/21/14	Hallway/Corridor	1st &2nd grade hall	Electrical
Brownsville EI (2057) 1B	Need 4 cases of light bulbs(F32t8)	2/6/14	Classroom	all over	Electrical
Brownsville EI (2057) 1B	1 light fixture not working(2 Lamp ballast)	2/7/14	Administration Area	main office	Electrical

Brownsville EI (2057) 1B	2 Light fixture not working(4 Lamp ballast)	2/7/14	Classroom	Rm.140 &142	Electrical
Brownsville EI (2057) 1B	5-2lamp ballast not working	2/20/14	Classroom	101,103,108	Electrical
Brownsville EI (2057) 1B	4- 2lamp ballast not working	2/20/14	Classroom	116,119,122	Electrical
Brownsville EI (2057) 1B	5- 2 lamp ballast not working	2/20/14	Classroom	124,125,126,127	Electrical
Brownsville EI (2057) 1B	1 - 2lamp ballast is out	2/20/14	Hallway/Corridor	3rd grade hall by Rm.127a	Electrical
Brownsville EI (2057) 1B	Set Master clock for Day light saving	2/24/14	Administration Area	main office	Electrical
Brownsville EI (2057) 1B	A/C UNIT COMING ON IN RM-140,142. SBE-KING/416-4300	7/23/13			Electrical
Brownsville EI (2057) 1B	Need Master clock set new school hours	7/31/13	Administration Area	main office	Electrical

Brownsville EI (2057) 1B	Reset school bell. 8:30, 8:45, 9:00am, 3:30, 3:45, & 4:00pm I.D.#234-111	8/12/13	Administration Area	main office	Electrical
Brownsville EI (2057) 1B	AC UNIT NORTH ANNEX 2ND FLR RM 45 (145)-NOT COMING ON-SBE KING 416-1775 KLR	8/19/13			Electrical
Brownsville EI (2057) 1B	Need 4 cases of classroom bulbs(F32t8)	4/24/14	Classroom	All over	Electrical
Brownsville EI (2057) 1B	UNIT IS MAKING NOISE IN RM-131 PLANT MGR-KING/834.4234	5/2/14			Electrical
Brownsville EI (2057) 1B	A/C RM 141-NOT COMING ON- PLANT MGR KING 416-1775 KLR	5/7/14			Electrical
Brownsville EI (2057) 1B	P-TACK UNIT - CAUGHT ON FIRE - NOT WORKING - PM/KING 416-1775	5/20/14			Electrical
Brownsville EI (2057) 1B	Light out need 2-2lamp ballast	6/2/14	Classroom	Rm.113 & 108	Electrical
Brownsville EI (2057) 1B	Need 4-2 lamp ballast in classrooms	6/2/14	Classroom	Rm.101,104,& 105	Electrical

Brownsville EI (2057) 1B	Lights stay on under canopy. Need photo eye fix.(Bucket truck.)	3/6/14	Grounds	W.annex	Electrical
Brownsville EI (2057) 1B	A/C RM 129 & RTU ANNEX SERVES RESTRMS/HALLWAYS-BOTH NOT COOLING-PLANT MGR KLR	9/9/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Monthly - Oil Lube & Belts - Brownsville Rd Elem - Refer to PM schedule details.	9/15/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	A/C unit in CLASSROOM 101 is NOT COOLING per Mr. Calvin McMickens, Plant Mgr. 373.2600	9/18/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UNIT NOT COOLING IN RM-29. PLANT MGR-CALVIN/596.8540	9/18/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	A/C unit in ROOM 128 NOT COOLING per Mr. King, Plant Mgr. 416.4300	9/19/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Monthly - Brownsville Road Elm Air Compressor - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU NOT COOLING IN GYM. PLANT MGR-KING/834.4234	10/15/13			Heating/Ventilation /Air Conditioning

Brownsville EI (2057) 1B	HEAT RM 218-NOT HEATING-PLANT MGR KING 416-1775 KLR	11/8/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Monthly - Filter-Brownsville Elementary - Refer to PM schedule details.	11/22/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UV NOT COMING ON IN RM-134 PLANT MGR-KING/834.4234	12/2/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Unit is NOT HEATING in ROOM 21 per Mr. King, Plant Mgr. 416.1775	12/3/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UV NOT HEATING IN RM-124 PLANT MGR-KING/834.4234	12/4/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU NOT HEATING & IN ALARM IN GYM PLANT MGR-KING/834.4234	12/10/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	HEAT GYM AREA-NOT HEATING-PLANT MGR KING 416-1775 KLR	12/11/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU GYM AREA-NOT HEATING-PLANT MGR KING 416-1775 KLR	12/16/13			Heating/Ventilation /Air Conditioning

Brownsville EI (2057) 1B	HEAT RMS 119 & 122-BOTH NOT HEATING-PLANT MGR KING 416-1775 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	HEAT RM 42-NOT HEATING-PLANT MGR KING 416-1775 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Rooftop Unit #1-MAIN ANNEX and Rooftop Unit #2-NORTH ANNEX is NOT HEATING per Mr. King, Plant Mgr. 416.1775	1/7/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UV NOT HEATING IN RM-123. PLANT MGR-KING/834.4234	1/10/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	HEAT GYM AREA-NOT HEATING-PLANT MGR KING 416-1775 KLR	1/21/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	HEAT MAIN OFC AREA-NOT HEATING-PLANT MGR KING 416-1775 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	5-A/C UNIT COOLING ON IN RM-129,138,136,141,& RTU NORTH ANNEX BLDG. SBE-KING/416-4300	7/23/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UNIT IN RM 108 IS NOT COOLING. SBE KING 416-4300	7/31/13			Heating/Ventilation /Air Conditioning

Brownsville EI (2057) 1B	(2) A/C UNITS IN RM 145-NOT COOLING-SBE KING 416-1775 KLR	8/5/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU-3 RM 106-NOT COOLING-SBE KING 416-1775 KLR	8/6/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	2-UV NOT COOLING IN RM-119(056) RM-116(058). PLANT MGR-KING/416.4300	8/8/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU NOT COOLING IN GYM(166) PLANT MGR-KING/416.4300	8/8/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU #20 NOT COOLING IN GYM. PLANT MGR-KING/416.1775	8/12/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UV IS LEAKING WATER IN RM-131(063) PLANT MGR-KING/416.1775	8/19/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UV NOT COOLING IN RM-129. PLANT MGR-KING/416.1775	8/28/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Room 101 not cooling (roof top unit) per Jerry King 416-1775	8/28/13			Heating/Ventilation /Air Conditioning

Brownsville EI (2057) 1B	A/C RM 142-NOT COOLING-PLANT MGR KING 416-1775 KLR	4/28/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	P-TACK UNIT - RM 140 & 142 - BLOWING NOT COOLING - PM/KING 416-1775	4/29/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	A/C RM 140-NOT COOLING-PLANT MGR KING 416-1775 KLR	4/29/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU GYM AREA & CAFE AREA-BOTH NOT COOLING-PLANT MGR KING 416-1775 KLR	4/29/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	ROOFTOP UNIT is NOT COOLING in the GYM per Mr. King, Plant Mgr. 416.1775	5/20/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	A/C RM 129-NOT COOLING-PLANT MGR KING 416-1775 KLR	6/4/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	RTU CAFE-NOT HEATING-PLANT MGR KING 416-1775 KLR	3/6/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	per king 416-1775 room 141 blowing cold	3/6/14			Heating/Ventilation /Air Conditioning

Brownsville EI (2057) 1B	per king 416-1775 the roof top unit that controls facilitator's office, plant manager's office and guidance office is blowing cold air	3/17/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	A/C RM 141-NOT COOLING- PLANT MGR KING 416-1775 KLR	4/3/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UNIT NOT COOLING IN RM-129 PLANT MGR/KING/834.4234	4/3/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Monthly - Brownsville Road Elm Air Compressor - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	UNIT NOT COOLING IN RM-141. PLANT MGR-KING/834.4234	4/4/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Yearly - Cooling Towers - Brownsville Rd Elem - Refer to PM schedule details.	3/1/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Monthly - Oil Lube & Belts - Brownsville Rd Elem - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning

Brownsville EI (2057) 1B	Monthly - Filter-Brownsville Elementary - Refer to PM schedule details.	3/21/14			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Monthly - Filter-Brownsville Elementary - Refer to PM schedule details.	7/19/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Yearly - Oil Samples-Brownsville Elementary - Refer to PM schedule details.	9/2/13			Heating/Ventilation /Air Conditioning
Brownsville EI (2057) 1B	Need 3in. step painting yellow & watch your step sign.a Kid has serious injury each year.	12/11/13	Grounds	main entrance	Painting
Brownsville EI (2057) 1B	Request that a/c wall unit leak be repaired (safety hazard).	9/12/13	Classroom	Cr 131	Plumbing
Brownsville EI (2057) 1B	WATER HEATER 4TH GR HALL CUST CLOSET-HAS BURST & WATER EVERYWHERE-PLANT MGR KING 416-1775 KLR	10/21/13			Plumbing
Brownsville EI (2057) 1B	double sink in kitchen is stopped up per Mr. King 416-4300	10/28/13			Plumbing
Brownsville EI (2057) 1B	sink in kitchen has leak underneath per mr. King 416-4300	10/28/13			Plumbing

Brownsville EI (2057) 1B	Water fountain next to Room 118 is OVERFLOWING with WATER and CANNOT BE CONTAINED per Mr. King, Plant Mgr. 416.1775	12/2/13			Plumbing
Brownsville EI (2057) 1B	Sink leaking#508422	12/12/13	Kitchen	cooking area	Plumbing
Brownsville EI (2057) 1B	Toilet keep flushing	12/17/13	Administration Area	Teacher Lounge upstairs	Plumbing
Brownsville EI (2057) 1B	Water fountain leaking	12/17/13	Hallway/Corridor	5th grade	Plumbing
Brownsville EI (2057) 1B	WATER IS COMING FROM RM 118 FLR PLANT MGR-KING/834.4234	1/8/14			Plumbing
Brownsville EI (2057) 1B	FLR DRAIN IS STOPPED UP IN KITCHEN PLANT MGR-KING/834.4234	1/8/14			Plumbing
Brownsville EI (2057) 1B	FLR IS FLOODED WITH WATER IN RM-118. PLANT MGR-KING/834.4234	1/14/14			Plumbing
Brownsville EI (2057) 1B	Water is coming from under the floor.(No rain)	1/17/14	Classroom	Rm.121	Plumbing

Brownsville EI (2057) 1B	per Mr. King 416-1775 on the 2nd grade hall there is a water fountain that won't cut off and he can't contain it	1/22/14			Plumbing
Brownsville EI (2057) 1B	per Mr. King 416-1775 the floor drain in the kitchen is backing up	1/29/14			Plumbing
Brownsville EI (2057) 1B	SEWER GAS SMELL 1ST GR HALL-PLANT MGR KING 416-1775 KLR	1/31/14			Plumbing
Brownsville EI (2057) 1B	UV IS LEAKING WATER IN RM 131(063). PLANT MGR-KING/416.1775	8/5/13			Plumbing
Brownsville EI (2057) 1B	FLR DRAIN IS BACKING UP IN BOILER RM . PLANT MGR-KING/416.4300	8/12/13			Plumbing
Brownsville EI (2057) 1B	A/C WEST ANNEX 1ST FLR RM 17-LEAKING-SBE KING 416-1775 KLR	8/13/13			Plumbing
Brownsville EI (2057) 1B	SEWAGE SMELL THRU MAIN HALL PLANT MGR-KING/834.4234	4/21/14			Plumbing
Brownsville EI (2057) 1B	per king 416-1775 there is sewer smell in the main office area	4/28/14			Plumbing

Brownsville EI (2057) 1B	per mr king 416-1775 the sewer is backing up in the kitchen/cafeteria	4/28/14			Plumbing
Brownsville EI (2057) 1B	A/C RM 144-LEAKING-PLANT MGR KING 416-1775 KLR	5/21/14			Plumbing
Brownsville EI (2057) 1B	WATER is COMING UP THROUGH the FLOOR DRAINS in the KITCHEN per Mr. King, Plant Mgr. 416.1775	5/21/14			Plumbing
Brownsville EI (2057) 1B	A/C RM 120-LEAKING-PLANT MGR KING 416-1775 KLR	6/4/14			Plumbing
Brownsville EI (2057) 1B	2 sinks are stop up	6/4/14	Custodial Closet	KK & 2nd grade hall	Plumbing
Brownsville EI (2057) 1B	Sink stop up	6/4/14	Custodial Closet	3rd grade hall	Plumbing
Brownsville EI (2057) 1B	UNIT VENT - RM 130 - LEAKING - PM/EVANS 438-7765	6/25/14			Plumbing
Brownsville EI (2057) 1B	UNIT VENT - RM 122,123,130 - LEAKING - PM/KING 416-1775	6/25/14			Plumbing

Brownsville EI (2057) 1B	Plant manager called complaining of sewer gas order, this has been a reoccurring problem. jd	3/11/14	Kitchen		Plumbing
Brownsville EI (2057) 1B	Water fountain is leaking onto floor	4/2/14	Hallway/Corridor	4th Grade hall	Plumbing
Brownsville EI (2057) 1B	At least 10 different drips spot when raining	2/6/14	Gym	ALL OVER	Roof
Brownsville EI (2057) 1B	leak onto gym floor when raining	7/23/13	Gym	by NE door	Roof
Brownsville EI (2057) 1B	Water leaks bad threw light fixture and making carpet with terrible brown stains	3/18/14	Library	by Circulation desk	Roof
Brownsville EI (2057) 1B	Need vent cover over return vent.Dust fall down where food is being prepare.	4/25/14	Cafeteria	Kitchen area	Sheet Metal

Count of Craft	Craft								
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Bruce ES (2060) 1A	2	1	50	166	66	2	26	2	315
Grand Total	2	1	50	166	66	2	26	2	315

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Bruce ES (2060) 1A	MEASURE, MAKE SHADES AND INSTALL BRACKETS FOR 29 CLASSROOMS SUNLIGHT VISION PROBLEM FOR STUDENTS DEP	7/12/13	1st Floor	ALL CLASSROOMS	Asbestos
Bruce ES (2060) 1A	repair or replace carpet divider that sitting up from the floor/tripp harzard at entrance door	10/24/13	1st Floor	library	Asbestos
Bruce ES (2060) 1A	Bruce Es -- WO#368760 -computer drops 12, 13, 7 and 9 is not working/(Request Network Cabling Maintenance Repair).	7/30/13	1st Floor	126 room	Cabling
Bruce ES (2060) 1A	repaI or replace 10 feet section of colbase/come from base board	6/23/14	1st Floor	multi purpose room	Carpentry
Bruce ES (2060) 1A	main exterior entrance door to court yard/can not open/door need adjusting	6/27/14	1st Floor	court yard	Carpentry
Bruce ES (2060) 1A	repair door on classroom door/has come off	5/15/14	1st Floor	120	Carpentry
Bruce ES (2060) 1A	adjust counter swinging door/off set	5/19/14	1st Floor	main office	Carpentry

Bruce ES (2060) 1A	door sprung open/cannot shut close	5/23/14	1st Floor	exterior door court yard	Carpentry
Bruce ES (2060) 1A	door knob very loose /about to come off/	5/23/14	1st Floor	teacher lounge inter door	Carpentry
Bruce ES (2060) 1A	entrance door not closing shut	1/15/14	1st Floor	library	Carpentry
Bruce ES (2060) 1A	REPAIR OR REPLACE DOOR HANDLE AND LOCK/LOOSE AND HARD TO LOCK	6/12/14	1st Floor	ROOM 123	Carpentry
Bruce ES (2060) 1A	place tack strip molding back on wall/	12/16/13	1st Floor	east hall	Carpentry
Bruce ES (2060) 1A	repair/replace 2 broken floor tile	12/27/13	1st Floor	cafeteria	Carpentry
Bruce ES (2060) 1A	door knob need to be tightly secure/very loose/about to come off/	1/6/14	1st Floor	105--106--110-119	Carpentry
Bruce ES (2060) 1A	door knob need to be secure to door/very loose	1/6/14	1st Floor	121--125--128	Carpentry

Bruce ES (2060) 1A	need to secure door knob /very loose	1/6/14	1st Floor	lab--library	Carpentry
Bruce ES (2060) 1A	NEED TO SECURE DOOR KNOB/ VERY LOOSE	1/7/14	1st Floor	106-- 119---125	Carpentry
Bruce ES (2060) 1A	NEED TO SECURE DOOR KNOB/VERY LOOSE	1/7/14	1st Floor	110---121--128	Carpentry
Bruce ES (2060) 1A	NEED TO SECURE DOOR KNOB/VERY LOOSE	1/7/14	1st Floor	LAB--LILIBARY	Carpentry
Bruce ES (2060) 1A	NEED TO SECURE DOOR KNOB/VERY LOOSE	1/8/14	1st Floor	105	Carpentry
Bruce ES (2060) 1A	repair or replace 2 sections of broken floor tile	1/16/14	1st Floor	multi purpose room	Carpentry
Bruce ES (2060) 1A	Relocate AED cabinet from behind door next to main office to a more visible area, designated by the principal.	1/24/14	Administration Area		Carpentry
Bruce ES (2060) 1A	TEACHER CANNOT UNLOCK CLASSROOM FROM INSIDE/BAD DOOR HANDLER	2/3/14	1st Floor	106	Carpentry

Bruce ES (2060) 1A	adjust exterior door do not close shut/off set to latch	2/13/14	1st Floor	south custodial closet	Carpentry
Bruce ES (2060) 1A	secure key cylinder in door/very loose/about to come out door	2/17/14	1st Floor	107	Carpentry
Bruce ES (2060) 1A	repair large hole in sheet rock wall	3/10/14	1st Floor	n/w hall	Carpentry
Bruce ES (2060) 1A	repair or replace door handler/ handler can not unlocked from inside classroom	3/10/14	1st Floor	104	Carpentry
Bruce ES (2060) 1A	need 3 boxes of hard ceiling tile	3/19/14	1st Floor	hall/main office area	Carpentry
Bruce ES (2060) 1A	repair very loose door knob	3/19/14	1st Floor	library	Carpentry
Bruce ES (2060) 1A	repair 5 door knobs very loose	3/19/14	1st Floor	library computer rooms	Carpentry
Bruce ES (2060) 1A	REPLACE MISSING CEILING TILE/12 FEET UP/NEED LIFT	3/25/14	1st Floor	MULTI PURPOSE ROOM	Carpentry

Bruce ES (2060) 1A	install swinging door at counter/per principal	3/27/14	1st Floor	main office	Carpentry
Bruce ES (2060) 1A	replace 4 sections of broken floor tile	7/29/13	1st Floor	116	Carpentry
Bruce ES (2060) 1A	need one box of soft back ceiling tile	8/6/13	1st Floor	main office area	Carpentry
Bruce ES (2060) 1A	REPLACE CEILING TILE /NEED LIFT 12 FEET HIGH	8/9/13	1st Floor	MULTI PURPOSE ROOM	Carpentry
Bruce ES (2060) 1A	install pick guard on entrance door and secure opening at bottom of walls of AHU 2/NOTE HOMELESS PEOPLE USEING AREA FOR PERSONAL USE AND	8/14/13	1st Floor	exterior west main bldg	Carpentry
Bruce ES (2060) 1A	door knob hanging off/can not lock or secure class room door	8/19/13	1st Floor	117	Carpentry
Bruce ES (2060) 1A	SOUTH OUTSIDE WONT DOOR, CANT SECURE. SBE-HILL/416-4488	7/1/13			Carpentry
Bruce ES (2060) 1A	Trim bottom of door	7/2/13			Carpentry

Bruce ES (2060) 1A	replace broken floor tile	7/1/13	Cafetorium	northside	Carpentry
Bruce ES (2060) 1A	need 4 boxes of 2 by 2 - 3/8 offset tegolar ceiling tile	7/1/13	1st Floor	hall/south and north	Carpentry
Bruce ES (2060) 1A	door off set adjust exterior south door to main bldg. where it can close without pulling shut	9/4/13	1st Floor	main bldg south exterior	Carpentry
Bruce ES (2060) 1A	three doors off set/donot shut close when entering or exiting/have to pull shut	9/4/13	1st Floor	main entrance east	Carpentry
Bruce ES (2060) 1A	can not secure door /door off set open	9/10/13	1st Floor	music room	Carpentry
Bruce ES (2060) 1A	DOOR - KIC WEST DR IS NO CLOSING COMPLETELY TO SECURE BLDG - PM/HILL 416-9032	9/19/13			Carpentry
Bruce ES (2060) 1A	DOOR HANDLE LATCH STICKING INSIDE CYLINDER	10/7/13	1st Floor	117	Carpentry
Bruce ES (2060) 1A	DOOR HANDLE VERY LOOSE/NEED TO BE SECURE	10/7/13	1st Floor	130	Carpentry

Bruce ES (2060) 1A	DOOR HANDLE LOOSE/NEED TO BE SECURE	10/7/13	1st Floor	122	Carpentry
Bruce ES (2060) 1A	INSTALL PANIC BAR WITH KEY CYLINDER TO MAIN ENTRANCE DOOR	8/2/13	1st Floor	main entrance door	Carpentry
Bruce ES (2060) 1A	INSTALL PANIC BAR WITH KEY CYLINDER TO MAIN ENTRANCE EAST DOOR	1/14/14	1st Floor	main entrance	Carpentry
Bruce ES (2060) 1A	MOVE BULLETIN BOARD TO HALL	6/12/14	1st Floor	124 ROOM	Carpentry
Bruce ES (2060) 1A	MOVE BOTH BULLETIN BOARDS TO HALLWAY	6/12/14	1st Floor	GUIDANCE OFFICE	Carpentry
Bruce ES (2060) 1A	MOVE BULLETIN BOARD TO HALL	6/12/14	1st Floor	ROOM 123	Carpentry
Bruce ES (2060) 1A	section of lights flicking/bad ballast	10/29/13	1st Floor	main office	Electrical
Bruce ES (2060) 1A	Power outage in the entire building per Cameron Hill, Plant Mgr. 416.4488	10/31/13			Electrical

Bruce ES (2060) 1A	ventilation fan over the stove is not working properly moter is weak	11/1/13	Kitchen	kitchen	Electrical
Bruce ES (2060) 1A	cahange master clock daylight saving time	11/4/13	1st Floor	main office	Electrical
Bruce ES (2060) 1A	remove broken bulb from light socket	11/8/13	1st Floor	east hall by library	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT BAD BALLAST	10/7/13	1st Floor	108	Electrical
Bruce ES (2060) 1A	RTU - CONTROLS NORTH & WEST HALL - BLOWING NOT COOLING - PM/HILL 416-9032	5/12/14			Electrical
Bruce ES (2060) 1A	UNIT NOT COMING ON IN PRIN OFFICE. PLANT MGR- HILL/416.4488	5/12/14			Electrical
Bruce ES (2060) 1A	per mr hill 416-9032 there is burning smell in room 102	5/12/14			Electrical
Bruce ES (2060) 1A	A/C LIBRARY AREA & NORTH HALL CLASSRMS ABOUT (9) RMS-ALL NOT COMING ON-PLANT MGR HILL 416-9032 KLR	5/13/14			Electrical

Bruce ES (2060) 1A	BURNING SMELL IN EAST HALL PLANT MGR- HILL/416.4495	5/15/14			Electrical
Bruce ES (2060) 1A	POWER OUTAGE THRU ENTIRE BLDG , & FIRE ALARM IS IN TROUBLE PLANT MGR- HILL/826.8480	5/21/14			Electrical
Bruce ES (2060) 1A	SECTION OF LIGHT OUT/BAD BALLAST	5/22/14	1st Floor	N/W HALL	Electrical
Bruce ES (2060) 1A	lamp out/bad ballast	6/2/14	Mechanical Room	exterior door/south	Electrical
Bruce ES (2060) 1A	LAMP OUT/BAD BALLAST ABOVE BOILER ROOM DOOR	6/4/14	1st Floor	EXTERIOR SOUTH MAIN BLDG	Electrical
Bruce ES (2060) 1A	FLICKING LIGHT/BAD BALLAST	6/12/14	1st Floor	MAIN OFFICE	Electrical
Bruce ES (2060) 1A	emerg. lights not working	1/15/14	1st Floor	100	Electrical
Bruce ES (2060) 1A	emerg. lights not working	1/15/14	1st Floor	cafeteria s/w wall	Electrical

Bruce ES (2060) 1A	emerg. lights not working	1/15/14	1st Floor	kitchen	Electrical
Bruce ES (2060) 1A	west wall south emerg. lights not working	1/15/14	1st Floor	multi purpose room	Electrical
Bruce ES (2060) 1A	east wall north emerg. lights not working	1/15/14	1st Floor	multi purpose room	Electrical
Bruce ES (2060) 1A	north wall emerg. lights not working	1/15/14	1st Floor	library	Electrical
Bruce ES (2060) 1A	4 sections of lights out/bad ballast	6/16/14	1st Floor	103	Electrical
Bruce ES (2060) 1A	one section of lights out/bad ballast	6/16/14	1st Floor	128	Electrical
Bruce ES (2060) 1A	one section of lights out/ballast	6/16/14	1st Floor	123	Electrical
Bruce ES (2060) 1A	two sections of lights out/bad ballast	6/16/14	1st Floor	118	Electrical

Bruce ES (2060) 1A	three sections of lights out/bad ballast	6/16/14	1st Floor	112	Electrical
Bruce ES (2060) 1A	two sections of lights out/bad ballast	6/16/14	1st Floor	106	Electrical
Bruce ES (2060) 1A	one light flicking/bad ballast	6/16/14	1st Floor	main office	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	11/11/13	1st Floor	N/E GIRLS RESROOM	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT/BALLAST BAD	11/11/13	1st Floor	ART ROOM	Electrical
Bruce ES (2060) 1A	REPAIR OR REPLACE BURN LIGHT SOCKET	11/11/13	1st Floor	N/W GIRLS RESTROOM FRONT	Electrical
Bruce ES (2060) 1A	2 SECTION OF LIGHTS OUT/BAD BALLAST	11/11/13	1st Floor	ESL ROOM	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	11/26/13	1st Floor	S/E girls retroom	Electrical

Bruce ES (2060) 1A	section of lights out/bad ballast	11/26/13	1st Floor	N/W boys restroom	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	12/5/13	1st Floor	n/w hall	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	12/5/13	1st Floor	s/w girls restroom	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	12/5/13	1st Floor	n/w restroom boys	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	12/5/13	1st Floor	main office	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	12/7/13	1st Floor	N/W BOYS RESTROOM	Electrical
Bruce ES (2060) 1A	NEED 2 CASES OF LAMPS #46807	12/17/13	1st Floor	MAIN BLDG	Electrical
Bruce ES (2060) 1A	Unit is NOT COMING ON per Caremo Hill, Plant Mgr. 416.9032	1/6/14			Electrical

Bruce ES (2060) 1A	need to replace ballast/section of lights out	1/9/14	1st Floor	east hall	Electrical
Bruce ES (2060) 1A	CIRCULATING PUMP MECH RM-NOT COMING-MOTOR BURNED UP PER SBE. PLANT MGR HILL 416-9032 KLR	1/9/14			Electrical
Bruce ES (2060) 1A	at main entrance section of lights out/bad ballast	1/27/14	1st Floor	east hall	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast/ replace	2/6/14	1st Floor	n/w hall	Electrical
Bruce ES (2060) 1A	Check building power outage	2/20/14			Electrical
Bruce ES (2060) 1A	SET MASTER CLOCK DAYLIGHT SAVING TIME	2/21/14	1st Floor	MAIN OFFICE	Electrical
Bruce ES (2060) 1A	repair or replace hall light switch donot turn lights on	2/25/14	1st Floor	south hall	Electrical
Bruce ES (2060) 1A	section of lights out/on the stage	2/27/14	1st Floor	multi purpose room	Electrical

Bruce ES (2060) 1A	replace 2 blown lamps/need small bucket truck about 12 feet up	3/6/14	1st Floor	exterior west main bldg	Electrical
Bruce ES (2060) 1A	replace one blown lamp/need small bucket truck	3/6/14	1st Floor	north exterior main bldg	Electrical
Bruce ES (2060) 1A	repair or replace bad hall light switch/will not turn on lights	3/20/14	1st Floor	west hall	Electrical
Bruce ES (2060) 1A	replace blown lamp/need small bucket truck	3/20/14	1st Floor	exyerior east main bldg	Electrical
Bruce ES (2060) 1A	replace blown lamp/need bucket truck	3/20/14	1st Floor	exterior north main bldg	Electrical
Bruce ES (2060) 1A	replace two blown lamps/need bucket truck	3/20/14	1st Floor	west exterior main bldg	Electrical
Bruce ES (2060) 1A	REPLACE THREE BLOWN LAMPS/12 FEET UP/ NEED LIFT	3/25/14	1st Floor	MULTI PURPOSE ROOM	Electrical
Bruce ES (2060) 1A	REPAIR TWO STAGE LIGHT LENS HANGING/12 FEET UP/NEED LIFT	3/25/14	1st Floor	MULTI PURPOSE ROOM	Electrical

Bruce ES (2060) 1A	replace flicking light/bad ballast	3/25/14	Library	library	Electrical
Bruce ES (2060) 1A	replace blown lamp over boiler room door	3/25/14	1st Floor	main bldg. exter. south	Electrical
Bruce ES (2060) 1A	replace light ballast/flicking light	3/27/14	1st Floor	west hall	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	3/31/14	1st Floor	n/w hall	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	3/31/14	1st Floor	library	Electrical
Bruce ES (2060) 1A	STEAMTABLE KITCHEN SERVING LINE AREA-KEEPS TRIPPING THE BREAKER WHEN CUT ON-PLANT MGR HILL 416-9032 KLR	4/2/14			Electrical
Bruce ES (2060) 1A	ELECTRICAL BURNING SMELL IN MAIN OFC AREA- PLANT MGR HILL 416-4495 KLR	4/16/14			Electrical
Bruce ES (2060) 1A	replace blown lamp/12 feet high/need bucket van	4/17/14	1st Floor	main bldg west exterior	Electrical

Bruce ES (2060) 1A	blown lamp/need bucket van/over 12 up feet	4/21/14	1st Floor	main bldg west exterior	Electrical
Bruce ES (2060) 1A	LIGHT - EMERGENCY LIGHTS ARE CONSTANTLY FLASHING IN THE MAIN OFC - PM/HILL 416-4488	4/22/14			Electrical
Bruce ES (2060) 1A	HAS COMPLETE POWER OUTAGE- PLANT MGR HILL 416-4488 KLR	4/28/14			Electrical
Bruce ES (2060) 1A	blown lamp need bucket van 12 feet high	5/7/14	1st Floor	west main bldg exterior	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	7/15/13	1st Floor	east hall/by cafeteria	Electrical
Bruce ES (2060) 1A	4 bad light bulb sockets/lights will not come on	7/15/13	1st Floor	library	Electrical
Bruce ES (2060) 1A	four sections of lights out/bad ballast	7/15/13	1st Floor	library	Electrical
Bruce ES (2060) 1A	3 bad light sockets/lights will not come on	7/15/13	1st Floor	main office area	Electrical

Bruce ES (2060) 1A	one bad light socket/lights will not come	7/15/13	1st Floor	finance office	Electrical
Bruce ES (2060) 1A	need 12 special bulbs number F18DBXT4/SPX35--18 W	7/15/13	1st Floor	east hall	Electrical
Bruce ES (2060) 1A	NEED 8 SPECIAL SIZE BULB SYLVANIA CF18DD/827 18W	7/15/13	1st Floor	main entrance area	Electrical
Bruce ES (2060) 1A	NEED 9 SPECIAL BULB SYLVANIA NUMBER FB032/735/6 32 WATT	7/15/13	1st Floor	MAIN ENTRANCE AREA	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	7/15/13	1st Floor	faculty room	Electrical
Bruce ES (2060) 1A	set correct time to 16 wall clocks	7/16/13	1st Floor	main hall area	Electrical
Bruce ES (2060) 1A	need 200 lamps (8 boxes) items #46807	7/16/13	1st Floor	classrooms/halls	Electrical
Bruce ES (2060) 1A	need to replace 20 blown lamps item # CF18DD/835/ECO	7/17/13	1st Floor	halls	Electrical

Bruce ES (2060) 1A	NEED 24 LAMPS/ITEM #F25T8-SP35--25 WATT--TRIMLINE OR ITEM # F025/735/ECO-SYLVANIA	7/17/13	1st Floor	main entrance lobby	Electrical
Bruce ES (2060) 1A	FOUR BLOWN LAMPS/PARKING LOTT/OVER 12 FEET UP/ NEED BUCKET TRUCK	7/18/13	1st Floor	exterior east main bldg	Electrical
Bruce ES (2060) 1A	blown lamp/12 feet up/ need bucket truck	7/18/13	1st Floor	west main bldg exterior	Electrical
Bruce ES (2060) 1A	ventilation fan not coming on	7/19/13	1st Floor	teacher's restroom	Electrical
Bruce ES (2060) 1A	replace bLown lamps item #F17T8SP35 OR FO17/735ECO NEED 12	7/19/13	1st Floor	women/men restroom	Electrical
Bruce ES (2060) 1A	set master clock bells to ring for new school start time/ DONOT HAVE CLOCK I.D	7/19/13	1st Floor	main office	Electrical
Bruce ES (2060) 1A	REMOVE BROKEN LAMP FROM LIGHT SOCKET	7/25/13	1st Floor	EAST HALL BY LIBRARY	Electrical
Bruce ES (2060) 1A	NEED TO REPLACE 250 BLOWN LAMPS ITEM # 46807	7/29/13	1st Floor	halls/main entrance	Electrical

Bruce ES (2060) 1A	wall outlet not working	7/29/13	1st Floor	main entrance lobby	Electrical
Bruce ES (2060) 1A	two light sockets with broken bulbs in them	7/30/13	1st Floor	n/w hall by restroom	Electrical
Bruce ES (2060) 1A	repair or replace light socket burned/not working	7/30/13	1st Floor	s/w hall by restroom	Electrical
Bruce ES (2060) 1A	three ballast not working/three section of lights out	7/30/13	1st Floor	main entrance lobby	Electrical
Bruce ES (2060) 1A	NEED 12 BULBS SPECIAL FB32T8/735/6/ECOMAX	7/30/13	1st Floor	main entrance lobby	Electrical
Bruce ES (2060) 1A	3-UNITS NOT COMING ON IN RM-100,110,113. PLANT MGR-HILL/416.4495	8/1/13			Electrical
Bruce ES (2060) 1A	repair or replace broken light socket	8/5/13	1st Floor	north hall by room 127	Electrical
Bruce ES (2060) 1A	section of lights out bad ballast	8/5/13	1st Floor	north hall	Electrical

Bruce ES (2060) 1A	section of lights out/bad ballast	8/7/13	1st Floor	east hall by main office	Electrical
Bruce ES (2060) 1A	two section of lights out/bad ballast	8/13/13	Kitchen	kitchen	Electrical
Bruce ES (2060) 1A	FCU RM 102-NOT COOLING-SBE HILL 416-9032 KLR	8/13/13			Electrical
Bruce ES (2060) 1A	bad light socket light will not come on	8/21/13	1st Floor	hall by 125 room	Electrical
Bruce ES (2060) 1A	light will not come on bad socket	8/21/13	1st Floor	hall by library	Electrical
Bruce ES (2060) 1A	section of lights out bad ballast	8/21/13	1st Floor	boys restroom. by106	Electrical
Bruce ES (2060) 1A	repair or replace burn light socket/will not come on	8/21/13	1st Floor	west hall by rm.106	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	8/21/13	1st Floor	speech therapist office	Electrical

Bruce ES (2060) 1A	section of lights out bad ballast	8/21/13	1st Floor	parents resource room	Electrical
Bruce ES (2060) 1A	FIRE ALARM-NOT RESETTING & CONSTANTLY GOING OFF PER SBE-PLANT MGR HILL 416-4488 KLR	8/26/13			Electrical
Bruce ES (2060) 1A	room 127 and 128 a/c is blowing hot air not cooling per Cameron Hill 416-9032	8/26/13			Electrical
Bruce ES (2060) 1A	set master clock /bells to ring children entering the building and ending of school day	8/27/13	1st Floor	main office	Electrical
Bruce ES (2060) 1A	three section of lights out/bad ballast	8/28/13	1st Floor	room130	Electrical
Bruce ES (2060) 1A	section of lights out bad ballast	8/28/13	1st Floor	room by student supply	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	8/28/13	1st Floor	room 129	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	8/28/13	1st Floor	128	Electrical

Bruce ES (2060) 1A	light will not come on bad light socket	8/28/13	1st Floor	room 123	Electrical
Bruce ES (2060) 1A	light socket bad	8/28/13	1st Floor	125	Electrical
Bruce ES (2060) 1A	NEED THREE CASES LAMPS/ITEM#46807	8/29/13	1st Floor	CLASSROOMS ALL	Electrical
Bruce ES (2060) 1A	UNIT NOT COOLING IN RM-120. PLANT MGR- HILL/416.4495	8/30/13			Electrical
Bruce ES (2060) 1A	SECTION OF LIGHT OUT/BAD BALLAST	8/30/13	1st Floor	BOYS RESTROOM S/W	Electrical
Bruce ES (2060) 1A	BAD BALLAST SECTION OF LIGHTS OUT	8/30/13	1st Floor	BOYS RESTROOM S/E	Electrical
Bruce ES (2060) 1A	NEED 8 BOXES OF ITEM 46807 LIGHT BULBS	9/2/13	1st Floor	classrooms	Electrical
Bruce ES (2060) 1A	drive on both mau's not working	7/9/13			Electrical

Bruce ES (2060) 1A	repair or replace broken light socket/	8/5/13	1st Floor	east hall by library	Electrical
Bruce ES (2060) 1A	repair or replace broken light socket	8/5/13	1st Floor	east hall by office supply room	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	8/21/13	1st Floor	resource by 124	Electrical
Bruce ES (2060) 1A	replace broken light socket/light is not come on	8/21/13	1st Floor	custodia closet by 128	Electrical
Bruce ES (2060) 1A	need 3 boxes item 46807 light bulbs	9/3/13	1st Floor	classrooms	Electrical
Bruce ES (2060) 1A	Room 128 not cooling per Cameron Hill 416-9032	9/3/13			Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	9/19/13	Kitchen	kitchen	Electrical
Bruce ES (2060) 1A	need 3 boxes of lamps/item#46807	9/19/13	1st Floor	cassrooms	Electrical

Bruce ES (2060) 1A	broken bulb in socket	10/7/13	1st Floor	N/W restroom area	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT BAD BALLAST	10/7/13	1st Floor	114	Electrical
Bruce ES (2060) 1A	NEED 12 F18DBX/835/ECO	10/7/13	1st Floor	NORTH HALL	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	10/29/13	1st Floor	s/w boys restroom	Electrical
Bruce ES (2060) 1A	section of lights out /bad ballast	10/29/13	1st Floor	118	Electrical
Bruce ES (2060) 1A	two sectios of lights out/bad ballast	10/29/13	1st Floor	112	Electrical
Bruce ES (2060) 1A	two sections of lights out/bad ballast	10/29/13	1st Floor	ESL ROOM	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	10/29/13	1st Floor	behind stage	Electrical

Bruce ES (2060) 1A	section of lights out/bad ballast	10/29/13	1st Floor	music room	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	10/29/13	1st Floor	108	Electrical
Bruce ES (2060) 1A	section of lights out/bad ballast	10/29/13	1st Floor	art room	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT BAD BALLAST	10/7/13	1st Floor	S/W RESTROOM	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT BAD BALLAST	10/7/13	1st Floor	BEHIND STAGE	Electrical
Bruce ES (2060) 1A	TWO SECTION OF LIGHTS OUT/BAD BALLAST	10/7/13	1st Floor	ESL ROOM	Electrical
Bruce ES (2060) 1A	TWO SECTION OF LIGHTS OUT/BAD BALLAST	10/7/13	1st Floor	112	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS OUT/BAD BALLAST	10/7/13	1st Floor	123	Electrical

Bruce ES (2060) 1A	BAD BALLAST SECTION OF LIGHTS OUT	10/7/13	1st Floor	118	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHTS BLOWN BAD BALLAST	10/7/13	1st Floor	ArT ROOM	Electrical
Bruce ES (2060) 1A	4 section of lights out/bad ballast	9/20/13	1st Floor	103	Electrical
Bruce ES (2060) 1A	two section of lights out/bad ballast	9/17/13	1st Floor	106	Electrical
Bruce ES (2060) 1A	two section of lights out/bad ballast	9/17/13	1st Floor	104	Electrical
Bruce ES (2060) 1A	two section of lights are out/bad ballast	9/18/13	1st Floor	100	Electrical
Bruce ES (2060) 1A	repair or replace 32 compact florescent fixtures that's not working	8/21/13	1st Floor	main entrance carport	Electrical
Bruce ES (2060) 1A	install 4 magnetic door stoppers	1/15/14	1st Floor	north hall	Electrical

Bruce ES (2060) 1A	install 4 magnetic door stoppers	1/15/14	1st Floor	south hall	Electrical
Bruce ES (2060) 1A	install 4 magnetic door stoppers	1/15/14	1st Floor	east hall	Electrical
Bruce ES (2060) 1A	install 4 magnetic door stoppers	1/15/14	1st Floor	west hall	Electrical
Bruce ES (2060) 1A	SECTION OF LIGHT OUT BALLAST	10/7/13	1st Floor	MUSIC ROOM	Electrical
Bruce ES (2060) 1A	3 sections of lights out/bad ballast	11/8/13	1st Floor	103	Electrical
Bruce ES (2060) 1A	6 cases light bulbs item#46807	8/22/13	1st Floor	all classrooms	Electrical
Bruce ES (2060) 1A	NEED TEN BULB -- F18DBX/835/ECO	8/5/13	1st Floor	main entrance area	Electrical
Bruce ES (2060) 1A	need 6 boxes of lamp , flr rapid start 25 - item #46807	7/1/13	1st Floor	entire building	Electrical

Bruce ES (2060) 1A	three section of lights out bad ballast	9/3/13	1st Floor	108	Electrical
Bruce ES (2060) 1A	three section of lights out/bad ballast	9/3/13	1st Floor	112	Electrical
Bruce ES (2060) 1A	TWO SECTIONS OF LIGHTS OUT BAD BALLAST	9/2/13	1st Floor	ROOM 118	Electrical
Bruce ES (2060) 1A	ONE SECTION OF LIGHTS OUT BAD BALLAST	9/2/13	1st Floor	ROOM 114	Electrical
Bruce ES (2060) 1A	Monthly - Filter-Bruce Elementary - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Check chiller for proper operation	6/17/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	purchase sensor for chiller	6/20/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	ckt #2 chiller	6/23/14			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	UNITS IS OVERHEATING IN RM-114,115,116,117,118,119,120 SOUTH HALL. PLANT MGR-HILL/416.4495	11/1/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	clean chiller	5/16/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Reset chiller	5/19/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	clean chiller	5/28/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Reset chiller	6/10/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	UNIT NOT HEATING IN RM-124 & SPECIAL NEED RM PLANT MGR-HILL/826.8480	1/15/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Yearly - Air Handler Cleanings-Bruce Elementary - Refer to PM schedule details.	11/12/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	boiler and ahu's in alarm	11/18/13			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	UNIT NOT HEATING IN MAIN OFFICE PLANT MGR- HILL/416.4495	11/19/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	boiler down	11/25/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	AHU's 1 & 2 -- lo temp tripped	11/25/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Unit in MAIN OFFICE is NOT HEATING per Mr. Hill, Plant Mgr. 416.9032	12/9/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	HEAT RM 134-NOT HEATING-PLANT MGR HILL 416-9032 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Monthly - Filter-Bruce Elementary - Refer to PM schedule details.	1/10/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	replace actuator on AHU #1 ---- SKB 62	1/17/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	AHU 1 has a bad actuator. Siemens Part number SKB62.	1/17/14			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	Monthly - Oil Lube & Belt-Bruce Elementary - Refer to PM schedule details.	1/20/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	CHILLER MECH RM- NOT COMING ON- PLANT MGR HILL 416-9032 KLR	4/11/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	UNIT IS LEAKING WATER IN PRIN & MAIN OFFICES PLANT MGR- HILL/416.4488	4/14/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	UNIT IS LEAKING WATER IN PARENTS RESEARCH AREA PLANT MGR- HILL/416.4488	4/14/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	CHILLER - ON BUT IS BLOWING HOT AIR - PM/HILL 416-4488	4/21/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	A/C UNIT is NOT COOLING in ROOMS 102, 103, 104, 109, and 113 per Cameron Hill, Plant Mgr. 416.9032	4/21/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	NOT AIR IN CLASS RMS IN THE NORTH & WEST AREAS - BLOWING NOT COOLING - PM/HILL 416-4488	4/22/14			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	chiller ckt #2 bad cond. fan motor	4/22/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	chiller ckt #1 replace relief valve on compressor	4/22/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	CHILLER - BLOWING NOT COOLING IN THE NORTH AND WEST HALLWAY AREA - PM/HILL 416-4488	4/23/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	CHILLER NOT COOLING PLANT MGR-HILL/416.4488	4/29/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	RTU - ALL CLASSRM ARE BLOWING BUT NOT COOLIN-PM/HILL 416-4488	5/5/14			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	No A/C in the entire school perCameron Hill 416-9032	7/22/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	no a/c in the entire school per Cameron Hill 416-9032	7/26/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	AHU IS NOT COMING ON THE ENTIRE BLDG IS HOT. SBE HILL 416-9032	7/29/13			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	UNIT IN FACILITIES OFFICE IS NOT COOLING SBE HILL	7/30/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	UNIT IN THE MAIN OFFICE IS NOT COOLING. SBE HILL 416-9032	8/6/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	A/C in room 101 not cooling per Cameron Hill 416-2060	8/6/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	AIR COOLED CHILLER-NOT COOLING ENTIRE BLDG-SBE HILL 416-9032 KLR	8/9/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	a/c library blowing hot air per Cameron Hill 416-9032	8/12/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	FCU-1 RM 107-NOT COOLING-SBE HILL 416-9032 KLR	8/12/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	room 102 a/c not cooling per cameron hill 4164495	8/14/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	FCU OVER COOLING (63) IN RM-100 PRE-K PLANT MGR-HILL/416.4495	8/19/13			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	FCU NOT COOLING IN RM-118 PLANT MGR- HILL/416.4488	8/19/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	FCU RM 126-NOT COOLING-SBE HILL 416-9032 KLR	8/21/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	chiller down	7/8/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	FCU NOT COOLING IN LIBRARY PLANT MGR- HILL/416.4495	8/21/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	Monthly - Filter-Bruce Elementary - Refer to PM schedule details.	9/6/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	A/C RMS 111 & MULTI- PURPOSE RM-BOTH NOT COOLING- PLANT MGR HILL 416- 1466 KLR	9/11/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	A/C RMS 121 & MUSIC RM-BOTH NOT COOLING-PLANT MGR HILL 416-1466 KLR	9/11/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	A/C unit in the LIBRARY is NOT COOLING per Mr. Cameron Hill, Plant Mgr. 416.1466.	9/18/13			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	A/C 128-NOT COOLING-PLANT MGR HILL 416-9032 KLR	9/19/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	rooms 128, 112, 102, 103 a/c not cooling per Cameron Hill 416-9032	9/19/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	rm 107 not cooling	9/20/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	rm 127 not cooling	9/20/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	rm 115 not cooling	9/20/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	rm 111 not cooling	9/20/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	CHILLER - NOT WORKING HAS NOT AIR IN THE ENTIRE SCHOOL - PM/HILL 416-9032	9/24/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	rooms 109, 110, 115, 117 are not cooling per Cameron Hill 416-9032	9/24/13			Heating/Ventilation /Air Conditioning

Bruce ES (2060) 1A	chiller down	10/17/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	CHILLER NOT COOLING . PLANT MGR- HILL/826.8480	10/22/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	facilities office and rooms 128, 129, 116, 115 are very very hot per cameron hill 416-9032	10/24/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	RM 115-IS REAL COLD-HAVE NOT BEEN SWITCH TO HEAT-PLANT MGR HILL 416-4495 KLR	10/28/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	A/C LIBRARY AREA- NOT COOLING- PLANT MGR HILL 416-9032 KLR	9/19/13			Heating/Ventilation /Air Conditioning
Bruce ES (2060) 1A	REPAIR DAMAGE PLASTER AND PAINT UNDERNEATH CARPORT AREA	7/12/13	1st Floor	EXTER. EAST MAIN BLDG	Painting
Bruce ES (2060) 1A	Stain and finish swing gate	4/10/14			Painting

Bruce ES (2060) 1A	replace broken commode seat/ handicap stall	6/23/14	1st Floor	s/w boys restroom	Plumbing
Bruce ES (2060) 1A	repair or replace bad flush valve/ commode will not flush	6/23/14	1st Floor	s/e girls restroom	Plumbing
Bruce ES (2060) 1A	secure water fountain against wall/about to come from wall	5/19/14	1st Floor	s/e hall	Plumbing
Bruce ES (2060) 1A	SECURE BACK IN PLACE WATER FOUNTAIN HAS COME FROM WALL	5/19/14	1st Floor	S/E HALL	Plumbing
Bruce ES (2060) 1A	south east restroom have bad flush valve/leaking water on tile floors when flush	11/8/13	1st Floor	BOYS RESTROOM	Plumbing
Bruce ES (2060) 1A	HOOK UP NEW FOUR BURNER RANGE/ALREADY AT THE SCHOOL	12/4/13	Kitchen	KITCHEN	Plumbing
Bruce ES (2060) 1A	Test and report on backflow prevention devices.	12/19/13			Plumbing
Bruce ES (2060) 1A	wash sink need to be secured against wall/slightly hanging/south wall	1/13/14	1st Floor	cafeteria	Plumbing

Bruce ES (2060) 1A	Test and report on backflow prevention devices.	1/21/14			Plumbing
Bruce ES (2060) 1A	BACK FLR VALVE IS LEAKING IN KITCHEN PLANT MGR-HILL/416.4495	1/28/14			Plumbing
Bruce ES (2060) 1A	WATER is BACKING UP W/SMELL; coming from two (2) DRAIN HOLES in the KITCHEN per Mr. Cameron Hill, Plant Mgr. 416.1466	2/20/14			Plumbing
Bruce ES (2060) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing
Bruce ES (2060) 1A	per hill 416-9037 no hot water in the kitchen	3/24/14			Plumbing
Bruce ES (2060) 1A	REPAIR OR REPLACE FLUSH HANDLER ON COMMODE/ NOT FLUSHING	3/25/14	1st Floor	FACULTY AREA RESTROOM	Plumbing
Bruce ES (2060) 1A	commode will not flush reair	3/26/14	1st Floor	main office area	Plumbing
Bruce ES (2060) 1A	faucet on ythree compartment sink is dripping water	3/26/14	Kitchen	kitchen	Plumbing

Bruce ES (2060) 1A	repair water constantly running wash sink/ bad washers	4/11/14	1st Floor	cafeteria	Plumbing
Bruce ES (2060) 1A	FCU CLINIC-LEAKING-PLANT MGR HILL 416-4495 KLR	4/30/14			Plumbing
Bruce ES (2060) 1A	UNIT IN THE MAIN OFFICE CONFERENCE RM IS LEAKING WATER/ SBE HILL 416-9032	7/17/13			Plumbing
Bruce ES (2060) 1A	AHU IS LEAKING WATER IN GUIDANCE OFFICE CARPET (NO ID) SBE-HILL/416-9032	7/17/13			Plumbing
Bruce ES (2060) 1A	WATER HEATER BOILER RM-NOT HEATING WATER TO KITCHEN-SBE HILL 416-9032 KLR	8/1/13			Plumbing
Bruce ES (2060) 1A	FCU IS LEAKING WATER IN RM-100. PLANT MGR-HILL/416.4495	8/7/13			Plumbing
Bruce ES (2060) 1A	mop sink stopped up	8/21/13	1st Floor	facility room	Plumbing
Bruce ES (2060) 1A	FCU IS LEAKING IN RM-101 PLANT MGR-HILL/416.4495	8/21/13			Plumbing

Bruce ES (2060) 1A	water cooler not working/ no water coming out	9/9/13	1st Floor	resource room	Plumbing
Bruce ES (2060) 1A	WATER FOUNTAIN LEAKING WATER FROM UNDERNEATH BODY FAME	10/14/13	1st Floor	N/E HALL BY RESTROOM	Plumbing
Bruce ES (2060) 1A	ROOF LEAK ON TILE FLOORS/BUCKET CATCHING WATER	2/4/14	1st Floor	104	Roof
Bruce ES (2060) 1A	leaking water on floor tile	4/30/14	Clinic	restroom	Roof

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Guthrie-Caldwell ES (2067) 1B	1	2	44	59	61	6	28	6	1	208
Grand Total	1	2	44	59	61	6	28	6	1	208

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Guthrie-Caldwell ES (2067) 1B	Insulate pipes hall in front of boiler room door	11/14/13			Asbestos
Guthrie-Caldwell ES (2067) 1B	Internet port in main office is down. Need to have the Main 10 and off 7 up and running.	7/10/13	Administration Area	Main office	Cabling
Guthrie-Caldwell ES (2067) 1B	room 120 and 209 need jacks checked for connectivity	6/16/14			Cabling
Guthrie-Caldwell ES (2067) 1B	Coat racks needed to hang coats and backpacks	5/29/14	Classroom	East 2nd floor hall classrooms	Carpentry
Guthrie-Caldwell ES (2067) 1B	Need coat racks hung for coats and backpacks	5/29/14	Classroom	West 2nd floor classrooms	Carpentry
Guthrie-Caldwell ES (2067) 1B	Need coats racks hung for coats and backpacks	5/29/14	Classroom	East 1st floor hall classrooms	Carpentry
Guthrie-Caldwell ES (2067) 1B	Need coat racks hung for coast and backpacks	5/29/14	Classroom	West 1st floor classrooms	Carpentry

Guthrie-Caldwell ES (2067) 1B	The Front and Back glass door was kicked out the last day of school. They put boards up there; however everytime you open doors the scattered glass falls. This is a safety risk. These are the only areas to enter building with ID. Urgent reply.	7/9/13	Administration Area	Front & Back area	Carpentry
Guthrie-Caldwell ES (2067) 1B	The stall door is fallen off the hinge. Students can and will get hurt. I also have a door on the 2nd floor boys that's the same way. Urgent reply needed. I put caution tape up and it's not helping	2/12/14	Restroom (Girls)	near 116	Carpentry
Guthrie-Caldwell ES (2067) 1B	The entire stall door is about to fall down. This door is very heavy and this is a 1st grade hall. Urgent reply before the door falls and someone gets hurt. I can't repair it.	1/30/14	Restroom (Boys)	1st floor hall	Carpentry
Guthrie-Caldwell ES (2067) 1B	The cylinder is about to come out of the lock. Urgent reply needed.	2/7/14	Classroom	109	Carpentry
Guthrie-Caldwell ES (2067) 1B	PROVIDE CHAIN AND SECURE PADLOCK FOR CAGE AT REAR OF CAFE.	11/19/13			Carpentry
Guthrie-Caldwell ES (2067) 1B	FURNISH TO BUILDING MANAGER TWO CHAINS AND TWO LOCKS TO LOCK OUTSIDE GATES.	11/20/13			Carpentry
Guthrie-Caldwell ES (2067) 1B	The Handle on door keeps sticking. It's getting stuck more often for some reason.	12/19/13	Classroom	Pre-K 102	Carpentry
Guthrie-Caldwell ES (2067) 1B	There are 15 or more ceiling tile that has sever wet/brown color wet stains on them. The ceiling is to high for me to reach on a 8ft ladder. Urgent reply needed.	12/20/13	Classroom	Music room	Carpentry

Guthrie-Caldwell ES (2067) 1B	Outside screen windows need to be repaired. Someone broke the screens and I can't get them to lock. The windows are secured, but the screens need to be locked from the outside.	1/6/14	Classroom	120 and 122	Carpentry
Guthrie-Caldwell ES (2067) 1B	The wood work from the bottom of the window is falling off and nails are exposed. The door door is hanging to. It's pushing into the window.	2/14/14	Restroom (Girls)		Carpentry
Guthrie-Caldwell ES (2067) 1B	Metal bar has start to fall. I tried to put screw in it, but it's not holding. Urgent reply before it falls on someone. It's The door leading out of the cafe to the hallway area.	2/20/14	Cafetorium	exit door to hallway	Carpentry
Guthrie-Caldwell ES (2067) 1B	FRONT ENTRANCE DOOR HARDWARE HAS FALLEN CAUSING DOOR NOT TO BE SECURED-PLANT MGR FIFER 426-3220 KLR	3/24/14			Carpentry
Guthrie-Caldwell ES (2067) 1B	This panic bar is bad, the door will not open to let the staff or visiorts in. Urgent reply needed.	4/4/14	Administration Area	Side main entrance	Carpentry
Guthrie-Caldwell ES (2067) 1B	The staff door is fallen down. Urgent reply needed before it falls on one of these babies.	4/17/14	Restroom (Girls)	Pre K hall	Carpentry
Guthrie-Caldwell ES (2067) 1B	per ms fifer 416-3220 in the boys restroom on 2nd floor window is totally out (across from rm 207)	4/17/14			Carpentry
Guthrie-Caldwell ES (2067) 1B	The SIDE MAIN ENTRANCE DOOR will NOT SECURING per Ms. Fifer, Plant Mgr. 416.3220	4/21/14			Carpentry

Guthrie-Caldwell ES (2067) 1B	SIDE ENTRY DOOR HANDLE HAS CAME COMPLETELY OFF BY PARKING LOT PLANT MGR-FIFER/416.3244	5/5/14	Administration Area	Side Main Entrance	Carpentry
Guthrie-Caldwell ES (2067) 1B	The BEAM has fallen from the FIRE DOOR in the CAFETERIA per Ms. Fifer, Plant Mgr. 416.0307	5/9/14			Carpentry
Guthrie-Caldwell ES (2067) 1B	Windows needs to be sealed. When it rain last night, water came in from the windows.	7/16/13	Hallway/Corridor	Teachers back entrance	Carpentry
Guthrie-Caldwell ES (2067) 1B	Need to boxes of soft ceiling tile to replace the mold tile thats present in these areas.	7/25/13	Classroom	hallway area	Carpentry
Guthrie-Caldwell ES (2067) 1B	Need to have ceiling tile cut around the sprinkler heads and around some light fixtures. I changed what I could.	8/6/13	Hallway/Corridor	1st floor hall	Carpentry
Guthrie-Caldwell ES (2067) 1B	Pole/ fence are bend around gate from the neighborhood children. I will have to put a lock on fence, to keep them out. The state Dept inspects this area and it must be up to code for the students.	8/19/13	Courtyard	pre K playground area	Carpentry
Guthrie-Caldwell ES (2067) 1B	Glass door is off the hinge. Students are tryn to slap the door shut and will break the entire glass door. Urgent reply needed.	9/3/13	Library	main entrance	Carpentry
Guthrie-Caldwell ES (2067) 1B	Rubber stairs is coming up. I put tape down to hold rubber down. This is a tripping hazzard coming down the stairs. Urgent reply needed. Clear tape is not going to hold this rubber down.	9/6/13	Hallway/Corridor	stairwell near Pre-K	Carpentry

Guthrie-Caldwell ES (2067) 1B	The entire rubber step cover came off after a teacher slip/fell on it!. There is also the top of the rubber cover is coming off the stairs too. Urgent reply needed before someone gets hurt coming down the stairs. I had a ticket in for the other set of stairs in the hallway.	11/1/13	Hallway/Corridor	Near Pre-K	Carpentry
Guthrie-Caldwell ES (2067) 1B	ENTRANCE DOOR PRE-K AREA-NOT CLOSING-WON'T BE ABLE TO SECURE-PLANT MGR FIFER 416-3220 KLR	11/14/13			Carpentry
Guthrie-Caldwell ES (2067) 1B	ENTRANCE DOORS PRE-K AREA-NOT CLOSING-WON'T BE ABLE TO SECURE-PLANT MGR FIFER 416-3220 KLR	9/19/13			Carpentry
Guthrie-Caldwell ES (2067) 1B	entire floor tile inside elevator needs to be repaired or replaced. The tiles are broke and I have put tape down to hold it together to keep people from tripping on the broke tile. Urgent reply needed.	9/25/13	Elevator	floor	Carpentry
Guthrie-Caldwell ES (2067) 1B	The tile at the doors where the student enter in the mornings needs to be replaced. From all the heavy rains the other day, water came under the door and damage the tile. This is a safety issue. Urgent reply needed.	9/25/13	Hallway/Corridor	students entrance	Carpentry
Guthrie-Caldwell ES (2067) 1B	Fire Doors or Latchings not closing properly. Stairwell at Main Lobby, Mechanical room up & down stairs. The Fire Marshall wrote these infractions up yesterday. Urgent reply needed	10/1/13	Mechanical Room	Stairwell/Main lobby	Carpentry
Guthrie-Caldwell ES (2067) 1B	I have no ceiling tile on site and most of these areas are too high for me to reach. Urgent reply needed.	5/27/14	Classroom	music room, 204, 122 closet, 220, library hall	Carpentry
Guthrie-Caldwell ES (2067) 1B	Replace stall doors in boys restrooms on 1st place	5/29/14	Restroom (Boys)	1st grade hall	Carpentry

Guthrie-Caldwell ES (2067) 1B	Replace tread on stairwell. It has come completely off stairs. Urgent reply	5/29/14	Stairway	near Pre k hall	Carpentry
Guthrie-Caldwell ES (2067) 1B	Ceiling tile needs to be replaced ober the intercome and sprinkler system inside the guidance area. It's the 2nd room in that inner office. I have moved everything out so you can get to it.	5/29/14	Classroom	2nd room inside the glass office	Carpentry
Guthrie-Caldwell ES (2067) 1B	I was out yesterday and the teacher got locked out the room. The GCA staff broke the lock off the door because it wouldn't open. Urgent reply to fix the door.	5/23/14	Classroom	Pre-K room 101	Carpentry
Guthrie-Caldwell ES (2067) 1B	Repair Baseboard in classroom.	5/27/14	Classroom	103	Carpentry
Guthrie-Caldwell ES (2067) 1B	Need to have damage/wet ceiling tile replaced around the speak and sprinkler system. I can't remove tile to replace it. It's starting to smell.	6/18/14	Administration Area	Guidance office/closet	Carpentry
Guthrie-Caldwell ES (2067) 1B	custodial closet door is off track. Need to have it fixed so, we can keep the door at all times when school starts.	6/18/14	Custodial	2nd floor back hall	Carpentry
Guthrie-Caldwell ES (2067) 1B	Someone stole the units to the freezers on yesterday. I'm requesting that barb wire be placed around the fence area. The unit was in it's on cage. Someone may have a key that's getting in stealing these units. We don't have cameras in this building at	11/19/13	Kitchen	Back area	Carpentry
Guthrie-Caldwell ES (2067) 1B	P.E teacher request for some curtains to be hung on the stage area to put the pe equipment behind. We are merging with Gordan and don't have enough space in the cafe for storage all this equipment.	5/20/14	Cafetorium	Stage area	Carpentry

Guthrie-Caldwell ES (2067) 1B	Ballast has burned out in the hall in front of the girl/boys restroom. It kinda dark to them.	2/12/14	Hallway/Corridor	near 116	Electrical
Guthrie-Caldwell ES (2067) 1B	Bells need to be reset for new start time 8:00-3:00	7/5/13	Administration Area		Electrical
Guthrie-Caldwell ES (2067) 1B	chiller down	7/9/13			Electrical
Guthrie-Caldwell ES (2067) 1B	LIGHT POLE in FRONT OF SCHOOL has been KNOCKED DOWN TO THE GROUND and WIRES ARE EXPOSED per Ms. Fifer, Plant Mgr. 416.3220	1/30/14			Electrical
Guthrie-Caldwell ES (2067) 1B	The Ballast is out over the computer table. I replace the bulbs and two other light housing that came back on.	11/20/13	Classroom	209	Electrical
Guthrie-Caldwell ES (2067) 1B	The outlet outside 112 does not work.	12/18/13	Hallway/Corridor	outside 112	Electrical
Guthrie-Caldwell ES (2067) 1B	There are two sets of ballast thats out. One over teachers desk and over computer board.	12/19/13	Classroom	109	Electrical
Guthrie-Caldwell ES (2067) 1B	There are 2 sets of ballist that has burned out. I change the bulbs this morn, but the back half of room is very dark over teaching board.	1/6/14	Classroom	113	Electrical

Guthrie-Caldwell ES (2067) 1B	The ballast has burned out in hall behind library and front of Boiler room.	1/10/14	Hallway/Corridor	behind library	Electrical
Guthrie-Caldwell ES (2067) 1B	In the hall in front of girls restroom. The lights keep flickering. It will make you have a seizure. Urgent reply needed. Special ED area	1/10/14	Hallway/Corridor		Electrical
Guthrie-Caldwell ES (2067) 1B	The ballast has burned out ti the closet. It's keep blinking.	1/16/14	Custodial Closet	1st floor hall	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has burned out over the alarm panel.	2/14/14	Administration Area	Main Office	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast out over the cashier area. Very dark. Urgent reply needed.	2/20/14	Kitchen	servicing area	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has burned out over the cashier stand. Area very dark. Urgent reply needed.	2/20/14	Kitchen	servicing area	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has burned out in the hall on first floor in frin tof both restrooms near rooms 115	2/20/14	Hallway/Corridor	1st floor hall near girls/boys restroom	Electrical
Guthrie-Caldwell ES (2067) 1B	The ballast has burned out. The light housing was turning red with bulbs inside?	2/20/14	Restroom (Boys)	2nd floor	Electrical

Guthrie-Caldwell ES (2067) 1B	Need to have the bells reset for daylight saving time. (SCS Network Cabling and Electronics dept.--Response – Please have electrician to service this request first, let us know if our help is needed to assist.	2/21/14	Administration Area	Main Office	Electrical
Guthrie-Caldwell ES (2067) 1B	There are 2 ballast out. One is blinking and the other didn't come back on when I changed the bulbs. Over the teacher desk and reading area.	3/26/14	Classroom	108	Electrical
Guthrie-Caldwell ES (2067) 1B	The light is flickering in the IT storage room in library. Room 216 also has a flickering light over teachers desk. The bulbs have be replaced but are still flickering.	4/9/14	Library	library and room 16	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has blown in the guidance area where they hold parent meetings. urgent reply needed.	4/9/14	Administration Area	Guidance area	Electrical
Guthrie-Caldwell ES (2067) 1B	The huge light in front of the school has been turned over. I can't move it!! It's heavy and the wires are exposed. Urgent reply needed today, so the kids won't mess with it at dismissal	5/7/14	Administration Area	Front of School	Electrical
Guthrie-Caldwell ES (2067) 1B	The following work order number 364412 was decline. I didn't have bulb number or count. I need the following bulbs and here's the number 46807 rapid start lamp 72 count and 42w 4 pin T/E Eco for main hall, and lobby area.	7/16/13	Classroom	cafe and hallway	Electrical
Guthrie-Caldwell ES (2067) 1B	There are about 7-8 big halogen lamps that are burned out in the dinning area. Switches have been turn on, but lights are not coming on. Urgent reply. Bring bulbs??	7/22/13	Cafetorium	Dinning area	Electrical
Guthrie-Caldwell ES (2067) 1B	Need about 20 flood lamps for stage area. Completely DARK.	7/23/13	Cafetorium	Stage area	Electrical

Guthrie-Caldwell ES (2067) 1B	I need 20 flood light lamps 90 watts stock number 46781.	7/23/13	Cafetorium	stage area	Electrical
Guthrie-Caldwell ES (2067) 1B	I need (16)- 26w compact floresent 4 pin bulbs. #F26DBX/835/ECO4P	7/23/13	Administration Area	Hallway/Corridor	Electrical
Guthrie-Caldwell ES (2067) 1B	I need (12)-26w compact floresent 2 pin lamp#F26DBX/835	7/23/13	Hallway/Corridor	Front lobby area	Electrical
Guthrie-Caldwell ES (2067) 1B	I need 50 rapid start Flr. lamp Stock# 46807	7/23/13	Classroom	Halls, Office, etc	Electrical
Guthrie-Caldwell ES (2067) 1B	I need (12) F32TBX/SPX35-835/4P	7/23/13	Administration Area	2nd lobby area	Electrical
Guthrie-Caldwell ES (2067) 1B	Bulbs has been replaced. (3) Ballast has burned out	7/23/13	Hallway/Corridor	Main Hall	Electrical
Guthrie-Caldwell ES (2067) 1B	Manager can't get power on the steamer. Urgent reply	7/29/13	Cafeteria	Kitchen serving area	Electrical
Guthrie-Caldwell ES (2067) 1B	There are twosets of ballast that has burn out in the hall near the copier. These lights uses 2 pin bulbs.	8/15/13	Administration Area	main office	Electrical

Guthrie-Caldwell ES (2067) 1B	Ballast has burned out with 4 bulb tube over Nurse desk.	8/15/13	Administration Area	Health Center in Main Office area	Electrical
Guthrie-Caldwell ES (2067) 1B	There are two sets of ballast that burned out. Hall very dark and gloomy	8/23/13	Hallway/Corridor	near room 211 & 213	Electrical
Guthrie-Caldwell ES (2067) 1B	I need three boxes of rapid start bulbs for classrooms and hallways. Urgent reply needed. That will be 75 bulbs. stock number 46807	8/23/13	Mechanical Room	boiler room	Electrical
Guthrie-Caldwell ES (2067) 1B	There are ballast out in the boys and girls restroom on 1st floor hall near 108	9/6/13	Restroom (Boys)	and girls RR near 108	Electrical
Guthrie-Caldwell ES (2067) 1B	There are several ballast out. Bulbs has been replace. In 113 ballast out near board. In 114 there are two ballast out with 2 bulbs burning in the fixture	9/6/13	Classroom	113 & 114	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has burn out in hall front of Pre-K entrance. Very dark for those babies at the end of the hall. urgent reply needed.	9/6/13	Hallway/Corridor	near Pre-K	Electrical
Guthrie-Caldwell ES (2067) 1B	I need two boxes of rapid start bulbs to replace these burned out lights. Urgent reply needed Mr. White. The ticket was decline for whatever reason, I sent you an email so, I need bulbs ASAP.	11/1/13	Classroom	main hall, back hall	Electrical
Guthrie-Caldwell ES (2067) 1B	Guthrie-Caldwell- WO395409 -- Master Clock needs to be program in the Main Office for time change. Bells are not ringing at the correct time. Urgent reply needed. We cant all call cause system is hooked to go over the neighborhood. Requested to	11/5/13	Administration Area	Main Office	Electrical

Guthrie-Caldwell ES (2067) 1B	There are two sets of ballast that are out in front and back of room. Urgent reply teacher cant see over desk.	11/5/13	Classroom	215	Electrical
Guthrie-Caldwell ES (2067) 1B	The ballast has burned out. I change bulbs, but didn't come back on. The elevator man has a hard time seeing. He will have to come back, it was too dak for him to see.	11/8/13	Elevator	Equipment Closet	Electrical
Guthrie-Caldwell ES (2067) 1B	There are 3 ballast that has burned out. There is also a 2 pin ballast out in that same hall. Bulbs have been replaced in this area They didn't come back on.	9/13/13	Hallway/Corridor	2nd floor behind library	Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has burned out. Its located behind the library on the back hall.	9/13/13	Restroom (Boys)	2nd floor back hall behind library	Electrical
Guthrie-Caldwell ES (2067) 1B	The Ballast has burned out over the food serving line. Urgent reply. Health Dept wrote this up.	9/19/13	Kitchen	Serving Line	Electrical
Guthrie-Caldwell ES (2067) 1B	Emergency Light not working properly in the following area. Main office lobby, south of guidance office, cafeteria nw,sw,se wall. The music room, bolier room, room 101, stairwell near 201, room 220 and library entrance 2nd floor lobby. Urgent	10/1/13	Administration Area	and Guidance area	Electrical
Guthrie-Caldwell ES (2067) 1B	Provide sockets covers for all Pre-K rooms per Fire Marshall inspection on Yesterday.	10/1/13	Classroom	all Pre-K rooms	Electrical
Guthrie-Caldwell ES (2067) 1B	Check chiller	10/15/13			Electrical

Guthrie-Caldwell ES (2067) 1B	Daniel request that an electrician come over to check the exhaust fan. We have been having foul odors in the building. Urgent reply needed	5/14/14	Mechanical Room	Exhaust Fan	Electrical
Guthrie-Caldwell ES (2067) 1B	Recess light hanging out of ceiling in library. Its working, but light and wires hanging.	5/16/14	Library	Over Teacher Desk	Electrical
Guthrie-Caldwell ES (2067) 1B	The ballast has burned out in hall. The light is located in the hall of the restrooms.	5/20/14	Hallway/Corridor	Pre-K hall in front of restrooms	Electrical
Guthrie-Caldwell ES (2067) 1B	Lights are out in the electrical closet on the 2nd floor back hall and the front hall near glass windows.	5/27/14	Mechanical Room	electrical closet, 1st floor hall	Electrical
Guthrie-Caldwell ES (2067) 1B	CHILLER IS IN ALARM-PLANT MGR FIFER 416-3220 KLR	10/15/13			Electrical
Guthrie-Caldwell ES (2067) 1B	Ballast has burned out in hall near the boys/girls restrooms in front of the water fountain.	6/18/14	1st Floor	1st floor hall	Electrical
Guthrie-Caldwell ES (2067) 1B	POWER OUTAGE throughout the ENTIRE BUILDING per Ms. Fifer, Plant Mgr. 901.413.8202	6/23/14			Electrical
Guthrie-Caldwell ES (2067) 1B	A/C UNIT is NOT COOLING in the MAIN OFFICE per Ms. Taylor, Plant Mgr. 416.3220	6/4/14			Electrical

Guthrie-Caldwell ES (2067) 1B	Need two cases of rapid start bulbs. I have changed out most of the building, until I ran out of bulbs. Urgent reply needed to finish the job on 2nd floor hall, restrooms and classrooms 2nd floor halls.	9/6/13	Administration Area	Boiler room	Electrical
Guthrie-Caldwell ES (2067) 1B	I need one box of rapid start light tubes for classrooms.	1/21/14	Classroom	all classrooms	Electrical
Guthrie-Caldwell ES (2067) 1B	I need two boxes of rapid start bulbs at Caldwell Guthrie. I still have lights I need to change but ran out of bulbs	2/14/14	Mechanical Room	1st floor hall	Electrical
Guthrie-Caldwell ES (2067) 1B	Monthly - Filter-Guthrie Elementary - Refer to PM schedule details.	6/3/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Supply electric heaters and sensor for roof mounted chiller. (Installed by contractor) YORK CHILLER	10/15/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	CHECK CHILLER ON ROOF. ONE CIRCUIT WILL NOT RUN.	5/12/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	BOILER IS IN ALARM. PLANT MGR-FIFER/416.3220	2/13/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	CHILLERS ARE NOT COMING ON ENTIRE BLDG IS HOT. SBE FIFER	7/1/13			Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	clean chiller	7/2/13				Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	HEAT RM 114-NOT HEATING-PLANT MGR FIFER 416-3220 KLR	1/21/14				Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	EM said that the the system is faulted. Urgent reply. Principal Hill can't work in there, it's too cold!	1/22/14	Administration Area		Principal conference	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	These rooms are freezing. EM said it's reading 70.5, but it's blowing out cold air.	1/22/14	Classroom		114/213	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	rm 215 not heating	1/27/14				Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	fix coil	1/28/14				Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Its some kind internal problem. EM states everything is working on there end, but the room is freezing. Reading 62 degree	1/28/14	Classroom		121	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Monthly - Filter-Guthrie Elementary - Refer to PM schedule details.	2/4/14				Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	BOILER HAS LOW WATER NOT HEATING. PLANT MGR-FIFER/416.3220	2/4/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	HEAT RM 119-NOT HEATING- PLANT MGR FIFER 416-3220 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	BOILER IS MAKING NOISE ON 2ND FLR PLANT MGR-FIFER/416.3220	11/19/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	PUMPS NOT COMING ON IN BOILER RM PLANT MGR-FIFER/416.3244	11/22/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	boilers down	11/25/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	The entire building is FREEZING!! The pipes are going to burst. Urgent reply Needed to get the HEAT working properly. I did submit a ticket on one of the boilers down. They came to get the chillers up, they were down	11/25/13	Administration Area	Entire Building	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Both chillers are in alarm, The school is in dis stress from the heat! Urgent reply needed. The principal can't work in the office it's that hot. The boilers are not on.	12/4/13	Administration Area	Entire Building	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	The first boiler is down! There are no lights on indicating it's on and working. The 2nd boiler has lights and you can hear it running. Urgent reply needed. We do have one boiler up and running, but it's not pulling the entire building.	12/9/13	Mechanical Room	Boiler room 1st floor	Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	These area are freezing. There is no heat. The Air is blowing!!! Help...Urgent reply needed.	1/6/14	Classroom	215. Library, 210, 122, halls	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	boiler down	1/8/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Please have someone to check room 213. One day it's warm and other days its freezing. I don't think this stat works. She complains everyday?	1/9/14	Classroom	213	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	PUMP NUMBER 4 ON BOILER NUMBER ONE NEEDS TO BE RESET	1/16/14		BOILER NO. 1	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	per ms fifer 416-3220 low water light on boiler	3/5/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Teacher and students state room is cold.	3/17/14	Classroom	112	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	AHU RM on 2nd flr ---- start up unit	3/19/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	CHILLER NEEDS TO BE RESET MAIN OFFICE ARE HOT PLANT MGR-FIFER/416.3220	4/2/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Main chiller for the office is down again. It's hot urgent reply needed	4/3/14	Administration Area	main office	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Rooms are not cooling. It's reading 77 in one and 78 in the other.	4/3/14	Classroom	211 & 212	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	HVAC had it working yesterday, came in today it's hot after EM shut the system down over night. Urgent reply needed it's reading 80 from the stat.	4/3/14	Administration Area	Main Office	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	ofc chiller	4/21/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	CHILLER-2 MECH RM-IN ALARM PLANT MGR FIFER 416-3244 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Chiller #2 NOT COMING ID#077-060 per Ms. Fifer at 901.413.8202.	7/10/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	replace two heaters and oil sensor	7/19/13			Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	check chiller	7/23/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Unit ventilator needs to be cleaned out. It's full of trash. I can't open it. Thermostat box not reading or broke.	7/23/13	Classroom	room 208	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Unit 1128 not cooling the library area or classrooms upstairs. Valve opening must stuck? Teachers in building complaining	7/29/13		library and classrooms upstairs	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Room is not cooling. It gets very hot around 10:00	8/8/13	Classroom	211	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	rm 114 and 208 no power to stats - not cooling	8/20/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	A/C IN RM 211-NOT COOLING-SBE FIFER 416-3220 KLR	8/20/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	UV RMS 208 & 211-BOTH NOT COOLING-PLANT MGR FIFER 416-3220 KLR	8/22/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	This room is reading 77 this morning. Teacher states its too hot. Urgent reply. I have called energy Management several times on yesterday, but got no answers.	8/27/13	Classroom	208	Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	The temp in the main office is reading 78 Principal states that's too hot. urgent reply needed	10/30/13	Administration Area		Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	show plant manager how to cut on boiler	11/8/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Monthly - Oil Lube & Belt-Guthrie Elem - Refer to PM schedule details.	11/11/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	unit not heating. Stat box is not working also.	11/13/13	Classroom	116	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	The room is so HOT the students were complaining they couldn't breathe. I had to turn the breaker off to the unit. Stat may not be working properly. Need someone to look at this ASAP	11/14/13	Classroom	210	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	There is a flame failure light on one of the boilers. It's cold in some parts of the building. Urgent reply needed. I also need someone to check the boiler on the 2nd floor also. It's freezing up there! I smell some gas fumes? on that hall near the boiler room	11/14/13	Mechanical Room	boiler room 1st floor	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	boiler down	11/18/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	chiller down	9/9/13			Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	The controllers has gone bad in both of these rooms. I spoke with energy management about this. Rooms are FREEZING>>>>	9/18/13	Classroom	215 & 217	Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Monthly - Filter-Guthrie Elementary - Refer to PM schedule details.	10/1/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	replace cond. motors on ckt 2 main bldg chiller	5/16/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	chiller down	5/27/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	chiller down	6/23/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	ofc chiller down	6/4/14			Heating/Ventilation /Air Conditioning
Guthrie-Caldwell ES (2067) 1B	Monthly - Oil Lube & Belt-Guthrie Elem - Refer to PM schedule details.	6/9/14			Heating/Ventilation /Air Conditioning

Guthrie-Caldwell ES (2067) 1B	We are requesting that all the outside doors be painted. Someone has marked the doors with gang signs and cuss words. There are 4-5 outside fire double doors that need to be painted over to remove the markings. Urgent reply needed.	10/17/13	Administration Area	entire	Painting
Guthrie-Caldwell ES (2067) 1B	Merger of new staff from Gordan request that these rooms be painted. They are an eyesore.	5/27/14	Classroom	116, 108, 103	Painting
Guthrie-Caldwell ES (2067) 1B	Teachers merge from Gordan request that these rooms be painted. Asap	5/27/14	Classroom	214, 220	Painting
Guthrie-Caldwell ES (2067) 1B	Need to have the outside doors painted. They are an eyesore and have marks in bedded in the old paint. Has gang and cuss words. All outside door to cafe and kitchen there are 6 doors total.	6/18/14	Administration Area	outside doors/cafe	Painting
Guthrie-Caldwell ES (2067) 1B	We need to have the handrails painted!. Everytime you touch the rails rush comes over over your hands. We have wipe and wipe. There is no paint present on rails, they are rusty. Urgent reply needed.	6/18/14	Hallway/Corridor	stairwells near main office and back hall	Painting
Guthrie-Caldwell ES (2067) 1B	Paint a/c grill	6/13/14			Painting
Guthrie-Caldwell ES (2067) 1B	Repair coil	2/14/14			Plumbing
Guthrie-Caldwell ES (2067) 1B	Test and report on backflow prevention devices.	1/21/14			Plumbing

Guthrie-Caldwell ES (2067) 1B	boys restroom on Pre K 1st floor need the toilet and urnial repaired. I had to cut it off due to the water leaking from the flush handles and water all iver the floor. This is prek area and didn't want anyone getting hurt. Urgent reply	1/28/14	Classroom		Plumbing
Guthrie-Caldwell ES (2067) 1B	2nd stall in boys restrooms messed up. Flooding the restroom. Urgent reply needed.	2/12/14	Classroom	near room 116	Plumbing
Guthrie-Caldwell ES (2067) 1B	The water in the hand sink will barley come on. They need to wash their hands!! Urgent reply needed.	12/10/13	Administration Area	Teacher's lounge	Plumbing
Guthrie-Caldwell ES (2067) 1B	WATER IS RUNNING IN BOILER RM. PLANT MGR-FIFER/416.3220	12/13/13			Plumbing
Guthrie-Caldwell ES (2067) 1B	Repair back flow preventer	12/16/13			Plumbing
Guthrie-Caldwell ES (2067) 1B	The water in handsink will not turn on. The plumber is here he can fix it.	12/16/13	Restroom (Boys)	Teachers Lounge	Plumbing
Guthrie-Caldwell ES (2067) 1B	Test and report on backflow prevention devices.	12/19/13			Plumbing
Guthrie-Caldwell ES (2067) 1B	Air Handler Pipe has BURST in the BOILER ROOM per Ms. Fifer, Plant Mgr. 416.3220	1/7/14			Plumbing

Guthrie-Caldwell ES (2067) 1B	COMMODE B RR MAIN HALL-LEAKS WHEN FLUSHED-LEAD HILL 416-3220 KLR	2/25/14			Plumbing
Guthrie-Caldwell ES (2067) 1B	Both of these restrooms has water running from the flush handle. I had to turn the water off. Urgent reply needed to have this working properly. 1st floor hall on the Main Office hall.	2/27/14	Restroom (Girls)	Girls and Boys	Plumbing
Guthrie-Caldwell ES (2067) 1B	The boys restroom the toilet just keep running and will not stop. Sign on door but students still use it. Urgent reply needed. Other restroom on the back hall and other hall.	2/27/14	Restroom (Boys)	2nd floor hall	Plumbing
Guthrie-Caldwell ES (2067) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing
Guthrie-Caldwell ES (2067) 1B	Toilet Keeps running over. Something is lodged in the neck of the toilet. I can't unstop it.	4/17/14	Restroom (Boys)	2nd floor	Plumbing
Guthrie-Caldwell ES (2067) 1B	Last stall, the toilet seat is broke. Urgent reply needed.	5/6/14	Restroom (Boys)	Pre-K hall	Plumbing
Guthrie-Caldwell ES (2067) 1B	The 3rd stall is stopped up, it floods the restroom floor, when Im at my other school. urgent reply needed	5/6/14	Restroom (Girls)	Pre-k hall	Plumbing
Guthrie-Caldwell ES (2067) 1B	PIPE IN RM 115 IS LEAKING IN SEVERAL SPOTS AND IN THE MECHANICAL RM SBE FIFER 416-3220	7/25/13			Plumbing

Guthrie-Caldwell ES (2067) 1B	need to have new toilet seat. The one on there broke and pinches the children when they use it. They are special need, don't parents to think teachers doin some to students. Leaves their bottoms red and scratches	8/20/13	Classroom	CDC room 108	Plumbing
Guthrie-Caldwell ES (2067) 1B	SEWAGE SMELL OUTSIDE BY PARKING LOT. PLANT MGR-FIFER/416.3220	8/28/13			Plumbing
Guthrie-Caldwell ES (2067) 1B	There is not hot water in the boys restrooms, custodial closet and its running brown! Don't know if they turned the hot water back on after working on leaking pipes? or the hotwater heater is down. Please come and check on this. Kitchen has hot water to cook.	10/28/13	Restroom (Boys)	1st floor near cafe	Plumbing
Guthrie-Caldwell ES (2067) 1B	Can someone come out to check the hot water? There is no hot water in the custodial closet, Library kitchen area, most restrooms. They worked on the pipes a few months back and couldn't have turn the water back on. hot water is not running.	11/6/13	Mechanical Room	all areas	Plumbing
Guthrie-Caldwell ES (2067) 1B	Valve needs to be replaced on the Ice Machine. Someone came out while I was gone and stated to the cafe Manager that the valve was bad. It's not making ice.	9/17/13	Kitchen	Serving line	Plumbing
Guthrie-Caldwell ES (2067) 1B	UV IS LEAKING WATER IN RM-218 PLANT MGR-FIFER/416.3220	9/19/13			Plumbing
Guthrie-Caldwell ES (2067) 1B	Urinal is over flowing on the 2nd floor boys near 208. I tried to cut it off from the handle. The urinal on the 1st floor near the cafe is stopped up. Urgent reply cause kids will flood this area if they keep flushing.	9/25/13	Restroom (Boys)	2nd floor & 1st floor	Plumbing
Guthrie-Caldwell ES (2067) 1B	Gas leak please building	5/14/14			Plumbing

Guthrie-Caldwell ES (2067) 1B	OVEN NEED PILOT LIT - KITC - PM/FIFER 416-3220	5/20/14				Plumbing
Guthrie-Caldwell ES (2067) 1B	Replace toilet seat inside classroom restroom	5/27/14	Classroom	122		Plumbing
Guthrie-Caldwell ES (2067) 1B	There are several leaks. When it rains we have to put out 10 cans to catch these leaks. A student fell and got injured. Urgent reply because we get alot of rain.	2/14/14	Cafetorium		Roof	Roof
Guthrie-Caldwell ES (2067) 1B	I called in last week about a student that fell in cafeteria do to water leaks from the roof. Sighs were down, but it's leaks all over.	2/18/14	Cafetorium		dinning area	Roof
Guthrie-Caldwell ES (2067) 1B	I need to have this roof inspected. I have leaks everywhere when it rains! Now that this ice is melting, we have leaks in the following areas. Kitchen, Boiler room, cafeteria dinning. Urgent reply needed before this problem gets worse.	3/6/14	Administration Area		Entire roof top	Roof
Guthrie-Caldwell ES (2067) 1B	Cafeteria and 1st floor halls has several leaks today from the rain. Urgent reply	4/28/14	Cafetorium			Roof
Guthrie-Caldwell ES (2067) 1B	Need to have someone take a look at the roof to see if the water is coming form the roof instead of the windows. Rain from last night left water in building.	7/16/13	Hallway/Corridor		Roof	Roof
Guthrie-Caldwell ES (2067) 1B	The cafeterai is still leaking!! It's coming from the metal roof where it look like the screws are coming through that area. Uregnt reply needed.	5/14/14	Cafetorium		Entire area	Roof

Guthrie-Caldwell ES (2067) 1B	MEET WITH A/C TECHNICIAN (JIM CRUTHIRDS) TUESDAY MORNING. FABRICATE AND INSTALL COVER FOR REFRIGERANT LINES AT REAR OF SCHOOL.	12/2/13			Sheet Metal
----------------------------------	---	---------	--	--	-------------

Count of Craft	Craft							
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Campbell ES (2463)	1	20	24	44	2	50	6	147
Grand Total	1	20	24	44	2	50	6	147

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Campbell ES (2463) 1B	Lucie Campbell- 379877- cabling with not stay in the outlet (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	8/30/13	1st Floor	B105	Cabling
Campbell ES (2463) 1B	per ms dawson 416-1000 there are bricks falling in the multi-purpose room	4/1/14			Carpentry
Campbell ES (2463) 1B	rubber cover need repairing on the stairway both set south and east end urgent tripping hazzard	8/26/13	Stairway	east end	Carpentry
Campbell ES (2463) 1B	need 10 toilet paper holders vandal resistant	9/5/13	Restroom (Girls)	through-out	Carpentry
Campbell ES (2463) 1B	need toilet holders replacement	9/11/13	Restroom (Girls)	2nd floor	Carpentry
Campbell ES (2463) 1B	need toilet holders replacement	9/11/13	Restroom (Boys)	2nd floor	Carpentry
Campbell ES (2463) 1B	ceiling tile need replacement cut to shape	9/19/13	1st Floor	library	Carpentry
Campbell ES (2463) 1B	KEY WONT FIT INSIDE FIN SECRETARY'S DOOR, WONT OPEN. PLANT MGR-DAWSON/416.1000	9/26/13			Carpentry

Campbell ES (2463) 1B	need built in cabinet repair door hanging off	11/25/13	2nd Floor	201	Carpentry
Campbell ES (2463) 1B	need ceiling tile replacement also ceiling tile hanging from the ceiling need a lift urgent	1/17/14	Gym	p.e. room	Carpentry
Campbell ES (2463) 1B	cabing wire on the flag pole need repair plant manager can't put the flag out	1/24/14	Grounds	front of the school	Carpentry
Campbell ES (2463) 1B	First floor A wing (left of main entry) repair/adjust stall doors.	2/19/14	Restroom (Girls)		Carpentry
Campbell ES (2463) 1B	steel cabling have falling from the wood fence down on the ground kids are playing with the cabling rope on going problem.I have been request help with the problem the entire schoo year! it is getting warm outside urgent	3/21/14	Grounds	front of the school	Carpentry
Campbell ES (2463) 1B	bar falling off the exterior door	3/25/14	1st Floor	A wings entrance	Carpentry
Campbell ES (2463) 1B	bar falling off the exterior door	3/25/14	1st Floor	A wings entrance	Carpentry
Campbell ES (2463) 1B	handler bar falling off the exteroir door	3/25/14	1st Floor	A wing hallway	Carpentry
Campbell ES (2463) 1B	inside on the classroom door extremely hard to lock the door leads outside..	10/23/13	1st Floor	D106	Carpentry

Campbell ES (2463) 1B	SCATTERED GLASS WINDOW DOOR ON DOCK ENTRY. PLANT MGR-DAWSON/416.3940	10/28/13				Carpentry
Campbell ES (2463) 1B	can't get the stall door open	11/12/13	1st Floor	Awing boys restroom		Carpentry
Campbell ES (2463) 1B	cabinet door need repairing	11/22/13	2nd Floor	201		Carpentry
Campbell ES (2463) 1B	need 15 toilet paper holder	9/4/13	Restroom (Girls)	through out		Carpentry
Campbell ES (2463) 1B	pole lights 15 willnot come on to dark	10/1/13	Grounds	front entrance		Electrical
Campbell ES (2463) 1B	a little boy got shocked because he put a paperclip into a socket in the hallway on the 2nd floor. they need someone to come remove it so no one else will touch it and get shocked. per Ms. Dawson 416-1000	8/16/13				Electrical
Campbell ES (2463) 1B	need lights replacement in the light fixture 3 boxes F32T8/ADV841EW	8/28/13	1st Floor	hallway		Electrical
Campbell ES (2463) 1B	lights need replacement over 8ft	8/28/13	1st Floor	library		Electrical
Campbell ES (2463) 1B	Program clock and bells.	7/16/13				Electrical

Campbell ES (2463) 1B	clocks need setting or replacement	9/5/13	1st Floor	through-out the building	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixtures 3 sets	9/16/13	1st Floor	gym	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixture	9/16/13	Administration Area	main office	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixture	9/30/13	Cafeteria	serving area	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixture	10/1/13	Administration Area	guidance office	Electrical
Campbell ES (2463) 1B	ballast need replacement in the light fixtures 5 sets need a lift	1/13/14	Cafeteria	serving area	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixtures	1/13/14	1st Floor	hallway	Electrical
Campbell ES (2463) 1B	need lamp 28 in a cases for classroom 2 cases F32T8ADV841/XLL	1/15/14	1st Floor	by s.b.e. office	Electrical
Campbell ES (2463) 1B	Repair pole lights 6 or 8 do not work. very dark at night.	1/22/14	Grounds		Electrical

Campbell ES (2463) 1B	outlets not working in the classroom pre k office headquarter urgent	2/6/14	1st Floor	C104	Electrical
Campbell ES (2463) 1B	need master clock set for day light saving time	2/25/14	Administration Area	Main office	Electrical
Campbell ES (2463) 1B	light bulb broken off in the light fixture	3/6/14	1st Floor	across from the cafeteria	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixture by the principal office	3/21/14	Administration Area	main office	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixture	10/2/13	Restroom (Boys)	2nd floor	Electrical
Campbell ES (2463) 1B	outlet not working	10/16/13	Cafeteria	kitchen	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixture	11/13/13	1st Floor	E105 storage room	Electrical
Campbell ES (2463) 1B	need ballast replacement in the light fixtures	4/9/14	1st Floor	music room	Electrical
Campbell ES (2463) 1B	need ballast replacement	4/9/14	1st Floor	hallway by music room	Electrical

Campbell ES (2463) 1B	northend stairwell landing too dark ballast need replacement in the light 12ft ladder	4/14/14	2nd Floor	landing	Electrical
Campbell ES (2463) 1B	chiller down	6/23/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Check York chiler. Two circuits will not cool.	8/12/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Monthly - Filter-Lucie Campbell Elementary - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER NOT COMING ON PLANT MGR-DAWSON/416.3940	8/13/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	AIR COOLED CHILLER OUTSIDE NE OF BOILER RM- NOT COMING ON-SBE DAWSON 416-1001 KLR	8/15/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	chiller --- supply contractor 60 lbs of R-22	8/19/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER NOT COMING ON-SBE DAWSON 416-1001 KLR	8/20/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER NOT COOLING- AFFECTS ENTIRE BLDG-PLANT MGR DAWSON 416-3940 KLR	9/3/13			Heating/Ventilation /Air Conditioning

Campbell ES (2463) 1B	chiller down	7/9/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	chiller down	7/23/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	chiller down	7/31/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	check chiller temp	9/29/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Monthly - Oil Lube & Belt-Lucie Campbell Elem - Refer to PM schedule details.	10/1/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Monthly - Filter-Lucie Campbell Elementary - Refer to PM schedule details.	12/8/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	AHU#6 NOT HEATING IN RM-E100 PLANT MGR-DAWSON/416.1000	12/9/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Boiler is ON; however, it's NOT HEATING throughout the ENTIRE BUILDING per Ms. Dawson, Plant Mgr. 416.1000	1/8/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	RTU NOT HEATING THRU ENTIRE BLDG PLANT MGR-DAWSON/416.1000	1/24/14			Heating/Ventilation /Air Conditioning

Campbell ES (2463) 1B	check boiler	1/29/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	boiler down	2/10/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	check temps throughout building	2/12/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	BOILER MECH RM-NOT COMING ON-PLANT MGR DAWSON 416-3940 KLR	2/14/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	BOILER MECH RM-NOT HEATING-AFFECTS ENTIRE BLDG-PLANT MGR DAWSON 416-1000 KLR	2/24/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	boiler down	2/26/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	boiler down	3/5/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	boiler down	3/6/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning

Campbell ES (2463) 1B	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Yearly - Air Handler Cleanings- Campbell Elem - Refer to PM schedule details.	11/22/13			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	chiller down	5/29/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	chiller down	5/30/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	chiller down	6/12/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	UNIT NOT COOLING THRU ENTIRE BLDG PLANT MGR-DAWSON/416.3940	6/12/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER MECH RM-IN ALARM- PLANT MGR DAWSON 416-1000 KLR	6/19/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	check chiller	6/20/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Monthly - Filter-Lucie Campbell Elementary - Refer to PM schedule details.	4/6/14			Heating/Ventilation /Air Conditioning

Campbell ES (2463) 1B	chiller down	4/14/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER - NOT COMING ON - RMS ARE HOT - PM/DOLSON 416-1000	4/24/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Monthly - Oil Lube & Belt-Lucie Campbell Elem - Refer to PM schedule details.	4/29/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	A/C CONFERENCE RM-NOT COOLING-PLANT MGR DAWSON 416-1000 KLR	4/29/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	A/C CONFERENCE RM-NOT COOLING-PLANT MGR DAWSON 416-1000 KLR	5/5/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	Re Set Chiller.	5/19/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER is NOT COMING ON per Gale Dawson, Plant Mgr. 416.1000	6/23/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER - NOT COMING ON - PM/DAWSON 416-1000	6/30/14			Heating/Ventilation /Air Conditioning
Campbell ES (2463) 1B	CHILLER IS IN ALARM PLANT MGR/OTTO/416.1000	4/3/14			Heating/Ventilation /Air Conditioning

Campbell ES (2463) 1B	principal request exterior door need painting writing on the doors	5/20/14	Administration Area	front entrance	Painting
Campbell ES (2463) 1B	Sand and paint metal nosing 10 each for Jim Goudy.	9/4/13			Painting
Campbell ES (2463) 1B	DISHWASHER NOT GETTING HOT ENOUGH TO CLEAN DISHES-SBE DAWSON 416-1001 KLR	8/14/13			Plumbing
Campbell ES (2463) 1B	Water will not cut off on dock faucet.	8/15/13	Kitchen		Plumbing
Campbell ES (2463) 1B	toilet stop up it is only two toilet on the floor urgent	8/15/13	Restroom (Boys)	2nd floor	Plumbing
Campbell ES (2463) 1B	toilet stop uo	8/15/13	Restroom (Girls)	A-wing	Plumbing
Campbell ES (2463) 1B	toilet stop up	8/15/13	Restroom (Girls)	2nd floor	Plumbing
Campbell ES (2463) 1B	toilet stop up	8/15/13	Restroom (Girls)	D104	Plumbing
Campbell ES (2463) 1B	Cannot cut water off on kitchen dock.	8/19/13			Plumbing

Campbell ES (2463) 1B	handler need replacement on the sink also on the 2nd grade hallway	8/23/13	1st Floor	by plant manager office	Plumbing
Campbell ES (2463) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/31/13			Plumbing
Campbell ES (2463) 1B	hand sinks hanging from the wall	8/6/13	Restroom (Boys)	2nd floor	Plumbing
Campbell ES (2463) 1B	handsinks hanging from the wall	8/6/13	Restroom (Boys)	1st floor	Plumbing
Campbell ES (2463) 1B	hand sink hanging from the wall	8/6/13	Restroom (Boys)	Adults by s.b.e office	Plumbing
Campbell ES (2463) 1B	WATER FAUCET OUTSIDE REAR OF CAFE-IS STRIPPED AND WATER IS RUNNING A FULL FORCE, CAN'T CUT OFF PER SBE-SBE DAWSON 416-1001 KLR	8/7/13			Plumbing
Campbell ES (2463) 1B	need h/b replacement on the water faucet request for joe	8/7/13	Grounds	dock out back	Plumbing
Campbell ES (2463) 1B	handler need replacement on the hand sink	8/8/13	Restroom (Girls)	1st grade hallway	Plumbing
Campbell ES (2463) 1B	toilet stop up	8/8/13	1st Floor	D101	Plumbing

Campbell ES (2463) 1B	toilet stop up	8/9/13	Restroom (Boys)	2nd floor	Plumbing
Campbell ES (2463) 1B	(2) COMMODES IN B RR 2ND FLR STOPPED UP WITH FECES- ONLY TWO IN RR PER SBE-SBE DAWSON 416-1001 KLR	8/9/13			Plumbing
Campbell ES (2463) 1B	water fountain 048-070 does not work	9/11/13	1st Floor	D wing hallway	Plumbing
Campbell ES (2463) 1B	water fountain leaking 048-070	9/18/13	1st Floor	D wing hallway	Plumbing
Campbell ES (2463) 1B	toilet got water coming from the neck	12/5/13	1st Floor	D wing boys restroom	Plumbing
Campbell ES (2463) 1B	water coming from the elbow	12/5/13	2nd Floor	hand sink	Plumbing
Campbell ES (2463) 1B	Replace/Repair sink faucet near boys RR.	1/8/14	2nd Floor		Plumbing
Campbell ES (2463) 1B	flush vale need replacement	1/9/14	1st Floor	S100A Clinic	Plumbing
Campbell ES (2463) 1B	faucet need replacemnt on the hand sink	1/9/14	2nd Floor	A wing teacher restroom	Plumbing

Campbell ES (2463) 1B	three compartment sink leaking	1/9/14	Cafeteria	kitchen	Plumbing
Campbell ES (2463) 1B	flush vale leaking on the toilet last toilet to much water on the floor urgent	1/21/14	Restroom (Girls)	2nd floor	Plumbing
Campbell ES (2463) 1B	STOVE KITCHEN AREA-PILOT NEED TO BE LIT-PLANT MGR DAWSON 416-1000 KLR	1/31/14			Plumbing
Campbell ES (2463) 1B	PIPES HAVE BURST IN RMS D105 & D108 PER SUB-PRIN-CALLED IN BY SUB PRIN CURRIE 416-1000 KLR	2/6/14			Plumbing
Campbell ES (2463) 1B	per ms dawson 416-1000 there are 2 pre-k rooms that have restrooms in them and there is water coming out of the restrooms into the classrooms with an odor rooms 105 and 108	2/7/14			Plumbing
Campbell ES (2463) 1B	large hole in the toilet bowl need replacement	2/13/14	Restroom (Girls)	A wing	Plumbing
Campbell ES (2463) 1B	per dawson 416-1000 girls restroom A wing there is a toilet bowl that is broken (has hole in it)	2/19/14			Plumbing
Campbell ES (2463) 1B	By the plant manager office hand sink fallen off the wall leaking water	2/26/14	1st Floor	Adults restroom	Plumbing
Campbell ES (2463) 1B	toilet flush vale leaving	3/19/14	Restroom (Boys)	2nd floor	Plumbing

Campbell ES (2463) 1B	toilet will not stop flushing water coming from the flush vale	3/20/14	Restroom (Girls)	D wing	Plumbing
Campbell ES (2463) 1B	need flush vale replacement on the toilet	3/21/14	Restroom (Girls)	D wings	Plumbing
Campbell ES (2463) 1B	sink falling off the wall	10/23/13	1st Floor	by the plant manager office	Plumbing
Campbell ES (2463) 1B	toilet seat need relpcacement	10/24/13	1st Floor	teacher planning room A wing	Plumbing
Campbell ES (2463) 1B	need toilet seat replacement broken inside of the classroom	11/4/13	1st Floor	D108	Plumbing
Campbell ES (2463) 1B	SINK - CAFE DINING AREA - LEAKING BAD - CAN'T SHUT OFF & CAN'T CONTAIN IT - PM/DAWSON 416-1000	5/23/14			Plumbing
Campbell ES (2463) 1B	toilet willn't stop flushing	6/5/14	Administration Area	main office	Plumbing
Campbell ES (2463) 1B	toilet willn't stop flushing	6/6/14	Administration Area	main office	Plumbing
Campbell ES (2463) 1B	FOUNTAIN HALL CONTINUES TO RUN WATER, CAN'T CONTROL PLANT MGR-DAWSON/416.1000	6/13/14			Plumbing

Campbell ES (2463) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	4/8/14				Plumbing
Campbell ES (2463) 1B	toilet leaking from the neck...	4/9/14	Restroom (Girls)	2nd floor		Plumbing
Campbell ES (2463) 1B	sink leaking from the neck	4/29/14	Cafeteria	dinning		Plumbing
Campbell ES (2463) 1B	flush vale leaking on the toilet	4/29/14	Restroom (Girls)	A wings		Plumbing
Campbell ES (2463) 1B	faucet need replacement on the sink	5/1/14	Restroom (Boys)	2nd floor		Plumbing
Campbell ES (2463) 1B	hand sink hanging from the wall	5/2/14	Cafeteria	serving area		Plumbing
Campbell ES (2463) 1B	water handler key strip	5/7/14	1st Floor	on the dock		Plumbing
Campbell ES (2463) 1B	leaking from the ceiling also in the light fixture water falling	8/15/13	1st Floor	main lobby		Roof
Campbell ES (2463) 1B	ceiling leaking in the hallway	12/19/13	1st Floor	By Adults Restroom		Roof

Campbell ES (2463) 1B	ceiling leaking in the hallway and main entrance	3/6/14	Hallway/Corridor	across from the cafeteria	Roof
Campbell ES (2463) 1B	ceiling leaking	3/28/14	Administration Area	main office	Roof
Campbell ES (2463) 1B	ceiling leaving	6/6/14	Administration Area	principal office	Roof
Campbell ES (2463) 1B	ceiling leaking	6/9/14	1st Floor	across from cafeteria	Roof

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Carnes ES (2075) 1B		1	2	17	30	66	1	31	3	151
Grand Total		1	2	17	30	66	1	31	3	151

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
Carnes ES (2075) 1B	Install all new insulation in room 111. Pipes are sweating. To support, F. Owens.	10/30/13				Asbestos
Carnes ES (2075) 1B	I need a network drop for the copier in the school book room in the main office. thank you (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	11/26/13				Cabling
Carnes ES (2075) 1B	Provide project management to develop computer lab including contractor installing cabling and or electrical -- customer desires for this to be a title one project.	1/15/14				Cabling
Carnes ES (2075) 1B	FRONT ENTRY DOOR,CANT SECURE. PLANT MGR-STOUT/416.4400	9/27/13				Carpentry
Carnes ES (2075) 1B	On the 1st floor mainhall the front door the closer to the door is broken and need to be fixed. thank you	10/17/13				Carpentry
Carnes ES (2075) 1B	The hooks on the flag pole is broken and need to be replace, as soon as possible. thank you	10/25/13				Carpentry
Carnes ES (2075) 1B	In room 209 I need the door to be put in alignment because it will not close to security the room. thank you. In the AAP building 2nd floor, it is the storage room inside the room 209	9/16/13				Carpentry

Carnes ES (2075) 1B	FRONT ENTRY DOOR, PANIC BAR HAS CAME OFF. LEAD CUST-PARKER/949.4342	2/7/14			Carpentry
Carnes ES (2075) 1B	CLOSER BROKEN ON FRONT ENTRANCE DOOR-NOT CLOSING WHEN PEOPLE GO OUT OF IT-LEAD CUSTODIAL PARKER 416-3206 KLR	2/13/14			Carpentry
Carnes ES (2075) 1B	On the main floor 1st floor between the office area and the library area I have about fourteen tile on the need to be replace they are coming up off the floor.thank you	1/6/14			Carpentry
Carnes ES (2075) 1B	In room 201 I have floor tile that is coming up off the floor that need to be replace. On the eastwing of the building 2nd floor. thank you	1/6/14			Carpentry
Carnes ES (2075) 1B	In room 221 on the westwing 2nd floor I have two piece of tile that is coming up need to be replace. thank you	1/23/14			Carpentry
Carnes ES (2075) 1B	The tile on the 2nd floor main hallway I have four tile that need to be replace. thank you	3/17/14			Carpentry
Carnes ES (2075) 1B	The tile by the main office need to be replace three (p) of it. thank you	3/17/14			Carpentry
Carnes ES (2075) 1B	The front door to the annex building is not closeing like it should the hinge is lose. thank you	4/21/14			Carpentry

Carnes ES (2075) 1B	The cafeteria doors planic bars is lose and need to be fixed. thank you	4/21/14			Carpentry
Carnes ES (2075) 1B	The front door to the main building where you in the door closer on the buzz in side is broken. thank you	4/21/14			Carpentry
Carnes ES (2075) 1B	In room 201 on the eastwing 2nd floor I have floor tile that need to be replace. thank you	4/21/14			Carpentry
Carnes ES (2075) 1B	CAFE DOOR HINGES WONT ALLOW DOOR TO SHUT. PLANT MGR-STOUT/416.3206	4/29/14			Carpentry
Carnes ES (2075) 1B	ANNEX DOOR WON'T SHUT OR OPEN. PLANT MGR-STOUT/416.3206	5/8/14			Carpentry
Carnes ES (2075) 1B	I have a light out hallway by the main office 1st floor the ballast is bad, need to be fixed. thank you	9/26/13			Electrical
Carnes ES (2075) 1B	A/C MAIN OFC & LIBRARY-BOTH NOT COMING ON-PLANT MGR STOUT 416-3206 KLR	10/14/13			Electrical
Carnes ES (2075) 1B	2-PUMPS NOT COMING ON IN WEST BOILER RM. PLANT MGR-STOUT/416.3206	11/8/13			Electrical

Carnes ES (2075) 1B	I have a light out west end of the hallway 1st floor in room 110 the ballast is bad. thank you	11/11/13			Electrical
Carnes ES (2075) 1B	RTU-1 MAIN BLDG SOUTH-NOT COMING ON-SBE STOUT 416-3206 KLR	8/8/13			Electrical
Carnes ES (2075) 1B	RTU NOT COMING ON THRU ENTIRE 2ND FLR PLANT MGR-STOUT/416.3206	8/12/13			Electrical
Carnes ES (2075) 1B	2-UV NOT COMING ON ANNEX RM-118. SBE-STOUT/416-4400	7/24/13			Electrical
Carnes ES (2075) 1B	I need light bulbs number 46807, as soon possible at carnes,elm two box 36 in each box that what I need,thank you.	8/1/13			Electrical
Carnes ES (2075) 1B	The outlet in the serving area need to be repaired it do not work. thank you	8/1/13			Electrical
Carnes ES (2075) 1B	FCU NOT COMING ON IN RM-217 PLANT MGR-BELL/292.6530	9/10/13			Electrical
Carnes ES (2075) 1B	I have a light out in the main office the ballast is gone bad in it because I have change the bulb. thank you	9/13/13			Electrical

Carnes ES (2075) 1B	The clock need to be reset for day light saving time for march 9, 2014.thank you	3/6/14			Electrical
Carnes ES (2075) 1B	In room 212 the Art Room I have a light out the ballast has gone bad,need to be replace. thank you	11/22/13			Electrical
Carnes ES (2075) 1B	In the caf. where the children eat at I have a light out. The ballast need to be replace. thank you	11/22/13			Electrical
Carnes ES (2075) 1B	In Mrs. white room 217 I have a light out the ballast is bad. thank you On the west end of hallway 2nd floor	12/9/13			Electrical
Carnes ES (2075) 1B	In the cafeteria the stage light in front of the stage do not work need to fixed, thank you.	1/23/14			Electrical
Carnes ES (2075) 1B	In the office area I have a light out, the ballast is out In the office. thank you	2/7/14			Electrical
Carnes ES (2075) 1B	On the 2nd floor mainhall there is a light out in the foyre the ballast bad. thank you	3/20/14			Electrical
Carnes ES (2075) 1B	In the cafeteria I have some light in the eating area that need to be fixed. thank you	4/1/14			Electrical

Carnes ES (2075) 1B	In the stairwell on eastwing I have a light out that need to be fixed. thank you	4/1/14			Electrical
Carnes ES (2075) 1B	In the stairwell on westwing of the building I have a light out that need to be fixed. thank you	4/1/14			Electrical
Carnes ES (2075) 1B	In the Annex Building the light in the girl bathroom is not working. thank you	4/8/14			Electrical
Carnes ES (2075) 1B	In the Annex Building the boy bathroom the light is out, it is not working. thank you	4/8/14			Electrical
Carnes ES (2075) 1B	In the main office,there is the phone room the light is out the baslast is bad and it need fixed. thank you	4/24/14			Electrical
Carnes ES (2075) 1B	UNIT NOT COMING ON THRU ENTIRE MAIN HALL 1ST-2ND FLRS PLANT MGR-STOUT/416.3206	5/14/14			Electrical
Carnes ES (2075) 1B	A/C UNITS are NOT COMING ON THROUGHOUT BUILDING per Mr. Stout, Plant Mgr. 416.3206	5/27/14			Electrical
Carnes ES (2075) 1B	help HVAC with vav's	5/30/14			Electrical

Carnes ES (2075) 1B	RTU - 2ND FLR MAIN HALL - NOT COMING ON - PM/STOUT 416-3206	6/4/14			Electrical
Carnes ES (2075) 1B	Pull motor from cooling tower	6/24/14			Electrical
Carnes ES (2075) 1B	I need two box of light bulb 36 in each box the number to the bulb are 46807. thank you	11/20/13			Electrical
Carnes ES (2075) 1B	room 205 blowing cold on one side per ms parker (lead cust) 416-3206	2/7/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	CHECK OUT TWO RTU TRANE A/C. WILL NOT COOL	8/22/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Check chiller in basement. Trane unit will not start.	9/23/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU 1ST FLR HALL PER SBE- NOT COOLING-PLANT MGR STOUT 416-3206 KLR	10/3/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	asst. plumber in fixing leaking valve	10/31/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	boiler not working west end of hallway 1st and 2nd floors per Mr. Stout 416-3206	11/7/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	HEAT 1ST FLR & 2ND FLR WEST ENDS-BOTH AREAS NOT HEATING-PLANT MGR STOUT 416-3206 KLR	11/8/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU NOT HEATING IN MAIN OFFICE, LIBRARY 1ST FLR. PLANT MGR-STOUT/416.3206	11/13/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	BOILER NOT COMING ON WEST-END BLDG 1ST & 2ND FLRS. PLANT MGR-STOUT/416.3206	11/14/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	BOILER NOT COMING ON-PLANT MGR STOUT 416-3206 KLR	11/14/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU-1 MAIN BLDG SOUTH SERVES 2ND FLR ABOUT (10) RMS-NOT COOLING-SBE STOUT 416-3206 KLR	8/6/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU-1 MAIN BLDG SOUTH SERVES 2ND FLR-NOT COOLING-SBE STOUT 416-3206 KLR	8/13/13			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	chiller down	7/1/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	rtu's not cooling	7/9/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	chiller down	7/18/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	rtu #2 not cooling	7/19/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	chiller down	7/23/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	UV NOT COOLING ON ANNEX RM-118,3-UV IN RM-102 EAST WING, SBE-STOUT/416-4400	7/24/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Yearly - Oil Samples-Carnes Elem - Refer to PM schedule details.	9/3/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	purchase oil sample kit	9/16/13			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	Monthly - Filter-Carnes Elementary Refer to PM schedule details.	9/20/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	chiller down	9/23/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	HEAT LIBRARY & MAIN OFC- BOTH NOT HEATING-PLANT MGR STOUT 416-3206 KLR	2/10/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	BOILER NOT COMING ON FOR EAST-WING. PLANT MGR-STOUT/416.3206	2/11/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Yearly - Cooling Towers(STRAINERS)-Carnes Elem - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Yearly - Rod Chiller - Carnes Elementary - Refer to PM schedule details.	3/8/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Yearly - Air Handler Cleanings- Carnes Elementary - Refer to PM schedule details.	11/23/13			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	HEAT CAFE AREA & ANNEX BLDG 2ND GRADE-BOTH NOT COMING ON-PLANT MGR STOUT 416-3206 KLR	1/6/14			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	per mr stout 416-3206 there is no heat in cafeteria - says it is blowing cold air and also not coming on???	1/9/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	BOILER MECH RM SERVES ANNEX & CAFE-NOT HEATING-PLANT MGR STOUT 416-3206 KLR	1/16/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Monthly - Oil Lube & Belt-Carnes Elementary - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Monthly - Filter-Carnes Elementary Refer to PM schedule details.	1/24/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Yearly - Water-Cool Chiller Filter-Carnes Elem - Refer to PM schedule details.	1/24/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	per mr stout 416-3206 there is no heat in the library, main office or the annex building	1/28/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	rtu #1 not heating	1/28/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	rtu #2 not heating	1/28/14			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	UNIT NOT HEATING IN CAFE PLANT MGR-STOUT/416.3206	2/3/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	HEAT MAIN OFC AREA-NOT HEATING-PLANT MGR STOUT 416-3206 KLR	2/5/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	UNIT in the ANNEX BUILDING is NOT HEATING per Mr. Stout, Plant Mgr. 416.3206	3/26/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	clean cooling tower	3/28/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU-2 CTRLS 2ND FLR HALLWAYS, MUSIC RM, ART RM, GUID OFC, COMPUTER RM, AND OTHER RMS-NOT COOLING- PLANT MGR STOUT 416-3206 KLR	4/2/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	cooling tower overflowing	4/2/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU 2ND FLR-KEEPS SHUTTING DOWN-PLANT MGR STOUT 416- 3206 KLR	4/4/14			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	oil, lube and belts	4/14/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU 2ND FLR MIDDLE SECTION- NOT COOLING-PLANT MGR STOUT 416-3206 KLR	4/14/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	chiller #2	4/21/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	CHILLER is NOT COOLING throughout the ENTIRE BUILDING per Mr. Stout, Plant Mgr. 416.3206	4/25/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	A/C 2ND FLR HALL INCLUDING (10) RMS MIDDLE HALL-ALL NOT COOLING-PLANT MGR STOUT 416-3206 KLR	4/28/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	chiller down	4/30/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	UNIT NOT COOLING IN MAIN HALL PLANT MGR-STOUT/416.3206	5/5/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	per stout 416-3206 main office and library blowing hot	5/7/14			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	UNIT NOT COOLING ON 2ND FLR MAIN HALL PLANT MGR-STOUT/416.3206	5/8/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	A/C CAFE, 2ND FLR MAIN HALL ABOUT (12) RMS, 1ST FLR MAIN OFC AREA, & LIBRARY-ALL NOT COOLING-PLANT MGR STOUT 416-3206 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	clean rtu #1 and #2	5/14/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Re set Chiller.	5/19/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	UNIT NOT COOLING IN CAFE PLANT MGR-STOUT/416.3206	5/21/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	RTU #1 and #2 not cooling	5/22/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	A/C UNIT is NOT COOLING in MAIN OFFICE, LIBRARY, CAFETERIA, and SECOND FLOOR MAIN HALLWAY per Mr. Stout, Plant Mgr. 416.3206	5/22/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Monthly - Filter-Carnes Elementary Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning

Carnes ES (2075) 1B	A/C EAST WING RMS 201, 202, 203, 204, 205, 206, 107, 108, 109, 110, 111, 112, 113, & 114-ALL NOT COOLING-PLANT MGR STOUT 416-3206 KLR	6/18/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	chiller down	6/23/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	CHILLER - BLOWING NOT COOLING - PM/STOUT 416-3206	6/23/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Pull motor from cooling tower	6/24/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	Yearly - Boiler 012 - Carnes EI-Bldg 2 Blr Rm - Refer to PM schedule details.	3/9/14			Heating/Ventilation /Air Conditioning
Carnes ES (2075) 1B	The kitchen area need to be painted on the request of her supervisor of the cafeteria.thank you cafeteria manger	8/1/13			Painting
Carnes ES (2075) 1B	REPAIR CONDENSATE DRAIN ON ROOF TOP A/C UNIT. (SEE PHOTO)	10/15/13			Plumbing
Carnes ES (2075) 1B	WATER PIPE LEAKING 1ST FLR WEST END-PLANT MGR STOUT 416-3206 KLR	10/30/13			Plumbing

Carnes ES (2075) 1B	PUMP IS LEAKING WEST BOILER RM. PLANT MGR-STOUT/416.3206	11/8/13			Plumbing
Carnes ES (2075) 1B	leak in room 114 pipe in ceiling west end of building per Mr. Stout 416-3206	11/11/13			Plumbing
Carnes ES (2075) 1B	Bad smell in building	8/7/13			Plumbing
Carnes ES (2075) 1B	AHU IS FLOODING BEHIND CAFE'S STAGE (199) PLANT MGR-STOUT/416.3206	8/13/13			Plumbing
Carnes ES (2075) 1B	I have a uninal in the boy bathroom 1st floor mainhall that is not working it is right by the library. thank you	8/14/13			Plumbing
Carnes ES (2075) 1B	Test and report on backflow prevention devices.	7/2/13			Plumbing
Carnes ES (2075) 1B	TOILET IN KITCHEN/RR IS OVERFLOWING PLANT MGR-BELLS/292.6530	9/9/13			Plumbing
Carnes ES (2075) 1B	On the westwing 1st floor the boy bathroom the toilet is stop up. thank you	2/14/14			Plumbing

Carnes ES (2075) 1B	2-COMPARTMENT SINK KITCHEN LEAKING FROM BOTTOM-PLANT MGR STOUT 416-3206 KLR	2/27/14			Plumbing
Carnes ES (2075) 1B	On the 1st grade hall on the eastwing the boy bathroom the unrail is broken it leaking out. thank you	11/20/13			Plumbing
Carnes ES (2075) 1B	I have a faust handle that is broken on the westwing girl bathroom 1st floor. thank you	11/21/13			Plumbing
Carnes ES (2075) 1B	Gas smell in kitchen per cafe manager.	12/17/13	Kitchen		Plumbing
Carnes ES (2075) 1B	On the main hallway by the library the girl bathroom toilet is stop up. thank you	2/4/14			Plumbing
Carnes ES (2075) 1B	On the 2nd floor eastwing the boy bathroom the uniral have water running from it. thank you	2/4/14			Plumbing
Carnes ES (2075) 1B	In the J-closet the sink is leaking. thank you	2/7/14			Plumbing
Carnes ES (2075) 1B	per mr parker (lead cust) 416-3206 boys restroom 2nd floor the commode next to wall water is gushing out	2/7/14			Plumbing

Carnes ES (2075) 1B	On the 3rd grade hallway the boy bathroom toilet is leaking around the flusher. thank you	3/19/14			Plumbing
Carnes ES (2075) 1B	Leak in girl bathroom toilet on the westwing 2nd floor. thank you	3/19/14			Plumbing
Carnes ES (2075) 1B	2nd floor boy bathroom handcape stall and the second stall leaking as well. thank you	3/21/14			Plumbing
Carnes ES (2075) 1B	GAS SMELL IN BACK BLDG BY CAFE PLANT MGR-STOUT/416.3206	3/24/14			Plumbing
Carnes ES (2075) 1B	The toilet in girl bathroom will not flush need to be fixed. thank you on the 2nd floor westwing	3/24/14			Plumbing
Carnes ES (2075) 1B	Gas on oven not working.	3/26/14	Kitchen		Plumbing
Carnes ES (2075) 1B	Repair make-up water line to cooling tower.	3/31/14			Plumbing
Carnes ES (2075) 1B	On the westwing 1st floor I have a toilet that will not stop runing in the boy bathroom. thank you	4/7/14			Plumbing

Carnes ES (2075) 1B	On the westwing 1st floor boy bathroom the toliet will not flush. thank you	4/28/14			Plumbing
Carnes ES (2075) 1B	SINK ANNEX BLDG-LEAKINIG FROM BOTTOM, CAN'T CUT OFF OR CONTAIN-WATER RUNNING EVERYWHERE PER SBE-PLANT MGR STOUT 416-3206 KLR	5/13/14			Plumbing
Carnes ES (2075) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	5/19/14			Plumbing
Carnes ES (2075) 1B	The slump pump in the boiler room on the westend of building is not working. thank you	5/20/14			Plumbing
Carnes ES (2075) 1B	Repair water cut off center of building.	5/20/14			Plumbing
Carnes ES (2075) 1B	I have a leak coming from the roof into room 201 on the 2nd floor on eastwing of the building. thank you	1/6/14			Roof
Carnes ES (2075) 1B	I have a roof leak in room 201 on the 2nd floor eastwing.thankyou	2/3/14			Roof
Carnes ES (2075) 1B	On the eastwing 2nd floor room 203 I have a leak coming from the roof. thank you	4/7/14			Roof

Count of Craft	Craft										
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Carver Sr (2085) 1A		2	1	84	128	42	9	38	9	5	318
Grand Total		2	1	84	128	42	9	38	9	5	318

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Carver Sr (2085) 1A	Need These two rooms to be checked for mold on the walls.	7/31/13	1st Floor	103, 203	Asbestos
Carver Sr (2085) 1A	Gym floor need Refinishing.	10/2/13	Gym	1st. Floor	Asbestos
Carver Sr (2085) 1A	Carver Sr 2085-1B-- WO# 369300- The first Internet drop to left In this room Is not working.(Request Network Cabling Maintenance Repair).	7/31/13	2nd Floor	236	Cabling
Carver Sr (2085) 1A	Need pick plate seals installed on rm.105 classroom door, ROTC room door & library storage rm. doors	1/28/14	Hallway/Corridor		Carpentry
Carver Sr (2085) 1A	Cage around gas main in the back of the school is falling down, needs to be secured.	1/30/14		behind the school	Carpentry
Carver Sr (2085) 1A	All auditorium exit doors not closing & locking properly.	2/6/14	Auditorium		Carpentry
Carver Sr (2085) 1A	Northside exit door panic bar lock broke, will not lock.	2/25/14	Auditorium	lobby	Carpentry

Carver Sr (2085) 1A	south side exit door not locking properly,panic bar falling off	3/6/14	Cafeteria	cafeteria	Carpentry
Carver Sr (2085) 1A	REPAIR FENCE AROUND A/C UNIT FOR AUDITORIUM. CUT BY VANDALS.	12/2/13			Carpentry
Carver Sr (2085) 1A	Repair outer perimeter fence behind Auditorium. REF. wo, 400457.	12/2/13	Grounds		Carpentry
Carver Sr (2085) 1A	Install expand metal at Auditorium HVAC gage. Repair hole in back fence.	12/10/13	Grounds		Carpentry
Carver Sr (2085) 1A	Repair #2 HVAC cage fence behind Auditorium.	12/12/13	Grounds		Carpentry
Carver Sr (2085) 1A	Iron handrail falling off wall in 1st flr. stairwell down by cafeteria,safety hazzard it's heavy.	1/8/14	1st Floor		Carpentry
Carver Sr (2085) 1A	Windows pushed out on southside of main gym.	1/8/14	Gym		Carpentry
Carver Sr (2085) 1A	Remove ceiling and grid so plumber can fix leak. @nd floor boys. Support Frank	6/13/14	2nd Floor		Carpentry

Carver Sr (2085) 1A	ceiling tiles need to be replaced in the north stairwell leading to the auditorium.	4/19/14	1st Floor		Carpentry
Carver Sr (2085) 1A	Attn. Barry Frost Storm drain on south parking lot near cafeteria has fallen in, need a safety barrier around it until it can be fixed.	4/17/14	Parking Lot	south parking lot	Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in rm. 158 ,main hall lobby & principals ofc.	4/19/14	1st Floor	rm.158	Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in the conference rm. ,main ofc. & assistant principals ofc.	4/19/14	Administration Area		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in rm. 104, 106, 107	4/19/14	1st Floor		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in rm. 108, 108b & ROTC rm.	4/19/14	1st Floor		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in the cafeteria lobby & cafeteria.	4/19/14	Cafeteria		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in 2nd flr. hall near rm. 203	4/19/14	2nd Floor		Carpentry

Carver Sr (2085) 1A	Repair door lock room 106, Home Ec.	4/22/14	1st Floor		Carpentry
Carver Sr (2085) 1A	Need door lock repaired on classroom door.	4/24/14	1st Floor	rm.158	Carpentry
Carver Sr (2085) 1A	In the outside gym, back exit door in the dance rm. won't close & lock properly if opened.	4/29/14	Auxiliary Gym		Carpentry
Carver Sr (2085) 1A	Repair window .Broken due to a break-in this weekend.	5/5/14			Carpentry
Carver Sr (2085) 1A	replace glass in room doors due to break in	5/6/14	1st Floor	rm. 154	Carpentry
Carver Sr (2085) 1A	replace glass in door due to break in	5/6/14	1st Floor	rm. 164	Carpentry
Carver Sr (2085) 1A	replace glass in door due to break in	5/6/14	2nd Floor	rm. 216	Carpentry
Carver Sr (2085) 1A	replace glass in 2nd flr. southend stairwell door due to break in	5/6/14	2nd Floor		Carpentry

Carver Sr (2085) 1A	replace glass in downstairs access door across from elevator	5/6/14			Carpentry
Carver Sr (2085) 1A	main entry doors to outside gym not closing properly	5/27/14	Auxiliary Gym		Carpentry
Carver Sr (2085) 1A	Door not closing properly need door lock faceplate	5/28/14	1st Floor	rm. 108	Carpentry
Carver Sr (2085) 1A	need pick plates for doors on rms.155,110,106,107,108B	3/18/14	Classroom		Carpentry
Carver Sr (2085) 1A	need pick plates for doors on rms. 233,224,229,216	3/18/14	Classroom		Carpentry
Carver Sr (2085) 1A	need pick plates for doors in library rms.306,307,308,computer lab,right&left doors beside computer lab	3/18/14	Library		Carpentry
Carver Sr (2085) 1A	cover access hole in sheetrock with metal panel, to support HVAC.	3/24/14	Administration Area		Carpentry
Carver Sr (2085) 1A	door handle fell off door to the main office	4/2/14	Administration Area		Carpentry

Carver Sr (2085) 1A	upper southeast exit door not closing & locking properly	4/2/14	Auditorium		Carpentry
Carver Sr (2085) 1A	lower southwest exit door not closing & locking properly	4/2/14	Auditorium		Carpentry
Carver Sr (2085) 1A	window fell out and broke	4/2/14	Classroom	1st. flr. rm. 104	Carpentry
Carver Sr (2085) 1A	window in classroom door broke out do to break in	4/7/14	1st Floor	rm 109	Carpentry
Carver Sr (2085) 1A	window in classroom door broke out do to break in	4/7/14	2nd Floor	rm. 207	Carpentry
Carver Sr (2085) 1A	window in classroom door broke out do to break in	4/7/14	2nd Floor	rm. 211	Carpentry
Carver Sr (2085) 1A	Need door lock repaired on hall doors near elevator.	4/7/14	Hallway/Corridor	1st. flr.	Carpentry
Carver Sr (2085) 1A	Classroom door lock broke due to recent break in.	4/9/14	1st Floor	rm. 106	Carpentry

Carver Sr (2085) 1A	Attn: Tom Palmertree need 3 bundles of ceiling tiles	4/15/14	Custodial		Carpentry
Carver Sr (2085) 1A	Repair door handle room 123.	7/11/13	1st Floor		Carpentry
Carver Sr (2085) 1A	Repair door closer room 105.	7/11/13	1st Floor		Carpentry
Carver Sr (2085) 1A	Install missing covebase in computer room.	7/11/13	1st Floor		Carpentry
Carver Sr (2085) 1A	Repair door handle room 206.	7/11/13	2nd Floor		Carpentry
Carver Sr (2085) 1A	Repair hardware on Gym double doors.	7/11/13	Gym		Carpentry
Carver Sr (2085) 1A	Repair metal expansion joint in Gym.	7/11/13	Gym		Carpentry
Carver Sr (2085) 1A	Repair door handle room 265.	7/11/13	2nd Floor		Carpentry

Carver Sr (2085) 1A	Repair electronic strike on hall door near Teachers lounge.	7/11/13	Hallway/Corridor		Carpentry
Carver Sr (2085) 1A	Repair door handle room 247.	7/11/13	2nd Floor		Carpentry
Carver Sr (2085) 1A	Repair hardware on double doors in main hall.	7/11/13	Hallway/Corridor		Carpentry
Carver Sr (2085) 1A	In Football Locker room where equipments are stored, 2 door knob need repair.	7/19/13	Annex	Football locker room	Carpentry
Carver Sr (2085) 1A	OUTSIDE BACK DOOR, CANT SECURE. SBE-MCFARLAND/650-0389	7/19/13			Carpentry
Carver Sr (2085) 1A	Back door Football Locker room the bar will not lock.	7/22/13	Annex	Football Locker room	Carpentry
Carver Sr (2085) 1A	Request for the fence the be repaired In this area. There Is a hole on the west side of the field In the fence.	7/29/13	Athletic Field	fOOTBALL FIELD	Carpentry
Carver Sr (2085) 1A	Repair HVAC fence area near main office (6 units were stolen).	7/31/13			Carpentry

Carver Sr (2085) 1A	security cages	8/2/13				Carpentry
Carver Sr (2085) 1A	Door knob is broken on the outside of the Asst. Principal door	8/2/13	Administration Area	1st. Floor 150		Carpentry
Carver Sr (2085) 1A	Repair chainlink area near main office, 6 hvac units inside , broke in again.	8/19/13	Grounds			Carpentry
Carver Sr (2085) 1A	Repair chainlink fence at the back of property.	8/19/13	Grounds			Carpentry
Carver Sr (2085) 1A	Install heavy guage expand metal to inside of fence (including gate)area to protect 6 hvac units. Weld to posts and use wire ties.	8/19/13	Grounds			Carpentry
Carver Sr (2085) 1A	Corner of window is being pried open, side of the driveway by the stairs.	8/23/13	Kitchen	Outside Window		Carpentry
Carver Sr (2085) 1A	Install razor wire around top of cage for A/C.	8/27/13				Carpentry
Carver Sr (2085) 1A	Install expand metal on inside of HVAC fence.From the existing 4' high to 10' high.	8/28/13	Grounds			Carpentry

Carver Sr (2085) 1A	Down stairs leftside last rail hanging off wall need repair.	9/18/13	Stairway	1st. floor	Carpentry
Carver Sr (2085) 1A	The back of the Cafeteria hole in wall.	9/19/13	Cafeteria	Wall	Carpentry
Carver Sr (2085) 1A	Hinge on the exit door need repair.	9/19/13	Gym	1st.flr. boys gym	Carpentry
Carver Sr (2085) 1A	Need door lock repaired on women toilet in teachers lounge on 2nd flr.	9/25/13	2nd Floor	219	Carpentry
Carver Sr (2085) 1A	Pipes are visible where the hole is in the wall need repair.	9/30/13	Kitchen	Basement	Carpentry
Carver Sr (2085) 1A	The girl's visitor's restroom the cylinda on the door is going round and round, can't lock the door.	9/12/13	Gym	Girl's Restroom	Carpentry
Carver Sr (2085) 1A	Bleachers need repair at the bottom, and in the same row at the very top on the right side.	10/2/13	Gym	1st. Floor	Carpentry
Carver Sr (2085) 1A	Cut access door in science lab table to operate gas vavle. Per Frank Owens.	10/4/13			Carpentry

Carver Sr (2085) 1A	ceiling tiles need to be replaced in rm.204,205,210.	4/19/14	2nd Floor		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in rm.219,224,225	4/19/14	2nd Floor		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in rm.231,232,233	4/19/14	2nd Floor		Carpentry
Carver Sr (2085) 1A	ceiling tiles need to be replaced in the library & rm.305	4/19/14	3rd Floor		Carpentry
Carver Sr (2085) 1A	Cover hole in wall.	6/16/14			Carpentry
Carver Sr (2085) 1A	Need pick plate seals installed on all classroom doors through out the school.	3/7/14	Classroom		Carpentry
Carver Sr (2085) 1A	Need door installed on boys restroom in outside girls gym.	9/4/13	Auxiliary Gym		Carpentry
Carver Sr (2085) 1A	In the Dance Studio which is by the Gym, need to replace a mirror.	8/9/13	Annex	Dance Studio	Carpentry

Carver Sr (2085) 1A	lights out in library girl restroom	1/17/14	Library		Electrical
Carver Sr (2085) 1A	UNIT NOT COMING THRU ENTIRE FRONT BLDG @ RIVERVIEW KANSAS DAYCARE PLANT MGR- TOWNSEND/946.0855	1/27/14			Electrical
Carver Sr (2085) 1A	Need light bulbs replaced on the stage & dressing rm. in auditorium	1/28/14	Auditorium		Electrical
Carver Sr (2085) 1A	Lights out in financial secretary office on 1st flr.	2/6/14	1st Floor		Electrical
Carver Sr (2085) 1A	Lights out in hallway near gym & rotc rm.	2/13/14	1st Floor		Electrical
Carver Sr (2085) 1A	Pole light is out behind the cafeteria.	10/25/13	Parking Lot	Cafeteria	Electrical
Carver Sr (2085) 1A	In Boiler Room light out at back door entrance.	10/25/13	Mechanical Room	003	Electrical
Carver Sr (2085) 1A	SCHOOL BELLS NOT RINGING AT THE PROPER TIME	10/28/13	Administration Area		Electrical

Carver Sr (2085) 1A	UNIT NOT COMING ON IN RM-236,232 PLANT MGR-BROWN/416.7844	2/21/14			Electrical
Carver Sr (2085) 1A	Emergency lights not working through out the school, per the fire marshalls inspection.	2/25/14	Custodial		Electrical
Carver Sr (2085) 1A	PUMP-1 MECH RM-NOT WORKING-PLANT MGR BROWN 416-7594 KLR	3/5/14			Electrical
Carver Sr (2085) 1A	RIVERVIEW-KANSAS DAYCARE-HEAT 2ND FLR AFTERCARE AREA-NOT COMING ON-PLANT MGR TOWNES 946-0855 KLR	3/5/14			Electrical
Carver Sr (2085) 1A	PUMP#2A NOT COMING ON IN BOILER PLANT MGR-BROWN/416.7594	3/5/14			Electrical
Carver Sr (2085) 1A	Power Outage.	3/6/14			Electrical
Carver Sr (2085) 1A	lights out in classroom	3/7/14	1st Floor	rm. 106	Electrical
Carver Sr (2085) 1A	Lights out behind and side of building.	10/30/13	Annex	Foot ball	Electrical

Carver Sr (2085) 1A	Requesting Philips Frost Incandescent Lamps, Ordering Code 300 M/IF 120-130 V, Quantity 7.	10/30/13	Mechanical Room	Basement	Electrical
Carver Sr (2085) 1A	Disregard this request that was just sent thanks.	10/30/13	Mechanical Room	Basement	Electrical
Carver Sr (2085) 1A	The housing unit burn out need replacing.	10/30/13	Mechanical Room	Basement	Electrical
Carver Sr (2085) 1A	In Closets lights with bad ballast.	10/30/13	Mechanical Room	Basement	Electrical
Carver Sr (2085) 1A	School bells off time, need to be reset.	11/4/13	Administration Area		Electrical
Carver Sr (2085) 1A	THERMOSTAT NO POWER FOR AHU IN GYM. PLANT MGR- BROWN/246.4141	11/14/13			Electrical
Carver Sr (2085) 1A	6-RTU NOT HEATING IN GYM. PLANT MGR- MCFARLAND/650.0389	11/25/13			Electrical
Carver Sr (2085) 1A	Units are NOT COMING ON in the (RIVERVIEW KANSAS DAY CARE CENTER) per Michael Townes, Plant Mgr. 416.0855	11/26/13			Electrical

Carver Sr (2085) 1A	lights out in library	12/17/13	Library		Electrical
Carver Sr (2085) 1A	4-UNITS NOT HEATING IN GYM PLANT MGR-BROWN/416.7894	1/8/14			Electrical
Carver Sr (2085) 1A	Light out in stairwell next too ROTC rm.	1/10/14	1st Floor		Electrical
Carver Sr (2085) 1A	Lights out in classroom 225.	4/16/14	2nd Floor		Electrical
Carver Sr (2085) 1A	lights out in girls restroom.	5/1/14	Gym		Electrical
Carver Sr (2085) 1A	a/c fan not blowing at all.	5/2/14	2nd Floor	rm. 236	Electrical
Carver Sr (2085) 1A	lights out in ROTC supply room.	5/2/14	1st Floor		Electrical
Carver Sr (2085) 1A	A/C MAIN OFC-HAS A STRONG BURNING SMELL-PLANT MGR BROWN KLR	6/10/14			Electrical

Carver Sr (2085) 1A	Time will not set for bells to pass classes.	3/12/14	1st Floor		Electrical
Carver Sr (2085) 1A	lights out in stairwell near the auditorium	3/18/14	1st Floor		Electrical
Carver Sr (2085) 1A	lights out in high ceiling area of the library	3/18/14	Library		Electrical
Carver Sr (2085) 1A	light out over outside exit door between main building & auditorium	3/18/14	1st Floor		Electrical
Carver Sr (2085) 1A	exit lights out on 1st flr. hallway	3/18/14	1st Floor		Electrical
Carver Sr (2085) 1A	lights out ,bad ballast	3/25/14	Classroom	rm. 107	Electrical
Carver Sr (2085) 1A	lights out in classrooms #106,107,108	4/15/14	1st Floor	rm. 106	Electrical
Carver Sr (2085) 1A	lights out in rm.108B, cafeteria,cafeteria serving area	4/15/14	1st Floor		Electrical

Carver Sr (2085) 1A	Lights out in boys gym entrance area.	4/15/14	Gym		Electrical
Carver Sr (2085) 1A	lights out in classrooms #203,208,225	4/16/14	2nd Floor	rm.203,208,225	Electrical
Carver Sr (2085) 1A	lights out in auditorium lobby	4/16/14	Auditorium	lobby	Electrical
Carver Sr (2085) 1A	lights out in classroom #151	4/16/14	1st Floor	rm.151	Electrical
Carver Sr (2085) 1A	The light switch will not work on this hall.	7/3/13	1st Floor	West/Hall	Electrical
Carver Sr (2085) 1A	Request for ceiling bulbs to be changed in this area.	7/3/13	1st Floor	Main Lobby area	Electrical
Carver Sr (2085) 1A	Bell not working in Front of office.	7/9/13	Administration Area	Main Hallway	Electrical
Carver Sr (2085) 1A	Large amount of Lights with Bad Ballast.	7/9/13	1st Floor	Guidance Office	Electrical

Carver Sr (2085) 1A	Lights Bad Ballast in center of Hallway.	7/9/13	Hallway/Corridor	2nd Floor	Electrical
Carver Sr (2085) 1A	Lights need repair.	7/18/13	Administration Area	1st.Floor 111	Electrical
Carver Sr (2085) 1A	CEILING UNIT NOT COMING ON IN RM-216 PLANT MGR- HARDMAN/412.7594	7/31/13			Electrical
Carver Sr (2085) 1A	The outlets to the left of the room Is not working.	7/31/13	Administration Area	224	Electrical
Carver Sr (2085) 1A	RECEPTACLE HAS NO POWER IN MAIN OFFICE @ RIVERVIEW DAYCARE. PLANT MGR- TOWNS/946.0855	8/1/13			Electrical
Carver Sr (2085) 1A	The outlets on the south wall Is not working In this room.	8/1/13	Library	Computer lab	Electrical
Carver Sr (2085) 1A	UNIT IN THE AUDIT. NOT COMING ON. SBE BROWN 416-7594	8/6/13			Electrical
Carver Sr (2085) 1A	wall sockets kicked ,out won't reset	8/8/13	1st Floor	rm.106	Electrical

Carver Sr (2085) 1A	In Main Office wall socket need a cover.	8/8/13	Administration Area	1st. Flf.	Electrical
Carver Sr (2085) 1A	Lights need repair in Assistance Principal Office.	8/8/13	Administration Area	1st. Flr. 116	Electrical
Carver Sr (2085) 1A	In Administrator Office lights need repair.	8/8/13	Administration Area	1st. flr. 141	Electrical
Carver Sr (2085) 1A	Water leaking from the pipes in the ceiling.	8/8/13	Classroom	1st. flr. 108 B	Electrical
Carver Sr (2085) 1A	One light need repair in Auditorium hallway.	8/8/13	Auditorium	1st. flr.	Electrical
Carver Sr (2085) 1A	Auditorium 4 security lights inside.	8/8/13	Auditorium	1st. Flr.	Electrical
Carver Sr (2085) 1A	Need lights repair in classroom.	8/9/13	Classroom	1st. Flr. 107	Electrical
Carver Sr (2085) 1A	5 lights out need repair.	8/9/13	Classroom	1st. flr. 109	Electrical

Carver Sr (2085) 1A	12 lights out need repair.	8/9/13	Classroom	1st. flr. 112	Electrical
Carver Sr (2085) 1A	8 lights out need repair.	8/9/13	Classroom	2nd flr. 232	Electrical
Carver Sr (2085) 1A	6 lights out need repair.	8/9/13	Classroom	2nd flr. 231	Electrical
Carver Sr (2085) 1A	9 lights out need repair.	8/9/13	Classroom	2nd flr. 209	Electrical
Carver Sr (2085) 1A	Dance Studio is by the Gym 6 lights out need repair.	8/9/13	Annex	Dance Studio	Electrical
Carver Sr (2085) 1A	4 lights out need repair.	8/9/13	Classroom	1st. Flr. 100	Electrical
Carver Sr (2085) 1A	Lights need repair 5 are out.	8/14/13	Classroom	1st. Flr. 107	Electrical
Carver Sr (2085) 1A	Install motion light and add siren/bell for audio alarm.	8/19/13	Grounds		Electrical

Carver Sr (2085) 1A	Out side Lights are needed, on the Northside end and Southside end of the building.	8/19/13	Auditorium	Outside Area	Electrical
Carver Sr (2085) 1A	Light need repair outside of building.	8/23/13	Annex	Rifle Bldg.	Electrical
Carver Sr (2085) 1A	Light need repair outside of building.	8/23/13	Annex	Girls Basketball	Electrical
Carver Sr (2085) 1A	Flood lights and regular lights need repair.	8/23/13	Cafetorium	Behind Building	Electrical
Carver Sr (2085) 1A	Poll Lights in parking lot need repair.	8/23/13	Parking Lot	Behind Gym	Electrical
Carver Sr (2085) 1A	Install two LED outside lights and motion sensor to protect HVAC area.	8/23/13	Grounds		Electrical
Carver Sr (2085) 1A	Light with bad ballast at the top of stairwell on the landing.	9/19/13	Stairway	Library	Electrical
Carver Sr (2085) 1A	Girls gym 2 outlet sockets need covers and.	9/19/13	Gym	Annex	Electrical

Carver Sr (2085) 1A	Bad Ballast need repair.	9/26/13	Gym	Coach Office	Electrical
Carver Sr (2085) 1A	3 Lights out need repair.	9/26/13	Gym	Court	Electrical
Carver Sr (2085) 1A	Light out leading toward the third floor.	9/26/13	Stairway	1st. Flr.by Rm. 106	Electrical
Carver Sr (2085) 1A	12 lights out need repair.	9/26/13	Classroom	First Flr. 103	Electrical
Carver Sr (2085) 1A	1 light out need repair.	9/26/13	Classroom	First Flr. 104	Electrical
Carver Sr (2085) 1A	5 lights out need repair.	9/26/13	Classroom	First Flr. 105	Electrical
Carver Sr (2085) 1A	11 lights out need repair.	9/26/13	Classroom	First Flr. 106	Electrical
Carver Sr (2085) 1A	4 lights out.	9/26/13	Classroom	First Flr. Hallway	Electrical

Carver Sr (2085) 1A	11 lights out need repair.	9/26/13	Classroom	First Flr. 153	Electrical
Carver Sr (2085) 1A	12 lights out need repair.	9/26/13	Classroom	First Flr. 152	Electrical
Carver Sr (2085) 1A	12 lights out need repair.	9/26/13	Classroom	First Flr. 155	Electrical
Carver Sr (2085) 1A	4 lights out need service.	9/26/13	Classroom	First Flr. 157	Electrical
Carver Sr (2085) 1A	8 lights out need service.	9/26/13	Classroom	First Flr. 159	Electrical
Carver Sr (2085) 1A	10 lights out need of service.	9/26/13	Classroom	First Flr. 158	Electrical
Carver Sr (2085) 1A	8 lights out.	9/30/13	Classroom	2nd.flr.hallway	Electrical
Carver Sr (2085) 1A	4 lights out need repair.	9/30/13	Classroom	2nd.flr. 204	Electrical

Carver Sr (2085) 1A	12 lights out need repair.	9/30/13	Classroom	2nd.flr. 205	Electrical
Carver Sr (2085) 1A	1 light out need repair.	9/30/13	Classroom	2nd.flr. 207	Electrical
Carver Sr (2085) 1A	11 lights out need repair.	9/30/13	Classroom	2nd.flr. 208	Electrical
Carver Sr (2085) 1A	10 lights out need repair.	9/30/13	Classroom	2nd.flr. 210	Electrical
Carver Sr (2085) 1A	8 lights out need repair.	9/30/13	Classroom	2nd.flr. 211	Electrical
Carver Sr (2085) 1A	4 lights out need repair.	9/30/13	Classroom	2nd.flr. 225	Electrical
Carver Sr (2085) 1A	6 lights out need repair.	9/30/13	Classroom	2nd.flr. 233	Electrical
Carver Sr (2085) 1A	7 lights out need service.	9/30/13	Classroom	2nd.flr. 234	Electrical

Carver Sr (2085) 1A	8 lights out need service.	9/30/13	Classroom	2nd.flr. 236	Electrical
Carver Sr (2085) 1A	7 lights out need of service.	9/30/13	Classroom	2nd.flr. 237	Electrical
Carver Sr (2085) 1A	7 lights out need of service.	9/30/13	Classroom	2nd.flr. 238	Electrical
Carver Sr (2085) 1A	8 lights out need of service.	9/30/13	Classroom	2nd.flr. 242	Electrical
Carver Sr (2085) 1A	6 lights out need of service.	9/30/13	Hallway/Corridor	2nd.flr.	Electrical
Carver Sr (2085) 1A	i need 3 boxes of t8 lamps.	10/1/13			Electrical
Carver Sr (2085) 1A	5 lights out.	10/2/13	Custodial Closet	Basement	Electrical
Carver Sr (2085) 1A	U Vent in rm 108b not coming on.	8/13/13	1st Floor		Electrical

Carver Sr (2085) 1A	FCU RM 233- SMOKING PER SBE- SBE BROWN 416- 7394 KLR	8/13/13				Electrical
Carver Sr (2085) 1A	A/C RM 242 & 236- BOTH DIDN'T COME BACK ON AFTER POWER OUTAGE OTHER DAY PER SBE- PLANT MGR BROWN 416-7594 KLR	9/13/13				Electrical
Carver Sr (2085) 1A	2 sets of lights with bad ballast.	10/2/13	Restroom (Girls)	2nd. Floor		Electrical
Carver Sr (2085) 1A	Light is out need repair.	10/3/13	Stairway	2nd. Floor		Electrical
Carver Sr (2085) 1A	lights out on gym score board	10/9/13	Gym			Electrical
Carver Sr (2085) 1A	lights out in the ceiling in the gym	10/9/13	Gym			Electrical
Carver Sr (2085) 1A	Lights out in girls toilet, bad wall switch.	10/14/13	Restroom (Girls)	2nd. Floor		Electrical
Carver Sr (2085) 1A	AHU-1 & AHU-2 AUDITORIUM AREA- BOTH NOT COMING ON-PLANT MGR BROWN KLR	9/16/13				Electrical

Carver Sr (2085) 1A	PARTIAL POWER OUTAGE IN KITCHEN, 2ND FLR @ RIVERVIEW KANSAS DAYCARE PLANT MGR- MELVIN/942.2659	6/13/14			Electrical
Carver Sr (2085) 1A	Mr.White, I'm requesting Philips Frost Incandescent Lamps, Ordering code 300 M/IF 120-130 V.	10/29/13	Mechanical Room	Basement	Electrical
Carver Sr (2085) 1A	Need 3 boxes of 48" tube light bulbs #46807	2/19/14	Custodial	main ofc.	Electrical
Carver Sr (2085) 1A	Lights need repair Types of Bulbs that are needed, (Fluorescent Bulbs 46823 - 25 watts/ 10 cases.	8/14/13	Mechanical Room	Basement	Electrical
Carver Sr (2085) 1A	Mr. White 4 boxes Fluorescent Bulbs are needed at Carver High School.	10/18/13			Electrical
Carver Sr (2085) 1A	Requesting at Carver High School Fluorescent Bulb#46823 -25 watt quantity 10 boxes. TRAFFIC SIGNAL 1950L Philips-PLG-160 watt 125 watt 8 boxes	10/2/13	Custodial Closet	Basement	Electrical
Carver Sr (2085) 1A	Need Fluorescent Bulbs #46823- 25 watt-quantitys 10, for 2nd flr. and hallways.	9/26/13	Classroom	1st. flr.	Electrical
Carver Sr (2085) 1A	Request for bulbs for the classrooms. See Sbe for locations	7/31/13	Classroom	throughout building	Electrical

Carver Sr (2085) 1A	HEAT RM 204-NOT HEATING-PLANT MGR BROWN 416-7844 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	AHU NOT HEATING IN AUDIT. PLANT MGR- BROWN/416.7594	1/23/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	rm 204 not heating	1/28/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	auditorium AHU #1 & 2 blowing cold air per mr brown	1/30/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	c/o to heat	10/23/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Boiler #1 needs Hi Limit replaced	10/23/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Monthly - Filter-Carver High - Refer to PM schedule details.	2/23/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	CEILING HEATER NOT HEATING IN BOILER RM PLANT MGR- BROWN/416.7594	3/5/14			Heating/Ventilation /Air Conditioning

Carver Sr (2085) 1A	assist supervisor ---- pump impellers froze up	3/6/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	bldg hot	10/31/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	check on coil alarm	11/13/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	bad controller rm 141	11/20/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Yearly - Air Handler Cleanings-Carver High - Refer to PM schedule details.	12/2/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	check aud. for vandalism	12/2/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Unit is LEAKING in the Auditorium on the Stage per Mr. Brown, Plant Mgr. 416.6926	12/3/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	meet lance on coil alarm	12/4/13			Heating/Ventilation /Air Conditioning

Carver Sr (2085) 1A	HEAT MAIN OFC AREA-NOT HEATING- PLANT MGR BROWN 416-7594 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Monthly - Oil Lube & Belt-Carver High - Refer to PM schedule details.	10/19/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Monthly - Filter-Carver High - Refer to PM schedule details.	10/20/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	per mr brown 416-7594 the chiller is down	4/29/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	main ofc freon leak	5/7/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	RM 158 level safety pan	5/7/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	RM 158 check drain and start unit back up -- - shut off by plumber	5/7/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	UNITS NOT COOLING IN GYM MAIN, CAFE PLANT MGR- BROWN/416.7594	5/15/14			Heating/Ventilation /Air Conditioning

Carver Sr (2085) 1A	Monthly - Oil Lube & Belt-Carver High - Refer to PM schedule details.	5/24/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	THERMOSTAT BANDRM-BROKEN, NOT ABLE TO CONTROL HEAT FLOW-PLANT MGR BROWN 416-7594 KLR	3/20/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Chiller, ID#125-089 NOT RUNNING in the Gym per Ms. McFarland, Plant Mgr. @ 650.0389.	7/9/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	clean chiller	7/10/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	SIX UNITS HAS BEEN STOLEN THAT CONTROLS THE MAIN OFFICE AREA. SBE HARDMAN 416-	7/29/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	purchase 2 cond. and material for job	7/31/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	UNIT IN THE FOOTBALL LOCKER RM IS NOT BLOWING. SBE MCFARLAND 416-7594	8/2/13			Heating/Ventilation /Air Conditioning

Carver Sr (2085) 1A	purchase 4 cond. for ofc areas	8/5/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	purchase cable	8/8/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	rooms not cooling thru out bldg	8/8/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	A/C IN MAIN OFC HAS BEEN VANDALIZED- CALLED IN BY PRIN JOHNSON 416-6900 KLR	8/19/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	AHU NOT COOLING IN RM-109 PLANT MGR- BROWN/416.7844	8/28/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	A/C in the Atrium is LEAKING and it's making a pond on the stage per Mr. Brown, Plant Mgr. 416.7594	9/17/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	RTU COIL IS FROZEN, NOT COMING ON FOR DANCE STUDIO. PLANT MGR- BROWN/416.7594	9/26/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	aud. unit left side of stage freezing up	9/30/13			Heating/Ventilation /Air Conditioning

Carver Sr (2085) 1A	Unit #135 in room 107 is making very loud noise per Ms. McFarland 650-0389	10/18/13			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	Monthly - Filter-Carver High - Refer to PM schedule details.	6/22/14			Heating/Ventilation /Air Conditioning
Carver Sr (2085) 1A	ceiling cracking up & falling in	4/16/14	1st Floor	boys toilet	Painting
Carver Sr (2085) 1A	ceiling cracking up & falling in	4/16/14	2nd Floor	girls toilet	Painting
Carver Sr (2085) 1A	Prime (only) expand metal and angle for HVAC fence encloser. To support Danny.	12/2/13	Grounds		Painting
Carver Sr (2085) 1A	GRAFFITI IN B/RR-G/RR. PLANT MGR-BROWN/416.7844	12/12/13			Painting
Carver Sr (2085) 1A	GRAFFITI ON BACK OF BLDG PLANT MGR-JOHNSON/416.7594	8/19/13			Painting
Carver Sr (2085) 1A	GRAFFITI OUTSIDE REAR ON (3) BLDGS-CALLED IN BY PRIN JOHNSON 416-6900 KLR	8/19/13			Painting

Carver Sr (2085) 1A	Prime only 16 expand metal panels, for Danny Walker.	9/4/13			Painting
Carver Sr (2085) 1A	Paint/Stain wood panels for science lab table over gas vavle. J. Murawske.	10/9/13			Painting
Carver Sr (2085) 1A	graffiti inside all restrooms per Mr. Brown 416-7594 (everett atkins told mr brown to put in emergency w/o for entire school)	10/14/13			Painting
Carver Sr (2085) 1A	RIVERVIEW-KANSAS DAYCARE-SINK MAIN HALL-LEAKING FROM BOTTOM, CAN'T CONTAIN-PLANT MGR TOWNES 949-0855 KLR	1/13/14			Plumbing
Carver Sr (2085) 1A	Water fountain near 2nd flr. girls restroom making loud fan noise.	1/24/14	Hallway/Corridor		Plumbing
Carver Sr (2085) 1A	Water fountain on 1st flr. near girls restroom making loud fan noise	1/24/14	Hallway/Corridor		Plumbing
Carver Sr (2085) 1A	rm 204 ---- clean strainer	1/31/14			Plumbing
Carver Sr (2085) 1A	Repair/Replace damaged (water) hose bib near front entrance. To support G.Burton.	10/24/13	Grounds		Plumbing

Carver Sr (2085) 1A	RIVERVIEW-KANSAS DAYCARE-COMMODE CAFE-NOT FLUSHING-PLANT MGR ROBINSON 946-0855 KLR	10/28/13			Plumbing
Carver Sr (2085) 1A	in response to work order #391910 ,the custodial sink is mounted to the fir. and leaking from the bottom.	10/29/13	Custodial Closet	rm.143	Plumbing
Carver Sr (2085) 1A	COMMODE G RR AUDITORIUM 3RD STALL-STOPPED UP-PLANT MGR McFARLAND 416-7495 KLR	11/1/13			Plumbing
Carver Sr (2085) 1A	urenal in1st flr. boys toilet stoped up, runs over when flushed	12/19/13	Restroom (Boys)		Plumbing
Carver Sr (2085) 1A	need hot water in custodial closet mop sink	6/13/14	2nd Floor		Plumbing
Carver Sr (2085) 1A	MLGW down street with broken main,check status of water inside.	4/17/14	1st Floor		Plumbing
Carver Sr (2085) 1A	per mr brown 416-6926 there is an a/c unit leaking in the main office	5/6/14			Plumbing
Carver Sr (2085) 1A	A/C RM 158-LEAKING IN CEILING-PLANT MGR BROWN KLR	5/7/14			Plumbing

Carver Sr (2085) 1A	drain stopped up in custodial next to 2nd flr boys toilet	6/11/14	Custodial Closet		Plumbing
Carver Sr (2085) 1A	all toilets in girls restroom loose & turning	3/19/14	Restroom (Girls)	1st.flr.	Plumbing
Carver Sr (2085) 1A	boys toilet 2nd stall loose & turning	3/19/14	Restroom (Boys)	1st.flr.	Plumbing
Carver Sr (2085) 1A	boys toilets loose & turning	3/19/14	Restroom (Boys)	2nd flr.	Plumbing
Carver Sr (2085) 1A	girls toilets loose & turning	3/19/14	Restroom (Girls)	2nd flr.	Plumbing
Carver Sr (2085) 1A	Toilet in 2nd stall leaking when flushed.	4/15/14	Restroom (Boys)	2nd flr.	Plumbing
Carver Sr (2085) 1A	Requesting to disconnect old Conv. oven (MCS# 522389). And Reconnect Conv. Oven (MCS#538631) already at school.	7/9/13	Kitchen	1st. Floor	Plumbing
Carver Sr (2085) 1A	Check gas on convet. oven.	7/15/13	Kitchen		Plumbing

Carver Sr (2085) 1A	Repair faucet on three comp.sink.	7/15/13	Kitchen		Plumbing
Carver Sr (2085) 1A	FCU RM 204-LEAKING SBE BROWN 416-7594 KLR	8/14/13			Plumbing
Carver Sr (2085) 1A	Overhead water pipes leaking in football equipment room.	9/17/13			Plumbing
Carver Sr (2085) 1A	Drian on double sided sink leaking when filled with water.	9/17/13	Cafeteria		Plumbing
Carver Sr (2085) 1A	BOILER RM PIPE IS LEAKING WATER BY CAFE. PLANT MGR- MCFARLAND/416.7594	9/17/13			Plumbing
Carver Sr (2085) 1A	Boys rest room badly stopped up need repaired.	9/17/13	Library	Restroom (Boys)	Plumbing
Carver Sr (2085) 1A	no hot water in sink in kitchen per Ms. McFarlane 416-7594	9/20/13			Plumbing
Carver Sr (2085) 1A	Test and report on backflow prevention devices.	9/25/13			Plumbing

Carver Sr (2085) 1A	Need toilet seat replaced in mens toilet in teachers lounge on 2nd flr.	9/25/13	2nd Floor	219	Plumbing
Carver Sr (2085) 1A	Girls restroom stopped up need repair.	9/27/13	Restroom (Girls)	Library	Plumbing
Carver Sr (2085) 1A	FCU MAIN OFC-LEAKING-SBE BROWN 416-7594 KLR	8/12/13			Plumbing
Carver Sr (2085) 1A	UV IS LEAKING WATER IN RM-108B PLANT MGR- BROWN/416.7594	8/13/13			Plumbing
Carver Sr (2085) 1A	A/C RMS 217 & 234- BOTH LEAKING- PLANT MGR BROWN 416-7594 KLR	9/11/13			Plumbing
Carver Sr (2085) 1A	Repair/replace saftey gas valves on two science lab tables.	10/3/13			Plumbing
Carver Sr (2085) 1A	A/C RM 216-LEAKING- PLANT MGR BROWN 416-7594 KLR	6/18/14			Plumbing
Carver Sr (2085) 1A	UNIT IS LEAKING WATER IN RM-108 PLANT MGR- BROWN/246.4141	6/20/14			Plumbing

Carver Sr (2085) 1A	Custodial wash tub has a hole in it at the bottom that need to be sealed, water runs out in the flr.	10/22/13	Custodial Closet	rm. 143	Plumbing
Carver Sr (2085) 1A	roof leaking in dance room	1/15/14	Auxiliary Gym		Roof
Carver Sr (2085) 1A	bad water leak every time it rains outside	1/15/14	Cafeteria		Roof
Carver Sr (2085) 1A	Check possible roof leak in main hallway. Near AHU duct work.	1/28/14	Hallway/Corridor		Roof
Carver Sr (2085) 1A	bad roof leaks in outside girls gym, water every where	11/22/13	Auxiliary Gym		Roof
Carver Sr (2085) 1A	rain water all over floor in cafeteria, coming in from outside	11/22/13	Cafeteria		Roof
Carver Sr (2085) 1A	RIVERVIEW-KANSAS DAYCARE-ROOF LEAKING MAIN HALL IN LIGHT FIXTURE- PLANT MGR TOWNES 946-0855 KLR	1/10/14			Roof
Carver Sr (2085) 1A	Roof leak in auditorium lobby area.	3/10/14	Auditorium		Roof

Carver Sr (2085) 1A	Raining badly on the Grils court and in the Studio Dance room need repair.	9/20/13	Annex	Girls Gym	Roof
Carver Sr (2085) 1A	water leaking in cafeteria when it rains outside.	9/23/13	Cafeteria		Roof
Carver Sr (2085) 1A	Fabricate cover plate for ceiling boys 2nd floor. Size 27.5 x 27.5. Support Frank-Jim.	6/13/14	Restroom (Boys)		Sheet Metal
Carver Sr (2085) 1A	need front gym door secured from recent break in.	1/28/14	Gym		Sheet Metal
Carver Sr (2085) 1A	patch hole in main office	3/25/14			Sheet Metal
Carver Sr (2085) 1A	need 3 foot of harden steel chain and lock for chiller gate	8/20/13			Sheet Metal
Carver Sr (2085) 1A	build and install cover for copper lines	8/20/13			Sheet Metal

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Central Sr (2090) 1A	6	13	124	116	100	11	151	11	9	541
Grand Total	6	13	124	116	100	11	151	11	9	541

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Central Sr (2090) 1A	Gym floor need to be done its been (4) years	10/2/13			Asbestos
Central Sr (2090) 1A	refinish gym floor	10/2/13			Asbestos
Central Sr (2090) 1A	Insulate new roof drain,band room	3/12/14			Asbestos
Central Sr (2090) 1A	Please schedule us to have our gymnasium floor refinished.	10/1/13	Gym		Asbestos
Central Sr (2090) 1A	insulation need for pipes around ac unit room c10	8/16/13			Asbestos
Central Sr (2090) 1A	abate and put back floor tile	4/30/14	Hallway/Corridor	2nd floor hallways	Asbestos
Central Sr (2090) 1A	computer drop in room-213 211-b-1 not working (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	2/19/14			Cabling

Central Sr (2090) 1A	cable for principal office knock down by (GCA) driver being supply on June 27 2013 (Request Network Cabling Installation Support).	7/1/13			Cabling
Central Sr (2090) 1A	room 301-1 and 301-2 are not functioning.computer drops in room 213, 211-b-1 not working.repair 211-1 office 211.	4/7/14			Cabling
Central Sr (2090) 1A	Central HG-WO379282--bad data port room A06 A06_2	8/29/13			Cabling
Central Sr (2090) 1A	room 301 drop port are out (301-1 301-2)	9/3/13			Cabling
Central Sr (2090) 1A	Central Sr. WO# 369159-- room (211) computer drop (B1) need repair (Request Network Cabling Maintenance Repair).	7/31/13			Cabling
Central Sr (2090) 1A	repair drop (13-5) room c 10 (Request Network Cabling Maintenance Repair).	8/5/13			Cabling
Central Sr (2090) 1A	move drops in weighroom to west side of room	10/10/13			Cabling
Central Sr (2090) 1A	room (AMOI) needs (2)computer outlet and (1) telephone outlet (Request Network Cabling Project Management).	7/27/13			Cabling

Central Sr (2090) 1A	Service call to install a new Network cable in the Weight room at Central High.	2/14/14			Cabling
Central Sr (2090) 1A	repair computer drop 211-1 office 211 (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	2/25/14			Cabling
Central Sr (2090) 1A	211 drop not done (SCS -Cabling and Electronics Dept.-- Response DECLINED - DUPLICATE REQUEST - "Please See Journal Notes")	2/25/14			Cabling
Central Sr (2090) 1A	wrong room number given on work order #(369159) correct room 213 asst principal office	8/19/13			Cabling
Central Sr (2090) 1A	room d110 move pull down screen next to projector screen	1/31/14			Carpentry
Central Sr (2090) 1A	BLEACHERS WONT LET OUT IN GYM (HAVING A PROGRAM TODAY) PLANT MGR- WILLIAMS/416.4500	2/7/14			Carpentry
Central Sr (2090) 1A	room c11 door will not lock with key	2/7/14			Carpentry
Central Sr (2090) 1A	hang banner in gym	2/7/14			Carpentry

Central Sr (2090) 1A	need (4)cases of ceiling tile hard and soft	2/10/14			Carpentry
Central Sr (2090) 1A	repair door to auditorium will not lock	2/10/14			Carpentry
Central Sr (2090) 1A	ceiling tile special cut (15)	2/11/14			Carpentry
Central Sr (2090) 1A	window broken out hallway by 217	2/19/14			Carpentry
Central Sr (2090) 1A	floor in 213 will not keep tile down	2/19/14			Carpentry
Central Sr (2090) 1A	install dry earase board in roomd113	2/19/14			Carpentry
Central Sr (2090) 1A	fix locker boys locker pe help stealing	2/21/14			Carpentry
Central Sr (2090) 1A	repair leg on scorer table in gym	11/22/13			Carpentry

Central Sr (2090) 1A	move pull down screen in rooms d119 112	8/7/13			Carpentry
Central Sr (2090) 1A	room (223) dry board has fallen off wall	1/6/14			Carpentry
Central Sr (2090) 1A	can not lock air handle door outside gym	1/6/14			Carpentry
Central Sr (2090) 1A	Repair or replace broken door.	1/27/14		C10	Carpentry
Central Sr (2090) 1A	repair handle on door in hallway by ao7	3/19/14			Carpentry
Central Sr (2090) 1A	repair door room ao3	3/19/14			Carpentry
Central Sr (2090) 1A	repair gate by football feild by alley hit by car	3/31/14			Carpentry
Central Sr (2090) 1A	repair bookshevles in library	4/2/14			Carpentry

Central Sr (2090) 1A	repair hole in wall in cafe mice coming thru it	4/3/14			Carpentry
Central Sr (2090) 1A	magnet on wall in hallway lower lobby	4/7/14			Carpentry
Central Sr (2090) 1A	repair broken window by room101 hallway	4/7/14			Carpentry
Central Sr (2090) 1A	remove door stop room e19 cutting floor	4/7/14			Carpentry
Central Sr (2090) 1A	door to room c10 will not close	1/9/14			Carpentry
Central Sr (2090) 1A	stop pads need repairs coming off wall	1/10/14			Carpentry
Central Sr (2090) 1A	replace ceiling tile speical cut tile is molded rooma08	1/10/14			Carpentry
Central Sr (2090) 1A	room 223 ceiling tile will not stay up	1/10/14			Carpentry

Central Sr (2090) 1A	repair 4door closers main lobby	4/21/14			Carpentry
Central Sr (2090) 1A	door handle and lock broken off door stairwell by cafe	4/22/14			Carpentry
Central Sr (2090) 1A	Door handle falling off cafe entrance.	4/23/14			Carpentry
Central Sr (2090) 1A	ceiling tiled replaced. Cut pieces east entrance by choir.	4/23/14			Carpentry
Central Sr (2090) 1A	ceiling tile cut and replace main building by breakroom	4/23/14			Carpentry
Central Sr (2090) 1A	door hinge and frame broken girls restroomby a04	4/23/14			Carpentry
Central Sr (2090) 1A	repair marquee p glass broken by high wind	4/10/14			Carpentry
Central Sr (2090) 1A	install door sweep in cafe storage room	3/24/14			Carpentry

Central Sr (2090) 1A	repair blind room d110	3/25/14			Carpentry
Central Sr (2090) 1A	room (D33) need dry erase board see me	8/12/13			Carpentry
Central Sr (2090) 1A	repair door panic bar by cafe	8/14/13			Carpentry
Central Sr (2090) 1A	install (2) dry eraser board room a02	8/21/13			Carpentry
Central Sr (2090) 1A	need one dry erase board d110	8/23/13			Carpentry
Central Sr (2090) 1A	repair push bar on door d building west side	9/3/13			Carpentry
Central Sr (2090) 1A	door lower looby will not close	11/22/13			Carpentry
Central Sr (2090) 1A	repair door hinge to fire door by pe lockerroom	12/5/13			Carpentry

Central Sr (2090) 1A	hang poster by main lobby for principal (5)	12/5/13			Carpentry
Central Sr (2090) 1A	repair door to gym will not stay lock	12/5/13			Carpentry
Central Sr (2090) 1A	door to cafe will not closehandle broken	12/5/13			Carpentry
Central Sr (2090) 1A	replace hinge to door boys restroom by cafe	12/5/13			Carpentry
Central Sr (2090) 1A	gym beachers wheel will not roll	12/18/13			Carpentry
Central Sr (2090) 1A	room (206) has missing tile	12/18/13			Carpentry
Central Sr (2090) 1A	cafe has (22) missing tiles	12/18/13			Carpentry
Central Sr (2090) 1A	hallway second floor missing tiles	12/18/13			Carpentry

Central Sr (2090) 1A	remove locker in football locker room per Daniel Hurdle	12/19/13			Carpentry
Central Sr (2090) 1A	center of outside door to d building can not secure door	10/30/13			Carpentry
Central Sr (2090) 1A	can not secure boiler room door	10/30/13			Carpentry
Central Sr (2090) 1A	need (4) cork boards (4)dry erasre board in weight room	11/1/13			Carpentry
Central Sr (2090) 1A	remove (5) door off hinge so floor can be laid	11/1/13			Carpentry
Central Sr (2090) 1A	BROKEN WINDOW IN CAFE PLANT MGR- WILLIAM/416.4500	11/13/13			Carpentry
Central Sr (2090) 1A	(8) doors carve with graffiti main lobby Linden side dry earse board for room (c 116)to cover black board	8/1/13			Carpentry
Central Sr (2090) 1A	door handle off to door main lobbt see me for handle	9/5/13			Carpentry

Central Sr (2090) 1A	rear door to gym will not close	9/6/13			Carpentry
Central Sr (2090) 1A	room (211) need two dry eraser boards	9/9/13			Carpentry
Central Sr (2090) 1A	room c11 door will not close	9/10/13			Carpentry
Central Sr (2090) 1A	cafe door will not open to serving line	9/10/13			Carpentry
Central Sr (2090) 1A	weight room remove boards from wall	9/24/13			Carpentry
Central Sr (2090) 1A	remove board from floor in weight room	9/24/13			Carpentry
Central Sr (2090) 1A	repair glass in stairwell A building third floor	9/26/13			Carpentry
Central Sr (2090) 1A	repair door in cafe off hinge	9/26/13			Carpentry

Central Sr (2090) 1A	replace door handle in library	9/26/13			Carpentry
Central Sr (2090) 1A	08 door will not close closer is broken	10/2/13			Carpentry
Central Sr (2090) 1A	CEILING TILE HAS FALLEN DUE TO A/C UNIT IN C-BLDG 2ND FLR BY RM-C21 PLANT MGR- WILLIAMS/416.4500	10/2/13			Carpentry
Central Sr (2090) 1A	cafe rear door screen hinge has pulled from door	10/2/13			Carpentry
Central Sr (2090) 1A	will install need (3) dry erase boards for room (a03 & ao!	7/22/13			Carpentry
Central Sr (2090) 1A	replace broken t in ceiling hallway chall	10/3/13			Carpentry
Central Sr (2090) 1A	replace hardware to door room 201	10/3/13			Carpentry
Central Sr (2090) 1A	can not open teacher restroom second floor d building	10/14/13			Carpentry

Central Sr (2090) 1A	restroom in stadium will not lock	10/18/13			Carpentry
Central Sr (2090) 1A	door closer broken main lobby door will not stay closed	10/21/13			Carpentry
Central Sr (2090) 1A	hang banner (see plant mgr } in gym	10/23/13			Carpentry
Central Sr (2090) 1A	main lobby door closer broken Linden side	10/23/13			Carpentry
Central Sr (2090) 1A	Weld/repair two wheeler.	8/27/13			Carpentry
Central Sr (2090) 1A	Repair ceiling tile	7/26/13			Carpentry
Central Sr (2090) 1A	need plaques hung in main lobby Linden side	7/27/13			Carpentry
Central Sr (2090) 1A	Assist tile layer	6/3/14			Carpentry

Central Sr (2090) 1A	repair principal door 306	5/14/14			Carpentry
Central Sr (2090) 1A	repair gate hit by car in back alley	5/7/14			Carpentry
Central Sr (2090) 1A	Remove plaster ceiling for plumbers	12/18/13			Carpentry
Central Sr (2090) 1A	boys locker room can't be secured because dead bolt will not line up and it needs to be locked for vandalism purposes per Mr. Williams 416-4500	11/26/13			Carpentry
Central Sr (2090) 1A	ceiling tile need replaced main building outside library. Have ceiling tiles on site	4/29/14			Carpentry
Central Sr (2090) 1A	door wont shut bathroom by gym	4/29/14			Carpentry
Central Sr (2090) 1A	repair outside door d building	5/9/14			Carpentry
Central Sr (2090) 1A	door closer is damaged in main lobby	5/16/14			Carpentry

Central Sr (2090) 1A	handle is falling off of door in cafeteria	5/16/14			Carpentry
Central Sr (2090) 1A	door is hard to close in bandroom	5/19/14			Carpentry
Central Sr (2090) 1A	girls restroom hinges damaged 3rd floor	5/19/14			Carpentry
Central Sr (2090) 1A	ceiling tiles need to replace by cafe	5/21/14			Carpentry
Central Sr (2090) 1A	repair broken fence behind school by track	5/29/14			Carpentry
Central Sr (2090) 1A	see plant mgr speical cut ceiling tile	5/29/14			Carpentry
Central Sr (2090) 1A	door closer to back broken cafe	2/26/14			Carpentry
Central Sr (2090) 1A	replace stain ceiling tile d building 2 floor a building 4 floor c building 5 floors	2/26/14			Carpentry

Central Sr (2090) 1A	replace molded ceiling tile (10)5 ROOMS LABS	2/27/14			Carpentry
Central Sr (2090) 1A	repair door handle lower lobby	3/12/14			Carpentry
Central Sr (2090) 1A	repair broken hinge to gym door	3/12/14			Carpentry
Central Sr (2090) 1A	repair door handle by cafe	3/12/14			Carpentry
Central Sr (2090) 1A	boiler room door will not close with out force	3/12/14			Carpentry
Central Sr (2090) 1A	cold base missing on 2nd floor a building hallway	3/12/14			Carpentry
Central Sr (2090) 1A	Door closure needs repair boys locker room.	4/14/14			Carpentry
Central Sr (2090) 1A	Door handle hanging by the weight room.	4/14/14			Carpentry

Central Sr (2090) 1A	door not closing properly	5/16/14	Library		Carpentry
Central Sr (2090) 1A	cafe needs (25) floor tiles room (302 310 315) need 10 each	7/25/13			Carpentry
Central Sr (2090) 1A	rooms (316 214 210) need (4) floor tile each	7/25/13			Carpentry
Central Sr (2090) 1A	rooms 209 need 20 tiles for floor 204 need 10 203 need4 201 need 4	7/25/13			Carpentry
Central Sr (2090) 1A	room A09)need door install with glass window	7/25/13			Carpentry
Central Sr (2090) 1A	outside door to gym will not close	8/15/13			Carpentry
Central Sr (2090) 1A	install dry erase board room a06	8/15/13			Carpentry
Central Sr (2090) 1A	flag pole hung up need line freed	8/16/13			Carpentry

Central Sr (2090) 1A	Door sticking. Hard to open and close.	4/14/14	2nd Floor	D108	Carpentry
Central Sr (2090) 1A	3rd floor c building needs 36 floor tiles replaced.	4/14/14	3rd Floor		Carpentry
Central Sr (2090) 1A	replace missing quarter round all floor atop locker	3/12/14			Carpentry
Central Sr (2090) 1A	ref wo#367674 (a09) is now a office glass door is needed for security	8/20/13			Carpentry
Central Sr (2090) 1A	change door boys lockerroom to coaches office	11/22/13			Carpentry
Central Sr (2090) 1A	repair principal desk room (304) see me	9/4/13			Carpentry
Central Sr (2090) 1A	repair/replace garbage disposal in home economics room	7/20/13	Classroom		Carpentry
Central Sr (2090) 1A	stairs in a building metal nose causing students to slip and fall	5/14/14			Carpentry

Central Sr (2090) 1A	prinicipal office has (2sets) of ballasts out	1/29/14			Electrical
Central Sr (2090) 1A	(9) lights out in gym	2/5/14			Electrical
Central Sr (2090) 1A	room 309 need ballast	2/11/14			Electrical
Central Sr (2090) 1A	room 313 need ballast	2/11/14			Electrical
Central Sr (2090) 1A	room 314 need ballast	2/11/14			Electrical
Central Sr (2090) 1A	room 302 need 2 ballast replace	2/11/14			Electrical
Central Sr (2090) 1A	need (4) cases of 46807 (10)46821	2/12/14			Electrical
Central Sr (2090) 1A	replace ballast in hallway by main office	2/12/14			Electrical

Central Sr (2090) 1A	need ballast in cafe mgr office	2/18/14			Electrical
Central Sr (2090) 1A	light in stairwell by room 300 need ballast	2/18/14			Electrical
Central Sr (2090) 1A	light in hallway by 313 need ballast	2/18/14			Electrical
Central Sr (2090) 1A	light in hallway by 313 need ballast	2/18/14			Electrical
Central Sr (2090) 1A	e16 lights will not come on	2/18/14			Electrical
Central Sr (2090) 1A	replace clock in library	2/19/14			Electrical
Central Sr (2090) 1A	REP/REPL LIGHTS IN GYM AREA- REQUESTED BY D HURDLE KLR	2/20/14			Electrical
Central Sr (2090) 1A	need ballast in hallway by 313	2/21/14			Electrical

Central Sr (2090) 1A	check em lights in gym	2/21/14			Electrical
Central Sr (2090) 1A	AHU NOT COMING ON IN AUDIT PLANT MGR- WILLIAMS/416.4500	10/23/13			Electrical
Central Sr (2090) 1A	NO POWER IN GUIDANCE OFFICE. PLANT MGR- WILLIAMS/416.4500	10/28/13			Electrical
Central Sr (2090) 1A	Need 6 ballast replaced in 1st floor hallway A building(1), A105(1), A122(1), A130(1), and A137(2).	10/28/13			Electrical
Central Sr (2090) 1A	Need 6 ballast replaced in 1st floor hallway A building(1), A105(1), A122(1), A130(1), and A137(2).	10/29/13			Electrical
Central Sr (2090) 1A	need (4)cases of(46807) (10)46778	10/29/13			Electrical
Central Sr (2090) 1A	air handlers for gym will not come on drampers will not open	1/7/14			Electrical
Central Sr (2090) 1A	need 46807 bulbs (4) cases need (10) 46821 bulbs	1/17/14			Electrical

Central Sr (2090) 1A	teachers lounge no power on one side of room	3/28/14			Electrical
Central Sr (2090) 1A	1 row of lights not working in gym	4/7/14			Electrical
Central Sr (2090) 1A	move light for hvac room 208	1/9/14			Electrical
Central Sr (2090) 1A	repair stage lights in ceiling auditorium	1/9/14			Electrical
Central Sr (2090) 1A	repair stage lights on stage flood lights	1/9/14			Electrical
Central Sr (2090) 1A	main lobby magnet will not hold fire doors	1/9/14			Electrical
Central Sr (2090) 1A	repair house lights in auditorium	1/9/14			Electrical
Central Sr (2090) 1A	elec wall socket broken hallway by cafe	4/17/14			Electrical

Central Sr (2090) 1A	need 4 cases of 46807 5 cases of 46821	4/17/14			Electrical
Central Sr (2090) 1A	teacher restroom a08 ballast out	4/22/14			Electrical
Central Sr (2090) 1A	3 sets of ballast out room a07	3/25/14			Electrical
Central Sr (2090) 1A	Mr. white this is a new request needed are(3) cases of #46807 and (10) 46821	8/14/13			Electrical
Central Sr (2090) 1A	new request needed are (5) # 46866	8/14/13			Electrical
Central Sr (2090) 1A	need 4 cases (46807) need 25 (46821)	7/23/13			Electrical
Central Sr (2090) 1A	exhaust fan bely broken pump room	8/30/13			Electrical
Central Sr (2090) 1A	room (319) thermostat fallen off wall	9/4/13			Electrical

Central Sr (2090) 1A	replace socket elec in a hallway by a09	11/22/13			Electrical
Central Sr (2090) 1A	replace elec socket in cafe wall	11/22/13			Electrical
Central Sr (2090) 1A	repair light stage in auditorium	12/2/13			Electrical
Central Sr (2090) 1A	need (3) cases of #46807 (10)46821	12/9/13			Electrical
Central Sr (2090) 1A	ballast out hallway by cafe	12/10/13			Electrical
Central Sr (2090) 1A	ballast out by main office hallway	12/10/13			Electrical
Central Sr (2090) 1A	replace light fixture in shower football locker room	12/19/13			Electrical
Central Sr (2090) 1A	replace ballast in plant mgr office	12/19/13			Electrical

Central Sr (2090) 1A	replace ballast in principal office	12/19/13			Electrical
Central Sr (2090) 1A	beaches in gym east side will not come out	10/30/13			Electrical
Central Sr (2090) 1A	HAS A COMPLETE POWER OUTAGE- PLANT MGR WILLIAMS 416-4500 KLR	10/31/13			Electrical
Central Sr (2090) 1A	repair lights in football locker shower	11/5/13			Electrical
Central Sr (2090) 1A	ballasts out in library office	12/11/13			Electrical
Central Sr (2090) 1A	replace ballasts room (A02)	11/13/13			Electrical
Central Sr (2090) 1A	(4) sets of ballast out room (A06)	9/4/13			Electrical
Central Sr (2090) 1A	(2) sets of ballast out library	9/4/13			Electrical

Central Sr (2090) 1A	(8) sets of ballast out in boys pe locker room	9/5/13			Electrical
Central Sr (2090) 1A	repair motor on exhaust fan for consecion stand	9/5/13			Electrical
Central Sr (2090) 1A	3-UNITS NOT COMING ON IN ASSIST PRIN, FIN SECRETARY & GUIDANCE OFFICE. PLANT MGR- WILLIAMS/416.4500	9/6/13			Electrical
Central Sr (2090) 1A	need (3) cases of (46807) also (5)46781 (10)46821all bulbs used up that we have	9/9/13			Electrical
Central Sr (2090) 1A	room (221) need 4 sets of ballats room(D110) need 2 sets of ballasts	9/18/13			Electrical
Central Sr (2090) 1A	RECEPTACLES HAVE NO POWER IN PRESS BOX STADIUM (HAVING AN EVENT TONITE). PLANT MGR- BELL/416.4500	9/27/13			Electrical
Central Sr (2090) 1A	(11) lights out in auditorium	8/27/13			Electrical
Central Sr (2090) 1A	check cab lights in elevator d building	10/10/13			Electrical

Central Sr (2090) 1A	repair door light dbuilding	10/10/13			Electrical
Central Sr (2090) 1A	install elec power to C113 satellite for new radio	10/8/13			Electrical
Central Sr (2090) 1A	cafe ventahood not working	10/15/13			Electrical
Central Sr (2090) 1A	hot water tank not working in stadium	10/15/13			Electrical
Central Sr (2090) 1A	need (3)cases of #46807	10/16/13			Electrical
Central Sr (2090) 1A	need (5) time clocks	10/16/13			Electrical
Central Sr (2090) 1A	need (10)46821 lamps	10/17/13			Electrical
Central Sr (2090) 1A	(8) sets of ballasts out roo 201	10/17/13			Electrical

Central Sr (2090) 1A	ballasts out second floor d building	10/18/13			Electrical
Central Sr (2090) 1A	(4) sets of ballasts out in room 300	10/19/13			Electrical
Central Sr (2090) 1A	(2) sets of ballasts out room d31	10/19/13			Electrical
Central Sr (2090) 1A	pole lights in back school are out also student parking lot and teacher lot on bellvue side	10/23/13			Electrical
Central Sr (2090) 1A	Check a/c third floor	6/9/14			Electrical
Central Sr (2090) 1A	per mr williams 416-4500 the bells are not working	5/7/14			Electrical
Central Sr (2090) 1A	Reset chiller	6/4/14			Electrical
Central Sr (2090) 1A	need ballasts in room 104	6/23/14			Electrical

Central Sr (2090) 1A	UNIT NOT COMING ON IN LIBRARY PLANT MGR- WILLIAMS/416.4500	5/5/14			Electrical
Central Sr (2090) 1A	need 4 cases of 46807 rapid start	5/5/14			Electrical
Central Sr (2090) 1A	1st floor d building south stairwell need ballast	6/11/14			Electrical
Central Sr (2090) 1A	d36 33 35 31 need ballasts do not put light in front board see plant mgr	6/11/14			Electrical
Central Sr (2090) 1A	d building stairwell 2nd floor need ballast	6/11/14			Electrical
Central Sr (2090) 1A	d 109 d111 d110 d112 need ballasts	6/11/14			Electrical
Central Sr (2090) 1A	rooms 100 137 asst principal office 105 guidance office library need ballasts	6/12/14			Electrical
Central Sr (2090) 1A	d building teachers restroom need light swtch room 310 need ballast	6/12/14			Electrical

Central Sr (2090) 1A	need ballasts in rooms a01 06 04 07 06	6/12/14			Electrical
Central Sr (2090) 1A	install Ditek relay for low voltage protection on McQuay Chiller	3/11/14			Electrical
Central Sr (2090) 1A	Purchase 5 bulbs for main lobby	10/16/13			Electrical
Central Sr (2090) 1A	vent a hood in cafe will not stay on	4/30/14			Electrical
Central Sr (2090) 1A	ALL RECEPTACLES HAVE NO POWER IN MAIN LOBBY BY LINDEN SIDE PLANT MGR- WILLIAMS/416.4500	5/9/14			Electrical
Central Sr (2090) 1A	light in girls restroom out can not change because of bolts 1st floor	5/20/14			Electrical
Central Sr (2090) 1A	2nd floor girls restroom lights out can not change lights	5/20/14			Electrical
Central Sr (2090) 1A	hallway light out needs ballast by room 101	5/21/14			Electrical

Central Sr (2090) 1A	(4)cases of 46807 (10)46778	11/7/13				Electrical
Central Sr (2090) 1A	Need ballast installed. Rm. A101 (1) and A106 (1)	4/17/14	Classroom			Electrical
Central Sr (2090) 1A	Need 8 ballast installed in 2nd floor classrooms. 205(1), 209(2), 219(2), and 220(3). Please install before TCAP testing.	4/16/14	Classroom			Electrical
Central Sr (2090) 1A	Need the ballast replaced in classrooms 217(3) and 106(2)	10/1/13	Classroom	217 and 106		Electrical
Central Sr (2090) 1A	replace ballast (2)	10/2/13	Classroom	301		Electrical
Central Sr (2090) 1A	Need 7 ballast replaced in A310(2), A315(2), A316(2), and A319(1).	10/29/13	Classroom			Electrical
Central Sr (2090) 1A	Need 3 ballast replaced	10/19/13	Classroom	201		Electrical
Central Sr (2090) 1A	Need approx. 11 ballast replaced. Rm 201(4),203(1), 206(1), 208(1), 210(1), 211(1), 221(1), and 223(1).	11/14/13	Classroom			Electrical

Central Sr (2090) 1A	need (10) 4100k bulbs	11/15/13	Classroom		Electrical
Central Sr (2090) 1A	need ballasts for room c25	11/15/13	Classroom		Electrical
Central Sr (2090) 1A	Need 2 ballast replaced in attendance office	10/11/13	Administration Area	Attendance OFC	Electrical
Central Sr (2090) 1A	3 ballast needs replacing in the dining area.	9/23/13	Cafeteria		Electrical
Central Sr (2090) 1A	Need 4 more cases of rapid start lamps (Item#46807). Sent Ken White an email.	8/20/13	Custodial Closet		Electrical
Central Sr (2090) 1A	Replace balast in girls restroom on ground floor of C- building.	8/8/13	Restroom (Girls)		Electrical
Central Sr (2090) 1A	Need 4 more cases of rapid start lamps (Item#46807).	8/8/13	Custodial		Electrical
Central Sr (2090) 1A	install Ditek relay for low voltage protection on McQuay Chiller	4/29/14			Electrical

Central Sr (2090) 1A	(12) sets of light out in gym	10/23/13			Electrical
Central Sr (2090) 1A	need (15) 150 watts bulbs	8/6/13			Electrical
Central Sr (2090) 1A	need (5) #46866 bulbs	8/7/13			Electrical
Central Sr (2090) 1A	Need approx. 10 cases of light bulbs for classrooms and hallways	7/29/13	Custodial		Electrical
Central Sr (2090) 1A	Monthly - CENTRAL HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Check McQuay chiller for proper operation. Repair display.	10/15/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Unit in ROOM C21 is NOT HEATING per Mr. Williams, Plant Mgr. 416.4500.	1/30/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	State boiler inpector was here today call me mike pressure too high on one of the boilers	1/30/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - CENTRAL HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - Oil Lube & Belt-Central High - Refer to PM schedule details.	2/1/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - Air Compressor - Central High - Refer to PM schedule details.	2/3/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	CONDENSER UNIT NOT HEATING IN CAFE. PLANT MGR- WILLIAMS/416.4500	2/5/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	21-UV NOT COOLING THRU ENTIRE 3RD FLR. SBE-WILLIAMS/416-4500	7/3/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	UNITS IN RM 300-316 ARE NOT COOLING. SBE WILLIAMS 416-4500	7/9/13			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	ION COMPRESSOR IS NOT COMING ON. SBE WILLIAMS 416-4500	7/10/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	UV NOT COOLING IN WIRE RACK RM BY RM-106. SBE-WILLIAMS/416-4500	7/15/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	mr mike simmon per phone call room (208)is (51)degrees valve will not open THANKS	1/7/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	UNIT NOT COMING ON IN CAFE, & UNIT BY STAIRWAY CHOIR RM PLANT MGR- WILLIAMS/416.4500	1/8/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	VENTING HOOD IS BLOWING COLD AIR IN KITCHEN PLANT MGR- WILLIAMS/416.4500	1/22/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	HEAT RM 300-NOT HEATING-PLANT MGR WILLIAMS 416-4500 KLR	1/28/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	UNIT NOT COMING ON IN CAFE PLANT MGR- WILLIAMS/416-4500	3/6/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - CENTRAL HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - Filter-Central High - Refer to PM schedule details.	1/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Yearly - Water-Cool Chiller Filter-Central High - Refer to PM schedule details.	1/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	HEAT RM A09- OVERHEATING-TEMP IS 77-PLANT MGR WILLIAMS 416-4500 KLR	1/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	HEAT A09- OVERHEATING, TEMP IS 79-PLANT MGR WILLIAMS 416-4500 KLR	1/15/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	Daily - Central High Level 1 Water Treatment - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	CHILLER NOT COOLING. SBE-WILLIAMS/416-4500	7/23/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C IN RMS 209 & 221- BOTH NOT COOLING- PLANT MGR WILLIAMS 416-4500 KLR	8/23/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Yearly - Oil Samples- Central High - Refer to PM schedule details.	8/31/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Yearly - Air Handler Cleanings-Central High - Refer to PM schedule details.	11/30/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	UNIT NOT HEATING IN PRIN OFFICE. PLANT MGR- WILLIAMS/846.2646	12/9/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	HEAT RM 300-NOT HEATING-PLANT MGR WILLIAMS 416-4500 KLR	12/12/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C RMS 221, 201, & C10-ALL NOT COOLING-PLANT MGR WILLIAMS 416-4500 KLR	9/10/13			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	Monthly - Filter-Central High - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C RM 100-NOT COOLING-PLANT MGR WILLIAMS 416-4500 KLR	9/24/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	AHU #2,3 NOT COOLING IN CAFE. PLANT MGR- WILLIAM/416.4500	9/27/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C BANDRM NOT COMING ON & GYM AHU BELT BROKE, NOT COMING ON- PLANT MGR WILLIAMS 416-4500 KLR	10/9/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C AUD MAKING NOISES-PLANT MGR WILLIAMS 416-4500 KLR	10/9/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C RM C11-NOT COOLING-PLANT MGR WILLIAMS 416-4500 KLR	10/15/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	rm 209 overcooling	10/4/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	library not cooling	7/22/13			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	rm 215 not cooling	9/26/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	chiller shut down test	9/26/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	library a/c is not cooling per Mr. Williams 416-4500	9/16/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	chiller down	8/26/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	rm E 15 not cooling	8/14/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	purchase adapter cable for ems connection	8/15/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - Air Compressor - Central High - Refer to PM schedule details.	7/29/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	chiller down	6/23/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	Reset chiller	6/10/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	chiller down	5/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	AHU #7 not cooling	5/6/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	per mr williams 416-4500 rooms 300, 302, 314 are all blowing hot	5/2/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	replace tstat in library	5/2/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	63 deg. in library	5/2/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	chiller down	5/1/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C AUDITORIUM- NOT COOLING- PLANT MGR WILLIAMS 416-4500 KLR	5/6/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	clean tower	3/27/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	check chiller	4/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	power outage	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	cafe contactor	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	cafe needs contactor	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Aud. needs contactor	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Aud. not coming on	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	library not coming on	4/29/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	locker room not coming on	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	cooling tower ckt 1 not coming on	4/29/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Make-up air unit not heating	1/15/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	check cond. pump	4/7/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	check boilers	3/6/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	rm 209 overheating	3/18/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	make up air unit not coming on --- north side of library	3/18/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	COND. PUMPS --- CLEAN STRAINERS	2/17/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	REPAIR OR REPLACE CIRCUIT SETTER	2/17/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	AHU #6 needs actuator	11/7/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	locate surge protection for controls	11/6/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	per mr williams 416- 4500 room C22 is blowing cold	2/12/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Locker room overhead a/c unit is blowing hot air per Mr. Williams 416- 4500	8/8/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	concession stand -- close dampers	12/4/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	check MAU unit on north side of building	12/4/13			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	AHU #5&6 not heating	12/10/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	room 209 overheating - 86 degrees per Mr. Williams 416-4500	12/2/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	boiler #1 not coming on	12/3/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	c/o to heat	10/23/13			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - CENTRAL HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	A/C AUDITORIUM & MAIN LOBBY-BOTH NOT COOLING- PLANT MGR WILLIAMS 416-4500 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - Filter-Central High - Refer to PM schedule details.	5/13/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Monthly - CENTRAL HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Yearly - Rod Chiller - Central High - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Daily - Centrel High Level 1 Water Treatment - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	UNIT IS OVERHEATING (86) IN RM-209 PLANT MGR- WILLIAMS/416.4500	3/7/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	Yearly - Cooling Towers(STRAINERS)- Central High - Refer to PM schedule details.	3/8/14			Heating/Ventilation /Air Conditioning
Central Sr (2090) 1A	CHILLER NOT COMING ON PLANT MGR- WILLIAMS/416.4500	6/9/14			Heating/Ventilation /Air Conditioning

Central Sr (2090) 1A	main office door need painting	7/29/13			Painting
Central Sr (2090) 1A	2nd floor hallway need plaster working and painting	7/29/13			Painting
Central Sr (2090) 1A	rooms (222 218 219) need plaster work and painting	7/25/13			Painting
Central Sr (2090) 1A	need paint where carpeters moved teachers mail boxes 2 summers ago main office	6/30/14			Painting
Central Sr (2090) 1A	GANG GRAFFITI OUTSIDE ON WINDOW SILL ON THE LINDEN ST. SIDE- PLANT MGR WILLIAMS 416-4500 KLR	4/1/14			Painting
Central Sr (2090) 1A	GANG GRAFFITI OUTSIDE ON NE STAIRWELL ON BRICK WALL-PLANT MGR WILLIAMS 416-4500 KLR	12/16/13			Painting
Central Sr (2090) 1A	Graffiti on the school building on the Linden Street side per Mr. Williams, Plant Mgr. 416.4500	9/23/13			Painting
Central Sr (2090) 1A	GRAFFITI ON RAILS LINDEN SIDE. PLANT MGR- WILLIAMS/416.4500	10/22/13			Painting

Central Sr (2090) 1A	Put clear finish on door	10/9/13			Painting
Central Sr (2090) 1A	Clear coat door	3/10/14			Painting
Central Sr (2090) 1A	lines needed for fire lane to met code teacher parking lot bellvue also painting principal parking spaces	8/16/13			Painting
Central Sr (2090) 1A	PIPE has BURST under LAB WORKSTATION in ROOM C115 per Mr. Williams, Plant Mgr. 416.4500.	1/30/14			Plumbing
Central Sr (2090) 1A	sink leaking in stadium concession	10/23/13			Plumbing
Central Sr (2090) 1A	sink in main office stop up	10/28/13			Plumbing
Central Sr (2090) 1A	girls restroom c building toilet will not stop running	10/28/13			Plumbing
Central Sr (2090) 1A	sink in boys restroom d building handle leaking	10/28/13			Plumbing

Central Sr (2090) 1A	toilet in boiler room stop up	10/28/13			Plumbing
Central Sr (2090) 1A	URINAL IS STOPPED UP IN B/RR 3RD FLR PLANT MGR- WILLIAMS/416.4500	11/18/13			Plumbing
Central Sr (2090) 1A	boys restroom toilet stopped up	11/20/13			Plumbing
Central Sr (2090) 1A	plant mgr restroom toilet seat broken	11/20/13			Plumbing
Central Sr (2090) 1A	girls restroom second floor toilet will not flush	11/20/13			Plumbing
Central Sr (2090) 1A	restroom main office toilet broken	11/20/13			Plumbing
Central Sr (2090) 1A	restroom by cafe boys urinal stopped	11/20/13			Plumbing
Central Sr (2090) 1A	UNIT IS LEAKING WATER IN MAIN OFFICE. PLANT MGR- WILLIAMS/416.4500	8/8/13			Plumbing

Central Sr (2090) 1A	urinal boys restroom dbuilding leahing from base of wall	1/17/14			Plumbing
Central Sr (2090) 1A	repair handles on sink in boys restroom second floor	1/23/14			Plumbing
Central Sr (2090) 1A	toilet on stage restroom stop up	1/27/14			Plumbing
Central Sr (2090) 1A	room sinks to lab station stop up room (c21)	1/27/14			Plumbing
Central Sr (2090) 1A	toilet coming off floor when flushed teacher lounge	3/12/14			Plumbing
Central Sr (2090) 1A	repair leaking mop sink by cafe	3/20/14			Plumbing
Central Sr (2090) 1A	repair mop sink 2nd floor	3/20/14			Plumbing
Central Sr (2090) 1A	repair lab sink room c115	3/20/14			Plumbing

Central Sr (2090) 1A	replace broken sink dbldg 2nd floor boys restroom	3/20/14			Plumbing
Central Sr (2090) 1A	SINK ON LAB STATION IN SCIENCE LAB C115-LEAKING AND WATER GOING DOWN INTO RM BELOW PER SBE- PLANT MGR WILLIAMS 416 4500	3/28/14			Plumbing
Central Sr (2090) 1A	room c115 lab sinking down on room c22	3/28/14			Plumbing
Central Sr (2090) 1A	restroom sink stop up 2nd floor a building	3/28/14			Plumbing
Central Sr (2090) 1A	d building restroom boys toilet stop up 1st floor	3/28/14			Plumbing
Central Sr (2090) 1A	cafe sink stop up	3/28/14			Plumbing
Central Sr (2090) 1A	cafe toilet will not flush	3/28/14			Plumbing
Central Sr (2090) 1A	2 roof drain stop up by watwr tower	4/2/14			Plumbing

Central Sr (2090) 1A	repair actuator room 114	1/9/14			Plumbing
Central Sr (2090) 1A	asst principal toilet will not stop running	1/9/14			Plumbing
Central Sr (2090) 1A	STEAM TABLE PIPE HAS BUSTED IN CAFE. PLANT MGR- WILLIAMS/416.4500	1/14/14			Plumbing
Central Sr (2090) 1A	water fountain drain stop up	4/17/14			Plumbing
Central Sr (2090) 1A	A/C RM A001-DRAIN STOPPED UP & LEAKING-PLANT MGR WILLIAMS 416-4500 KLR	4/22/14			Plumbing
Central Sr (2090) 1A	sink in boys restroom leaking drain pipe under sink	1/16/14			Plumbing
Central Sr (2090) 1A	girls restroom by room c115 handicap stall stopped up	1/16/14			Plumbing
Central Sr (2090) 1A	turn down water flow throughout building	1/17/14		restrooms	Plumbing

Central Sr (2090) 1A	toilets stopped up in girls restroom in gym.	4/9/14			Plumbing
Central Sr (2090) 1A	toilet stop up boys restroom 3rd floor	4/29/14			Plumbing
Central Sr (2090) 1A	water fountain stoped up cafe	4/29/14			Plumbing
Central Sr (2090) 1A	toilet will not flush d building 1st	4/29/14			Plumbing
Central Sr (2090) 1A	water fountain leaking 2nd floor	4/29/14			Plumbing
Central Sr (2090) 1A	WATER TANK NOT RELEASING HOT WATER IN CAFE, & CHEMICAL DISPENSER LEAKING WATER FROM CUST CLOSET 2ND FLR C-PLD GOING DOWN	8/9/13			Plumbing
Central Sr (2090) 1A	room (c114)need water turn on	8/12/13			Plumbing
Central Sr (2090) 1A	PIPE LEAKING IN CEILING OF RM C10-SBE WILLIAMS 416-4500 KLR	8/12/13			Plumbing

Central Sr (2090) 1A	GAS SMELL IN KITCHEN, CAFE, & HALLWAY BY AREA-SBE WILLIAMS 416-4500 KLR	8/13/13			Plumbing
Central Sr (2090) 1A	turn watwr on in roomc144	8/14/13			Plumbing
Central Sr (2090) 1A	shower head leaking basketball locker room	8/14/13			Plumbing
Central Sr (2090) 1A	boys dressing room water running will not stop	8/14/13			Plumbing
Central Sr (2090) 1A	CEILING UNIT IS LEAKING WATER RM-306 PLANT MGR-WILLIAMS/416.4500	8/23/13			Plumbing
Central Sr (2090) 1A	water fountain leaking hallway by main lobby	8/26/13			Plumbing
Central Sr (2090) 1A	restroom third floor boys water will not cut off in sink	8/26/13			Plumbing
Central Sr (2090) 1A	football locker room urinal will not stop running	8/26/13			Plumbing

Central Sr (2090) 1A	FLOOR DRAIN BACKING UP PE B LOCKER RM FECES ALSO COMING UP THRU FLR-PLANT MGR WILLIAMS 416- 4500 KLR	8/29/13			Plumbing
Central Sr (2090) 1A	water fountain not cooling 2nd floor by room 211	8/30/13			Plumbing
Central Sr (2090) 1A	water by cafe not cooling	8/30/13			Plumbing
Central Sr (2090) 1A	two waterr fountain in cafe not cooling	8/30/13			Plumbing
Central Sr (2090) 1A	sink leaking on floor	11/26/13			Plumbing
Central Sr (2090) 1A	3rd floor boys restroom toilet drain stopped up leaking down to 2nd floor	11/26/13			Plumbing
Central Sr (2090) 1A	toilets leaking from bottom in 3rd floor boys restroom	11/26/13			Plumbing
Central Sr (2090) 1A	urinal stopped up in first floor boys restroom	11/26/13			Plumbing

Central Sr (2090) 1A	drain leaking under kitchen sink	11/26/13		kitchen	Plumbing
Central Sr (2090) 1A	toilet leaking loose from floor girls restroomthird floor	12/5/13			Plumbing
Central Sr (2090) 1A	two faucet leaking girls restroom third floor	12/5/13			Plumbing
Central Sr (2090) 1A	third floor boys urinal stopped up	12/5/13			Plumbing
Central Sr (2090) 1A	handle off sink d building ist floor	12/10/13			Plumbing
Central Sr (2090) 1A	Repair urinal in football locker room. Urinal will not stop fushing.	12/18/13			Plumbing
Central Sr (2090) 1A	SEWAGE BACK-UP IN RM-A08. PLANT MGR- WILIAMS/416.4500	12/19/13			Plumbing
Central Sr (2090) 1A	urinal boys restroom by cafe will flush	11/5/13			Plumbing

Central Sr (2090) 1A	replace seat to toilet grils restroom handicap third floor	12/4/13			Plumbing
Central Sr (2090) 1A	urinal main hallway boys restroom stop up	12/12/13			Plumbing
Central Sr (2090) 1A	UNIT IS LEAKING WATER IN RM-C115. PLANT MGR- WILLIAMS/416.4500	9/5/13			Plumbing
Central Sr (2090) 1A	girl restroom in gym toilet flush water come up out of toilet	9/5/13			Plumbing
Central Sr (2090) 1A	girls restroom toilet stop up	9/5/13			Plumbing
Central Sr (2090) 1A	UNIT IS LEAKING WATER IN RM-C115. PLANT MGR- WILLIAMS/416.4500	9/6/13			Plumbing
Central Sr (2090) 1A	room (A06) sink stopped up	9/10/13			Plumbing
Central Sr (2090) 1A	cafe floor drain stopped up	9/11/13			Plumbing

Central Sr (2090) 1A	CAFE AREA- FLOODED OUT-SBE DOES NOT KNOW WHERE WATER IS COMING FROM- PLANT MGR WILLIAMS 416-4500 KLR	9/20/13			Plumbing
Central Sr (2090) 1A	NO HOT WATER TO KITCHEN AT ALL-WILL NEED-PLANT MGR WILLIAMS 416-4500 KLR	9/23/13			Plumbing
Central Sr (2090) 1A	replace toilet seat restroom main office	9/25/13			Plumbing
Central Sr (2090) 1A	replace toilet seat teacher work roomby asst principal office	9/25/13			Plumbing
Central Sr (2090) 1A	replace broken hand sink boys restroom third floor	9/25/13			Plumbing
Central Sr (2090) 1A	drain stopped up boiler room	9/26/13			Plumbing
Central Sr (2090) 1A	teacher lounge restroom toilet stopped up	9/26/13			Plumbing
Central Sr (2090) 1A	replace boys restroom toilet seat D building	9/27/13			Plumbing

Central Sr (2090) 1A	UNIT IS LEAKING WATER C-BLDG 2ND FLR BY RM-C21 PLANT MGR- WILLIAMS/416.4500	10/2/13			Plumbing
Central Sr (2090) 1A	FLOOR DRAIN STOPPED UP IN KITCHEN AREA- PLANT MGR WILLIAMS 416-4500 KLR	8/27/13			Plumbing
Central Sr (2090) 1A	A/C RM 209-DRAIN STOPPED CAUSING IT TO LEAK-PLANT MGR WILLIAMS 416- 4500 KLR	10/15/13			Plumbing
Central Sr (2090) 1A	toilet stop up girls restroom second floor handicap stall	10/22/13			Plumbing
Central Sr (2090) 1A	toilet in boys restroom by cafe handicap stall	10/22/13			Plumbing
Central Sr (2090) 1A	p[pe leaking boys locker room by shower	10/22/13			Plumbing
Central Sr (2090) 1A	sink leaking in gym boys restroom	10/22/13			Plumbing
Central Sr (2090) 1A	teacher lounge restroom toilet will not stop running	10/22/13			Plumbing

Central Sr (2090) 1A	camera storm drain	10/14/13			Plumbing
Central Sr (2090) 1A	Flush storm sewer	10/14/13			Plumbing
Central Sr (2090) 1A	Inspect sewer in cafeteria	10/4/13			Plumbing
Central Sr (2090) 1A	Inspect sewer in cafeteria	10/4/13			Plumbing
Central Sr (2090) 1A	Smoke test sewer, Wed. 10/09/13	10/4/13			Plumbing
Central Sr (2090) 1A	Stopped up sink in cafeteria and on the 3rd floor boys restroom a sink has been torn off the wall and can't shut off water per Mr. Williams 416-4500	9/16/13			Plumbing
Central Sr (2090) 1A	Replace toilet seat girls restroom	6/12/14			Plumbing
Central Sr (2090) 1A	Test and report on backflow prevention devices.	6/17/14			Plumbing

Central Sr (2090) 1A	Test and report on backflow prevention devices.	6/17/14			Plumbing
Central Sr (2090) 1A	Repair mop sink faucet	6/12/14			Plumbing
Central Sr (2090) 1A	per mr williams 416-4500 on the 2nd floor water fountain water is running out of the bottom	5/7/14			Plumbing
Central Sr (2090) 1A	Core drill hole for carpenter	6/6/14			Plumbing
Central Sr (2090) 1A	NO HOT WTR IN THE KITC - PM/WILLIAMS 416-4500	5/13/14			Plumbing
Central Sr (2090) 1A	restroom main office will not flush	5/30/14			Plumbing
Central Sr (2090) 1A	ELEVATOR BY CAFE PIT HAS WATER IN IT, NEED TO BE PUMPED OUT-PLANT MGR WILLIAMS 416-4500 KLR	6/30/14			Plumbing
Central Sr (2090) 1A	clean out roof drain all building	5/5/14			Plumbing

Central Sr (2090) 1A	clean roof drain d building	5/14/14			Plumbing
Central Sr (2090) 1A	A/C RM 104 DRAIN STOPPED UP CAUSING IT TO LEAK- PLANT MGR WILLIAMS 416-4500 KLR	6/6/14			Plumbing
Central Sr (2090) 1A	change out faucet in c hall porter closet and add hot water	6/12/14			Plumbing
Central Sr (2090) 1A	girls restroom toilet leaking from bottom by a06	6/12/14			Plumbing
Central Sr (2090) 1A	Test and report on backflow prevention devices.	7/2/13			Plumbing
Central Sr (2090) 1A	Turn water on for stadium	2/28/14			Plumbing
Central Sr (2090) 1A	Winterize stadium	12/17/13			Plumbing
Central Sr (2090) 1A	Reroute roof drain threw locker room	12/5/13			Plumbing

Central Sr (2090) 1A	sink in football lockerroom will not stop running	11/5/13			Plumbing
Central Sr (2090) 1A	replace prv on chill water system rated to maintain 25-28 psi and add gauge	10/23/13			Plumbing
Central Sr (2090) 1A	FOUNTAIN IS RUNNING CAN'T CONTROL 2ND FLR & FLR DRAIN IS BACKING UP IN CAFE PLANT MGR- WILLIAMS/416-4500	5/1/14			Plumbing
Central Sr (2090) 1A	toilet stopped up girls restroom d building	5/9/14			Plumbing
Central Sr (2090) 1A	fauet not working 2nd floor girl restroom	5/9/14			Plumbing
Central Sr (2090) 1A	mopped sink 2nd floor stopped	5/9/14			Plumbing
Central Sr (2090) 1A	sink off wall 1st floor hallway	5/9/14			Plumbing
Central Sr (2090) 1A	toilet stopped up girls restroom 3rd floor	5/19/14			Plumbing

Central Sr (2090) 1A	faucet is leaking girls restroom 2nd floor	5/19/14			Plumbing
Central Sr (2090) 1A	ROOF DRAIN IS LEAKING WATER 2ND FLR BY ELEVATOR (TECH IS ALREADY ON SITE). PLANT MGR- WILLIAMS/416.4500	5/29/14			Plumbing
Central Sr (2090) 1A	urinal stopped up boys restroom by cafe	11/6/13			Plumbing
Central Sr (2090) 1A	replace faucet sink boys lockroom	11/6/13			Plumbing
Central Sr (2090) 1A	d building teacher toilet when flushed water comes from botton	3/7/14			Plumbing
Central Sr (2090) 1A	urinal d building water runs from wall boys restroom	3/7/14			Plumbing
Central Sr (2090) 1A	sink girls restroom coming off wall 1st floor	3/7/14			Plumbing
Central Sr (2090) 1A	sink leaking from bottom in girls restroom	6/9/14	Gym		Plumbing

Central Sr (2090) 1A	a/c leak in room 206	6/9/14	Classroom		Plumbing
Central Sr (2090) 1A	drinking fountain is leaking beside main office	6/9/14	Hallway/Corridor		Plumbing
Central Sr (2090) 1A	drinking fountain leaking	12/20/13	Hallway/Corridor	2nd floor main	Plumbing
Central Sr (2090) 1A	mop sink not draining	1/17/14	Custodial Closet	by cafeteria	Plumbing
Central Sr (2090) 1A	mop sink is stopped up on second floor	6/9/14	Custodial Closet		Plumbing
Central Sr (2090) 1A	1st sink in restroom is leaking water out of faucet and drain is leaking.	6/9/14	Restroom (Girls)		Plumbing
Central Sr (2090) 1A	toilet stopped up	1/8/14	Restroom (Girls)	3rd floor	Plumbing
Central Sr (2090) 1A	urinal stopped up	1/8/14	Restroom (Boys)	d building 1st floor	Plumbing

Central Sr (2090) 1A	toilet stopped up	12/20/13	Restroom (Boys)	3rd floor	Plumbing
Central Sr (2090) 1A	urinal leaking and drain slow	1/17/14	Restroom (Boys)	pe locker room	Plumbing
Central Sr (2090) 1A	toilet and 2 urinals stopped up c bldg	6/9/14	Restroom (Boys)		Plumbing
Central Sr (2090) 1A	a/c leaking in hallway in front of band room	6/9/14	1st Floor		Plumbing
Central Sr (2090) 1A	flush valve does not work	1/8/14	1st Floor	d building boys	Plumbing
Central Sr (2090) 1A	toilet continuously flushes	12/20/13	1st Floor	d building boys	Plumbing
Central Sr (2090) 1A	toilet leaking badly when flushed	12/20/13	1st Floor	d building girls	Plumbing
Central Sr (2090) 1A	mop sink dripping and drain slow	3/19/14	2nd Floor	custodial closet	Plumbing

Central Sr (2090) 1A	toilet leaking 3rd floor girls restroom	6/9/14	3rd Floor		Plumbing
Central Sr (2090) 1A	two toilets stopped up	3/19/14	3rd Floor	boys restroom	Plumbing
Central Sr (2090) 1A	roof leaking second by room 200 see plant mgr	2/3/14			Roof
Central Sr (2090) 1A	room a07 leaking in closet	2/4/14			Roof
Central Sr (2090) 1A	(3) leaks in gym roof	2/5/14			Roof
Central Sr (2090) 1A	roof leaking in bandroom	2/5/14			Roof
Central Sr (2090) 1A	d building roof leaks aii classroom snd floor 3rd request	4/4/14			Roof
Central Sr (2090) 1A	roof leaking room a07 in closet 2nd request	4/4/14			Roof

Central Sr (2090) 1A	roof drain stop up see plant mgr	4/4/14			Roof
Central Sr (2090) 1A	roof leaking room d109	1/14/14			Roof
Central Sr (2090) 1A	roof leaking main lobby linden side room (307)	7/23/13			Roof
Central Sr (2090) 1A	Repair leak in roof on basement floor across from Plant Manager office	4/7/14	Custodial		Roof
Central Sr (2090) 1A	d building roof leaking west side	5/14/14			Roof
Central Sr (2090) 1A	repair (36) broken locker 3rd floor	4/29/14			Sheet Metal
Central Sr (2090) 1A	25 broken lockers 2nd floor	4/29/14			Sheet Metal
Central Sr (2090) 1A	locker #1057 need repair	1/28/14			Sheet Metal

Central Sr (2090) 1A	wheels or broken on let out bleacher in gym	11/21/13			Sheet Metal
Central Sr (2090) 1A	locker #789 is coming apart	1/16/14			Sheet Metal
Central Sr (2090) 1A	remove thumb lock from pe girls locker door	1/16/14			Sheet Metal
Central Sr (2090) 1A	need filter rack installed	2/4/14			Sheet Metal
Central Sr (2090) 1A	15 lockers need repair (A1) hallway	2/12/14			Sheet Metal
Central Sr (2090) 1A	repair (5) broken seat in gym	2/13/14			Sheet Metal

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Charjean ES (2095) 1A	1	1	32	63	26	4	29	4	4	164
Grand Total	1	1	32	63	26	4	29	4	4	164

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Charjean ES (2095) 1A	Water leaking from pipe in ceiling.	8/22/13	Hallway/Corridor	North hallway	Asbestos
Charjean ES (2095) 1A	Network cable ends missing in Rms. 10&11. (Request Network Cabling Maintenance Repair).	7/24/13	Classroom	Rm10&Rm11	Cabling
Charjean ES (2095) 1A	Broken floor tile in portables# 42 & #187.	2/6/14	Portables	West of school Portables #42& #187	Carpentry
Charjean ES (2095) 1A	At the front entrance, rotten floor and loose floor tile	2/20/14	Portables	East of school # 45	Carpentry
Charjean ES (2095) 1A	Stall # 3 loose stall door and long screws in hinge, possible puncture from screws.	2/25/14	Restroom (Boys)	East hallway south	Carpentry
Charjean ES (2095) 1A	Please install Men restroom sign in front of restroom.	2/25/14	Hallway/Corridor	East hallway south	Carpentry
Charjean ES (2095) 1A	Loose hand rails	3/19/14	Portables	East of school # 45	Carpentry

Charjean ES (2095) 1A	Gate needs to be lower to prevent dogs from crawling under the fence.	3/19/14	Grounds	East of cafe.	Carpentry
Charjean ES (2095) 1A	Loose hand rails	3/19/14	Portables	East of school # 42	Carpentry
Charjean ES (2095) 1A	Door speed too fast and slams the door.	3/19/14	Mechanical Room	South of cafe.	Carpentry
Charjean ES (2095) 1A	Top of fence section has a loose pole.	3/19/14	Grounds	North of cafe.	Carpentry
Charjean ES (2095) 1A	A large person size hole in fence. Section looks as if it was cut out with a bolt cutters.	4/3/14	Grounds	Northeast section	Carpentry
Charjean ES (2095) 1A	Please secure window screen @ boys restroom.	4/4/14	Restroom (Boys)	North of cafe.	Carpentry
Charjean ES (2095) 1A	Please repair torn window screen.	4/4/14	Grounds	Northeast of bldg	Carpentry
Charjean ES (2095) 1A	Broken floor tile in front of ventilator unit.	4/11/14	Classroom	East hallway south	Carpentry

Charjean ES (2095) 1A	Water comes thru front door,when it rains	4/29/14	Portables	East of school # 45	Carpentry
Charjean ES (2095) 1A	large hole in fence, behind the play ground.	5/12/14	Grounds	Northeast section	Carpentry
Charjean ES (2095) 1A	Please replace soiled ceiling tile. Special cut.	5/15/14	Hallway/Corridor	Northwest hallway	Carpentry
Charjean ES (2095) 1A	Please install 3 white boards in classroom #7.	7/25/13	Classroom	Rm#7	Carpentry
Charjean ES (2095) 1A	Soiled ceiling tile,needs special cut.	7/31/13	Hallway/Corridor	Hallway north @ clock	Carpentry
Charjean ES (2095) 1A	please install a white board into Rm17.	8/2/13	Classroom	Rm 17	Carpentry
Charjean ES (2095) 1A	Please install a map in clasroom and secure loose white board.	8/22/13	Classroom	Rm19	Carpentry
Charjean ES (2095) 1A	Please install something to prevent dogs from entering the grounds under the gate @ east fence section.	9/16/13	Grounds	Fence east of school	Carpentry

Charjean ES (2095) 1A	Loose bulletin board in hallway.	11/13/13	Hallway/Corridor	Next to teacher lounge	Carpentry
Charjean ES (2095) 1A	Please send 2 pack of ceiling tile.	11/13/13	Classroom	all classroom	Carpentry
Charjean ES (2095) 1A	loose floor tiles in front of ventilator #108-105 in library.	1/6/14	Library	north hallway	Carpentry
Charjean ES (2095) 1A	Loose floor tile in front of ventilator unit 108-135.	1/7/14	Cafetorium	North of kitchen	Carpentry
Charjean ES (2095) 1A	Loose floor tile in front of ventelator unit in library south.	1/9/14	Library	Main hallway north	Carpentry
Charjean ES (2095) 1A	Loose floor tile in front of ventelator unit.	1/9/14	Classroom	West hallway Rm32	Carpentry
Charjean ES (2095) 1A	Soiled ceiling tile, special cut	1/14/14	Hallway/Corridor	Northwest hallway	Carpentry
Charjean ES (2095) 1A	Please secure loose screen on window.	1/17/14	Grounds	North of building	Carpentry

Charjean ES (2095) 1A	Check gutters on north side of building.	1/17/14	Grounds	North of building	Carpentry
Charjean ES (2095) 1A	Broken door knob in teacher lounge.	1/23/14	1st Floor	West of cafe	Carpentry
Charjean ES (2095) 1A	Loose floor tile in front of ventilator in classroom.	1/24/14	Classroom	Rm12	Carpentry
Charjean ES (2095) 1A	per mr green 416-2454 rooms 31 heat not coming on at all	1/30/14			Electrical
Charjean ES (2095) 1A	Clock will not keep proper time.	1/31/14	Classroom	West hallway Rm7	Electrical
Charjean ES (2095) 1A	The POWER IS OUT in the COMPUTER OUTLETS THROUGHOUT BUILDING per James Green, Plant Mgr. 416.2454	2/4/14			Electrical
Charjean ES (2095) 1A	Emergency exit light bad when tested.	2/6/14	Hallway/Corridor	Southeast hallway exit	Electrical
Charjean ES (2095) 1A	Bad ballast in cafe.	2/18/14	Cafetorium	South of stage	Electrical

Charjean ES (2095) 1A	Bad light switch, hard to turn on and off.	2/20/14	Hallway/Corridor	Across from Rm 14	Electrical
Charjean ES (2095) 1A	Please set clocks for day light saving time.	2/24/14	Administration Area	Office	Electrical
Charjean ES (2095) 1A	Exhaust fan making a humming noise.	2/24/14	Classroom	Rm #1	Electrical
Charjean ES (2095) 1A	Bad ballast.	2/28/14	Cafetorium	Right of stage	Electrical
Charjean ES (2095) 1A	POWER OUTAGE THRU ENTIRE BLDG. SBE-GREEN/314-8386	7/23/13			Electrical
Charjean ES (2095) 1A	Clocks needs to be reset after power outage.	7/23/13	Administration Area	Office	Electrical
Charjean ES (2095) 1A	UNIT IN RM 7 IS NOT COMING ON. SBE GREEN 416-2454	7/24/13			Electrical
Charjean ES (2095) 1A	Bad ballast @ the right of stage.	4/10/14	Cafetorium	North of cafe.	Electrical

Charjean ES (2095) 1A	Check ballasts in portable,change to T8s.	4/21/14	Portables	East of school # 45	Electrical
Charjean ES (2095) 1A	Check ballasts in portable,change to T8s.	4/21/14	Portables	East of school # 42	Electrical
Charjean ES (2095) 1A	Check ballasts in portable,change to T8s.	4/21/14	Portables	East of school #187	Electrical
Charjean ES (2095) 1A	A/C RM 9-NOT COOLING-PLANT MGR GREENE 416-2454 KLR	5/5/14			Electrical
Charjean ES (2095) 1A	UNIT VENT - CAFE SWITCH IS BROKEN - CAN'T TURN ON - PM/GREENE 416-2454	5/9/14			Electrical
Charjean ES (2095) 1A	per mr green 416-2454 room 31 a/c not coming on	5/12/14			Electrical
Charjean ES (2095) 1A	Clock bad will not keep proper time.	7/31/13	Hallway/Corridor	East hallway	Electrical
Charjean ES (2095) 1A	Bad clock will not keep proper time.	7/31/13	Kitchen	Serving line	Electrical

Charjean ES (2095) 1A	Bad clock, will not keep proper time.	7/31/13	Hallway/Corridor	Hallway north	Electrical
Charjean ES (2095) 1A	Bad clock, will not keep proper time.	7/31/13	Library	Main hallway north	Electrical
Charjean ES (2095) 1A	Bad clock, will not keep proper time.	7/31/13	Hallway/Corridor	East hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad.	8/1/13	Hallway/Corridor	South East hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad.	8/1/13	Kitchen	South of cafe	Electrical
Charjean ES (2095) 1A	Emergency exit light bad.	8/1/13	Hallway/Corridor	North East hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad, by girls restroom.	8/1/13	Hallway/Corridor	North east hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad @ the exit door.	8/1/13	Hallway/Corridor	North east hallway	Electrical

Charjean ES (2095) 1A	Emergency exit light bad @ door.	8/1/13	Hallway/Corridor	East hallway south	Electrical
Charjean ES (2095) 1A	Emergency exit light bad @2cd door.	8/1/13	Hallway/Corridor	East hallway south	Electrical
Charjean ES (2095) 1A	School bells not working,low battery indication.	8/7/13	Administration Area	office	Electrical
Charjean ES (2095) 1A	UV-10 RM 1-NOT COMING ON-SBE GREEN 416-2454 KLR	8/12/13			Electrical
Charjean ES (2095) 1A	Pole light is out in the rear of school and light is out in front of school south west.	8/15/13	Grounds	South east of bldg.	Electrical
Charjean ES (2095) 1A	Emergency light bad.	9/3/13	Cafetorium	North of cafe	Electrical
Charjean ES (2095) 1A	IClock bad in classroom.	9/4/13	Classroom	Rm 24	Electrical
Charjean ES (2095) 1A	Bad ballast in front of fire extinguisher	10/18/13	Hallway/Corridor	North hallway	Electrical

Charjean ES (2095) 1A	Bad ballast in hallway in front of room 11.	10/18/13	Hallway/Corridor	West hallway	Electrical
Charjean ES (2095) 1A	boiler in alarm per Mr. Green 416-2454	10/24/13			Electrical
Charjean ES (2095) 1A	pumps in alarm	10/24/13			Electrical
Charjean ES (2095) 1A	Please repair bad light @ door entrance.	10/31/13	1st Floor	Rear entrance door by chiller	Electrical
Charjean ES (2095) 1A	Please repair bad light fixtrue,bad bulb.	10/31/13	Grounds	Southwest of bldg	Electrical
Charjean ES (2095) 1A	Please set clocks for day lite saving time	11/4/13	Administration Area	1st fl office	Electrical
Charjean ES (2095) 1A	Clock will not keep proper time.	11/13/13	Classroom	Rm 28	Electrical
Charjean ES (2095) 1A	Bad emergency Light in boiler room.	12/3/13	Mechanical Room	BOiler Rm	Electrical

Charjean ES (2095) 1A	Emergency light bad west hallway.	12/3/13	Hallway/Corridor	West hallway	Electrical
Charjean ES (2095) 1A	Emergency light bad , west hallway	12/3/13	Hallway/Corridor	West hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad northeast hallway.	12/3/13	Hallway/Corridor	northeast hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad 2ea. @ rear exit door.	12/3/13	Hallway/Corridor	East hallway	Electrical
Charjean ES (2095) 1A	Emergency exit light bad 2ea. @southeast exit door.	12/3/13	Hallway/Corridor	Southeast hallway	Electrical
Charjean ES (2095) 1A	Bad emergency light @ southeast hallway.	12/3/13	Hallway/Corridor	Southeast hallway	Electrical
Charjean ES (2095) 1A	Bad emergency light on stage.	12/3/13	Cafetorium	On stage	Electrical
Charjean ES (2095) 1A	Bad emergency light in hallway. Light flashes on & off.	12/3/13	Hallway/Corridor	West hallway	Electrical

Charjean ES (2095) 1A	HEAT RM 11-NOT COMING ON-PLANT MGR GREEN KLR	1/7/14			Electrical
Charjean ES (2095) 1A	One (1) unit in the CAFETERIA is NOT COMING ON per James Green, Plant Mgr. 416.2454	1/7/14			Electrical
Charjean ES (2095) 1A	Outside lights out @exit doors 5ea. Northeast & Northwest hallway @ exit doors. Westsouth hallway @exit door. Entrance door in courtyard and Southwest hallway @	1/9/14	Grounds	outside @ exit doors	Electrical
Charjean ES (2095) 1A	Clock not running.	1/14/14	Cafetorium	North of kitchen	Electrical
Charjean ES (2095) 1A	UV NOT COMING ON IN LIBRARY PLANT MGR-GREEN/416.5016	1/15/14			Electrical
Charjean ES (2095) 1A	UNIT NOT COMING ON IN RM-31. PLANT MGR-GREEN/416.5016	1/23/14			Electrical
Charjean ES (2095) 1A	Bad clock in classroom, will not keep proper time.	1/24/14	Classroom	Rm 32	Electrical
Charjean ES (2095) 1A	Please send 25 T8 ultramax Eco XL light bulbs.	7/25/13	2nd Floor	North&South hallways	Electrical

Charjean ES (2095) 1A	I need 50 ea T8 ultra max eco light bulbs.	3/19/14	Grounds	Classrooms and hallways	Electrical
Charjean ES (2095) 1A	Please send 50 T8 ultramax ECO XL light bulbs.	10/17/13	Hallway/Corridor	East hallways	Electrical
Charjean ES (2095) 1A	UNIT NOT HEATING IN RM-11 PLANT MGR- GREEN/416.5016	1/28/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	reset ems panel and check boiler	2/4/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	check pump in alarm	2/18/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	UNIT NOT HEATING IN PORT-187 PLANT MGR- GREEN/416.5016	3/5/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	UNIT IN RM 17 & 27 IS NOT COOLING. SBE GREEN 416-2454	7/24/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	per mr green 416-2454 the boiler is showing low water	3/20/14			Heating/Ventilation /Air Conditioning

Charjean ES (2095) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	repair ckt 1 on chiller	4/2/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	Monthly - Oil Lube & Belt-Charjean Elementary - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	CHILLER NOT COMING ON PPLANT MGR-GREEN/416.5016	4/11/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	UNIT VENT - MAIN OFC - BLOWING BUT NOT COOLING - PM/GREENE 416-2454	4/21/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	clean cond. units	4/25/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	Monthly - Filter-Charjean Elementary - Refer to PM schedule details.	4/28/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	CHILLER NOT COMING ON PLANT MGR-GREEN/416.5016	4/28/14			Heating/Ventilation /Air Conditioning

Charjean ES (2095) 1A	A/C MAIN OFC AREA- NOT COOLING- PLANT MGR GREEN 416-2454 KLR	5/7/14			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	chiller down	7/26/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	UNIT NOT COOLING IN PORT-45. PLANT MGR- GREEN/416.5016	7/30/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	chiller down	8/19/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	Monthly - Oil Lube & Belt-Charjean Elementary - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	Monthly - Filter- Charjean Elementary - Refer to PM schedule details.	9/2/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	A/C RM 25-NOT COOLING-PLANT MGR GREEN 416- 5016 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning

Charjean ES (2095) 1A	HEAT MAIN OFC AREA-NOT HEATING- PLANT MGR GREEN 416-2454 KLR	10/28/13				Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	Monthly - Filter- Charjean Elementary - Refer to PM schedule details.	12/30/13				Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	One (1) unit in the CAFETERIA and in Room 32 is NOT HEATING per James Green, Plant Mgr. 416.2454	1/7/14				Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	UV NOT HEATING IN LIBRARY PLANT MGR- GREEN/416.5016	1/15/14				Heating/Ventilation /Air Conditioning
Charjean ES (2095) 1A	Paint peeling off walls,restroom needs painting.	1/24/14	Restroom (Boys)	North of cafe		Painting
Charjean ES (2095) 1A	Please remove graffiti from door.	3/17/14	Portables	East of cafe.		Painting
Charjean ES (2095) 1A	Paint peeling off wall in restroom.	12/11/13	Restroom (Girls)	Northeast hallway		Painting
Charjean ES (2095) 1A	GRAFFITI ON PLAYGROUND PLANT MGR- GREEN/416.5016	1/16/14				Painting

Charjean ES (2095) 1A	WATER is LEAKING from SPRINKLER PIPE in the ATTIC per James Green, Plant Mgr. 416.2454	2/4/14				Plumbing
Charjean ES (2095) 1A	Repair pump	2/5/14				Plumbing
Charjean ES (2095) 1A	ICE MAKER LINE IS LEAKING IN KITCHEN. PLANT MGR- GREEN/416.5016	2/11/14				Plumbing
Charjean ES (2095) 1A	Pull pump	2/19/14				Plumbing
Charjean ES (2095) 1A	Sink in restroom drains very slow.	2/19/14	Restroom (Girls)	kitchen		Plumbing
Charjean ES (2095) 1A	Leaky flush valve stall # 1.	2/20/14	Restroom (Girls)	Northeast hallway		Plumbing
Charjean ES (2095) 1A	Loose wash sink in kitchen.	2/24/14	Kitchen	East wall of kitchen		Plumbing
Charjean ES (2095) 1A	Toilet in restroom will not flush properly.	2/25/14	Kitchen	Restroom		Plumbing

Charjean ES (2095) 1A	Toilet in restroom is loose @ the floor.	2/25/14	Kitchen	Restroom	Plumbing
Charjean ES (2095) 1A	GAS SMELL ON THE OUTSIDE OF SCHOOL FRONT OF BLDG WEST SIDE- PLANT MGR GREEN 416-2454 KLR	5/22/14			Plumbing
Charjean ES (2095) 1A	Urinal leaking from bottom when flushed.	7/31/13	Restroom (Boys)	East hallway	Plumbing
Charjean ES (2095) 1A	Water leaking from pipe in ceiling.	8/14/13	Hallway/Corridor	North hallway	Plumbing
Charjean ES (2095) 1A	Water leak on hot water tank. Need plumber Friday morning. No hot water.	8/15/13			Plumbing
Charjean ES (2095) 1A	hand washing sink only has two faucets working.	8/20/13	Hallway/Corridor	south hallway	Plumbing
Charjean ES (2095) 1A	Urinal leaking on floor when flush. Stall #5	9/3/13	Restroom (Boys)	North of cafe.	Plumbing
Charjean ES (2095) 1A	Toilet will not flush properly. Tried the hand held snake twice but still bad.	9/4/13	Restroom (Girls)	South of cafe	Plumbing

Charjean ES (2095) 1A	2-COMPARTMENT SINK KITCHEN-LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF-PLANT MGR GREEN 416-5016 KLR	9/12/13				Plumbing
Charjean ES (2095) 1A	GARBAGE DISPOSAL IS BACKING UP IN KITCHEN PLANT MGR-GREEN/416.5006	9/17/13				Plumbing
Charjean ES (2095) 1A	2-COM SINK IS STOPPED UP IN KITCHEN. PLANT MGR-GREEN/416.5016	9/24/13				Plumbing
Charjean ES (2095) 1A	Water is leaking from the bottom of the handwashing sink on the Southeast Hallway by the Boy's and Girl's RR per Mr. James Green, Plant Mgr. 416.5054	9/25/13				Plumbing
Charjean ES (2095) 1A	PILOT NEEDS TO BE LIT KITCHEN PLANT MGR-GREEN/416.5006	9/26/13				Plumbing
Charjean ES (2095) 1A	Urinal in boys restroom will not drain properly.	10/2/13	Restroom (Boys)	north of cafe		Plumbing
Charjean ES (2095) 1A	Flush valve leaking @ urinal in boys restroom.	10/3/13	Restroom (Boys)	North of cafe.		Plumbing
Charjean ES (2095) 1A	Toilets will not flush properly in stalls #1 and in the handicap stall	10/29/13	Restroom (Girls)	South of boiler		Plumbing

Charjean ES (2095) 1A	Loose toilet in stall #4	11/13/13	Restroom (Boys)	South hallway	Plumbing
Charjean ES (2095) 1A	Urinal will not drain after flushing.	11/19/13	Restroom (Boys)	East hallway	Plumbing
Charjean ES (2095) 1A	DISHWASHER KITCHEN AREA- BACKING UP WATER- PLANT MGR GREEN 416-2454 KLR	11/22/13			Plumbing
Charjean ES (2095) 1A	Test and report on backflow prevention devices.	12/19/13			Plumbing
Charjean ES (2095) 1A	Test and report on backflow prevention devices.	1/21/14			Plumbing
Charjean ES (2095) 1A	Water leaking from ceiling.	2/5/14	Hallway/Corridor	Northwest hallway	Roof
Charjean ES (2095) 1A	Water leaking from ceiling into light fixture in kitchen.	7/23/13	Kitchen	South of cafe	Roof
Charjean ES (2095) 1A	Water leaking from ceiling	5/15/14	Hallway/Corridor	West hallway across from cafe	Roof

Charjean ES (2095) 1A	Water leaking from ceiling in library.	9/25/13	Library	South of office	Roof
Charjean ES (2095) 1A	Locker in classroom needs repair.	5/14/14	Classroom	East hallway Rm27	Sheet Metal
Charjean ES (2095) 1A	Broken locker in classroom.	1/23/14	Classroom	East hallway Rm27	Sheet Metal
Charjean ES (2095) 1A	Broken locker in hallway.	1/23/14	Hallway/Corridor	South of cafe	Sheet Metal
Charjean ES (2095) 1A	Please replace the locks on a file cabinet. 2 draws & 3 draws.	8/15/13	Administration Area	office	Sheet Metal

Count of Craft	Craft				
Location	Carpentry	Electrical	HVAC	Plumbing	Grand Total
City University/Dunn El (8204) 1A	5	7	11	8	31
Grand Total	5	7	11	8	31

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
City University/Dunn EI (8204) 1A	Repair fence at rear of school. To prevent people from entering school property.	10/23/13			Carpentry
City University/Dunn EI (8204) 1A	Acquire and Install barrel bolts (inside) to all outside doors. Including common zone master locks.	11/15/13	1st Floor		Carpentry
City University/Dunn EI (8204) 1A	Main front entrance door security screens repalce missing vandal proof screws.	2/19/14	1st Floor		Carpentry
City University/Dunn EI (8204) 1A	Remove exsiting (outside) basketball hoops.	2/20/14	Grounds		Carpentry
City University/Dunn EI (8204) 1A	Repair windows in the back.	3/21/14	1st Floor		Carpentry
City University/Dunn EI (8204) 1A	Check fire alarm. Activated last night on water flow. Cannot shut off.	8/15/13			Electrical
City University/Dunn EI (8204) 1A	Check/Re set electrical panel, power out car hit pole in front of building. MLGW has completed their work.	8/15/13			Electrical
City University/Dunn EI (8204) 1A	Check main building for power. To suport HVAC.	11/8/13			Electrical
City University/Dunn EI (8204) 1A	Check/repair boiler pump motor.	11/13/13			Electrical

City University/Dunn EI (8204) 1A	Check/repair fire alarm.	11/13/13			Electrical
City University/Dunn EI (8204) 1A	P-5 not coming on	11/13/13			Electrical
City University/Dunn EI (8204) 1A	panel in alarm, possible sprinkler system (Lasco) if so contact Albert Herman.	2/20/14	Administration Area		Electrical
City University/Dunn EI (8204) 1A	Three rooms will not cool...101, 103, 120. There was a power outage and all other rooms came back up except for these three.	8/12/13			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Monthly - Filter-City University (Dunn Elementary) - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	c/o to heat	11/6/13			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Drain and winterize heating and cooling systems	2/18/14			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Put on blanks on gas	4/2/14			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Monthly - Filter-City University (Dunn Elementary) - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Monthly - Oil Lube & Belt-City University(Dunn EI) - Refer to PM schedule details.	4/8/14			Heating/Ventilation /Air Conditioning

City University/Dunn EI (8204) 1A	Monthly - Filter-City University (Dunn Elementary) - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Monthly - Oil Lube & Belt-City University(Dunn EI) - Refer to PM schedule details.	9/10/13			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Yearly - Fire Boilers 039 - City University - Refer to PM schedule details.	3/9/14			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Yearly - Fire Boilers 077 - City University - Refer to PM schedule details.	3/9/14			Heating/Ventilation /Air Conditioning
City University/Dunn EI (8204) 1A	Floor drain backing up.	8/13/13			Plumbing
City University/Dunn EI (8204) 1A	GAS SMELL THRU ENTIRE BLDG COOR-TOM PALMERTREE/626.4300	8/15/13			Plumbing
City University/Dunn EI (8204) 1A	Water leak rooms 123 and 124. Clean drain on HVAC units.	8/22/13			Plumbing
City University/Dunn EI (8204) 1A	Unstop sewer	8/26/13			Plumbing
City University/Dunn EI (8204) 1A	secure the building since it is unoccupied - fix the parking lot fence - repair and secure parking lot gates - stop all PM activity - keep enough heat on the building to prevent freezing	10/24/13			Plumbing
City University/Dunn EI (8204) 1A	Meet with MLGW Monday Nov 11 to turn on gas and water to school. Electric has been restored. (need keys) MLGW will call with time of day.	11/8/13			Plumbing

City University/Dunn EI (8204) 1A	Drain mechanical and plumbing systems and winterize building. HVAC to support -Tony.	2/14/14			Plumbing
City University/Dunn EI (8204) 1A	Cap water lines at water meter	4/14/14			Plumbing

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Craigmont MS (2128) 1B	2	2	23	70	40	6	29	1	1	174
Grand Total	2	2	23	70	40	6	29	1	1	174

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Craigmont MS (2128) 1B	Reinsulate exposed interior roof drains , after Oct. 31st. being repair by plumber, and lift is on site.	10/31/13	Hallway/Corridor		Asbestos
Craigmont MS (2128) 1B	Insulate 2 1/2" copper water line repaired by plumbers.	11/1/13	Gym		Asbestos
Craigmont MS (2128) 1B	requesting that the security cameras be made accessible from the security officers computer.	9/6/13	1st Floor	security office	Cabling
Craigmont MS (2128) 1B	Data Jack gone bad	9/6/13	2nd Floor	S215	Cabling
Craigmont MS (2128) 1B	the screws that hold up the marquee has come off the bars, it fall while trying to change the sign, unsafe	10/18/13	Grounds	marquee	Carpentry
Craigmont MS (2128) 1B	The carpet in the front entry needs replacing, cannot be cleaned, its a public eyesore, its damaged, and has embebbed gum.	7/18/13	1st Floor	main entry	Carpentry
Craigmont MS (2128) 1B	The doors at the main entry needs to be repaired, they have made it intercom accessable, but two of the doors wont close properly, this is a safety issue.	8/23/13	1st Floor	main entrance	Carpentry

Craigmont MS (2128) 1B	install card swipe hardware on main entrance door(far left)	8/20/13				Carpentry
Craigmont MS (2128) 1B	teacher is requesting that the screen be moved so that she can use the overhead projector for her class	12/2/13	2nd Floor	S216		Carpentry
Craigmont MS (2128) 1B	This door entering the music hall seem to be hanging a bit, its rubbing against the other door.	12/12/13	1st Floor	music suites lower level		Carpentry
Craigmont MS (2128) 1B	choir door makes loud sound when trying to open or close	12/12/13	1st Floor	music suites		Carpentry
Craigmont MS (2128) 1B	The screws have stripped on the inside of the door, leaving the metal part exposed and hanging.	12/13/13	1st Floor	S109		Carpentry
Craigmont MS (2128) 1B	3 broken bleacher seats, dangerous for setting down	10/24/13	Gym	lower level left of hall		Carpentry
Craigmont MS (2128) 1B	back door in the gym wont lock properly	10/28/13	Gym	lower level		Carpentry
Craigmont MS (2128) 1B	needing sheet rock replaced after repairing a leak, two holes in the wall	11/5/13	Gym	lower level		Carpentry

Craigmont MS (2128) 1B	door to the supply room for the gym equipment is broken, wont secure.	11/7/13	Gym	lower level	Carpentry
Craigmont MS (2128) 1B	requesting a picture to be hung in the middle school coordinator's office.	1/28/14	Administration Area	main entrance	Carpentry
Craigmont MS (2128) 1B	door will not lock, high traffic area needs to be locked at all times	1/21/14	1st Floor	girls restroom near auditorium	Carpentry
Craigmont MS (2128) 1B	DOOR - FRONT ENTRANCE & SO. EXIT DR - BOTH LATCHES WON'T LOCK - CAN'T SECURE - PM/EVANS 416-9925	9/11/13			Carpentry
Craigmont MS (2128) 1B	Requesting a dry erase board for classroom	3/7/14	2nd Floor	S209	Carpentry
Craigmont MS (2128) 1B	per ms evans 416-7780 exit door in music suite the panic bar on exit door is broken and can't secure building	3/20/14			Carpentry
Craigmont MS (2128) 1B	lock is twisting around, cant lock, and its a must that this door be locked during the day.	2/21/14	1st Floor	boys restroom	Carpentry
Craigmont MS (2128) 1B	Leak on second floor, coming through ceiling on the first floor. Remove ceiling tile before it falls.	4/7/14			Carpentry

Craigmont MS (2128) 1B	DOOR - EXIT ON THE SOUTH SIDE OF BLDG - WON'T LOCK CAN'T SECURE- PM/EVANS 416-9925	4/21/14			Carpentry
Craigmont MS (2128) 1B	one of the benches in the boys locker room has been completely broken off, and the metal is exposed, very dangerous	4/24/14	Gym	lower level	Carpentry
Craigmont MS (2128) 1B	lock on the back door in the gym does not work	5/7/14	Gym	lower level	Carpentry
Craigmont MS (2128) 1B	screws have come out of the door	5/21/14	1st Floor	N127	Carpentry
Craigmont MS (2128) 1B	Replace Vfd	7/17/13			Electrical
Craigmont MS (2128) 1B	We have 10 light fixtures out. I have changed the bulbs. (BAD BALLAST)	7/25/13	Kitchen	serving line	Electrical
Craigmont MS (2128) 1B	Repair or replace gym lights 400w metal halide.	7/25/13	Gym		Electrical
Craigmont MS (2128) 1B	Repair and replace floor lamps as needed.	7/25/13	Cafeteria		Electrical

Craigmont MS (2128) 1B	Repair and replace push handles on drink fountains check entire bldg.	7/25/13			Electrical
Craigmont MS (2128) 1B	ballast bad in front of classroom	8/29/13	2nd Floor	N222	Electrical
Craigmont MS (2128) 1B	Ballast out at the end of the hall.	9/6/13	2nd Floor	north end of hall	Electrical
Craigmont MS (2128) 1B	Ballast blown out in both lamps in this closet.	9/6/13	1st Floor	South end electrical closet	Electrical
Craigmont MS (2128) 1B	Only one lamp lighting up, two bad ballists, restroom dark	8/1/13	1st Floor	North end girls restroom	Electrical
Craigmont MS (2128) 1B	UV NOT COMING ON IN RM-S127(107) . PLANT MGR-EVANS/416.7780	8/8/13			Electrical
Craigmont MS (2128) 1B	Unit Ventilator NOT COMING ON in Rm N220 per Ms. Evans, Plant Mgr at 901.416.9925.	8/20/13			Electrical
Craigmont MS (2128) 1B	ballast out	8/20/13	2nd Floor	S215	Electrical

Craigmont MS (2128) 1B	Emergency lights fixture not working	8/20/13	1st Floor	N117	Electrical
Craigmont MS (2128) 1B	ballist blown	8/20/13	Hallway/Corridor	elevator	Electrical
Craigmont MS (2128) 1B	UV NOT COMING ON IN RM-218, & UNIT IN RM-N205M PLANT MGR-EVANS/416.7780	8/20/13			Electrical
Craigmont MS (2128) 1B	HEAT RMS N124 & N127- BOTH NOT HEATING-PLANT MGR EVANS 416-9925 KLR	11/25/13			Electrical
Craigmont MS (2128) 1B	3 fixtures with bad ballasts in them.	11/26/13	1st Floor	N129	Electrical
Craigmont MS (2128) 1B	10 lights are blown out in this classroom	11/26/13	1st Floor	N127	Electrical
Craigmont MS (2128) 1B	changed bulbs and ballast is bad in two fixtures on this hall, becoming dark	12/3/13	Hallway/Corridor	2nd floor north hall	Electrical
Craigmont MS (2128) 1B	bad ballasts	12/3/13	1st Floor	band practice room	Electrical

Craigmont MS (2128) 1B	north end of hall stairwell, can lights blown out	12/4/13	2nd Floor	2nd floor stairwell	Electrical
Craigmont MS (2128) 1B	SBE/Plant Manager requesting lamps to replace blown out ones.	12/4/13	Mechanical Room	requesting lamps	Electrical
Craigmont MS (2128) 1B	per Ms. Evans 416-7780 AH#1 and the cafeteria units not coming on at all no heat	12/9/13			Electrical
Craigmont MS (2128) 1B	There are 4 bad ballasts in this classroom	12/9/13	2nd Floor	S216	Electrical
Craigmont MS (2128) 1B	There are 3 bad ballasts	12/9/13	2nd Floor	S218	Electrical
Craigmont MS (2128) 1B	ballast out in girls restroom	12/10/13	1st Floor	north end girls restroom	Electrical
Craigmont MS (2128) 1B	ballast out	12/10/13	1st Floor	N117	Electrical
Craigmont MS (2128) 1B	ballast out	12/10/13	1st Floor	N119	Electrical

Craigmont MS (2128) 1B	2 ballasts out	12/10/13	1st Floor	N123	Electrical
Craigmont MS (2128) 1B	RTU- IN GYM HAS TRIPPED - VERY COLD IN GYM - PM/EVANS 416-7780	12/10/13			Electrical
Craigmont MS (2128) 1B	requesting lamps to, replace blown ones	12/12/13	Mechanical Room	plant managers office	Electrical
Craigmont MS (2128) 1B	Repair/replace pole lights, check and repair exterior lights on building.	12/18/13	Parking Lot		Electrical
Craigmont MS (2128) 1B	two fixtures side by side have bad ballasts	1/2/14	1st Floor	upon entering the north end	Electrical
Craigmont MS (2128) 1B	requesting more lamps to replace blown out ones	1/3/14	Mechanical Room	lower level	Electrical
Craigmont MS (2128) 1B	there a lot of blown lamps... too high for sbe to change.	1/6/14	Hallway/Corridor	music hall lower level right of bldg.	Electrical
Craigmont MS (2128) 1B	Unit in Room S130 is NOT COMING ON per Ms. Davis, Plant Mgr. 416.7780	1/7/14			Electrical

Craigmont MS (2128) 1B	HEAT RM S227-NOT COMING ON-PLANT MGR EVANS 416-9925 KLR	1/8/14			Electrical
Craigmont MS (2128) 1B	HEAT AUDITORIUM-OVERHEATING, TEMP IS 94 PER SBE-PLANT MGR EVANS 416-9925 KLR	1/8/14			Electrical
Craigmont MS (2128) 1B	requesting lamps to replace the many blown ones	10/22/13	Administration Area	main area	Electrical
Craigmont MS (2128) 1B	SCHOOL BELL NEEDS TO BE RESET PLANT MGR-EVANS/416.7780	11/13/13			Electrical
Craigmont MS (2128) 1B	The emergency lights aren't working in this classroom	11/14/13	1st Floor	N124	Electrical
Craigmont MS (2128) 1B	needing the banner hung on the building for healthy choices week starting next week.	11/15/13	Parking Lot	front, side of building	Electrical
Craigmont MS (2128) 1B	the girls locker room is completely dark in the toilet area, ballast bad	1/22/14	Gym	girls locker room	Electrical
Craigmont MS (2128) 1B	ahu in cafeteria has tripped and there is no a/c working per Ms. Evans 416-9925	9/9/13			Electrical

Craigmont MS (2128) 1B	ballast out in hallway	9/10/13	2nd Floor	south end of hall	Electrical
Craigmont MS (2128) 1B	three electrical outlets dont work, checked the breaker	9/10/13	2nd Floor	S230	Electrical
Craigmont MS (2128) 1B	RTU #1 not coming on.	9/11/13			Electrical
Craigmont MS (2128) 1B	ballast out in one of the offices in the main office.	9/12/13	Administration Area	main office	Electrical
Craigmont MS (2128) 1B	We have a banner that needs to be hung up in the gym	9/16/13	Gym	lower level	Electrical
Craigmont MS (2128) 1B	ballast bad, causing entry way to be very dark	9/25/13	Hallway/Corridor	south end entry way	Electrical
Craigmont MS (2128) 1B	several lights have blown in the hallway that plant manager cant reach	2/3/14	Hallway/Corridor	music hall	Electrical
Craigmont MS (2128) 1B	this classroom has at least 5 fixtures with bad ballasts	2/3/14	1st Floor	S109	Electrical

Craigmont MS (2128) 1B	lights blown, too high for plant manager to replace	2/3/14	Mechanical Room	boiler room	Electrical
Craigmont MS (2128) 1B	there are 4 lights blown out, requires a lift	3/19/14	Gym	lower level	Electrical
Craigmont MS (2128) 1B	3 lights blown out in the hallway, becoming dark	3/19/14	1st Floor	lower level	Electrical
Craigmont MS (2128) 1B	all lights have blown out, too high for the 6ft. ladder to reach	2/18/14	Mechanical Room	entering boiler room	Electrical
Craigmont MS (2128) 1B	many lights out in the stage, plant manager cant reach	2/21/14	Auditorium	lower level	Electrical
Craigmont MS (2128) 1B	The master clock in the office needs to be reset for daylight savings.	2/27/14	Administration Area	main entry	Electrical
Craigmont MS (2128) 1B	bad ballast in the mechanical room	3/26/14	Mechanical Room	north hall first floor	Electrical
Craigmont MS (2128) 1B	Followup to check electrical equipement, there was a power outage over the weekend.	4/1/14			Electrical

Craigmont MS (2128) 1B	Due to a power outage, our clocks need to be reset.	4/3/14	Administration Area	main office	Electrical
Craigmont MS (2128) 1B	3 hall lights have blown out and these lights have to be replaced with a lift	4/3/14	Hallway/Corridor	lower level	Electrical
Craigmont MS (2128) 1B	We have 2 emergence lights not working ,it may be the batteries.	4/10/14	1st Floor	main office	Electrical
Craigmont MS (2128) 1B	Emergency light not working,It need to be repaired.	4/11/14	1st Floor	hall next room 127	Electrical
Craigmont MS (2128) 1B	EXPOSE WIRES IN GYM B/LOCKER RM. PLANT MGR-EVANS/416.7780	4/24/14			Electrical
Craigmont MS (2128) 1B	per ms evans 416-9925 the AHU #1 that controls cafeteria and auditorium is not running	5/7/14			Electrical
Craigmont MS (2128) 1B	AHU - AUD - NOT COMING ON - HAVING MOVIE DAY IN THERE - PM/EVANS 416-7780	5/8/14			Electrical
Craigmont MS (2128) 1B	RTU AUDITORIUM AREA-NEEDS RESETTING, NOT COMING ON-THEY ARE HAVING GRADUATION TOMORROW-PLANT MGR EVANS 416-9925 KLR	5/19/14			Electrical

Craigmont MS (2128) 1B	Air Handler Units NOT COMING ON per Ms. Evans, Plant Mgr. 901.416.9925 (Unit #3 in Gym, ID#102.033 and Unit #1 in Cafeteria, ID#102-041).	7/10/13			Electrical
Craigmont MS (2128) 1B	tried to replace lamps, bad ballast	8/22/13	Administration Area	nurses station	Electrical
Craigmont MS (2128) 1B	UNIT IN THE GYM IS NOT COMING ON,. SBE EVANS 416-9925	7/19/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	AHU#5 NOT COOLING IN MAIN OFFICE & CHILLER NOT COMING ON. FIN SEC-HINES/416-7780	7/23/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	2-UV ARE NOT COOLING IN RM-N22, 227 PLANT MGR-EVANS/416.7780	8/23/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	UNIT IN RM S211 IS NOT COOLING. SBE EVANS 416-9925	7/31/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	AHU #1 NOT COOLING IN CAFE(041). PLANT MGR-EVANS/416.7780	8/12/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	AHU #5, N220, N222, Coaches office in gym all are not cooling per Evans 416-9925	8/13/13			Heating/Ventilation /Air Conditioning

Craigmont MS (2128) 1B	main office and room 115 cold per Ms. Evans 416-9925 heat not working	11/25/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Rooms S209 and S213 overheating (99 degrees) per Ms. Evans 416-7780	12/9/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	UNIT VENT - RM 124 & 127 - BLOWING COLD AIR - PM/EVANS 416-7780	12/10/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	per Ms. Evans 416-7780 in the gym it is 61 degrees and blowing cold air - per EM damper needs to be reset and there is a game in there TONIGHT	12/16/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	RTU NOT HEATING IN GYM PLANR MGR-EVANS/416-7780	12/17/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	AHU#2 HAS TRIPPED IN AUDIT (HAVING PROGRAM TODAY) PLANT MGR-EVANS/416.4312	12/17/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	AHU IS OVERHEATING (75)IN MAIN OFFICE. PLANT MGR-EVANS/438.7765	10/22/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	CHILLER-2-IS IN ALARM- PLANT MGR EVANS 416-9925 KLR	10/29/13			Heating/Ventilation /Air Conditioning

Craigmont MS (2128) 1B	UV NOT HEATING IN RM-N115 PLANT MGR-EVANS/416.7780	11/13/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	HEAT GYM AREA-NOT HEATING-PLANT MGR EVANS 416-7780 KLR	1/24/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	been having a lot of condensation problems, time for filters to be changed.	9/12/13	Administration Area	entire building	Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Monthly - Oil Lube & Belt- Craigmont Middle - Refer to PM schedule details.	10/15/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	per ms evans 416-7780 room N119 is overheating	2/4/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	HEAT GYM AREA-NOT HEATING-PLANT MGR EVANS 416-9925 KLR	2/5/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	per ms evans 416-7780 both chillers are in alarm	3/20/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	BOILER NOT HEATING ON 2ND FLR NORTH-END LEAD PERSON-TINA/318.0947	2/25/14			Heating/Ventilation /Air Conditioning

Craigmont MS (2128) 1B	supply chemicals	3/31/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	CHILLER-1 MECH RM-IN ALARM-PLANT MGR EVANS 416-7780 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	PUMP-9 MECH RM-IN ALARM- PLANT MGR EVANS 416-7780 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	CHILLER-1 & CHILLER-2- BOTH ARE IN ALARM-PLANT MGR EVANS 416-9925 KLR	4/28/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	per ms evans 416-9925 main office not cooling	5/9/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Monthly - Oil Lube & Belt- Craigmont Middle - Refer to PM schedule details.	5/13/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	UNIT NOT COOLING IN AUDIT (HAVING AN EVENT IN MORNING TOMORROW) PLANT MGR-EVANS/416.7780	5/21/14			Heating/Ventilation /Air Conditioning

Craigmont MS (2128) 1B	CHILLERS - BOTH ARE IN ALARM - PM/EVANS 416-4312	5/23/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	AHU#1 IS TRIPPING IN CAFE (041). SBE-EVANS/416-7780	7/3/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Air Handler Unit #4 NOT COOLING, ID# 102-034 per Ms. Evans at 901.416.9925.	7/10/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Yearly - Oil Samples-Craigmont Middle - Refer to PM schedule details.	9/8/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Monthly - Filter-Craigmont Middle - Refer to PM schedule details.	7/28/13			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Yearly - Cooling Towers-Craigmont Middle - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Monthly - Filter-Craigmont Middle - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Daily - Craigmont Middle Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Craigmont MS (2128) 1B	Monthly - CRAIGMONT MID LVL 2 WATER TREATMENT - Refer to PM schedule details.	1/31/14				Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	Monthly - Filter-Craigmont Middle - Refer to PM schedule details.	11/24/13				Heating/Ventilation /Air Conditioning
Craigmont MS (2128) 1B	toilet upstairs leaked all weekend, resulting in the boys restroom on the first floor having water damage, the paint is peeling off the wall and plaster in falling down on the floor	1/13/14	1st Floor	boys restroom south end		Painting
Craigmont MS (2128) 1B	The floors in the locker rooms are in bad shape, even when they have been mopped, they still look very bad. Can they be repainted?	2/13/14	Gym	lower level		Painting
Craigmont MS (2128) 1B	there was a busted pipe in the ceiling that was being worked on by hvac, this resulted in the ceiling being soiled and water was pouring out of light fixtures. the ceiling has puckered as if its going to break and the plaster has peeled very badly.	2/3/14	Gym	girls locker room		Painting
Craigmont MS (2128) 1B	Finish and paint drywall patches in the wall covering plumbing chase. Scissor Lift is on sign.jd	1/22/14	Gym			Painting
Craigmont MS (2128) 1B	paint lines on football field	9/16/13				Painting
Craigmont MS (2128) 1B	paint lines on football field	5/28/14				Painting

Craigmont MS (2128) 1B	UNIT VENT - RM 218 - LEAKING BAD - PM/EVANS 416-9925	8/23/13			Plumbing
Craigmont MS (2128) 1B	The second stall is stopped up, tried to use the plunger, and the snake.	8/29/13	2nd Floor	girls restroom north end	Plumbing
Craigmont MS (2128) 1B	WATER FOUNTAIN 1ST FLR- CONSTANTLY RUNNING PER SBE, CAN'T CUT OFF-PLANT MGR EVANS 416-9925 KLR	8/30/13			Plumbing
Craigmont MS (2128) 1B	Toilet is cracked and water is running out of it, especially when flushed.	8/1/13	1st Floor	South end boys restroom	Plumbing
Craigmont MS (2128) 1B	Roofdrain repair inside leaks.	8/1/13	Hallway/Corridor		Plumbing
Craigmont MS (2128) 1B	water fountain is leaking	8/2/13	1st Floor	lower hallway	Plumbing
Craigmont MS (2128) 1B	WATER TANK NOT RELEASING ANY HOT WATER IN CAFE(061) PLANT MGR-EVANS/416.7780	8/6/13			Plumbing
Craigmont MS (2128) 1B	RTU#3 IN THE GYM IS LEAKING. SBE EVANS 416- 9925	8/6/13			Plumbing

Craigmont MS (2128) 1B	FOUNTAIN IN CAFE CONTINUES TO RUN . PLANT MGR-EVANS/416.7780	8/8/13			Plumbing
Craigmont MS (2128) 1B	FAUCETS ON SINK SOUTH END 1ST FLR RR AREA-ARE STRIPPED AND RUNNING AT FULL FORCE PER SBE, CAN'T CUT OFF-SBE EVANS 416- 7780 KLR	8/12/13			Plumbing
Craigmont MS (2128) 1B	there is a leak under the sink in the restroom area	8/15/13	2nd Floor	South hall restrooms	Plumbing
Craigmont MS (2128) 1B	PIPE BEHIND WALL IS LEAKING ONTO GYM FLR PLANT MGR-EVANS/416.7780	8/22/13			Plumbing
Craigmont MS (2128) 1B	per Ms. Evans 416-7780 toilet leaking really bad in boys restroom 2nd floor south end	1/13/14			Plumbing
Craigmont MS (2128) 1B	bad leak in hallway, roofer says its the drain pipe	10/28/13	Hallway/Corridor	lower level	Plumbing
Craigmont MS (2128) 1B	Test and repair RP Devices per MLG&W.	10/29/13	Mechanical Room		Plumbing
Craigmont MS (2128) 1B	HOT WATER TANK NURSE'S STATION-NOT RESETTING, NO HOT WATER TO NURSE'S STATION-PLANT MGR EVANS 416-9925 KLR	11/7/13			Plumbing

Craigmont MS (2128) 1B	two sinks are stopped up, and the disposals aren't working properly.	11/14/13	1st Floor	N127	Plumbing
Craigmont MS (2128) 1B	on 2nd floor 7th grade hall water fountain continuously running and is all over floor per Mr. Blakely 416-7780	1/23/14			Plumbing
Craigmont MS (2128) 1B	sink is leaking from the top and the bottom in the kitchen	1/28/14	Kitchen	lower level	Plumbing
Craigmont MS (2128) 1B	SEWAGE SMELL IN GYM. PLANT MGR-EVANS/416.7780	1/21/14			Plumbing
Craigmont MS (2128) 1B	toilet in girls locker room is stopped up	9/12/13	Gym	girls locker room	Plumbing
Craigmont MS (2128) 1B	Toilet is stopped up	9/12/13	Gym	boys locker room	Plumbing
Craigmont MS (2128) 1B	Concession stand foryer and stairwell lights, repair or replace.	10/7/13			Plumbing
Craigmont MS (2128) 1B	The second stall in the girls restroom is stopped up, Ive tried to unstop it to no avail	2/11/14	2nd Floor	north end girls restroom	Plumbing

Craigmont MS (2128) 1B	there was a sound of water running, now there is a leak in the auditorium on the stage.	2/18/14	Auditorium	lower level	Plumbing
Craigmont MS (2128) 1B	sound of running water in the ceiling, now there is a leak in the closet.	2/18/14	1st Floor	custodial closet	Plumbing
Craigmont MS (2128) 1B	Leak on second floor, coming through ceiling on the first floor.	4/7/14			Plumbing
Craigmont MS (2128) 1B	water fountains leaking, and have been turned off	8/29/13	1st Floor	near auditorium	Plumbing
Craigmont MS (2128) 1B	fountains were running, plumber turned them off, needs repairing.	8/29/13	Cafeteria	lower level to the right of hall	Plumbing
Craigmont MS (2128) 1B	Check for roof leaks and repair as needed	7/26/13			Roof
Craigmont MS (2128) 1B	WASP ARE COMING THRU DUCT WORK OF BLDG PLANT MGR-EVANS/416.7780	12/2/13			Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Craigmont Sr (2126) 1B	2	1	68	158	48	8	54	3	1	343
Grand Total	2	1	68	158	48	8	54	3	1	343

Location	Request Description	Submittal Dat	Area Descript	Area Number	Craft
Craigmont Sr (2126) 1B	We need our gym floor clean. THANKS	12/5/13	Gym	GYM	Asbestos
Craigmont Sr (2126) 1B	large area of floor tile has buckled and is known to have asbestos in it	1/10/14	1st Floor	near boiler room	Asbestos
Craigmont Sr (2126) 1B	Craigmont Sr. --WO373602 computers need to be connected to the internet (Request Network Cabling Maintenance Repair).	8/12/13	1st Floor	107	Cabling
Craigmont Sr (2126) 1B	In reference to work order #374348, I do understand you cant replace the marquee, but can it be lowered for safety purposes?	8/26/13	Grounds	marquee	Carpentry
Craigmont Sr (2126) 1B	The front porch banester was torn down,it need to be place back up. We have it on the dock. THANKS	5/16/14	Grounds	The front porch banester	Carpentry
Craigmont Sr (2126) 1B	handle is coming off the door to the managers restroom	5/19/14	Kitchen	managers office	Carpentry
Craigmont Sr (2126) 1B	these doors are so old and badly damaged that its very hard to open them, and key gets stuck.	8/26/13	2nd Floor	exit doors	Carpentry

Craigmont Sr (2126) 1B	rear door in the classroom, closes sometimes and sometimes it doesnt, this is a safety issue.	9/11/13	1st Floor	119	Carpentry
Craigmont Sr (2126) 1B	The bleacher in this Gym is jammed, it need to be repair. THANKS	5/7/14	Gym	Main Gym	Carpentry
Craigmont Sr (2126) 1B	This door latch is jammed,it need to be repair.	5/7/14	2nd Floor	ROOM 100	Carpentry
Craigmont Sr (2126) 1B	This door latch is jammed, it need to be repair. THANKS	5/7/14	1st Floor	ROOM 104	Carpentry
Craigmont Sr (2126) 1B	PANIC BAR is BROKEN on the EXIT DOOR under the DOCK AREA per Ms. Evans, Plant Mgr. 416.4312	5/14/14			Carpentry
Craigmont Sr (2126) 1B	DOOR, CANT SECURE BY GYM PLANT MGR- BLAKLEY/340.8296	4/8/14			Carpentry
Craigmont Sr (2126) 1B	We need a set of double doors rehung. We need panic bars ,a middle bar,and door closures . We also need to be able to lock the doors.	4/9/14	1st Floor	At the end of ROTC hall	Carpentry
Craigmont Sr (2126) 1B	DOOR OUTSIDE CANT SECURE IN RM-119 PLANT MGR-EVANS/416.4312	4/14/14			Carpentry

Craigmont Sr (2126) 1B	EXIT DOOR BY ELEVATOR PANIC BAR HAS BROKEN OFF & METAL IS STICKING OUT ON 3RD FLR . PLANT MGR-EVANS/416.7780	4/24/14			Carpentry
Craigmont Sr (2126) 1B	These doors are not locking they need to be repaired. THANKS	4/24/14	1st Floor	double doors at storage room,back dock.	Carpentry
Craigmont Sr (2126) 1B	These doors are not locking, they need to be repaired. THANKS	4/24/14	1st Floor	south west of cafeteria	Carpentry
Craigmont Sr (2126) 1B	1st set of double doors on ROTC hall, fire magnetic door holder is missing. THANKS	4/24/14	1st Floor	ROTC hall	Carpentry
Craigmont Sr (2126) 1B	This door has half the lock missing,it need to be repaired. THANKS	4/24/14	1st Floor	ROTC hall double doors leading to stairs	Carpentry
Craigmont Sr (2126) 1B	We have a panic bar missing from the double doors at these stairs. It need to be replace. THANKS	4/25/14	2nd Floor	stairs at room 149	Carpentry
Craigmont Sr (2126) 1B	Door closure is hanging down,it need to be repaired	4/25/14	2nd Floor	Practice GYM	Carpentry
Craigmont Sr (2126) 1B	These doors are not locking,they need to be repaired. THANKS	4/25/14	2nd Floor	double doors at AHU 12	Carpentry

Craigmont Sr (2126) 1B	The 1st set of double doors need new panic bars, the 2on set locks need to be repaired , 3rd set locks need to be repaired. THANKS	4/25/14	3rd Floor	1st set of double doors leading to the gym	Carpentry
Craigmont Sr (2126) 1B	The door closure east end of hall is hanging down, it need to be repaired. THANKS	4/25/14	Gym	hall to boy's locker rm	Carpentry
Craigmont Sr (2126) 1B	Principal is requesting flags be hung in the hallway.	1/8/14	Hallway/Corridor	main hall entrance	Carpentry
Craigmont Sr (2126) 1B	2013 class picture needs to be hung with the rest of the class pictures	1/8/14	Administration Area	near main office	Carpentry
Craigmont Sr (2126) 1B	need concert nail in wall to hang a wall clock	1/13/14	Administration Area	main office	Carpentry
Craigmont Sr (2126) 1B	exit door in rear of room sticks when opened	1/13/14	1st Floor	119	Carpentry
Craigmont Sr (2126) 1B	the screw that bars the door back is broken, deliveries have to be made to the cafeteria from this entrance.	2/3/14	Mechanical Room	dock door entrance	Carpentry
Craigmont Sr (2126) 1B	silver plate is coming up from the floor when entering and exiting the gym from the porch entrance, dangerous	2/3/14	Auxiliary Gym	entrance to the gym from porch	Carpentry

Craigmont Sr (2126) 1B	All of the bleachers are loose, this is resulting in the bleachers not being to go in....athletic director says these loose bleachers are a hazard to the childrens safety	2/3/14	Gym	large gym	Carpentry
Craigmont Sr (2126) 1B	panic bar broken off two doors, fire hazard, doors cant open	2/5/14	Gym	big gym	Carpentry
Craigmont Sr (2126) 1B	This door knob is verry loose ,I have tride to tighten it up but I could not,it need to be repaired. THANKS	2/25/14	Cafeteria	serving line door next to clock	Carpentry
Craigmont Sr (2126) 1B	This room has an exit door with 1 hing bolt missing,it need to be replaced. THANKS	4/2/14	2nd Floor	room 119	Carpentry
Craigmont Sr (2126) 1B	This door closer hinge need to be replaced. THANKS	4/2/14	Library	Door leading to gym	Carpentry
Craigmont Sr (2126) 1B	both closures on the doors are broken	8/29/13	1st Floor	hallway to the right, ahu 12	Carpentry
Craigmont Sr (2126) 1B	water is leaking from the window seal	8/6/13	2nd Floor	Rm. 113	Carpentry
Craigmont Sr (2126) 1B	We have a thrushplate sticking up it is trip hazard. It need to be repaired.	8/13/13	Gym	north west side of the gym	Carpentry

Craigmont Sr (2126) 1B	one of the main door has a broken handle, the handle is preventing the door from being to be opened properly, and this door absolutely has to be open every morning, also it is dangerous.	8/1/13	1st Floor	main entry to the left	Carpentry
Craigmont Sr (2126) 1B	The ceiling has fallen in, very hazardeous	8/1/13	2nd Floor	boys restroom upper gym area	Carpentry
Craigmont Sr (2126) 1B	door knob was replaced, now door wont open at all.	8/6/13	3rd Floor	ahu21 rm	Carpentry
Craigmont Sr (2126) 1B	needs a door sweep or a threshold, large space under door,anything can crawl in.	8/6/13	2nd Floor	north end exit doors	Carpentry
Craigmont Sr (2126) 1B	no door knob on the inside of door	7/9/13	2nd Floor	room 316	Carpentry
Craigmont Sr (2126) 1B	door wont open leading to cooling tower	7/9/13	2nd Floor	room 362	Carpentry
Craigmont Sr (2126) 1B	There is a hallway from the gym where the doors won't secure. Students can wonder into an unsafe and unsecure area.	7/15/13	Hallway/Corridor	gym area	Carpentry
Craigmont Sr (2126) 1B	door is jammed tight and cannot be opened	7/16/13	1st Floor	2nd boys restroom on the left	Carpentry

Craigmont Sr (2126) 1B	swinging door in office needs replacing,its scrubbing the wall	7/16/13	Administration Area	main office	Carpentry
Craigmont Sr (2126) 1B	requesting a pallet of celing tiles because these need replacing badly.over 80 or more	7/16/13	Mechanical Room	lower level	Carpentry
Craigmont Sr (2126) 1B	Colum in the middle of locker room floor has a hole in it. It need to be repaired. THANKS This is sheetrock jd	9/24/13	Gym	girl's locker room	Carpentry
Craigmont Sr (2126) 1B	The magnet on wall will no longer hold door open...its mandatory that this door remains open for the safety of the children.	9/26/13	1st Floor	near cafeteria	Carpentry
Craigmont Sr (2126) 1B	The key cabinet fell off the wall, please hang up for plant manager.	10/14/13	Mechanical Room	bottom area	Carpentry
Craigmont Sr (2126) 1B	The security tech checked the automatic doors and says that the box needs replacing in order for the doors to properly work.	10/18/13	Administration Area	main entry	Carpentry
Craigmont Sr (2126) 1B	The doorclosure in this rr is broken, it need to be repaired THANKS	11/5/13	Gym	boy's rr west side of gym	Carpentry
Craigmont Sr (2126) 1B	Door hardware is hanging from the door,It need to be repaired. THANKS	11/6/13	Gym	hall next to boy's locker rm	Carpentry

Craigmont Sr (2126) 1B	glass is broken in the hallway door	11/7/13	1st Floor	north end of the hall	Carpentry
Craigmont Sr (2126) 1B	Doors entering the guidance office are very hard to close, door is broken.	11/7/13	1st Floor	first floor	Carpentry
Craigmont Sr (2126) 1B	the cylinder in the door keeps turning, can't secure room and items are starting to become up missing.	11/14/13	2nd Floor	room 242	Carpentry
Craigmont Sr (2126) 1B	panic bar in hanging from the door, dangerous	11/14/13	Gym	gym area exit	Carpentry
Craigmont Sr (2126) 1B	glass in door is cracked badly	11/14/13	Gym	exit area in gym	Carpentry
Craigmont Sr (2126) 1B	this door is almost impossible to open, it almost breaks key trying to open.....doors are very old and rubbung together	11/14/13	Gym	upper hallway leading to gym	Carpentry
Craigmont Sr (2126) 1B	screws are coming out of the door, needs repairing	11/15/13	1st Floor	rm 147	Carpentry
Craigmont Sr (2126) 1B	Door cylinder turning and will not lock .It need to be repaired. THANKS	11/26/13	3rd Floor	room 242	Carpentry

Craigmont Sr (2126) 1B	Door cylinder turning and will not lock the door.It need to be repaired. THANKS	11/26/13	2nd Floor	room 105	Carpentry
Craigmont Sr (2126) 1B	Door will not lock.It need to be repaired. THANKS	11/26/13	1st Floor	room 42	Carpentry
Craigmont Sr (2126) 1B	Crash bar isnt working, wont allow access with badge.	6/9/14	Parking Lot	covington pike entrance	Carpentry
Craigmont Sr (2126) 1B	ENTRANCE DOORS CONCESSION STAND-NOT LOCKING, CAN BE PULLED OPEN FROM OUTSIDE WHILE IN LOCKED POSITION-HAD A BREAK IN OVERNIGHT-PLANT MGR EVANS 416-4312 KLR	6/24/14			Carpentry
Craigmont Sr (2126) 1B	This is per the Principal....we are in need of new white boards, we currently have the chalk boards and some of the Teachers are very allergic to chalk...There are 6 in deperate need like asap.	8/23/13	Administration Area	all classrooms	Carpentry
Craigmont Sr (2126) 1B	We need 20 soap dispensers	8/30/13	1st Floor	storage rm	Carpentry
Craigmont Sr (2126) 1B	Ceiling needs replacing where it had fallen down, very hazardous.	7/16/13	1st Floor	2nd boys restroom on the left	Carpentry
Craigmont Sr (2126) 1B	swinging door in hanging off	8/6/13	Administration Area	main office	Carpentry

Craigmont Sr (2126) 1B	We need 3 cases of lamps	5/16/14	1st Floor	plant manager's office	Electrical
Craigmont Sr (2126) 1B	We need 5 small 2 pin 32 watt lamps. THANKS	5/16/14	1st Floor	plant managers's office	Electrical
Craigmont Sr (2126) 1B	We need C 8 lamps ,about 20	8/23/13	1st Floor	storage rm	Electrical
Craigmont Sr (2126) 1B	light switch is broken, cant turn lights on	8/26/13	2nd Floor	area near gym	Electrical
Craigmont Sr (2126) 1B	Craigmont Sr. WO382797 --Bells are ringing whenever they fell like it and the clocks are wrong per Ms. Evans 416-4312	9/11/13			Electrical
Craigmont Sr (2126) 1B	electrical sockets arent working in this classroom	9/11/13	2nd Floor	232	Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	5/8/14	1st Floor	Plant manager's office	Electrical
Craigmont Sr (2126) 1B	We have 3 light fixtures out , I have change the lamps. BAD BALLAST THANKS	5/9/14	3rd Floor	room 205when you frist come in the door.	Electrical

Craigmont Sr (2126) 1B	the entire stairwell is dark and needs lights immediately	5/12/14	Hallway/Corridor	stairwell	Electrical
Craigmont Sr (2126) 1B	per ms evans 416-4312 AHU #12 keeps tripping out and it controls main office	5/12/14			Electrical
Craigmont Sr (2126) 1B	Its very dark in the walk way, its dangerous when opening the building..5 lights are blown out	5/13/14	Parking Lot	near guidance office	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps. BAD BALLAST THANKS	5/13/14	1st Floor	room 42	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out , I have change the lamps. BAD BALLAST THANKS	5/13/14	1st Floor	room 44	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out , I have change the lamps. BAD BALLAST THANKS	5/14/14	3rd Floor	room 225	Electrical
Craigmont Sr (2126) 1B	We have a light fixture out , I have change the lamps. BAD BALLAST THANKS	5/14/14	3rd Floor	Hall in front of rm 225	Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	4/7/14	1st Floor	plant manager's office	Electrical

Craigmont Sr (2126) 1B	We have a light fixture blinking. It need to be repaired.	4/8/14	1st Floor	plant manager`s office	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out I have change the lamps . BAD BALLAST THANKS	4/14/14	Kitchen	pantry	Electrical
Craigmont Sr (2126) 1B	Install 3 pull station cover at locations designated by the building engineer.	4/21/14			Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	4/21/14	1st Floor	plant manager`s office	Electrical
Craigmont Sr (2126) 1B	We have a light fixture out, I have remove the lamps BAD BALLAST THANKS	4/21/14	2nd Floor	100C	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out ,I have change the lamps.BAD BALLAST THANKS	4/21/14		assisent principal `s office	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out ,I have change the lamps. BAD BALLAST THANKS	4/21/14	2nd Floor	MAIN OFFICE MEN RR	Electrical
Craigmont Sr (2126) 1B	The floor magnetic door holder is not working,it need to be repaired. THANKS	4/25/14	2nd Floor	double doors at room 111	Electrical

Craigmont Sr (2126) 1B	BALLAST IS OUT IN MEN/RR MAIN OFFICE PLANT MGR-EVANS/438.7765	4/28/14			Electrical
Craigmont Sr (2126) 1B	basketball goals, south 3 and north 3 are not working...south 2 is broken and wont let down.	5/2/14	Gym	left of main entry	Electrical
Craigmont Sr (2126) 1B	We have 3 light fixtures out, I have change the lamps. BAD BALLAST THANKS	12/4/13	3rd Floor	library landing	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out . I have change the lamps . BAD BALLAST THANKS	12/4/13	1st Floor	ROTC room	Electrical
Craigmont Sr (2126) 1B	There are 3 bad ballasts out in this room, one is blinking and is very anoying to teacher	12/9/13	Library	library classroom	Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	12/11/13	1st Floor	storage rm	Electrical
Craigmont Sr (2126) 1B	We have half of room 150 light fixtures out. They need to be repaired	12/11/13	2nd Floor	rm 150	Electrical
Craigmont Sr (2126) 1B	PARTIAL OUTAGE-RM 204-HAS NO POWER AT ALL-NO LIGHTS, NO POWER TO RECEPTACLES, ETC. PER SBE- PLANT MGR EVANS 416-4312 KLR	12/12/13			Electrical

Craigmont Sr (2126) 1B	several recepticals not working at all.	12/12/13	Library	main entrance	Electrical
Craigmont Sr (2126) 1B	magnet holding doors open, pulled from wall	12/12/13	1st Floor	main entry stairs	Electrical
Craigmont Sr (2126) 1B	magnets broken that holds the hall doors open	12/12/13	3rd Floor		Electrical
Craigmont Sr (2126) 1B	The cover for the fire alarm has been pulled off, leaving access for children to pull the alarm.	12/12/13	1st Floor	north stairwell	Electrical
Craigmont Sr (2126) 1B	PARTIAL POWER OUTAGE IN RM-100 PLANT MGR-EVANS/416-7780	12/13/13			Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out. I have change the lamps. BAD BALLAST THANKS	12/20/13	2nd Floor	rm 243	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out .It need to be repaired. BAD BALLAST THANKS	12/20/13	3rd Floor	RM 245	Electrical
Craigmont Sr (2126) 1B	HEAT GREENRM-NOT COMING ON-PLANT MGR EVANS 416-9925 KLR	1/8/14			Electrical

Craigmont Sr (2126) 1B	We need 2 cases of longe lamps for auto shop thanks. 8ft single pin.jd	1/8/14	1st Floor	stoarge rm	Electrical
Craigmont Sr (2126) 1B	bad ballast in back of room near the sink, making a horrible noise	1/13/14	1st Floor	117	Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps . THANKS	1/14/14	1st Floor	storage room	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out. I have change the lamps. BAD BALLAST THANKS	1/16/14	3rd Floor	rm 205	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out ,I have change the lamps. BAD LAMPS THANKS	1/16/14	3rd Floor	RM 221	Electrical
Craigmont Sr (2126) 1B	We have 4 light fixtures out ,I have change the lamps. BAD BALLAST. THANKS	1/16/14	3rd Floor	RM 200	Electrical
Craigmont Sr (2126) 1B	We have a light fixture out in front of room 203, I have change the lamps . BAD BALLAST THANKS	1/22/14	3rd Floor	hall in front of room 203	Electrical
Craigmont Sr (2126) 1B	We need an electrical outlet for a deep fryer in this room.	1/24/14	2nd Floor	TEA ROOM	Electrical

Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	2/5/14	1st Floor	storage room	Electrical
Craigmont Sr (2126) 1B	We need 5 two pin fluorescent light bulbs.	2/14/14	1st Floor	plant manager's office	Electrical
Craigmont Sr (2126) 1B	We have one light fixture out, I have change the lamps. It need to be repaired. THANKS	2/18/14	1st Floor	Hall in front of the aquarium	Electrical
Craigmont Sr (2126) 1B	We have a light fixture out in this rest room , I have change the lamps . BAD BALLAST THANKS	2/18/14	1st Floor	girls rr across from the aquarium room.	Electrical
Craigmont Sr (2126) 1B	lights are flickering	2/19/14	Gym	main gym	Electrical
Craigmont Sr (2126) 1B	3 basketball goals wont lift up or down	2/19/14	Gym		Electrical
Craigmont Sr (2126) 1B	ballast is exposed and needing one more replaced in it	2/19/14	2nd Floor	rm 221	Electrical
Craigmont Sr (2126) 1B	We have a light fixture out. I have change the lamps . BAD BALLAST THANKS	2/25/14	1st Floor	north end of cafeteria.	Electrical

Craigmont Sr (2126) 1B	We have a light fixture out in this rr, I have change the lamps . BAD BALLAST THANKS	2/25/14	1st Floor	Girl's rr north end of cafeteria.	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps. BAD BALLAST THANKS	3/6/14	3rd Floor	room 202	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps . BAD BALLAST THANKS	3/6/14	2nd Floor	ROOM 204	Electrical
Craigmont Sr (2126) 1B	We have a light fixture out, I have change the lamps. BAD BALLAST THANKS	3/6/14	2nd Floor	nurse station	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out. I have change the lamps. BAD BALLAST THANKS	3/17/14	3rd Floor	rm 221	Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	3/18/14	1st Floor	storage room	Electrical
Craigmont Sr (2126) 1B	light is blown out, and its very dark at this entrance, very unsafe	3/20/14	Parking Lot	exit near guidance	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out ,I have change the lamps . BAD BALLAST THANKS	3/28/14	1st Floor	room 143	Electrical

Craigmont Sr (2126) 1B	We have 1 light fixture out .I have change the lamps. BAD BALLAST THANKS	3/28/14	3rd Floor	room 221	Electrical
Craigmont Sr (2126) 1B	We have 4 light fixtures out .I have change the lamps . BAD BALLAST THANKS	3/28/14	3rd Floor	ROOM 217	Electrical
Craigmont Sr (2126) 1B	HOT WATER TANK FOR KITCHEN AREA-NOT COMING ON-NO HOT WATER TO KITCHEN-PLANT MGR EVANS 416-4312 KLR	3/31/14			Electrical
Craigmont Sr (2126) 1B	Followup to check electrical equipement, there was a power outage over the weekend.	4/1/14			Electrical
Craigmont Sr (2126) 1B	The lights in front of the building are blown out and its very dark, there is a tall wall in front of the building and its dangerous for the Principal and the Plant Manager to open the building very early in the morning. please help	4/1/14	Parking Lot	main entrance	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps. BAD BALLAST THANKS	4/2/14	2nd Floor	hall in front of room 117	Electrical
Craigmont Sr (2126) 1B	Belt guard is off, repair and replace.	4/3/14	Mechanical Room	AHU !&2	Electrical
Craigmont Sr (2126) 1B	We have 5 light fixtures out I have change the lamps . BAD BALLAST	8/26/13	3rd Floor	south end of hall	Electrical

Craigmont Sr (2126) 1B	We have 1 light fixture out. I have change the lamps. BAD BALLAST THANKS	8/27/13	3rd Floor	rm 255	Electrical
Craigmont Sr (2126) 1B	We have 4 light fixtures , I have change the lamps. BAD BALLAST THANKS	8/27/13	3rd Floor	RM 253	Electrical
Craigmont Sr (2126) 1B	Magnetic door holder has been pull off the wall.	8/29/13	Gym	near hall of flags	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out, I have change the lamps. BAD BALLAST	8/30/13	3rd Floor	RM 254	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps . BAD BALLAST THANKS	8/30/13	3rd Floor	RM 247	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out ,I have changed the lamps. BAD BALLAST	9/3/13	3rd Floor	rm 234	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixtures out , I have change the lamps , BAD BALLAST	9/3/13	3rd Floor	fixture in front of rm 234	Electrical
Craigmont Sr (2126) 1B	Dryer won't run for atheletic dept.	9/4/13			Electrical

Craigmont Sr (2126) 1B	Repair lights in restroom plumber can't see to make repairs.	9/4/13				Electrical
Craigmont Sr (2126) 1B	We have 3 light fixtures out. I have change the lamps. BAD BALLAST	9/4/13	1st Floor	hall north west side of building		Electrical
Craigmont Sr (2126) 1B	We have 3 light fixtures out . I have change the lamps. BAD BALLAST	9/6/13	1st Floor	north east side of cafeteria,hall		Electrical
Craigmont Sr (2126) 1B	BREAKER KEEPS TRIPPING FOR THE CAFE - STEAMTABLES WONT STAY ON - PM/EVANS416-4312	8/7/13				Electrical
Craigmont Sr (2126) 1B	The outlet that services the smart isnt working	8/12/13	2nd Floor	RM246		Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out , I have change the light bulbs BAD BALLAST	8/22/13	3rd Floor	RM 251		Electrical
Craigmont Sr (2126) 1B	We have 4 light fixtures out .I have change the lighet bulbs. BAD BULBS	8/22/13	Cafeteria	cafeteria		Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out . I have change the bulbs .BAD BALLAST	8/22/13	2nd Floor	RM 115 Band teacher's office		Electrical

Craigmont Sr (2126) 1B	There are about 15 blown lights, these require a lift to replace.	8/1/13	Library	main entry on the left	Electrical
Craigmont Sr (2126) 1B	I counted about 10 lights out in this hall entering the gym, hallway is too dark., requires a lift	8/1/13	Gym	hall of flags area	Electrical
Craigmont Sr (2126) 1B	This gym needs to have lights replaced, requires a lift.	8/1/13	Gym	big gym, hall of flags	Electrical
Craigmont Sr (2126) 1B	magnet on floor is broken, wont allow automatic doors to remain open.	8/6/13	3rd Floor	near room 214	Electrical
Craigmont Sr (2126) 1B	requesting more lamps, plenty out.	8/6/13	Mechanical Room	ground floor	Electrical
Craigmont Sr (2126) 1B	there are aproximately 100 blown bulbs on the first floor alone.	7/3/13	1st Floor	hallways and classrooms	Electrical
Craigmont Sr (2126) 1B	DRIVER ED SIMULATOR DOES NOT HAVE ANY POWER. SBE EVANS 416-2557	7/9/13			Electrical
Craigmont Sr (2126) 1B	We have 10 light fixtures out .I have changed the bulbs. BAD BALLAST	7/25/13	Kitchen	servicing line	Electrical

Craigmont Sr (2126) 1B	We have 2 light fixtures out ,I have change the bulbs.BAD BALLAST THANK YOU	7/25/13	2nd Floor	RM 145	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out .I have change the bulbs. BAD BALLAST.	7/25/13	2nd Floor	rm 140	Electrical
Craigmont Sr (2126) 1B	The kitchen part of rm 140. I have changed the bulbs . BAD BALLAST	7/25/13	2nd Floor	rm 140	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out. I have changed the bulbes, BAD BALLAST	7/25/13	2nd Floor	RM 142	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out . I have changed the bulbs. BAD BALLAST	7/25/13	2nd Floor	rm 149	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out. I have changed the bulb. BAD BALLAST	7/25/13	2nd Floor	in front of the front door	Electrical
Craigmont Sr (2126) 1B	We need light bulbs. 10 cases	7/26/13	1st Floor	storage area just on the other side of dock doors	Electrical
Craigmont Sr (2126) 1B	This is highly important, all of the outside lights needs to be checked, having to arrive in the dark to open the building is very dangerous, too many lights are blown out.	9/13/13	Grounds	outside around building	Electrical

Craigmont Sr (2126) 1B	We have 1 light fixture out , I have change the lamps .BAD BALLAST	9/13/13	2nd Floor	main office	Electrical
Craigmont Sr (2126) 1B	AHU #17,18 NOT COOLING IN CAFE PLANT MGR-EVANS/438.7765	9/16/13			Electrical
Craigmont Sr (2126) 1B	LIGHTS - IN THE ALL OF FLAGS- NOT COMING - PM/EVANS 416-4312	9/17/13			Electrical
Craigmont Sr (2126) 1B	There are 3 lights out, requires a lift to replace.	9/26/13		hall of flags hallway near concession	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out in this closet. I have change the lamps . BAD BALLAST	10/1/13	Gym	custodial closet	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out , I have change the lamps. BAD BALLAST THANKS	10/2/13	2nd Floor	rm between the library & Gym	Electrical
Craigmont Sr (2126) 1B	Our electronic access device isn't working....	10/7/13	1st Floor	main entry	Electrical
Craigmont Sr (2126) 1B	needing several lights replaced	10/14/13	1st Floor	planetarium	Electrical

Craigmont Sr (2126) 1B	The two magnets that hold the exit doors open have been torn from the wall, these doors need to be opened at all times for the safety of the children.	10/14/13	3rd Floor	gym area	Electrical
Craigmont Sr (2126) 1B	LIGHTS - IN THE HALL OF FLAGS - NOT WORKING & CAN'T RESET - PM/EVANS 416-4312	10/16/13			Electrical
Craigmont Sr (2126) 1B	There are 3 fixtures with bad ballasts in them.	10/22/13	1st Floor	rm. 138	Electrical
Craigmont Sr (2126) 1B	There are hundreds of lights blown out, needing more lamps.	10/22/13	Mechanical Room	lower level	Electrical
Craigmont Sr (2126) 1B	light keeps flickering in classroom	10/22/13	1st Floor	coachs office	Electrical
Craigmont Sr (2126) 1B	Outlet in front of the room doesn't work.	10/28/13	2nd Floor	206	Electrical
Craigmont Sr (2126) 1B	Outlet in front of room do not work. It need to be repaired. THANKS	11/1/13	3rd Floor	rm 206	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps. BAD BALLAST THANKS	11/6/13	2nd Floor	rm 138	Electrical

Craigmont Sr (2126) 1B	LIGHTS - MAIN ENTRY, IN FRONT OF MAIN OFC - 1ST FLR BAND HALL & 3RD FLR SECURITY AREA - ALL ARE NOT WORKING - PM/EVANS 416-4312	11/7/13			Electrical
Craigmont Sr (2126) 1B	The magnetic device that holds the door open has been torn from the wall, and the door needs to be open at all times. the device is hanging.	11/7/13	1st Floor	main entry stairwell	Electrical
Craigmont Sr (2126) 1B	Repair or replace lights in Gym Balcony both north and south, high pressure fixtures only.	11/12/13	Gym		Electrical
Craigmont Sr (2126) 1B	We need 4 cases of lamps.THANKS	11/12/13	1st Floor	storage room	Electrical
Craigmont Sr (2126) 1B	per ms. evans 416-4312 AHU in alarm and cold in the following rooms - 1, 2, 7, 8, 13, 14, 22, 23, 24, 25, 26, 29, 30	11/13/13			Electrical
Craigmont Sr (2126) 1B	Repair lighting in the Hall of Flags this area will be used for voting on Nov. 21st.	11/19/13	Hallway/Corridor		Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out ,I have change the lamps. BAD BALLAST THANKS	11/19/13	2nd Floor	Night school office	Electrical
Craigmont Sr (2126) 1B	room 204 there are no lights on per Ms. Evans 416-4312 said has checked breaker and it not that	11/21/13			Electrical

Craigmont Sr (2126) 1B	We have 2 light fixtures out,I have change the lamps. BAD LAMPS. THANKS	11/21/13	2nd Floor	room 101c	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out .I have change the lamps. BAD BALLAST	11/21/13	2nd Floor	room 103	Electrical
Craigmont Sr (2126) 1B	We have 4 light fixtures out, I have change the lamps. BAD BALLAST THANKS	11/21/13	2nd Floor	room 105	Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out ,I have change the lamps. BAD BALLAST THANKS	11/21/13	2nd Floor	room 109	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out,I have change the lamps. BAD BALLAST THANKS	11/21/13	3rd Floor	room 227	Electrical
Craigmont Sr (2126) 1B	We have 3 light fixtures out .I have change the lamps. BAD BALLAST THANKS	11/21/13	2nd Floor	room 100c	Electrical
Craigmont Sr (2126) 1B	We have 4 light fixtures out,I have change the lamps. BAD BALLAST THANKS	11/21/13	2nd Floor	room 102c	Electrical
Craigmont Sr (2126) 1B	We have 1 light fixture out,I have change the lamps. BAD BALLAST THANKS	11/21/13	2nd Floor	room 111c	Electrical

Craigmont Sr (2126) 1B	We have 2 light fixtures out, I have change the lamps. BAD BALLAST THANKS	11/21/13	1st Floor	room 117 storage area	Electrical
Craigmont Sr (2126) 1B	We need 3 cases of lamps. THANKS	11/21/13	1st Floor	storage rm	Electrical
Craigmont Sr (2126) 1B	We have 8 light fixtures out in this area, I have change the lamps , BAD BALLAST THANKS	11/22/13	1st Floor	ROTC hall leading to stairs	Electrical
Craigmont Sr (2126) 1B	We have 5 light fixtures out, I have change the lamps. BAD BALLAST THANKS	11/22/13	2nd Floor	TEA ROOM	Electrical
Craigmont Sr (2126) 1B	LIGHTS HAVE NO POWER IN RM-210 PLANT MGR-EVANS/416.7780	11/25/13			Electrical
Craigmont Sr (2126) 1B	5-UV NOT COMING ON IN RM-221,223,225,227,231. PLANT MGR-EVANS/416.4312	11/25/13			Electrical
Craigmont Sr (2126) 1B	We have 2 light fixtures out , I have change the lamps. BAD BALLAST THANKS	5/29/14	3rd Floor	rm 227 when you frist come in the door	Electrical
Craigmont Sr (2126) 1B	We need 3 casses of lamps. THANKS	6/4/14	1st Floor	plant manager`s office	Electrical

Craigmont Sr (2126) 1B	needing an outlet added	6/11/14	1st Floor	plant manager office	Electrical
Craigmont Sr (2126) 1B	ballast out	6/26/14	1st Floor	near elevator	Electrical
Craigmont Sr (2126) 1B	4 blown lights, too high for the plant manager, requires a lift	6/26/14	2nd Floor	band room	Electrical
Craigmont Sr (2126) 1B	there are 2 bad ballasts	6/26/14	2nd Floor	band room , equipment room	Electrical
Craigmont Sr (2126) 1B	requesting lights for this area, its too dark and not safe	6/26/14	Parking Lot	front porch	Electrical
Craigmont Sr (2126) 1B	emergency lights not working	6/26/14	Library	main entry	Electrical
Craigmont Sr (2126) 1B	14 blown lights, requires a lift to replace	6/26/14	Gym	front of building	Electrical
Craigmont Sr (2126) 1B	bad motor on one of the basketball goals	6/26/14	Gym	front of building	Electrical

Craigmont Sr (2126) 1B	6 blown florscent lights	6/26/14	Gym	front entry	Electrical
Craigmont Sr (2126) 1B	4 lights blown out, requires a lift	6/26/14	Hallway/Corridor	hall of flags	Electrical
Craigmont Sr (2126) 1B	very high ceiling, three blown bulbs	6/26/14	Library	main entry	Electrical
Craigmont Sr (2126) 1B	This is concerning the marquee, its very old, and has become very dangerous, not to mention that we shouldnt go pass 6 feet on a 8 foot ladder, this marquee is at least 10 ft.	8/13/13	Administration Area	main lobby	Electrical
Craigmont Sr (2126) 1B	too many lights are blown out in the auditorium	5/2/14	Auditorium	left of library	Electrical
Craigmont Sr (2126) 1B	AHU#1 smoke detector is in alarm and not cooling per Ms. Evans 416-4312 New fire alarm under warranty.	9/12/13			Electrical
Craigmont Sr (2126) 1B	Monthly - Air Compressor 049 - Craigmont High - Refer to PM schedule details.	5/16/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Oil Lube & Belt- Craigmont High - Refer to PM schedule details.	5/16/14			Heating/Ventilation /Air Conditioning

Craigmont Sr (2126) 1B	CHILLER-1 MECH RM-MAKING NOISES-PLANT MGR 416-4312 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Air Compressor 048 - Craigmont High - Refer to PM schedule details.	5/16/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	UNIT IS MAKING NOISE IN RM-143 . PLANT MGR- BLAKELY/416.4312	4/16/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	2-CHILLERS & PUMP#5 IN ALARM PLANT MGR-EVANS/416.4312	4/22/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	CHILLER-1 MECH RM-IN ALARM & CHILLER-2 MECH RM-NOT COOLING-PLANT MGR EVANS 416-4312 KLR	4/25/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	hot water pump in alarm also AH#8, 17, 12 in alarm per Ms. Evans 416-4312	12/9/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	HEAT RM 221-OVERHEATING, TEMP IS 100 PER SBE & RM 142-NOT HEATING-PLANT MGR EVANS 416-4312 KLR	12/12/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	BOILER is in ALARM per William Blakely, Plant Mgr. 416.4312	1/6/14			Heating/Ventilation /Air Conditioning

Craigmont Sr (2126) 1B	UNIT is NOT HEATING in Room 142 for Ms. Evans, Plant Mgr. 416.4312	1/31/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	3-BOILERS IN ALARM PLANT MGR-EVANS/416.4312	2/21/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	BOILER is NOT HEATING throughout the ENTIRE BUILDING per Ms. Evans, Plant Mgr. 416.4312	2/24/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Repair purge unit on both chillers-contracted to Integrity Mechanical	8/26/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	AHU#11 NOT COOLING IN LIBRARY . PLANT MGR-EVANS/416.4312	9/3/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Per Ms. Evans the AHU #7 is in alarm	8/6/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	3-AHU ARE IN ALARM IN AUDIT. PLANT MGR-EVANS/416.7780	8/7/13			Heating/Ventilation /Air Conditioning

Craigmont Sr (2126) 1B	UV NOT COOLING IN RM-200,& 4-AHU#1,2,7,21 KEEP ON TRIPPING IN RM-302,347,322 PLANT MGR-EVANS/416.8202	8/9/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	AHU RM 260 2ND FLR-NOT COOLING-PLANT MGR EVANS 416-4312 KLR	8/21/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	WINDOW UNIT IN THE DRIVER SIMULATOR IS NOT COMING ON. SBE EVANS 416-4312	8/2/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	AHU THAT CONTROLS THE MAIN OFFICE IS NOT COOLING. SBE EVANS 416- 4312	8/5/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	CHILLER AND RTU'S ARE IN ALARM . SBE EVANS 416-2557	7/9/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Air Handler #11 NOT COOLING in the Main office per Ms. Evans, Plant Mgr at 901.416.9225!	7/11/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	UNIT NOT COOLING IN GYM. PLANT MGR-EVANS/416-4312	7/29/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	AHU #17,18 NOT COOLING IN CAFE AGAIN PLANT MGR-EVANS/438.7765	9/17/13			Heating/Ventilation /Air Conditioning

Craigmont Sr (2126) 1B	AHU-17 & AHU-18 CAFE AREA- BOTH NOT COOLING-PLANT MGR EVANS 416-4312 KLR	9/30/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	chiller is in alarm per Ms. Evans 416-4312	10/14/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Per Ms. Evans 416-4312 both boilers are in alarm and the following AH in alarm - 2, 5, 6, 10, 12, 13, 14, 15, 17, 19, 20, 21, 22, 23, 24, 28	10/17/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Oil Lube & Belt- Craigmont High - Refer to PM schedule details.	10/18/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	WHEN A/C UNIT IS TURNED ON IN DRIVER'S ED SIMULATOR-IT'S KNOCKING THE POWER OUT TO THE ENTIRE SIMULATOR-PLANT MGR BLAKELY 416-4312 KLR	10/22/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	cafeteria too hot - not cooling per Ms. Evans 416-4312	10/29/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	units 1, 2 and 7 are not coming on per Ms. Evans 416-4312	10/30/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	units 14, 23, 25, 26, 29, 30 are in alarm units 17 and 18 not cooling (cafe) per Ms. Evans 416-4312	10/30/13			Heating/Ventilation /Air Conditioning

Craigmont Sr (2126) 1B	Monthly - Air Compressor 048 - Craigmont High - Refer to PM schedule details.	11/15/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Air Compressor 049 - Craigmont High - Refer to PM schedule details.	11/15/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	10-AHU IN ALARM IN NORTH-END, SOUTH-END 3RD FLRS, SOUTH-END 2ND FLR, BASEMENT BEHIND CAFE, B-LOCKER 3RD FLR. PLANT MGR-EVANS/416.4312	11/25/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	CHILLERS - BOTH ARE IN ALARM - PM/EVANS 416-4312	5/23/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	AIR HANDLER #12 will NOT RESET in the MAIN OFFICE per Ms. Evans, Plant Mgr. 416.4312	5/23/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	CHILLERS - BOTH ARE NOT COMING - PM/EVANS 416-4213	6/9/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	pump #4 tripping overloads	6/23/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Filter-Craigmont High - Refer to PM schedule details.	8/2/13			Heating/Ventilation /Air Conditioning

Craigmont Sr (2126) 1B	Yearly - Oil Samples-Craigmont High - Refer to PM schedule details.	9/8/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Filter-Craigmont High - Refer to PM schedule details.	11/29/13			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - Filter-Craigmont High - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Yearly - Cooling Towers(STRAINERS)-Craigmont High - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Daily - Craigmont High Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Monthly - CRAIGMONT HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Craigmont Sr (2126) 1B	Graffiti outside brick wall NE side of building per William Blakely 416-9312	7/30/13			Painting
Craigmont Sr (2126) 1B	GRAFFITI IN FRONT OF BLDG WALL PLANT MGR-EVANS/416.4312	5/12/14			Painting

Craigmont Sr (2126) 1B	GRAFFITI ON THE WALL OF RM 252. SBE BLAKELY 416-4312	7/25/13			Painting
Craigmont Sr (2126) 1B	GRAFFITI IN RM 252 ON THE WALLS. SBE EVANS 416-2552	7/11/13			Painting
Craigmont Sr (2126) 1B	Graffiti (spray paint) on outside of building near guidance office per Ms. Evans 416-4312	9/23/13			Painting
Craigmont Sr (2126) 1B	on the dugout, there is graffiti per William Blakely 416-4312	9/24/13			Painting
Craigmont Sr (2126) 1B	GRAFFITI - 2ND FLR NEAR B LOCKER RM - GANG RELATED ON WALLS - NOT - PM/EVANS 416-4312	10/16/13			Painting
Craigmont Sr (2126) 1B	paint walls in rm.113	10/17/13			Painting
Craigmont Sr (2126) 1B	hot water in the sink keeps running	5/19/14	1st Floor	room 133	Plumbing
Craigmont Sr (2126) 1B	The hot water has been cut off by the plant manager because it keeps running.	5/19/14	3rd Floor	north end teachers lounge	Plumbing

Craigmont Sr (2126) 1B	The sink hot water is leaking bad , it need to be repaired. THANKS	5/20/14	Custodial Closet	2on floor next to elevator	Plumbing
Craigmont Sr (2126) 1B	Toilet tank handle is broken, it need to be repaired . THANKS	5/9/14	2nd Floor	Guidance office rest room	Plumbing
Craigmont Sr (2126) 1B	Cooling tower low water.	5/13/14			Plumbing
Craigmont Sr (2126) 1B	The sink in this room hot water is leaking ,it need to be repaired. THANKS	5/15/14	2nd Floor	room 138	Plumbing
Craigmont Sr (2126) 1B	The drainplug in this sink will not hold water. It need to be repaired. THANKS	4/14/14	Kitchen	3 compartment sink	Plumbing
Craigmont Sr (2126) 1B	The commode in this rest room flush valve is sticking & it is leaking from the neck,it need to be repaired. THANKS	4/14/14	Gym	boy's locker room rr	Plumbing
Craigmont Sr (2126) 1B	The sink in this rr,drain pipe is leaking. It need to be repaired. THANKS	4/14/14	Gym	south east side	Plumbing
Craigmont Sr (2126) 1B	NO HOT WATER IN CAFE PLANT MGR-EVANS/416.7780	4/23/14			Plumbing

Craigmont Sr (2126) 1B	Need plumber to work with techs from S M Larence to check strainers at class room units.	12/12/13				Plumbing
Craigmont Sr (2126) 1B	PIPE BURST IN GREENRM-PLANT MGR EVANS 416-9925 KLR	1/8/14				Plumbing
Craigmont Sr (2126) 1B	SPRINKLER PIPE BURST - OUTSIDE IN DOCK AREA - PM/EVANS 416-4312	1/9/14				Plumbing
Craigmont Sr (2126) 1B	Gas smells in the Main Entrance and also in Room 133 per Ms. Evans, Plant Mgr. 416.4312	1/9/14				Plumbing
Craigmont Sr (2126) 1B	This rest room has a small hole in the weter pipe under the sink,it need to be repaired. THANKS	1/9/14	2nd Floor	Girls rr lobby next to room 104		Plumbing
Craigmont Sr (2126) 1B	needs water turned on in science room, its been off so long that plant manager prefers that skilled plumber turns it on.	1/13/14	3rd Floor	260 and 255		Plumbing
Craigmont Sr (2126) 1B	per Ms Evans 416-4312 girls restroom near rm 104 there is a leaking pipe under sink	1/13/14				Plumbing
Craigmont Sr (2126) 1B	The commode in this rest room will not stop runing,it need to be repaired. THANKS	1/14/14	Auditorium	rest room		Plumbing

Craigmont Sr (2126) 1B	SEWER GAS SMELL ON 1ST & 2ND FLRS-PLANT MGR EVANS 416-4312 KLR	1/17/14				Plumbing
Craigmont Sr (2126) 1B	the flush valve is leaking bad when the toilet is flushed	1/31/14	2nd Floor	girls rest room near rm 104		Plumbing
Craigmont Sr (2126) 1B	The urinal neck has a real bad leak, it need to be repaired. THANKS	1/31/14	2nd Floor	boy's rr practice gym		Plumbing
Craigmont Sr (2126) 1B	The sink in this rest room is leaking hot water, it need to be repaired.	1/31/14	2nd Floor	nurse station rest room		Plumbing
Craigmont Sr (2126) 1B	ceiling leaking bad, floor tile has been replaced, but the leak is still leaking.	2/10/14	1st Floor	near plant managers office		Plumbing
Craigmont Sr (2126) 1B	Assistant Principal is reporting that the sink in her restroom is leaking bad from the faucet.	2/13/14	Administration Area	Left upon entering the building		Plumbing
Craigmont Sr (2126) 1B	FLOOR DRAINS 2ND FLR B/G RR'S NEXT TO RM 104-BACKING UP IN BOTH-PLANT MGR BLAKELY 416-4312 KLR	2/20/14				Plumbing
Craigmont Sr (2126) 1B	sink stopped up in the science lab	3/26/14	2nd Floor	rm 260		Plumbing

Craigmont Sr (2126) 1B	The water needs to be turned on out on the baseball field.	3/26/14	Grounds	baseball field	Plumbing
Craigmont Sr (2126) 1B	please check faucets and turn on water	3/26/14	2nd Floor	rm 254	Plumbing
Craigmont Sr (2126) 1B	per evans 416-4312 sewer backing up in kitchen and plant manager's office	4/1/14			Plumbing
Craigmont Sr (2126) 1B	All of the toilets are stopped up, no water in them, havent been used since Ive been on site.	8/29/13	1st Floor	girls restroom, outside cafeteria	Plumbing
Craigmont Sr (2126) 1B	floor drains backing up in kitchen.	8/29/13	Kitchen	lower level	Plumbing
Craigmont Sr (2126) 1B	We have pipes leaking from in the cieling of cafereria manager's office & storage rm. It need to be repaired. THANKS	8/30/13	Cafeteria	manager's office & storage rm	Plumbing
Craigmont Sr (2126) 1B	The sink has a leaking water faucet, it need to be repaired. THANKS	8/6/13	2nd Floor	boy's rr south end of building	Plumbing
Craigmont Sr (2126) 1B	The urinal in this rr flush valve is not working properly and is leaking.	8/7/13	3rd Floor	teacher's lounge south end of building	Plumbing

Craigmont Sr (2126) 1B	Hot water faucet is leaking, it needs to be repaired. 3 sink compartment. THANKS	8/7/13	Kitchen	sink	Plumbing
Craigmont Sr (2126) 1B	3-COMPARTMENT SINK KITCHEN-NOT HOLDING WATER AND DRAIN STOPPED UP CAUSING IT TO LEAK-SBE EVANS 416-4312 KLR	8/12/13			Plumbing
Craigmont Sr (2126) 1B	This rr has a sink with a leaking water faucet, it needs to be repaired. THANKS	8/12/13	2nd Floor	girls rr across from the elevator	Plumbing
Craigmont Sr (2126) 1B	The water fountain across from the elevator is leaking from the drain. it needs to be repaired. THANKS	8/13/13	2nd Floor	across from the elevator	Plumbing
Craigmont Sr (2126) 1B	We have a faucet that is leaking hot water it needs to be repaired. THANK YOU	7/30/13	Kitchen	cafeteria manager's offices	Plumbing
Craigmont Sr (2126) 1B	STEAM TABLE ARE NOT DRAINING. AND THEY LEAKING. SBE EVANS	8/5/13			Plumbing
Craigmont Sr (2126) 1B	We have a flush valve that is leaking, it needs to be repaired. ASAP THANKS	8/5/13	2nd Floor	boy's rr south end of building	Plumbing
Craigmont Sr (2126) 1B	The sink in this rest room hot water faucet will not turn off, it needs to be repaired. THANKS	8/5/13	2nd Floor	girl's rr next to library	Plumbing

Craigmont Sr (2126) 1B	Art room needing the sink traps cleaned out.	8/6/13	1st Floor	117, left of main entrance	Plumbing
Craigmont Sr (2126) 1B	flush valves leaking	8/6/13	1st Floor	rotc area, boys and girls restroom	Plumbing
Craigmont Sr (2126) 1B	toilet in room wont flush, no water pressure at all.	8/6/13	1st Floor	room 100C	Plumbing
Craigmont Sr (2126) 1B	We have 3 drain plugs that's not working properly. They need to be replaced or repaired. THANKS	7/26/13	Kitchen	by the exit door	Plumbing
Craigmont Sr (2126) 1B	WATER TANK NOT RELEASING NO HOT IN CAFE. PLANT MGR-EVANS/416.4312	7/29/13			Plumbing
Craigmont Sr (2126) 1B	Sensor loop plugged on discharge line- very low pressure. Per GE report	9/12/13	Mechanical Room		Plumbing
Craigmont Sr (2126) 1B	strong sewer gas smell 1st and 2nd floors per Ms. Evans 416-4312	9/26/13			Plumbing
Craigmont Sr (2126) 1B	Test and repair RP Devices per MLG&W.	10/1/13	Mechanical Room		Plumbing

Craigmont Sr (2126) 1B	Water fountain in this lobby is hanging from the wall. It need to be repaird	10/22/13	2nd Floor	lobby next to room 104	Plumbing
Craigmont Sr (2126) 1B	The sink in this room is stoped up .I have tried to unstoped it but I couldn` t. It need to be repaird.	11/21/13	2nd Floor	room 117	Plumbing
Craigmont Sr (2126) 1B	Winterize RP device .	11/22/13			Plumbing
Craigmont Sr (2126) 1B	The sink in this room hot water is leaking bad , it need to be repaird. THANKS	5/20/14	2nd Floor	room 133	Plumbing
Craigmont Sr (2126) 1B	ceiling leaking above front desks	1/13/14	1st Floor	117	Roof
Craigmont Sr (2126) 1B	bad leak in cafeteria managers office	8/29/13	Kitchen	lower level	Roof
Craigmont Sr (2126) 1B	We have a roof leak on the landing leading to the weight rm	8/6/13	Stairway	leading to weight room	Roof
Craigmont Sr (2126) 1B	Just out side the laundry room and above the drop ceiling. AC duct has a large leak, duct is bent needs repair.	8/22/13	Gym	Just outside boys dressing room	Sheet Metal

Count of Craft	Craft				Grand Total
	Carpentry	Electrical	Painting	Plumbing	
Crump Stadium 180-1A	4	2	1	1	8
Grand Total	4	2	1	1	8

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Crump Stadium 180-1A	The goal post in the west end zone is tilted	8/28/13			Carpentry
Crump Stadium 180-1A	East endzone Goal Post is not straight, please repair Goal Post Near Cleveland Street	9/20/13	Athletic Field		Carpentry
Crump Stadium 180-1A	please add nuts and screws to pole vault standards for upcoming 2014 Track and Field Season. First track meet is 1 March	2/3/14	Athletic Field		Carpentry
Crump Stadium 180-1A	Please straighten out the goal post at the east end of the field. Someone was hanging on it over the weekend and it's twisted	4/29/14	Athletic Field		Carpentry
Crump Stadium 180-1A	Exhaust fan in concession stand area is broke, please repair	8/21/13	Athletic Field		Electrical
Crump Stadium 180-1A	north wall electrical outlet behind storage shelves in concessions stand area is not working, please repair. outlet has been taped for identification	8/21/13	Athletic Field		Electrical
Crump Stadium 180-1A	please paint the sector lines for the shot put pad. The sector lines are the "V" shape lines that participants use to gage when throwing the shot put and discus.	2/21/14	Athletic Field		Painting

Crump Stadium 180-1A	Stadiums were winterized in late fall, please bring the water back online for the upcoming soccer and track & field season. Track Season starts March 1, 2014 and Soccer Season starts February 27, 2014. CHECK WEATHER REPORT	2/24/14	Athletic Field		Plumbing
----------------------	---	---------	----------------	--	----------

Count of Craft	Craft								
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Cummings ES (2135) 1A	3	18	60	46	4	39	1	4	175
Grand Total	3	18	60	46	4	39	1	4	175

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Cummings ES (2135) 1A	Several pieces of tile are broken on Main Hallway TRIPPING HAZ THANKS	9/9/13	Administration Area	C Wing	Asbestos
Cummings ES (2135) 1A	Several pieces of tile is coming up on C/Wing hallway. TRIPPING HAZ, THANKS	11/13/13	Hallway/Corridor	C/Wing across from 106 C	Asbestos
Cummings ES (2135) 1A	Please have someone come out to replace several pieces of asbesto tile that are very loose. TRIPPING HAZ. THANKS	2/25/14	Classroom	201A	Asbestos
Cummings ES (2135) 1A	Principal requesting classrooms to have marker board. THANKS	8/12/13	Classroom	201A, 107A WING	Carpentry
Cummings ES (2135) 1A	Please have someone come out to replace damage ceiling tile in cafe. THANKS	8/13/13	Cafetorium	CAFE	Carpentry
Cummings ES (2135) 1A	Reinstall windows	8/21/13			Carpentry
Cummings ES (2135) 1A	Please have someone come out to fix exit door , hard to open and close. THANKS	8/23/13	Kitchen	Outside door	Carpentry
Cummings ES (2135) 1A	Having hard time opening and closing door.	8/23/13	1st Floor	Teacher lounge	Carpentry
Cummings ES (2135) 1A	Classroom door is very hard to open and close. THANKS (ISS ROOM)	8/29/13	Classroom	ISS ROOM	Carpentry

Cummings ES (2135) 1A	OUTSIDE WINDOW CANT SECURE 1ST FLR IN RM-102A. PLANT MGR- TAYLOR/315.4670	10/21/13				Carpentry
Cummings ES (2135) 1A	Repair window	11/6/13				Carpentry
Cummings ES (2135) 1A	Please have someone come out to fix swing door on main hallway that leads to front porch. Hinge is bent and door dose not close. THANKS	1/13/14	Hallway/Corridor	Main Hallway		Carpentry
Cummings ES (2135) 1A	Book store window needs handle to help raise window. THANKS	3/4/14	Hallway/Corridor	book store		Carpentry
Cummings ES (2135) 1A	Repair pump base	3/19/14				Carpentry
Cummings ES (2135) 1A	HANDRAIL 2ND FLR B WING MIDDLE SCH-STUDENTS WERE FIGHTING AND KNOCKED HANDRAIL LOOSE FROM WALL & NOW IT'S HANGING DOWN- SAFETY ISSUE-PLANT MGR TAYLOR/416.7860	3/31/14				Carpentry
Cummings ES (2135) 1A	WINDOW IS BROKEN OUT IN MAIN OFFICE PLANT MGR- TAYLOR/416.7860	4/7/14				Carpentry
Cummings ES (2135) 1A	DOOR WINDOW IS BROKEN OUT IN RM-102B PLANT MGR- TAYLOR/416.7810	4/7/14				Carpentry
Cummings ES (2135) 1A	Stall door is hanging off, THANKS	4/9/14	Restroom (Boys)	ACROSS FROM OFFICE		Carpentry
Cummings ES (2135) 1A	EXIT DOOR B-WING, CANT SECURE SCREWS CAME OUT PLANT MGR- TAYLOR/416.7860	4/9/14				Carpentry

Cummings ES (2135) 1A	Need someone to come out to repair cafe door thats cracks on 1st floor B/Wing, that leads to to back of cafe. THANKS	5/8/14	Cafetorium	Cafe on 1st floor B/WING IN THE BACK.	Carpentry
Cummings ES (2135) 1A	Please have someone repair door handle on 1st floor B/Wing cafe door. THANKS	5/19/14	Cafetorium	Cafe Door	Carpentry
Cummings ES (2135) 1A	Oil a/c unit first floor	6/12/14			Electrical
Cummings ES (2135) 1A	Oil a/c unit main floor	6/12/14			Electrical
Cummings ES (2135) 1A	Oil a/c unit westwing first floor	6/12/14			Electrical
Cummings ES (2135) 1A	Oil a/c unit westwing first floor	6/12/14			Electrical
Cummings ES (2135) 1A	replace computer outlet	6/12/14			Electrical
Cummings ES (2135) 1A	Replace motor a/c unit first floor hall	6/16/14			Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	6/25/14	Classroom	306 floor A/Wing, and3rd floor hallway	Electrical
Cummings ES (2135) 1A	Please have someone come out to reset school bell. THANKS	8/7/13	Administration Area	Main Office	Electrical

Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	8/12/13	Classroom	105B	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	8/12/13	Kitchen	cafe.	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	8/14/13	Classroom	201A	Electrical
Cummings ES (2135) 1A	Please have someone come out to replace several lights that are out on stage. THANKS	8/23/13	Cafetorium	stage	Electrical
Cummings ES (2135) 1A	FCU NOT COMING ON IN RM-107A. PLANT MGR- TAYLOR/416.7810	9/5/13			Electrical
Cummings ES (2135) 1A	Room 201A a/c not coming on per Ms. Taylor 416-3634	9/10/13			Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	9/13/13	Hallway/Corridor	Hallway 2nd floor A/wing	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballasts. THANKS	9/20/13	Administration Area	Hallway	Electrical
Cummings ES (2135) 1A	Several lights are out in classrooms. Needs 3 boxes of (F32T8/ADV841/EW, 25 Lamps, 28Watt. THANKS	9/20/13	Classroom	103A	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	9/23/13	Restroom (Girls)	C/Wing	Electrical

Cummings ES (2135) 1A	Pull Station Handler is broken, which sets the Fire Alarm per Ms. Taylor 416.3634	9/25/13				Electrical
Cummings ES (2135) 1A	CONDENSER PUMP-4 MECH RM-NOT COMING ON- PLANT MGR TAYLOR 416- 3634 KLR	10/1/13				Electrical
Cummings ES (2135) 1A	Several lights are out in classroom. THANKS	10/3/13	Classroom		103,306,307A/Wing	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	10/3/13	Classroom		102A/Wing	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	10/9/13	Classroom		306,307A/Wing	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	10/9/13	Administration Area		Teacher Lounge	Electrical
Cummings ES (2135) 1A	Orange outlet making loud humming sound. THANKS	10/9/13	Classroom		305A/Wing	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	10/9/13	Hallway/Corridor		1st floor B/Wing	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	10/9/13	Classroom		102A/Wing	Electrical
Cummings ES (2135) 1A	RECEPTACLE SHOOT OUT FIRE BACK KITCHEN BY WINDOW. PLANT MGR- TAYLOR/416.7860	10/15/13				Electrical

Cummings ES (2135) 1A	FCU NOT COOLING DUE TO SWITCH BROKEN IN RM-105B PLANT MGR-TAYLOR/416.7860	10/21/13				Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	11/6/13	Hallway/Corridor	2nd floor A/Wing		Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	11/6/13	1st Floor	105C/Wing		Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	11/18/13	Restroom (Girls)	Across from main office		Electrical
Cummings ES (2135) 1A	Lights out due to bad ballast. THANKS	11/26/13	Hallway/Corridor	2ND Floor A/Wing		Electrical
Cummings ES (2135) 1A	FCU IS OVERHEATING IN ISS AREA PLANT MGR-EASLEY/416.7860	12/18/13				Electrical
Cummings ES (2135) 1A	Light out due to bad ballast in hallway. THANKS	1/6/14	Hallway/Corridor	next to 306a		Electrical
Cummings ES (2135) 1A	1st row of lights keeps blinking on and off ballast needs to be change. THANKS	1/6/14	Classroom	306A		Electrical
Cummings ES (2135) 1A	Emergency Lights in kindergarten room needs battery. THANKS	1/22/14		102A WING		Electrical
Cummings ES (2135) 1A	Replace motor on air handler	2/10/14				Electrical

Cummings ES (2135) 1A	Rebuild motor	2/11/14				Electrical
Cummings ES (2135) 1A	FIRE ALARM IS SHOWING TROUBLE IN MAIN HALL . PLANT MGR- TAYLOR/315.4670	2/19/14				Electrical
Cummings ES (2135) 1A	FIRE ALARM IS SHOWING TROUBLE IN MAIN HALL . PLANT MGR- TAYLOR/315.4670	2/20/14				Electrical
Cummings ES (2135) 1A	Please have someone come out to change over school clocks due to daylight saving time on (MARCH 9,2014) THANKS	2/21/14	Administration Area	Main office		Electrical
Cummings ES (2135) 1A	Check fire alarm system	2/24/14				Electrical
Cummings ES (2135) 1A	UNIT SWITCH is BROKEN in ROOM 104C classroom per Ms. Taylor, Plant Mgr. 416.3634	3/6/14				Electrical
Cummings ES (2135) 1A	Repair pump	3/19/14				Electrical
Cummings ES (2135) 1A	No lights in restroom. (Bad ballast)	3/21/14	3rd Floor	Boys R/R Bldg B		Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	4/4/14	Classroom	104A		Electrical
Cummings ES (2135) 1A	Requesting 3 boxes of bulbs for CUMMING SCHOOL. THANKS	4/4/14	Administration Area	SBE OFFICE		Electrical

Cummings ES (2135) 1A	UNIT IS MAKING NOISE IN MAIN OFFICE. PIECES OF GLASS HAVE BEEN BROKEN & IS INSIDE THE UNIT PLANT MGR-TAYLOR/416.7860	4/7/14				Electrical
Cummings ES (2135) 1A	Orange sockets are not working in 305,309 A/WING. THANKS	4/7/14	Classroom		305A,309A WING	Electrical
Cummings ES (2135) 1A	Requesting 3boxes of ballast for Cummings School. THANKS	4/21/14	Administration Area		Main Office	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	4/22/14	Hallway/Corridor		1ST FLOOR B	Electrical
Cummings ES (2135) 1A	Please have someone come out to fix light switch that has an shortage. THANKS	4/23/14	Classroom		104 C	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast in 104 and 102 B. 102 also need one light cover. THANKS	4/23/14	Classroom		102, 104 B/WING	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	4/23/14	Classroom		101B, 201B	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	4/23/14	Classroom		306A, 307A	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	4/30/14	Classroom		106A	Electrical
Cummings ES (2135) 1A	Several lights are out due to bad ballast. THANKS	4/30/14	Administration Area		Guidance office	Electrical

Cummings ES (2135) 1A	Teacher has no power to her computer. THANKS	4/30/14		203A, CLASSROOM INSIDE CAFE.	Electrical
Cummings ES (2135) 1A	Please have someone come out to fix school bell that keeps ringing every 10 second. THANKS	5/28/14	Administration Area	Main Office	Electrical
Cummings ES (2135) 1A	Monthly - CUMMINGS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Filter-Cummings Elementary - Refer to PM schedule details.	7/16/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - Cooling Towers(STRAINERS)-Cummings Elem - Refer to PM schedule details.	3/8/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - Rod Chiller - Cummings Elementary - Refer to PM schedule details.	3/9/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Oil Lube & Belt-Cummings Elementary - Refer to PM schedule details.	8/25/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - Oil Samples-Cummings Elem - Refer to PM schedule details.	9/8/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Air Compressor - Cummings Elem - Refer to PM schedule details.	9/21/13			Heating/Ventilation /Air Conditioning

Cummings ES (2135) 1A	chiller is down per Ms. Anita Taylor 416-3634	9/30/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	chiller is down per anita taylor 416-3634	10/14/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	o/o to heat	10/18/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Filter-Cummings Elementary - Refer to PM schedule details.	11/12/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - Air Handler Cleanings-Cumming Elementary - Refer to PM schedule details.	12/16/13			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Unit is NOT HEATING in the Library per Ms. Taylor, Plant Mgr. 416.3634	1/6/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - Water-Cool Chiller Filter-Cummings Elem - Refer to PM schedule details.	1/21/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	UNIT NOT HEATING IN RM-LIBRARY PLANT MGR-TAYLOR/416.7860	1/29/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	purchase heaters for library	1/30/14			Heating/Ventilation /Air Conditioning

Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	2/2/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	install heaters in library	2/3/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - CUMMINGS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Filter-Cummings Elementary - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Air Compressor - Cummings Elem - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - Oil Lube & Belt-Cummings Elementary - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning

Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	principal's office a/c not coming on per ms taylor 416-3634	4/2/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - CUMMINGS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	CHILLER NOT COMING ON PLANT MGR-TAYLOR/315.4670	4/4/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	check cooling tower level	4/7/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	clean glass out of unit	4/8/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	cooling tower flooding per ms taylor 416-3634	4/8/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	CHILLER MECH RM-NOT COMING ON-PLANT MGR TAYLOR 416-3634 KLR	4/14/14			Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	UNIT NOT COMING ON IN RM-101B PLANT MGR-TAYLOR/416.7860	4/23/14			Heating/Ventilation /Air Conditioning

Cummings ES (2135) 1A	CHILLER - NOT COMING ON - PM/TAYLOR 416-3634	4/24/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	4/27/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Monthly - CUMMINGS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	repair filtertracks on hall units	5/6/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	5/11/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Daily - Cummings Elem Level 1 Water Treatment - Refer to PM schedule details.	5/25/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - #2 Boiler 003- Cummings-Basement Blr Rm - Refer to PM schedule details.	3/7/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Yearly - Boiler 002 - Cummings El-Basement Blr Rm - Refer to PM schedule details.	3/11/14				Heating/Ventilation /Air Conditioning
Cummings ES (2135) 1A	Principal requesting for 1st and 2nd floor B/Wing hallway to be painted. THANKS	8/12/13	Classroom	B/Wing		Painting
Cummings ES (2135) 1A	Principal requesting to have 103B painted, due to peeling paint in classroom. THANKS	8/12/13	Classroom	103B		Painting

Cummings ES (2135) 1A	GRAFFITI - PARKING LOT ENTRY -GANG RELATED - ON ALL DR AND ON OUTSIDE OF BLDG ON BRICK - PM/TAYLOR 416-3634	5/20/14				Painting
Cummings ES (2135) 1A	GRAFFITI - FRONT OF SCH ON BRICK - GANG RELATED - PM/TAYLOR 416-3634	5/21/14				Painting
Cummings ES (2135) 1A	Check water flow a/c coil,second floor west hall	6/16/14				Plumbing
Cummings ES (2135) 1A	WATER HEATER KITCHEN MECH RM-HAS BURST AND WATER EVERYWHERE-SBE TAYLOR 416-3634 KLR	8/1/13				Plumbing
Cummings ES (2135) 1A	Please have someone to check water pressure in water fountain. THANKS	8/12/13	Hallway/Corridor	C/Wing		Plumbing
Cummings ES (2135) 1A	Hand sink on boys side is leaking underneath. THANKS	8/14/13	Hallway/Corridor	1st. floor B/Wing		Plumbing
Cummings ES (2135) 1A	Water fountain is leaking underneath. THANKS	8/14/13	Hallway/Corridor	2nd. floor B/Wing		Plumbing
Cummings ES (2135) 1A	cooling tower is overflowing per anita taylor 416-3634	10/14/13				Plumbing
Cummings ES (2135) 1A	Please have someone come out to unstop urinal. THANKS	10/15/13	Restroom (Boys)	1st. floor A/Wing		Plumbing
Cummings ES (2135) 1A	Faucet leaking. THANKS	10/16/13	Kitchen	Kitchen		Plumbing

Cummings ES (2135) 1A	no hot water in the kitchen per Ms. Taylor 416-3634	10/17/13				Plumbing
Cummings ES (2135) 1A	Faucet handle broken. THANKS	10/17/13	Kitchen	Kitchen		Plumbing
Cummings ES (2135) 1A	Both water fountain on C/Wing are leaking underneath next to boys restroom. THANKS	10/25/13	Hallway/Corridor	C/Wing		Plumbing
Cummings ES (2135) 1A	Water fountain is leaking underneath. THANKS	10/25/13	Administration Area	Teacher Lounge		Plumbing
Cummings ES (2135) 1A	WATER FOUNTAIN C WING- LEAKING FROM BEHIND FTN THRU WALL-PLANT MGR TAYLOR 416-3634 KLR	11/12/13				Plumbing
Cummings ES (2135) 1A	Commode is stopup in girls restroom 2nd stall. THANKS	11/21/13	Restroom (Girls)	2nd floor A/Wing		Plumbing
Cummings ES (2135) 1A	1st stall keeps leaking underneath. THANKS	11/26/13	Restroom (Girls)	1st floor B/Wing		Plumbing
Cummings ES (2135) 1A	2nd stall keeps leaking underneath. THANKS	11/26/13	Restroom (Girls)	C/Wing		Plumbing
Cummings ES (2135) 1A	1st stall keeps leaking underneath. THANKS	11/26/13	Restroom (Boys)	C/Wing		Plumbing
Cummings ES (2135) 1A	per Ms. Taylor 416-3634 in the kitchen the 3 compartment sink is backing up overflowing	11/10/14				Plumbing

Cummings ES (2135) 1A	Urinal on 2nd floor A/Wing is leaking underneath. THANKS	1/16/14	Restroom (Boys)	2nd floor A/Wing	Plumbing
Cummings ES (2135) 1A	Last stall keeps over flowing. THANKS	1/16/14	Restroom (Girls)	1st floor A/Wing, 2ND FLOOR a/WING	Plumbing
Cummings ES (2135) 1A	replace shaft and bearings on library unit	2/10/14			Plumbing
Cummings ES (2135) 1A	Check room for odor	2/13/14			Plumbing
Cummings ES (2135) 1A	PILOT needs LIGHTING in the KITCHEN AREA per Ms. Taylor, Plant Mgr. 416.3634	2/24/14			Plumbing
Cummings ES (2135) 1A	On/Off handle for sink is stripped.	3/19/14	1st Floor	Teachers Lounge	Plumbing
Cummings ES (2135) 1A	1st stall toilet stopped up	3/19/14	3rd Floor	Boys restroom	Plumbing
Cummings ES (2135) 1A	Urinal not flushing	3/19/14	3rd Floor	Boys restroom	Plumbing
Cummings ES (2135) 1A	2nd stall toilet stopped up	3/19/14	2nd Floor	Girls restroom	Plumbing
Cummings ES (2135) 1A	Water keeps overflowing. THANKS	4/9/14	Administration Area	PRINCIPAL RESTROOM	Plumbing

Cummings ES (2135) 1A	Test and report on backflow prevention devices.	4/11/14				Plumbing
Cummings ES (2135) 1A	COOLING TOWER OVERFLOWING-PLANT MGR TAYLOR 416-3634 KLR	4/14/14				Plumbing
Cummings ES (2135) 1A	Please have someone come out to fix faucet will not come on. THANKS	4/17/14	1st Floor	Teacher lounge C/WING		Plumbing
Cummings ES (2135) 1A	Faucet on 3rd floor A/wing is very hard to turn off. THANKS	4/17/14	3rd Floor	Hand Sink A/WING		Plumbing
Cummings ES (2135) 1A	Commode keeps stopping up. THANKS	4/21/14	Administration Area	Assistant Principal Office		Plumbing
Cummings ES (2135) 1A	Test and report on backflow prevention devices.	4/22/14				Plumbing
Cummings ES (2135) 1A	Requesting plumber and electrician, to remove old disposer and hook up new disposer that's already at school. THANKS	4/30/14	Kitchen	Kitchen		Plumbing
Cummings ES (2135) 1A	Water fountain leaking underneath. THANKS	4/30/14	Hallway/Corridor	1st floor B/WING		Plumbing
Cummings ES (2135) 1A	Need someone to check roof drain for stoppage. THANKS	5/5/14	Mechanical Room	SBE OFFICE		Plumbing
Cummings ES (2135) 1A	Repair back flow	5/15/14				Plumbing

Cummings ES (2135) 1A	3-COMPARTMENT SINK KITCHEN AREA-ALL (3) SIDES ARE STOPPED UP- PLANT MGR TAYLOR 416- 7360 KLR	5/15/14			Plumbing
Cummings ES (2135) 1A	Rain is coming inside office next to window . THANKS	2/10/14	Administration Area	Assistant Principal Office	Roof
Cummings ES (2135) 1A	Check a/c pan 302A	6/13/14			Sheet Metal
Cummings ES (2135) 1A	Repair a/c pan	6/17/14			Sheet Metal
Cummings ES (2135) 1A	Please install metal flashing around pipe. THANKS	2/28/14	Classroom	101A	Sheet Metal
Cummings ES (2135) 1A	Fabricate box cover	5/14/14			Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Delano ES (2145) 1B	1	1	22	60	61	4	51	7	2	209
Grand Total	1	1	22	60	61	4	51	7	2	209

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
Delano ES (2145) 1B	portable 102 has spots in the ceiling that looks as if it is mold. The ceiling tile needs to be replaced, the ceiling tile is not the regular tile the schools are provided with. it is a large square.	2/7/14	Portables		portables 102	Asbestos
Delano ES (2145) 1B	There is a wire that is hanging from the front of the building. Support WO # 409910, electrical craftman Joe Kisner said looks like a cable wire (low volt). Thank you.	1/24/14	Grounds			Cabbling
Delano ES (2145) 1B	PORTABLE#100 WINDOW IS COMING OUT AND THE BLDG CANNOT BE SECURED. SBE JEFFERSON 416-3932	7/3/13				Carpentry
Delano ES (2145) 1B	the entrance door that is on the west end of the building is not securing at all time. it has been called in a couple of times, however, the problem was not found during those times. the door bar is broken. it is not allowing teachers and staff to assess the building	5/23/14	1st Floor		west end of the building	Carpentry
Delano ES (2145) 1B	Door knob comes off	8/21/13	1st Floor		Boiler rm	Carpentry
Delano ES (2145) 1B	Planks to entrance loose	8/23/13	Annex		portable 99 (west side)	Carpentry
Delano ES (2145) 1B	Portable door will not close all the way	9/9/13	Portables		Port. 102	Carpentry

Delano ES (2145) 1B	Door do not close properly	9/12/13	1st Floor	West entrance	Carpentry
Delano ES (2145) 1B	Portable door still not closing properly	9/19/13	Portables	Rm. 102	Carpentry
Delano ES (2145) 1B	there are several stalls that are rotten, inside the boy's restroom on the 2nd floor. there is a need to be repaired or replaced	12/18/13	Restroom (Boys)	2nd floor boy's restroom	Carpentry
Delano ES (2145) 1B	The cafeteria back door will NOT close (door is NOT secure) per Ms. Easley, Plant Mgr. 416.3932	1/6/14			Carpentry
Delano ES (2145) 1B	Back CAFETERIA door WILL NOT OPEN per Ms. Beasley, Plant Mgr. 416.3932	1/7/14			Carpentry
Delano ES (2145) 1B	the rear cafeteria door to the parking lot needs a weather scrip.	1/7/14	Cafeteria	cafeteria door to back parking lot	Carpentry
Delano ES (2145) 1B	there is a piece of metal that is sticking out of the stairwell rails. this is a safety issue for the students.	1/22/14	Portables	Portables 99	Carpentry
Delano ES (2145) 1B	DOOR PORT 102-NOT LOCKING, WON'T BE ABLE TO SECURE-PLANT MGR EASELY 416-3932 KLR	1/24/14			Carpentry

Delano ES (2145) 1B	the back door to the rear entrance of the cafeteria needs a weather protection to help prevent the water from coming inside of the kitchen area. the standing water could cause a mark against the cafeteria staff score. please help, thanks!	2/4/14	Cafeteria	the rear door to the outside entrance	Carpentry
Delano ES (2145) 1B	the window sill in the main office needs to be recloak. there is alot of outdoor air coming into the building, right on the office staff.	2/5/14	Administration Area	main office	Carpentry
Delano ES (2145) 1B	portable 100 has a large cut into the side of the portable, which looks like an attempt to break in. it is located on the side near the cafeteria	2/7/14	Portables	portable 100	Carpentry
Delano ES (2145) 1B	there are about 4 lockers that needs to be repaired, this is inside of classroom 202.	2/14/14	Classroom	classroom 202	Carpentry
Delano ES (2145) 1B	the door to portable 102 will not close completely.	2/24/14	Portables	portable 102	Carpentry
Delano ES (2145) 1B	the staircase to the back of portable 100 is coming loose from the portable. this portable also has a couple of areas that looks as if someone or something has been tampering with it, it is cut and pulled from the portable.	3/20/14	Portables	portable 100	Carpentry
Delano ES (2145) 1B	the sink in the restroom that is inside of the main office is coming from the wall. it needs to be sealed or replaced.	3/31/14	Administration Area	main office	Carpentry
Delano ES (2145) 1B	there was painting going on here at Delano before I became Plant Manager, however, in the process of moving the principal desk got broken. She is requesting that it be repaired.	7/15/13	Administration Area	the principal office	Carpentry

Delano ES (2145) 1B	the rope to the curtains on the stage inside the cafeteria is broken.	12/18/13	Cafeteria	on the stage	Carpentry
Delano ES (2145) 1B	change receptacle for ptac unit in main office --- plug up and turn on	6/25/14			Electrical
Delano ES (2145) 1B	CHILLER - NOT COMING ON - PM/EASLEY 416-3932	6/25/14			Electrical
Delano ES (2145) 1B	there are several bad ballast in the cafeteria.	7/23/13	Cafeteria	cafeteria	Electrical
Delano ES (2145) 1B	there is a ballast out in the teacher's lounge.	7/23/13	Administration Area	teacher's lounge	Electrical
Delano ES (2145) 1B	there is no power(outlets/lights) inside classroom 201 and 204. tried switch box still didn't work	7/12/13	Classroom	classrooms 201 and 204	Electrical
Delano ES (2145) 1B	there are some wires hanging down from the building on the eastend near portable 102, the cafeteria part of the building.	5/8/14	Courtyard	outside of cafeteria eastend near portable 102	Electrical
Delano ES (2145) 1B	there is a bad ballast in the light fixture inside the cafeteria near the front of the stage.	5/27/14	Cafeteria	cafeteria	Electrical

Delano ES (2145) 1B	the bells needs to be turned off during the summer. I do not have a key.	5/30/14	Administration Area	main office	Electrical
Delano ES (2145) 1B	RECEPTACLES HAVE NO POWER IN RM-201,204. PLANT MGR-EASLEY/552.6226	7/25/13			Electrical
Delano ES (2145) 1B	we need 3 oxes of t8 lamps(sp). there is a light fixture inside the cafeteria by the entrance from the hallway ballast bad.	7/31/13	Cafeteria	inside the cafeteria by the entrance door from hal	Electrical
Delano ES (2145) 1B	there is a couple of ballast that are bad on the 1st floor hallway near the southwest end of the bldg.	7/31/13	Hallway/Corridor	1st floor hallway	Electrical
Delano ES (2145) 1B	there is a bad ballast in the hallway right at the main entrance.	8/1/13	Hallway/Corridor	at the main entrance	Electrical
Delano ES (2145) 1B	the school bells need to be reset to the new times. 1st 7:30 a.m. 2nd 7:45 a. m. 3rd 8:00 a. m. 4th 2:45 p.m. 5th 3:00 p.m.	8/5/13	Administration Area	main office	Electrical
Delano ES (2145) 1B	there are a couple of ballast that are out in classroom 201 on the 2nd floor.	8/14/13	Classroom	classroom 201 on the 2nd floor	Electrical
Delano ES (2145) 1B	Bad ballast	8/23/13	1st Floor	Teacher lounge	Electrical

Delano ES (2145) 1B	Plug on Laminating machine burned out	8/26/13	2nd Floor	Copy room	Electrical
Delano ES (2145) 1B	Outside light to back entrance is blown	8/28/13	Parking Lot	Outside back entrance	Electrical
Delano ES (2145) 1B	A/C MAIN OFC-NOT COOLING-PLANT MGR PATTERSON KLR	9/10/13			Electrical
Delano ES (2145) 1B	Bad ballast	9/13/13	2nd Floor	205	Electrical
Delano ES (2145) 1B	Lights/ballast 3 out library.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 1 light out rm 205.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 2 out rm 210.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 1 out 2nd floor near 208.	9/18/13			Electrical

Delano ES (2145) 1B	Lights/ballast 1 out need cover rm 204.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 2 out rm 201.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 1 out rm 102.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 2 out rm 107.	9/18/13			Electrical
Delano ES (2145) 1B	Lights/ballast 1 out rm103.	9/18/13			Electrical
Delano ES (2145) 1B	Bad ballast	9/25/13	Portables	portable #100	Electrical
Delano ES (2145) 1B	Need to get bells ring time reset	10/3/13	1st Floor	Main office	Electrical
Delano ES (2145) 1B	Light switch has short in it	10/14/13	2nd Floor	Teachers workroom	Electrical

Delano ES (2145) 1B	Need to get bell ringing reset	10/23/13	1st Floor	main office	Electrical
Delano ES (2145) 1B	Need to get master clock set to DST	11/4/13	1st Floor	Main office	Electrical
Delano ES (2145) 1B	Bad ballast	11/20/13	Portables	portable #100	Electrical
Delano ES (2145) 1B	Exit sign need to be put back on the wall	11/20/13	1st Floor	East exit	Electrical
Delano ES (2145) 1B	Outside lights to back entrance, West entrance and front of bldg need replacing. Need Bucket truck to get to lights.	11/27/13	Parking Lot	grounds	Electrical
Delano ES (2145) 1B	there is an outlet that is located next to the SBE office across from the trophy case, that is loose.	12/9/13			Electrical
Delano ES (2145) 1B	inside of classroom 203, the switch is sticking. this is causing for the useage of half of the lighting inside that classroom.	12/11/13	Classroom	classroom 203	Electrical
Delano ES (2145) 1B	there is an outlet that is going bad inside the computer lab room 112.	1/6/14	Classroom	classroom computer lab 112	Electrical

Delano ES (2145) 1B	the light outside of the entrance door on the west side of the bldg is out.	1/10/14		west wing outside of the bldg.	Electrical
Delano ES (2145) 1B	the clock on the 1st floor hallway near the main office needs to be set.	1/13/14	Hallway/Corridor	1st floor hallway near the main office	Electrical
Delano ES (2145) 1B	there is a live wire that is hanging from the front of the building, that needs to be secured.	1/21/14	Grounds	front of the building	Electrical
Delano ES (2145) 1B	there is an exit light that is coming off of the wall. it is broken from the wall.	1/24/14	Hallway/Corridor	on the 1st floor east end	Electrical
Delano ES (2145) 1B	there are some wires hanging from the ceiling in boy's restroom on the 1st floor. these wires are left exposed and are hanging from the ceiling.	2/3/14	Restroom (Boys)	boy's restroom on the 1st floor	Electrical
Delano ES (2145) 1B	there are several clocks inside of the classrooms that are working, we also have some classrooms that do not have clocks. And the clocks in the hallway facing the east side of the building they are not working.	2/10/14	Classroom	several classrooms 1st & 2nd floors	Electrical
Delano ES (2145) 1B	there is a light fixture that ballast is burning inside of classroom 111.	2/13/14	Administration Area	Room 111	Electrical
Delano ES (2145) 1B	there is a light fixture that ballast is bad.	2/14/14	Classroom	classroom 108	Electrical

Delano ES (2145) 1B	MAIN CLOCK NEED TO BE RESET PLANT MGR-EASLEY/5526226	2/17/14			Electrical
Delano ES (2145) 1B	there is a light pole next to portable 100 where the light does not work.	2/25/14	Grounds	parking lot near the cafeteria	Electrical
Delano ES (2145) 1B	there are some clock that need to be reset for daylight saving time.	3/7/14	Hallway/Corri dor	thru out the school	Electrical
Delano ES (2145) 1B	there are few classrooms and admin. areas that do not have clocks, I did recieves 5 clocks already, however, there are still more needed. based on the count there are 5 more needed. Thanks!!	3/7/14	Classroom	on the 1st & 2nd floors	Electrical
Delano ES (2145) 1B	there are three light fixture where the ballast are bad, all are in the caferia.	3/12/14	Cafeteria	cafeteria 1st floor	Electrical
Delano ES (2145) 1B	the light fixtures in the stairway at the bottom of the staircase has bad ballast.	3/17/14	Hallway/Corri dor	in the stairway northwest of the bldg.	Electrical
Delano ES (2145) 1B	there is a light fixture that the light bulb is out, this job is calling for a 12ft. or higher ladder.	3/25/14	Cafeteria	cafeteria in front of the stage	Electrical
Delano ES (2145) 1B	the door in the northwest stairway, will not hold to the magnet.	3/27/14	Hallway/Corri dor	northwest stairway	Electrical

Delano ES (2145) 1B	there is a light fixture with a bad ballast.	3/27/14	Classroom	classroom 206	Electrical
Delano ES (2145) 1B	per ms easley 416-3932 vent a hood over stove in kitchen is not working	4/9/14			Electrical
Delano ES (2145) 1B	Outside lights to back entrance, West entrance and front of bldg need replacing. Need Bucket truck to get to lights.	9/19/13	Parking Lot	grounds	Electrical
Delano ES (2145) 1B	both 1st and 2nd floors hallways and classrooms need light bulbs. F32T8/SPX41/ECO=36	7/24/13	Hallway/Corridor	hallways and classrooms	Electrical
Delano ES (2145) 1B	there are some classrooms that needs light bulbs.	7/23/13	Classroom	1st & 2nd floors classrooms	Electrical
Delano ES (2145) 1B	main office not cooling	6/23/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CHILLER - IS NOT WORKING - PM/EASLEY 416-3932	6/24/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CHILLER - NOT COMING ON AGAIN PM/EASLEY 416-3932	6/26/14			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	CHILLER is NOT COMING ON per Ms. Easley, Plant Mgr. 416.3932	6/30/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Entire school no a/c chiller down #014047 per ms. easley 416-3932	7/22/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	A/C UNIT is OVER COOLING in ROOM 108 per Wanda Easley, Plant Mgr. 416.3932	4/25/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	A/C RM 108 BLOWING TOO COLD-TEMP IS 68 & A/C RM 107 BLOWING TOO COLD-TEMP IS 66-PLANT MGR EASELY 416-3932 KLR	4/29/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UNIT NOT COOLING IN RM-203 PLANT MGR-EASLEY/552.6226	5/5/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CHILLER - NOT COMING ON - ENTIRE SCHOOL IS HOT PM/EASLEY 416-3930	5/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	clean chiller	5/8/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	chiller down	5/9/14			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	chiller down	5/14/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Monthly - Oil Lube & Belt-Corning Elem - Refer to PM schedule details.	5/18/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	there is a odor that is coming from the a/c unit inside the main office. the unit needs to be serviced.	5/21/14	Administration Area	main office	Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	A/C MAIN OFC AREA-NOT COOLING-PLANT MGR EASELY 416-3932 KLR	5/27/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	chiller down	5/28/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	main office not cooling	6/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	princ. ofc not cooling	6/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	clean ptac in main ofc	6/6/14			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	clean ptac in princ. ofc	6/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Reset Chiller.	6/9/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	chiller down	6/12/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CHILLER - NOT COMING ON - PM/EASLEY 416-3932	6/13/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	chiller down	6/18/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UNIT IN THE MAIN OFFICE IS NOT COOLING. SBE EASLEY 416-3932	8/2/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UNIT IN RM 210 IS LEAKING. . SBE EASLEY 416-3932	8/2/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Monthly - Filter-Delano Elementary - Refer to PM schedule details.	8/5/13			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	Unit NOT COOLING in Room 206 per Ms. Easley, Plant Mgr. at 901.416.3932	8/7/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UV MAIN OFC OUTSIDE WALL-NOT COOLING-SBE EASELY 416-3932 KLR	8/8/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	put pumps in auto	10/8/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Monthly - Oil Lube & Belt-Corning Elem - Refer to PM schedule details.	10/13/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CAFE NE TEMP 87, RM 102 TEMP 74, & RM 104 TEMP 77-ALL ARE OVERHEATING PER SBE-PLANT MGR PATTERSON 416-3932 KLR	10/25/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	BOILER IS IN ALARM. PLANT MGR-PATTERSON/416.3932	11/11/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	2 units in cafeteria not heating per mr. patterson 416-3932	11/12/13			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	2-AHU NOT HEATING IN CAFE PLANT MGR-PATTERSON/416.3932	11/13/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CHILLER-1 IS IN ALARM-PLANT MGR PATTERSON 416-3932 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	BOILER-1-IS IN ALARM-PLANT MGR PATTERSON 416-3932 KLR	11/15/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	room 108, 110 blowing cold air per Ms Easley 416-3932	11/25/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	BOILER IS MAKING NOISE PLANT MGR-EASLEY/552.6226	12/3/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Monthly - Filter-Delano Elementary - Refer to PM schedule details.	12/9/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	HEAT RM 210, 203, & 207-ALL NOT HEATING-PLANT MGR EASELY 416- 3932 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	Yearly - Air Handler Cleanings-Delano Elementary - Refer to PM schedule details.	12/13/13			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	The unit that controls the Serving Line in the Cafeteria and Gym Classroom (right next to cafeteria) is NOT HEATING per Ms. Easley, Plant Mgr. 416.3932	1/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	HEAT CAFE LAST UNIT-OVERHEATING. TEMP IS 77-PLANT MGR EASELY 416-3932 KLR	1/14/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	boiler is down per Ms. Easley 416-3932	1/22/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UNIT NOT HEATING IN RM-208 PLANT MGR-EASLEY/552.6226	2/5/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UV NOT HEATING IN RM-206 PLANT MGR-EASLEY/416.3932	2/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	BOILER MAKING NOISE. PLANT MGR-EASLEY/552.6226	2/14/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	CHILLER - NOT COMING ON - PM/EASLEY 416-3932	2/17/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	UNIT NOT HEATING IN LIBRARY PLANT MGR- EASLEY/416.3932	2/18/14			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	boiler down	2/26/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	HEAT RM 207 & 210-BOTH NOT HEATING-PLANT MGR EASELY 416-3932 KLR	2/26/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	boiler down	2/26/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	BOILER-1 MECH RM-IN ALARM-PLANT MGR EASELY 416-3932 KLR	2/27/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	boiler down	3/5/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	boiler down	3/6/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	check boiler --- Bldg has been without power	3/11/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning

Delano ES (2145) 1B	Monthly - Filter-Delano Elementary - Refer to PM schedule details.	4/7/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	A/C MAIN OFC AREA-NOT COOLING-PLANT MGR EASELY 416-3932 KLR	6/19/14			Heating/Ventilation /Air Conditioning
Delano ES (2145) 1B	on the rear and east side of the parking lots, the parking lines are gone in many spaces. please repaint the park lines in the parking lot.	4/24/14	Grounds	rear and east side of the parking lot	Painting
Delano ES (2145) 1B	GRAFFITI OUTSIDE ON PORT 102-PLANT MGR EASELY 416-3932 KLR	12/18/13			Painting
Delano ES (2145) 1B	[PAINT CEILING IN PORTABLE BLDG 120?	2/17/14			Painting
Delano ES (2145) 1B	there is a space on the hallway wall that needs to be painted. this space came about after an object was removed from the wall. the walls have been repainted, however, this space is a real eye catcher.	3/25/14	Hallway/Corridor	1st floor hallway next classroom	Painting
Delano ES (2145) 1B	UNIT VENT 014-068 - RM 201 - LEAKING BAD - PM/EASLEY 416-3932	7/24/13			Plumbing
Delano ES (2145) 1B	Check toilets.	7/3/13			Plumbing

Delano ES (2145) 1B	Unit Ventilator ID#014-058 leaking in Front part of Room #101 per Ms. Beasley, Plant Mgr. 901.416.3932.	7/12/13			Plumbing
Delano ES (2145) 1B	there is a leak in the teachers' lounge from the a/c unit. FYI-- before this request was made Mr. Joe repaired, he was over on an emergency call when asked about the a/c unit.	7/15/13	Administration Area	teachers' lounge 1st floor	Plumbing
Delano ES (2145) 1B	there is a leak in a/c unit located inside the library. the equipment number is 014-079.	7/15/13	Library	2nd floor	Plumbing
Delano ES (2145) 1B	on both floors and the stairwells, the heating vents needs some more installation around the pipes.	7/15/13	Hallway/Corridor	1st and 2nd floors	Plumbing
Delano ES (2145) 1B	the drainage outside by an entrance is stopped up.	6/23/14	Grounds	outside drainage	Plumbing
Delano ES (2145) 1B	the second urinal in the boy's restroom on the 1st floor is stopped up.	4/28/14	Restroom (Boys)	1st floor boy's restroom	Plumbing
Delano ES (2145) 1B	STEAM NEEDS TO BE LIT IN KITCHEN PLANT MGR-EASLEY/416.3932	4/29/14			Plumbing
Delano ES (2145) 1B	A/C LIBRARY AREA-LEAKING- PLANT MGR EASELY 416-3932 KLR	5/1/14			Plumbing

Delano ES (2145) 1B	SINK EAST END OF 1ST FLR HALLWAY-VALVES MAKING A NOISE-PLANT MGR EASELY 416-3932 KLR	5/1/14			Plumbing
Delano ES (2145) 1B	STEAMTABLE SERVING LINE AREA- PILOT NEEDS TO BE LIT-LEAD RHODES 416-3932 KLR	5/6/14			Plumbing
Delano ES (2145) 1B	there are two urinals that are constantly flushing.	5/28/14	Restroom (Boys)	2nd floor boy's restroom	Plumbing
Delano ES (2145) 1B	the mop sink stopped up in the 2nd floor boy's restroom.	6/9/14	Restroom (Boys)	2nd floor boy's restroom	Plumbing
Delano ES (2145) 1B	there are three urinals in the boy's restroom on the 2nd floor that are stopped up.	6/11/14	Restroom (Boys)	2nd floor boy's restroom	Plumbing
Delano ES (2145) 1B	there are a couple of areas where the pipes are leaking causing the ceiling tile to soil.	6/13/14	Cafeteria	cafeteria	Plumbing
Delano ES (2145) 1B	there is a continue leak in the sink inside of the teacher's lounge restroom.	7/25/13	Administration Area	teacher's lounge	Plumbing
Delano ES (2145) 1B	Gas smell in cafeteria per easley 416-3932	7/31/13			Plumbing

Delano ES (2145) 1B	the sink in the kitchen area has a bad leak. near the receiving line.	7/31/13	Cafeteria	kitchen area	Plumbing
Delano ES (2145) 1B	GREASE TRAP IS BACKING UP IN KITCHEN PLANT MGR-EASLEY/416.3932	8/6/13			Plumbing
Delano ES (2145) 1B	Gas smell in cafeteria per Ms. Easley 416-3932	8/6/13			Plumbing
Delano ES (2145) 1B	UV IS LEAKING IN RM-202(069) . PLANT MGR-EASLEY/416.3932	8/12/13			Plumbing
Delano ES (2145) 1B	UV RM 211 (210)-LEAKING-SBE EASELY 416-3932 KLR	8/13/13			Plumbing
Delano ES (2145) 1B	there is a toilet in the girl's restroom that keeps on flushing. it is the toilet in the 2nd stall from the window.	8/13/13	Restroom (Girls)	1st floor near the teachers lounge	Plumbing
Delano ES (2145) 1B	VENTILATION SYSTEM SERVING LINE-LEAKING-PLANT MGR PATTERSON 416-3932 KLR	8/19/13			Plumbing
Delano ES (2145) 1B	Toilet flushing slowly	8/23/13	1st Floor	Teacher lounge	Plumbing

Delano ES (2145) 1B	Sink leaking	8/27/13	Kitchen	south wall	Plumbing
Delano ES (2145) 1B	A/C RM 207-LEAKING-PLANT MGR PATTERSON 416-3932 KLR	8/29/13			Plumbing
Delano ES (2145) 1B	Water dripping from over head pipe	8/30/13	Kitchen	Cafe mgr office	Plumbing
Delano ES (2145) 1B	GAS SMELL IN KITCHEN OVEN. PLANT MGR-PATTERSON/416.3932	9/4/13			Plumbing
Delano ES (2145) 1B	STEAM TABLE NEEDS TO BE LIT. PLANT MGR-PATTERSON/416.3932	9/6/13			Plumbing
Delano ES (2145) 1B	Toilet stopped up	9/12/13	1st Floor	Girls restroom	Plumbing
Delano ES (2145) 1B	Water dripping from overhead pipe	9/13/13	1st Floor	Teachers lounge	Plumbing
Delano ES (2145) 1B	Hand sink leaking	9/16/13	1st Floor	By teachers lounge	Plumbing

Delano ES (2145) 1B	Toilet constantly runs	9/19/13	1st Floor	Girls restroom	Plumbing
Delano ES (2145) 1B	Hand sink constantly leaking	9/30/13	2nd Floor	Boys restroom	Plumbing
Delano ES (2145) 1B	Urinal not flushing	10/3/13	2nd Floor	Boys restroom	Plumbing
Delano ES (2145) 1B	KITCHEN AREA-SMELLS GAS WHEN OVEN OR STEAMER IS TURNED ON-PLANT MGR PATTERSON KLR	11/4/13			Plumbing
Delano ES (2145) 1B	Toilet seat broken	11/6/13	2nd Floor	Girls restroom	Plumbing
Delano ES (2145) 1B	Hand sink constanly dripping	11/7/13	1st Floor	main hall	Plumbing
Delano ES (2145) 1B	there is a toilet seat that needs to be replaced in the 4th stall of the girl's restroom on the 1st floor.	12/9/13	1st Floor	1st floor girl's restroom	Plumbing
Delano ES (2145) 1B	GAS SMELL KITCHEN AREA-PLANT MGR EASELY 416-3932 KLR	1/6/14			Plumbing

Delano ES (2145) 1B	the toilet inside the teachers lounge restroom will not flush at all times. usually that first flush has a delayed reaction.	1/7/14	Administration Area	1st floor teachers lounge	Plumbing
Delano ES (2145) 1B	per ms easley 416-3932 room 102 sink water is continuously running and has flooded classroom	2/3/14			Plumbing
Delano ES (2145) 1B	the toilets in both the teacher's lounge and room 111 are both flushing slowly and filling up with water. it is like something is inside the drainage.	2/14/14	Administration Area	teacher's lounge and room 111 restrooms	Plumbing
Delano ES (2145) 1B	the toilet in the 2nd stall of the girl's restroom on the 1st floor will not flush.	3/4/14	Restroom (Girls)	1st floor girl's restroom	Plumbing
Delano ES (2145) 1B	there is a leak coming from the pipes to the a/c unit.	3/17/14	Classroom	classroom 102	Plumbing
Delano ES (2145) 1B	the hand sink in the hallway on the 1st floor is leaking.	3/18/14	Hallway/Corridor	1st floor eastend	Plumbing
Delano ES (2145) 1B	per ms easley 416-3932 there is a gas smell in the kitchen	4/9/14			Plumbing
Delano ES (2145) 1B	the hand washing sinks on both ends need to be repaired. the one on the east end is constantly running and the one on the west end one of the faucet not coming on at all.	4/15/14	Hallway/Corridor	the west and east end	Plumbing

Delano ES (2145) 1B	the water fountain on the 1st floor of the west end of the building needs the stop replaced.	4/23/14	Hallway/Corridor	1st floor west end of the bldg.	Plumbing
Delano ES (2145) 1B	there is a leak in the ceiling in the cafeteria, near the east by the window.	5/30/14	Cafeteria	cafeteria	Roof
Delano ES (2145) 1B	there is a leak in the window in the stairwell at the west side of the building.	2/5/14	Hallway/Corridor	west side stairwell window	Roof
Delano ES (2145) 1B	Repair roof Port. # 102	2/14/14			Roof
Delano ES (2145) 1B	there is a leak inside the cafeteria east end near the first window by the stage.	2/17/14	Cafeteria	the cafeteria	Roof
Delano ES (2145) 1B	there is a bad leak inside of classroom 206, this leak has a brownish color to it.	3/7/14	Classroom	classroom 206	Roof
Delano ES (2145) 1B	there is a leak from the ceiling inside of classroom 204.	3/17/14	Classroom	classroom 204	Roof
Delano ES (2145) 1B	there is a leak inside of classroom 103, coming from the ceiling.	4/4/14	Classroom	classroom 103	Roof

Delano ES (2145) 1B	trim out ptac unit in main office	6/25/14			Sheet Metal
Delano ES (2145) 1B	Vandals damaged doors on the marquee	10/21/13	Grounds	Front yard	Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Denver ES (2150) 1B	1	1	37	26	96	5	45	17	2	230
Grand Total	1	1	37	26	96	5	45	17	2	230

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Denver ES (2150) 1B	the library has a very foul odor, that seems to appear once the chiller comes on. therefore, I am not sure if the odor is coming from the a/c vent or something else.	5/27/14	Library	1st floor of the B-bldg.	Asbestos
Denver ES (2150) 1B	the cord to the TV that is in the guidance office on the 1st floor in the B-bldg. needs to be replaced. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	2/21/14	Administration Area	guidance office in the B-bldg.	Cabling
Denver ES (2150) 1B	the door to the side of the cafeteria, kitchen entrance is sticking. the plate that the lock goes into needs to be replaced. the one that is on there now is chipped top and bottom.	6/5/14	Cafeteria	side door to the kitchen entrance	Carpentry
Denver ES (2150) 1B	the water fountain is coming from the wall in the cafeteria near the stage.	6/10/14	Cafeteria	cafeteria	Carpentry
Denver ES (2150) 1B	there is a locker handle that is broken, inside of classroom B201.	6/16/14	Classroom	classroom B201	Carpentry
Denver ES (2150) 1B	there are hooks that need to be repaired in some of the cubbies inside of classroom C127	6/16/14	Classroom	classroom C127	Carpentry
Denver ES (2150) 1B	there are a couple of outlets with exposed wiring, inside of room C114, near the PLC desk, eye level.	6/17/14	Administration Area	room C-114	Carpentry

Denver ES (2150) 1B	there is a very bad leak coming into classroom B-201 from the window seal.	4/17/14	Classroom	classroom B-201	Carpentry
Denver ES (2150) 1B	the door that is located at building C is closing too hard. it needs to be adjusted.	4/25/14	Annex	building C between the walkway	Carpentry
Denver ES (2150) 1B	per ms easley 416-3936 the back access door B building will not close after allowing access	5/12/14			Carpentry
Denver ES (2150) 1B	there are two bullet boards that the principal needs to be put up before the start of school.	7/16/13	Hallway/Corridor	in the new bldg.	Carpentry
Denver ES (2150) 1B	SOUTHWEST END DOOR ON BLDG A IS DENTED AND CANNOT THE BLDG CANNOT BE SECURED.S BE EASLEY 416- 3936	7/17/13			Carpentry
Denver ES (2150) 1B	there is a window leak, southeast end of the cafeteria. it is the first window.	7/22/13	Cafeteria	cafeteria	Carpentry
Denver ES (2150) 1B	there are some mailboxes that need to be place on the wall outside of each classroom, on the 1st floor of the C-bldg.	7/23/13	Hallway/Corridor	1st floor C-bldg.	Carpentry
Denver ES (2150) 1B	there are some mailboxes that need to be placed on the wall outside of the classrooms.	7/23/13	Hallway/Corridor	2nd floor C-bldg.	Carpentry

Denver ES (2150) 1B	there are some mailboxes that need to be put on the wall outside of the classrooms, on the 1st floor of the A & B bldg.	7/23/13	Hallway/Corridor	1st floor of A&B bldg.	Carpentry
Denver ES (2150) 1B	there are some mailboxes that need to be put on the walls outside of the classrooms in bldg. A & B.	7/23/13	Hallway/Corridor	2nd floor A & B bldg.	Carpentry
Denver ES (2150) 1B	per principal request, that the staff mailbox cabinet be removed from the main office in the C-bldg. and placed in the teacher;s lounge, 1st floor of the C-bldg.	8/1/13	Administration Area	main office C-bldg.	Carpentry
Denver ES (2150) 1B	Attach expand metal (4 sides) on storm drains (2) at end of new wing near canopy area. 1 " metal, 7" x 13 ".See SBE as needed.	9/6/13	Grounds		Carpentry
Denver ES (2150) 1B	Missing and cracked floor tile	9/25/13	2nd Floor	Nurses Room	Carpentry
Denver ES (2150) 1B	Floor tile missing at the entrance to restroom	9/25/13	1st Floor	Boys r/r A bldg	Carpentry
Denver ES (2150) 1B	Doors will not close behind you when you enter or exit the bldg.	10/28/13	Annex	West ent. to annex	Carpentry
Denver ES (2150) 1B	ENTRANCE DOOR FROM MAIN BLDG LEADING TO ANNEX-NOT CLOSING-WON'T BE ABLE TO SECURE-PLANT MGR PATTERSON 416-3936 KLR	10/30/13			Carpentry

Denver ES (2150) 1B	ENTRY DOOR C-BLDG, CANT SECURE PLANT MGR-PATTERSON/416.3936	11/13/13			Carpentry
Denver ES (2150) 1B	the tile in the restroom that is located inside the SBE office is buckling and also right outside of the restroom. there was some water issues that may have cause some molding problems.	11/25/13	Custodial	1st floor SBE office B104	Carpentry
Denver ES (2150) 1B	the door to classroom A-203 is locking, however, the door does not close and stay closed. if the handle is pulled the door will open.	1/7/14	Classroom	classroom A-203 science lab	Carpentry
Denver ES (2150) 1B	the door to classroom B-110 will not close and stay.	1/7/14	Classroom	classroom B-110	Carpentry
Denver ES (2150) 1B	per Ms. Easley 416-3936 the doorway that leads into stairwell the center mullion has no screws in it and is hazardous	1/9/14			Carpentry
Denver ES (2150) 1B	classroom C-225 door arm handle is broken, this is causing the door to not close completely.	2/13/14	Classroom	classroom C-225	Carpentry
Denver ES (2150) 1B	there is a news board that is in the teacher's lounge on the 1st floor of the C- bldg. that needs to be secured on the wall.	2/28/14	Administration Area	C-bldg. 1st floor teacher's lounge	Carpentry
Denver ES (2150) 1B	there is a bad leak that is leaking from the window sill in the stairway in front of the SBE/Plant Manager office. the window at the first flight of steps.	3/4/14	Stairway	stairway in front of the SBE office	Carpentry

Denver ES (2150) 1B	there is alot of water that come into the building when it rains thru the doors in the stairway near the C-bldg. it is like the water is draining to that area and sitting at the bottom of the stairway, this is happening everytime it rains.	3/5/14	Hallway/Corridor	1st floor of the B-bldg.	Carpentry
Denver ES (2150) 1B	ENTRANCE DOOR C BLDG SIDE BREEZEWAY-LOCK HAS BEEN COMPLETELY TAKEN OUT-WILL NOT BE ABLE TO SECURE-PLANT MGR EASELY 416-3926 KLR	12/9/13			Carpentry
Denver ES (2150) 1B	FRONT DOOR, CANT SECURE C-BLDG PLANT MGR-EASLEY/416.3936	12/12/13			Carpentry
Denver ES (2150) 1B	there is a cover plate that has fallen off the wall in the 1st restroom inside the teacher's lounge, this cover plate was covering a large whole in the wall.	4/3/14	Restroom (Girls)	1st restroom in the teacher lounge C-bldg	Carpentry
Denver ES (2150) 1B	there is a door to one of the stall inside of the restroom that has fallen off the hinges, this is located in the boy's restroom on the 1st floor of the A-bldg.	4/3/14	Restroom (Boys)	the boy's restroom in the A-bldg.	Carpentry
Denver ES (2150) 1B	the door to the stall in the boy's restroom on the 1st floor A-bldg. is broken.	3/11/14	Restroom (Boys)	1st floor A-bldg.	Carpentry
Denver ES (2150) 1B	the school markee needs to be changed to the new principal name and remove the old one.	6/11/14	Administration Area	front lawn	Carpentry
Denver ES (2150) 1B	the tops to both trophy cases needs to be replaced. They both are badly damaged where the wood is cracking and can cause a serious injury.	4/7/14	Hallway/Corridor	1st floor B-building	Carpentry

Denver ES (2150) 1B	the bells need to be turned off for the summer.	6/4/14	Administration Area	main office C-bldg.	Electrical
Denver ES (2150) 1B	all of the outdoor lights are on during the day, this is at the annex building-C.	4/25/14	Annex	building C	Electrical
Denver ES (2150) 1B	RTU-22-NOT COMING ON, HAS NO POWER-PLANT MGR EASELY 416-3936 KLR	5/12/14			Electrical
Denver ES (2150) 1B	NO POWER TO RECEPTACLES IN RM-B104. SEC-SMITH/416.3936	7/25/13			Electrical
Denver ES (2150) 1B	2-THERMOSTAT NOT COMING ON IN RM-A102,A204. PLANT MGR-PATTERSON/416.3936	10/22/13			Electrical
Denver ES (2150) 1B	Need light fixtures put in the boiler room	11/7/13	1st Floor	boiler room	Electrical
Denver ES (2150) 1B	Outside light to back entrance is blown	11/27/13	Parking Lot	Outside back entrance	Electrical
Denver ES (2150) 1B	all doors in both buildings are not sticky to the magnets. the fire panel is reading--dirty outside bookstore, photo dectector -- L1S04	12/3/13	Hallway/Corridor	all doors in both buildings	Electrical

Denver ES (2150) 1B	there are a couple of light fixture where the roof was leaking into, which may have cause the ballast to go bad.	1/16/14	Classroom	classroom A-210	Electrical
Denver ES (2150) 1B	there are a couple of doors on the 2nd floor of the C-bldg. that metal stopper are broken. one is located at the 5th grade hallway and the other one is located at the 4th grade hallway near the stairwell once you enter the building.	1/30/14	Hallway/Corridor	2nd floor of the C-bldg.	Electrical
Denver ES (2150) 1B	HEAT RM B141-NOT COMING ON-PLANT MGR EASELY 416-3936 KLR	2/3/14			Electrical
Denver ES (2150) 1B	Unit is NOT COMING ON in ROOM B141 per Ms. Easley, Plant Mgr. 416.3936	2/4/14			Electrical
Denver ES (2150) 1B	there is a light fixture on the 1st floor B-bldg. that has a bad ballast.	2/6/14	Hallway/Corridor	1st floor B-bldg. near the library	Electrical
Denver ES (2150) 1B	there is an electrical panel that supplies all the computers to rooms A-110 and A-111 is not working. I have tried the panel outside the classroom and it is on, however, both classrooms computers are down.	2/19/14	Classroom	classrooms A-110 & A-111	Electrical
Denver ES (2150) 1B	there is a light pole that is in the rear parking lot near the principal parking space that needs to be replaced/repaired.	2/25/14	Grounds	rear parking lot	Electrical
Denver ES (2150) 1B	Disconnect hot water tank teachers lounge.	3/5/14			Electrical

Denver ES (2150) 1B	New hot tank in place. please hook up power.	3/5/14			Electrical
Denver ES (2150) 1B	HEAT RM B139, B141, C208, C213, C211, C207, C222, C225, C221, C220, B103, & D142-ALL NOT COMING ON-PLANT MGR EASELY 416-3936 KLR	3/6/14			Electrical
Denver ES (2150) 1B	there are some clocks that need to be reset for daylight saving time.	3/7/14	Hallway/Corridor	thru out the school	Electrical
Denver ES (2150) 1B	RTU NOT COMING ON IN RM-C208. PLANT MGR-EASLEY/416.3936	12/16/13			Electrical
Denver ES (2150) 1B	there several classrooms that need some light bulbs. F32T8/SPX41/ECO=48	7/24/13	Classroom	1st and 2nd floors of A,B,C bldgs.	Electrical
Denver ES (2150) 1B	Outside light to back entrance is blown	8/28/13	Parking Lot	Outside back entrance	Electrical
Denver ES (2150) 1B	there are light bulbs needed for classroom A-203, the number to the bulbs are-- Philips(30)F32T8/ADV841/XLL 28 WATT. I need two(2) boxes of (30). Thanks	2/6/14	Classroom	classroom A203	Electrical
Denver ES (2150) 1B	there is alot of smoke, as well as overheating of the laminating machine inside of room C-114. the machine is overheating even when it is plugged up but not on. this is causing huge amount of fumes to overflow into the hallways as well as some classrooms. complaints of	12/3/13	Administration Area	C-114 inside the new building	Electrical

Denver ES (2150) 1B	I need 2 boxes of # f32tb/spx41/eco- 35 qty 4 foot tubes I have e mailed this work order to Ken White.	8/6/13			Electrical
Denver ES (2150) 1B	there are several classrooms that need light bulbs to be replaced. need light bulbs badly.	7/23/13	Classroom	1st & 2nd floors in both bldg.	Electrical
Denver ES (2150) 1B	rm 104B possible bad actuator	7/23/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	5/27/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT NOT COOLING IN RM-B115,B205 PLANT MGR-EASLEY/552.6226	6/3/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT VENT - BLDG B MAIN OFC - BLOWING NOT COOLING - PM/EASLEY 416-3936	6/10/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C UNIT is NOT COOLING in ROOM B215 per Ms. Easley, Plant Mgr. 416.3936	6/13/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT NOT COOLING IN SERVING LINE AREA , RM-B110 PLANT MGR-EASLEY/552.6226	6/17/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	UNIT NOT COOLING IN RM-B110 plant mgr-EASLEY/552.6226	6/19/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT VENT - B104 & B110 BLOWING NOT COOLING - PM/EASLEY 416-3936	6/23/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	CHILLER - NOT COMING ON - PM/EASLEY 416-3936	6/24/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	there is a smell that occurs in the library everytime the chiller is down then cut back on.	6/24/14	Library	library	Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C UNIT is NOT COOLING in ROOM B215 per Ms. Easley, Plant Mgr. 416.3936	6/25/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT VENT - IN CAFE, RMA204, A201 - BLOWING NOT COOLING - SHOWING 79 & 82 DEGREES - PM/EASLEY 416-3936	6/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	CHILLER B CKT CHECK CHARGE	6/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Monthly - Filter-Denver Elementary - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	there is a very foul odor coming from the vents in the library once the boiler changed over.	4/15/14	Library	1st floor of the A-building	Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT NOT COMING ON IN RM-B209,B209,A209,C213 PLANT MGR-EASLEY/552.6226	4/24/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A & B bldg not cooling	4/29/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	C213 not cooling	4/29/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Rm B208 not cooling	4/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Rm B207 not cooling	4/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Rm A211 not cooling	4/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Rm A210 not cooling	4/30/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	Rm A204 not cooling	4/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT NOT COOLING IN RM-8210,8209,8204,203,205 PLANT MGR-EASLEY/552.6226	5/6/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	5/7/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	clean chiller	5/7/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C RM B107-NOT COOLING-PLANT MGR EASELY 416-3932 KLR	5/7/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	5/9/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C RM C BLDG RM 222, 207, & 208-ALL NOT COOLING-PLANT MGR EASELY 416-3936 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	per ms easley 416-3936 a/c in main office building B not cooling	5/12/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	chiller down	5/14/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C RM B110-NOT COOLING-PLANT MGR EASELY KLR	5/20/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C UNITS is NOT COOLING in ROOM A204 per Wanda Easley, Plant Mgr. 416.3936	5/22/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	5/22/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Monthly - Oil Lube & Belt-Denver Elementary - Refer to PM schedule details.	7/9/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Main Chiller in Area A, ID#105-047 NOT COOLING per Wanda Easley, Plant Mgr. at 901.416.3936!	7/12/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	7/17/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	CHILLER NOT COOLING (047), AHU IN CAFE (017,072,073,074) SBE-EASLEY/416-3936	7/18/13			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	UV#4 NOT COOLING IN RM-104B. SBE-EASLEY/416-3936	7/23/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UV-3 RM 104-NOT COOLING-SBE EASELY 416-3936 KLR	8/1/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UV NOT COOLING IN RM-205(085) . PLANT MGR-EASLEY/416.3936	8/5/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNIT IN THE C BLDG IS NOT COOLING. SBE EASLEY 416-3936	8/6/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C NOT COOLING IN THE ENTIRE B BLDG PER SBE-SBE EASELY 416-3936 KLR	8/6/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	3-UNITS NOT COOLING IN RM-C213, RM- B205(085) RM-B104(041) PLANT MGR-EASLEY/416.3936	8/8/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Monthly - Filter-Denver Elementary - Refer to PM schedule details.	8/9/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Per Ms. Easley entire C building chiller is down 416-3936	8/12/13			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	A/C IN C BLDG RMS C222 & C226-BOTH NOT COOLING-SBE EASELY 416-3936 KLR	8/12/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rtu's need filters checked	8/13/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	engineer's office and the main office in B building the a/c units are not cooling per Patterson 416-3932	8/27/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	8/29/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	chiller down	9/3/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	CHILLER D BLDG-NOT COOLING-AFFECTS BLDG-PLANT MGR PATTERSON 416-3936 KLR	9/3/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	A/C RM B214-NOT COOLING-PLANT MGR PATTERSON 416-3936 KLR	9/3/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	3-UV NOT COOLING IN RM-B104,B148,C213. PLANT MGR-PATTERSON/416.3936	9/3/13			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	Main Office in B Building and Room 214 a/c not cooling per Patterson 416-3936	9/10/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	BOILERS A & B BLDG-STILL NOT HEATING-PLANT MGR EASELY 416-3936 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 105 -- not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm B131 --- not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 104 --- not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 103 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	asst. princ. ofc not heating	1/8/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	rm 101 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	library -- not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 209 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 109 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	meet siemens to look at controls	1/10/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT RM C226, C222, & C208-ALL NOT HEATING-PLANT MGR EASELY 416-3936 KLR	1/16/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	per ms easley 416-3936 buildings A and B have no heat-	1/22/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	per ms smith financial secretary 416-3936 building C rooms 222 and 226 have no heat	1/22/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	siemens controls	1/23/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT RM B141-MAKING NOISES-PLANT MGR EASELY 416-3936 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT C BLDG RM C226, C222, C207, & C208-ALL NOT HEATING-PLANT MGR EASELY 416-3932 KLR	1/24/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	boiler only sending 75* water to bldg	1/27/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT RM C208, C226, C222, C221, & C219-ALL NOT HEATING-CALLED IN FIN SEC SMITH 416-3936 KLR	1/28/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	UNITS NOT HEATING ON IN RM-C221,C220,C207 PLANT MGR-EASLEY/552.6226	1/29/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 226 not heating	1/29/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 226 not heating	1/30/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	rm 222 not heating	1/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 221 not heating	1/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm 208 not heating	1/30/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT RM C226-NOT HEATING-PLANT MGR EASELY 416-3936 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Monthly - Oil Lube & Belt-Denver Elementary - Refer to PM schedule details.	2/11/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	rm c221 not heating	2/13/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	check rooms	3/6/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	B213 needs transformer	3/6/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	Monthly - Filter-Denver Elementary - Refer to PM schedule details.	12/6/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	CHILLER is NOT HEATING per Ms. Easley, Plant Mgr. 416.3936	12/12/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT A BLDG, B BLDG, & C BLDG-ALL NOT HEATING & UNIT IN RM A209-LEAKING OIL OR A BROWN SOLUTION PER SBE-PLANT MGR EASELY 416-3936 KLR	12/19/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	check actuator	12/20/13			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	BOILER A & B BLDGS & BOILER C BLDG-ALL NOT HEATING-PLANT MGR EASELY 416-3936 KLR	1/2/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	meet siemens to get power to unit	1/2/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	check boiler	3/25/14			Heating/Ventilation /Air Conditioning

Denver ES (2150) 1B	boiler down	3/26/14				Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	HEAT RM A209-NOT HEATING-PLANT MGR EASELY 416-3936 KLR	1/6/14				Heating/Ventilation /Air Conditioning
Denver ES (2150) 1B	Paint peeling in the ceiling	8/28/13	Cafeteria	kitchen		Painting
Denver ES (2150) 1B	there are two trophy cases in the hallway of the B-bldg. that need the top of the cases to be replaced or sanded down then painted.	6/10/14	Hallway/Corridor	1st floor of the B-bldg		Painting
Denver ES (2150) 1B	GRAFFITI OUTSIDE ON PLAYGROUND EQUIP IN GATED PLAYGROUND AREA- PLANT MGR EASELY 416-3936 KLR	6/25/14				Painting
Denver ES (2150) 1B	there is areas over the food preparing table that was painted and is now chipping and falling onto the table where food is being prepared.	8/2/13	Cafeteria	kitchen		Painting
Denver ES (2150) 1B	Prime small metal frames(8) for Danny W.	9/11/13				Painting
Denver ES (2150) 1B	Sink on south wall leaking	8/28/13	Cafeteria	kitchen		Plumbing

Denver ES (2150) 1B	the sink in the library office is stopped up.	6/6/14	Library	library	Plumbing
Denver ES (2150) 1B	Test and report on backflow prevention devices.	6/17/14			Plumbing
Denver ES (2150) 1B	there is a drainage in between building B & C that is always getting stopped up from the debris mainly because of the way it was made. there is a urgent for a new one that will help let the debris as well as the water to flow.	4/15/14	Grounds	at the rear of B & C building	Plumbing
Denver ES (2150) 1B	the first sink in the girl's restroom on the 2nd floor of the B-bldg. is constantly leaking.	5/9/14	Restroom (Girls)	2nd floor B-bldg.	Plumbing
Denver ES (2150) 1B	there is a water fountain that is leaking, on the 1st floor of the C-bldg.	5/9/14	Hallway/Corridor	1st floor C-bldg.	Plumbing
Denver ES (2150) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	5/19/14			Plumbing
Denver ES (2150) 1B	the water fountain in the cafeteria is leaking badly.	5/20/14	Cafeteria	cafeteria	Plumbing
Denver ES (2150) 1B	the 1st and 2nd floors in both building water fountains are leaking, which is cause stain spots on the floor.	7/12/13	Hallway/Corridor	1st, and 2nd floors hallways	Plumbing

Denver ES (2150) 1B	the water from the sinks in the custodial closets on the 1st and 2nd floors has a continue drip. they can not be turned off.	7/12/13	Custodial Closet	1st and 2nd floors	Plumbing
Denver ES (2150) 1B	the a/c units that are in the hallways, also going up the stairwells installation needs to be replaced around the pipes.	7/12/13	Hallway/Corridor	1st and 2nd floors	Plumbing
Denver ES (2150) 1B	the toilet inside the Plant Manager's office is leaking once flushed.	7/15/13	1st Floor	Plant Manager's office	Plumbing
Denver ES (2150) 1B	there is a sink in the custodial closet that is continual running. the water is running out hard.	7/18/13	Custodial Closet	2nd floor of the A&B bldg	Plumbing
Denver ES (2150) 1B	there is a very bad leak coming from the ice machine in the kitchen on the service line.	7/25/13	Cafeteria	service line area	Plumbing
Denver ES (2150) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/31/13			Plumbing
Denver ES (2150) 1B	the sink inside the restroom in the asst. principal office in the A & B bldg. is leaking.	8/1/13	Administration Area	inside main office asst. principal	Plumbing
Denver ES (2150) 1B	the restroom inside of room B104 needs a toilet seat.	8/5/13	Classroom	room B104	Plumbing

Denver ES (2150) 1B	COMMODE IN ASST. PRINC OFFICE IS OVER FLOWING AND CANNOT BE TURNED OFF.S BE EASLEY 416-3936	8/6/13			Plumbing
Denver ES (2150) 1B	TOILET IS OVER FLOWING IN ASSIST PRIN OFFICE. PLANT MGR-EASLEY/416.3936	8/8/13			Plumbing
Denver ES (2150) 1B	there is a bad leak in the kitchen area, the sink near the dishwasher.	8/12/13	Kitchen	kitchen area	Plumbing
Denver ES (2150) 1B	Sink in bathroom leaking	8/21/13	1st Floor	bldg B asst. prin office	Plumbing
Denver ES (2150) 1B	Toilet not flushing	8/22/13	1st Floor	bldg B asst. prin office	Plumbing
Denver ES (2150) 1B	Sink leaking. Water seeping into hallway and restroom	9/16/13	2nd Floor	Custodial closet	Plumbing
Denver ES (2150) 1B	Floor drain stopped up	9/17/13	1st Floor	Boys & girls R/R B bldg	Plumbing
Denver ES (2150) 1B	Drain clogged up	10/1/13	1st Floor	Boys restroom (B) bldg	Plumbing

Denver ES (2150) 1B	Drain clogged up	10/1/13	2nd Floor	Boys restroom (B) bldg	Plumbing
Denver ES (2150) 1B	Toilet constantly running	11/5/13	2nd Floor	A bldg boys restroom	Plumbing
Denver ES (2150) 1B	Need to get on/off handles adjusted. they will not cut completely off	11/7/13	1st Floor	Teachers lounge C bldg	Plumbing
Denver ES (2150) 1B	OVERHEAD PIPE IS LEAKING WATER IN KITCHEN. PLANT MGR-PATTERSON/416.3932	11/12/13			Plumbing
Denver ES (2150) 1B	Toilet not flushing	11/13/13	1st Floor	B bldg Rm 141	Plumbing
Denver ES (2150) 1B	Toilet seat will not tighten up	11/13/13	1st Floor	B bldg Rm 139	Plumbing
Denver ES (2150) 1B	Toilet stopped up	11/21/13	1st Floor	B-141	Plumbing
Denver ES (2150) 1B	the boy's restroom in the B-bldg. a couple of the toilets inside the stalls are leaking.	11/26/13	Restroom (Boys)	1st and 2nd floors boys restrooms b-bldg.	Plumbing

Denver ES (2150) 1B	the toilet inside of classroom B-141 is overflowing once flushed.	12/2/13	Classroom	B141 on the 1st floor	Plumbing
Denver ES (2150) 1B	there is a leak coming from a pipe inside the boiler room that is causing a great access amount of water on the floor of boiler room.	1/13/14	Mechanical Room	1st floor of the B-bldg.	Plumbing
Denver ES (2150) 1B	there is a urinal that is stopped up inside of the boy's restroom on the 2nd floor of the C-bldg.	1/16/14	Restroom (Boys)	boy's restroom in the C-bldg.	Plumbing
Denver ES (2150) 1B	both water fountains on the 2nd floor of the C-bldg. 5th grade hallway are overflowing. it started out as a very slow leak however, now it is constantly flowing.	1/24/14	Hallway/Corridor	2nd floor C-bldg. 5th grade hall	Plumbing
Denver ES (2150) 1B	the water fountain on the 2nd floor of the C-bldg., 4th grade hall is not working.	2/13/14	Hallway/Corridor	2nd floor C-bldg. 4th grade hall	Plumbing
Denver ES (2150) 1B	there is a leak coming from the 2nd floor boy's restroom pipes into the 1st floor boy's restroom. over by the urinals.	2/21/14	Restroom (Boys)	1st and 2nd floors boy's restrooms	Plumbing
Denver ES (2150) 1B	the urinals in the boy's restroom in the B-bldg. is stopped up.	2/21/14	Restroom (Boys)	1st floor B-bldg.	Plumbing
Denver ES (2150) 1B	PIPE TEACHER'S LOUNGE 1ST FLR- SINK HAS BURST AND WATER EVERYWHERE PER SBE-PLANT MGR EASELY 416-3936 KLR	2/27/14			Plumbing

Denver ES (2150) 1B	there is a very bad leak that is coming from the pipes from the heater that is in the stairway, or the leak is coming from the walls.	3/6/14	Hallway/Corridor	B-bldg. stairway near the boy's restroom 1st fl.	Plumbing
Denver ES (2150) 1B	there is a very bad leak coming from the walls into room B-104 (SBE office) as well as the restroom inside the SBE office.	12/3/13	Classroom	SBE office B-104	Plumbing
Denver ES (2150) 1B	there is a toilet that is loose from the floor, inside the boy's restroom on the 1st floor Bldg-A.	12/18/13	Restroom (Boys)	1st floor boy's restroom	Plumbing
Denver ES (2150) 1B	there is a leak that is coming from the water fountain inside of the cafeteria.	4/3/14	Cafeteria	cafeteria	Plumbing
Denver ES (2150) 1B	the ceiling tile inside the kitchen area of the cafeteria is peeling up and dropping down where food is being prepared. This can cause the cafeteria to get a poor grade from their inspection. second time requesting.	5/27/14	Kitchen	cafeteria/kitchen	Roof
Denver ES (2150) 1B	there is a very bad leak at the northwest entrance of the service line.	7/22/13	Cafeteria	servicing line	Roof
Denver ES (2150) 1B	there is a very bad leak inside of classroom B139. the floor was done over the weekend and now has water damage to the waxing.	7/22/13	Classroom	B139	Roof
Denver ES (2150) 1B	there is a very bad leak coming from the ceiling tile inside of classroom A-209. This leak has been reported once before.	1/10/14	Classroom	classroom A-209	Roof

Denver ES (2150) 1B	the roof inside of classroom A-209 has two leaks that are very bad. these leaks are coming from the ceiling with some type of oil liquid coming from it.	1/13/14	Classroom	A-209 classroom	Roof
Denver ES (2150) 1B	there is a couple of very bad leaks inside of classroom A-210, one of those leaks are coming from a light fixture that also has some kind of black oily liquid that is all over the ceiling tile as well as the light fixture.	1/13/14	Classroom	classroom A-210	Roof
Denver ES (2150) 1B	there are a couple of very bad leaks inside of classroom A-203, one of those leaks are real close to the ITT room where alot of wiring is located.	1/13/14	Classroom	classroom A-203(science lab)	Roof
Denver ES (2150) 1B	there is a very bad leak coming from the window in the stairwell in the B-bldg. at the teacher's entrance.	2/4/14	Hallway/Corridor	B-bldg. stairwell teacher's entrance	Roof
Denver ES (2150) 1B	there is a very bad leak inside of classroom C-221. this leak is coming from the ceiling.	2/4/14	Classroom	C-221	Roof
Denver ES (2150) 1B	there is a leak inside of classroom A-210, that is leaking from the light fixture. this leak is a reoccurring leak with the brown/black oily liquid and water. this leak is causing some visual issues with the students and teacher, due to the ballast going bad from the leak.	2/5/14	Classroom	classroom A-210	Roof
Denver ES (2150) 1B	there is a leak coming from the light fixture onto the teacher's station, where there is alot of equipment like computer, ect.	2/6/14	Classroom	classroom A209	Roof
Denver ES (2150) 1B	there is a leak coming from the ceiling on the 2nd floor of the C-bldg. near the elevator.	2/13/14	Hallway/Corridor	2nd floor C-bldg.	Roof

Denver ES (2150) 1B	there is a leak that is coming from the ceiling tile, on the 3rd grade hall of the C-bldg.	2/14/14	Hallway/Corridor	1st floor C-bldg, 3rd grade hall	Roof
Denver ES (2150) 1B	there is something that is on the ceiling tile inside of classrooms A-209 & A-210 that appears to me of mold.	2/14/14	Classroom	classrooms A-209 & A-210	Roof
Denver ES (2150) 1B	there is a bad leak inside of the science lab classroom A-203, there are leaks all over that room.	2/21/14	Classroom	A-203	Roof
Denver ES (2150) 1B	there are very bad leaks inside of classrooms A-203(science lab) as well as classroom A-209. These leaks are causing the ceiling tile to fall and the floor tile to bulk. This is not safe for the students nor the staff.	1/2/14	Classroom	inside of classrooms A203 and A209	Roof
Denver ES (2150) 1B	there are bad leaks coming from the ceiling in classrooms A-204,209,210.	3/17/14	Classroom	classrooms A-204,209,210	Roof
Denver ES (2150) 1B	Need cover plate for hole in the wall	11/7/13	1st Floor	A bldg Girls restroom	Sheet Metal
Denver ES (2150) 1B	the rail that is at the cafeteria doors, rear parking lot has fallen down .	3/21/14	Grounds	the rear parking lot cafeteria doors	Sheet Metal

Count of Craft	Craft							
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Downtown ES (2162) 1A	1	13	24	40	1	42	3	124
Grand Total	1	13	24	40	1	42	3	124

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Downtown ES (2162) 1A	provide project management for vendor to install smart boards	4/4/14			Cabling
Downtown ES (2162) 1A	Repair holes in the walls that was made from the door knob.	10/2/13	1st Floor	boys rest rooms	Carpentry
Downtown ES (2162) 1A	Install door stops in stalls,move tissue holder patch holes in sheet rock walls in boys and girls, frist and 2nd floor restrooms.	10/14/13	1st Floor	rest rooms	Carpentry
Downtown ES (2162) 1A	Main entrance center pole needs rework,also center pole on 1st floor URGENT.	12/3/13	2nd Floor	FRONT ENTRANCE	Carpentry
Downtown ES (2162) 1A	Front entrance door to main office will not open and close properlyURGENT.	7/26/13	1st Floor	main office	Carpentry
Downtown ES (2162) 1A	Install backsplash	7/29/13			Carpentry
Downtown ES (2162) 1A	Replace broken glass across from boys restroom.	8/8/13	1st Floor	rotunda	Carpentry
Downtown ES (2162) 1A	Dividing wall needs repair some screws are missing.	2/4/14	1st Floor	multipurpose	Carpentry

Downtown ES (2162) 1A	Back kitchen door not closing properly.	3/17/14	Cafeteria	kitchen back door	Carpentry
Downtown ES (2162) 1A	Stage curtain stuck at very top will not move.	3/17/14	1st Floor	multipurpose	Carpentry
Downtown ES (2162) 1A	Folding wall coming apart needs repair.	4/1/14	1st Floor	multipurpose	Carpentry
Downtown ES (2162) 1A	Stage curtains will not close HELP URGENT.	5/6/14	1st Floor	MULTIPURPOSE	Carpentry
Downtown ES (2162) 1A	ENTRANCE DOOR FRAME LEADING TO PLAYGROUND AREA-IS COMING LOOSE- WON'T BE ABLE TO SECURE-PLANT MGR SHARP 416-8400 KLR	6/20/14			Carpentry
Downtown ES (2162) 1A	women rest room, short hall center of building, 215, 215a, guidance, 214,213,211a, mechanical,210, 210a,custodial, men rest room short hall center of building, 204a mechanical, 204,201.	8/29/13	2nd Floor	217, 216, and	Carpentry
Downtown ES (2162) 1A	Reset chiller	9/17/13			Electrical
Downtown ES (2162) 1A	Repair lights in main hall in front of main office also these are spial	9/17/13	1st Floor	hall	Electrical
Downtown ES (2162) 1A	Replace wall clock in cafeteria URGENT.	10/2/13	1st Floor	cafe.	Electrical

Downtown ES (2162) 1A	POWER OUTAGE THRU BLDG PLANT MGR- SHARPE/870.0368	10/31/13			Electrical
Downtown ES (2162) 1A	Kitchen ventilation hood not working URGENT.	11/6/13	1st Floor	kitchen	Electrical
Downtown ES (2162) 1A	Replace balast in light all bulbs have been changed URGENT.	11/8/13	1st Floor	guidance	Electrical
Downtown ES (2162) 1A	Boys restroom exhast fan not working 1st grade hall URGENT.	11/19/13	1st Floor	boys restroom	Electrical
Downtown ES (2162) 1A	Kitchen venter hood not working.	8/11/13	1st Floor	Kitchen	Electrical
Downtown ES (2162) 1A	DELIVERED 75 LAMP STOCK# 46807. (SHANE PORTER) REQUESTED AMOUNT Ordering 50 lamp flr rapid start 25 #46807 also 100watt compact bulbs	8/11/13	1st Floor	Plant manageroffice	Electrical
Downtown ES (2162) 1A	Set clock for outside lights.	1/31/14	1st Floor	electrical room	Electrical
Downtown ES (2162) 1A	day light saving time start march 9th, sunday so the clocks can be ajusted for that time. at Douglass k-8.	2/24/14	1st Floor	main office	Electrical
Downtown ES (2162) 1A	Check circuit breaker in panel LPD it keeps tripping out.	2/27/14	2nd Floor	a206m	Electrical

Downtown ES (2162) 1A	Replace burnt wall plug in socket.	2/27/14	1st Floor	Library	Electrical
Downtown ES (2162) 1A	Set master clock for time change #010-002	2/28/14	1st Floor	main office	Electrical
Downtown ES (2162) 1A	Repair timer for outside lights around the building.	3/17/14	1st Floor	c110m	Electrical
Downtown ES (2162) 1A	Need 3 boxes of flr. rapid start 25 bulbs for class rooms. #46807	3/19/14	1st Floor	Plant Manager	Electrical
Downtown ES (2162) 1A	Repair electrical plug for ice cream box URGENT.	3/27/14	Kitchen	serving line	Electrical
Downtown ES (2162) 1A	chiller down	4/7/14			Electrical
Downtown ES (2162) 1A	Need lift to replace blown out lights over head# blown 17.	4/21/14	1st Floor	cafe.& multipurpose	Electrical
Downtown ES (2162) 1A	Please give me 2 boxes of 4 foot lights for classrooms	4/22/14			Electrical
Downtown ES (2162) 1A	Hall light out bad balast.	5/14/14	2nd Floor	hallway	Electrical

Downtown ES (2162) 1A	Ten lights out need lift to replace them multipurpose&cafe.	3/17/14	1st Floor	cafe.&multipurpose	Electrical
Downtown ES (2162) 1A	Have GE Service tech reset settings on main breaker to engineer specifications to avoid nuisance tripping.	2/19/14			Electrical
Downtown ES (2162) 1A	Lamp fir,rapid start 25 #46807 3 boxes.	1/8/14	1st Floor	Plant manager	Electrical
Downtown ES (2162) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	RTU NOT COOLING IN MAIN OFFICE, & PLANT MGR OFFICE. PLANT MGR- SHARPE/416.8400	10/17/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	chiller in alarm	11/6/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	RTU NOT HEATING THRU ENTIRE 2ND FLR PLANT MGR- SHARPE/416.8400	11/26/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Monthly - Filter-Downtown Elementary - Refer to PM schedule details.	12/7/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	clean ahu's	12/11/13			Heating/Ventilation /Air Conditioning

Downtown ES (2162) 1A	Check unit 1n library #010-129 per energy management not working.	12/11/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	RTU#3 NOT COMING ON IN MULTI-PURPOSE RM PLANT MGR-SHARPE/416.8400	12/12/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	AHU #3 NOT HEATING IN RM-A225 PLANT MGR-SHARPE/870.0368	12/13/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	boiler in lo fire	1/7/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Monthly - Oil Lube & Belt-Downtown Elem - Refer to PM schedule details.	7/14/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	AIR COOLED CHILLER CHILLER COURTYARD-NOT COMING ON-AFFECTS ENTIRE BLDG-SBE SHARP 416-8400 KLR	8/8/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Monthly - Filter-Downtown Elementary - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	AHU-3 2ND FLR AREA D RMS 214, 215, 216, & 213-ALL ARE OVERHEATING-TEMPS ARE OVER 80 PER SBE-PLANT MGR SHARPE 416-8400	1/10/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Replace aqua stat on boiler	1/15/14			Heating/Ventilation /Air Conditioning

Downtown ES (2162) 1A	per mr sharpe 416-8400 AH#3 stuck hot water valve (per energy management) and in the library one of the units is not heating	1/30/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	rm A216 overheating	2/4/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	RTU NOT HEATING IN MULTI- PURPOSE RM & DINNING AREA. PLANT MGR- WILIAMS/416.8400	2/4/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	clean fresh air screen on AHU #3	2/7/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	HEAT RM A214 & A215- BOTH NOT HEATING-PLANT MGR SHARP KLR	2/10/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Monthly - Oil Lube & Belt- Downtown Elem - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	AIR HANDLER UNIT #3 is LEAKING WATER DOWN THE WALL per Mr. Sharp, Plant Mgr. 416.8400 or 870.0368	3/4/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	AHU #3 not heating	3/6/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	RTU-1 MULTI-PURPOSE RM- NOT HEATING-PLANT MGR SHARPE 416-8400 KLR	3/6/14			Heating/Ventilation /Air Conditioning

Downtown ES (2162) 1A	UNIT NOT HEATING IN LIBRARY PLANT MGR- SHARPE/870.0368	3/17/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	C/O to A/C ---- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	CHILLER MECH RM-HAS GONE DOWN-PLANT MGR SHARP 416-8400 KLR	3/28/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	CHILLER MECH RM-IN ALARM-PLANT MGR SHARP 416-8400 KLR	3/31/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	5-UNITS ARE OVER HEATING (88) IN RM- 201,A202,,A203,A200,A204 PLANT MGR- SHARPE/416.8400	4/1/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Monthly - Filter-Downtown Elementary - Refer to PM schedule details.	4/5/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	chiller down	4/17/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	A/C CAFE AREA-NOT COMING ON-PLANT MGR SHARP 416-8400 KLR	5/6/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	A/C KITCHEN AREA-NOT COOLING-PLANT MGR SHARP 416-8400 KLR	5/6/14			Heating/Ventilation /Air Conditioning

Downtown ES (2162) 1A	A/C KINDERGARTEN TEACHER'S LOUNGE-NOT COMING ON-PLANT MGR SHARP 416-8400 KLR	5/7/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	CHILLER MECH RM-NOT COMING ON-PLANT MGR SHARP 416-8400 KLR	5/16/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	UNIT NOT COMING ON IN CAFE, MULTI-RM PLANT MGR- SHARPE/870.0368	5/22/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	A/C CAFE/MULTI-PURPOSE RM-NOT COOLING-PLANT MGR SHARP 416-8400 KLR	6/3/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	UNIT NOT COOLING IN MULTI PURPOSE RM & CAFE (HAVING SUMMER CAMP) PLANT MGR- SHARPE/416.8400	6/5/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	clean unit and change filter in guidance ofc	6/6/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	clean ahu	6/11/14			Heating/Ventilation /Air Conditioning
Downtown ES (2162) 1A	Pressure wash outside of the building.	3/10/14	Grounds	outside of building	Painting
Downtown ES (2162) 1A	Second grade boys rest room,urinal not flushing properly.	9/8/13			Plumbing

Downtown ES (2162) 1A	Water leaking in restroom from an unseen place,also urinal 2nd floor flushing all over the the floor URGENT.	9/13/13	1st Floor	1grade boys restroom	Plumbing
Downtown ES (2162) 1A	Hand washing sink faucet water will not turn off URGENT.	9/16/13	1st Floor	PreK	Plumbing
Downtown ES (2162) 1A	faucet need repairing,hot water stripped,not able cut-off	9/19/13	Cafeteria	kitchen area	Plumbing
Downtown ES (2162) 1A	Shower in nurse office needs repair,water not hot and it run slow per principal URGENT. Facuet in kitchen hot side needs repair,it just spins around.	9/23/13	1st Floor	nurse station	Plumbing
Downtown ES (2162) 1A	Water fountian in kk aria leaking badly.	9/26/13	1st Floor	kk	Plumbing
Downtown ES (2162) 1A	Water leaking from AC unite can not contain.	9/27/13	1st Floor	plantmanagers office	Plumbing
Downtown ES (2162) 1A	Repair hand washing sink,water will not turn off.	10/25/13	1st Floor	PRE-K REST ROOM	Plumbing
Downtown ES (2162) 1A	Hand washing sink water will not turn off.	10/30/13	1st Floor	teacher lounge1st grade	Plumbing
Downtown ES (2162) 1A	BOYS urinal stop up water coming over the top help.	11/6/13	2nd Floor	BOYS RESTROOM	Plumbing

Downtown ES (2162) 1A	Commode not flushing properly.	11/8/13	2nd Floor	boys restroom	Plumbing
Downtown ES (2162) 1A	Commod has something stopping it up.	11/19/13	2nd Floor	boys restro	Plumbing
Downtown ES (2162) 1A	Urinal not flushing properly.URGENT	12/11/13	1st Floor	1st grade boys	Plumbing
Downtown ES (2162) 1A	Commode stop up ladies room.	12/12/13	1st Floor	main office	Plumbing
Downtown ES (2162) 1A	Urinal stop up.	12/12/13	2nd Floor	boys restroom	Plumbing
Downtown ES (2162) 1A	Commode keeps stopping up as if something is stuck in it.	12/19/13	Restroom (Boys)	2ND FLOOR	Plumbing
Downtown ES (2162) 1A	Test and report on backflow prevention devices.	12/19/13			Plumbing
Downtown ES (2162) 1A	Water leaking from ceiling URGENT.	12/19/13	2nd Floor	room 225	Plumbing
Downtown ES (2162) 1A	Commode stop up.	1/6/14	2nd Floor	boys restroom	Plumbing

Downtown ES (2162) 1A	Outside water faucet on back dock will not turn off with the key URGENT.	7/1/13	1st Floor	outside faucet	Plumbing
Downtown ES (2162) 1A	KK boys & 2nd grad commodes are not flushing properly 1 in each rest room.	7/2/13	1st Floor	KK&2ND BOYS RR	Plumbing
Downtown ES (2162) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/30/13			Plumbing
Downtown ES (2162) 1A	Kitchen has no hot water per mgt. URGENT.	7/31/13	1st Floor	KITCHEN	Plumbing
Downtown ES (2162) 1A	Principal toilet runs constantly, AC drain pipe in the ladies restroom is over flooring URGENT.	8/11/13	1st Floor	mainoffice	Plumbing
Downtown ES (2162) 1A	Urinal boys restroom has bad flush valve.	8/11/13	1st Floor	boysrestroom	Plumbing
Downtown ES (2162) 1A	Hand washing sink in kitchen and the restroom have no hot water.	8/21/13	1st Floor	kitchen	Plumbing
Downtown ES (2162) 1A	Urinal over flowing bad flush valve.	1/8/14	2nd Floor	boys restroom	Plumbing
Downtown ES (2162) 1A	Test and report on backflow prevention devices.	1/21/14			Plumbing

Downtown ES (2162) 1A	Broken commode seat needs replacing.	2/5/14	1st Floor		Plumbing
Downtown ES (2162) 1A	Commode seat needs replaceing URGENT.	2/18/14	1st Floor	kk boys resrtroom	Plumbing
Downtown ES (2162) 1A	per mr sharp 870-0368 water leak on chiller on main water cut off	3/4/14			Plumbing
Downtown ES (2162) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing
Downtown ES (2162) 1A	Commode lose from the bottom 2nd floor boys restroom.	3/17/14	2nd Floor	BOYS RESTROOM	Plumbing
Downtown ES (2162) 1A	Commode bottom lose.	3/17/14	1st Floor	boysrestroom	Plumbing
Downtown ES (2162) 1A	Push on faucet will not cut off girls restroom.	3/17/14	1st Floor	center hall	Plumbing
Downtown ES (2162) 1A	Commode lose at the bottom.	3/17/14	1st Floor	kk boys restroom	Plumbing
Downtown ES (2162) 1A	Commode needs flush valve.	3/18/14	1st Floor	boys restroom	Plumbing

Downtown ES (2162) 1A	Commode needs flush 3rd stall.	3/18/14	2nd Floor	girls restroom	Plumbing
Downtown ES (2162) 1A	HOT WATER HEATER KITCHEN AREA-NOT HEATING WATER, NOT HOT WATER TO KITCHEN-PLANT MGR SHARP 416-8400 KLR	3/24/14			Plumbing
Downtown ES (2162) 1A	Guidance office AC drain pan leaking water.	5/13/14	1st Floor	GUIDANCE	Plumbing
Downtown ES (2162) 1A	Urinal stop up.	5/14/14	2nd Floor	boys restroom	Plumbing
Downtown ES (2162) 1A	Water leaking from ceiling possible AC unite drain stop up.	6/16/14	1st Floor	plant manager office	Plumbing
Downtown ES (2162) 1A	Roof drain stop up slow draining water is causeing mold build up.	8/11/13	2nd Floor	back porch	Roof
Downtown ES (2162) 1A	Leaking from roof in plant manager office.	5/14/14	1st Floor	plant manager office	Roof
Downtown ES (2162) 1A	water leaking in plant managers office & in main hall north end around entrance doors.	6/13/14	1st Floor	plant manager office	Roof

Location	Request Description	Submittal Date	Area Descript	Area Number	Craft	
Egypt EI (2183) 1B	Several pieces of tile is missing off gym floor	5/8/14	Gym		Asbestos	
Egypt EI (2183) 1B	Floor tile is cracking all the way across the hallway	4/23/14	1st Floor	Hallway	Asbestos	
Egypt EI (2183) 1B	Several pieces of tile coming up off floor	2/13/14	1st Floor	Main Hallway	Asbestos	
Egypt EI (2183) 1B	A large area of floor tile is coming up in the area	11/19/13	Annex	Hallway	Asbestos	
Egypt EI (2183) 1B	Floor tile coming up in several spots	1/23/14	Gym		Asbestos	
Egypt EI (2183) 1B	Pieces of floor tile coming up in classroom	1/24/14	2nd Floor	205	Asbestos	
Egypt EI (2183) 1B	per mr hill room 105 window broken out and also room 101 inside door glass broken out	5/9/14			Carpentry	

Egypt EI (2183) 1B	Over several pieces of tile up off floor	7/3/13	Portables	303A	Carpentry
Egypt EI (2183) 1B	Panic bar at back exit door is falling apart	4/24/14	Kitchen		Carpentry
Egypt EI (2183) 1B	Wood on ramp is coming up	4/24/14	Portables	303	Carpentry
Egypt EI (2183) 1B	Door closure broken	4/25/14	Cafeteria	Back Door	Carpentry
Egypt EI (2183) 1B	Door slams when close	4/29/14	Administration Area	Main Office	Carpentry
Egypt EI (2183) 1B	Classroom needs dry erase board	7/16/13	2nd Floor	402	Carpentry
Egypt EI (2183) 1B	Latch keeps getting stuck in entrance door	8/1/13	Gym	Entrance Door	Carpentry
Egypt EI (2183) 1B	Install baracades around hole in asphalt caused by washout adjacent to storm drain.	8/6/13	Parking Lot		Carpentry

Egypt EI (2183) 1B	LOADING DOCK DOOR CANT SECURE. PLANT MGR- GREGORY/416.4150	8/9/13			Carpentry
Egypt EI (2183) 1B	Handle about to fall off door	2/7/14	Administration Area	Main Office	Carpentry
Egypt EI (2183) 1B	Doorknob fell off classroom door	2/7/14	Annex	A5	Carpentry
Egypt EI (2183) 1B	Door will not close all the way up without pulling it close	2/11/14		Exit Door By Loading Dock	Carpentry
Egypt EI (2183) 1B	Water is coming thru the window	2/13/14	Gym		Carpentry
Egypt EI (2183) 1B	per diane gregory 416-4150 1st floor exit door can't secure	2/19/14			Carpentry
Egypt EI (2183) 1B	Door not closing all the way up after opening	2/19/14	1st Floor	Exit Door By Parking Lot	Carpentry
Egypt EI (2183) 1B	Hand rail falling apart	3/6/14		From 1st floor to second floor	Carpentry

Egypt EI (2183) 1B	Water coming in from top of window	8/19/13	1st Floor	Teachers' Lounge	Carpentry
Egypt EI (2183) 1B	Door will not close	8/20/13	Cafeteria	Door To Serving Line Area	Carpentry
Egypt EI (2183) 1B	Wood on ramp has came apart, safety hazard,	8/22/13	Portables	337	Carpentry
Egypt EI (2183) 1B	One of the cafeteria exit doors is stuck will not open	8/27/13	Cafeteria		Carpentry
Egypt EI (2183) 1B	Door knob falling off door	8/27/13	Administration Area		Carpentry
Egypt EI (2183) 1B	Remove baracad from parking lot.	9/4/13			Carpentry
Egypt EI (2183) 1B	Wood is coming up on ramp, safety hazard, side planks coming off	9/6/13	Portables	303	Carpentry
Egypt EI (2183) 1B	Door not closing properly	10/24/13	Cafeteria	Side Door Leading Entrance	Carpentry

Egypt EI (2183) 1B	Door closure is broken	11/13/13	1st Floor	Exit Door	Carpentry
Egypt EI (2183) 1B	Baseboard missing in hallway	11/22/13	2nd Floor	Hallway	Carpentry
Egypt EI (2183) 1B	Panic bar is about to come off both doors	11/26/13	Portables	337B and	Carpentry
Egypt EI (2183) 1B	Repair lock.	12/20/13			Carpentry
Egypt EI (2183) 1B	Door will not unlock from the outside by Plant Manager office	1/6/14	1st Floor	Outside Door	Carpentry
Egypt EI (2183) 1B	Stall door needs to be put back up	1/23/14	Gym	Girls' Restroom	Carpentry
Egypt EI (2183) 1B	Stall door needs to be put back up	1/23/14	2nd Floor	Girls' Restroom	Carpentry
Egypt EI (2183) 1B	Stall door down needs to be put back up	1/27/14	Annex	Girls' Restroom	Carpentry

Egypt EI (2183) 1B	(5) none working window units need to be taken down	1/29/14	Kitchen		Carpentry
Egypt EI (2183) 1B	Doorknob fell off	1/31/14	2nd Floor	206	Carpentry
Egypt EI (2183) 1B	Baseboard is missing in hallway	6/2/14	1st Floor		Carpentry
Egypt EI (2183) 1B	Power outage, make any necessary repairs.	5/28/14			Electrical
Egypt EI (2183) 1B	Light in hallway needs ballast	7/3/13	Hallway/Corridor	North Wing Upstairs	Electrical
Egypt EI (2183) 1B	Light needs a ballast	3/10/14	2nd Floor	409	Electrical
Egypt EI (2183) 1B	Light needs a ballast	3/10/14	2nd Floor	409	Electrical
Egypt EI (2183) 1B	Light needs a ballast	4/21/14	1st Floor	Teacher's Lounge	Electrical

Egypt EI (2183) 1B	(2) closets needs a ballast	4/23/14	1st Floor	Custodian Closet	Electrical
Egypt EI (2183) 1B	Light needs a ballast	4/23/14	2nd Floor	409	Electrical
Egypt EI (2183) 1B	Light switch has a shortage	4/25/14		Serving Line Area	Electrical
Egypt EI (2183) 1B	UNIT VENTS - RM 105, & 309 - NOT COMING ON - PM/GREGORY 416-4150	5/2/14			Electrical
Egypt EI (2183) 1B	ELECTRICAL WIRE IS DOWN IN THE FRONT OF THE BLDG. AND THE BLDG CANNOT BE SECURED.SBE DIANE	8/2/13			Electrical
Egypt EI (2183) 1B	FIRE ALARM 238-017 - CONSTANTLY GOING OFF - SBE/GREGORY 416-4150	8/6/13			Electrical
Egypt EI (2183) 1B	UNIT NOT COMING ON IN PORT-253 PLANT MGR- GREGORY/416.4150	8/13/13			Electrical
Egypt EI (2183) 1B	portable 276 a/c is not coming on per Ms. Gregory 416-4150	8/13/13			Electrical

Egypt EI (2183) 1B	FIRE ALARM SYSTEM-SHOWING TROUBLE-SBE GREGORY 416-4150 KLR	8/14/13			Electrical
Egypt EI (2183) 1B	per ms gregory 416-4150 rooms 402 and 406 unit not coming on	2/5/14			Electrical
Egypt EI (2183) 1B	Emergency lights out	2/12/14		Thru Out Building	Electrical
Egypt EI (2183) 1B	Light needs a ballast	2/19/14	Annex	A8	Electrical
Egypt EI (2183) 1B	Clocks needs to be changed for day saving time	3/4/14		Thru Out Building	Electrical
Egypt EI (2183) 1B	School needs (4) boxes of lights (46807)	8/20/13		All Over Building	Electrical
Egypt EI (2183) 1B	Light needs a ballast	9/3/13	Administration Area	Asst Principal Office	Electrical
Egypt EI (2183) 1B	Light needs a ballast	9/3/13	1st Floor	Girls' Restroom	Electrical

Egypt EI (2183) 1B	Light needs a ballast	9/3/13	2nd Floor	402 and 409	Electrical
Egypt EI (2183) 1B	Light needs a ballast	9/3/13	2nd Floor	201	Electrical
Egypt EI (2183) 1B	Light needs a ballast	9/4/13	Annex	A6	Electrical
Egypt EI (2183) 1B	Lights out in back of building	9/4/13		Back of Building	Electrical
Egypt EI (2183) 1B	Light needs a ballast	9/11/13	1st Floor	101	Electrical
Egypt EI (2183) 1B	Light needs a ballast	9/11/13	Annex	A5	Electrical
Egypt EI (2183) 1B	Need (3) boxes of light	9/30/13		All Over Building	Electrical
Egypt EI (2183) 1B	Light needs a ballast	10/14/13	1st Floor	By Stairs	Electrical

Egypt EI (2183) 1B	teachers lounge socket has not power per Ms. Gregory 416-4150	10/14/13			Electrical
Egypt EI (2183) 1B	Some of the lights are out, some of the lights are flashing	10/28/13	Gym	in front and leading to gym	Electrical
Egypt EI (2183) 1B	HEAT PORT 337 & GYM AREA- BOTH NOT HEATING-PLANT MGR GREGORY 416-4150 KLR	11/13/13			Electrical
Egypt EI (2183) 1B	PUMP NOT COMING ON IN BOILER RM. PLANT MGR- GREGORY/416.4141	11/20/13			Electrical
Egypt EI (2183) 1B	HEAT RM 205-HAS A BURNING SMELL & SMOKING-PLANT MGR GREGORY 416-4150 KLR	12/9/13			Electrical
Egypt EI (2183) 1B	One side light needs a ballast and other light switch has a shortage	12/9/13	1st Floor	105	Electrical
Egypt EI (2183) 1B	A piece is broken off the light fixture that holds the bulb in place	12/9/13	1st Floor	Custodial Closet	Electrical
Egypt EI (2183) 1B	per Ms. Gregory 416-4150 room 105 all the lights are out and switch doesn't work - can't get lights on	12/12/13			Electrical

Egypt EI (2183) 1B	Light needs a ballast	12/12/13	1st Floor	107	Electrical
Egypt EI (2183) 1B	Light switch has a shortage	12/12/13	1st Floor	106	Electrical
Egypt EI (2183) 1B	Light needs a ballast	12/17/13	2nd Floor	206	Electrical
Egypt EI (2183) 1B	UV NOT COMING ON IN RM- 205 PLANT MGR- GREGORY/416.4150	1/8/14			Electrical
Egypt EI (2183) 1B	Lights needs a ballast	1/13/14	Library	Closet and Back Room	Electrical
Egypt EI (2183) 1B	Light switch has a shortage	1/13/14	2nd Floor	409	Electrical
Egypt EI (2183) 1B	Lght needs a ballast	1/13/14	2nd Floor	405	Electrical
Egypt EI (2183) 1B	Light needs a ballast	1/13/14	1st Floor	107	Electrical

Egypt EI (2183) 1B	Light needs a ballast	1/13/14	1st Floor	Hallway	Electrical
Egypt EI (2183) 1B	Lights needs a ballast	1/13/14	2nd Floor	206	Electrical
Egypt EI (2183) 1B	Lights needs a ballast	1/13/14	Annex	A5 and A6	Electrical
Egypt EI (2183) 1B	Light needs a ballast	1/13/14	2nd Floor	201	Electrical
Egypt EI (2183) 1B	UV NOT COMING ON IN RM-105 PLANT MGR- GREGORY/416.4141	1/24/14			Electrical
Egypt EI (2183) 1B	per ms byers total power outage See wo# 414206 time logged there.jd	2/4/14			Electrical
Egypt EI (2183) 1B	per ms gregory 416-1450 AHU in gym leaking and not cooling	5/7/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning

Egypt EI (2183) 1B	UNV NOT COOLING IN RM-308(041). PLANT MGR- GREGORY/416.4141	7/26/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	UNITS ARE NOT COOLING IN RMS 309,401,4707,409. SBE GREGORY 416-4150	8/7/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per ms gregory 416-4150 cafeteria, rooms 101, 103, 201, 204 & 304 blowing cold air	2/5/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per ms gregory 416-4150 the principal and asst principal's offices are not heating	2/7/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Replace unit in principal office	2/7/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Replace unit in main office	2/7/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per diane gregory 416-4150 the gym is blowing cold air	2/11/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	RTU NOT HEATING IN MAIN OFFICE PLANT MGR- GREGORY/416.4150	11/13/13			Heating/Ventilation /Air Conditioning

Egypt EI (2183) 1B	UV NOT HEATING IN RM-101 PLANT MGR- GREGORY/416.4150	11/18/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	BOILER-NOT HEATING- AFFECTS ENTIRE BLDG- PLANT MGR GREGORY 416- 4150 KLR	11/19/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Gym blowing cold air per Diane 416-4150	11/26/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	HEAT MAIN OFC-NOT HEATING-PLANT MGR GREGORY 416-4150 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	HEAT MAIN OFC & KITCHEN AREA-BOTH NOT HEATING- PLANT MGR GREGORY 416- 4141 KLR	1/7/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per diane gregory 416-4150 rooms 304 and 309 blowing cold air	1/8/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Monthly - Oil Lube & Belt-Egypt Elementary - Refer to PM schedule details.	1/14/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	UV NOT HEATING IN RM-204 PLANT MGR- GREGORY/416.4141	1/24/14			Heating/Ventilation /Air Conditioning

Egypt EI (2183) 1B	HEAT RM 309-NOT HEATING- PLANT MGR GREGORY 416- 4150 KLR	1/24/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	COMPRESSOR NOT COMING ON IN GYM PLANT MGR- GREGORY/416.4150	1/27/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	BOILER-1 & BOILER-2-BOTH NOT COMING ON-PLANT MGR GREGORY 416-4150 KLR	2/3/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	UNITS are NOT HEATING in ROOMS 101, 104, 201, 203, and 204 per Diane Gregory, Plant Mgr. 416.4150	2/3/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per ms gregory 416-4150 gym is not heating	2/4/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per ms gregory 416-4150 main office blowing cold air	2/4/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	per ms gregory 416-4150 rooms 301 and 405 not coming on at all	2/4/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Yearly - Boiler 001 - Egypt Elem - 1st Floor - Refer to PM schedule details.	3/7/14			Heating/Ventilation /Air Conditioning

Egypt EI (2183) 1B	Monthly - Filter-Egypt Elementary - Refer to PM schedule details.	11/8/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Monthly - Filter-Egypt Elementary - Refer to PM schedule details.	3/7/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Yearly - Boiler 002 - Egypt Elem - Boiler Rm - Refer to PM schedule details.	3/15/14			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	Monthly - Filter-Egypt Elementary - Refer to PM schedule details.	7/5/13			Heating/Ventilation /Air Conditioning
Egypt EI (2183) 1B	UNIT IS LEAKING WATER IN RM-108 PLANT MGR- GREGORY/416.4141	6/5/14			Plumbing
Egypt EI (2183) 1B	PIPES IS MAKING NOISE IN KITCHEN PLANT MGR- GREGORY/416.4150	5/14/14			Plumbing
Egypt EI (2183) 1B	(2) compartment sink is leaking and release handle to let the water out is coming all the way out	3/28/14	Kitchen		Plumbing
Egypt EI (2183) 1B	BURNER ON STEAM TABLE WONT TURN OFF IN KITCHEN PLANT MGR- GREGORY/416.4150	3/31/14			Plumbing

Egypt EI (2183) 1B	Sink constantly leaking will not shut off	4/8/14	2nd Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	CUST CLOSET BOTTOM WALL IS LEAKING WATER & RM-302 PLANT MGR-GREGORY/416.4141	4/9/14			Plumbing
Egypt EI (2183) 1B	Urinal is stopped up in restroom	4/23/14	2nd Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	Sink stopped up in closet	4/24/14	1st Floor	Custodian Closet	Plumbing
Egypt EI (2183) 1B	Water constantly leaking from sink	4/24/14	Portables	303B	Plumbing
Egypt EI (2183) 1B	per ms gregory 416-4150 in the boiler room there is something knocking	4/30/14			Plumbing
Egypt EI (2183) 1B	1st toilet stopped up, 3rd toilet water coming from bottom of toilet	5/2/14	1st Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	UV IS LEAKING WATER IN RM-203(029). PLANT MGR-GREGORY/416.4141	7/26/13			Plumbing

Egypt EI (2183) 1B	Flush handle broken on toilet	7/30/13	Portables	337B	Plumbing
Egypt EI (2183) 1B	Flush handle not working	8/6/13	Portables	303A	Plumbing
Egypt EI (2183) 1B	FCU 1ST FLR RM 304- LEAKING-SBE GREGORY 416- 4150 KLR	8/13/13			Plumbing
Egypt EI (2183) 1B	Water is leaking from 2nd floor restroom to 1st floor girls'	8/15/13	1st Floor	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	GAS SMELL OUTSIDE KITCHEN REAR ENTRANCE DOOR IN GAS METER CAGE PER SBE-PLANT MGR GREGORY 416-4150 KLR	2/5/14			Plumbing
Egypt EI (2183) 1B	Toilet stopped up	2/5/14	Portables	337A	Plumbing
Egypt EI (2183) 1B	Water coming up from bottom of toilet	2/5/14	2nd Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	STEAMTABLE - CAFE- NEED (2) PILOT LIT - PM/GREGORY 416-4150	2/10/14			Plumbing

Egypt EI (2183) 1B	FLOOR DRAIN B RR GYM AREA-BACKS UP WHEN COMMODES ARE FLUSHED-PLANT MGR GREGORY 416-4150 KLR	2/10/14			Plumbing
Egypt EI (2183) 1B	FLR DRAIN IS BACKING UP IN KITCHEN. PLANT MGR-GREGORY/416.4150	2/13/14			Plumbing
Egypt EI (2183) 1B	Unstop sewer	2/17/14			Plumbing
Egypt EI (2183) 1B	FLR DRAIN IS BACKING UP IN B/RR 2ND FLR PLANT MGR-GREGORY/416-4141	3/6/14			Plumbing
Egypt EI (2183) 1B	PIPE IS FLOODING TEACHERS' LOUNGE FLR PLANT MGR-GREGORY/416.4141	8/21/13			Plumbing
Egypt EI (2183) 1B	Fan coil units room 207 and 209 leaking water per Diane Gregory 416-4150	8/30/13			Plumbing
Egypt EI (2183) 1B	RTU IS LEAKING WATER IN MAIN OFFICE PLANT MGR-GREGORY/416.4141	9/3/13			Plumbing
Egypt EI (2183) 1B	TOILET BASE IS LEAKING IN PRIN/RR PLANT MGR-GREGORY/416.4150	9/5/13			Plumbing

Egypt EI (2183) 1B	A/C RM 401 LEAKING & IT'S GOING DOWN INTO RM 301 PER SBE-PLANT MGR GREGORY 416-4150 KLR	9/9/13			Plumbing
Egypt EI (2183) 1B	Water will not shut all the way off in outside storage room	9/9/13		outside cafeteria door	Plumbing
Egypt EI (2183) 1B	A/C MAIN OFC & RM 207- BOTH LEAKING-PLANT MGR GREGORY 416-4150 KLR	9/9/13			Plumbing
Egypt EI (2183) 1B	Urinal is stopped up	9/10/13	2nd Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	Assist the pipe fitters and mlgw, gas leak on main line in parking lot just west of building.	9/12/13			Plumbing
Egypt EI (2183) 1B	Repair storm drain, damaged while excavating gas main.	9/16/13			Plumbing
Egypt EI (2183) 1B	Main Gas lines have been repaired, make necessary test and repairs , before lighting equipement.	9/18/13			Plumbing
Egypt EI (2183) 1B	GAS LEAK - CAFE - PM/GREGORY 416-4150	9/19/13			Plumbing

Egypt EI (2183) 1B	A/C RMS 205 & 207-BOTH ARE LEAKING-PLANT MGR 416-4150 KLR	9/19/13			Plumbing
Egypt EI (2183) 1B	Toilet stopped up	10/4/13	Gym	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	UV room 103 and 107 leaking per Ms. Gregory 416-4150	10/4/13			Plumbing
Egypt EI (2183) 1B	Test and repair RP Devices per MLG&W.	10/10/13	Mechanical Room		Plumbing
Egypt EI (2183) 1B	Urinal stopped up	10/16/13	2nd Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	1-SINK HAS CAME COMPLETELY OFF WALL & 1-SINK IS HANGING FROM WALL IN B/RR ANNEX PLANT MGR-GREGORY/416.4150	10/18/13			Plumbing
Egypt EI (2183) 1B	1st stall toilet stopped up	10/22/13	1st Floor	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	Toilet stopped up	10/22/13	1st Floor	Boys' Restroom	Plumbing

Egypt EI (2183) 1B	2 compartment sink stopped up	10/28/13	Kitchen	By window facing parking lot	Plumbing
Egypt EI (2183) 1B	Water leaking from top pipe in restroom	10/28/13	Annex	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	GREASE TRAP CONTINUES TO RUN WATER IN PARKING LOT. PLANT MGR- GREGORY/416.4150	10/29/13			Plumbing
Egypt EI (2183) 1B	per Ms. Gregory 416-4150 the boys and girls restrooms in gym are backing up thru floor drains	10/30/13			Plumbing
Egypt EI (2183) 1B	Un-stop main sewer	11/5/13			Plumbing
Egypt EI (2183) 1B	COMMODE TEACHER'S LOUNGE-WATER SHOOTS OUT WHEN FLUSHED-PLANT MGR GREGORY 416-4150 KLR	11/13/13			Plumbing
Egypt EI (2183) 1B	DRAIN B RR 5TH GR HALL 2ND FLR-WHEN COMMODOES ARE FLUSHED, WATER COMES UP THRU FLOOR DRAIN PER SBE-PLANT MGR GREGORY 416-4150 KLR	11/15/13			Plumbing
Egypt EI (2183) 1B	Toilet in 1st stall constantly running non stop	11/18/13	Annex	Girls' Restroom	Plumbing

Egypt EI (2183) 1B	Toilet not flushing only (1) toilet working in girls' restroom and it's not flushing properly	11/20/13	Annex	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	Tissue holder remounted on wall	12/2/13	1st Floor	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	(1) toilet when flush water shoots up from a hole in the toilet, another toilet water is coming from bottom of toilet, only (2) toilets left for students to use	12/19/13	1st Floor	Boys' Restroom	Plumbing
Egypt EI (2183) 1B	Gas odor just outside kitchen, near boiler room. Direct call to Jim Davis Late Wednesday afternoon 1/8/14.	1/10/14		O.S. kitchen near gas service	Plumbing
Egypt EI (2183) 1B	STEAMTABLE KITCHEN AREA- PILOT NEEDS TO BE RE-LIT- WILL NEED FOR LUNCH- PLANT MGR GREGORY 416-4150 KLR	1/17/14			Plumbing
Egypt EI (2183) 1B	Toilet stopped up over flowing	1/17/14	Portables	337B	Plumbing
Egypt EI (2183) 1B	Water will not turn off in sink water constantly running	1/21/14	2nd Floor	Hallway	Plumbing
Egypt EI (2183) 1B	Toilet stopped up	1/27/14	1st Floor	Girls' Restroom	Plumbing

Egypt EI (2183) 1B	Toilet stopped up	1/27/14	2nd Floor	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	Sink is leaking from the bottom	5/2/14	1st Floor	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	Water is leaking from 2nd floor restroom to 1st floor girls'	8/15/13	1st Floor	Girls' Restroom	Plumbing
Egypt EI (2183) 1B	Can't really tell were water is coming from into classroom when it rains	3/31/14	2nd Floor	306 and 308	Roof
Egypt EI (2183) 1B	Water leaking in building from ceiling in (2) places	2/18/14		Main Hall	Roof
Egypt EI (2183) 1B	Water leaking in classroom from roof	3/6/14	Annex	A2 and A4	Roof
Egypt EI (2183) 1B	Water leaking from the ceiling	1/13/14	2nd Floor	205	Roof
Egypt EI (2183) 1B	Water is leaking from the ceiling	1/13/14	Annex	A2	Roof

Egypt EI (2183) 1B	Every time it rains water comes thru the unit vent into the teacher's lounge runs thru into the hallway	6/13/14	1st Floor	Teacher's Lounge	Sheet Metal
Egypt EI (2183) 1B	Locker door off locker	8/20/13	2nd Floor	203	Sheet Metal
Egypt EI (2183) 1B	Mud and water coming thru the unit vent when it rains hard	3/31/14	1st Floor	Faciliator Office	Sheet Metal
Egypt EI (2183) 1B	Water is coming thru the unit vent onto the hallway when it rains	3/31/14	1st Floor	Teachers Lounge	Sheet Metal

Count of Craft	Craft							
Location	Asbestos	Carpentry	Electrical	HVAC	Plumbing	Roof	Sheet Metal	Grand Total
Florida/Kansas ES (2208) 1A	1	26	37	52	32	2	1	151
Grand Total	1	26	37	52	32	2	1	151

Location	Request Description	Submittal Date	Area Descript Area Number		Craft
Florida/Kansas ES (2208) 1A	INSULATE PIPES TO NEWLY INSTALLED CHILLER- REQUESTED BY D HURDLE KLR	4/8/14			Asbestos
Florida/Kansas ES (2208) 1A	Doors to main office will not lock. Doors are to far apart to make lock work.	3/6/14	Administration Area		Carpentry
Florida/Kansas ES (2208) 1A	In need of two round mirrors hung up in corners of room next to ceiling for viewing around corners. We have mirrors on hand in Library.	11/8/13	Library		Carpentry
Florida/Kansas ES (2208) 1A	Main door that has electronic door access on it is draging on door frame and will not let it close. may be hing.	12/2/13	1st Floor	Main Door	Carpentry
Florida/Kansas ES (2208) 1A	Repair window trim prin office	3/26/14	Administration Area	prin	Carpentry
Florida/Kansas ES (2208) 1A	Install threshold	4/4/14			Carpentry
Florida/Kansas ES (2208) 1A	South west front door not latching closed.	4/8/14	1st Floor	out side	Carpentry

Florida/Kansas ES (2208) 1A	Main office entrance doors are sticking, hard to open and close.	5/12/14		Main office	Carpentry
Florida/Kansas ES (2208) 1A	Counter that was moved is coming apart on a corner in front.	5/29/14		Main office	Carpentry
Florida/Kansas ES (2208) 1A	REPLACE DOOR GLASS DUE TO BREAK IN.	7/8/13			Carpentry
Florida/Kansas ES (2208) 1A	transferr four white boards, hang two new ones and bring one new one to be hung	7/24/13	1st Floor		Carpentry
Florida/Kansas ES (2208) 1A	repair hole in wall by room 111 door has hit wall	7/24/13			Carpentry
Florida/Kansas ES (2208) 1A	Need new cable and hooks on flag pole hooks are broken	8/7/13			Carpentry
Florida/Kansas ES (2208) 1A	Door handle broken off of door from dock to kit.	8/8/13		out side	Carpentry
Florida/Kansas ES (2208) 1A	Need two box of ceiling tile 2x4 accustic type	9/10/13		plant manager	Carpentry

Florida/Kansas ES (2208) 1A	repair window out of track	1/9/14		130	Carpentry
Florida/Kansas ES (2208) 1A	main door dragging and breaking	1/9/14		main office	Carpentry
Florida/Kansas ES (2208) 1A	Need to cut to fit ceiling tile replace from water damage one or more boxes	1/10/14	Administration Area		Carpentry
Florida/Kansas ES (2208) 1A	Need ceiling tile cut to fit from water damage one or more boxes	1/10/14	Auditorium		Carpentry
Florida/Kansas ES (2208) 1A	Remove office shelving,cabinets for M.Tutton	1/21/14			Carpentry
Florida/Kansas ES (2208) 1A	need door stop on wall,	1/29/14		105,135,136	Carpentry
Florida/Kansas ES (2208) 1A	Dining hall door stop on floor.	1/29/14		133	Carpentry
Florida/Kansas ES (2208) 1A	Need shade brackets on window to put up shade on.	1/29/14		116	Carpentry

Florida/Kansas ES (2208) 1A	Treshole to main lose.	2/12/14	Administration Area		Carpentry
Florida/Kansas ES (2208) 1A	As a security issue the office can not see front doors and would like a window installed as to they in office can see doors.Doors is all they can see though and windows in doors are very small.	9/16/13		main office	Carpentry
Florida/Kansas ES (2208) 1A	Requestt to take down fence on back parking lot. Not being used any more. 8 foot tall.	3/20/14		out side	Carpentry
Florida/Kansas ES (2208) 1A	Door props 6 for main office and cust closets	3/25/14	1st Floor		Carpentry
Florida/Kansas ES (2208) 1A	Rec in floor that milk boxes plug in to is loose and throws breaker may have short.	9/17/13	Cafeteria	kit	Electrical
Florida/Kansas ES (2208) 1A	Replace three pendum lights with lay in fixtures (two).	2/28/14	Library		Electrical
Florida/Kansas ES (2208) 1A	Two ballast bad in boiler room two lamp each	3/20/14	Mechanical Room		Electrical
Florida/Kansas ES (2208) 1A	one ballast bad in office two lamp	3/20/14		plant manager	Electrical

Florida/Kansas ES (2208) 1A	Exit signs 3 battery's bad, also emerg. lights 3 battery's bad	10/21/13		east hall	Electrical
Florida/Kansas ES (2208) 1A	Exit signs 3 battery's bad, also emerg lights 4 battery's bad.	10/21/13		middle hall	Electrical
Florida/Kansas ES (2208) 1A	Exit signs 3 in hall 1 in stair way battery's bad, emerg lights 5 battery's bad.	10/21/13		west hall	Electrical
Florida/Kansas ES (2208) 1A	Exit lights 4 battery's bad, emerg lights 4 battery's bad.	10/21/13	Cafeteria		Electrical
Florida/Kansas ES (2208) 1A	Exit signs 1 battery bad, emerg lights 2 battery's bad.	10/21/13	Kitchen		Electrical
Florida/Kansas ES (2208) 1A	Exit signs 2 battery's bad, emerg lights 5 battery's bad.	10/21/13	2nd Floor		Electrical
Florida/Kansas ES (2208) 1A	Emerg lights 1 battery bad.	10/21/13	Library		Electrical
Florida/Kansas ES (2208) 1A	Emerg lights 3 battery's bad	10/21/13	1st Floor	pre k	Electrical

Florida/Kansas ES (2208) 1A	Exit signs 1 battery bad, emerg lights 2 battery's bad	10/21/13	Auditorium		Electrical
Florida/Kansas ES (2208) 1A	Remove 4 globe light fixtures in front office. Install lay in fixtures to improve lighting in front area.	11/5/13			Electrical
Florida/Kansas ES (2208) 1A	Connect electrical to new chiiller	11/14/13			Electrical
Florida/Kansas ES (2208) 1A	Replace incandesent light fixtures in main office with fluorescent fixures. Area over the GOS work station is very dark.	11/26/13	Administration Area		Electrical
Florida/Kansas ES (2208) 1A	wiring for stolen cond.	3/26/14			Electrical
Florida/Kansas ES (2208) 1A	Ballast bad 4 lamp 1 fixture	3/31/14	Administration Area	100d	Electrical
Florida/Kansas ES (2208) 1A	A/C UNIT is NOT COMING ON in ROOM 113 per Jim Thomason, Plant Mgr. 497.7782	4/24/14			Electrical
Florida/Kansas ES (2208) 1A	tie loop pumps into chiller	4/24/14			Electrical

Florida/Kansas ES (2208) 1A	run power to evap. barrel heat trace	4/24/14			Electrical
Florida/Kansas ES (2208) 1A	Room 135 A/C fan motor burned up no air.	6/24/14	1st Floor	135	Electrical
Florida/Kansas ES (2208) 1A	2-AHU NOT COMING ON IN MAIN OFFICE(029), CAFE(059) . SBE-THOMPSON/416-7874	7/24/13			Electrical
Florida/Kansas ES (2208) 1A	Master clock will not keep time, also need bells set. 036-040	7/25/13		main office	Electrical
Florida/Kansas ES (2208) 1A	Ballast bad one fixture two lamp	7/26/13		sbe office	Electrical
Florida/Kansas ES (2208) 1A	cancel earlyer request. Need 100 lamps, stock # 46807	7/26/13		sbe office	Electrical
Florida/Kansas ES (2208) 1A	GAS FIRED WATER HEATER BOILER RM SERVES KITCHEN AREA-NOT COMING ON-NO HOT WATER TO KITCHEN-SBE THOMASON 416-7874 KLR	8/5/13			Electrical
Florida/Kansas ES (2208) 1A	need 10 lens covers for kit	8/7/13	Cafeteria	kit	Electrical

Florida/Kansas ES (2208) 1A	Pre K rest room exhaust Fan motor locked up.	8/14/13	1st Floor	102-A	Electrical
Florida/Kansas ES (2208) 1A	Three pole lights in front are out, plus two led lights on blg are not working.	8/14/13		out side	Electrical
Florida/Kansas ES (2208) 1A	Exhust fans for restrooms are not working. They are on roof. Don't have numbers, never were numbered. There may be six. Don,t think they have worked in years.	8/20/13	Restroom (Boys)	All main restrooms	Electrical
Florida/Kansas ES (2208) 1A	Front proch lights, three lights are reg light bulbs, three look like ballast driven not sure, so five out.	8/26/13		out side	Electrical
Florida/Kansas ES (2208) 1A	HAS A COMPLETE POWER OUTAGE-PLANT MGR THOMASON 416-1950 KLR	9/11/13			Electrical
Florida/Kansas ES (2208) 1A	Three (3) units are NOT COMING ON in the MAIN OFFICE per Jim Thomason, Plant Mgr. 497.7782	1/7/14			Electrical
Florida/Kansas ES (2208) 1A	exhust fans for all student restrooms are not working.	2/28/14		all restrooms	Electrical
Florida/Kansas ES (2208) 1A	need plastic covers for four foot lamps T8 for kit area. one box with ends.	8/2/13		plant manager	Electrical

Florida/Kansas ES (2208) 1A	Need at lease three boxes of t8 lamps stock#46807	12/16/13			Electrical
Florida/Kansas ES (2208) 1A	Replace chiller. Unit is beyond reppair. (Purchase only. Instalation to be by SCS)	10/17/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Repair themostat on unit	3/21/14		132	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	get info needed to repair ofc units	3/21/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	unload chiller	10/4/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	cafe unit not coming on	3/6/14			Heating/Ventilation /Air Conditioning

Florida/Kansas ES (2208) 1A	boiler down	3/7/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Monthly - Filter-Florida/Kansas Elementary - Refer to PM schedule details.	3/9/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Boiler #1 -- Replace low water cutoff controller ----- model #750 mcdonnell miller part # 176207	10/18/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	AHU - 2 fresh air hot water has been turned off and AHU - 14 also has been turned off reason, don't know, but no heat in main office.	10/25/13	Administration Area		Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	shut down chiller and drain for pipe fitters to start disconnecting.	10/28/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	get control boards off old chiller	11/7/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Monthly - Filter-Florida/Kansas Elementary - Refer to PM schedule details.	11/10/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	set new chiller	11/13/13			Heating/Ventilation /Air Conditioning

Florida/Kansas ES (2208) 1A	Remove and install a chiller	11/14/13	Parking Lot		Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Monthly - Oil Lube & Belt- Florida/Kansas Elem - Refer to PM schedule details.	11/17/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	install alarms	12/2/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	purchase 5ton cond.	3/27/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	purchase two 2 ton cond.	3/27/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	chiller --- put plugs in barrel and open valves also check for leaks	4/8/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	install 5 ton unit	4/8/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Get chiller ready for start-up --- fill out pre-start checklist	4/9/14			Heating/Ventilation /Air Conditioning

Florida/Kansas ES (2208) 1A	chiller checklist --- adding glycol	4/9/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	start up chiller	4/24/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	A/C MAIN OFC AREA-NOT COMING ON-PLANT MGR THOMASON KLR	5/8/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	ofc not cooling	5/14/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	deliver cond. unit	6/5/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	install cond. unit in guidance ofc	6/5/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	install cond. unit in lounge	6/5/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Monthly - Oil Lube & Belt- Florida/Kansas Elem - Refer to PM schedule details.	6/15/14			Heating/Ventilation /Air Conditioning

Florida/Kansas ES (2208) 1A	Room 117 hvac running but air is hot filter maybe stoped up	6/25/14	1st Floor	classroom	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Monthly - Filter-Florida/Kansas Elementary - Refer to PM schedule details.	7/7/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	clean chiller	7/11/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	AHU NOT COOLING IN CAFE (058) SBE-THOMPSON/416-7874	7/24/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	ahu #3 not cooling --- bad actuator	7/29/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	2-AHU NOT COOLING IN AUDIT (093) LIBRARY (094) PLANT MGR-THOMPSON/416.7300	7/30/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	FCU-3 RM 134-NOT COOLING-SBE THOMASON 416-1950 KLR	8/5/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Fresh air unit 032-062 belt brooken.	8/20/13	2nd Floor		Heating/Ventilation /Air Conditioning

Florida/Kansas ES (2208) 1A	chiller down	8/26/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	A/C MAIN OFC-NOT COOLING-PLANT MGR 416-7874 KLR	9/9/13			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	pull wire for chiller	1/2/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	UNIT NOT HEATING IN RM-132 PLANT MGR-JIM/416.7874	1/16/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	No heat needs belt A26	1/21/14	Library		Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	No heat valve not opening	1/21/14		122	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	No heat main office & risk management	1/24/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	boiler down	1/27/14			Heating/Ventilation /Air Conditioning

Florida/Kansas ES (2208) 1A	Still no heat in main office.	1/29/14	Administration Area	100	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Pre K play room no heat valve bad	1/29/14		102	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	108 Art room valve bad no heat	1/29/14		108	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	104 unit 036-090 fan motor bad.	1/29/14		104	Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	put alarm switches on chiller	2/14/14			Heating/Ventilation /Air Conditioning
Florida/Kansas ES (2208) 1A	Boys rest room west hall third stall toilet set is broken in half	10/2/13	1st Floor		Plumbing
Florida/Kansas ES (2208) 1A	Boys rest room second toilet seat broken,	10/2/13	2nd Floor		Plumbing
Florida/Kansas ES (2208) 1A	First compartment sink is leaking around base of pipe may need new seal.	10/14/13	Kitchen		Plumbing

Florida/Kansas ES (2208) 1A	P-7 coupling gone	10/23/13			Plumbing
Florida/Kansas ES (2208) 1A	3 1/2" line leaking behind Boiler #2	10/23/13			Plumbing
Florida/Kansas ES (2208) 1A	D9 leaking on water line to ice maker	10/23/13	Kitchen		Plumbing
Florida/Kansas ES (2208) 1A	gasket on return line above pump is bad leaking	10/23/13		boiler room	Plumbing
Florida/Kansas ES (2208) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13			Plumbing
Florida/Kansas ES (2208) 1A	Two seats boys first floor east hall, one seat boys upstairs.	12/4/13		rest rooms	Plumbing
Florida/Kansas ES (2208) 1A	Main line stoped up both tollets will not flush.	4/10/14	1st Floor	pre k	Plumbing
Florida/Kansas ES (2208) 1A	Flush handle leaking	4/11/14		pre k	Plumbing

Florida/Kansas ES (2208) 1A	Girls rest room toilet seat broken n half	4/11/14		west hall	Plumbing
Florida/Kansas ES (2208) 1A	Cold water line leaking in ceiling drip on prep table	4/23/14	Kitchen		Plumbing
Florida/Kansas ES (2208) 1A	TOILET is STOPPED UP and WATER is RUNNING on the FLOOR per Jim Thompson, Plant Mgr. 497.7782	4/23/14			Plumbing
Florida/Kansas ES (2208) 1A	ALL TOILETS ARE OVERFLOWING IN CAFE/RR PLANT MGR-THOMASON/497.7782	4/30/14			Plumbing
Florida/Kansas ES (2208) 1A	Unstop area drains	6/9/14			Plumbing
Florida/Kansas ES (2208) 1A	Unrul boys westhall something in it can't get it out stoped up.	6/24/14		rest room	Plumbing
Florida/Kansas ES (2208) 1A	West hall boys unrel on left leaking	6/25/14	1st Floor	rest room	Plumbing
Florida/Kansas ES (2208) 1A	water cooler on main hall by rm 106 runs altime can not unplug	7/25/13		hall way	Plumbing

Florida/Kansas ES (2208) 1A	water cooler on second floor hall will not stop runing 036-114	7/25/13		hall way	Plumbing
Florida/Kansas ES (2208) 1A	Water coolers on west hall need handles - push bars to work. three in all.	8/7/13	1st Floor		Plumbing
Florida/Kansas ES (2208) 1A	Floor drain behind serving line stoped up slip hazzared	8/20/13	Kitchen		Plumbing
Florida/Kansas ES (2208) 1A	stoped up unral west hall 1st floor	9/10/13		rest room	Plumbing
Florida/Kansas ES (2208) 1A	main ofc leaking	9/11/13			Plumbing
Florida/Kansas ES (2208) 1A	Girls restroom west hall tollet seat broken both sides third one from right.	12/19/13		rest room	Plumbing
Florida/Kansas ES (2208) 1A	WATER LINE TO RR BY MAIN OFC- HAS BURST-PLANT MGR THOMASON KLR	1/7/14			Plumbing
Florida/Kansas ES (2208) 1A	Floor drain in office lounge won't drain.	1/13/14	Administration Area		Plumbing

Florida/Kansas ES (2208) 1A	Floor drains in rest rooms main office won't drain.	1/13/14	Administration Area	rest room	Plumbing
Florida/Kansas ES (2208) 1A	Second unil leaking around spud sprays students.	1/13/14	Restroom (Boys)	east hall	Plumbing
Florida/Kansas ES (2208) 1A	Tolilet leaking at spud on to floor one on left.	1/13/14	1st Floor	teachers lounge	Plumbing
Florida/Kansas ES (2208) 1A	Assist HVAC	1/28/14			Plumbing
Florida/Kansas ES (2208) 1A	Pump #6 036-052 is leaking	2/11/14	Mechanical Room		Plumbing
Florida/Kansas ES (2208) 1A	62+ shengels or tabs have been blown off. Most in front.	1/24/14		ROOF	Roof
Florida/Kansas ES (2208) 1A	room 134 roof leak	2/11/14		134	Roof
Florida/Kansas ES (2208) 1A	A peace of sideing has blown off blg.	7/1/13		out side	Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Georgian Hills MS (2255) 1B	5	4	101	76	61	5	46	10	3	311
Grand Total	5	4	101	76	61	5	46	10	3	311

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
Georgian Hills MS (2255) 1B	replace strain ceiling tile in two classroom	8/29/13	Classroom			Asbestos
Georgian Hills MS (2255) 1B	Ceiling tile was damaged due to a flood. Tile is the type that was never dropped. ASBESTOS REMOVAL AND PAINT CEILING	8/29/13	1st Floor	108		Asbestos
Georgian Hills MS (2255) 1B	Gym floor may need to be refinished.	9/11/13	Gym	floor		Asbestos
Georgian Hills MS (2255) 1B	remove carpet and install floor tile	3/20/14	Administration Area	fin. sec. office and nurses station		Asbestos
Georgian Hills MS (2255) 1B	Floor tile (possible) ACM missing through out in classroom 204. Ref. WO 403073	1/8/14	2nd Floor			Asbestos
Georgian Hills MS (2255) 1B	The cover plate holding the internet wiring has come apart and cables are exposed. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	12/19/13	1st Floor	104-computer lab		Cabling
Georgian Hills MS (2255) 1B	Add an additional line for computers.	9/16/13	1st Floor	109		Cabling

Georgian Hills MS (2255) 1B	Repair jacks in room 104 - lab and activate the second internet outle in plc coach office	4/7/14				Cabling
Georgian Hills MS (2255) 1B	Activate the second internet outlet in receptacle box. Request comes from i.t. person that was onsite.	1/30/14	Administration Area	PLC Coach office		Cabling
Georgian Hills MS (2255) 1B	REPAIR WORK ON EXTERIOR WINDOWS	1/27/14				Carpentry
Georgian Hills MS (2255) 1B	replace 4 pieces of glass damaged by vandalism.	8/29/13				Carpentry
Georgian Hills MS (2255) 1B	Fabricate window guards for classroom windows at rear of school.	9/17/13				Carpentry
Georgian Hills MS (2255) 1B	Door elbow has been broken.	9/20/13	Gym	entrance near room 211		Carpentry
Georgian Hills MS (2255) 1B	Install windows guards on Gym.	9/25/13				Carpentry
Georgian Hills MS (2255) 1B	Install window guards at rear of main building.	9/25/13				Carpentry

Georgian Hills MS (2255) 1B	Install plywood on science tables.	9/25/13	Classroom		Carpentry
Georgian Hills MS (2255) 1B	Move keybox from old office to the new one. Walls are concrete and are hard to drill through.	8/23/13	Administration Area	assistant principal office	Carpentry
Georgian Hills MS (2255) 1B	Door won't close completely.	8/28/13	Custodial Closet	annex	Carpentry
Georgian Hills MS (2255) 1B	Door handle is missing from restroom door as you exit.	10/22/13	Gym	boys locker room	Carpentry
Georgian Hills MS (2255) 1B	Door can't be secured exiting rear of locker room.	10/22/13	Gym	girls locker room	Carpentry
Georgian Hills MS (2255) 1B	Replace 20 windows at rear of school damaged by vandalism.	10/24/13			Carpentry
Georgian Hills MS (2255) 1B	Remove window guards from windows on rear of building.	10/25/13			Carpentry
Georgian Hills MS (2255) 1B	Baseboard is lose near door.	11/5/13	1st Floor	106	Carpentry

Georgian Hills MS (2255) 1B	Light fixture came apart from ceiling as plant mgr. was changing bulbs. Is there anyway the rest of the ceiling can be looked at?	11/5/13	Gym	coaches office/storage	Carpentry
Georgian Hills MS (2255) 1B	Window cracked due to vandilsm.	11/5/13	1st Floor	guidance office	Carpentry
Georgian Hills MS (2255) 1B	Storage room doors (2) will not completely close to be locked.	11/7/13	1st Floor	108	Carpentry
Georgian Hills MS (2255) 1B	Replace strip plate on storage room door frame.	11/18/13	Cafeteria	closet near stage	Carpentry
Georgian Hills MS (2255) 1B	T-Crossing and ceiling tiles are hanging in Room 204 per Gale Dawson, Plant Mgr. 416.3940	11/26/13			Carpentry
Georgian Hills MS (2255) 1B	per Mr. Whitelow 416-3740 the handrail came off of the wall in the special needs stairwell in the annex building	12/11/13			Carpentry
Georgian Hills MS (2255) 1B	Floortile is missing from areas in classroom floor.	12/11/13	2nd Floor	204	Carpentry
Georgian Hills MS (2255) 1B	Doors have somehow got stuck together and will not open by key or force.	12/16/13	Mechanical Room	lower level under gym	Carpentry

Georgian Hills MS (2255) 1B	Fire doors not closing when alarm goes off. Leading to gym from 1st floor.	12/17/13	Hallway/Corridor		Carpentry
Georgian Hills MS (2255) 1B	Fire doors in hallway not latching when alarm goes off.	12/17/13	Annex		Carpentry
Georgian Hills MS (2255) 1B	Remove screw in center piece in doorframe so delievery can be made. Immediate attention for Barry Frost.	12/19/13	Gym	north entrance door	Carpentry
Georgian Hills MS (2255) 1B	Replace damaged ceiling tile in east hall.	8/29/13			Carpentry
Georgian Hills MS (2255) 1B	Two handrails have been ripped from walls.	8/30/13	Stairway	staircase leading underneath gym	Carpentry
Georgian Hills MS (2255) 1B	Three windows damaged due to vandilsm.	9/3/13	1st Floor	107	Carpentry
Georgian Hills MS (2255) 1B	Handrail broken off due to vandilsm.	9/3/13	Portables	316	Carpentry
Georgian Hills MS (2255) 1B	Windows damaged due to vandilsm.	9/3/13	Annex	111	Carpentry

Georgian Hills MS (2255) 1B	Windows damaged due to vandilism.	9/3/13	Annex	112	Carpentry
Georgian Hills MS (2255) 1B	Window damaged due to vandilism.	9/4/13	1st Floor	103	Carpentry
Georgian Hills MS (2255) 1B	Window damaged due to vandilism.	9/4/13	Hallway/Corridor	under gym near elevator	Carpentry
Georgian Hills MS (2255) 1B	Three of the four screws that holds the pole for doors to close are nissing and pole may fall.	9/6/13	Gym	entrance from hallway	Carpentry
Georgian Hills MS (2255) 1B	Baseboard is missing under dry eraser board.	9/9/13	1st Floor	112	Carpentry
Georgian Hills MS (2255) 1B	Classroom won't close completely.	9/10/13	1st Floor	112	Carpentry
Georgian Hills MS (2255) 1B	Door won't close properly.	9/17/13	Annex	215	Carpentry
Georgian Hills MS (2255) 1B	Principial wants wooden art that's drilled into brick wall to be moved to gymnasium front hall.	7/12/13	2nd Floor	across from main office	Carpentry

Georgian Hills MS (2255) 1B	Baseboard is loose from wall.	7/17/13	1st Floor	106	Carpentry
Georgian Hills MS (2255) 1B	Door will not completely close to secure access to other areas of buildings.	7/17/13	Hallway/Corridor	hallway to annex	Carpentry
Georgian Hills MS (2255) 1B	Remove old wooden handrails that's been replaced underneath stairs.	7/17/13	Gym	underneath stairs	Carpentry
Georgian Hills MS (2255) 1B	Trophy seems to be drilled onto the floor.	7/31/13	Hallway/Corridor	Main lobby	Carpentry
Georgian Hills MS (2255) 1B	Sheetrock has stripped from wall with projector attached to it.	7/31/13	1st Floor	107	Carpentry
Georgian Hills MS (2255) 1B	Cover science tables book slots per request from principal.	8/5/13	1st Floor	108	Carpentry
Georgian Hills MS (2255) 1B	Remove old gas hookups/hardware from science lab tables per request from principal.	8/5/13	1st Floor	108	Carpentry
Georgian Hills MS (2255) 1B	Window needs replacing due to vandilsm.	8/5/13	Gym	102	Carpentry

Georgian Hills MS (2255) 1B	Window needs replacing due to vandilsm.	8/5/13	Gym	Near north entrance	Carpentry
Georgian Hills MS (2255) 1B	Install chains onto four concrete particians for toilet tissue.	8/8/13	Restroom (Girls)	Lower floor beneath gym	Carpentry
Georgian Hills MS (2255) 1B	There's no baseboard on northwall.	8/9/13	1st Floor	104	Carpentry
Georgian Hills MS (2255) 1B	Hardware on top off is bent and door won't open/close properly.	8/9/13	Hallway/Corridor	Door leading to 2nd floor	Carpentry
Georgian Hills MS (2255) 1B	Hardware has been ripped off at the top of the door.	8/15/13	2nd Floor	Entrance door to main hall	Carpentry
Georgian Hills MS (2255) 1B	Stall doesn't have a door for students privacy.	8/21/13	Restroom (Girls)	2nd floor	Carpentry
Georgian Hills MS (2255) 1B	Handrail has been ripped from wall.	8/21/13	Hallway/Corridor	Leading to lower floor under gym	Carpentry
Georgian Hills MS (2255) 1B	Replace four ceiling tiles damaged from water.	6/16/14	2nd Floor	215	Carpentry

Georgian Hills MS (2255) 1B	Replace ceiling tile due to water damage.	6/16/14	1st Floor	101-band room	Carpentry
Georgian Hills MS (2255) 1B	Replace one ceiling tile due to water damage.	6/16/14	2nd Floor	210	Carpentry
Georgian Hills MS (2255) 1B	Replace five ceiling tiles due to water damage.	6/16/14	2nd Floor	204	Carpentry
Georgian Hills MS (2255) 1B	Replace six ceiling tiles due to water damage.	6/16/14	2nd Floor	205	Carpentry
Georgian Hills MS (2255) 1B	Replace two ceiling tiles due to water damage.	6/16/14	2nd Floor	207	Carpentry
Georgian Hills MS (2255) 1B	Replace four ceiling tiles due to water damage.	6/16/14	2nd Floor	209	Carpentry
Georgian Hills MS (2255) 1B	Replace six ceiling tiles due to water damage.	6/16/14	2nd Floor	208	Carpentry
Georgian Hills MS (2255) 1B	Replace twenty ceiling tiles due to water damaged. A lift will be needed to replace ceiling tiles due to the height of the ceiling.	6/16/14	Cafeteria		Carpentry

Georgian Hills MS (2255) 1B	Replace eight ceiling tiles due to water damage.	6/16/14	Cafeteria	Serving line	Carpentry
Georgian Hills MS (2255) 1B	HAND RAIL IS VERY LOOSE IN GYM 2ND FLR PLANT MGR- WHITELOW/921.8492	2/25/14			Carpentry
Georgian Hills MS (2255) 1B	Door vent has been kicked out of the door.	3/5/14	Restroom (Boys)	2nd floor	Carpentry
Georgian Hills MS (2255) 1B	Door elbow was ripped from door and it won't open/close properly.	3/7/14	Restroom (Boys)	Main lobby-2nd floor	Carpentry
Georgian Hills MS (2255) 1B	per mr whitelow 416-0807 handrail in the special ed area has been ripped off the wall annex hallway	3/27/14			Carpentry
Georgian Hills MS (2255) 1B	Cut and replace water damaged ceiling tile around exposed pipes in ceiling.	3/31/14	Library	2nd floor	Carpentry
Georgian Hills MS (2255) 1B	Center piece for doors to close/lock properly has been damaged.	4/2/14	Gym	Entrance near upper level	Carpentry
Georgian Hills MS (2255) 1B	HANDRAIL COMING LOOSE FROM WALL IN ANNEX STAIRWELL-SOMEONE COULD FALL WHEN GRABBING HOLD OF HANDRAIL-PLANT MGR WHITELOW 416-0807 KLR	4/11/14			Carpentry

Georgian Hills MS (2255) 1B	Replace three ceiling tile due to water damage. Plant mgr. doesn't have any onsite.	4/17/14	Library	2nd floor	Carpentry
Georgian Hills MS (2255) 1B	Door won't close between main entrance and main hall.	4/23/14	Hallway/Corridor	main hall	Carpentry
Georgian Hills MS (2255) 1B	Replace ceiling tile that's been damaged to rook leaks.	4/29/14	Cafeteria	stage	Carpentry
Georgian Hills MS (2255) 1B	Replace ceiling tile damaged due to roof leak.	4/29/14	2nd Floor	Main entrance hall	Carpentry
Georgian Hills MS (2255) 1B	Door is closing very fast as kitchen staff uses the door to go to the restroom.	4/29/14	Kitchen	restroom entrance	Carpentry
Georgian Hills MS (2255) 1B	PORTABLES 277 and 310 DOOR PLATES needs replacing DUE to BREAK-IN per Mr. Whitelow, Plant Mgr. 416.0807	5/27/14			Carpentry
Georgian Hills MS (2255) 1B	replace broken glass in two caft. windows	6/4/14	Cafeteria		Carpentry
Georgian Hills MS (2255) 1B	Handrail has been broken.	8/22/13	Stairway	near room 208	Carpentry

Georgian Hills MS (2255) 1B	Door will not close.	2/17/14	Administration Area	Main office	Carpentry
Georgian Hills MS (2255) 1B	WATER is LEAKING through the WINDOW in the PRINCIPAL'S OFFICE and WATER is RUNNING ONTO the AIR HANDLING UNIT per Mr. Whitelow, Plant Mgr. 416.0807	2/4/14			Carpentry
Georgian Hills MS (2255) 1B	Water is leaking at the base of the lockers when it rains.	2/4/14	1st Floor	hallway	Carpentry
Georgian Hills MS (2255) 1B	HANDRAIL VERY LOOSE on the NORTHWEST STAIRWELL per Mr. Whitelow, Plant Mgr. 416.0807	2/6/14			Carpentry
Georgian Hills MS (2255) 1B	per mr whitelow 416-0807 plant manager's boiler room entrance door cylinder just spins can't open	2/7/14			Carpentry
Georgian Hills MS (2255) 1B	Window cracked.	1/2/14	Cafeteria		Carpentry
Georgian Hills MS (2255) 1B	Windows cracked due to vandilsm.	1/2/14	Annex	112	Carpentry
Georgian Hills MS (2255) 1B	Two windows are cracked. One due to vandilsm and one from a bullet.	1/3/14	Annex	102	Carpentry

Georgian Hills MS (2255) 1B	Window damaged due to vandilsm.	1/3/14	Annex	103	Carpentry
Georgian Hills MS (2255) 1B	Door will not completely close.	1/7/14	2nd Floor	208	Carpentry
Georgian Hills MS (2255) 1B	Door is very hard and sometimes will not open from the outside.	1/7/14	Cafeteria	kitchen rear entrance	Carpentry
Georgian Hills MS (2255) 1B	Install weather strips on unused exit door in plant mgrs. office to keep cold air out.	1/8/14	Mechanical Room	boiler room	Carpentry
Georgian Hills MS (2255) 1B	REAR GLASS GYM DOOR ENTRANCE-IS SHATTERED ALL THE WAY DOWN-COULD FALL OUT AT ANY TIME PER SBE-PLANT MGR WHITELOW 416-0807 KLR	1/9/14			Carpentry
Georgian Hills MS (2255) 1B	Ceiling tile that has a smoke detector attached needs replacing due to rain damage.	1/13/14	2nd Floor	Main lobby	Carpentry
Georgian Hills MS (2255) 1B	Repalce damage ceiling tile from Roof leak.	1/14/14	Cafetorium		Carpentry
Georgian Hills MS (2255) 1B	EXIT WINDOW CANT SECURE IN RM-104 GYM. PLANT MGR- WHITELOW/921.8492	1/14/14			Carpentry

Georgian Hills MS (2255) 1B	Repair exit door glass from gym floor level to outside fire escape.	1/14/14	Gym		Carpentry
Georgian Hills MS (2255) 1B	A few pieces of floor tile are either cracked or missing.	1/16/14	2nd Floor	206	Carpentry
Georgian Hills MS (2255) 1B	Remove six science lab tables because they're inoperable and not being used. I spoke with Mr. Frost about this.	2/17/14	1st Floor	108	Carpentry
Georgian Hills MS (2255) 1B	Remove six inoperable science lab table.	2/13/14	1st Floor	108	Carpentry
Georgian Hills MS (2255) 1B	Add an additional shelf for serving.	10/23/13	Concession Stand	gym	Carpentry
Georgian Hills MS (2255) 1B	Remove drawers from science lab tables and replace them with plywood.	10/2/13	1st Floor	109	Carpentry
Georgian Hills MS (2255) 1B	Remove screen door and lock in kitchen. Request comes from fire inspector.	10/1/13	Kitchen	cafeteria	Carpentry
Georgian Hills MS (2255) 1B	Five boxes of bulbs are needed for light fixtures. item number is 147348. attn: Ken White	12/23/13	Hallway/Corridor		Electrical

Georgian Hills MS (2255) 1B	Bells are ringing throughtout the day unscheduled. id#114-125	9/20/13	Administration Area	Main office	Electrical
Georgian Hills MS (2255) 1B	Light fixture will not come after changing bulb. Elcetrical boxes were checked and all seemed fine.	9/30/13	Custodial Closet	annex buliding 1st floor	Electrical
Georgian Hills MS (2255) 1B	Bells aren't ringing. id#114-125	8/22/13	Administration Area	Main office	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in the light fixture.	8/28/13	1st Floor	108	Electrical
Georgian Hills MS (2255) 1B	Emergency lights aren't working.	10/1/13	Cafeteria	kitchen	Electrical
Georgian Hills MS (2255) 1B	Emergency lights aren't working.	10/1/13	Gym	west entrance	Electrical
Georgian Hills MS (2255) 1B	Emergency lights aren't working.	10/1/13	Gym	east exit	Electrical
Georgian Hills MS (2255) 1B	Emergency light isn't working.	10/1/13	Annex	216	Electrical

Georgian Hills MS (2255) 1B	Emergency light isn't working.	10/1/13	Annex	112	Electrical
Georgian Hills MS (2255) 1B	Emergency light isn't working.	10/1/13	Annex	214	Electrical
Georgian Hills MS (2255) 1B	Emergency light isn't working.	10/1/13	1st Floor	105	Electrical
Georgian Hills MS (2255) 1B	Fire/smoke doors not latching or closing when alarm goes off.	10/1/13	Hallway/Corridor	annex building	Electrical
Georgian Hills MS (2255) 1B	Fire/smoke door not latching or closing when alarm goes off.	10/1/13	Hallway/Corridor	leading to gym from 1st floor	Electrical
Georgian Hills MS (2255) 1B	Cafeteria manager says light isn't on when she arrives and it's very dark at door and she feels unsafe.	10/18/13	Cafeteria	Rear entrance	Electrical
Georgian Hills MS (2255) 1B	gym unit in girls locker no power	10/25/13			Electrical
Georgian Hills MS (2255) 1B	Two light fixture bulbs and/or ballast needs replacing. Fixtures are over steps.	10/28/13	Stairway	near main hall elevator	Electrical

Georgian Hills MS (2255) 1B	Set time on master clock due to daylight saving time i.d.#114-125	10/30/13	Administration Area	main office	Electrical
Georgian Hills MS (2255) 1B	Light fixture came apart from ceiling and is now hanging apart touching the floor.	11/5/13	Gym	coaches office	Electrical
Georgian Hills MS (2255) 1B	Four lights are out over court.	11/5/13	Gym	basketball court	Electrical
Georgian Hills MS (2255) 1B	Outlet under smart board is cracked at the top.	11/7/13	1st Floor	105	Electrical
Georgian Hills MS (2255) 1B	Repalce the ballast in two light fixtures.	11/14/13	1st Floor	103	Electrical
Georgian Hills MS (2255) 1B	On/off switch won't operate to turn hall lights on.	12/3/13	Annex	1st floor hall	Electrical
Georgian Hills MS (2255) 1B	Replace bulbs or ballasts in two light fixtures. Fixtures are over stairs.	12/3/13	2nd Floor	Stairwell	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light fixture.	12/3/13	Gym	2nd level entrance	Electrical

Georgian Hills MS (2255) 1B	ASST PRIN'S OFC-NOT COMING ON-PLANT MGR WHITELOW 416-0807 KLR	12/13/13			Electrical
Georgian Hills MS (2255) 1B	Gym bleachers aren't coming out evenly for proper setup.	12/16/13	Gym		Electrical
Georgian Hills MS (2255) 1B	Hallway clock has been pulled from it's base.	12/19/13	2nd Floor	main hall	Electrical
Georgian Hills MS (2255) 1B	Cable cords hanging from buildings not secured from students touching or damaging them.	9/3/13	Grounds	west/north side outside of buildings	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light fixture.	9/3/13	Stairway	annex north stairwell	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light fixture.	9/3/13	1st Floor	hallway exit near room 108	Electrical
Georgian Hills MS (2255) 1B	Coverplate is needed for switch to turn off/on hallway lights.	9/4/13	Annex	stairwell heading to 2nd floor	Electrical
Georgian Hills MS (2255) 1B	A bulb replacement is needed for this unique light fixture. model#33113Q	9/10/13	Hallway/Corridor	attendance office	Electrical

Georgian Hills MS (2255) 1B	Electrical outlet cover plate needs replacing.	8/5/13	Gym	west wall	Electrical
Georgian Hills MS (2255) 1B	Magnetic contact is working for hallway door to stay open.	8/7/13	Hallway/Corridor	Near gym weightroom	Electrical
Georgian Hills MS (2255) 1B	Outlets aren't working on the wall as you enter the room.	8/8/13	1st Floor	104	Electrical
Georgian Hills MS (2255) 1B	Piece of plugin is stuck in outlet.	8/9/13	Hallway/Corridor	Main hall across for main office	Electrical
Georgian Hills MS (2255) 1B	After replacing bulbs in light fixture and beeping noise continues to come from the fixture.	8/9/13	1st Floor	Outside of guidance office	Electrical
Georgian Hills MS (2255) 1B	Electrical outlets aren't working.	8/12/13	2nd Floor	207	Electrical
Georgian Hills MS (2255) 1B	Light aren't coming on.	8/13/13	2nd Floor	206	Electrical
Georgian Hills MS (2255) 1B	Electrical outlets aren't working.	8/13/13	2nd Floor	206	Electrical

Georgian Hills MS (2255) 1B	Half of lights won't come on.	8/13/13	2nd Floor	204	Electrical
Georgian Hills MS (2255) 1B	Light fixture has a beeping sound coming from it.	8/14/13	Annex	2nd floor near elevator	Electrical
Georgian Hills MS (2255) 1B	Light fixture won't open and water is in fixture from restroom flood	8/16/13	Restroom (Boys)	underneath gym	Electrical
Georgian Hills MS (2255) 1B	Light fixture won't open and water is inside due to flood in girls locker room in gym.	8/16/13	Restroom (Girls)	underneath gym	Electrical
Georgian Hills MS (2255) 1B	Door won't stay open due to contact.	8/16/13	1st Floor	Door leading to gym	Electrical
Georgian Hills MS (2255) 1B	Replace two ballast in hall light fixture across from room 107.	8/19/13	1st Floor	hallway	Electrical
Georgian Hills MS (2255) 1B	Replace the ballasts/bulbs in eight light fixtures the plant manager can't reach.	8/19/13	Gym	lobby	Electrical
Georgian Hills MS (2255) 1B	Set master clock bells to ring at 8 a.m. and 3 p.m. id#114-125	8/19/13	Administration Area	Main office	Electrical

Georgian Hills MS (2255) 1B	Provide light bulbs for kitchen area. These are not stock bulbs. Thank you	6/11/14			Electrical
Georgian Hills MS (2255) 1B	Bulb can't fit because connect in light fixture is broken/cracked.	6/12/14	Kitchen	storage room	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light fixture.	6/24/14	Restroom (Girls)	2nd floor across from main office	Electrical
Georgian Hills MS (2255) 1B	Light fixture will not come on even though bulb and ballast has been replaced. One end off the fixture looks burnt at the end of it.	2/18/14	1st Floor	hallway outside of room 107	Electrical
Georgian Hills MS (2255) 1B	Covers and/or bulbs are needed for five light fixtures. Plnt mgr. doesn't have neither in storage.	2/21/14	Cafeteria	Storage and employee room	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light four fixture.	2/26/14	1st Floor	109	Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light fixture.	3/5/14	Library	2nd floor	Electrical
Georgian Hills MS (2255) 1B	Reset master clock for daylight savings time. i.d. #114-125	3/7/14	Administration Area	Main office	Electrical

Georgian Hills MS (2255) 1B	Plant manager can't change light bulb in the hall outside of restroom inside main office.	3/19/14	Administration Area		Electrical
Georgian Hills MS (2255) 1B	Clock in cafeteria hasn't adjusted to master clock correct time. Clock isn't battery opearted.	3/19/14	Cafeteria		Electrical
Georgian Hills MS (2255) 1B	Replace ballast in light fixture.	4/23/14	Library	2nd floor	Electrical
Georgian Hills MS (2255) 1B	Breaker trips when lights are turned on causing half of lights to stay off.	4/25/14	2nd Floor	202	Electrical
Georgian Hills MS (2255) 1B	A/C KITCHEN AREA-NOT COOLING-PLANT MGR WHITELOW 416-0807 KLR	5/8/14			Electrical
Georgian Hills MS (2255) 1B	Replace the ballast in two light fixtures.	5/27/14	Hallway/Corridor	Lower level beanthe gym	Electrical
Georgian Hills MS (2255) 1B	lights will not come on in room 202 per Mr. Whitelow 416-0807	8/22/13			Electrical
Georgian Hills MS (2255) 1B	Fire alarm was set off this morning due to smoke detector sensing something.	1/31/14	1st Floor	108	Electrical

Georgian Hills MS (2255) 1B	Replace bulbs or ballast in two light fixtures over stairs. Plant mgr. can't reach them.	1/31/14	Hallway/Corridor	stairwell outside of room 207	Electrical
Georgian Hills MS (2255) 1B	Repalce ballast in light fixture.	2/3/14	2nd Floor	boiler room/plant mgr. office	Electrical
Georgian Hills MS (2255) 1B	Two (2) units in Room 208 are NOT COMING ON per Mr. Whitelow, Plant Mgr. 416.0807	1/7/14			Electrical
Georgian Hills MS (2255) 1B	WIRING UNDER GYM AREA- EXPOSED-SBE DOES NOT KNOW IF IT'S LIVE OR NOT- PLANT MGR WHITELOW 416-3740 KLR	1/8/14			Electrical
Georgian Hills MS (2255) 1B	Remove and replace in new ceiling tile a smoke detector. Water damage. Support Jason.	1/14/14	Cafetorium		Electrical
Georgian Hills MS (2255) 1B	Replace the ballast in four light fixtures.	1/22/14	Gym	212	Electrical
Georgian Hills MS (2255) 1B	Repalce the ballast in four light fixtures.	1/27/14	1st Floor	105	Electrical
Georgian Hills MS (2255) 1B	Electrical outlets for students computers aren't working. Breaker boxes were checked and was ok.	1/27/14	1st Floor	105	Electrical

Georgian Hills MS (2255) 1B	Five boxes of bulbs are needed for for facility. 147348 is the box number.	8/22/13	Hallway/Corridor		Electrical
Georgian Hills MS (2255) 1B	Install an electrical outlet. attn:Mr.Wilson	9/17/13	1st Floor	109	Electrical
Georgian Hills MS (2255) 1B	Board to operate score clock for basketball isn't working.	10/2/13	Gym		Electrical
Georgian Hills MS (2255) 1B	Monthly - Oil Lube & Belt- Georgian Hills Middle - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 204 freezing up	9/19/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 216 -- pull unit from wall -- bad cond. motor	9/25/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C RMS 104 & 204-BOTH ARE LEAKING-PLANT MGR WHITELOW 416-3740 KLR	10/1/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C RM 105-NOT COOLING- PLANT MGR WHITELOW 416- 3740 KLR	10/1/13			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	UNIT NOT COOLING IN RM-105 PLANT MGR- WHITELOW/416.3740	8/22/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	(2) A/C UNITS RM 208-BOTH NOT COOLING-PLANT MGR WHITELOW 416-0807 KLR	8/22/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C UNITS IN BANDRM, RMS 105 1ST FLR, RM 112 ANNEX, RM 205 2ND FLR, 215 2ND FLR & LOBBY AREA 2ND FLR-ALL NOT COOLING-PLANT MGR WHITELOW 416-3740 KLR	8/27/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	2-AHU NOT COOLING IN RM- 112,216 PLANT MGR- WHITELOW/416.3740	10/3/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	AHU NOT COOLING IN RM-201 PLANT MGR- WHITELOW/416.3740	10/15/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	c/o to heat	10/17/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	gym not heating	10/25/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	repair coil for rm 204	11/1/13			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	Monthly - Oil Lube & Belt- Georgian Hills Middle - Refer to PM schedule details.	11/10/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	Monthly - Filter-Georgian Hills Middle - Refer to PM schedule details.	11/24/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 204 install coil and low temp detector	12/2/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	HEAT GYM, RMS 106, 111, & 215-ALL NOT HEATING-PLANT MGR WHITELOW 416-3740 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	HEAT RMS 105 & 208-BOTH NOT HEATING-PLANT MGR WHITELOW 416-3740 KLR	12/10/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	HEAT RM 211-NOT HEATING- PLANT MGR WHITELOW 416- 0807 KLR	12/13/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 204 not cooling	8/29/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 105 not cooling	8/30/13			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	rm 204 -- change txv and recharge	9/4/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	AHU NOT COOLING IN RM-215- PLANT MGR- WHITELOW/416.0807	9/4/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C BANDRM-NOT COOLING- PLANT MGR WHITELOW 416-3740 KLR	9/4/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 105 not cooling	9/6/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 204 install comp.	9/6/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C RMS 110, 112, 104, & 215- ALL NOT COOLING-PLANT MGR WHITELOW 416-3740 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	kitchen a/c unit not cooling per Mr. Whitelow 416-0807	9/10/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 204 bad contactor	9/12/13			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	rm 105 not cooling	9/13/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C 114-045 - MAIN ENTRANCE LOBBY - NOT COOLING SBE/WHITELOW 416-0807	7/15/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	5-UV NOT COOLING IN RM-105(057) RM-106(055) RM-107(051) RM-205(027) RM-216(064) . SBE-WHITELOW/416-3740	7/17/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	Monthly - Filter-Georgian Hills Middle - Refer to PM schedule details.	7/28/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	8-UNITS NOT COOLING IN RM-104(076) RM-105(057) RM-108(048,049) RM-103(077) RM-102(078) RM-204(028)RM-205(027) RM-216(064). PLANT MGR-WHITELOW/416-3740	7/29/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C UNIT GYM MEZZANINE RM 212 & A/C UNIT GYM MEZZANINE RM 211-BOTH NOT COOLING-SBE WHITELOW 416-3740 KLR	8/2/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	main ofc leaking	8/6/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C UNIT 2ND FLR RM 210 EAST, 2ND FLR RM 210 WEST & 2ND FLR LOBBY EAST UNIT- ALL NOT COOLING-SBE WHITELOW 416-0837 KLR	8/9/13			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	A/C UNIT GYM BASMENT RM 101, GYM BASEMENT RM 103, GYM BASEMENT RM 104, ANNEX 1ST FLR RM 112, & 1ST FLR RM 105-ALL NOT COOLING-SBE WHITELOW 416-0837 KLR	8/13/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	clean gym unit	8/13/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	2-UNITS NOT COOLING IN RM-205(027) RM-208(021) PLANT MGR-WHITELOW/416.3740	8/13/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	Per Mr. Whitelow 416-0837 the a/c is not cooling in room 207	8/15/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	replace condenser on kitchen	6/30/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	HEAT MAIN OFC & MAIN LOBBY AREA-BOTH NOT HEATING-PLANT MGR WHITELOW 416-0807 KLR	3/6/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	HEAT CAFE AREA-MAKING NOISES-PLANT MGR WHITELOW 416-0807 KLR	3/6/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	west lobby bad sensor	3/7/14			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	check boiler --- power outage	3/11/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	2-UNITS NOT HEATING IN MAIN LOBBY PLANT MGR- WHITELOW/416.3740	3/17/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	Monthly - Filter-Georgian Hills Middle - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	A/C UNITS in the CAFETERIA are NOT COOLING per Mr. Whitelow, Plant Mgr. 416.0807	4/21/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	start gym A/C	4/24/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	UNIT NOT COOLING IN RM-215 PLANT MGR- WHITELOW/416.3740	4/28/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	per mr whitelow 416-0807 rooms 105 and 108 blowing hot	4/29/14			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	A/C RM 204, 207, & 209-ALL NOT COOLING-PLANT MGR WHITELOW 416-0807 KLR	5/8/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	UNIT NOT COOLING IN RM-105,107,111,112,204,214 PLANT MGR-WHITELOW/416.3740	5/13/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	2 units in cafeteria kitchen not cooling per Mr. Whitelow 416-0807	8/22/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	UV NOT COOLING IN RM-207 PLANT MGR-WHITELOW/416.3740	9/17/13			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	(2) AHU'S FRONT LOBBY AREA-BOTH NOT HEATING-PLANT MGR WHITELOW 416-0807 KLR	1/3/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	HEAT RM 102 & 103-BOTH NOT HEATING-PLANT MGR WHITELOW 416-0807 KLR	1/22/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 105 busted coil	1/22/14			Heating/Ventilation /Air Conditioning
Georgian Hills MS (2255) 1B	rm 102 not heating	1/22/14			Heating/Ventilation /Air Conditioning

Georgian Hills MS (2255) 1B	The parking and some no parking lines are very hard to see.	8/21/13	Parking Lot	front/rear	Painting
Georgian Hills MS (2255) 1B	G.O.S., Nutrion Spvr. and Plant mgr. need assigned parking spaces painted.	3/19/14	Parking Lot	front lot	Painting
Georgian Hills MS (2255) 1B	Paint (silver to match frame) expand metal for windows guards. For Danny Walker.	9/20/13	1st Floor		Painting
Georgian Hills MS (2255) 1B	Paint stall door.	8/27/13	Restroom (Boys)		Painting
Georgian Hills MS (2255) 1B	Paint/stain plywood to match exsitnig.	9/4/13			Painting
Georgian Hills MS (2255) 1B	UV IS LEAKING WATER IN MAIN LOBBY PLANT MGR-WHITELOW/416.3740	9/26/13			Plumbing
Georgian Hills MS (2255) 1B	Drain covers for two urinals has been removed and needs replacing.	9/30/13	Restroom (Boys)	2nd floor	Plumbing
Georgian Hills MS (2255) 1B	Commode in first stall is flooding restroom when it's flushed.	8/23/13	Restroom (Boys)	2nd floor	Plumbing

Georgian Hills MS (2255) 1B	SINK B RR 2ND FLR- CONSTANTLY LEAKING-SBE HAS IT CUT OFF, STILL LEAKING, CAN'T CONTAIN- PLANT MGR WHITELOW 416- 3740 KLR	8/27/13			Plumbing
Georgian Hills MS (2255) 1B	Urinal is flooding restroom up when it's flushed.	10/3/13	Restroom (Boys)	2nd floor	Plumbing
Georgian Hills MS (2255) 1B	Handsink is leaking from pipe when it's being used.	10/23/13	Restroom (Boys)	Lower floor of gym	Plumbing
Georgian Hills MS (2255) 1B	Commode in 2nd stall won't stop flushing.	10/23/13	Restroom (Girls)	2nd floor	Plumbing
Georgian Hills MS (2255) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	10/31/13			Plumbing
Georgian Hills MS (2255) 1B	Connect for waterhose continues to leak water and area is becoming saturated with water and posing a hazard. Plant mgr. was unsuccessful trying to shut it off.	11/4/13	Grounds	Front of school	Plumbing
Georgian Hills MS (2255) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13			Plumbing
Georgian Hills MS (2255) 1B	Water is leaking from pipes on commode.	11/15/13	Restroom (Boys)	annex	Plumbing

Georgian Hills MS (2255) 1B	rm 204 install coil	11/19/13			Plumbing
Georgian Hills MS (2255) 1B	Test and report on backflow prevention devices.	12/18/13			Plumbing
Georgian Hills MS (2255) 1B	Commode has been left in closet.	9/10/13	Mechanical Room	beneath gym	Plumbing
Georgian Hills MS (2255) 1B	Urinal won't stop flushing.	9/16/13	Restroom (Boys)	annex	Plumbing
Georgian Hills MS (2255) 1B	Commode in 2nd stall won't stop flushing.	9/17/13	Restroom (Girls)	2nd floor across from room 206	Plumbing
Georgian Hills MS (2255) 1B	A/C - 114-043 - MAIN OFC - ASST PRIN OFC - LEAKING - SBE/WHITELOW 416-0807	7/15/13			Plumbing
Georgian Hills MS (2255) 1B	strong gas smell in kitchen around stove and warmers Mr. Whitelow 416-0807	7/16/13			Plumbing
Georgian Hills MS (2255) 1B	UV IS LEAKING WATER IN RM-203(029) . SBE-WHITELOW/416-3740	7/17/13			Plumbing

Georgian Hills MS (2255) 1B	The drains in the three restrooms doesn't drain well.	7/18/13	Restroom (Boys)	2nd floor	Plumbing
Georgian Hills MS (2255) 1B	The drains in the three girls restroom doesn't drain well.	7/18/13	2nd Floor	Girls restrooms	Plumbing
Georgian Hills MS (2255) 1B	Water leaks from handle on commode when it's flushed.	7/18/13	Administration Area	Main office	Plumbing
Georgian Hills MS (2255) 1B	Water leaks from the handle on commode when it's flushed.	7/30/13	Administration Area	Principal office	Plumbing
Georgian Hills MS (2255) 1B	UNIT IS LEAKING WATER IN PRIN OFFICE(042) . PLANT MGR- WHITELOW/416.3740	8/6/13			Plumbing
Georgian Hills MS (2255) 1B	Shower head leaking water.	8/7/13	Gym	girls locker room	Plumbing
Georgian Hills MS (2255) 1B	Water leaking from the base of commode when it's flushed.	8/7/13	Restroom (Girls)	near bandroom	Plumbing
Georgian Hills MS (2255) 1B	Urinal overflows when it's flushed.	8/7/13	Restroom (Boys)	2nd floor	Plumbing

Georgian Hills MS (2255) 1B	2nd floor leak water all over entire floor not sure where it is coming from per Mr. Whitelow 416-0867	8/13/13			Plumbing
Georgian Hills MS (2255) 1B	install coil in rm 204	8/15/13			Plumbing
Georgian Hills MS (2255) 1B	PIPES ARE LEAKING FROM WALK IN COOLER KITCHEN PLANT MGR- WHITELOW/416.3740	8/21/13			Plumbing
Georgian Hills MS (2255) 1B	Commode will not flush properly.	6/11/14	Kitchen	Cafeterian manager office	Plumbing
Georgian Hills MS (2255) 1B	Toilet seat is damaged and needs replacing.	6/11/14	Kitchen	Cafeteria manager office	Plumbing
Georgian Hills MS (2255) 1B	No water is coming in the garbade disposal when it's being used. i.d. #114-083	6/12/14	Cafeteria	kitchen	Plumbing
Georgian Hills MS (2255) 1B	UNITS ARE LEAKING IN RMS 101 & 102. SBE WHITELOWE 416-0807	6/23/14			Plumbing
Georgian Hills MS (2255) 1B	Have a connect for waterhose installed on or underneath hand sinks so restrooms can be cleaned better. Their are four boys restroom in the facility and a boys locker room.	6/24/14	Restroom (Boys)		Plumbing

Georgian Hills MS (2255) 1B	Have a connect installed on or underneath handsink so waterhose can be used to clean restrooms better. There are six girls restrooms and a locker room.	6/24/14			Plumbing
Georgian Hills MS (2255) 1B	Commode seat is missing in hadicap stall.	6/24/14	Restroom (Boys)	2nd floor across from the main office	Plumbing
Georgian Hills MS (2255) 1B	Air Handler Unit is LEAKING WATER in Room 207 per Mr. Whitelow, Plant Mgr. 416.0807	3/21/14			Plumbing
Georgian Hills MS (2255) 1B	WATER IS RUNNING IN BOILER RM. PLANT MGR- WHITELOW/416.3740	3/28/14			Plumbing
Georgian Hills MS (2255) 1B	UNIT IS LEAKING WATER IN LIBRARY PLANT MGR- WHITELOW/416.3740	6/2/14			Plumbing
Georgian Hills MS (2255) 1B	Water cooler isn't working. id#114081	8/22/13	Cafeteria		Plumbing
Georgian Hills MS (2255) 1B	UV IS LEAKING IN RM-204 PLANT MGR- WHITELOW/416.3740	9/17/13			Plumbing
Georgian Hills MS (2255) 1B	Both commodes are leaking water at the base when it's flushed.	2/13/14	Restroom (Boys)	boys	Plumbing

Georgian Hills MS (2255) 1B	WATER LEAKING IN RM 108- THRU WALL PER SBE-PLANT MGR WHITELOW 416-3740 KLR	1/8/14				Plumbing
Georgian Hills MS (2255) 1B	Repalce hardware on sink with a long neck faucet so staff can clean pots and utensils.	10/23/13	Concession Stand	gym		Plumbing
Georgian Hills MS (2255) 1B	Can hot water be turned on or added for cleaning purposes?	10/23/13	Concession Stand	gym		Plumbing
Georgian Hills MS (2255) 1B	Water leaks onto ceiling when it rains.	10/16/13	2nd Floor	203		Roof
Georgian Hills MS (2255) 1B	Water leaks onto ceiling and floor when it rains.	11/18/13	2nd Floor	203		Roof
Georgian Hills MS (2255) 1B	Water is leaking through roof when it rains.	12/10/13	Kitchen	cafeteria		Roof
Georgian Hills MS (2255) 1B	Water coming through the ceiling when it rains.	12/11/13	2nd Floor	204		Roof
Georgian Hills MS (2255) 1B	Ceiling tiles are stained from water leaking from the roof when it rains.	12/13/13	Hallway/Corri dor	main entrance		Roof

Georgian Hills MS (2255) 1B	Rain is leaking onto the ceiling tile and floor.	3/6/14	Library	2nd floor	Roof
Georgian Hills MS (2255) 1B	Water is leaking onto ceiling tile when it rains.	3/6/14	2nd Floor	Main lobby	Roof
Georgian Hills MS (2255) 1B	Water is leaking onto ceiling tile when it rains.	3/31/14	Library	2nd floor	Roof
Georgian Hills MS (2255) 1B	Water leaks from the ceiling when it rains.	4/17/14	Kitchen	pantry	Roof
Georgian Hills MS (2255) 1B	Water is leaking down vent-a-hood when it rains.	2/4/14	Kitchen	cafeteria	Roof
Georgian Hills MS (2255) 1B	per Mr. whitelow 416-0807 in the annex building girls restroom special ed area the cover over the heater is off and cannot be put back on and needs sheet metal dept so children cannot touch	12/13/13			Sheet Metal
Georgian Hills MS (2255) 1B	patch work on unit in rm 204	9/3/13			Sheet Metal
Georgian Hills MS (2255) 1B	Student locker won't open when using combination.	2/25/14	1st Floor	locker 115	Sheet Metal

Count of Craft	Craft									
	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Location										
Gordon ES (2265) 1B	1	3	37	53	54	4	68	3	1	224
Grand Total	1	3	37	53	54	4	68	3	1	224

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Gordon ES (2265) 1B	there is a 2-ft section of pipe that has no insulation and its sweats on floor in this area, please correct	8/21/13	Hallway/Corridor	accross from cafeteria	Asbestos
Gordon ES (2265) 1B	PLEASE REPAIR OR REPLACE BAD DROP IN THIS CLASSROOM, REQUEST BY COMPUTOR TECHWHO WAS AT SCHOOL TODAY (Request Network Cabling Maintenance Repair).	7/30/13	Classroom	183	Cabling
Gordon ES (2265) 1B	please hook up printer in sbs's office , tech came out 1 1/2 months ago , said cable needed but i didnt have , said he was comming back, i have cable for him to complete	9/18/13	1st Floor	sbe office	Cabling
Gordon ES (2265) 1B	Service call for Accessdnsi to repair fiber optical cable at Gordon . Requested by Lance Burgess and It dept. This service call will be funded by general services per Eddie Miller	4/30/14	Grounds		Cabling
Gordon ES (2265) 1B	please repair gate in both these area's , campus can not be secured	2/6/14	Grounds	behind cafeteria and behind gym	Carpentry
Gordon ES (2265) 1B	PLEASE INSTALL 3- 4 BY 6 DRY ERASER BOARDS IN THIS CLASSROO IN PLACE OF OLD CHALK BOARD., PRINCIPLES REQUEST""	2/14/14	Classroom	ROOM 190	Carpentry
Gordon ES (2265) 1B	REAR GATE BEHIND CAFETERIA IS BENT SO BAD , GATE CANT BE CLOSED, PLEASE REPAIR	2/20/14	Grounds	rear entrance gate	Carpentry

Gordon ES (2265) 1B	stall door is hanging , please repair	2/20/14	Restroom (Girls)	across from library	Carpentry
Gordon ES (2265) 1B	please replace door closure that has fallen off	2/20/14	Cafeteria	serving area	Carpentry
Gordon ES (2265) 1B	white board has come off wall and needs to be secured	4/1/14	Classroom	190	Carpentry
Gordon ES (2265) 1B	please place door sweeps at 3-doors in cafe cooking area, see sbe for locations	12/13/13	Cafeteria	cooking area	Carpentry
Gordon ES (2265) 1B	please repair door lock, this door is very hard to open and lock with key , locks sticks and sometimes its impossible to relock once its unlocked, by boys restroom 5th grade hall	12/17/13	Courtyard	exit door to courtyard	Carpentry
Gordon ES (2265) 1B	Fabricate wall grill	12/17/13			Carpentry
Gordon ES (2265) 1B	PLEASE REPAIR DOOR CLOSURE, WHICH WAS HANGING BY 1- SCREW. CAPENTERS WAS AT SCHOOL AND REPAIRED IT ALREADY	12/17/13	Hallway/Corridor	REAR DOOR BY CAFETERIA	Carpentry
Gordon ES (2265) 1B	ENTRY BACK CAFE DOOR, CANT SECURE PLANT MGR-LONMIRE/416.3212	12/18/13			Carpentry

Gordon ES (2265) 1B	stall door falling off the hinges. 2nd stall on the left hand side as you enter the restroom (girls restroom on kindergarden hallway)	7/18/13	Restroom (Girls)	kindergarten hallway	Carpentry
Gordon ES (2265) 1B	PLEASE INSTALL DOOR SWEEPS ON 2- DOORS FOR SBE OFFICE. MICE ARE ENTERING AND EXITING, PEST CONTROL HAS BEEN NOTIFIED'	7/30/13		sbe office	Carpentry
Gordon ES (2265) 1B	threshold's are needed on 2- doors in cafe and 1- door sweep , please see sbe	7/30/13	Cafeteria	managers office and pantry	Carpentry
Gordon ES (2265) 1B	please open sliding room divider so that 2 room can 1 tried to disconnect this door but it will not open-	7/30/13	Classroom	room 183- music	Carpentry
Gordon ES (2265) 1B	PLEASE REPAIR GATE TO PARKING LOT , THE POLE ON ONE SIDE IS SO BENT YOU CANT OPEN THE SECOND GATE, ONLY 1-CAR AT A TIME CAN ENTER OR EXIT.	7/30/13	Parking Lot	front of school(brevlove)	Carpentry
Gordon ES (2265) 1B	DOOR KNOB IS STRIPED AND NEED TO BE REPLACED WITH NEW KNOB , MANAGER CANT GET IN STORAGE ROOM	7/30/13	Cafeteria	STORAGE ROOM	Carpentry
Gordon ES (2265) 1B	SEVERAL PIECES OF FLOOR TILE IS BROKEN AND NEED TO BE REPLACED	7/30/13	Hallway/Corridor	BEHIND CAFETERIA	Carpentry
Gordon ES (2265) 1B	please replace shelves that were eaten up by termites, this area has been treated by pest control and the pesy tech has requested this	8/1/13	Classroom	rm 186	Carpentry

Gordon ES (2265) 1B	please remove 1-VERY SECURED bookcase from south wall in this music room and secure on north wall in rn 201, SBE WILL MOVE , ONCE TAKEN FROM WALL	8/2/13	Classroom	195	Carpentry
Gordon ES (2265) 1B	HOOKS THAT HOLD FLAG IN PLACE NEED TO BE ADJUSTED , NOT ENOUGH SPACE FOR FLAG. HOOKS ARE TOO CLOSE "	8/7/13	Grounds	flag pole out front	Carpentry
Gordon ES (2265) 1B	please make 4- special cuts of ceiling tile in this classroom- directly next to wall	8/21/13	Classroom	rm 128	Carpentry
Gordon ES (2265) 1B	please replace ceiling tile , badly stained. special cut , around sprinkler	8/27/13	Hallway/Corridor	n front on rm 188	Carpentry
Gordon ES (2265) 1B	PLEASE DISCONCT OR TAKE APART 2- PIECES OF PLAYGROUN EQUIMENT SO THAT GROUND CREW CAN REMOVE, PER CONVERSATION WITH ROBERT REED ON TODAY AT 7:34 AM- SEE SBE FOR LOCATION	8/29/13	Grounds	PLAYGROUN D AREA	Carpentry
Gordon ES (2265) 1B	please replace stall door in this restroom, josh jennings is on site and will take care of it today	9/5/13	Restroom (Girls)	across from library	Carpentry
Gordon ES (2265) 1B	PLEASE REPLACE DOOR CLOSER ON THIS DOOR , HEALTH DEPT REQUEST"	9/12/13	Cafeteria	serving rm door	Carpentry
Gordon ES (2265) 1B	PLEASE INSTALL 2- 4BY 6FT MARKERS BOARD IN THIS CLASSROOM. THIS ROOM WAS VACATED BY GASTALT AND THEY TOOK BOARDS WITH THEM, THERE ARE NO BOARDS IN THIS ROOM AND IT IS IN USE AS A CLASSROOM	9/13/13	Classroom	135	Carpentry

Gordon ES (2265) 1B	please rehang stall door that has fallen off, see sbe for location	10/15/13	Restroom (Girls)	accross from library	Carpentry
Gordon ES (2265) 1B	please repair door, key can not open this door	10/16/13	Classroom	rm 139	Carpentry
Gordon ES (2265) 1B	special cuts need to replace ceiling tile that was damaged in process of repairing leaking pipe, also a piece of grid was torn out and need replaced	10/24/13	Hallway/Corridor	just outside of cafeteria	Carpentry
Gordon ES (2265) 1B	please remove center mull from 2-door so that grounds men can get to this area and remove some playground equipment	11/11/13	Courtyard	rear exit mian door to courtyard	Carpentry
Gordon ES (2265) 1B	please replace floor tile just out of classroom , tile has begun to buckle from a flood in hallway, at least a 6ft by 6ft section	11/15/13	Hallway/Corridor	in front of room 184	Carpentry
Gordon ES (2265) 1B	please replace stall door, was torn off by kids	11/19/13	Restroom (Boys)	5th grade hall	Carpentry
Gordon ES (2265) 1B	2- basketball goals were left at school by robert reed , that need to be assemble and placed in concrete outside in the courtyard	11/20/13	Courtyard	middle of school	Carpentry
Gordon ES (2265) 1B	please replace seving line threshold. was torn loose and prevented serving line door from closing	2/5/14	Cafeteria	#-2-serving line door	Carpentry

Gordon ES (2265) 1B	please install a treshold to keep mice from entering this room	8/16/13	Cafeteria	cafe managers office	Carpentry
Gordon ES (2265) 1B	Please look at caf wall. Look outside and see if the wall on outside needs to be water proofed before we fill in the sink hole.	9/18/13			Carpentry
Gordon ES (2265) 1B	NEW STEAMER in the KITCHEN is SPARKING per per Mr. Longmire, Plant Mgr. 416.2909	2/6/14			Electrical
Gordon ES (2265) 1B	there are 2- outlets located in serving area that need to be covered, wires are exposed"	2/19/14	Cafeteria	serving line area	Electrical
Gordon ES (2265) 1B	please replace bad ballast - stobe light effect	2/19/14	Cafeteria	mian eating area	Electrical
Gordon ES (2265) 1B	please repair exit light, not working	2/20/14	Cafeteria	eating area over s w exit door	Electrical
Gordon ES (2265) 1B	please reset clocks to daylight savings time	2/21/14	Administration Area	set clocks in main office to daylight saving time	Electrical
Gordon ES (2265) 1B	PLEASE REPLACE BAD BALLAST IN THESE CLASSROOMS, 1- RM HAS 4- LIGHTS OUT AND 1-HAS 2LIGHTS OUT , BULBS HAVE BEEN CHANGED	4/21/14	Classroom	107 & 118	Electrical

Gordon ES (2265) 1B	HEAT RM 179-MAKING LOUD NOISES-PLANT MGR LONGMIRE 416-2904 KLR	12/9/13			Electrical
Gordon ES (2265) 1B	FCU NOT COMING ON IN MAIN OFFICE, & BREEZEWAY BY CAFE PLANT MGR-LONGMIRE/283-6544	12/9/13			Electrical
Gordon ES (2265) 1B	HEAT RMS 135 & 136-BOTH NOT HEATING-PLANT MGR LONGMIRE 416-2909 KLR	12/10/13			Electrical
Gordon ES (2265) 1B	PILOTS NEEDS TO BE LIT - EVERYTHING IS OUT IN THE KITC - PM/LONGMEIR 416-2909	12/11/13			Electrical
Gordon ES (2265) 1B	please change ballast ion 3-light poles on front parking lot. very dark	12/13/13	Parking Lot	front of school	Electrical
Gordon ES (2265) 1B	HEAT CAFE AREA-NOT COMING ON-PLANT MGR LONGMIRE 416-2909 KLR	1/6/14			Electrical
Gordon ES (2265) 1B	please replace 3- ballast in this classroom. half of room is without lights	1/13/14	Classroom	174	Electrical
Gordon ES (2265) 1B	please repair light in this store room, bulbs were changed out and light still doesn't come on	1/15/14	Cafeteria	mop room	Electrical

Gordon ES (2265) 1B	please replace bad ballast in this classroom, all 4- bulbs where change out and still no lights	1/22/14	Classroom	188	Electrical
Gordon ES (2265) 1B	please replace ballast in this room, strobe light effect	1/22/14	Administration Area	zstorage room where heating systems are	Electrical
Gordon ES (2265) 1B	please replace ballast in boiler room- at least 3 are out . stobe light effect	1/24/14	Mechanical Room	behind cafe	Electrical
Gordon ES (2265) 1B	HEAT MAIN OFC-NOT COMING ON-PLANT MGR LONGMIRE 416-3212 KLR	1/28/14			Electrical
Gordon ES (2265) 1B	please change out bad ballast, stobe light effects going on!	1/29/14	Administration Area	storage rm in main off	Electrical
Gordon ES (2265) 1B	please repair stage lights, do not come on	1/30/14	Cafetorium	stage	Electrical
Gordon ES (2265) 1B	FIRE ALARM NEEDS TO BE RESET KEEPS GOING OFF. SBE LONGMIRE	7/1/13			Electrical
Gordon ES (2265) 1B	UNIT IN RM 110 IS NOT COMING ON SBE LONGMIERE 416-	7/24/13			Electrical

Gordon ES (2265) 1B	UNIT IN RM 190 IS NOT COMING. SBE LONGMIRE 416-3212	7/24/13			Electrical
Gordon ES (2265) 1B	please replace broken hooks on flag pole out front, so that flag can be raised, just notice this "	7/29/13			Electrical
Gordon ES (2265) 1B	please set bells for this school year	8/1/13	Administration Area	main office	Electrical
Gordon ES (2265) 1B	please replace bad ballast in this classroom. 2- lights are out and bulbs have been changed	8/2/13	Classroom	rm 164	Electrical
Gordon ES (2265) 1B	UV-1 RM 178-NOT COMING ON-SBE LONGMIRE 416-3212 KLR	8/5/13			Electrical
Gordon ES (2265) 1B	UNIT NOT COMING ON IN RM-129(025). PLANT MGR-LONGMIRE/416.3212	8/6/13			Electrical
Gordon ES (2265) 1B	please replace bad ballast in computer rack storage room in this rm, strobe light effect is happening	8/7/13	Classroom	room 183	Electrical
Gordon ES (2265) 1B	work order change to reflect only 3 boxes of bulbs please bring 4- boxes of bulbs for lights through out bldg	8/21/13	Administration Area	through out bldg	Electrical

Gordon ES (2265) 1B	please replace bad ballastn light fixture. bulbs hav already been change out	8/26/13	Hallway/Corridor	in front of library	Electrical
Gordon ES (2265) 1B	please replace bad ballast , 4- lights are out in the same row and bulbs have been changes	8/28/13	Cafeteria	eating area	Electrical
Gordon ES (2265) 1B	UV NOT COMING ON IN RM-131. PLANT MGR- LONGMIRE/416.3212	9/6/13			Electrical
Gordon ES (2265) 1B	A/C RM 131-NOT COMING ON- PLANT MGR LONGMIRE 416-2909 KLR	9/11/13			Electrical
Gordon ES (2265) 1B	please replace bad ballast, all 4- bulbs have been changed	9/18/13	Administration Area	next to exit door	Electrical
Gordon ES (2265) 1B	please replace ballast, there are 8 lights out in this classroom	9/26/13	Classroom	room 191	Electrical
Gordon ES (2265) 1B	please replace ballast, stobe light effect	9/30/13	Hallway/Corridor	in front of music rm , 188	Electrical
Gordon ES (2265) 1B	please replace bad ballast in hall light fixture	9/30/13	Hallway/Corridor	in front of rm 112	Electrical

Gordon ES (2265) 1B	there are 3 security- lights out in front of school, 1-parking lot , and 2- directly in front of main bldg	10/2/13	Grounds	front of school	Electrical
Gordon ES (2265) 1B	please replace two security lights - located beneath the overhang in front of bldg by principle office	10/3/13	Grounds	front of school	Electrical
Gordon ES (2265) 1B	please replace bad ballast in this restroom	10/17/13	Restroom (Boys)	5th grade hall	Electrical
Gordon ES (2265) 1B	there are 3-security lights out and need to be replaced, lights are located over parking lot	10/24/13	Parking Lot	north side of lot	Electrical
Gordon ES (2265) 1B	please repair or replace door bell at rear door, cafe manager request	10/24/13	Cafeteria	rear door	Electrical
Gordon ES (2265) 1B	UV NOT COMING ON IN RM-111(045). PLANT MGR- LONGMIRE/416.3212	8/12/13			Electrical
Gordon ES (2265) 1B	PLEASE REPLACE BAD BALLAST IN LIGHT FIXTURE , BULBS ALREADY BEEN CHANGE	8/14/13	Administration Area	MAIN OFFICE LOBBY AREA	Electrical
Gordon ES (2265) 1B	RTU NOT COMING ON IN LIBRARY(201). PLANT MGR- LONGMIRE/416.3212	8/15/13			Electrical

Gordon ES (2265) 1B	A/C UNIT is NOT COMING ON in CAFETERIA per James Longmire, Plant Mgr. 416.2909	5/20/14			Electrical
Gordon ES (2265) 1B	POWER OUTAGE throughout the ENTIRE BUILDING per Mr. Longmire, Plant Mgr. 416.2909	6/23/14			Electrical
Gordon ES (2265) 1B	FIRE ALARM SYSTEM MAIN OFC. SHOWING TROUBLE-PLANT MGR LONGMIRE 416-2909 KLR	6/24/14			Electrical
Gordon ES (2265) 1B	Need to have an electrician mount/replace Fire alarm Horn/Strobes in the courtyard area. I have the new waterproof Horn/Strobes, I can give them to you or meet you out on site to complete repairs. Will Warren 409-4000	6/25/14			Electrical
Gordon ES (2265) 1B	please replace 5-lights in this lobby area , lights are at least 20ft above ground, see P M for location	8/19/13	Administration Area	lobby just as you enter front door	Electrical
Gordon ES (2265) 1B	Unit Ventilator in serving line in cafeteria won't come on per Mr. Longmeier 416-2909	8/15/13			Electrical
Gordon ES (2265) 1B	2- lights are out in this classroom, bad ballast, bulbs have already been changed	4/28/14	Classroom	rm 190	Electrical
Gordon ES (2265) 1B	Monthly - Filter-Gordon Elementary - Refer to PM schedule details.	5/27/14			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	Monthly - GORDON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	6/22/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	annex boiler down	2/11/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	annex boiler down	2/13/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	annex boiler --- check	2/18/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	MAIN BUILDING BOILER will NOT COME ON per Mr. Longmire, Plant Mgr. 416.2909	2/26/14			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	Monthly - GORDON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	boiler down	3/11/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Yearly - Cooling Towers(STRAINERS)- Gordon Elem - Refer to PM schedule details.	3/15/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Yearly - Rod Chiller - Gordon Elementary - Refer to PM schedule details.	3/15/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	per mr longmeier 416-2909 no heat in kitchen	3/24/14			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Monthly - GORDON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	clean cooling tower	4/4/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	annex chiller check flow	4/21/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	CHILLER MECH RM WEST SIDE OF BLDG-NOT COMING ON-PLANT MGR LONGMIRE 416-3212 KLR	4/22/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	4/27/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Units NOT HEATING in ROOMS 137 & 139 per Mr. Longmire, Plant Mgr. 416.2903	11/25/13			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	RTU - COVERS CAFE - BLOWING BUT HEATING - PM/LONGMEIR 416-2909	12/13/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Unit is NOT COMING ON in the LIBRARY per Mr. Longmire, Plant Mgr. 416.2909.	1/6/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Unit is NOT HEATING in P.E. room per Mr. Longmire, Plant Mgr. 416.2909	1/16/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Monthly - Filter-Gordon Elementary - Refer to PM schedule details.	1/28/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	UNIT IN THE CAFE IS NOT COOLING. SBE JEFFERSON 416-2909	7/17/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Rm 111 no a/c in room per James Longmeier	7/31/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Rooftop unit #024-124 BLOWING WARM AIR. Unit covers eating area in Cafeteria per Mr. Longmire, Plant Mgr. at 901.283.6544	8/20/13			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	Yearly - Oil Samples-Gordon Elem - Refer to PM schedule details.	9/10/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Monthly - Filter-Gordon Elementary - Refer to PM schedule details.	9/24/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	check oil at cooling towers	10/4/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	cooling towers	10/8/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Monthly - Oil Lube & Belt-Gordon Elem - Refer to PM schedule details.	10/29/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	HEAT WEST SIDE OF BLDG-NOT COMING ON-PLANT MGR LONGMIRE 416-3212 KLR	11/4/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	BOILER - COVERS CAFE & WEST SIDE OF BLDG - SHOWING IGNITION FAILUTE - PM/LONGMIER 416-2909	11/12/13			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	BOILERS - NOT COMING ON - PM/LONGMEIR 416-2909	11/25/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	UNIT NOT COOLING IN CAFE. PLANT MGR-LONGMIRE/416.3212	8/12/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	hallway units in north and south halls are blowing hot air #090 and 091, per Mr. Longmeier 416-2909	8/15/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	2/2/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	UNITS in the MAIN BUILDING are NOT HEATING per Mr. Longmire, Plant Mgr. 416.2909	2/4/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	boiler is down per mr longmeier 416-2909	2/5/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Monthly - GORDON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning

Gordon ES (2265) 1B	Daily - Gordon Elem Level 1 Water Treatment - Refer to PM schedule details.	5/25/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	CHILLER - NOT COMING ON - PM/LONGMEIR 416-2909	6/23/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Monthly - Oil Lube & Belt-Gordon Elem - Refer to PM schedule details.	6/3/14			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	boilers down	11/25/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	Rooftop unit #024-124 BLOWING WARM AIR covers eating area in Cafeteria per Mr. Longmire, Plant Mgr. at 901.283.6544	8/20/13			Heating/Ventilation /Air Conditioning
Gordon ES (2265) 1B	PLEASE PAINT 2- REAR OUTSIDE ENTRANCE DOORS TO CAFETERIA, THESE 2- DOORS ARE VERY RUSTY AND VERY UNATTRACTED FROM THE STREET, PLEASE CORRECT	8/12/13	Cafeteria	outside rear doors	Painting
Gordon ES (2265) 1B	please re-stripe front parking lot, principle request"	1/30/14	Parking Lot	parking lot	Painting
Gordon ES (2265) 1B	GRAFFITI ON THE EXT. OF CAFE DOOR. SBE JEFFERSON 416-2914	7/11/13			Painting

Gordon ES (2265) 1B	please paint main office only- this area is the 1st seen by visitors and principle wants it painted	8/21/13	Administration Area	main office-only	Painting
Gordon ES (2265) 1B	please repair leaking sink in classroom	10/30/13	Classroom	116	Plumbing
Gordon ES (2265) 1B	per mr longmeier 416-2909 all the pilots are out in the kitchen	2/7/14			Plumbing
Gordon ES (2265) 1B	per mr longmeier 416-2909 pilots are out (again) in the kitchen	2/10/14			Plumbing
Gordon ES (2265) 1B	Pull in check regulator	2/17/14			Plumbing
Gordon ES (2265) 1B	please un stop drinking water fountain, water do not go down	2/18/14	Hallway/Corridor	just across from sbs's office	Plumbing
Gordon ES (2265) 1B	Rebuild backflow	2/19/14			Plumbing
Gordon ES (2265) 1B	1st toilet as you enter restroom is stopped up. bag is over this commode and needs to be repaired	2/20/14	Restroom (Girls)	5th grade hall	Plumbing

Gordon ES (2265) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing
Gordon ES (2265) 1B	FLR DRAIN IS BACKING UP IN KITCHEN PLANT MGR- LONGMIRE/416.3212	4/8/14			Plumbing
Gordon ES (2265) 1B	please unstop comode in 5th grade restroom	4/9/14	Restroom (Boys)	5th grade hall	Plumbing
Gordon ES (2265) 1B	there are 2- sinks in cafeteria that are leaking , please repair	4/9/14	Cafeteria	sink leaking	Plumbing
Gordon ES (2265) 1B	COMMODES 5TH GR G RR-ALL (6) ARE STOPPED UP-PLANT MGR LONGMIRE 416-2909 KLR	4/16/14			Plumbing
Gordon ES (2265) 1B	COUPLING ON BLEED VALVE IS LEAKING.SEE MIKE SIMMONS FOR LOCATION.	4/16/14			Plumbing
Gordon ES (2265) 1B	Lighting of pilots on all OVENS per Mr. Longmire, Plant Mgr. 416.2909	12/3/13			Plumbing
Gordon ES (2265) 1B	please un stop 1st commode as you enter restroom, tried unstopping but did not work	12/4/13	Restroom (Boys)	5th grade hall	Plumbing

Gordon ES (2265) 1B	In the kitchen/cafeteria all of the pilot lights are out and need to be lit per Mr. Longmeir 416-2909	12/12/13			Plumbing
Gordon ES (2265) 1B	RETURN PIPE TO BOILER IS RUNNING WATER IN BOILER RM PLANT MGR- LONGMIRE/283.6544	12/18/13			Plumbing
Gordon ES (2265) 1B	Test and report on backflow prevention devices.	12/19/13			Plumbing
Gordon ES (2265) 1B	LIGHT ALL PILOTS & OVENS ARE OUT - PM/LONGMEIR 416-2909	1/8/14			Plumbing
Gordon ES (2265) 1B	please repair leak under sink in this class room-science lab	1/13/14	Classroom	rm 187	Plumbing
Gordon ES (2265) 1B	mop sink stopped up	1/14/14	Custodial Closet	by sbe office	Plumbing
Gordon ES (2265) 1B	per Mr. Longmeier 416-2909 in the cafeteria all the pilots are out	1/16/14			Plumbing
Gordon ES (2265) 1B	Test and report on backflow prevention devices.	1/21/14			Plumbing

Gordon ES (2265) 1B	in kitchen all pilots are out per Mr. Longmeier 416-2909	1/22/14			Plumbing
Gordon ES (2265) 1B	GAS SMELL in the MAIN OFFICE per Mr. Longmire, Plant Mgr. 416.2909	1/27/14			Plumbing
Gordon ES (2265) 1B	Unit Ventilator leaking in Classroom #133 per Mr. Jefferson, Sub Plant Mgr. at 901.416.2914!	7/12/13			Plumbing
Gordon ES (2265) 1B	UNIT IN RM 174 IS LEAKING. SBE JEFFERSON 416-2909	7/18/13			Plumbing
Gordon ES (2265) 1B	UNT IIN RM E 207 IS LEAKING SBE LONGMIERE 416-	7/24/13			Plumbing
Gordon ES (2265) 1B	no 3 urinal as you enter restroom , has come loose from top, everytime its flushed , water squirts out from top , please repair	7/29/13	Restroom (Boys)	across from class room 141	Plumbing
Gordon ES (2265) 1B	please repair pipe leak in ceiling in this classroom, barrels are under leak	8/1/13	Classroom	rm 111	Plumbing
Gordon ES (2265) 1B	PLEASE REPAIR LEAK COMMING FROM PIPE IN CEILING, AVAC TECH WAS HERE AND SAID THIS WAS A PLAUMMING ISSUE	8/12/13	Classroom	RM 111	Plumbing

Gordon ES (2265) 1B	Check chemical feed system for A/C system. The #2 Sensor Loop supply is plugged up.	8/29/13			Plumbing
Gordon ES (2265) 1B	UV RM 135-DRAIN STOPPED UP & WATER LEAKING OUT-PLANT MGR LONGMIRE 416-3212 KLR	8/29/13			Plumbing
Gordon ES (2265) 1B	after several plunges and several times water has spilled over on floor, this comode needs to snaked out , please unstop comode	9/9/13	Restroom (Girls)	elementary hall	Plumbing
Gordon ES (2265) 1B	PLEASE REPAIR FLUSH VALVE ON COMMODE IN TEACHERS LOUNGE, ACCROSS FROM MAIN OFFICE	9/11/13	Administration Area	TEACHERS LOUNGE RESTROOM	Plumbing
Gordon ES (2265) 1B	PLEASE UNSTOP UNRINAL IN THIS RESTROOM3- FROM RIGHT	9/11/13	Restroom (Boys)	5TH GRADE HALL	Plumbing
Gordon ES (2265) 1B	Unit Ventilator is LEAKING in RM 172 per Mr. Longmire, Plant Mgr. 416.2909	9/12/13			Plumbing
Gordon ES (2265) 1B	floor drain cover needed for drain in cooking area. cover thats there is way too small and workers keep tripping over it . because it doesnt fit properly in this drain	9/12/13	Cafeteria	cooking area	Plumbing
Gordon ES (2265) 1B	PLEASE UNSTOP COMODE, TRIED PLUNGING BUT IT STILL RUNS OVER , KINDEGARDEN RESTROOM	9/24/13	Restroom (Girls)	ACROSS FROM LIBRARY	Plumbing

Gordon ES (2265) 1B	PLEASE REPLACE BROKEN SEAT IN 3RD STALL	9/24/13	Restroom (Girls)	BY CAFETERIA	Plumbing
Gordon ES (2265) 1B	please replace stall door that was torn down by kids	9/25/13	Restroom (Girls)	across from library	Plumbing
Gordon ES (2265) 1B	A/C RMS 179 & 188-BOTH ARE LEAKING-PLANT MGR LONGMIRE 416-3212 KLR	9/26/13			Plumbing
Gordon ES (2265) 1B	please unstop mop sink	9/27/13	Custodial Closet	by room 180	Plumbing
Gordon ES (2265) 1B	comode and urinal stopped up	10/1/13	Restroom (Boys)	kindergarden hall	Plumbing
Gordon ES (2265) 1B	water fountain leaking from inside , please repair	10/1/13	Hallway/Corridor	infront of cafeteria	Plumbing
Gordon ES (2265) 1B	UV IS LEAKING WATER IN GUIDANCE OFFICE. PLANT MGR- LONGMIRE/416.3212	10/3/13			Plumbing
Gordon ES (2265) 1B	REP WATER LINE LEAK MAIN HALL EAST OF SBE'S OFC- REQUESTED BY D HURDLE KLR	10/7/13			Plumbing

Gordon ES (2265) 1B	please repair leak on 2- sinks in this restroom	10/7/13	Restroom (Boys)	across from sbe office	Plumbing
Gordon ES (2265) 1B	2- sinks in boys restroom are running and cant be turned off	10/7/13	Restroom (Girls)	across from sbe office	Plumbing
Gordon ES (2265) 1B	Assist zone with water main repair	10/14/13			Plumbing
Gordon ES (2265) 1B	please un-stop toilet, tried to snake it but could not get it	10/15/13	Restroom (Girls)	6 stall from entry	Plumbing
Gordon ES (2265) 1B	please replace on and off handle on water fountain	10/17/13	Auxiliary Gym	next to cafeteria	Plumbing
Gordon ES (2265) 1B	comode keeps stopping up- plumbers said on last visit, they may have to pull toilet, this comode keeps stopping up	10/30/13	Restroom (Girls)	across from library	Plumbing
Gordon ES (2265) 1B	2nd commode as you enter restroom is stopped up. tried plunging , no good	11/4/13	Restroom (Boys)	5th grade hall	Plumbing
Gordon ES (2265) 1B	OVENS KITCHEN AREA-NEED PILOT LIT-PLANT MGR LONGMIRE 416-2909 KLR	11/6/13			Plumbing

Gordon ES (2265) 1B	please repair leak under sink in this lab	11/6/13	Classroom	room 187	Plumbing
Gordon ES (2265) 1B	DRAIN PAN IS LEAKING IN RM-178. PLANT MGR- LONGMIRE/416.3212	8/12/13			Plumbing
Gordon ES (2265) 1B	per longmeier 416-2909 all of the pilots are out on the equipment in the kitchen	1/31/14			Plumbing
Gordon ES (2265) 1B	Hot water valve is leaking in this bioler room	2/5/14	Mechanical Room	in main bldg	Plumbing
Gordon ES (2265) 1B	ALL OVENS KITCHEN AREA- PILOTS HAVE GONE OUT-WILL NEED-PLANT MGR LONGMIRE 416-3212 KLR	2/6/14			Plumbing
Gordon ES (2265) 1B	please repair water leak under sink	4/29/14	Cafeteria	cooking area	Plumbing
Gordon ES (2265) 1B	please repair leaking sink	5/6/14	Classroom	rm 179	Plumbing
Gordon ES (2265) 1B	please unstop comode- 3rd from entrance door, very slow going down	5/6/14	Restroom (Boys)	5th grade hall	Plumbing

Gordon ES (2265) 1B	flush valve leaking please repair	5/6/14	Restroom (Girls)	kindergarden hall	Plumbing
Gordon ES (2265) 1B	UNIT IS LEAKING WATER IN RM-179 PLANT MGR- LONGMIRE/416.3212	5/8/14			Plumbing
Gordon ES (2265) 1B	please unstop toliet	5/22/14	Restroom (Boys)	5th grade hall	Plumbing
Gordon ES (2265) 1B	disposal backing up, please correct	5/22/14	Cafeteria	cooking area	Plumbing
Gordon ES (2265) 1B	please repair wataer fountain leak, leaking from underneath	5/22/14	Hallway/Corridor	across from plant managers off	Plumbing
Gordon ES (2265) 1B	PLEASE REPAIR ROOF LEAK IN THIS ROOM	7/23/13	Auxiliary Gym	PLAY ROOM	Roof
Gordon ES (2265) 1B	please repair roof drain leak, this rm has bin leaking ferom roof drain for 2-weeks , please correct	8/20/13	Classroom	rm 111	Roof
Gordon ES (2265) 1B	please repair roof leak in the multipurpose room next to caferteria	10/17/13	Gym	next to caferteria	Roof

Gordon ES (2265) 1B	need a vent installed to keep rodents from going under bldg. this area is missing a vent, see sbe for locations	12/11/13	Grounds	directly behind cafe	Sheet Metal
---------------------	---	----------	---------	----------------------	-------------

Count of Craft	Craft								
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Grandview Heights MS (2835) 1B	3	44	56	76	6	50	24	8	267
Grand Total	3	44	56	76	6	50	24	8	267

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Grandview Heights MS (2835) 1B	cable wire need checking internet not working	9/23/13	Gym	coach office	Cabling
Grandview Heights MS (2835) 1B	The outer office area needs a phone line. The guidance counselor is moving to this space from a classroom and needs a phone line. The outer office area need a computer drop for the same reason listed above	6/19/14	Classroom	security/guidance office Room 19	Cabling
Grandview Heights MS (2835) 1B	This area will be the guidance counselor's office and she needs a computer "drop".	6/19/14	Classroom	guidance/security suite Room 19	Cabling
Grandview Heights MS (2835) 1B	need cork board install on the wall in the gym	9/23/13	Gym		Carpentry
Grandview Heights MS (2835) 1B	need cork board install in the classroom	9/24/13	1st Floor	12	Carpentry
Grandview Heights MS (2835) 1B	tile crossing and ceiling tile hanging from the ceiling...	8/9/13	1st Floor	main hall	Carpentry
Grandview Heights MS (2835) 1B	need 10 toilet paper holder student are throwing rolls of the paper in the toilet	8/12/13	Restroom (Boys)	1st and 2nd floor	Carpentry

Grandview Heights MS (2835) 1B	DIFIBRILIATOR NEED TO BE MOUNT ON THE WALL	8/13/13	Gym	EAST END	Carpentry
Grandview Heights MS (2835) 1B	need ceiling tile replacement cut to shape classroom 205-206-211-215 west end hallway pupil services room	8/13/13	1st Floor	through-out	Carpentry
Grandview Heights MS (2835) 1B	Replace 2x4 ceiling tile in main hall.	8/29/13	Hallway/Corri dor		Carpentry
Grandview Heights MS (2835) 1B	Replace damaged 2x4 layin ceiling tile rm B9.	8/29/13			Carpentry
Grandview Heights MS (2835) 1B	Replace damaged ceiling tile in pupil servies.	8/29/13			Carpentry
Grandview Heights MS (2835) 1B	need lack replacement on a two door wood cabinet build in classroom hall	8/30/13	1st Floor	104 annex	Carpentry
Grandview Heights MS (2835) 1B	Flag line is stuck at top of pole. Will not come down	7/17/13	Grounds	front yard	Carpentry
Grandview Heights MS (2835) 1B	window broken need replacement	7/25/13	1st Floor	4	Carpentry

Grandview Heights MS (2835) 1B	rm 7 weld motor bracket	7/29/13				Carpentry
Grandview Heights MS (2835) 1B	need handler and latch replacement on the build in wooden cabinet ...	7/31/13	1st Floor	101		Carpentry
Grandview Heights MS (2835) 1B	can't get the flag off the cord jam flag mid-way on the pole...	8/8/13	Grounds			Carpentry
Grandview Heights MS (2835) 1B	need ceiling tile replacement cut to shape	10/16/13	Administration Area	main office		Carpentry
Grandview Heights MS (2835) 1B	need elbow replacement on the exterior door west end	10/17/13	1st Floor	annex building		Carpentry
Grandview Heights MS (2835) 1B	need stall door install	10/29/13	Gym	boys locker room		Carpentry
Grandview Heights MS (2835) 1B	fire door magnetic arm need replacement has falling off door willn't stay open	2/5/14	2nd Floor	annex hallway door		Carpentry
Grandview Heights MS (2835) 1B	Remove/Repair sheetrock ceiling because of pipe leak, 1st floor. support joe conry.	2/12/14	Annex			Carpentry

Grandview Heights MS (2835) 1B	need screws replacement in the exterior door center mud prevent break-in	1/17/14	Gym	north end	Carpentry
Grandview Heights MS (2835) 1B	stall door down need repair	1/21/14	Restroom (Boys)	8th grade hallway	Carpentry
Grandview Heights MS (2835) 1B	stall door down need repair	1/21/14	Restroom (Girls)	sped hallway	Carpentry
Grandview Heights MS (2835) 1B	T-crossing need replacement tile hanging from the ceiling	1/22/14	1st Floor	15	Carpentry
Grandview Heights MS (2835) 1B	need cold base replacement around the bottom wall	6/13/14	1st Floor	Teacher lounge	Carpentry
Grandview Heights MS (2835) 1B	fire door magnetic arm need replacement falling off the door someone put completed it is not completed	3/17/14	2nd Floor	annex hallway door	Carpentry
Grandview Heights MS (2835) 1B	cabling request is for Grandview height middle not L.Campbell cabling on the ground the entire school year urgent	3/21/14	1st Floor	plant manager office	Carpentry
Grandview Heights MS (2835) 1B	need window pane replacement broken in the classroom number 2	4/1/14	1st Floor	2	Carpentry

Grandview Heights MS (2835) 1B	need stall door replacement	4/1/14	Restroom (Boys)	1st floor	Carpentry
Grandview Heights MS (2835) 1B	need stall door replacement	4/1/14	2nd Floor	sped hallway	Carpentry
Grandview Heights MS (2835) 1B	stall door need repair	4/9/14	Restroom (Boys)	2nd floor	Carpentry
Grandview Heights MS (2835) 1B	need stall door repair	4/9/14	Restroom (Boys)	1st floor	Carpentry
Grandview Heights MS (2835) 1B	window need replacement bullet holes in the glass	4/14/14	2nd Floor	203	Carpentry
Grandview Heights MS (2835) 1B	screw coming out of the bar need replacement for security	4/24/14	Gym	north exit back door	Carpentry
Grandview Heights MS (2835) 1B	need ceiling tile replacement cut to shape 206,215	4/28/14	2nd Floor	Annex	Carpentry
Grandview Heights MS (2835) 1B	need ceiling tile replacement cut to shape	4/28/14	1st Floor	library	Carpentry

Grandview Heights MS (2835) 1B	front entry door won't open. PLANT MGR-DAWSON/416.3940	5/22/14			Carpentry
Grandview Heights MS (2835) 1B	REPAIR OUTSIDE DOOR	6/5/14			Carpentry
Grandview Heights MS (2835) 1B	ceiling missing tile	6/10/14	1st Floor	9	Carpentry
Grandview Heights MS (2835) 1B	need master lock for the toilet paper holder 10 each	9/4/13	Restroom (Girls)	1st floor annex	Carpentry
Grandview Heights MS (2835) 1B	need toilet paper holders in the boys restroom	8/9/13	Restroom (Boys)	2nd floor	Carpentry
Grandview Heights MS (2835) 1B	need toilet holders replacement in the girls restroom	8/9/13	Restroom (Girls)	2nd floor	Carpentry
Grandview Heights MS (2835) 1B	new installment need a flag pole on the gym wall	10/31/13	Gym	front	Carpentry
Grandview Heights MS (2835) 1B	new request need a cork board placement on the wall	1/24/14	1st Floor	north end hallway	Carpentry

Grandview Heights MS (2835) 1B	light poles are not coming on to dark out back	11/27/13	Grounds	on the west end	Electrical
Grandview Heights MS (2835) 1B	following rooms are blowing cold air 201, 204, 111, 18 per ms dawson 416-3940 also main office blowing cold	1/7/14			Electrical
Grandview Heights MS (2835) 1B	school building to dark lights need to be reset	9/12/13	Grounds	exterior	Electrical
Grandview Heights MS (2835) 1B	principal request bell time change on the clock urgent	9/23/13	Administration Area	main office	Electrical
Grandview Heights MS (2835) 1B	master clock need resetting student need to here the bell to pass class urgent	10/2/13	Administration Area	office	Electrical
Grandview Heights MS (2835) 1B	UV NOT COMING ON IN RM-9(124). PLANT MGR-DAWSON/416.3940	8/9/13			Electrical
Grandview Heights MS (2835) 1B	Replace bulbs in main hall. SBE will install the rest. Provide approx. 100 tubes # 72866.	8/27/13	Hallway/Corridor		Electrical
Grandview Heights MS (2835) 1B	FIRE ALARM SYSTEM- CONSTANTLY GOING OFF-PLANT MGR DAWSON 416-3940 KLR	8/29/13			Electrical

Grandview Heights MS (2835) 1B	VENT-A-HOOD KITCHEN-MAKING LOUD NOISES WHEN TURNED ON- PLANT MGR DAWSON 416-3940 KLR	9/3/13			Electrical
Grandview Heights MS (2835) 1B	water cooler will not work 026-202	7/15/13	Cafeteria	dinning area	Electrical
Grandview Heights MS (2835) 1B	Need to get master clock reset	7/19/13	1st Floor	main office	Electrical
Grandview Heights MS (2835) 1B	Trouble light on the fire alarm panal wont reset	7/19/13	1st Floor	main office	Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixture	7/29/13	1st Floor	teacher lounge	Electrical
Grandview Heights MS (2835) 1B	need clock bell change	7/30/13	1st Floor	main office	Electrical
Grandview Heights MS (2835) 1B	AHU #1 not coming on	7/31/13			Electrical
Grandview Heights MS (2835) 1B	need 108 lamps flr.rapid start	8/1/13	1st Floor	s.b.e. office	Electrical

Grandview Heights MS (2835) 1B	UNITS ARE NOT COMING ON RM 174,188. SBE DAWSON 416-3940	8/5/13			Electrical
Grandview Heights MS (2835) 1B	need clocks replacement through-out the building	8/7/13	1st Floor	hallway	Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixture front entrance	8/7/13	1st Floor	hallway	Electrical
Grandview Heights MS (2835) 1B	cable cord and pole lying on the ground stunents playing the the cord danger need repairing.	8/8/13	Grounds	front of the school building	Electrical
Grandview Heights MS (2835) 1B	in the wiring closet a cable box alarm is going off and is very loud per Ms. Dawson 416-3940	10/14/13			Electrical
Grandview Heights MS (2835) 1B	INTERCOM SYS IS MAKING NOISE PLANT MGR-DAWSON/416.3940	10/16/13			Electrical
Grandview Heights MS (2835) 1B	light need replacement to dark in front of the gym basketball season have started urgent also on the side of the school building.parking lot lights	10/29/13	Gym	outside	Electrical
Grandview Heights MS (2835) 1B	ball on top of the light fixture need a lift to remove	10/29/13	Gym	front	Electrical

Grandview Heights MS (2835) 1B	Unit Ventilators are NOT COMING ON in classrooms 10 & 101 per Gale, Plant Mgr. 416.3940	10/31/13			Electrical
Grandview Heights MS (2835) 1B	outlet are not working	11/1/13	Library	2nd floor annex	Electrical
Grandview Heights MS (2835) 1B	bell need resetting on the master clock	11/12/13	Administration Area	main office	Electrical
Grandview Heights MS (2835) 1B	outlet not working urgent this outlet is use for the cash resigster	11/13/13	Cafeteria	serving area	Electrical
Grandview Heights MS (2835) 1B	HEAT PRIN'S OFC-NOT COMING ON- PLANT MGR 416-3940 KLR	11/25/13			Electrical
Grandview Heights MS (2835) 1B	Need new ballast front entrance.	1/31/14			Electrical
Grandview Heights MS (2835) 1B	HEAT RM 15A-NOT COMING ON- PLANT MGR DAWSON 416-3940 KLR	2/14/14			Electrical
Grandview Heights MS (2835) 1B	master clock need setting for day light saving time	2/25/14	Administration Area	Main office	Electrical

Grandview Heights MS (2835) 1B	following rooms are not coming on 17, 8A, 101, 6 per Ms. Dawson 416-3940	1/7/14				Electrical
Grandview Heights MS (2835) 1B	UV NOT COMING ON IN RM-2 PLANT MGR-DAWSON/416.3940	1/22/14				Electrical
Grandview Heights MS (2835) 1B	per Ms. Dawson 416-3940 the lights in the gym cannot be turned OFF and there is a tournament Saturday and need to be able to turn on and off for homecoming court	1/23/14				Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixture	12/10/13	1st Floor	front of the office		Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixture	12/10/13	1st Floor	sped hallway		Electrical
Grandview Heights MS (2835) 1B	HEAT RM 6-NOT COMING ON- PLANT MGR DAWSON 416-3940 KLR	1/6/14				Electrical
Grandview Heights MS (2835) 1B	too dark on the eastside of the building light pole need replacement	6/13/14	Parking Lot			Electrical
Grandview Heights MS (2835) 1B	BURNING SMELL IN MAIN LOBBY BY OFFICE. PLANT MGR-DAWSON/416.3940	9/4/13				Electrical

Grandview Heights MS (2835) 1B	A/C RM 104-NOT COMING ON- PLANT MGR DAWSON 416-3940 KLR	9/10/13				Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixtures	4/11/14	1st Floor	8A		Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixtures	4/11/14	1st Floor	8B		Electrical
Grandview Heights MS (2835) 1B	UV RM 104-MOTOR GONE OUT, NOT COMING ON-PLANT MGR DAWSON 416-3940 KLR	4/14/14				Electrical
Grandview Heights MS (2835) 1B	Repair/adjust door magnet.	4/24/14				Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixture	5/7/14	Administration Area	office		Electrical
Grandview Heights MS (2835) 1B	Front entrance elec. swipe not working check power to strike.	5/22/14	Administration Area			Electrical
Grandview Heights MS (2835) 1B	timer need resetting on the lights talk through with plant manager	6/2/14	Gym	entire gym		Electrical

Grandview Heights MS (2835) 1B	too dark on the back side of the building	6/3/14	Parking Lot	side of the building	Electrical
Grandview Heights MS (2835) 1B	Reset gym lights timer. They are on past 5:00.	6/9/14	Auxiliary Gym		Electrical
Grandview Heights MS (2835) 1B	outlet hanging from wall	6/10/14	1st Floor	15	Electrical
Grandview Heights MS (2835) 1B	outlet hanging from the wall	6/10/14	1st Floor	7	Electrical
Grandview Heights MS (2835) 1B	classroom leaking from the ceiling	6/10/14	1st Floor	8B	Electrical
Grandview Heights MS (2835) 1B	outlet hanging from the ceiling	6/10/14	1st Floor	8B	Electrical
Grandview Heights MS (2835) 1B	light poles are not coming on to dark out back	8/27/13	Grounds	on the west end	Electrical
Grandview Heights MS (2835) 1B	need ballast replacement in the light fixture to dark	10/2/13	Cafeteria	dining area	Electrical

Grandview Heights MS (2835) 1B	Monthly - Oil Lube & Belts - Grandview Heights EI - Refer to PM schedule details.	6/14/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	repair four A/C systems for office area.	9/11/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Purchase unit for princ. Office	9/11/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	a/c #3 not cooling	9/16/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	CLEAN ALL AHU'S PER SBE MIKE SIMMONS SAID IT'S OK-PLANT MGR DAWSON 416-3940 KLR	9/18/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	A/C #3 not cooling	9/26/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	purchase drain pan	9/30/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	AIR COOLED CHILLER-NOT COMING ON-SBE DAWSON 416- 3940 KLR	8/13/13			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	filters need changing in the gym electric thermometer	8/13/13	Gym	east end	Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	3-uv not cooling in cafe PLANT MGR-DAWSON/416.3940	8/29/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	CHILLER NOT COOLING-AFFECTS ENTIRE BLDG-PLANT MGR DAWSON 416-3940 KLR	9/3/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	A/C NOT COOLING ENTIRE ANNEX BLDG-PLANT MGR DAWSON 416- 3940 KLR	9/4/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	clean chiller	7/10/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	chiller down	7/18/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	CHILLER NOT COMING ON (067). SBE-PATTERSON/416-3940	7/22/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	CHILLER NOT COOLING (067). SBE-DOTSON/416-3940	7/23/13			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	Rms 9, 5, 8A, 8B, 7, 4, 1 a/c not working per Gail Dawson 416-3940	7/24/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Chiller NOT COMING ON, ID# 024-067 per Gail Dotson, Plant Mgr. 901.416.3940.	7/30/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	AIR COOLED CHILLER-NOT COMING ON-AFFECTS ENTIRE BLDG-SBE DAWSON 416-3940 KLR	8/8/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	A/C IN ANNEX BLDG NOT COOLING & UV-9 ANNEX 2ND FLR RM 223 (SBE'S OFC)-NOT COOLING-SBE DAWSON 416-3940 KLR	8/8/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	A/C RM 1-MAKING NOISES-PLANT MGR DAWSON 416-3940 KLR	10/15/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	PIPE IS LEAKING WATER IN BOILER RM 1ST FLR PLANT MGR-DAWSON/416.3940	10/18/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	BOILER NOT COMING ON. PLANT MGR-DAWSON/416.3940	10/25/13			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	Monthly - Filters - Grandview Heights Elem - Refer to PM schedule details.	11/1/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	temperature pull away from the wall hanging	11/7/13	Restroom (Boys)	sped hallway	Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rooms 2 and 3 blowing cold air per Ms. Dawson 416-3940	11/14/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	HEAT RM 18-NOT HEATING-PLANT MGR DAWSON 416-3940 KLR	11/14/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Monthly - Oil Lube & Belts - Grandview Heights EI - Refer to PM schedule details.	11/16/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	RTU NOT HEATING IN MAIN OFFICE PLANT MGR-DAWSON/416.3940	11/25/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Unit NOT HEATING in ROOM 3 per Gale Dawson, Plant Mgr. 416.3940	11/26/13			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler in alarm	1/27/14			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	HEAT RM 16, 9, & 202-ALL NOT HEATING-PLANT MGR DAWSON 416.3940 KLR	1/27/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rm 102 not heating	1/27/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rm 202 not heating	1/27/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rm 16 not heating	1/28/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rm 9 not heating	1/28/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	UNITS NOT HEATING IN GYM, G/RR-B/RR STEAD HALL, MAIN HALL, CAFE, ANNEX HALL PLANT MGR-DAWSON/416.3940	1/29/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	hall units not heating	1/29/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	restrooms not heating	1/29/14			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	cafe not heating	1/29/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	2/3/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	2/4/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	per Ms. Dawson 416-3940 the boiler is down	2/4/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rm 14 not heating	2/4/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	rm 19 not heating	2/4/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	per ms dawson 416-3940 the boiler is down	2/5/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	2/6/14			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	per ms dawson 416-3940 rooms 202 and 14 are blowing cold air	2/7/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	2/10/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	per ms dawson 416-9430 the boiler is down	2/10/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	classroom 113. Has a bad fan motor. Per Siemens	2/10/14	1st Floor	rm 113	Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	per ms dawson 416-3940 the boiler is down	2/12/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	2/26/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	2/27/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Monthly - Filters - Grandview Heights Elem - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	boiler down	3/6/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	check bldg after power outage	3/11/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	per ms dawson 416-3940 room 202 is blowing cold air	1/9/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	HEAT MAIN OFC AREA-NOT HEATING-PLANT MGR DAWSON 416.3940 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	UNIT NOT HEATING IN RM-102, GYM, g/RR-B/RR BY SPECIAL NEED HALL, HALL ANNEX. PLANT MGR-DAWSON/416.3940	1/24/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	BOILER is in ALARM per Ms. Dawson, Plant Mgr. 416.3940	1/6/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	HEATING UNIT MAIN HALL-NOT HEATING-PLANT MGR DAWSON 416.3940 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	check bldg for not cooling	9/6/13			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	unit ventilator need cleaning out to much trash in them in the hallways and cafeteria for hvac	9/6/13	Hallway/Corridor	through-out the building	Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	boiler down	3/26/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	per ms dawson 416-3940 in boiler room the there is valve leaking on boiler	4/3/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	A/C UNIT is NOT COOLING in the PRINCIPAL'S OFFICE per Gale Dawson, Plant Mgr. 416.3940	5/6/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	ofc not cooling	5/22/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	install coil in main ofc	5/28/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	check main ofc	5/28/14			Heating/Ventilation /Air Conditioning

Grandview Heights MS (2835) 1B	UNIT NOT COMING ON IN MAIN OFFICE. PLANT MGR-DAWSON/416.3940	5/30/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Princ. ofc not cooling	6/4/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	CHILLER is NOT COMING ON per Ms. Dawson, Plant Mgr. 416.3940	6/19/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	Yearly - Boiler - Grandview Heights Elem - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Grandview Heights MS (2835) 1B	I would like to have the ADMIN/SECRETARY sections of the parking lot changed to "VISITOR" and handicapped parking spaces. Please also remove the "no parking" signs attached to the school building above these areas.	6/12/14	Parking Lot	Grounds	Painting
Grandview Heights MS (2835) 1B	GANG GRAFFITI OUTSIDE ON REAR OF BLDG ON BRICK WALL- PLANT MGR DAWSON 416-3940 KLR	10/15/13			Painting
Grandview Heights MS (2835) 1B	graffiti on east end of building (outside) per Gail 416-2930	10/18/13			Painting
Grandview Heights MS (2835) 1B	GRAFFITI ON FRONT MAILBOX PLANT MGR-DAWSON/416.1000	1/10/14			Painting

Grandview Heights MS (2835) 1B	classroom doors need painting	12/13/13	1st Floor	main hallway	Painting
Grandview Heights MS (2835) 1B	gang writting on the fire door need painting	4/1/14	2nd Floor	annex	Painting
Grandview Heights MS (2835) 1B	A/C RM 104-LEAKING-PLANT MGR DAWSON 416-3940 KLR	9/18/13			Plumbing
Grandview Heights MS (2835) 1B	three cpmpartment sink leaking	9/18/13	Cafeteria	kitchen	Plumbing
Grandview Heights MS (2835) 1B	Test and report on backflow prevention devices.	9/25/13			Plumbing
Grandview Heights MS (2835) 1B	need water turn on in the sciecne lab sink	9/27/13	1st Floor	8B	Plumbing
Grandview Heights MS (2835) 1B	UV IS LEAKING WATER IN CAFE(096). PLANT MGR-DAWSON/416.3940	8/9/13			Plumbing
Grandview Heights MS (2835) 1B	per ms dawson 416-3940 unit ventilator leaking rm 8A 026123 and teachers lounge 026090	8/13/13			Plumbing

Grandview Heights MS (2835) 1B	2 3-compartment sinks are stopped up per Gale Dawson 416-3940	8/26/13			Plumbing
Grandview Heights MS (2835) 1B	In the boiler room the sprinkler pipe is leaking water and filling up room per Gale Dawson 416-3940	8/28/13			Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	8/29/13	2nd Floor	boys restroom	Plumbing
Grandview Heights MS (2835) 1B	need flush vale replacement	8/29/13	1st Floor	annex teacher rest room	Plumbing
Grandview Heights MS (2835) 1B	two compartment sink leaking	8/30/13	Cafeteria	kitchen	Plumbing
Grandview Heights MS (2835) 1B	water cooler not working 026-184	7/15/13	1st Floor	south end	Plumbing
Grandview Heights MS (2835) 1B	water cooler need handler replacement	7/15/13	1st Floor	south east end	Plumbing
Grandview Heights MS (2835) 1B	toilet leaking from the bowl on the back	7/25/13	Cafeteria	rest room	Plumbing

Grandview Heights MS (2835) 1B	UNIT IN RM 8A IS LEAKING & TEACHER LOUNGE SBE DAWSON 416-3940	7/31/13			Plumbing
Grandview Heights MS (2835) 1B	UV-2 RM 12-LEAKING-SBE DAWSON 416-3940 KLR	8/8/13			Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	10/4/13	Restroom (Boys)	2nd floor	Plumbing
Grandview Heights MS (2835) 1B	Replace drian pan rm 214.	10/10/13			Plumbing
Grandview Heights MS (2835) 1B	need washer reoplacement on the facet	11/7/13	2nd Floor	sped hallway	Plumbing
Grandview Heights MS (2835) 1B	toilet with not stop flushing	11/12/13	2nd Floor	plant manager office	Plumbing
Grandview Heights MS (2835) 1B	toilet need two seats replacement	11/19/13	2nd Floor	girl restroom	Plumbing
Grandview Heights MS (2835) 1B	need flush vale replacement on the toilet	11/20/13	Restroom (Girls)	1st floor	Plumbing

Grandview Heights MS (2835) 1B	flush vale need replacement on the urinal	11/22/13	Restroom (Boys)	2nd floor annex	Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	11/25/13	Restroom (Boys)	2nd floor	Plumbing
Grandview Heights MS (2835) 1B	flush vale need replacement	11/25/13	Restroom (Boys)	1st floor annex	Plumbing
Grandview Heights MS (2835) 1B	Check/Repair GAS meter - line. MLGW says possible leak.	1/27/14	Grounds		Plumbing
Grandview Heights MS (2835) 1B	Repair 1st floor cut off in Boys Bathroom.	1/27/14	Annex		Plumbing
Grandview Heights MS (2835) 1B	vale leaking for the unit roof top	1/29/14	Restroom (Boys)	annex 1st floor	Plumbing
Grandview Heights MS (2835) 1B	hand sink leaking from the trap	2/19/14	Restroom (Girls)	2nd floor	Plumbing
Grandview Heights MS (2835) 1B	flush vale leaking on the toilet	2/19/14	Restroom (Girls)	2nd floor	Plumbing

Grandview Heights MS (2835) 1B	pipe still leaving from the ceiling	2/21/14	Restroom (Boys)	2nd floor annex	Plumbing
Grandview Heights MS (2835) 1B	three compartment need a washer replacement on the faucet	2/21/14	Cafeteria	kitchen	Plumbing
Grandview Heights MS (2835) 1B	OVEN NEEDS TO BE LIT PLANT MGR-DAWSON/416.3940	2/24/14			Plumbing
Grandview Heights MS (2835) 1B	Boiler is LEAKING per Gale Dawson, Plant Mgr. 416.3940	1/8/14			Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	12/2/13	Administration Area	main office	Plumbing
Grandview Heights MS (2835) 1B	three compartment sink water keep running the tub onto the floor , also floor drain stop up	12/3/13	Cafeteria	kitchen	Plumbing
Grandview Heights MS (2835) 1B	A/C RM 8A-LEAKING-PLANT MGR DAWSON 416-3940 KLR	9/6/13			Plumbing
Grandview Heights MS (2835) 1B	A/C RM 12-LEAKING-PLANT MGR DAWSON 416-3940 KLR	9/10/13			Plumbing

Grandview Heights MS (2835) 1B	handler need replacement on the water fountain 026-159	9/11/13	Hallway/Corridor	2nd floor annex	Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	3/19/14	Restroom (Boys)	2nd floor hallway	Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	3/26/14	Restroom (Girls)	1st floor annex	Plumbing
Grandview Heights MS (2835) 1B	sink will not hold water stopped doesn't work two compartment	4/4/14	Cafeteria	kitchen	Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	4/14/14	Restroom (Boys)	2nd floor	Plumbing
Grandview Heights MS (2835) 1B	flush vale need replacement	4/15/14	Restroom (Boys)	2nd floor annex	Plumbing
Grandview Heights MS (2835) 1B	toilet stop up	5/2/14	Restroom (Boys)	2nd floor annex	Plumbing
Grandview Heights MS (2835) 1B	water key handler is strip need replacement two or more request..	5/7/14	Grounds	on the dock	Plumbing

Grandview Heights MS (2835) 1B	RTU MAIN OFC AREA-LEAKING- PLANT MGR DAWSON 416-3940 KLR	5/12/14				Plumbing
Grandview Heights MS (2835) 1B	air handler leaking water	5/29/14	Administration Area	main office		Plumbing
Grandview Heights MS (2835) 1B	RTU -BY PRIN OFC - LEAKING IN HALLWAY - PM/DAWSON 416-3940	6/4/14				Plumbing
Grandview Heights MS (2835) 1B	water heater- standing water in the tub the hot water tank are in,,	6/10/14	1st Floor	119		Plumbing
Grandview Heights MS (2835) 1B	roof leak was raining over the serving area	9/26/13	Cafeteria	serving area		Roof
Grandview Heights MS (2835) 1B	leaking in the classroom from the ceiling	9/27/13	2nd Floor	206 annex		Roof
Grandview Heights MS (2835) 1B	Roof leaking	7/19/13	2nd Floor	Rm. 206		Roof
Grandview Heights MS (2835) 1B	Roof leaking	8/2/13	1st Floor	09		Roof

Grandview Heights MS (2835) 1B	ceiling leaking on going promblem	11/22/13	2nd Floor	206	Roof
Grandview Heights MS (2835) 1B	roof ceiling from the ceiling	11/26/13	Cafeteria	back of gym	Roof
Grandview Heights MS (2835) 1B	ceiling leaking in classroom 215,206,204 also Assiatant principal office	2/5/14	2nd Floor	annex	Roof
Grandview Heights MS (2835) 1B	leaking from the ceiling	2/5/14	Library	2nd floor annex	Roof
Grandview Heights MS (2835) 1B	roof leaking	12/2/13	Cafeteria	north end	Roof
Grandview Heights MS (2835) 1B	leaking in the classroom on going problem this is not complete this is a computer lap	12/10/13	2nd Floor	206	Roof
Grandview Heights MS (2835) 1B	ceiling leaking all over the room	3/27/14	Library	2ND Floor Annex	Roof
Grandview Heights MS (2835) 1B	ceiling leaking	4/7/14	2nd Floor	204 annex	Roof

Grandview Heights MS (2835) 1B	leaking from the ceiling	4/9/14	Library	2nd floor annex	Roof
Grandview Heights MS (2835) 1B	leaking from the ceiling	4/9/14	2nd Floor	204	Roof
Grandview Heights MS (2835) 1B	leaking from the ceiling	4/9/14	Administration Area	main office	Roof
Grandview Heights MS (2835) 1B	ceiling leaking	5/29/14	Library	2nd floor	Roof
Grandview Heights MS (2835) 1B	ceiling leaking	6/2/14	Administration Area	hallway by the principal office	Roof
Grandview Heights MS (2835) 1B	ceiling leaking water all principal office	6/9/14	Administration Area	Ast.Principal	Roof
Grandview Heights MS (2835) 1B	ceiling leaking	6/9/14	Administration Area	hallway	Roof
Grandview Heights MS (2835) 1B	classroom leaking from the ceiling	6/10/14	2nd Floor	204	Roof

Grandview Heights MS (2835) 1B	classroom leaking from the ceiling	6/10/14	1st Floor	105	Roof
Grandview Heights MS (2835) 1B	classroom leaking from the ceiling	6/10/14	1st Floor	113	Roof
Grandview Heights MS (2835) 1B	classroom leaking from the ceiling	6/10/14	1st Floor	19	Roof
Grandview Heights MS (2835) 1B	ceiling tile leaking	6/10/14	1st Floor	106	Roof
Grandview Heights MS (2835) 1B	Fabricate sheet metal cover for electric recep. Support Chalk	6/13/14	Classroom		Sheet Metal
Grandview Heights MS (2835) 1B	screw coming out of the metal strip on the step tripping hazard	9/23/13	Gym	east end	Sheet Metal
Grandview Heights MS (2835) 1B	siding on the dog house need repair and replcement over anex and kitchen east wing. This sheetmetal work	8/27/13	Grounds	root top	Sheet Metal
Grandview Heights MS (2835) 1B	unit ventilators need cleaning out..	7/15/13	1st Floor	hallway eastend	Sheet Metal

Grandview Heights MS (2835) 1B	Fabricate front panel cover on water foun.	7/26/13	Annex		Sheet Metal
Grandview Heights MS (2835) 1B	gutter have falling off the building on the cafeteria wing also east end annex wing	1/6/14	Grounds	gutter	Sheet Metal
Grandview Heights MS (2835) 1B	looker jam	3/26/14	2nd Floor	hallway	Sheet Metal
Grandview Heights MS (2835) 1B	gusses need repairing hanging	4/17/14	Annex	root top	Sheet Metal

Count of Craft	Craft							Grand Total
	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Sheet Metal	
Hamilton ES (2310) 1A	5	16	60	36	1	43	3	164
Grand Total	5	16	60	36	1	43	3	164

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Hamilton ES (2310) 1A	Main Office area replace carpet with floor tile.	4/7/14	Administration Area	2nd floor	Asbestos
Hamilton ES (2310) 1A	Assistant Principal Office replace carpet with floor tile.	4/7/14	2nd Floor	Assistant Prin. Office	Asbestos
Hamilton ES (2310) 1A	HVAC leak first floor hallway, please insulate pipe. Thank you. Support WO 430840. Zone 1b.	4/22/14	1st Floor		Asbestos
Hamilton ES (2310) 1A	Insulate pipes (2) near room 206, uni-vent. Ref. wo 398944.	11/22/13	2nd Floor		Asbestos
Hamilton ES (2310) 1A	In Principal Office replace carpet with floor tile. This is a trip hazard. This has not been done.	3/5/14	Administration Area	2nd Floor	Asbestos
Hamilton ES (2310) 1A	Window need replace this is a different work order.	4/10/14	2nd Floor	207	Carpentry
Hamilton ES (2310) 1A	Trimmer is come loose from under stairway.	4/10/14	Hallway/Corridor	2nd floor	Carpentry

Hamilton ES (2310) 1A	Doors is hard to open.	4/10/14	2nd Floor	Enter Door	Carpentry
Hamilton ES (2310) 1A	Handle is come loose from door.	4/10/14	Hallway/Corridor	2nd floor west end	Carpentry
Hamilton ES (2310) 1A	Floor tile need replace.	7/18/13	2nd Floor	Teacher Lounge	Carpentry
Hamilton ES (2310) 1A	Floor tile need replace.	7/18/13	Cafeteria	2Nd floor	Carpentry
Hamilton ES (2310) 1A	Door will not close.	8/6/13	2nd Floor	Teacher Lounge	Carpentry
Hamilton ES (2310) 1A	Stall door need installing.	4/30/14	Restroom (Boys)	1st floor	Carpentry
Hamilton ES (2310) 1A	Door needs a security plate urgent.	6/3/14	2nd Floor	Front enter door	Carpentry
Hamilton ES (2310) 1A	screw will not tight up in door hinges.	9/12/13	Mechanical Room	3rd floor west end	Carpentry

Hamilton ES (2310) 1A	Door is sticking.	12/4/13	2nd Floor	Teacher Lounge	Carpentry
Hamilton ES (2310) 1A	Recycle Dumpster need a place weld for a pad lock to fixture. (need zone welder to weld lock tabs on dumpster)	2/10/14	Grounds	North of building	Carpentry
Hamilton ES (2310) 1A	Install a stall door.	2/18/14	Restroom (Boys)	3rd floor east end	Carpentry
Hamilton ES (2310) 1A	Flag pole need a cable.	2/24/14	Grounds	Front of school	Carpentry
Hamilton ES (2310) 1A	Replace window.	3/4/14	2nd Floor	207	Carpentry
Hamilton ES (2310) 1A	Locker is come loose fromthe wall.	4/7/14	1st Floor	108	Carpentry
Hamilton ES (2310) 1A	Light ballast is burn out in the hall by the main office.	4/9/14	Hallway/Corridor	2Nd floor	Electrical
Hamilton ES (2310) 1A	Lights ballast is burn out.	4/10/14	Cafeteria	2dn floor	Electrical

Hamilton ES (2310) 1A	FCU PE AREA & UV PE AREA-BOTH NOT COMING ON-PLANT MGR FANE 416- 7826 KLR	4/11/14			Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	4/15/14	Library	3rd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	7/16/13	Hallway/Corridor	2Nd floor	Electrical
Hamilton ES (2310) 1A	Set Master Clock for new start time.	7/30/13	Administration Area	2Nd floor	Electrical
Hamilton ES (2310) 1A	UNIT VENT IN RM 311 IS NOT COMING ON SBE FANE 416-7826	7/31/13			Electrical
Hamilton ES (2310) 1A	UV 3RD FLR RM 311-NOT COMING ON-SBE FANE 416- 7826 KLR	8/6/13			Electrical
Hamilton ES (2310) 1A	Light ballast is burn out over secretary deck.	8/7/13	Administration Area	2Nd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	4/24/14	Cafeteria	2Nd floor	Electrical

Hamilton ES (2310) 1A	Light ballast is burn out.	4/25/14	Hallway/Corridor	1st floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	5/22/14	Hallway/Corridor	2nd floor east end	Electrical
Hamilton ES (2310) 1A	Unit not coming on in rm-306 Plant Mgr-Fane/416.7826	6/18/14			Electrical
Hamilton ES (2310) 1A	light ballast is burn out.	7/2/13	1st Floor	103	Electrical
Hamilton ES (2310) 1A	Exhaust Fan for kitchen vent hood is not working.when oven doors is open it's set off the fire alarm from the heat.	9/16/13	Kitchen	Roof west end	Electrical
Hamilton ES (2310) 1A	Install new exhaust fan because it's was stolen.	9/17/13	Kitchen	Roof west end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	9/20/13	1st Floor	103	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	9/20/13	Hallway/Corridor	1st floor	Electrical

Hamilton ES (2310) 1A	Light ballast is burn out.	9/20/13	2nd Floor	Guidance Room	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	9/20/13	Hallway/Corridor	2Nd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out	10/2/13	3rd Floor	311	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	10/17/13	3rd Floor	303	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	10/17/13	Hallway/Corridor	3rd floor east end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	10/17/13	Hallway/Corridor	2nd floor east end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	10/18/13	Hallway/Corridor	1st floor east end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	10/28/13	1st Floor	103	Electrical

Hamilton ES (2310) 1A	Light ballast is burn out.	10/28/13	1st Floor	105	Electrical
Hamilton ES (2310) 1A	Receptacle is not working.	10/28/13	Administration Area	2Nd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	10/28/13	1st Floor	102	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	11/14/13	2nd Floor	209	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	11/14/13	3rd Floor	309	Electrical
Hamilton ES (2310) 1A	Unit Ventilator in Room 318 is NOT COMING ON per Mr. Fane, Plant Mgr. 416.7826	12/2/13			Electrical
Hamilton ES (2310) 1A	Light ballasts is burn out.	12/9/13	2nd Floor	Serving Area	Electrical
Hamilton ES (2310) 1A	UV NOT COMING ON IN RM-316 PLANT MGR- FANE/416.7826	12/11/13			Electrical

Hamilton ES (2310) 1A	Light ballast is burn out.	1/8/14	2nd Floor	210	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out .	1/9/14	3rd Floor	303	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	1/9/14	Hallway/Corridor	3rd floor east end	Electrical
Hamilton ES (2310) 1A	Emergency light is not come on location by room 103.	1/22/14	Hallway/Corridor	1st floor	Electrical
Hamilton ES (2310) 1A	Emergency light is not come on location by room 203	1/22/14	Hallway/Corridor	2Nd floor	Electrical
Hamilton ES (2310) 1A	Emergency light is not come by room 210	1/22/14	Hallway/Corridor	2Nd floor	Electrical
Hamilton ES (2310) 1A	Emergency light is not come on between 2nd &3rd floor.	1/22/14	Stairway	west end	Electrical
Hamilton ES (2310) 1A	Emergency light is not come on location on the east &north wall.	1/22/14	Cafeteria	2Nd floor	Electrical

Hamilton ES (2310) 1A	Emergency light is not come on.	1/22/14	Kitchen	2Nd floor	Electrical
Hamilton ES (2310) 1A	Replace belt on exhaust fan.	2/18/14	Grounds	West end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	2/20/14	3rd Floor	302	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	2/24/14	Hallway/Corridor	East end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	2/24/14	3rd Floor	315	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	2/26/14	2nd Floor	204	Electrical
Hamilton ES (2310) 1A	Set Master Clock for daylight saving time.	3/4/14	Administration Area	2Nd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out in restroom across from room306.	3/17/14	Restroom (Boys)	3rd floor west end	Electrical

Hamilton ES (2310) 1A	Light ballast is burn out.	3/24/14	Hallway/Corridor	1st floor	Electrical
Hamilton ES (2310) 1A	Four lamp light ballast is burn out.	3/27/14	1st Floor	101	Electrical
Hamilton ES (2310) 1A	Four lamp light ballast is burn out.	3/27/14	1st Floor	106	Electrical
Hamilton ES (2310) 1A	Exhaust Fan is not working properly. when the oven door is open the fire alarm goes off. This is urgent!	3/31/14	Kitchen	2nd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	3/31/14	Restroom (Girls)	3rd floor west end	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	3/31/14	3rd Floor	319	Electrical
Hamilton ES (2310) 1A	Cafeteria Manager Office light ballast is burn out.	4/2/14	Kitchen	2nd floor	Electrical
Hamilton ES (2310) 1A	Light ballast is burn out.	4/24/14	3rd Floor	306	Electrical

Hamilton ES (2310) 1A	Needs fifty fluorescent lamps.	8/16/13	2nd Floor	Boiler room	Electrical
Hamilton ES (2310) 1A	Need fluorescent lamps 4 ft long.	12/4/13	2nd Floor	Custodial closet	Electrical
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	CHILLER MECH RM-IN ALARM-PLANT MGR FANE 416-7826 KLR	4/17/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - Oil Lube & Belt- Hamilton Elementary - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - HAMILTON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning

Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - Filter-Hamilton Elementary - Refer to PM schedule details.	5/26/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	6/6/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Yearly - Oil Samples-Hamilton Elem - Refer to PM schedule details.	9/6/13			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	chiller is down no a/c per fane 416-7826	9/17/13			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - Filter-Hamilton Elementary - Refer to PM schedule details.	9/23/13			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning

Hamilton ES (2310) 1A	drain system for plumber to fix leak	11/21/13			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	BOILER MECH RM-NOT COMING ON-PLANT MGR FANE 416-7826 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	hwh boiler make up pressure regulator	11/25/13	Mechanical Room		Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	boiler #027046 boiler is down per Mr. Fane 416-7826	1/3/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	HEAT RM 316-NOT HEATING-PLANT MGR FANE 416-7826 KLR	1/9/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - Filter-Hamilton Elementary - Refer to PM schedule details.	1/27/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Hamilton ES (2310) 1A	Monthly - HAMILTON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Yearly - Water-Cool Chiller Filter-Hamilton Elem - Refer to PM schedule details.	2/7/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - HAMILTON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Yearly - Rod Chiller - Hamilton Elementary - Refer to PM schedule details.	3/17/14			Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Yearly - Cooling Towers-Hamilton Elem - Refer to PM schedule details.	3/17/14			Heating/Ventilation /Air Conditioning

Hamilton ES (2310) 1A	Monthly - Oil Lube & Belt- Hamilton Elementary - Refer to PM schedule details.	3/17/14				Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	C/O to A/C	3/21/14				Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	clean cooling tower	3/26/14				Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Daily - Hamilton ElemLevel 1 Water Treatment - Refer to PM schedule details.	3/28/14				Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	The pumps for the boiler and chiller only work in hand position. They do not work in the automatic position. Fan coil unit and unit ventilator work only in hand position.	3/31/14	2nd Floor	Boiler room		Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Monthly - HAMILTON ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14				Heating/Ventilation /Air Conditioning
Hamilton ES (2310) 1A	Park Lot need striping per (principal) request.	7/15/13	Grounds	Park Lot		Painting
Hamilton ES (2310) 1A	SEWAGE SMELL THRU BLDG PLANT MGR- FANE/416.7826	4/8/14				Plumbing

Hamilton ES (2310) 1A	nurses restroom repair toilet	4/10/14			Plumbing
Hamilton ES (2310) 1A	Replace toilet seat	4/10/14	Restroom (Girls)	3rd floor west end	Plumbing
Hamilton ES (2310) 1A	Faucet pipe is leaking.	4/22/14	Restroom (Boys)	3rd floor west end	Plumbing
Hamilton ES (2310) 1A	UNIT IS LEAKING WATER ON 1ST FLR HALL PLANT MGR- FANE/416.7826	4/22/14			Plumbing
Hamilton ES (2310) 1A	Faucet is leaking from pea trap.	8/12/13	Restroom (Boys)	1st floor	Plumbing
Hamilton ES (2310) 1A	UV 1ST FLR RM 101 & 1ST FLR RM 103-BOTH LEAKING-SBE FANE 416- 7826 KLR	8/13/13			Plumbing
Hamilton ES (2310) 1A	FLOOR DRAIN BACKING UP IN KITCHEN AREA-SBE FANE 416-7826 KLR	8/13/13			Plumbing
Hamilton ES (2310) 1A	room 101 unit ventilator leaking water per Fane 416- 7826	8/14/13			Plumbing

Hamilton ES (2310) 1A	UV IS LEAKING IN RM- 103(071), & P.E. AREA(072) PLANT MGR- FANE/416.7826	8/14/13			Plumbing
Hamilton ES (2310) 1A	Sink is leaking.	5/12/14	Hallway/Corridor	3rd floor east end	Plumbing
Hamilton ES (2310) 1A	Sewer gas is come from around toilet	5/22/14	2nd Floor	Boiler room	Plumbing
Hamilton ES (2310) 1A	UNIT VENTILATOR is LEAKING in the P.E. area per Mr. Fane, Plant Mgr. 416.7826	6/4/14			Plumbing
Hamilton ES (2310) 1A	repair faucet main hall 2 floor	7/1/13			Plumbing
Hamilton ES (2310) 1A	Repair Drinking foun.	7/3/13			Plumbing
Hamilton ES (2310) 1A	Replace floor drains cover.	7/15/13	Kitchen	2Nd floor	Plumbing
Hamilton ES (2310) 1A	UNIT VENTILATOR is LEAKING in CLASSROOMS 316 per Mr. Fane, Plant Mgr. 416.7826	6/20/14			Plumbing

Hamilton ES (2310) 1A	WALL UNIT is LEAKING in ROOM 312 per William Blakely, Plant Mgr. 416.7826	6/23/14			Plumbing
Hamilton ES (2310) 1A	UV RM 101-LEAKING-SBE FANE 416-7826 KLR	8/20/13			Plumbing
Hamilton ES (2310) 1A	UV IS LEAKING IN RM-101 PLANT MGR- FANE/416.7826	8/21/13			Plumbing
Hamilton ES (2310) 1A	UV IS LEAKING WATER IN RM-306 PLANT MGR- FANE/416.7826	8/22/13			Plumbing
Hamilton ES (2310) 1A	UV IS LEAKING WATER IN RM-306(058) PLANT MGR- FANE/416.7826	8/23/13			Plumbing
Hamilton ES (2310) 1A	toilet is stop up.	8/23/13	Restroom (Boys)	2Nd floor	Plumbing
Hamilton ES (2310) 1A	Unstop sewer	8/26/13			Plumbing
Hamilton ES (2310) 1A	Toilet is stop-up.	8/29/13	Restroom (Boys)	2Nd floor	Plumbing

Hamilton ES (2310) 1A	UV IS LEAKING WATER IN RM-101. PLANT MGR- FANE/416.7826	9/5/13			Plumbing
Hamilton ES (2310) 1A	Wash basin sink is leaking.	9/30/13	Hallway/Corridor	2Nd floor hall	Plumbing
Hamilton ES (2310) 1A	Wash basin sink is leaking.	9/30/13	Hallway/Corridor	3rd floor west end	Plumbing
Hamilton ES (2310) 1A	A/C RM 213 & 317-BOTH DRAINS ARE STOPPED UP & LEAKING-PLANT MGR FANE 416-7826 KLR	10/16/13			Plumbing
Hamilton ES (2310) 1A	Sink is leaking from drain pipe.	10/24/13	Hallway/Corridor	3rd floor east end	Plumbing
Hamilton ES (2310) 1A	Commode is stop up.	11/7/13	Restroom (Boys)	1st floor	Plumbing
Hamilton ES (2310) 1A	UV PIPE HAS BUSTED IN RM-206 PLANT MGR-FANE/416- 7826	11/21/13			Plumbing
Hamilton ES (2310) 1A	Replace handle on wash basin sink.	11/21/13	2nd Floor	west end hall	Plumbing

Hamilton ES (2310) 1A	Toilet is stop up.	12/11/13	Restroom (Boys)	2nd floor east end	Plumbing
Hamilton ES (2310) 1A	Commode is leaking from the bottom.	1/22/14	Restroom (Boys)	2nd floor east end	Plumbing
Hamilton ES (2310) 1A	Urgent commode is leaking from pipe.	2/11/14	2nd Floor	Teacher Lounge	Plumbing
Hamilton ES (2310) 1A	GARBAGE DISPOSAL IS STOPPED UP IN KITCHEN PLANT MGR-FANE/416.7826	2/13/14			Plumbing
Hamilton ES (2310) 1A	Floor drain is stop up.	2/18/14	Restroom (Girls)	2nd floor west end	Plumbing
Hamilton ES (2310) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing
Hamilton ES (2310) 1A	Replace clean out plug.	3/24/14	2nd Floor	Boiler room	Plumbing
Hamilton ES (2310) 1A	Cooling Tower pipe is buster.	3/26/14		Roof	Plumbing

Hamilton ES (2310) 1A	Insulate pipe on cooling tower. Contact Frank Owens if needed. Thanks	3/27/14			Plumbing
Hamilton ES (2310) 1A	UNIT VENTILATOR is LEAKING in CLASSROOM 317 per Mr. Fane, Plant Mgr. 416.7826	6/19/14			Plumbing
Hamilton ES (2310) 1A	Repair hole out side of the building to keep birds from come into cafeteria.	4/9/14	Cafeteria	North of building	Sheet Metal
Hamilton ES (2310) 1A	Remove lockers near room 206. Pipe leak in wall. Ref. 398944.	11/21/13	2nd Floor		Sheet Metal
Hamilton ES (2310) 1A	Provide and install 2each pieces of sheet metal to cover around pipes 8" by 16". Re-install lockers.	11/21/13	2nd Floor		Sheet Metal

Count of Craft	Craft							Grand Total
	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	
Hamilton Middle (2315) 1A	5	1	33	50	38	5	52	184
Grand Total	5	1	33	50	38	5	52	184

Location	Request Description	Submittal Dat	Area Descript	Area Number	Craft
Hamilton Middle (2315) 1A	Check for mold growth in classroom #4 in the Success Academy (located under the auditorium).	8/13/13			Asbestos
Hamilton Middle (2315) 1A	Success Academy room # 4 replace ceiling tile and cut around sprinkler head.	8/14/13			Asbestos
Hamilton Middle (2315) 1A	We need the gym floor refinished.	12/3/13	Gym		Asbestos
Hamilton Middle (2315) 1A	Repair/replace ACM floor tile, located in the alternative wing in front of the boys restroom. This supports WO # 405078, Zone 1b. Thank you.	1/15/14	Hallway/Corridor		Asbestos
Hamilton Middle (2315) 1A	Please insulate sprinkler pipe overhead. Leading to cafeteria 20 to 28 feet. This pipe busted last week.	1/22/14	Hallway/Corridor		Asbestos
Hamilton Middle (2315) 1A	We have a bad drop in room 219 port 219-8 ---IDF-2 RECEIVED".and we will provide service as soon as we possibly can . "SCS NCE Dept.- Mr. Leslie Ratliff -- 301-3661) See journal note	4/15/14	Classroom	219	Cabling
Hamilton Middle (2315) 1A	We have a crack and a couple of holes that needs to be repaired on the gym floor located in the free throw lane when entering the gym.	9/19/13	Gym		Carpentry

Hamilton Middle (2315) 1A	ENTRANCE DOOR BY GYM TICKET BOOTH-NOT LOCKING- NOT ABLE TO SECURE-SBE ROGERS 416-7838 KLR	8/14/13			Carpentry
Hamilton Middle (2315) 1A	We have some new basketball goals that coach needs installed in the gym.	10/14/13	Gym		Carpentry
Hamilton Middle (2315) 1A	We have a outside door handle across from the gym that needs to be replaced due to vandalism.	10/14/13	Stairway		Carpentry
Hamilton Middle (2315) 1A	We have some banners that need to be hung in the gym that will require a lift.	12/3/13	Gym		Carpentry
Hamilton Middle (2315) 1A	The flag pole cord is damaged and needs to be replaced. The wire has breaks in it making it difficult to raise and lower the flag.	7/12/13	Grounds		Carpentry
Hamilton Middle (2315) 1A	Repair door handle room 118.	7/12/13	Classroom		Carpentry
Hamilton Middle (2315) 1A	Hall door across from room 110 is sticking.	7/12/13	Hallway/Corri dor		Carpentry
Hamilton Middle (2315) 1A	Repair weather stripping Exit door southside.	7/12/13	1st Floor		Carpentry

Hamilton Middle (2315) 1A	Repair door closer near room 215.	7/12/13	2nd Floor		Carpentry
Hamilton Middle (2315) 1A	Repair floor tile by expansion joint.	7/12/13	2nd Floor		Carpentry
Hamilton Middle (2315) 1A	Repair door handle room 222.	7/12/13	2nd Floor		Carpentry
Hamilton Middle (2315) 1A	Repair covebase main hall.	7/12/13	3rd Floor		Carpentry
Hamilton Middle (2315) 1A	Repair door handle room 305.	7/12/13	3rd Floor		Carpentry
Hamilton Middle (2315) 1A	Install new threshold in hallway, existing is damaged.	7/12/13	3rd Floor		Carpentry
Hamilton Middle (2315) 1A	Repair door closer room 306.	7/12/13	3rd Floor		Carpentry
Hamilton Middle (2315) 1A	Repair (main office) swing gate so it can lock.	7/12/13	Administration Area		Carpentry

Hamilton Middle (2315) 1A	Replace RCI with sargent at south door entry.	7/12/13	Hallway/Corridor		Carpentry
Hamilton Middle (2315) 1A	We have 2 windows that needs replacing in the boys restroom on the 3rd floor.	7/15/13	Restroom (Boys)		Carpentry
Hamilton Middle (2315) 1A	We have floor tiles that needs to be replaced that have come up.	7/16/13	Classroom	309	Carpentry
Hamilton Middle (2315) 1A	Repair gym doors (2).	7/17/13	Gym		Carpentry
Hamilton Middle (2315) 1A	Repair/adjust door locker area.	7/17/13	Gym		Carpentry
Hamilton Middle (2315) 1A	Repair door hardware.	7/17/13	Gym		Carpentry
Hamilton Middle (2315) 1A	We some pieces of the floor that needs to be replaced that are broken before the floor gets refinished.	12/11/13	Gym		Carpentry
Hamilton Middle (2315) 1A	replace a few damage hardwood	12/11/13	Basketball Court		Carpentry

Hamilton Middle (2315) 1A	We have some broken floor tile that needs to be replaced located in the alternative wing in front of the boys restroom.	12/20/13	Hallway/Corridor		Carpentry
Hamilton Middle (2315) 1A	We have a couple of ceiling tiles that needs to be replaced located on the hallway walking into the cafe where the pipe busted. There is 1 tile with the sprinkler head and 1 with a smoke detector.	1/7/14	Hallway/Corridor		Carpentry
Hamilton Middle (2315) 1A	We have a door lock that is stripped that needs to be repaired.	1/10/14	Classroom	201	Carpentry
Hamilton Middle (2315) 1A	FRONT DOOR, CANT SECURE PANIC BAR HAS CAME OFF PLANT MGR- HENDERSON/503.3884	3/6/14			Carpentry
Hamilton Middle (2315) 1A	The handicap railing is broken and needs to be repaired located in the alternative wing.	4/21/14	Annex		Carpentry
Hamilton Middle (2315) 1A	We have a door handle that is broken and needs to be repaired located in the alternative wing.(classroom 6)	4/24/14	Classroom	6	Carpentry
Hamilton Middle (2315) 1A	We have a panic bar that is broken and needs to be repaired located in the alternative wing by room #4.	4/29/14	Hallway/Corridor		Carpentry
Hamilton Middle (2315) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located on the 1st and 3rd floors.	5/13/14	Hallway/Corridor		Carpentry

Hamilton Middle (2315) 1A	We have a bad motor on the far end of the bleachers on the left side. One side come in and out and one side don't. No I.D.#	9/19/13	Gym		Electrical
Hamilton Middle (2315) 1A	We have light switch that has a shortage that needs to be replaced located on the 2nd floor.	9/23/13	Hallway/Corridor		Electrical
Hamilton Middle (2315) 1A	We have a light switch in the alternative wing boys restroom that needs to be replaced.	8/9/13	Restroom (Boys)		Electrical
Hamilton Middle (2315) 1A	We have a light switch that needs to be replaced in the girls restroom on the alternative wing.	8/9/13	Restroom (Girls)		Electrical
Hamilton Middle (2315) 1A	FCU-2 RM 217 & FCU-2 RM 219- BOTH NOT COMING ON-SBE ROGERS 416-7832 KLR	8/12/13			Electrical
Hamilton Middle (2315) 1A	The main office clock needs to be reset due to power failure.	8/15/13	Administration Area	main office	Electrical
Hamilton Middle (2315) 1A	UV RM 122-NOT COMING ON-PLANT MGR ROGERS 416-7832 KLR	8/26/13			Electrical
Hamilton Middle (2315) 1A	We have a bad switch that needs to be replaced located in the cafe. It has a row of lights that are out and I checked the breakers.	9/3/13	Cafeteria		Electrical

Hamilton Middle (2315) 1A	We have 2 bad ballasts in the stairwell that needs to be repaired.	9/9/13	Stairway		Electrical
Hamilton Middle (2315) 1A	We 3 lights that are out on the side of the building facing the gym that needs to be replaced. They are used for security purposes.	9/10/13	Grounds		Electrical
Hamilton Middle (2315) 1A	A/C ALTERNATIVE WING RM 6- NOT COMING ON-PLANT MGR ROGERS 416-7832 KLR	9/11/13			Electrical
Hamilton Middle (2315) 1A	We need a timer installed for the lights that were put in under the walkway so they won't be burning all day and night.	9/30/13	Grounds		Electrical
Hamilton Middle (2315) 1A	LIGHTS 3RD FLR HALLWAY-HALF ARE COMING ON-BREAKER IS FINE-KINDA DARK IN AREA- PLANT MGR ROGERS 416-7832 KLR	10/14/13			Electrical
Hamilton Middle (2315) 1A	We have a bad ballast in light that needs to be replaced.	10/24/13	Cafeteria		Electrical
Hamilton Middle (2315) 1A	We have a bad ballast in light on the 3rd floor located by the elevator on the main office side of the building that needs to be replaced.	10/24/13	Hallway/Corridor		Electrical
Hamilton Middle (2315) 1A	The light switch has a shortage and needs to be replaced. It sparked when I turned it on.	11/4/13	Classroom	208	Electrical

Hamilton Middle (2315) 1A	We need the lights on the outside of the auditorium needs replacing. They are security lights that are not working.	11/6/13	Grounds		Electrical
Hamilton Middle (2315) 1A	We have a bad motor on the far end of the bleachers on the left side. One side come in and out and one side don't. No I.D.#	11/27/13	Gym		Electrical
Hamilton Middle (2315) 1A	We have 4 lights on the front of the building that needs to be replaced. The lights are for security purposes.	11/27/13	Grounds		Electrical
Hamilton Middle (2315) 1A	We have some lights that needs replacing under the walkway entering the main office. Lights are needed for safety when entering and leaving the building at night.	7/15/13	Grounds		Electrical
Hamilton Middle (2315) 1A	The main office clock needs resetting to bell schedule for principal.	7/15/13	Administration Area		Electrical
Hamilton Middle (2315) 1A	Program clock and bells.	7/16/13	Administration Area		Electrical
Hamilton Middle (2315) 1A	UNIT NOT COMING ON IN RM-207(277). PLANT MGR-ROGERS/416.7832	8/1/13			Electrical
Hamilton Middle (2315) 1A	We have the lights out in girl's locker room that needs to be repaired.	12/5/13	Gym	girl's locker room	Electrical

Hamilton Middle (2315) 1A	Pump #6 is NOT COMING ON per Mr. Rogers, Plant Mgr. 416.7832	12/9/13			Electrical
Hamilton Middle (2315) 1A	We have 2 bad receptables that needs to be replaced located in the teacher's lounge on the 1st floor.	12/12/13	Administration Area		Electrical
Hamilton Middle (2315) 1A	We need the lights checked out in the boy's locker room. I checked the breakers but they were ok.	12/18/13	Gym		Electrical
Hamilton Middle (2315) 1A	We have a couple of bad receptables that needs to be replaced located in the alternative wing classroom #4.	12/20/13	Classroom	4	Electrical
Hamilton Middle (2315) 1A	PUMP-6 MECH RM-NOT COMING ON-PLANT MGR ROGERS 416-7832 KLR	1/7/14			Electrical
Hamilton Middle (2315) 1A	Disconnect power to pump # 6. To support Frank.	1/10/14			Electrical
Hamilton Middle (2315) 1A	Re-connect power to pump #6. To support Frank.	1/10/14			Electrical
Hamilton Middle (2315) 1A	We have a blown outlet in the gym's concession stand where the popcorn machine plugs in that needs to be replaced.	1/21/14	Gym		Electrical

Hamilton Middle (2315) 1A	We have 4 bad ballasts out in lights in the kitchen area that needs to be repaired.	1/24/14	Kitchen		Electrical
Hamilton Middle (2315) 1A	We need the clock in the main office set for day light saving time.	3/6/14	Administration Area	main office	Electrical
Hamilton Middle (2315) 1A	We have some expose wires that needs to covered located inside the boys locker room.	3/6/14	Gym		Electrical
Hamilton Middle (2315) 1A	We have a bad ballast in light located in the stairwell going down in the alternative wing.	3/25/14	Stairway		Electrical
Hamilton Middle (2315) 1A	We have 2 bad ballasts in lights located in the boys restroom on the 2nd floor by elevator on Kerr end.	3/25/14	Restroom (Boys)		Electrical
Hamilton Middle (2315) 1A	We have a bad ballast in light located in the men teacher's restroom on the 2nd floor.	3/25/14	Administration Area		Electrical
Hamilton Middle (2315) 1A	We have 4 bad ballasts out that needs to be replaced inside classroom 4 located in the alternative wing.	4/10/14	Classroom	4	Electrical
Hamilton Middle (2315) 1A	We have a bad ballast in light that needs to be replaced.	4/10/14	Cafeteria		Electrical

Hamilton Middle (2315) 1A	We have a bad computer receptable in the library besides the teacher desk.	4/14/14	Library		Electrical
Hamilton Middle (2315) 1A	We have a bad ballast in light located in the stairwell going down to the alternative wing. The light is out again.	4/25/14	Stairway		Electrical
Hamilton Middle (2315) 1A	A/C RM 112-NOT COMING ON-PLANT MGR ROGERS 416-7832 KLR	5/12/14			Electrical
Hamilton Middle (2315) 1A	EMERGENCY LIGHT IS HANGING FROM CEILING IN ADMIN HALL PLANT MGR-HENDERSON/503.3884	6/11/14			Electrical
Hamilton Middle (2315) 1A	We have 9 bad ballasts out in lights that needs to be replaced.	6/16/14	Classroom	222	Electrical
Hamilton Middle (2315) 1A	PARTIAL OUTAGE-NO POWER AT ALL TO ALTERNATIVE WING-PLANT MGR ROGERS 416-7838 KLR	6/30/14			Electrical
Hamilton Middle (2315) 1A	We have 4 lights on the front of the building that needs to be replaced. The lights are for security purposes.	9/25/13	Grounds		Electrical
Hamilton Middle (2315) 1A	We need 3 cases of classroom light bulbs (4ft.) to install through out the building.	3/6/14			Electrical

Hamilton Middle (2315) 1A	We need 3 cases of 4ft classroom light bulbs for Hamilton Middle and 3 cases of 4ft light bulbs for classroom for Hamilton High.	12/3/13			Electrical
Hamilton Middle (2315) 1A	We need some light bulbs for the entire locker room.	8/16/13	Gym	girls locker room	Electrical
Hamilton Middle (2315) 1A	Check auditorium chiller will not cool.	9/18/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Monthly - Filter-Hamilton Middle - Refer to PM schedule details.	9/20/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Monthly - Oil Lube & Belt-Hamilton Middle - Refer to PM schedule details.	8/6/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Check A/C in room #4 at the Success Academy. Too high a temperature and too high humidity.	8/13/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	chiller down	8/28/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	CHILLER-3 IN ALARM-PLANT MGR ROGERS 416-7832 KLR	9/6/13			Heating/Ventilation /Air Conditioning

Hamilton Middle (2315) 1A	CHILLER-3 IS IN ALARM-PLANT MGR ROGERS 416-7832 KLR	9/11/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	clean chillers	7/16/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	HEAT RMS 1 - 6 ALTERNATIVE SIDE OF BLDG-NOT WORKING- CALLED BY DR SUGGS 416-7832 KLR	12/11/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	lower auditorium --- not heating	12/17/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	check spt's on lower auditorium	12/18/13			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	HEAT HALF OF GYM & B/G LOCKER RMS-ALL NOT HEATING- PLANT MGR ROGERS 416-7832 KLR	1/9/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	HEAT RM 110-NOT HEATING- PLANT MGR ROGERS 416-7832 KLR	1/15/14			Heating/Ventilation /Air Conditioning

Hamilton Middle (2315) 1A	per Mr. Rogers 416-7832 rooms 305, 312, assist principal's office on 1st floor, auditorium and cafeteria are blowing cold air	1/22/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	boiler down	1/22/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Monthly - Filter-Hamilton Middle - Refer to PM schedule details.	1/24/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Rooftop units #3 & #4 are NOT HEATING per Mr. Rogers, Plant Mgr. 416.7832	1/24/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	HEAT RM 1 & 3 ON THE SUCCESS SIDE PER PRIN-NOT COMING ON-CALLED BY DR SUGGS 416-7949 KLR	1/27/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	rm #2 replace valve and actuator	1/29/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	HEAT KITCHEN AREA & CAFE AREA-BOTH NOT HEATING-PLANT MGR ROGERS 416-7832 KLR	1/29/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	cafe not heating	1/29/14			Heating/Ventilation /Air Conditioning

Hamilton Middle (2315) 1A	Yearly - Water-Cool Chiller Filter-Hamilton Middl - Refer to PM schedule details.	2/18/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	boiler down	3/6/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Monthly - Oil Lube & Belt-Hamilton Middle - Refer to PM schedule details.	3/11/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Aud. boiler not coming on	3/17/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	C/O to A/C --- 4 pipe system ?	3/21/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	CHILLER-1 & CHILLER-2-BOTH ARE IN ALARM-PLANT MGR ROGERS 416-7838 KLR	3/28/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	A/C AUDITORIUM-NOT COOLING-PLANT MGR ROGERS 416-7832 KLR	4/2/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	CHILLER IS IN ALARM. PRIN-HENDERSON/416.7832	4/4/14			Heating/Ventilation /Air Conditioning

Hamilton Middle (2315) 1A	chiller down	4/21/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	chiller down	4/24/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	clean chiller coils	4/29/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	Monthly - Filter-Hamilton Middle - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	chiller down	5/28/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	chiller down	6/5/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	check chillers	6/16/14			Heating/Ventilation /Air Conditioning
Hamilton Middle (2315) 1A	chiller down	6/23/14			Heating/Ventilation /Air Conditioning

Hamilton Middle (2315) 1A	Principal request that the administration parking lot be restripped and label.	8/5/13	Parking Lot		Painting
Hamilton Middle (2315) 1A	paint lines on football field	9/9/13			Painting
Hamilton Middle (2315) 1A	paint lines on football field	8/2/13			Painting
Hamilton Middle (2315) 1A	paint lines on football field	5/12/14			Painting
Hamilton Middle (2315) 1A	paint lines on football field	5/19/14			Painting
Hamilton Middle (2315) 1A	The boys restroom on the 2nd floor located by the elevator in the last stall needs a flush valve.	9/19/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have 3 toilet seats in the girls restroom on the 2nd floor that needs to be replaced.	8/13/13	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	The boys restroom toilet needs a flush val put in so the toilet will flush. The location is on the 2nd floor boys restroom.	8/14/13	Restroom (Boys)		Plumbing

Hamilton Middle (2315) 1A	The girl's restroom on the 2nd floor needs toilet seat replaced.	8/21/13	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	The custodial closet sink located on the first floor need the faucet replaced.	8/23/13	Custodial Closet	1st floor	Plumbing
Hamilton Middle (2315) 1A	We have a sink in the girls restroom that needs to be repaired located in the alternative wing.	8/28/13	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet seat that is broken and needs to be replaced located in the teacher's on the 2nd floor.	9/4/13	Administration Area	teacher' s lounge	Plumbing
Hamilton Middle (2315) 1A	The boys restroom located on the first floor as you enter the building has a faucet that needs to be replaced on the last sink when you enter the restroom.	9/5/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	The boys restroom located on the 2nd floor needs a faucet replaced on the sink when you enter the restroom.	9/9/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet that needs to be snaked out. I tried snaking it but it continues to bag up.	9/26/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet with a broken seat that needs to be replaced located on the 2nd floor white hallway.	10/31/13	Restroom (Boys)		Plumbing

Hamilton Middle (2315) 1A	The men's restroom in the alternative wing needs to be snaked out. I tried snaking it but it continues to bag up.	11/13/13	Administration Area		Plumbing
Hamilton Middle (2315) 1A	The boys restroom on the 3rd floor brown hallway has a toilet seat broken and needs to be repaired.	11/13/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a bad valve on back of the toilet that needs to be replaced located on the 1st floor.	11/15/13	Administration Area		Plumbing
Hamilton Middle (2315) 1A	We have a toilet that needs to be snake out located in the girl's locker room in the gym. I tried snaking it but it continues to bag up.	11/19/13	Gym		Plumbing
Hamilton Middle (2315) 1A	We have a toilet stopped that needs snaking out located on the 3rd floor on the white hallway first stall.	11/25/13	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet that is cracked and broken that needs to be replaced in the 3rd floor restroom.	7/15/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a faucet that needs repairing on the sink in the 3rd floor restroom.	7/15/13	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	The boys restroom on the 3rd floor has a broken toilet that needs to be replaced.	7/23/13	Restroom (Boys)		Plumbing

Hamilton Middle (2315) 1A	Girls locker room has a sink that is leaking and the faucet needs repairing.	7/25/13	Gym		Plumbing
Hamilton Middle (2315) 1A	We have a sink in the girls restroom that needs repairing.	7/25/13	Gym		Plumbing
Hamilton Middle (2315) 1A	We have a toilet in the boys restroom that needs repairing.	7/25/13	Gym		Plumbing
Hamilton Middle (2315) 1A	We have a sink that needs the faucet replaced in the girls restroom located on the first floor.	7/29/13	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	We have a water fountain that is leaking on the floor and needs to be repaired. (I.D.#161-296)	8/1/13			Plumbing
Hamilton Middle (2315) 1A	We have a broken toilet seat that needs to be replaced located in the gym girl's restroom.	12/5/13	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet located in the girl's locker room 1st stall that needs to be snaked out.	12/18/13	Gym		Plumbing
Hamilton Middle (2315) 1A	per Mr. Rogers 416-7832 there is a sprinkler pipe that has fallen out of the ceiling as you are going to cafeteria	1/7/14			Plumbing

Hamilton Middle (2315) 1A	Repair/Replace leaking pump # 6.	1/10/14			Plumbing
Hamilton Middle (2315) 1A	The sink inside the closet is stopped up.	1/10/14	Custodial Closet		Plumbing
Hamilton Middle (2315) 1A	We have a sink in the girl's locker room that is stopped up.	1/10/14	Grounds		Plumbing
Hamilton Middle (2315) 1A	WATER VALVE IS LEAKING WATER BY CAFE PLANT MGR-ROGERS/416.7832	1/16/14			Plumbing
Hamilton Middle (2315) 1A	The boys locker room needs the hot water turned on or repaired. There is no hot water.	1/21/14	Gym		Plumbing
Hamilton Middle (2315) 1A	rm #2 change hot water valve	1/30/14			Plumbing
Hamilton Middle (2315) 1A	Replace # 6 pump leaking very bad.	2/5/14			Plumbing
Hamilton Middle (2315) 1A	We have a pipe on the back of the toilet that is leaking and needs to be repaired located on the 3rd floor boys restroom on the Kerr end of the building. The 2nd stall when you walk in restroom.	2/21/14	Restroom (Boys)		Plumbing

Hamilton Middle (2315) 1A	We have a toilet in the boys restroom that needs to be snaked out located on the 2nd floor last stall on the Kerr end of the building.	2/24/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet in the boys restroom last stall that has come aloose from the floor that needs to be repaired located on the 2nd floor by elevator.	3/27/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a pipe in the ceiling that has a hole in it and leaking that needs to be repaired located in the boys restroom on the 2nd floor by elevator.	3/31/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a sink leaking and needs to be repaired located on the 1st floor by the elevator. The 3rd sink at the bottom.	4/7/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	4/8/14			Plumbing
Hamilton Middle (2315) 1A	We have a faucet on the sink inside the custodial closet that needs to be repaired.	4/10/14	Custodial Closet		Plumbing
Hamilton Middle (2315) 1A	We have a toilet in the 3rd that is leaking from the back pipe that needs to be repaired located on the end by the elevator.	4/14/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet that needs to be snaked out located in the boys restroom on the 2nd floor by the elevator.	4/14/14	Restroom (Boys)		Plumbing

Hamilton Middle (2315) 1A	WATER FOUNTAIN 2ND FLR MAIN OFC END-HAS BEEN PULLED FROM WALL & WATER LEAKING OUT, CAN'T CONTAIN OR CUT OFF-PLANT MGR ROGERS 416-7832 KLR	4/15/14			Plumbing
Hamilton Middle (2315) 1A	We have a toilet that is coming aloose from the floor that needs to be repaired located on the 2nd floor.(mens teacher restroom)	4/16/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet that needs to be repaired that is coming aloose from the floor located in the alternative wing.	4/24/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet that needs to be snaked out located on the 1st floor by the teacher's lounge.	4/25/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet in the girl's restroom located in the gym that is stopped up and needs to be snaked out.	5/1/14	Restroom (Girls)	gym	Plumbing
Hamilton Middle (2315) 1A	We have a toilet in the boys restroom by the elevator 1st stall that is stopped up and needs to be snaked out.	5/1/14	Restroom (Boys)		Plumbing
Hamilton Middle (2315) 1A	We have a toilet in the girl's restroom that needs to be snaked out located on the 1st floor and 1st stall.	5/9/14	Restroom (Girls)		Plumbing
Hamilton Middle (2315) 1A	We have a floor drain that has broken from the floor that needs to be replaced located by the main entrance.	6/16/14	Restroom (Girls)	1st floor	Plumbing

Hamilton Middle (2315) 1A	UNIT IS LEAKING WATER IN RM-4 plant mgr-ROGERS/416.7838	6/19/14			Plumbing
---------------------------	--	---------	--	--	----------

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Hamilton Sr (2317) 1A	2	1	77	141	61	5	89	3	4	383
Grand Total	2	1	77	141	61	5	89	3	4	383

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Hamilton Sr (2317) 1A	Remove ACM from pipe so it can be repaired. It is located by AHU # 13. Approx. 15 to 20 feet. Support WO 420743 Frank Owens. Thank you	3/10/14			Asbestos
Hamilton Sr (2317) 1A	Please refinish gym floor	10/2/13			Asbestos
Hamilton Sr (2317) 1A	Bad network port. (Request Network Cabling Maintenance Repair).	7/24/13	Classroom	230	Cabling
Hamilton Sr (2317) 1A	We have some floor tiles that needs to be replaced located on the hall behind the gym in front of the boys restroom.	4/8/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some cole base that needs to be replaced in the cafe.	4/10/14	Cafeteria		Carpentry
Hamilton Sr (2317) 1A	We have some cole base that needs to be replaced on the hallway outside the cafe.	4/10/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some cole base that needs to be replaced located in the gym lobby by boys locker room.	4/10/14	Gym		Carpentry
Hamilton Sr (2317) 1A	The classroom door needs to be adjusted. The teacher is having problems with her door staying completely close when she locks it.	4/14/14	Classroom	129	Carpentry

Hamilton Sr (2317) 1A	The classroom door needs to be adjusted. The door won't stay shut after the teacher locks and closes it.	4/16/14	Classroom	227	Carpentry
Hamilton Sr (2317) 1A	The door handle is broken and needs to be repaired.	4/16/14	Classroom	308	Carpentry
Hamilton Sr (2317) 1A	The cafe door across from the elevator panic bar is broken and needs to be repaired.	4/21/14	Cafeteria		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located in front of the girls locker room.	6/18/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a panic bar that needs to be repaired located on the 3rd floor stairwell D.	6/18/14	Stairway		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located from room 129 to 135	5/7/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	Procure and cut lexan for recessed lights (9) each to support Keith.	5/13/14			Carpentry
Hamilton Sr (2317) 1A	We have a panic bar that needs to be repaired located by main entrance front door.	3/11/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a metal piece in the floor that needs to be replaced that is used to hold down the volleyball net before the game next week.	8/23/13	Gym		Carpentry

Hamilton Sr (2317) 1A	The door on the room needs to be adjusted. The door will not close properly to lock.	3/27/14	Administration Area	109	Carpentry
Hamilton Sr (2317) 1A	per mr rogers 416-7838 outside lower gym entrance door has been kicked and panic bar now broken and can't secure	3/27/14			Carpentry
Hamilton Sr (2317) 1A	We have a handle that is broken and needs to be repaired located in room 131.	2/26/14	Classroom	131	Carpentry
Hamilton Sr (2317) 1A	We have a couple of double doors that needs to be repaired located across from room 134 that leads into the auditorium. The doors won't lock to keep students out.	2/26/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located in the hallway by rooms 131 to 135.	3/4/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a door closure that needs to be replaced located on the 2nd floor in front 212.	1/8/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a panic bar that needs to be replaced on the door located in stairwell A on the 2nd floor in front of room 212.	1/8/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some hinges that needs to be replaced on the door on staiwell D on the 3rd floor.	1/8/14	Stairway		Carpentry
Hamilton Sr (2317) 1A	We have a lock that needs to be replaced on the 1st floor room 111.The lock is broken.	1/8/14	Classroom		Carpentry

Hamilton Sr (2317) 1A	We have some floor tiles that needs to be replaced where the leak was inside the ROTC shooting range.We also, have some tiles that needs replacing outside the door of the classroom. (room 116)	1/17/14	Classroom	116	Carpentry
Hamilton Sr (2317) 1A	We have a panic bar that get jammed located in the area where the ticket booth is located that needs to be repaired.	1/21/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a door on the hallway that needs to be adjusted located on the blue hallway first floor. Having problems opening and closing the door.	1/27/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	The door handle is broken and needs to be repaired. The plate and the handle has come aloose.	1/29/14	Classroom	235	Carpentry
Hamilton Sr (2317) 1A	We have a big picture that needs to be hung outside the gym area.	1/29/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have 2 doors on the 3rd floor landing that needs to be adjusted due to not properly opening and closing.	1/30/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located in the gym lobby area by the boys locker room.	1/30/14	Gym		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located on the hallway in front of the cafe.	1/30/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located on the blue hallway behind the cafe.	1/30/14	Hallway/Corridor		Carpentry

Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located in the main lobby by the history room.	1/30/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a large piece of the locker that is broken and needs the wood piece replaced located on the R.O.T.C. hallway by room 112.	2/3/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	The door handle is broken and needs to be repaired.	2/3/14	Classroom	217	Carpentry
Hamilton Sr (2317) 1A	We have the door hinges that needs to be replace on classroom door due to it dragging.	2/5/14	Classroom	228	Carpentry
Hamilton Sr (2317) 1A	We have a door that needs to be repaired located on the hallway entering the gym across from the trophy case.	2/14/14	Gym		Carpentry
Hamilton Sr (2317) 1A	We have a panic bar that is broken and needs to be repaired located on the hallway by trophy case.	3/28/14	Gym		Carpentry
Hamilton Sr (2317) 1A	We need the ceiling tiles and grids replaced on the R.O.T.C. wing of hallway from rooms 124 to 112 due to flood over the weekend.	6/10/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism located in front of rooms 126 to 128.	5/7/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a huge picture to be put on the wall outside the gym besides the other pictures. It will also need a lex sand cover to keep from being damaged.	1/27/14	Hallway/Corridor		Carpentry

Hamilton Sr (2317) 1A	We have a door closure that is broken and needs to be replaced located on gym door entering from the hallway.	8/28/13	Gym		Carpentry
Hamilton Sr (2317) 1A	We have some grids and ceiling tiles that needs replacing due to vandalism located from room 128 to double doors in front of the cafe.	7/12/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some grids and ceiling tiles that needs replacing due to vandalism located on the hall of stairwell B and stairwell A that needs replacing.	7/12/13	Stairway		Carpentry
Hamilton Sr (2317) 1A	2-GYM DOORS, CANT SECURE. SBE-RODGERS/416-7838	7/16/13			Carpentry
Hamilton Sr (2317) 1A	We have lockers throughout the third floor that needs to be repaired that are broken and damaged.	7/16/13	3rd Floor		Carpentry
Hamilton Sr (2317) 1A	Repair outside double doors.	7/16/13	Gym		Carpentry
Hamilton Sr (2317) 1A	We have hardware on the gym door that needs to be replaced.	7/16/13	Gym		Carpentry
Hamilton Sr (2317) 1A	We have hardware that needs repairing on the double doors by the ticket booth.	7/16/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a door on the 3rd floor balcony area that needs to be repaired. Hardware needs repairing.	7/24/13	Auditorium		Carpentry

Hamilton Sr (2317) 1A	GYM DOOR WILL NOT CLOSE AND THE BLDG CANNOT BE SECURED. SBE ROGERS 416-7838	7/26/13			Carpentry
Hamilton Sr (2317) 1A	We have some ceiling and grids that needs to be replaced due to vandalism located in stairwell A landing.	8/2/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs replacing due to vandalism located in stairwell B landing.	8/2/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a stall door that needs to be replaced on the 2nd stall girl's restroom by the gym.	8/7/13	Restroom (Girls)		Carpentry
Hamilton Sr (2317) 1A	We have a 3 to 4 inch crack in the floor with a 2 to 3 inch drop that needs to be repaired located in the boys restroom behind the main office.	8/7/13	Restroom (Boys)		Carpentry
Hamilton Sr (2317) 1A	We have some tiles that are broken and have come up that needs replacing located in the boys restroom inside the locker room.	8/7/13	Restroom (Boys)		Carpentry
Hamilton Sr (2317) 1A	We have a hole in the ceiling that needs to be repaired located in the boys restroom behind the gym.	8/7/13	Restroom (Boys)		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs to be replaced due to vandalism.	8/7/13	Classroom	rifle range (116)	Carpentry
Hamilton Sr (2317) 1A	We have ceiling tiles and grids that needs to be replaced throughout the 3rd floor hallway due to vandalism.	9/13/13	Hallway/Corridor		Carpentry

Hamilton Sr (2317) 1A	We have ceiling tiles and grids that needs to be replaced located in front of classroom 203 and 204 due to vandalism.	9/17/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	front door main building the center bar is broken and can't secure per Mr. Rogers 416-7838	9/19/13			Carpentry
Hamilton Sr (2317) 1A	DOOR GLASS TO GYM ENTRANCE DOOR-BROKEN OUT-WON'T BE ABLE TO SECURE-PLANT MGR ROGERS 416-7832 KLR	9/30/13			Carpentry
Hamilton Sr (2317) 1A	front door center piece is broken and can't secure building per Mr. Rogers 416-7838	10/4/13			Carpentry
Hamilton Sr (2317) 1A	The hardware needs replacing on the stairweel D door located on the 1st floor across from the plant manager's office.	10/16/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	The henges on the consession door needs to be repaired. The door is hard to open and close.	10/17/13	Concession Stand		Carpentry
Hamilton Sr (2317) 1A	The request to hang a banner on the wall by the first basketball goal as you walk in the gym. A lift will be needed.	10/22/13	Gym		Carpentry
Hamilton Sr (2317) 1A	We have a section of the bleachers on the wood side that needs to be repaired. W e have the city wide jamboree 11/14/2013.	11/13/13	Gym		Carpentry
Hamilton Sr (2317) 1A	UNBOLT FRAMEWORK FOR MACHINES TO BE MOVED. PRINT SHOP, WOOD SHOP AUTO SHOP SEE ROBERT BRADEN THURSDAY AT 8:30.	11/13/13			Carpentry

Hamilton Sr (2317) 1A	We have a panic bar on the gym door that needs repairing located on the door as you walk in from the hallway.	11/15/13	Gym		Carpentry
Hamilton Sr (2317) 1A	We have a center bar that used to keep the door close that needs repairing located in the gym on the right side of the bleachers.	11/15/13	Gym		Carpentry
Hamilton Sr (2317) 1A	We have some ceiling tiles and grids that needs replacing due to vandalism located on the 2nd floor between room 211 and the teacher's lounge.	11/20/13	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	BACK ENTRY DOOR BY COMMUNITY CTR, CANT SECURE. PLANT MGR-ROGERS/416.7838	12/13/13			Carpentry
Hamilton Sr (2317) 1A	We need the center bar door closure reinstalled on the 2nd floor across from the concession stand.	1/7/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have some floor tiles that needs to be replaced located in front of room 116.	1/7/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a center bar reinstall on the R.O.T.C. hallway.	1/8/14	Hallway/Corridor		Carpentry
Hamilton Sr (2317) 1A	We have a panic that needs to be repaired on the door as you walk in from the hallway.	1/8/14	Gym		Carpentry
Hamilton Sr (2317) 1A	Boys locker room door needs the hinges replaced.The door will not close properly.	1/8/14	Gym		Carpentry

Hamilton Sr (2317) 1A	UNIT NOT COMING ON IN CAFE PLANT MGR-ROGERS/416.7832	4/4/14			Electrical
Hamilton Sr (2317) 1A	COOLING TOWER#2 NOT COMING ON PLANT MGR-ROGERS/416.7838	4/4/14			Electrical
Hamilton Sr (2317) 1A	We have a broken receptable located inside the classroom that needs to be replaced.	4/8/14	Classroom	217	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be replaced located in front of classroom 212.	4/10/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad receptable located by the teacher's desk.	4/10/14	Classroom	209	Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts that needs to be replaced.	4/10/14	Classroom	226	Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts that needs to be replaced.	4/10/14	Classroom	224	Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in light in front of room 225 that needs to be replaced.	4/11/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	The lights at the main entrance and on the west side of the building are out and needs to be repaired for security purposes.	4/22/14	Grounds		Electrical

Hamilton Sr (2317) 1A	The light are out and needs to be repaired located behind the cafe and the walkway by the community center on the school side for security purposes.	4/22/14	Grounds		Electrical
Hamilton Sr (2317) 1A	The lights are out and needs to be repaired located at both gym entrances for security purposes.	4/22/14	Grounds		Electrical
Hamilton Sr (2317) 1A	We have 5 bad ballasts out inside the room that needs to be replaced.	9/12/13	Classroom		Electrical
Hamilton Sr (2317) 1A	per mr rogers 416-7838 AHU #14 is not coming on at all and it controls the gym and surrounding areas	5/7/14			Electrical
Hamilton Sr (2317) 1A	Replace 3 bad ballasts in custodial break room	6/16/14	Custodial		Electrical
Hamilton Sr (2317) 1A	Replace 2 bad ballasts in rack room by room 224	6/16/14	Data Closet		Electrical
Hamilton Sr (2317) 1A	Replace 2 bad ball in classroom 209, and 1 ballast in storage room	6/16/14	2nd Floor	209	Electrical
Hamilton Sr (2317) 1A	Please replace 2 computer receptacles, receptacles making chirping sound	6/16/14	2nd Floor	215	Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in light located in the history room by the main office that needs to be replaced.	6/17/14	2nd Floor		Electrical

Hamilton Sr (2317) 1A	We have a bad ballast in light located in front of the auditorium by the main office.	6/17/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad computer receptable that is chirping and needs to be replaced.	6/17/14	Classroom	101	Electrical
Hamilton Sr (2317) 1A	UNIT NOT COMING ON IN GYM & HALLWAYS PLANT MGR-ROGERS/416.7838	6/17/14			Electrical
Hamilton Sr (2317) 1A	We have a exit sign that is coming aloose from the ceiling that needs to be repaired.	6/17/14	Library		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in light located in front of the girl's locker room that needs to be replaced.	6/18/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	UNIT NOT COMING ON IN RAF IN PINHOUSE, plant mgr-ROGERS/416.7838	6/19/14			Electrical
Hamilton Sr (2317) 1A	UNIT NOT COMING ON RAF IN PINHOUSE, plant mgr-ROGERS/416.7838	6/19/14			Electrical
Hamilton Sr (2317) 1A	Need 3 cases bulbs	6/20/14			Electrical
Hamilton Sr (2317) 1A	Check motor on AHU 20	6/24/14			Electrical

Hamilton Sr (2317) 1A	We have a couple of bad ballasts that needs to be replaced located in room 210.	5/14/14	Classroom	210	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be repaired located in room 112.	5/14/14	Classroom	112	Electrical
Hamilton Sr (2317) 1A	We have 11 lights out that needs to be replaced throughout the classroom.	5/14/14	Classroom	210	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts out in lights that needs to be repaired located in the security room.	5/15/14	Administration Area	124	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts in lights that needs to be repaired.	5/19/14	Administration Area	teacher's lounge	Electrical
Hamilton Sr (2317) 1A	We have 4 badballasts that needs to be repaired located inside the boys locker room.	5/23/14	Gym		Electrical
Hamilton Sr (2317) 1A	We have 5 bad ballasts out in lights located in the culinary arts kitchen that needs to be replaced.	5/29/14	Classroom	132	Electrical
Hamilton Sr (2317) 1A	The lights are out in the kitchen area under the vent hood in the culinary arts room.	5/29/14	Classroom	132	Electrical
Hamilton Sr (2317) 1A	Replace 3 ballast in room. Lamps have been changed	6/2/14	1st Floor	112	Electrical

Hamilton Sr (2317) 1A	Replace 2 ballasts in art room, RM135	6/3/14			Electrical
Hamilton Sr (2317) 1A	Replace 2 ballasts in hall outside room 132 / 133	6/3/14	1st Floor		Electrical
Hamilton Sr (2317) 1A	Replace 4 ballasts in room 128	6/3/14	1st Floor	128	Electrical
Hamilton Sr (2317) 1A	AHU-14 GYM AREA-NOT COMING ON-PLANT MGR ROGERS 416-7838 KLR	6/6/14			Electrical
Hamilton Sr (2317) 1A	Replace 2 ballasts in work room in library	6/6/14	Library		Electrical
Hamilton Sr (2317) 1A	replce ballast in fixture in chiller room	6/6/14	Mechanical Room		Electrical
Hamilton Sr (2317) 1A	replace ballast in 2 fixtures in kitchen	6/6/14	Kitchen		Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be replaced inside the classroom.	9/11/13	Classroom		Electrical
Hamilton Sr (2317) 1A	We have a bell that has a shortage and making noise that needs to be repaired located across from room 112.	9/11/13	Hallway/Corridor		Electrical

Hamilton Sr (2317) 1A	We need light fixtures repaired in the shooting range.(not standard light bulbs)	9/11/13	Classroom	118	Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in the boys restroom that needs to be replaced located across from room 108.	9/12/13	Restroom (Boys)		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in the light that needs to be replaced in girl's restroom located across room 108.	9/12/13	Restroom (Girls)		Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts that needs to be replaced inside the gym going to boys locker room.	9/12/13	Gym		Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts out in light in front of room 124 that needs to be replaced.	9/12/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	Please replace 3 ballasts in lobby by SBE office	3/18/14	1st Floor	Lobby	Electrical
Hamilton Sr (2317) 1A	Please replace 2 ballast in hallway by JROTC	3/18/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	Please replace 2 ballasts in stairwell b 2nd floor landing	3/18/14	Stairway	B	Electrical
Hamilton Sr (2317) 1A	AHU-14 GYM AREA AND SURROUNDING AREA-NOT COMING ON-PLANT MGR ROGERS 416-7838	3/20/14			Electrical

Hamilton Sr (2317) 1A	Power Outage.	3/28/14			Electrical
Hamilton Sr (2317) 1A	We need the clock inside the main office set for day light saving time.	3/6/14	Administration Area		Electrical
Hamilton Sr (2317) 1A	We have 2 lights out down in the parking area where the bus is located.	1/9/14	Grounds		Electrical
Hamilton Sr (2317) 1A	We have lights out at the main entrance of the building that needs replacing.	1/9/14	Grounds		Electrical
Hamilton Sr (2317) 1A	HEAT ENTIRE GYM AREA-NOT COMING ON-PLANT MGR ROGERS 416-7832 KLR	1/9/14			Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in the asst. principal office that needs to be replaced.	1/13/14	Administration Area		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in light located in the restroom in the kitchen area that needs to be replaced.	1/22/14	Kitchen		Electrical
Hamilton Sr (2317) 1A	We have 5 lights that went out in the gym that needs to be replaced.	1/29/14	Gym		Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be replaced located at the bottom of stairwell A.	1/30/14	Stairway		Electrical

Hamilton Sr (2317) 1A	We have a bad ballast in light that needs to be replaced located in between rooms 111 and 112.	1/30/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad ground fault receptable that needs to be replaced.	2/3/14	Classroom	212	Electrical
Hamilton Sr (2317) 1A	The clock inside the main office needs to be reset. The bells are off due to power outage.	2/4/14	Administration Area		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in light inside the main office over the secretary desk that needs to be replaced.	2/17/14	Administration Area	main office	Electrical
Hamilton Sr (2317) 1A	AHU-23 CAFE AREA & AHU-14 GYM AREA-BOTH NOT COMING ON-PLANT MGR ROGERS 416-7838 KLR	2/18/14			Electrical
Hamilton Sr (2317) 1A	AHU-13 GYM AREA & SURROUNDING HALLWAY-NOT COMING ON-PLANT MGR ROGERS 416-7838 KLR	6/30/14			Electrical
Hamilton Sr (2317) 1A	Please replace 2 ballast in hallway by room 216	4/3/14	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	Please replace 3 bad ballasts in room 101	4/3/14	Classroom	101	Electrical
Hamilton Sr (2317) 1A	Please replace ballast in 2 fixtures in bookroom by room 101	4/3/14	1st Floor	Bookroom	Electrical

Hamilton Sr (2317) 1A	Replace 3 bad ballasts in boys locker room in gym	4/3/14	Restroom (Boys)	Lockerroom	Electrical
Hamilton Sr (2317) 1A	We need about 6 cases of light to start replacing bulbs throughout building. rapid start 25 (46807).	7/29/13			Electrical
Hamilton Sr (2317) 1A	We need 2 cases of 8 ft. light bulbs to replace the blown bulbs in the R.O.T.C. shooting range. (classroom 118)	9/11/13	Classroom		Electrical
Hamilton Sr (2317) 1A	We need 3 cases of classroom light bulbs (4ft.) to install through out the building.	3/6/14			Electrical
Hamilton Sr (2317) 1A	We need 3 cases of light bulbs to replace all blown bulbs inside the cafe and the band room.	9/12/13	Cafeteria		Electrical
Hamilton Sr (2317) 1A	We need 3 cases of bulbs to replace the all the blown bulbs inside the library and the weight room.	9/12/13	Library		Electrical
Hamilton Sr (2317) 1A	We need 3 cases of light bulbs to install throughout the building.	11/4/13			Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts in the lights that needs to be replaced in front of classroom 208.	8/27/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts in the lights inside the classroom that needs to be replaced.	8/27/13	Classroom	112	Electrical

Hamilton Sr (2317) 1A	We have 3 bad ballasts in the girls restroom located behind the gym that needs to be replaced.	8/27/13	Restroom (Girls)		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in the light located in the main entrance that needs to be replaced.	8/27/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	PLEASE PROVIDE 3 CASE OF ITEM# 46807 FOR DIFFERENT LOCATIONS We have a couple of bad ballasts in the lights in the hallway located in front of room 112 that needs to be replaced.	8/27/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a couple of bad ballasts in stairwell C going down into room 101 that needs to be replaced.	8/28/13	Stairway	C	Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts in the hallway in front of classroom 318 that needs to be replaced.	8/28/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in the hallway located in front of room 306 that needs to be replaced.	8/28/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have 5 bad ballasts out that needs to be replaced located in the boys locker room and the restroom located in the boys locker room.	8/28/13	Gym		Electrical
Hamilton Sr (2317) 1A	We have 5 blown bulbs that needs to be replaced located inside the gym over the floor.	8/28/13	Gym		Electrical
Hamilton Sr (2317) 1A	We need 3 cases of light bulbs to start replacing lamps throughout the building.	8/28/13			Electrical

Hamilton Sr (2317) 1A	We have a bad ballast in light in front of room 132 that needs to be replaced.	8/29/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	Boys locker room repair lights.	9/3/13	Gym		Electrical
Hamilton Sr (2317) 1A	UNIT IS MAKING NOISE IN RM-218. PLANT MGR-RODGERS/416.7838	9/6/13			Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in light in front of room 228 that needs to be repaired.	9/9/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts in the lights located in front of room 226 that needs to be repaired.	9/9/13			Electrical
Hamilton Sr (2317) 1A	We have 2 bad ballasts in lights located in front of room 208 that needs to be replaced.	9/9/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in the light in the main entrance located in front of room 201 that needs to be replaced.	9/9/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in light in front of room 210 that needs to be replaced.	9/10/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	STEAM BOILER KITCHEN-NOT COMING ON-WILL NOT BE ABLE TO PREPARE LUNCH PER SBE-PLANT MGR 416-7838 KLR	9/11/13			Electrical

Hamilton Sr (2317) 1A	We have 2 bad ballasts that needs to be replaced inside the cafe.	9/11/13	Cafeteria		Electrical
Hamilton Sr (2317) 1A	We have some electrical wires and conduit coming out of the floor that needs to be removed.	7/15/13	Cafeteria		Electrical
Hamilton Sr (2317) 1A	Replace 3 balasts in room 102 (KC)	7/15/13	1st Floor	102	Electrical
Hamilton Sr (2317) 1A	Repair 2 broken receptacles in room 121	7/15/13	1st Floor	121	Electrical
Hamilton Sr (2317) 1A	Rplace 2 balasts in room 207, and repair broken receptacle on north wall.	7/15/13	2nd Floor	207	Electrical
Hamilton Sr (2317) 1A	Air Handler #7 ID#129-072, NOT COMING ON per Mr. Rogers, Plant Mgr. at 901.416.7838.	7/17/13			Electrical
Hamilton Sr (2317) 1A	RAF#7 ID#129033 belt is broken #14 ID# 129025 motor burning RU#60 rm 216 ID# 129354 damper not closing making whining noise per Mr. Rogers 416-7838	7/30/13			Electrical
Hamilton Sr (2317) 1A	We need the clock in the main office set for the school bells for the 2013-2014 school year.	7/31/13	Administration Area	main office	Electrical
Hamilton Sr (2317) 1A	We need a electrical cover put over expose wires in the locker room wall switch.	7/31/13	Gym	boys locker room	Electrical

Hamilton Sr (2317) 1A	We have a bad ballast in the librarian's office that needs to be repaired.	8/2/13	Library		Electrical
Hamilton Sr (2317) 1A	The thermostat has been torn off the wall and needs to be replaced.	8/7/13	Classroom	rifle range (116)	Electrical
Hamilton Sr (2317) 1A	We need a electrical cover put over receptable in restroom located by the gym.	8/8/13	Restroom (Boys)	behind gym	Electrical
Hamilton Sr (2317) 1A	We need the light pole bulb changed on the admin. parking lot.	9/12/13	Grounds		Electrical
Hamilton Sr (2317) 1A	We have 4 bad ballasts out in the room that needs to be replaced.	9/13/13	Classroom		Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts out in front of room 334 that needs to be replaced.	9/13/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in front of the boys restroom on the 3rd floor that needs to be replaced.	9/13/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have 4 bad ballasts out in the lights inside the classroom that needs to be replaced.	9/17/13	Classroom	216	Electrical
Hamilton Sr (2317) 1A	We have 4 bad ballasts in lights inside classroom that needs to be replaced.	9/19/13	Classroom	126	Electrical

Hamilton Sr (2317) 1A	We have 4 bad ballasts in lights inside classroom that needs to be replaced.	9/19/13	Classroom	127	Electrical
Hamilton Sr (2317) 1A	We have 5 bad ballasts that needs to be replaced inside the classroom.	9/19/13	Classroom	129	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be replaced inside classroom.	9/19/13	Classroom	132	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be replaced inside the classroom.	9/19/13	Classroom	131	Electrical
Hamilton Sr (2317) 1A	We have 7 bad ballasts in both rooms that needs to be replaced.	9/19/13	Classroom	133 and 134	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts that needs to be replaced inside classroom.	9/19/13	Classroom	135	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts out in lights located by the elevator on the 1st floor that needs to be replaced.	9/19/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in light located at the bottom of stairwell B on the 1st floor by room 135 that needs to be replaced.	9/19/13	Stairway		Electrical
Hamilton Sr (2317) 1A	We have 1 bad ballasts in lights in each area.	9/19/13	Classroom	133A and 133B	Electrical

Hamilton Sr (2317) 1A	We have 4 lights out on the front of the building that needs to be replaced. The lights are for security purposes.	9/25/13	Grounds		Electrical
Hamilton Sr (2317) 1A	We need a timer put on the lights in the gym to keep from burning lamps and ballasts.	9/30/13	Gym		Electrical
Hamilton Sr (2317) 1A	The outlet that the score board plug into has a shortage and needs to be repaired. It won't be able to be repaired until 10/28/2013 because the floor is being refinished today.	10/22/13	Gym		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast in light in hallway located in front of room 211 that needs replacing.	10/24/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have a 2 lights out at the main entrance that needs to be replaced.	10/24/13	Grounds		Electrical
Hamilton Sr (2317) 1A	We have a bad ballast out in light located in between rooms 111 and 112 that needs to be replaced.	10/24/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have 4 bad ballasts out in lights that needs to be replaced.	10/31/13	Classroom	226	Electrical
Hamilton Sr (2317) 1A	We have 3 bad ballasts out in lights that needs to be replaced located in front of stairwell B.	10/31/13	Hallway/Corridor		Electrical
Hamilton Sr (2317) 1A	We have 3 bad receptables that are bad and needs to be replaced inside classroom.	10/31/13	Classroom	217	Electrical

Hamilton Sr (2317) 1A	We have 4 bad ballasts in lights that needs repairing.	11/1/13	Classroom	224	Electrical
Hamilton Sr (2317) 1A	We have a bad receptable ground fault that needs to be replaced.	11/6/13	Classroom	212	Electrical
Hamilton Sr (2317) 1A	DISCONNECT ELECTRIC FOR MACHINES TO BE MOVED. PRINT SHOP, WOOD SHOP AUTO SHOP SEE ROBERT BRADEN THURSDAY AT 8:30.	11/13/13			Electrical
Hamilton Sr (2317) 1A	The motor on the the basketball goal located on the left side of the gym 2nd goal when you walk in is not working.The goal will not raise all the up.	12/16/13	Gym		Electrical
Hamilton Sr (2317) 1A	Power outage in different areas (Band Room, ROTC Room, and Stairwells) per Mr. Murdock, Plant Mgr. 690.6367	1/6/14			Electrical
Hamilton Sr (2317) 1A	Power outage in ENTIRE CAFETERIA AREA per Mr. Murdock, Plant Mgr. 690.6367.	1/6/14			Electrical
Hamilton Sr (2317) 1A	Provide purge pump for chiller. To be installed by contract at later date.	6/24/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	CHANGE OIL AND FILTERS ON CHILLER	3/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Install new purge pump on York chiller	7/10/13			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	Check out two York chillers for season	2/21/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Provide and install controller for chemical feed.	8/20/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	REPLACE 2 LEAKING VLAVES ON BOTH YORK CHILLERS.	3/10/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Purge air from chiller #2. Change oil and filter.York ChillerPrice includes parts.	4/3/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - HAMILTON HIGH LVL 2 WATER TREATMENT Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	purchase new coil for AHU #13	4/7/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - HAMILTON HIGH LVL 2 WATER TREATMENT Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	CHILLER#2 IS LEAKING OIL plant mgr-ROGERS/416.7838	6/19/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Filter-Hamilton High - Refer to PM schedule details.	5/17/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	6/6/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	provide plumber nitrogen bottle to blow out coil --- assist if needed	3/12/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Yearly - Rod Chiller - Hamilton High - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	meet contractor --- chiller	3/20/14			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	AHU #13 help plumber fix busted coil	3/21/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	AHU #13 --- clean coil and vacuum return duct	3/24/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	AHU # 13 fixing busted coil	3/26/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	remove coil from AHU #13	3/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	asst. contractor	2/26/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - HAMILTON HIGH LVL 2 WATER TREATMENT Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	Monthly - Hamilton SR Air Compressor #129065 - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Hamilton SR Air Compressor #129313 - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Oil Lube & Belt-Hamilton High - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	AIR HANDLER #13 is LEAKING in the above the BOYS LOCKER ROOM per Mr. Rodgers, Plant Mgr. 416.7838	3/6/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	HEAT RM 226-NOT HEATING-PLANT MGR ROGERS 416-7832 KLR	1/9/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Filter-Hamilton High - Refer to PM schedule details.	1/18/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	HEAT LIBRARY & ASST PRIN'S OFC-BOTH ARE OVERHEATING, TEMP IS 90-PLANT MGR ROGERS 416-7832 KLR	1/29/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	Monthly - HAMILTON HIGH LVL 2 WATER TREATMENT Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Yearly - Water-Cool Chiller Filter-Hamilton High - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	CHILLER#2 NOT COMING ON & LEAKING OIL, & UNIT NOT COOLING IN ASSIST PRINC OFFICE, LIBRARY PLANT MGR-ROGERS/416.7832	2/20/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	show plumber where holes are on busted coil	3/6/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Daily - PM Schedule created on 1/7/2014 - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Yearly - Cooling Towers - Hamilton High - Refer to PM schedule details.	3/17/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Yearly - Boiler 164 - Hamilton High - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Yearly - Boiler 163 - Hamilton High - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	Yearly - Boiler 162 - Hamilton High - Refer to PM schedule details.	3/17/14			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Hamilton SR Air Compressor #129065 - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Hamilton SR Air Compressor #129313 - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Yearly - Oil Samples-Hamilton High - Refer to PM schedule details.	9/7/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	CHILLER#1 IS NOT COMING. SBE ROGERS 416-7838	7/23/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Chiller down 129113 not coming on per Mr. Rogers 416-7838	8/1/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Oil Lube & Belt-Hamilton High - Refer to PM schedule details.	8/2/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Monthly - Filter-Hamilton High - Refer to PM schedule details.	9/14/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	chiller down	10/1/13			Heating/Ventilation /Air Conditioning

Hamilton Sr (2317) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	CHILLER#2 NOT COMING ON. PLANT MGR-ROGERS/416.7838	10/22/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	boiler down	11/25/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	Air Handler Unit #20 - DRIVE IS NOT COMING ON per Mr. Rogers, Plant Mgr. 416.7838	12/16/13			Heating/Ventilation /Air Conditioning
Hamilton Sr (2317) 1A	The principal request that the furniture be painted inside his office for the new principal for the 2014-2015 school year.	4/2/14	Administration Area	principal's office	Painting
Hamilton Sr (2317) 1A	We have some graffiti on the walls through out the 1st and 2nd floor due to vandalism.	1/30/14			Painting
Hamilton Sr (2317) 1A	GRAFFITI IN B/RR-G/RR THRU OUT BLDG PLANT MGR-ROGERS/416.7838	2/6/14			Painting
Hamilton Sr (2317) 1A	GRAFFITI OUTSIDE CHILD CARE ON BRICK WALL FACING ELVIS PRESLEY BLVD-PLANT MGR ROGERS 416-7838 KLR	2/17/14			Painting
Hamilton Sr (2317) 1A	GRAFFITI ON WALLS OF FRONT OUTSIDE AREA BY PLAYGROUND PLANT MGR-ROGERS/416.7832	3/17/14			Painting

Hamilton Sr (2317) 1A	Remove pipe elbow , flange from bad coil.	4/4/14			Plumbing
Hamilton Sr (2317) 1A	We have a urinal that is stopped up and needs to be snaked out located in the boys restroom 1st floor by the cafe.	4/8/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have 3 toilets that are stopped up and needs to be snaked out located by SMS.(On the left side of the restroom the 2nd and 3rd stalls and right it's the 3rd stall.)	4/23/14	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	per mr rogers 416-7838 there is a pump in the kitchen that is leaking	5/7/14			Plumbing
Hamilton Sr (2317) 1A	We have a pipe leaking in the ceiling that needs to be repaired located in front of the chiller room.	6/18/14	Hallway/Corridor		Plumbing
Hamilton Sr (2317) 1A	We have a sink in the custodial closet on the 3rd floor that needs the hot water side handle replaced.	6/20/14	Custodial Closet		Plumbing
Hamilton Sr (2317) 1A	We have 2 urinals that are stopped up and needs to be snaked out located in the boys restroom behind the gym 1st and 2nd stalls.	5/9/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a water fountain that is leaking and needs to be repaired located inside the boys locker room.	5/12/14	Gym		Plumbing
Hamilton Sr (2317) 1A	We have a leak coming from the ceiling located in the boys restroom behind the gym.	5/12/14	Restroom (Boys)		Plumbing

Hamilton Sr (2317) 1A	We have a toilet that needs to be snaked out located on the 2nd floor by the elevator 3rd stall.	5/12/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a water fountain leaking in front of classroom 228 that needs to be repaired.	5/13/14	Hallway/Corridor		Plumbing
Hamilton Sr (2317) 1A	We have a toilet in the boys restroom across from the cafe that needs the flush valve replaced and another toilet seat located in the 1st stall.	5/19/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a pipe beside the steam kettle that needs to be repaired.	5/21/14	Kitchen		Plumbing
Hamilton Sr (2317) 1A	We have a water pump that is leaking and needs to be repaired located in the kitchen area storage closet.	5/21/14	Kitchen		Plumbing
Hamilton Sr (2317) 1A	We have a water fountain that is leaking inside the football locker room that needs to be repaired.	5/23/14	Gym		Plumbing
Hamilton Sr (2317) 1A	Install new coil in AHU 13. Support wo # 425151.	5/28/14	Mechanical Room		Plumbing
Hamilton Sr (2317) 1A	We have a pipe leaking in the boys restroom ceiling that needs to be repaired located on the hallway behind the gym.	6/4/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a water fountain inside the boys locker room on the football side that is leaking and needs to be repaired.	6/5/14	Gym		Plumbing

Hamilton Sr (2317) 1A	Repair hose bib and cut water back on.	6/9/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	Blow down drain not closing.	8/20/13			Plumbing
Hamilton Sr (2317) 1A	We have a toilet in the third stall that needs the flush valve replaced.	8/23/13	Restroom (Boys)	3rd	Plumbing
Hamilton Sr (2317) 1A	We have 2 sinks leaking that needs to be repaired. The 1st sink and the 3rd sink.	3/24/14	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	Remove coil on AHU 13, to shop.	3/28/14			Plumbing
Hamilton Sr (2317) 1A	We have a water fountain that is leaking and needs to be repaired located on the R.O.T.C. wing by room 116.	2/25/14	Hallway/Corridor		Plumbing
Hamilton Sr (2317) 1A	We have a water fountain that needs to be repaired located outside the Plant Manager's office.	2/25/14	Hallway/Corridor		Plumbing
Hamilton Sr (2317) 1A	We have a sink with a broken handle that needs to be repaired located in room 132 kitchen area.	2/26/14	Classroom	132	Plumbing
Hamilton Sr (2317) 1A	HOT WATER TANK PIPE is LEAKING inside the BOILER ROOM per Mr. Rogers, Plant Mgr. 416.7838	2/26/14			Plumbing

Hamilton Sr (2317) 1A	per mr rogers 416-7838 AHU #13 is leaking water	2/28/14			Plumbing
Hamilton Sr (2317) 1A	Check water pressure room 132	3/4/14			Plumbing
Hamilton Sr (2317) 1A	Check water pressure room 132	3/4/14			Plumbing
Hamilton Sr (2317) 1A	repair pipe leak near AHU #13.	3/6/14			Plumbing
Hamilton Sr (2317) 1A	We have a broken pipe that needs to be repaired in classroom located by the teacher's desk.	1/9/14	Classroom	219	Plumbing
Hamilton Sr (2317) 1A	Test and report on backflow prevention devices.	1/9/14			Plumbing
Hamilton Sr (2317) 1A	We have a urinal in the boys locker room restroom that is stopped up and needs snaking out.	1/13/14	Gym	boys locker room	Plumbing
Hamilton Sr (2317) 1A	We have a toilet seat that needs to be replaced inside the restroom of the new principal's office loacted where the SMS office .	1/17/14	Administration Area	main office	Plumbing
Hamilton Sr (2317) 1A	We have a toilet seat that needs to be replaced in the boys locker room restroom 2nd stall.	1/17/14	Gym		Plumbing

Hamilton Sr (2317) 1A	Test and report on backflow prevention devices.	1/21/14			Plumbing
Hamilton Sr (2317) 1A	We have a leak in the 4th stall. The flush valve is bad and needs replacing located in the girl's restroom in front of the cafe.	1/24/14	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	The last stall in the boy's restroom on the 3rd floor has a toilet that needs tighten up. The entire toilet shifts from side to side causing leaking.	1/24/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	The toilet in the 1st stall is leaking located on the hall behind the gym.	1/24/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet seat broken that needs to be replaced located in the boys restroom by the cafe in the last stall.(A.D.A. STALL)	1/27/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet leaking from the bottom and turn off valve that needs to be repaired located in the plant manager's office.	2/5/14	Administration Area	Plant Manager's Office	Plumbing
Hamilton Sr (2317) 1A	We have a sink that continues to run that needs to be repaired located in the girl's restroom on the 3rd floor.	2/6/14	Restroom (Girls)	3rd floor	Plumbing
Hamilton Sr (2317) 1A	We have a sink in the girl's restroom 3rd sink that needs to be repaired.	2/21/14	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	We have a sink that is leaking from the bottom that is located in the boys restroom behind the gym 3rd stall.	3/31/14	Restroom (Boys)		Plumbing

Hamilton Sr (2317) 1A	We have a water fountain that continues to run and needs to be repaired located across from room 228.	3/31/14	Hallway/Corridor		Plumbing
Hamilton Sr (2317) 1A	We have a sink in classroom that is stopped up and needs to be unclogged.	4/1/14	Classroom	201	Plumbing
Hamilton Sr (2317) 1A	We have a toilet leaking in the boys restroom on the 3rd floor 3rd stall on the right side that needs to be repaired.	4/2/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet that needs to be snake out located in the boys restroom behind the gym. (1st stall)	3/6/14	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	FLOOR DRAIN KITCHEN-BACKING UP-THEY ARE TRYING TO PREPARE LUNCH STANDING IN WATER PER SBE-PLANT MGR ROGERS 416-7838 KLR	8/29/13			Plumbing
Hamilton Sr (2317) 1A	The boys restroom inside the gym locker room needs a flush vavle put in the first toilet in the first stall.	9/4/13	Gym		Plumbing
Hamilton Sr (2317) 1A	The 2nd stall in the restroom needs to be snake out located behind the main off.I tried snaking it but it continues to bag up.	9/9/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a sink that needs the faucet replaced located in the boys restroom behind the gym.	9/11/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a sink in the closet that needs unclogging located on the second floor by the boys restroom.	7/17/13	Custodial Closet		Plumbing

Hamilton Sr (2317) 1A	Air Handler #25 ID#129-050 LEAKING per Mr. Rogers, Plant Mgr. at 901.416.7838! Leaking very bad!	7/17/13			Plumbing
Hamilton Sr (2317) 1A	We have a sink in the custodial closet that needs to be repaired. It continues to run hot water.	7/30/13	Custodial Closet		Plumbing
Hamilton Sr (2317) 1A	We have a sink in the girl's restroom by the gym that needs to be repaired.	8/2/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	We have a water fountain that needs the knob replaced on it located by the Plant Manager's office. (I.D.#129- 315)	8/6/13	Hallway/Corridor		Plumbing
Hamilton Sr (2317) 1A	Repair sink faucet.	8/6/13	Library		Plumbing
Hamilton Sr (2317) 1A	The girls restroom on the 3rd floor has a toilet in the 5th stall that needs to be repaired. The toilet will not flush.	8/6/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	FLOOR DRAINS BACKING UP IN KITCHEN-SBE ROGERS 416-7838 KLR	8/7/13			Plumbing
Hamilton Sr (2317) 1A	We have a sink leaking in the boys restroom on the third floor that needs to be repaired.	8/9/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet in the first stall that is stopped up. I tried snaking it but it is still backing up.	8/9/13	Restroom (Boys)		Plumbing

Hamilton Sr (2317) 1A	We have a toilet in the last stall of the girls restroom that needs to be snake out. I tried snaking it but it continues to bag up.	8/15/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	CONDENSING WATER PUMP-5-LEAKING-PLANT MGR ROGERS 416-7838 KLR	8/19/13			Plumbing
Hamilton Sr (2317) 1A	The toilet seat is broken and needs to be replaced in the teacher's lounge on the 2nd floor.	9/13/13	Administration Area		Plumbing
Hamilton Sr (2317) 1A	We have a toilet that needs to be snake out located behind the gym. I tried snaking it but it continues to bag up.	9/17/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet that needs to be snaked out located in the girl's restroom located behind the main office first stall to the left when entering. I tried to snake but it continues to bag up.	9/17/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	We have a sink that needs the faucet replaced located in the girl's restroom behind the main office.	9/17/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet in the girl's restroom 3rd stall that needs to be snaked out located behind the gym. I tried to snake it but it continues to bag up.	9/18/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	Floor Drain in kitchen are backing up per Mr. Rogers, Plant Mgr. 416.7838	9/24/13			Plumbing
Hamilton Sr (2317) 1A	Science lab room 228 repair/replace valve making noise.	9/24/13			Plumbing

Hamilton Sr (2317) 1A	We have a faucet on the sink in the boys restroom that needs to be replaced located behind the main office.	9/26/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	floor drains backing up in kitchen per Mr. Rogers 416-7838	10/14/13			Plumbing
Hamilton Sr (2317) 1A	We have a faucet leaking that needs repairing on sink in room 218.	10/17/13	Classroom	218	Plumbing
Hamilton Sr (2317) 1A	We have a toilet that needs to be snaked out located on the 3rd floor last stall on the left side of the restroom. I tried snaking it but it continues to bag up.	10/28/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet that is stopped up and needs to be snaked out. I tried snaking it but it continues to bag up.	10/29/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a toilet that needs snaking due to being stopped up. I tried snaking it but it continues to bag up.	11/5/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	FLR DRAINS ARE BACKING UP IN KITCHEN. PLANT MGR-ROGERS/416.7832	11/8/13			Plumbing
Hamilton Sr (2317) 1A	We have a toilet that needs to be snaked out located in the restroom behind the gym. I tried snaking out but it continues to bag up.	11/20/13	Restroom (Girls)		Plumbing
Hamilton Sr (2317) 1A	PIPE in ceiling is LEAKING above the FREEZER in the kitchen per Mr. Rogers, Plant Mgr. 416.7838	11/22/13			Plumbing

Hamilton Sr (2317) 1A	We have a sink leaking from the pipe that needs to be repaired located on the 3rd floor.	11/27/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	The sink in the break room is stopped up and needs to be repaired.	12/10/13	Library		Plumbing
Hamilton Sr (2317) 1A	The toilet in the plant manager's office is continuing to run and needs repairing.	12/10/13	Administration Area		Plumbing
Hamilton Sr (2317) 1A	We have a bad leak in the boys locker room in the gym. The water is coming from the wall in the room with the hot tub in it located right beside the boys locker room that needs repairing.	12/11/13	Gym		Plumbing
Hamilton Sr (2317) 1A	We have a toilet in the boys restroom on the 3rd floor that needs to be snaked out.	12/11/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	We have a urinal stopped up that needs to be snaked out located in the boys locker room restroom.	12/12/13	Gym		Plumbing
Hamilton Sr (2317) 1A	We have a toilet in the boys restroom 3rd stall that needs snaking out located behind the gym.	12/16/13	Restroom (Boys)		Plumbing
Hamilton Sr (2317) 1A	Test and report on backflow prevention devices.	12/18/13			Plumbing
Hamilton Sr (2317) 1A	Clean and repair	8/23/13			Roof

Hamilton Sr (2317) 1A	Repair roof holes to fix the leaks.	7/8/13		roof	Roof
Hamilton Sr (2317) 1A	We have a leak in stairweel C that needs to be repaired.The leak is located above the glass area in the stairway.	11/1/13	Stairway	C	Roof
Hamilton Sr (2317) 1A	Install new HVAC coil.	6/13/14			Sheet Metal
Hamilton Sr (2317) 1A	install freeze stat	6/3/14			Sheet Metal
Hamilton Sr (2317) 1A	We have lockers that needs to be repaired throughout the first floor that are broken and damaged.	7/16/13	1st Floor		Sheet Metal
Hamilton Sr (2317) 1A	We have lockers throughout the second floor that needs to be repaired that are broken and damaged.	7/16/13	2nd Floor		Sheet Metal

Count of Craft	Craft								
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Hawkins Mill ES (2330) 1B	2	44	68	46	3	66	1	3	233
Grand Total	2	44	68	46	3	66	1	3	233

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Hawkins Mill ES (2330) 1B	Hawkins Mill -- El. Work Order 2330-1B-- Principal is requesting a quote for rewiring/renovation of computer lab. (Request Network Cabling Project Management). (SCS Network Cabling and Electronics dept. Response -- "Please See Journal Notes")	7/19/13	Administration Area	computer lab room12	Cabling
Hawkins Mill ES (2330) 1B	Install tv for display of data in main hallway. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	10/31/13		Main hallway entrance	Cabling
Hawkins Mill ES (2330) 1B	Repair door it will not lock, when lock with key it will still open.	1/30/14	1st Floor	classroom 1	Carpentry
Hawkins Mill ES (2330) 1B	Install markerboard strips (10).	2/13/14	1st Floor	main hallway	Carpentry
Hawkins Mill ES (2330) 1B	Install 3'by 4' marker board in conference room to display data.	2/13/14	Administration Area	conference room	Carpentry
Hawkins Mill ES (2330) 1B	Repair door will not close and repair door stop.	1/13/14	2nd Floor	Room G4	Carpentry
Hawkins Mill ES (2330) 1B	repair lock continuously turns when teacher tries to lock door with key.	1/17/14	2nd Floor	Room G4	Carpentry
Hawkins Mill ES (2330) 1B	Install bulletin board strips in the hallway (10) per principal request.	1/23/14	Hallway/Corridor	lower level hallway	Carpentry

Hawkins Mill ES (2330) 1B	Install bulletin board strips (10) throughout hallway.	10/31/13	1st Floor	main hallway	Carpentry
Hawkins Mill ES (2330) 1B	Back entrance door in the CAFETERIA will NOT SECURE per Ms. Johnson, Plant Mgr. 416.0656	11/4/13			Carpentry
Hawkins Mill ES (2330) 1B	repair cylinder in door.	12/5/13	2nd Floor	room 4	Carpentry
Hawkins Mill ES (2330) 1B	Install (2) 4 by 8 marker boards teacher states she has a semi blind child who can not see black board effectively.	12/10/13	1st Floor	room 6	Carpentry
Hawkins Mill ES (2330) 1B	Pipe leak in girls restroom remove plaster ceiling for access for repair.	12/11/13			Carpentry
Hawkins Mill ES (2330) 1B	Replace ceiling tile, special cut.	12/16/13		main hallway	Carpentry
Hawkins Mill ES (2330) 1B	In the cafe, a piece of ceiling tile is hanging from the ceiling. Not necessary to replace immediately but need to get this tile down by Tuesday, registration.	7/25/13			Carpentry
Hawkins Mill ES (2330) 1B	Repair swing door on front counter in the main office.	7/30/13	Administration Area	main office	Carpentry
Hawkins Mill ES (2330) 1B	Replace flagpole cord fasteners are broken.	8/6/13	Courtyard	flagpole	Carpentry

Hawkins Mill ES (2330) 1B	Install flag pole in main lobby.	7/2/13	Annex	room a8	Carpentry
Hawkins Mill ES (2330) 1B	Room G10,G4 Lock sticking. RR Girls stall missing.	7/2/13			Carpentry
Hawkins Mill ES (2330) 1B	RR boys kick plate, girls stall door missing,A-6 door sticking.	7/2/13			Carpentry
Hawkins Mill ES (2330) 1B	Rm 9,7 lock sticking. Library door, Teachers lounge dragging,R5 Strick plate.	7/2/13			Carpentry
Hawkins Mill ES (2330) 1B	Door repair main hall.	7/8/13	1st Floor		Carpentry
Hawkins Mill ES (2330) 1B	Install door.	7/8/13	Restroom (Girls)		Carpentry
Hawkins Mill ES (2330) 1B	Install plate around lock in door there is a hole in door to prevent break in.	7/17/13	Courtyard	frontdoor of building	Carpentry
Hawkins Mill ES (2330) 1B	Reseal window loose from rain and wind damage water enters building during rain.	7/17/13	Hallway/Corridor	first floor hallway	Carpentry
Hawkins Mill ES (2330) 1B	Install tissue holders (4)	8/8/13	2nd Floor	girls restroom	Carpentry

Hawkins Mill ES (2330) 1B	Please replace the fiberglass insulation and ceiling tiles in hallway ceiling, due to water damage insulation was soaked requiring it to be removed about 12 ft.	8/20/13	1st Floor	main hallway	Carpentry
Hawkins Mill ES (2330) 1B	Install restroom door in ladies restroom.	8/26/13	Kitchen	kitchen/main hallway	Carpentry
Hawkins Mill ES (2330) 1B	Install three 4 by 8 bulletin boards to display school data in office per principals request.	9/17/13	Administration Area	Main office	Carpentry
Hawkins Mill ES (2330) 1B	replace metal plate over whole in wall, children placing items in hole, child hands got caught in the whole.	9/19/13	2nd Floor	girl restroom downstairs	Carpentry
Hawkins Mill ES (2330) 1B	replace 2 chalk boards 4by 8 with 2 4by 8 marker board teacher has child who has asthma.	9/25/13	1st Floor	room 7	Carpentry
Hawkins Mill ES (2330) 1B	Install bulletin board strips throughout hallway (4) 12by 12 on each side.	10/2/13	1st Floor	main hallway	Carpentry
Hawkins Mill ES (2330) 1B	Install bulletin board strips throughout the hallway (4) 12 by 12	10/2/13	2nd Floor	downstairs hallway	Carpentry
Hawkins Mill ES (2330) 1B	Install/replace metal plate on door damaged during break in.	10/2/13	2nd Floor	downstairs entrance door	Carpentry
Hawkins Mill ES (2330) 1B	Reattach door it is hanging off.	2/26/14	1st Floor	girlrestroom	Carpentry

Hawkins Mill ES (2330) 1B	replace metal plate over whole in wall, replace crews	2/26/14	2nd Floor	girlsrestroom	Carpentry
Hawkins Mill ES (2330) 1B	Install (3) Marker boards 4by 8 and (2) 4by 8 bulletin boards	4/4/14	1st Floor	room 9	Carpentry
Hawkins Mill ES (2330) 1B	replace existing (2) 4by 4 chalkboards with 4by 4 marker boards.	4/4/14	1st Floor	room 9	Carpentry
Hawkins Mill ES (2330) 1B	Replace ceiling tile (2) special cutt.	4/24/14	1st Floor	room 6	Carpentry
Hawkins Mill ES (2330) 1B	Repair door not closing properly.	4/24/14	1st Floor	room 13	Carpentry
Hawkins Mill ES (2330) 1B	Section of fence around playground need to be put back up	5/18/14	Grounds	Playground	Carpentry
Hawkins Mill ES (2330) 1B	hang papertowel holder	5/20/14	Annex	boy restroom	Carpentry
Hawkins Mill ES (2330) 1B	Install (2) 4'8' dry erase boards in the front of classroom.	6/3/14	1st Floor	room 15	Carpentry
Hawkins Mill ES (2330) 1B	Install (2) 4'8' bulletin boards in classroom	6/3/14	1st Floor	room 15	Carpentry

Hawkins Mill ES (2330) 1B	Remove maps from room g-8 and install into room 15	6/11/14	1st Floor	room 15	Carpentry
Hawkins Mill ES (2330) 1B	(2) shades 44inches by 72inches Replace shades	7/29/13	1st Floor	room 105	Carpentry
Hawkins Mill ES (2330) 1B	Replace (2) ballast	2/6/14	Library	1st floor	Electrical
Hawkins Mill ES (2330) 1B	Check motor on ventahood.	1/6/14	Kitchen	kitchern	Electrical
Hawkins Mill ES (2330) 1B	Fan Coil Unit is NOT COMING ON in Room G8 per Denise Johnson, Plant Mgr. 416.0656	1/6/14			Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	1/8/14	1st Floor	girls restroom	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (3)	1/8/14	1st Floor	classroom 13	Electrical
Hawkins Mill ES (2330) 1B	UV RM 8-NOT COMING ON-PLANT MGR JOHNSON 416-3944 KLR	1/24/14			Electrical
Hawkins Mill ES (2330) 1B	Air Handler Unit in Room 12 is NOT COMING ON per Denise Johnson, Plant Mgr. 416.0656	10/25/13			Electrical

Hawkins Mill ES (2330) 1B	Replace surge protector in HVAC panel.	11/27/13	1st Floor		Electrical
Hawkins Mill ES (2330) 1B	Repair/replace lights along front lawn along sidewalk (3)	11/27/13	Courtyard	front of building	Electrical
Hawkins Mill ES (2330) 1B	Requesting (10) cases of light bulbs-hg-Lamp F32T8/ADV841/EW 25 Lamps 28 Watt 5 00 46677 14734 6	7/19/13	Cafeteria	cafeteria	Electrical
Hawkins Mill ES (2330) 1B	4-UV NOT COMING ON IN RM-2,17,18,G-5. SBE-HUBBARD/416-3880	7/23/13			Electrical
Hawkins Mill ES (2330) 1B	RTU NOT COMING ON IN RM-4,5 ANNEX. PLANT MGR-JOHNSON/416-3944	7/29/13			Electrical
Hawkins Mill ES (2330) 1B	Set clocks	8/6/13	Administration Area	main office/hallways	Electrical
Hawkins Mill ES (2330) 1B	AHU 2ND FLR RM 17, 2ND FLR RM 18, 2ND FLR RM 2, 2ND FLR RM 8, & CAFE EAST-ALL NOT COMING ON SBE JOHNSON 416-3944 KLR	8/7/13			Electrical
Hawkins Mill ES (2330) 1B	2-FCU NOT COMING ON IN RM-17(043) RM-18(049). PLANT MGR-JOHNSON/416.3944	8/8/13			Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	Restroom (Girls)	main office restroom hallway	Electrical

Hawkins Mill ES (2330) 1B	replace ballast (2)	7/2/13	1st Floor	room 4	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast(2)	7/2/13	1st Floor	room 3	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (2)	7/2/13	1st Floor	room 2	Electrical
Hawkins Mill ES (2330) 1B	Replacwe ballast (1)	7/2/13	1st Floor	room 1	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 6	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 7	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 8	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 9	Electrical
Hawkins Mill ES (2330) 1B	Replacwe ballast (1)	7/2/13	1st Floor	room 11	Electrical

Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 12	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast(1)	7/2/13	1st Floor	room 13	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 14	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 15	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 16	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 17	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	1st Floor	room 18	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g5	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g6	Electrical

Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g7	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g9	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g10	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g3	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g2	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	2nd Floor	room g1	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	Annex	room a1	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (1)	7/2/13	Annex	room a2	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (2)	7/2/13	Annex	room a2	Electrical

Hawkins Mill ES (2330) 1B	Replace ballast (2)	7/2/13	Annex	room a5	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (2)	7/2/13	Annex	room a6	Electrical
Hawkins Mill ES (2330) 1B	Replace ballast (2)	7/2/13	Annex	room a8	Electrical
Hawkins Mill ES (2330) 1B	Repair lobby lights.	8/12/13	1st Floor		Electrical
Hawkins Mill ES (2330) 1B	Repair lights in Kitchen.	8/12/13	1st Floor		Electrical
Hawkins Mill ES (2330) 1B	Repair lights.	8/12/13	Kitchen		Electrical
Hawkins Mill ES (2330) 1B	Repair ballast/lights.	8/19/13	Cafetorium		Electrical
Hawkins Mill ES (2330) 1B	cafe west unit -- bad ifm	8/27/13			Electrical
Hawkins Mill ES (2330) 1B	BREAKER KITCHEN AREA-KEEPS TRIPPING KNOCKING POWER OUT TO REFRIGERATOR & MILKBOX PER SBE-PLANT MGR JOHNSON 416-3244 KLR	10/1/13			Electrical

Hawkins Mill ES (2330) 1B	Replace ballast in hallway (2)	10/16/13	Hallway/Corridor	main hallway	Electrical
Hawkins Mill ES (2330) 1B	Requesting (4) F32TB/ADV841/EW 25 LAMPS 28 WATTS 5 00 46677 147346	10/16/13	Custodial Closet	plant manager office	Electrical
Hawkins Mill ES (2330) 1B	reattach broken wire to building.	3/5/14	Parking Lot	out near cafeteria	Electrical
Hawkins Mill ES (2330) 1B	Set clocks to daylight savings time.	3/5/14	Administration Area	main office	Electrical
Hawkins Mill ES (2330) 1B	Replace surge protector. Kevin and MLGW will be on site 11 or 12 at 8:00 am.	3/10/14			Electrical
Hawkins Mill ES (2330) 1B	CIRCUIT BREAKER KITCHEN AREA- BLEW FUSE TO FREEZER-PLANT MGR JOHNSON 416-3944 KLR	4/10/14			Electrical
Hawkins Mill ES (2330) 1B	replace light cover.	4/15/14	Administration Area	main office	Electrical
Hawkins Mill ES (2330) 1B	Bad ballast	5/9/14	1st Floor	Back hall by cafe	Electrical
Hawkins Mill ES (2330) 1B	install electricity for kettle pot in kitchen area.	3/24/14	Kitchen	kitchen	Electrical

Hawkins Mill ES (2330) 1B	Reattach clock to wall, hanging by electrical wires.	4/2/14	2nd Floor	hallway	Electrical
Hawkins Mill ES (2330) 1B	repair/replace light fixture.	3/12/14	Stairway	middle stepsn main building	Electrical
Hawkins Mill ES (2330) 1B	Repair/replace lights along front lawn along sidewalk (3)	8/8/13	Courtyard	front of building	Electrical
Hawkins Mill ES (2330) 1B	Replace surge protector in HVAC panel.	8/2/13	1st Floor		Electrical
Hawkins Mill ES (2330) 1B	Replace surge module in main switchgear.	2/19/14			Electrical
Hawkins Mill ES (2330) 1B	Requesting (4 CASES) light bulbs, case numbers are as follows: F32TB/ADV841/EW 25 LAMPS 28 WATTS 5 00 46677147346	12/23/13	Custodial	sbe office	Electrical
Hawkins Mill ES (2330) 1B	I am requesting (3) cases of 4ft T8 Light bulbs for stairwells.	3/28/14	Stairway	main hallway	Electrical
Hawkins Mill ES (2330) 1B	RTU-2 SECTION A SW-LEAKING CARBON MONOXIDE AND WAS SHUT DOWN BY MLG&W-PLANT MGR PATTERSON 416-3944 KLR	1/28/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmentmen - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Hawkins Mill ES (2330) 1B	Monthly - HAWKINS MILL ELM LVL 2 WATER TREATMENT - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	put panels back on rtu's	2/6/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Cafe RTU's --- clean and change screens on burners also check gas pressure	2/10/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	HEAT G RR ANNEX BLDG-NOT HEATING-PLANT MGR JOHNSON 416-3944 KLR	2/13/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	boys r/r annex --- needs comp.	10/30/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Filter-Hawkins Mill Elementary - Refer to PM schedule details.	11/10/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	UV NOT HEATING IN RM-A3 ANNEX PLANT MGR-JOHNSON/416.3944	11/13/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	per Ms. Johnson 416-0656 AHU G5 And 17 blowing cold air	12/10/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	UNITS ARE NOT COOLING IN RM G5, 17, 18, 2,. PRINC,- NELSON 416-3944	7/23/13			Heating/Ventilation /Air Conditioning

Hawkins Mill ES (2330) 1B	UNITS ARE NOT COOLING IN RMS 17,18,2,G5. SBE JOHNSON	7/29/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Cafeteria a/c not coming on Room 2 not cooling per Denise Johnson 416-0656	8/1/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	RTU-5 ANNEX WEST CTR SERVES RM A5 & RTU-7 ANNEX WEST 2ND FROM NORTH SERVES RM A7- BOTH NOT COMING ON-SBE JOHNSON 416-0656 KLR	8/6/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	AHU CAFE WEST & AHU CAFE EAST-BOTH NOT COOLING-SBE JOHNSON 416-3944 KLR	8/8/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Filter-Hawkins Mill Elementary - Refer to PM schedule details.	7/7/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	A/C not working at all in rooms 2, 17, 18 Denise Johnson 416-3944	7/18/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	FCU NOT COOLING IN LIBRARY PLANT MGR-BANKS/416.1030	8/19/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	show pmt how to access cond. coil	8/28/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	rms not cooling	9/29/13			Heating/Ventilation /Air Conditioning

Hawkins Mill ES (2330) 1B	restroom in annex has bad comp.	9/30/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	P.E. room needs comp.	10/7/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Oil Lube & Belt-Hawkins Mill - Refer to PM schedule details.	10/22/13			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Filter-Hawkins Mill Elementary - Refer to PM schedule details.	3/9/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning

Hawkins Mill ES (2330) 1B	Monthly - HAWKINS MILL ELM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Air Compressor - Hawkins Mill Elem - Refer to PM schedule details.	5/20/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Oil Lube & Belt-Hawkins Mill - Refer to PM schedule details.	5/20/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	UNIT NOT COOLING IN MAIN CAFE, & RM-10 PLANT MGR-JOHNSON/416.3944	6/2/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	6/6/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmen - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - HAWKINS MILL ELM LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning

Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmentmen - Refer to PM schedule details.	3/28/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - HAWKINS MILL ELM LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Daily - Hawkins Mill Elem Level 1 Water Treatmentmen - Refer to PM schedule details.	3/14/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Yearly - Rod Chiller - Hawkins Mill Elementary - Refer to PM schedule details.	3/16/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Yearly - Cooling Towers-Hawkins Mill Elem - Refer to PM schedule details.	3/18/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Monthly - Air Compressor - Hawkins Mill Elem - Refer to PM schedule details.	11/19/13				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Yearly - Water-Cool Chiller Filter-Hawkins Mill - Refer to PM schedule details.	2/25/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	Yearly - Boiler - Hawkins Mill El - Mech Rm - Refer to PM schedule details.	3/22/14				Heating/Ventilation /Air Conditioning
Hawkins Mill ES (2330) 1B	paint area where hand washing sink has been removed	7/19/13	2nd Floor	girls restroom		Painting

Hawkins Mill ES (2330) 1B	refinish and update front counter (per principal request)	10/22/13	Administration Area	main office	Painting
Hawkins Mill ES (2330) 1B	touch up hallway paint peeling off walls due to water damage.	10/22/13	1st Floor	main hallway	Painting
Hawkins Mill ES (2330) 1B	RTU IS LEAKING C20 IN CAFE PLANT MGR-JOHNSON/834.4267	1/27/14			Plumbing
Hawkins Mill ES (2330) 1B	repair drinking fountain	2/6/14	Annex	a5	Plumbing
Hawkins Mill ES (2330) 1B	GAS LEAK IN KITCHEN. PLANT MGR-JOHNSON/416.3944	2/10/14			Plumbing
Hawkins Mill ES (2330) 1B	POSSIBLE GAS LEAK KITCHEN AREA PER B SHIPP-CALLED IN BY B SHIPP KLR	2/10/14			Plumbing
Hawkins Mill ES (2330) 1B	Replace hot water tank in main office. Repair pipe leak.	2/13/14			Plumbing
Hawkins Mill ES (2330) 1B	VERY STRONG GAS SMELL IN MAIN OFC AREA-PLANT MGR JOHNSON 416-3944 KLR	2/13/14			Plumbing
Hawkins Mill ES (2330) 1B	Check pilot on stove in kitchen area continuously going out, smelling gas.	1/3/14	Cafeteria	kitchen	Plumbing

Hawkins Mill ES (2330) 1B	GAS SMELL in the CAFETERIA per Ms. Johnson, Plant Mgr. at 901.416.0556	1/3/14			Plumbing
Hawkins Mill ES (2330) 1B	Check for strong smell in kitchen-suspect gas.	1/6/14	Kitchen	kitchen	Plumbing
Hawkins Mill ES (2330) 1B	Replace flush valve toilet overflowing.	1/8/14	1st Floor	Girls restroom	Plumbing
Hawkins Mill ES (2330) 1B	replace washer on hand washing sink.	1/22/14	1st Floor	room 7	Plumbing
Hawkins Mill ES (2330) 1B	replace washer in sink.	1/22/14	Kitchen	kitchen	Plumbing
Hawkins Mill ES (2330) 1B	unclog toilet.	1/23/14	2nd Floor	girls restroom	Plumbing
Hawkins Mill ES (2330) 1B	GAS LEAK in the KITCHEN per Denise Johnson, Plant Mgr. 416.0652.	1/27/14			Plumbing
Hawkins Mill ES (2330) 1B	pipe busted underneath 3 compartment sink in kitchen per Denise Johnson 416-6056	10/28/13			Plumbing
Hawkins Mill ES (2330) 1B	Domestic boiler is leaking water.	11/7/13	Mechanical Room	boiler room	Plumbing

Hawkins Mill ES (2330) 1B	unclog sink, replace flush valves	12/5/13	2nd Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	unclog slop sink	12/5/13	2nd Floor	custodial closet	Plumbing
Hawkins Mill ES (2330) 1B	Girls restroom overhead pipe leak.	12/11/13			Plumbing
Hawkins Mill ES (2330) 1B	UV IS LEAKING WATER IN RM-G-8. SBE-HUBBARD/416-3880	7/23/13			Plumbing
Hawkins Mill ES (2330) 1B	UNIT IN RM G8 IS LEAKING PRINC,- NELSON 416-3944	7/23/13			Plumbing
Hawkins Mill ES (2330) 1B	Repair or replace refrigerated water cooler in cafeteria. ALSO Girls restroom main floor a faucet does not work.	7/25/13			Plumbing
Hawkins Mill ES (2330) 1B	Leak in cafeteria	7/29/13	Cafeteria	Cafeteria	Plumbing
Hawkins Mill ES (2330) 1B	Leak in hallway	7/29/13	1st Floor	main hallway outside of cafeteria	Plumbing
Hawkins Mill ES (2330) 1B	toilet not working	7/29/13	Annex	repair toilet not flushing	Plumbing

Hawkins Mill ES (2330) 1B	replace handle on sink in hallway.	7/29/13	1st Floor	hallway	Plumbing
Hawkins Mill ES (2330) 1B	repair handwashing sink leaking from nozzle.	7/29/13	2nd Floor	girls restroom	Plumbing
Hawkins Mill ES (2330) 1B	Repair drain pipe.	7/2/13	Annex	right side of building	Plumbing
Hawkins Mill ES (2330) 1B	unclog slop sink in custodial closet.	8/19/13	2nd Floor	custodial closet	Plumbing
Hawkins Mill ES (2330) 1B	unclog drinking fountain.	8/19/13	1st Floor	main hallway	Plumbing
Hawkins Mill ES (2330) 1B	Replace flush valve in toilet.	8/20/13	Annex	girls restroom	Plumbing
Hawkins Mill ES (2330) 1B	Repair/replace petrap on hand washing sink.	8/20/13	Annex	main hallway	Plumbing
Hawkins Mill ES (2330) 1B	Bad odor in main building early in mornings, goes away during the day.	8/20/13			Plumbing
Hawkins Mill ES (2330) 1B	Flush sewer drains	8/26/13			Plumbing

Hawkins Mill ES (2330) 1B	Replace flush valve in urinal, sticking causing restroom to flood.	8/26/13	1st Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	Repair toilet leaking from back of of toilet.	8/27/13	1st Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	FLOOR DRAIN RM 4 A/C CLOSET- STOPPED UP & WATER STANDING IN FLR-PLANT MGR JOHNSON 416-3944 KLR	8/27/13			Plumbing
Hawkins Mill ES (2330) 1B	boys 1st stall, unclog.	8/29/13	1st Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	Unclog boys first uniral.	8/29/13	2nd Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	repair drinking fountin, continuously ruining	9/4/13	1st Floor	main hallway	Plumbing
Hawkins Mill ES (2330) 1B	TOILET IS OVERFLOWING IN B/RR 1ST FLR PLANT MGR-JOHNSON/416.3920	9/10/13			Plumbing
Hawkins Mill ES (2330) 1B	Replace flush valves.	9/11/13	Restroom (Boys)	lower level	Plumbing
Hawkins Mill ES (2330) 1B	unclog urinal.	9/17/13	1st Floor	boys restroom	Plumbing

Hawkins Mill ES (2330) 1B	Unclog uniral.	9/17/13	2nd Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	COMMODE G RR 1ST FLR 1ST STALL-CONSTANTLY FLUSHING & LEAKING WATER OUT PER SBE-PLANT MGR JOHNSON 416-3944 KLR	9/18/13			Plumbing
Hawkins Mill ES (2330) 1B	Unclog 2nd toilet	10/2/13	1st Floor	girls restroom	Plumbing
Hawkins Mill ES (2330) 1B	Repair drinking fountain continuously running.	10/3/13	1st Floor	girls restroom	Plumbing
Hawkins Mill ES (2330) 1B	Unclog toilet in girls restroom in last stall.	10/3/13	2nd Floor	bottom floor	Plumbing
Hawkins Mill ES (2330) 1B	Mop sink is stopped up.	10/10/13	Custodial Closet	1st. Floor	Plumbing
Hawkins Mill ES (2330) 1B	repair 3 compartment sink. leaking from he bottom onto floor..	10/18/13	Cafeteria	kitchen	Plumbing
Hawkins Mill ES (2330) 1B	Boys restroom flooding hallway	3/7/14	2nd Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	replace flush valve, not flushing.	2/26/14	2nd Floor	boysrestroom	Plumbing

Hawkins Mill ES (2330) 1B	unstop toilet, replace flush valve.	2/26/14	1st Floor	boysrestroom	Plumbing
Hawkins Mill ES (2330) 1B	BUSTED PIPE IS LEAKING WATER IN BOILER RM PLANT MGR-JOHNSON/210.5496	3/20/14			Plumbing
Hawkins Mill ES (2330) 1B	Unclog drain	3/21/14	2nd Floor	boiler room	Plumbing
Hawkins Mill ES (2330) 1B	replace flushvalve continuously flushing	4/4/14	Kitchen	employees restroom	Plumbing
Hawkins Mill ES (2330) 1B	GAS SMELL ON 2ND FLR AREA- PLANT MGR JOHNSON 416-3920 KLR	4/10/14			Plumbing
Hawkins Mill ES (2330) 1B	Check on level of sewer gas it is increasing strong in the hallways.	4/17/14	1st Floor	hallway	Plumbing
Hawkins Mill ES (2330) 1B	unclog sink	4/23/14	1st Floor	custodial closet	Plumbing
Hawkins Mill ES (2330) 1B	Unstop sewer	4/25/14			Plumbing
Hawkins Mill ES (2330) 1B	Toilet stopped up	6/30/14	1st Floor	washroom	Plumbing

Hawkins Mill ES (2330) 1B	water is leaking from inside of wall causing a slip hazard in third stall.	3/25/14	1st Floor	girlsrestroom	Plumbing
Hawkins Mill ES (2330) 1B	Repair toilet/replace flush valve.	3/28/14	Annex	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	reset uniral in place, it is leaking.	3/31/14	Annex	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	unclog uniral (3rd) on kindergarten hallway.	3/31/14	1st Floor	boys restroom	Plumbing
Hawkins Mill ES (2330) 1B	repair drinking fountains (2) top of drinking fountain broken, hazard for children.	4/2/14	Annex	hallway	Plumbing
Hawkins Mill ES (2330) 1B	Repair roof leak in main hallway.	8/12/13	1st Floor	main hallway	Roof
Hawkins Mill ES (2330) 1B	Fabricate and install stainless access panel in girls restroom for pipe repair. Lead person Jason.	12/11/13			Sheet Metal
Hawkins Mill ES (2330) 1B	Repair/Replace frame around lockers.	8/19/13	2nd Floor	g5	Sheet Metal
Hawkins Mill ES (2330) 1B	Vent is loose on A/C unit on roof over the office area, allowing animals to enter	9/19/13			Sheet Metal

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Idlewild ES (2355) 1A	2	3	30	70	50	3	43	2	5	208
Grand Total	2	3	30	70	50	3	43	2	5	208

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Idlewild ES (2355) 1A	Varies floor tile need repair and cove base replaced.	7/23/13	Hallway/Corridor	2nd flr.	Asbestos
Idlewild ES (2355) 1A	Please resurface or clean rubber gym floor. Thanks! Plant Manger.	10/1/13	Gym	Floor	Asbestos
Idlewild ES (2355) 1A	Please repair Office-3/IDF-3 Cat-6 Gym-2/Mdf Cat-6, phone jacks and computers.	4/11/14	Gym	Office/West wall	Cabling
Idlewild ES (2355) 1A	Please have tech, look at 315 - 315B Thanks! Plant Manger	9/3/13	Classroom	315	Cabling
Idlewild ES (2355) 1A	Please have tect check or replace LSM drop in the boiler room. Thanks Plant Manger(Request Network Cabling Maintenance Repair).	8/5/13	Mechanical Room	boiler room	Cabling
Idlewild ES (2355) 1A	Please repair strike plate, door that will not lock. Thanks! Plant Manager.	2/21/14	Classroom	2nd fl 202	Carpentry
Idlewild ES (2355) 1A	Check for leak above ceiling of tutor room.	7/23/13	Library		Carpentry

Idlewild ES (2355) 1A	Please remove kindergarden loft, for more space in the classroom. Thanks! Plant Manager.	6/16/14	Classroom	KK-104	Carpentry
Idlewild ES (2355) 1A	Please ask carpenter to make special cuts for damage ceiling titles. Thanks! Plant Manager.	6/24/14	Hallway/Corridor	1st-2nd-3rd Floors-Annex	Carpentry
Idlewild ES (2355) 1A	Please repair broken door knob. Thanks!Plant Manger	9/3/13	Classroom	300	Carpentry
Idlewild ES (2355) 1A	Check ceiling for leak and replace tile as needed.	7/23/13	Administration Area	Main office	Carpentry
Idlewild ES (2355) 1A	Please send two bundles of fire rated ceiling titles. Thanks Plant Manger.	7/25/13	Hallway/Corridor	ceiling titles	Carpentry
Idlewild ES (2355) 1A	Restroom door is off the hinges. Please repair. Thanks Plant Manger	7/30/13	Restroom (Boys)	2nd fl	Carpentry
Idlewild ES (2355) 1A	Courtyard just outside the library there's a strip of metal facing missing and allowing damage from the weather. Repair and replace.	7/23/13	Library		Carpentry
Idlewild ES (2355) 1A	Door is coming off. Repair or replace.	7/23/13	Restroom (Boys)	3rd fir.	Carpentry

Idlewild ES (2355) 1A	Please repair panic bar, bar is in plant managers office. Thanks! Plant Manger.	9/30/13	Annex	2nd floor northeast	Carpentry
Idlewild ES (2355) 1A	Please secure top grates back to outside door. Thanks! Plant Manager	10/15/13	Mechanical Room	East outside door	Carpentry
Idlewild ES (2355) 1A	Please repair, fallen stall door. Thanks! Plant Manager.	11/4/13	Restroom (Girls)	3d fl main	Carpentry
Idlewild ES (2355) 1A	Please repair, fallen stall door. Thanks! Plant Manager.	11/4/13	Restroom (Boys)	3rd fl main	Carpentry
Idlewild ES (2355) 1A	Please repair loose door jam stairwell doors east wing. Thanks! Plant Manager.	11/15/13	Hallway/Corridor	3rd fl main	Carpentry
Idlewild ES (2355) 1A	Please check for crack window sills, or broken window. Thanks! Plant Manager.	11/22/13	3rd Floor	Counselor's Office	Carpentry
Idlewild ES (2355) 1A	per Mr. King 416-9060 door knob off on main office door and room 202	11/27/13			Carpentry
Idlewild ES (2355) 1A	Replace ceiling tile in main office.	1/3/14	Administration Area		Carpentry

Idlewild ES (2355) 1A	Doors are sticking and dragging please correct.Thanks! Plant Manager.	3/19/14	1st Floor	1st fl South&Northwest	Carpentry
Idlewild ES (2355) 1A	Please make special cut for ceiling tiles. Thanks! Plant Manager.	3/19/14	Administration Area	Principals restroom	Carpentry
Idlewild ES (2355) 1A	SOUTH ENTRY DOOR, CANT SECURE. PLANT MGR-KING/416.4536	3/19/14			Carpentry
Idlewild ES (2355) 1A	FRONT ENTRANCE DOOR-NOT CLOSING-WON'T BE ABLE TO SECURE-PLANT MGR KING 416-9060 KLR	4/4/14			Carpentry
Idlewild ES (2355) 1A	front of 3 story Bldg. repair gutter & wooden soffit, wood damaged by gutter pulling away from fascia board, would like for F.I.M. to oversee contract for repairs, very high, we have no way to reach.-os	9/16/13			Carpentry
Idlewild ES (2355) 1A	Please repair sinking floor and tiles. Thanks! Plant Manager.	4/17/14	Hallway/Corridor	West exit	Carpentry
Idlewild ES (2355) 1A	please reset or repair partition, hazard may fall down. thanks! Plant Manager	5/29/14	Gym	boys restroom	Carpentry
Idlewild ES (2355) 1A	Please repair stall door, hanging by one hinge. Thanks! Plant Manager.	5/29/14	Restroom (Boys)	2nd fl near 214A	Carpentry

Idlewild ES (2355) 1A	Please rehang stall door, have door on hand. Thanks! Plant Manager.	5/29/14	Restroom (Girls)	3rd fl southeast	Carpentry
Idlewild ES (2355) 1A	Please rehang stall door. Thanks! Plant Manager.	5/29/14	Restroom (Boys)	2nd fl southwest	Carpentry
Idlewild ES (2355) 1A	Please reattach stall door. Thanks! Plant Manager.	5/29/14	Restroom (Girls)	2nd fl southwest	Carpentry
Idlewild ES (2355) 1A	Flooring in south east corner spongy just in front of tutor room doorway.Repair and replace as needed.	7/23/13	Library		Carpentry
Idlewild ES (2355) 1A	Please replace 4 tube ballast in classroom, southwest corner. Thanks! Plant Manager	2/5/14	Classroom	312	Electrical
Idlewild ES (2355) 1A	Please replace blower motor, for heater. Temp is the same as the outside. Can cause a freezing problem of the pipes. Thanks! Plant Manager.	2/5/14	Mechanical Room	1st Floor-Kindergarden	Electrical
Idlewild ES (2355) 1A	Please check blower motor. Thanks! Plant Manager.	2/5/14	Mechanical Room	Boiler room east side	Electrical
Idlewild ES (2355) 1A	Please reset clocks for up coming day light savings time. Thanks! Plant Manager.	2/21/14	Administration Area	1st fl	Electrical

Idlewild ES (2355) 1A	Emergency lighting dosen't work. Please repair. Thanks! Plant Manger	8/14/13	Restroom (Boys)	1st-2nd Floor	Electrical
Idlewild ES (2355) 1A	Emergency lighting dosen't work. Please repair. Thanks! Plant Manger	8/14/13	Restroom (Girls)	2nd Floor	Electrical
Idlewild ES (2355) 1A	Room 104 has a receptacle that is arcing when used per John King 416-9060	8/16/13			Electrical
Idlewild ES (2355) 1A	Please repair cracked exposed socket on the North/West wall. Thanks! Plant Manger.	8/19/13	Cafeteria	1stFloor	Electrical
Idlewild ES (2355) 1A	Please replace blown light bulbs, outside of east wall of boiler room. Thanks! Plant Manger	8/27/13	1st Floor	outside boiler room door	Electrical
Idlewild ES (2355) 1A	Please replace blown lights. Thanks! Plant Manger	8/27/13	Stairway	2nd floor	Electrical
Idlewild ES (2355) 1A	Please change out ballast. Thanks! Plant Manger	8/28/13	Administration Area	Counsels Office 3rd Floor	Electrical
Idlewild ES (2355) 1A	Outside of classroom 210, light ballast is out. Thanks! Plant Manger	8/30/13	Hallway/Corridor	west 2nd fl	Electrical

Idlewild ES (2355) 1A	Reinstall light fixture , removed to repair ceiling.	7/25/13	1st Floor	At main entry	Electrical
Idlewild ES (2355) 1A	Please repair burned out socket, south wall. Thanks Plant Manger	7/31/13	Classroom	110	Electrical
Idlewild ES (2355) 1A	Please repair vent fan teachers restroom. Thanks Plant Manger	7/31/13	2nd Floor	Teachers Lounge	Electrical
Idlewild ES (2355) 1A	Please replace bad wall switch for A/C unit. Thanks Plant Manger	7/31/13	Classroom	101	Electrical
Idlewild ES (2355) 1A	Please replace two ballasts. Thanks Plant Manger	8/5/13	Cafeteria	Serving Line	Electrical
Idlewild ES (2355) 1A	Replace motor starter to cooling tower fan.	8/6/13		Cooling Tower	Electrical
Idlewild ES (2355) 1A	Please check room for light switch, no way to turn lights on or off. Thanks Plant Manger	8/6/13	Mechanical Room	207A	Electrical
Idlewild ES (2355) 1A	Please check east wall, teacher reported seeing sparks, no power. Thanks! Plant Manager.	10/8/13	Classroom	210	Electrical

Idlewild ES (2355) 1A	Please deliver 2(two) cases of 4 inch tube bulbs, 2(two) packs of regular light bulbs for closets. Thanks! Plant Manager.	10/11/13	Hallway/Corridor	Light fixtures	Electrical
Idlewild ES (2355) 1A	Please replace the following, Emergency exits lights are out south-east-north, main building. Annex-east-south-south-south to street. Cafe dinning area- north-west-west-west. Thanks! Plant Manager.	10/11/13	Hallway/Corridor	1st floor	Electrical
Idlewild ES (2355) 1A	Please replace emergency exit lights, north wall west. Thanks! Plant Manager	10/11/13	Hallway/Corridor	2nd Floor main	Electrical
Idlewild ES (2355) 1A	Please repair ballast outside classroom 108. Thanks! Plant Manager.	10/23/13	Annex	1st Floor-Kindergarden	Electrical
Idlewild ES (2355) 1A	Please replace blown ballasts. Thanks! Plant Manager.	10/24/13	Classroom	304-309-103-104-200	Electrical
Idlewild ES (2355) 1A	Please replace blown ballast.Thanks! Plant Manager.	10/24/13	Hallway/Corridor	2nd Floor east 3rd Floor West- 1st Fl. Main Entran	Electrical
Idlewild ES (2355) 1A	Please replace ballast A H room north. Thanks! Plant Manager.	10/28/13	Mechanical Room	1st Floor North	Electrical
Idlewild ES (2355) 1A	Repair or replace 120v. recept. by cooling tower that powers the chemical feed pumps.	10/30/13			Electrical

Idlewild ES (2355) 1A	Please replace four (4) blown light bulbs. Thanks! Plant Manager.	10/31/13	Gym	Ceiling	Electrical
Idlewild ES (2355) 1A	Please update clocks to correct time. Thanks! Plant Manager.	11/4/13	Administration Area	Clocks	Electrical
Idlewild ES (2355) 1A	Please reset all clocks to the correct time. Thanks! Plant Manager.	12/3/13	Administration Area	Annex and Main Building	Electrical
Idlewild ES (2355) 1A	4-tube ballast is out, please replace ballast. Thanks! Plant Manager.	12/16/13	Classroom	210	Electrical
Idlewild ES (2355) 1A	Please send 22, 60 watt light bulbs, and 1 case of 8 foot tube bulbs. For closets and outside lighting. Thanks! Plant Manager.	1/9/14	Classroom	Closets	Electrical
Idlewild ES (2355) 1A	Principal called Otto plant manager not on sight, teachers are smelling a strange order on all three floor, possible some thing burning.	1/24/14			Electrical
Idlewild ES (2355) 1A	Please replace missing electrical junction wall plate. Duct tape has been placed over box. Thanks! Plant Manager.	1/27/14	Gym	South wall	Electrical
Idlewild ES (2355) 1A	Please replace blown ballast, bulbs has been changed. Thanks! Plant Manager.	3/19/14	Stairway	West 3rd floor	Electrical

Idlewild ES (2355) 1A	Please replace or repair 2-lights, 14-exit lights, 12-emergency lights, 1 ballast. See Plant Manager for locations, of listed items above. Thanks! Plant Manager.	3/19/14	3rd Floor	northeast	Electrical
Idlewild ES (2355) 1A	Please replace blown electrical outlet, on the north wall. Thanks! Plant Manager.	3/27/14	Classroom	306	Electrical
Idlewild ES (2355) 1A	Please repair or replace emergency lights. Thanks! Plant Manager.	4/4/14	3rd Floor	northeast-girls & boys restroom	Electrical
Idlewild ES (2355) 1A	Please replace ballast. Thanks! Plant Manager.	4/4/14	2nd Floor	Stairs south	Electrical
Idlewild ES (2355) 1A	Please replace or repair exit light.	4/4/14	1st Floor	East	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	Cafeteria	West	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	1st Floor	Door west cafeteria	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	Cafeteria	West door	Electrical

Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	Cafeteria	West double door	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	Cafeteria	East Entrance	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	1st Floor	East wall	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	1st Floor	Main entrance	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	1st Floor	West wall	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager	4/4/14	Mechanical Room	East door	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	1st Floor	North	Electrical
Idlewild ES (2355) 1A	Please replace exit lights. Thanks! Plant Manager.	4/4/14	Library	South&West door	Electrical

Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Library	West wall	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Restroom (Girls)	1st floor	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	1st Floor	North	Electrical
Idlewild ES (2355) 1A	Please install exit light at the west door in classroom. Thanks! Plant Manager.	4/4/14	Classroom	102	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Annex	1st fl east	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Restroom (Boys)	Annex 1st fl	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Restroom (Girls)	Annex 1st fl	Electrical
Idlewild ES (2355) 1A	Please replace exit light. Thanks! Plant Manager.	4/4/14	Annex	1 fl south	Electrical

Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Annex	2nd boys restroom	Electrical
Idlewild ES (2355) 1A	Please replace emergency light. Thanks! Plant Manager.	4/4/14	Annex	2nd fl girls restroom	Electrical
Idlewild ES (2355) 1A	Please replace ballast. Thanks! Plant Manager.	4/4/14	Annex	2nd fl girls restroom	Electrical
Idlewild ES (2355) 1A	Please change two sets of ballast. Thanks! Plant Manger.	9/13/13	Classroom	108	Electrical
Idlewild ES (2355) 1A	2nd & 3rd Floor two sets of bulbs is out on the 2nd floor. 3rd floor, five sets of bulbs is out. Will need very tall ladder for the 3rd floor. Thanks! Plant Manger	9/18/13	Stairway	Northeast	Electrical
Idlewild ES (2355) 1A	Please replace two blown high ceiling lights. Thanks! Plant Manger	9/18/13	Classroom	Main Building 103	Electrical
Idlewild ES (2355) 1A	Please replace ceiling lights in classroom. Thanks! Plant Manger	9/23/13	Classroom	103	Electrical
Idlewild ES (2355) 1A	Please replace third story outside light. Thanks! plant Manger	9/23/13	Parking Lot	North side	Electrical

Idlewild ES (2355) 1A	Plant Manger is requesting one case of tube bulbs for classrooms and halls, ten compact fluorescent-40W-medium base-S7335, for closets.Thanks! Plant Manger	9/25/13	Hallway/Corridor	Annex and Main Building	Electrical
Idlewild ES (2355) 1A	Pulley on guide wire dose not work on the flagpole. Please correct. Thanks Plant Manger.	8/5/13	Grounds	Flagpole	Electrical
Idlewild ES (2355) 1A	replace p-tac on 3rd and 1/2 floor	4/11/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	ROOFTOP UNIT is NOT COOLING in the CAFETERIA per Mr. King, Plant Mgr. 416.9060	6/5/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RM 315-NOT HEATING-PLANT MGR KING 416-9060 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	UNITS are NOT HEATING in ROOMS 100, 103, 315, and PLANT MANAGER'S OFFICE on the 2ND FLOOR per Mr. King, Plant Mgr. 901.416.9060.	2/7/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Yearly - Cooling Towers (STRAINERS)-Idlewild Elem - Refer to PM schedule details.	3/7/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Building hot	6/27/14			Heating/Ventilation /Air Conditioning

Idlewild ES (2355) 1A	A/C GYM AREA-NOT COOLING-PLANT MGR KING 416-9060 KLR	6/30/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	AHU CAFE-NOT COOLING-SBE KING KLR	8/12/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT PUMP CAFE EAST-NOT COOLING-SBE KING 416-9060 KLR	8/13/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	2-UNITS NOT COOLING IN RM-204,211 PLANT MGR -KING/416.9060	8/23/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Air Handler #1 is not cooling, for annex Building. Please repair. Thanks! Plant Manger	8/26/13	Classroom	Annex-1st-2nd fl	Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Rm 110 not cooling per mr. king	7/30/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT PUMP 2ND FLR RM 208A-STARTED SMOKING AND QUIT WORKING-SBE KING 416-4566 KLR	8/1/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	4-UV NOT COOLING IN RM-101,207,211,GYM. PLANT MGR-KING/416.4566	8/6/13			Heating/Ventilation /Air Conditioning

Idlewild ES (2355) 1A	2-CEILING UNITS NOT COOLING IN RM-308, 309. PLANT MGR-KING/416.9060	8/8/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Please check Belt or pully, bearrings may be bad. Thanks! Plant Manager.	11/4/13	Classroom	312A	Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RMS 102, 100, 103, 101, 211, 204, 206, 312, 310, 315, 306, 304, 218, 216, GUID OFC 3RD FLR, SPEECH THERAPY RM, 300, 302, 200, 202, 309, GYM, & LIBRARY-ALL NOT COMING ON-CALLED BY PE COACH ACEY 416-4566 KLR	11/12/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RM 206-NOT HEATING-PLANT MGR KING 416-9060 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RMS 101, 210, 211, 315, 306, 304, & 309-ALL NOT HEATING-PLANT MGR KING 416-4536 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	counselor's office 3rd floor, rooms 309, 206, 210, 211 blowing cold air per Mr. King 416-9060	11/27/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT GYM & KINDERGARTEN AREA NORTH SIDE OF BLDG CLASSRMS-ALL NOT HEATING-PLANT MGR MACON 416-2148 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RMS 106, 103, 101, 210, 211, 315, 214, 202, 309, GUIDANCE OFC 3RD FLR, NURSE STATION, & ASST PRIN'S OFC 1ST FLR-ALL NOT HEATING-PLANT MGR KING 416-9060 KLR	12/9/13			Heating/Ventilation /Air Conditioning

Idlewild ES (2355) 1A	AHU for entire kindergarten wing is not coming on 1st floor per Mr. King 416-9060	1/3/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RMS 101, 209, 210, 296, & (2) OFCS IN GYM AREA-ALL NOT HEATING-PLANT MGR KING 416-9060 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	UNIT NOT HEATING IN GYM. PLANT MGR-KING/205.8663	1/14/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RM 101-NOT HEATING-PLANT MGR KING 416-9060 KLR	1/27/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Unit in Room 103 is NOT HEATING per Mr. King, Plant Mgr. 416.9060.	1/29/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	HEAT RM 309-NOT HEATING-PLANT MGR KING 416-9060 KLR	3/26/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	DRAIN LINE is CRACK outside at the COOLING TOWER per Mr. King, Plant Mgr. 416.9060	4/7/14			Heating/Ventilation /Air Conditioning

Idlewild ES (2355) 1A	replace unit in rm 315	4/11/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Please check compressor. Thanks! Plant Manger.	9/13/13	Classroom	315	Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Have thermostat check or unit is freezing up. Thanks! Plant Manger	9/13/13	Administration Area	Across from main office	Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Monthly - Oil Lube & Belts - Idlewild Elem - Refer to PM schedule details.	9/14/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Unit is LEAKING from overhead in Room 312 per Mr. King, Plant Mgr. 416.9060.	9/16/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	A/C NOT COOLING in Room 210 per Mr. King, Plant Mgr. 416.9060	9/25/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	UNITS are NOT COOLING in ROOMS 103, 204, 209, 210, 306, 308, 315, MAIN OFFICE and the OFFICE directly across from the MAIN OFFICE per Mr. King, Plant Mgr. 416.9060	4/21/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	UNIT NOT COOLING IN TEACHERS' LOUNGE 2ND -3RD FLRS, RM-311,309,101,211,202, 214,218,216,212 PLANT MGR-KING/416.4566 PLANT MGR-FIFER/	4/29/14			Heating/Ventilation /Air Conditioning

Idlewild ES (2355) 1A	UNITS NOT COOLING IN ANNEX,309,311,310 PLANT MGR-KING/416.4536	5/6/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	UNIT NOT COOLING IN RM-210,211(T-CAP TESTING TODAY) PLANT MGR-KING/205.8663	5/8/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	CHILLER NOT COOLING THRU ANNEX PLANT MGR-KING/205.8663	5/12/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	3-PUMPS NOT COMING ON. PLANT MGR-KING/205.8663	5/22/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	A/C IN RM 315 - HAS POWER BUT NOT WORKING - NEEDS TO BE RESET - PM/KING 416-9060	5/23/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	A/C MAIN OFC-NOT COOLING- PLANT MGR KING 416-9060 KLR	5/30/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Yearly - Oil Samples-Idlewild Elementary - Refer to PM schedule details.	9/10/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Monthly - Filter-Idlewild Elementary - Refer to PM schedule details.	2/3/14			Heating/Ventilation /Air Conditioning

Idlewild ES (2355) 1A	Monthly - Filter-Idlewild Elementary - Refer to PM schedule details.	6/2/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Monthly - Filter-Idlewild Elementary - Refer to PM schedule details.	9/30/13			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Monthly - Oil Lube & Belts - Idlewild Elem - Refer to PM schedule details.	4/12/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Yearly - Boiler 069 - Idlewild Elem - Boiler Rm - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Idlewild ES (2355) 1A	Plaster wall needs repair.	7/23/13	3rd Floor		Painting
Idlewild ES (2355) 1A	Please patch and large hole in the wall, in between room 308 and the water fountain. Thanks Plant Manger.	8/8/13	Hallway/Corridor	3Rd floor	Painting
Idlewild ES (2355) 1A	Finish and paint sheetrock ceiling at main entry.	7/1/13	Hallway/Corridor		Painting
Idlewild ES (2355) 1A	Please repair leaking faucet, handle is stripped.	4/11/14	Restroom (Boys)	3rd floor	Plumbing

Idlewild ES (2355) 1A	test back flow device-os	7/2/13			Plumbing
Idlewild ES (2355) 1A	DISPOSAL KITCHEN AREA- STOPPED UP-PLANT MGR KING 416-9060 KLR	3/6/14			Plumbing
Idlewild ES (2355) 1A	2-COM SINK IS STOPPED UP IN KITCHEN PLANT MGR-KING/416.9660	8/15/13			Plumbing
Idlewild ES (2355) 1A	Please repair leaking flush value, or floor o-ring. Thanks! Plant Manger	8/19/13	Gym	Boys Restroom	Plumbing
Idlewild ES (2355) 1A	Unstop gutter downspouts	8/30/13			Plumbing
Idlewild ES (2355) 1A	Leaking in outer offices,please repair. Thanks! Plant Manger	9/3/13	Administration Area	Across from main office	Plumbing
Idlewild ES (2355) 1A	Please repair flush kit. Thanks Plant Manger	7/25/13	Restroom (Boys)	3rd fl West	Plumbing
Idlewild ES (2355) 1A	Please replace flush kit. Thanks Plant Manger	7/30/13	Restroom (Boys)	3rd fl	Plumbing

Idlewild ES (2355) 1A	Please clean out stopped up drain. Thanks Plant Manger	7/30/13	Classroom	306 A	Plumbing
Idlewild ES (2355) 1A	Rain gutter outside the northeast corner of the library.	7/23/13	Library		Plumbing
Idlewild ES (2355) 1A	Westend gutter needs cleaning out extremely high.	7/23/13		Front of bldg.	Plumbing
Idlewild ES (2355) 1A	No hot water in the kitchen per Mr. King 416-9060	8/7/13			Plumbing
Idlewild ES (2355) 1A	Please clear stopped up toilet. Thanks! Plant Manger.	10/2/13	Restroom (Boys)	2nd Floor main	Plumbing
Idlewild ES (2355) 1A	Please un stopped 1st and 2nd stalls. Thanks! Plant Manger.	10/2/13	Restroom (Boys)	3Rd floor main	Plumbing
Idlewild ES (2355) 1A	Check chemical feed system for G.E. at Lester.	10/17/13	Mechanical Room		Plumbing
Idlewild ES (2355) 1A	NO HOT WATER TO KITCHEN- PLANT MGR KING 416-4566 KLR	10/28/13			Plumbing

Idlewild ES (2355) 1A	A/C MAIN OFC AREA-LEAKING PER SBE-PLANT MGR KING KLR	10/31/13			Plumbing
Idlewild ES (2355) 1A	Needs flush kit, handle keeps getting stuck, low water pressure. Please repair. Thanks! Plant Manager.	11/1/13	Restroom (Girls)	2nd floor Main	Plumbing
Idlewild ES (2355) 1A	Needs flush kit, handle keeps getting stuck, low water pressure. Please repair. Thanks! Plant Manager.	11/1/13	Restroom (Girls)	2nd floor Main	Plumbing
Idlewild ES (2355) 1A	NO HOT WATER TO KITCHEN AREA-PLANT MGR KING 416- 9060 KLR	11/1/13			Plumbing
Idlewild ES (2355) 1A	SINK IS STOPPED UP IN KITCHEN PLANT MGR-KING/416.4536	11/15/13			Plumbing
Idlewild ES (2355) 1A	Air Handler drain is stopped up leaking on floor. Please correct. Thanks! Plant Manager.	11/22/13	Classroom	100	Plumbing
Idlewild ES (2355) 1A	Please clear stopped up sink. Thanks! Plant Manager.	11/25/13	Restroom (Boys)		Plumbing
Idlewild ES (2355) 1A	Units leaking in ceiling in Main office.	1/2/14	Administration Area		Plumbing

Idlewild ES (2355) 1A	No HOT WATER in the KITCHEN per John King, Plant Mgr. 416.9060.	1/27/14			Plumbing
Idlewild ES (2355) 1A	sewage is backing up in the serving area of cafeteria per Mr. King 416-9060	9/11/13			Plumbing
Idlewild ES (2355) 1A	Units has trash in drain lines,please have lines blown out. Thanks! Plant Manger	9/12/13	Classroom	204	Plumbing
Idlewild ES (2355) 1A	Ceiling heater, waterlines are leaking on ceiling titles. Please repair before soaked ceiling falls on someone. Thanks! Plant Manger.	9/12/13	Hallway/Corridor	1st Floor South (outside of library)	Plumbing
Idlewild ES (2355) 1A	Please repair seats in faucet handles. Thanks! Plant Manager.	4/17/14	Restroom (Girls)	1st and 3rd floor	Plumbing
Idlewild ES (2355) 1A	Please repair flush kit in toilet. Thanks! Plant Manager.	4/17/14	Restroom (Boys)	2nd floor Annex	Plumbing
Idlewild ES (2355) 1A	Please repair flush kits in toilet. Thanks! Plant Manager.	4/17/14	Restroom (Boys)	3rd and 2nd floor main building	Plumbing
Idlewild ES (2355) 1A	Please repair leake in water line, on drinking fountain. Water has been shutoff. Thanks! Plant Manager.	4/25/14	3rd Floor	south wall	Plumbing

Idlewild ES (2355) 1A	Please repair inlet and outlet valves, has a small pin hole leak around the fittings. Thanks! Plant Manager.	5/8/14	Administration Area	Main Office	Plumbing
Idlewild ES (2355) 1A	please replace toilet seat. Thanks! Plant Manager.	5/29/14	Gym	Girls restroom	Plumbing
Idlewild ES (2355) 1A	please replace 2nd stall toilet. thanks! Plant Manager.	5/29/14	Restroom (Boys)	kindergarden	Plumbing
Idlewild ES (2355) 1A	Please replace toilet in the last stall. Thanks! Plant Manager.	5/29/14	Restroom (Girls)	2nd fl near 214A	Plumbing
Idlewild ES (2355) 1A	Please replace toilet. Thanks! Plant Manager.	5/29/14	Restroom (Girls)	3rd fl southeast	Plumbing
Idlewild ES (2355) 1A	Please replace o-ring in middle faucet. Thanks! Plant Manager.	5/29/14	Restroom (Boys)	2nd fl southwest	Plumbing
Idlewild ES (2355) 1A	Please replace toilet in second stall. Thanks! Plant Manager.	5/29/14	Restroom (Girls)	2nd fl southwest	Plumbing
Idlewild ES (2355) 1A	Please replace o-ring on center faucet. Thanks! Plant Manager.	5/29/14	Restroom (Boys)	1st fl southeast	Plumbing

Idlewild ES (2355) 1A	Please repair pin hole leak in the water fountain. Thanks! Plant Manager.	6/5/14	Gym	Basketball Court	Plumbing
Idlewild ES (2355) 1A	Test and/or repair RP devices per MLGW.	8/22/13			Plumbing
Idlewild ES (2355) 1A	Please repair leaking roof, water is pouring onto floor, on the west side. Thanks! Plant Manager.	2/3/14	Gym	West side roof	Roof
Idlewild ES (2355) 1A	Please repair leak at teachers entrance north. Thanks! Plant Manager.	2/4/14	Hallway/Corridor	1st Floor South (outside of library)	Roof
Idlewild ES (2355) 1A	Please replace missing door for roof top unit. Thanks! Plant Manger	8/15/13	Gym	Roof Top Unit	Sheet Metal
Idlewild ES (2355) 1A	Locker is coming off the wall, please secure. Thanks Plant Manger	7/30/13	Classroom	205	Sheet Metal
Idlewild ES (2355) 1A	Air duct is missing vent cover, please replace. Thanks! Plant Manager.	11/22/13	Classroom	309 main building	Sheet Metal
Idlewild ES (2355) 1A	Please repair duct damper. Thanks! Plant Manager.	12/3/13	Administration Area	Main Office	Sheet Metal

Idlewild ES (2355) 1A	NATALIE J CATCHINGS Mr. King, please do a work order for the request below. Thanks. From: OTTO H SCHLAFER Sent: Wednesday, April 30, 2014 8:33 AM To: NATALIE J CATCHINGS Subject: Re: Water Barrels Yes we will support just get the to send us	5/2/14	Grounds	South side of gym	Sheet Metal
-----------------------	--	--------	---------	----------------------	-------------

Count of Craft	Craft								Grand Total
	Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	
Jeter ES (0080) 1B	1	8	26	25	4	41	4	1	110
Grand Total	1	8	26	25	4	41	4	1	110

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Jeter ES (0080) 1B	Please correct boys and girls locker rooms, located in gymnasium. AMG. Also, please observe and modify these areas for upcoming school year, we're going back to 8th grade as these areas will be used on a daily bases.	3/27/14		Gymnasium./boys and girls locker rooms..	Asbestos
Jeter ES (0080) 1B	Replace pipe chase door on back side of gym	7/15/13			Carpentry
Jeter ES (0080) 1B	Please remove the wooden shelves on the window side of the girls locker room to make room for lockers to be installed.	6/20/14			Carpentry
Jeter ES (0080) 1B	Please replace black baseboard on the wall of the yellow hallway in front of the elevator.	4/9/14		Yellow hall/in front of elevator.	Carpentry
Jeter ES (0080) 1B	Adjust all lab tables to ADA height.	5/28/14			Carpentry
Jeter ES (0080) 1B	The closure is broken on the electric room door located in gym.	10/23/13		gymnasium.	Carpentry
Jeter ES (0080) 1B	Please install academic excellence banner on the outside front wall of our school building.	12/9/13			Carpentry
Jeter ES (0080) 1B	The handle on the exit door on the westside of the gym is not attached very well it needs new screws so that we will be able to well secure the building.	2/14/14		gymnasium./exit door on the westside of gym.	Carpentry
Jeter ES (0080) 1B	I don't mean to get ahead of the game plan and apologize in advance if such impression is given. however; my concern is if there will be someone coming out to set our boys and girls locker rooms up for 8th grade, they are in need of lockers, showers	4/1/14		Gymnasium./boys and girls locker rooms..	Carpentry
Jeter ES (0080) 1B	Please run Test. Generator Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical
Jeter ES (0080) 1B	The music rm. *214 upstairs nds. light ballast.	6/20/14		closet/rm*214	Electrical

Jeter ES (0080) 1B	Both storage closets in the upstairs art room nd new ballasts.	6/20/14		upstairs art room.	Electrical
Jeter ES (0080) 1B	The storage closet in the library nds. a light ballast.	6/20/14		Library.	Electrical
Jeter ES (0080) 1B	The water main closet in the text book room nds. a light ballast.	6/20/14		text book room.	Electrical
Jeter ES (0080) 1B	FIRE ALARM IS GOING OFF PLANT MGR-WILLIAMS/873.8172	4/7/14			Electrical
Jeter ES (0080) 1B	A/C UNIT is NOT COMING ON in PLANT MANAGER'S OFFICE per Will Williams, Plant Mgr. 873.8170	5/23/14			Electrical
Jeter ES (0080) 1B	electric ceiling heater on yellow hall won't turn off. cut off at breaker	5/28/14		Yellow hall ceilinh heat	Electrical
Jeter ES (0080) 1B	The light fixture at the top of the stairwell located on the grn.hallway nds a ballast.	7/19/13	2nd Floor	upstairs/top of stairwell on grn.hallway	Electrical
Jeter ES (0080) 1B	The light fixture in the main hallway entrance is in nd. of a ballast.	7/19/13	1st Floor	Main hallway entrance.	Electrical
Jeter ES (0080) 1B	Two of the light fixtures in the dn.stairs teachers lounge needs ballast replacements.	7/24/13	1st Floor	Dn.stairs/teachers lounge.	Electrical
Jeter ES (0080) 1B	The light is out under the breezeway.	7/26/13		Lights under breezeway.	Electrical
Jeter ES (0080) 1B	The outside light on the outside back wall of y-care classroom is in need of a ballast.	7/26/13		outside wall of y-care classroom.	Electrical
Jeter ES (0080) 1B	The light is out in the principals office.The fixture needs a ballast.	7/30/13		PRINCIPals office.	Electrical

Jeter ES (0080) 1B	The outlets on the north,south and east walls in our science lab are not working. This is located in room*207 upstairs.	8/13/13		Upstairs-purple hall.	Electrical
Jeter ES (0080) 1B	The lights in the girls and boys restroom located on the yellow hallway will not come on.it is very dark in the area.	9/23/13		Boys and girls rst.rm./on the yellow hallway.	Electrical
Jeter ES (0080) 1B	Verify data base in burglar alarm panel.	11/1/13			Electrical
Jeter ES (0080) 1B	The wall clock in the gym needs repairing,it does not have the correct time.	12/13/13		gymnasium.	Electrical
Jeter ES (0080) 1B	The two lights underneath the walkway coming out of the main office or main front entrance of the school.these lights does not come on and it's very dark on those persons who leaves at 6:00pm or later.	12/18/13		underneath walkway/coming directly from the main o	Electrical
Jeter ES (0080) 1B	The clock in the gym is not working.	1/7/14		gymnasium.	Electrical
Jeter ES (0080) 1B	The timing is off on the westside of the hallway clock located upstairs on the green hallway.	1/24/14		green hallway/upstairs.	Electrical
Jeter ES (0080) 1B	The alarm has gone off three or four times during the weee hours of the morning/ i think it's some due to power outage in the area and also batteries. not any of the hallway clocks have the correct time currently. please check this out.	2/3/14		gymnasium.	Electrical
Jeter ES (0080) 1B	FIRE ALARM IS SHOWING TROUBLE PLANT MGR-WILLIAMS/846.9898	2/5/14			Electrical
Jeter ES (0080) 1B	Replace battery in generator	2/5/14			Electrical
Jeter ES (0080) 1B	The electric heater in the sprinkler room located in the gymnasium is not working.	3/6/14		sprinkler rm./gymnasium.	Electrical
Jeter ES (0080) 1B	Please reset the time on the outside lights, have them to go off at 7:00am in the morning and come on at 7:00pm in the afternoon.	3/21/14		outside of school.	Electrical

Jeter ES (0080) 1B	UNIT NOT COOLING IN CAFE PLANT MGR-WILLIAMS/873.8172	4/11/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	The heating vent in the storage room located next to the data room on the yellow hallway is blowing out constant heat none stop. i cannot turn it off.	5/27/14		yellow hallway.	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	Wash units	5/28/14		Gym cafe library	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	A/C IN TEACHER'S LOUNGE 2ND FLR & LIBRARIAN'S OFC-BOTH NOT COMING ON-PLANT MGR WILLIAMS 873-9170 KLR	8/26/13			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	ROOM 201 IS BLOWING COLD AIR (ROOM IS IN HEAT MODE)	11/5/13		ROOM 201	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	Classroom *201 upstairs is very cold,the fan is blowing but there is only air coming out, no heat.	11/6/13		Classroom*201/upstairs.	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	HEAT RM 201-NOT HEATING-PLANT MGR WILLIAMS 873-8170 KLR	11/6/13			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	The heat is not working in the following classrooms/ classroom*102, 204,205 and *206/in classrooms *204 and 205, it just blows cold air no heat,however; in classrooms *102 and 206,it's not coming on at all.	11/12/13		Classrooms*102,204,205 and*206	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	The kitchen is very cold, only cold air is blowing out of the vents.	11/13/13		Kitchen.	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	The ceiling fan heater located at the main entrance door in vestaview area in front of the main office is not working.	11/13/13		Main hallway entrance.	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	It is very cold in the plant managers office, the vent is blowing out cold air.	11/14/13		Plantmanagers office.	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	It is cold in the cafeteria dining area.	11/15/13		cafe. dining room.	Heating/Ventilation /Air Conditioning

Jeter ES (0080) 1B	UNIT NOT HEATING IN RM-111. PLANT MGR-WILLIAMS/873-8172	12/12/13			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	HEAT RMS 100, 202, LIBRARY, 2ND FLR RMS 200, 201, 202, & 204-ALL NOT HEATING-PLANT MGR WILLIAMS 873-8170 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	HEAT RMS 111, LIBRARY, 2ND FLR RMS 210 & 213-ALL NOT COMING ON-PLANT MGR WILLIAMS 873-8170 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	HEAT RM 201-NOT HEATING-PLANT MGR WILLIAMS 353-8580 KLR	1/9/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	HEAT RM 110-NOT HEATING-PLANT MGR WILLIAMS 873-8170 KLR	1/24/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	repair heat in room 213	1/29/14		Room 213	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	CHECK THE UPS POWER SUPPLY TO THE EMS PANEL	2/5/14		EMS	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	HEAT PRIN'S OFC-NOT HEATING- PLANT MGR WILLIAMS 873-8170 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	UNIT NOT HEATING IN RM- 107,206,210 PLANT MGR-WILLIAMS/873.8172	2/7/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	Replaced blower bracket	2/10/14		Rm 102	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	per will williams 873-8170 room 101 is blowing cold	2/13/14			Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	PM gym unit	7/18/13		Gym	Heating/Ventilation /Air Conditioning

Jeter ES (0080) 1B	We have a water drip coming from the ceiling in our text book room, located on the yellow hallway downstairs.	7/15/13	1st Floor	yellow hallway/text book rm.	Heating/Ventilation /Air Conditioning
Jeter ES (0080) 1B	Please paint the boys and girls locker room.	6/9/14		gymnasium.	Painting
Jeter ES (0080) 1B	Please touch up paint on hallways as necessary.	6/27/14		hallways/ entreties	Painting
Jeter ES (0080) 1B	Please paint the exit doors located on the red hallway.	6/9/14		First floor hallway of school building.	Painting
Jeter ES (0080) 1B	Newly installed door on back of gym is ready to be painted	7/17/13			Painting
Jeter ES (0080) 1B	Please repair the shower heads on showers in the boys and girls locker rooms.	6/9/14		locker rooms.	Plumbing
Jeter ES (0080) 1B	Please install water heater for the shower rooms.	6/9/14			Plumbing
Jeter ES (0080) 1B	Please replace or refinish the sinks in the boys and girls shower rooms.	6/9/14		locker rooms.	Plumbing
Jeter ES (0080) 1B	Please check the flush valves in the boys and girls locker rooms.	6/9/14		Locker rooms.	Plumbing
Jeter ES (0080) 1B	Please check the flush valves in the boys and girls restrooms, located in the front gym lobby.	6/9/14		Gymnasium.	Plumbing
Jeter ES (0080) 1B	Repair the drain in the main building.	7/12/13			Plumbing
Jeter ES (0080) 1B	Please repair the flush valves in the toilet located between classrooms *107 and 109.	6/20/14		classrooms 107,109	Plumbing

Jeter ES (0080) 1B	Check shower heads and shower valves in boys and girls locker rooms. Repair or replace as necessary.	6/26/14			Plumbing
Jeter ES (0080) 1B	replace hot water heater for boys and girls showers. See Kirk for size	6/27/14			Plumbing
Jeter ES (0080) 1B	Replace handle on mop sink red hall boys restroom.	7/16/13			Plumbing
Jeter ES (0080) 1B	Unstop drain on mop sink red hall boys restroom.	7/16/13			Plumbing
Jeter ES (0080) 1B	Tighten toilet seat red hall boys restroom.	7/16/13			Plumbing
Jeter ES (0080) 1B	Unstop mop sink red hall girls restroom.	7/16/13			Plumbing
Jeter ES (0080) 1B	Tighten 4th toilet seat yellow hall girls restroom.	7/16/13			Plumbing
Jeter ES (0080) 1B	Tighten 7th toilet seat yellow hall girls restroom.	7/16/13			Plumbing
Jeter ES (0080) 1B	Please chk. our eye wash station upstairs , it has been suggested that it is possibly leaking.	7/17/13	2nd Floor		Plumbing
Jeter ES (0080) 1B	Please turn the outside water hydrogens on.	4/11/14		outside water hydrogen.	Plumbing
Jeter ES (0080) 1B	The sewer pipe to the kitchen dishwasher is backing up.	5/23/14		kitchen.	Plumbing
Jeter ES (0080) 1B	We have a water leak some place in the janitorial closet in the boys rst.rm. on the red hallway.	8/23/13		Janitorial closet on red hall/boys rst.rm.	Plumbing

Jeter ES (0080) 1B	The steamer filter in the kitchen needs cleaning or replacing badly.	9/6/13		Kitchen.	Plumbing
Jeter ES (0080) 1B	Please test the following RP 564216 1" 909 Watts 2nd Fl. Custodial	9/19/13			Plumbing
Jeter ES (0080) 1B	Please test the following RP 562219 1" 909 Watts	9/19/13			Plumbing
Jeter ES (0080) 1B	Please test the following RP 393086 2" 909 Watts	9/19/13			Plumbing
Jeter ES (0080) 1B	Please test the following RP 395354 2" 909 Watts	9/19/13			Plumbing
Jeter ES (0080) 1B	Please repair the toilet in the teachers work room, located on the first floor.	11/11/13		teachers work room.	Plumbing
Jeter ES (0080) 1B	Please repair the first toilet in the boys restroom, located on the red hallway.	11/11/13		boys restroom/ on red hallway.	Plumbing
Jeter ES (0080) 1B	Please repair the toilet located in the principals office.	11/11/13		PRINCIPals office.	Plumbing
Jeter ES (0080) 1B	Please repair the first toilet in the girls restroom, located near room *207 upstairs.	11/11/13		Girls restroom.	Plumbing
Jeter ES (0080) 1B	The toilet seat is broken in the girls restroom located in the gym lobby.	12/13/13		girls restroom/gym lobby.	Plumbing
Jeter ES (0080) 1B	The toilet seat is broken in the last stall of the girls restroom located on the yellow hallway.	12/13/13		girls restroom/yellow hallway.	Plumbing
Jeter ES (0080) 1B	Please repair the faucet on the girls side, located on the red hallway.	12/18/13		Red hall.	Plumbing

Jeter ES (0080) 1B	Please repair the girls handicap toilet located in the restroom on the purple hallway.	12/18/13		upstairs purple hallway.	Plumbing
Jeter ES (0080) 1B	Please unstop two sinks located in the boys restroom rear of gymnasium.	1/14/14		gymnasium.	Plumbing
Jeter ES (0080) 1B	Please repair the 3rd urinal in the boys restroom, located in the rear of gym.	1/14/14		boys restroom /gym.	Plumbing
Jeter ES (0080) 1B	Repair toilet in the boys restroom rear of gym.	1/14/14		boys rst.rm./gymnasium.	Plumbing
Jeter ES (0080) 1B	Please repair the toilet in the girls restroom located in the rear of gym.	1/14/14		girls restroom/gymnasium.	Plumbing
Jeter ES (0080) 1B	Please unclog sink in main office location.	1/15/14		main office.	Plumbing
Jeter ES (0080) 1B	The hand wash sink in the kitchen is leaking water.	1/24/14		Kitchen.	Plumbing
Jeter ES (0080) 1B	Turn water to the gym off.	3/5/14			Plumbing
Jeter ES (0080) 1B	Turn off water and turn it back on once power comes back on	3/6/14			Plumbing
Jeter ES (0080) 1B	The water faucet on the outside west gym wall has a constant slow water flow,not a drip but a flow.	7/19/13		outside/on west gymnasium wall.	Plumbing
Jeter ES (0080) 1B	The gym teachers office located in the gymnasium has a bad roof leak.	2/7/14		gymnasium.	Roof
Jeter ES (0080) 1B	The boys locker room located in the gym has a roof leak.	2/7/14		gymnasium.	Roof

Jeter ES (0080) 1B	The utility work room off the dock of the gymnasium has a roof leak.	2/7/14		gymnasium.	Roof
Jeter ES (0080) 1B	There is a bad leak coming from the ceiling in the gym teachers office, it has a bad smell. It also leaks badly in girls and boys locker room in same location.	3/19/14		gymnasium.	Roof
Jeter ES (0080) 1B	We have two hand rails thats about to dis attach from the wall on the stairwells leading to the second floor.	6/5/14		Stairwells.	Sheet Metal

Count of Craft	Craft								
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Weystone ES (2368)	1	1	20	66	69	2	30	5	194
Grand Total	1	1	20	66	69	2	30	5	194

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Keystone ES (2368) 1B	remove carpet and replace with floor tile	5/1/14	Classroom	16 classrooms	Asbestos
Keystone ES (2368) 1B	C38 data port is not working in Room B123. Need repairs (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	10/29/13	Classroom	B123	Cabling
Keystone ES (2368) 1B	Door closure broken off and Plant Mgr. left it in Financial Sec. office.	4/3/14	Administration Area	Ladies restroom in Main Office	Carpentry
Keystone ES (2368) 1B	ENTRANCE DOOR GYM AREA-CTR MULL BROKEN, WON'T BE ABLE TO SECURE-PLANT MGR BYERS 416-0906 KLR	3/27/14			Carpentry
Keystone ES (2368) 1B	roof leaking at the front of the main office area	3/6/14	Administration Area		Carpentry
Keystone ES (2368) 1B	FRONT ENTRANCE DOOR-CTR MULL HAS SCREWS MISSING, CAN'T SECURE-PLANT MGR BYERS 416-0906 KLR	2/10/14			Carpentry
Keystone ES (2368) 1B	Cold air is coming thru walls per teacher. See classroom teacher for location	2/7/14	Classroom	B101A	Carpentry
Keystone ES (2368) 1B	Windows are leaking and need caulking	2/5/14	Administration Area	A103 and 105A	Carpentry
Keystone ES (2368) 1B	Exterior Cafe doors facing front entrance are difficult to open--could be a fire hazard.	1/9/14	Cafeteria	Exterior Cafe doors	Carpentry
Keystone ES (2368) 1B	Need 4 paper towel holders installed into concrete wall for students use. Plant Manager is not equipped with tools.	12/17/13	Hallway/Corridor	Boys restrooms	Carpentry

Keystone ES (2368) 1B	need 10 boxes of soft tile (atten. Mr. Means)	1/2/14	Kitchen		Carpentry
Keystone ES (2368) 1B	6 ceiling tiles which are over 8 ft. high need to be replaced in gym and 3 floor tiles are loose and need to be glued back down.	7/22/13	Gym	Court area	Carpentry
Keystone ES (2368) 1B	Sink countertop in classroom need to be re-glued.	7/25/13	Classroom	Room B104-A	Carpentry
Keystone ES (2368) 1B	Need 4x8 bullentine board(cork) aand not white board installed in each room. Room D103 and D-105	7/29/13	Classroom	Roomas D-103 and D105	Carpentry
Keystone ES (2368) 1B	Need 2 boxes of ceiling tiles and 2 boxes of 46807 lamps for ceiling fixtures.	8/2/13	Administration Area	Entire building	Carpentry
Keystone ES (2368) 1B	Window closest to coach's office is leaking and leaving puddles of water on floor. Need repairs	8/5/13	Gym	By coach's office	Carpentry
Keystone ES (2368) 1B	Door to AHU 3,4 and 5 closet is stuck and door need to be rehung. Plant Manager cannot get inside.	8/16/13	Hallway/Corridor	Door to AHU closet	Carpentry
Keystone ES (2368) 1B	Teacher is requesting a 4x8 dry erase board in classroom	8/27/13	Classroom	D122	Carpentry
Keystone ES (2368) 1B	KNOB HAS COME COMPLETELY OFF DOOR TO RM C111-DOOR IS OPEN NOW-PLANT MGR BYERS KLR	8/30/13			Carpentry
Keystone ES (2368) 1B	Reattach the pull-up bars to concrete wall in gym.	9/25/13	Gym	Court area	Carpentry
Keystone ES (2368) 1B	inside door knob has fallen off room D103 per Ms. Pat Byers 416-0609	10/18/13			Carpentry

Keystone ES (2368) 1B	Need tiles replaced because of water over flowing onto floor.	1/7/14	Gym	Court area by window	Carpentry
Keystone ES (2368) 1B	FIRE ALARM IS SHOWING TROUBLE PLANT MGR/BYERS/416.3924	4/3/14			Electrical
Keystone ES (2368) 1B	Need lamps for light fixtures in ceiling. Need 5 boxes for classrooms having TCAP tests.	4/21/14	Administration Area	Hallways and classrooms	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture. All new lights in fixture.	4/23/14	Classroom	Room D125	Electrical
Keystone ES (2368) 1B	UNIT NOT COMING ON IN RM-C118 PLANT MGR-BYERS/416.3924	5/2/14			Electrical
Keystone ES (2368) 1B	FIRE ALARM SYSTEM CONSTANTLY BEEPING PER PRIN-CALLED IN BY WHEADON KLR	3/28/14			Electrical
Keystone ES (2368) 1B	UV HAS A BURNING SMELL IN RM-D126 PLANT MGR-BYERS/416.4108	2/12/14			Electrical
Keystone ES (2368) 1B	Need clocks and bells reset because of Day light savings time.	3/17/14	Administration Area	Main Office and Hallway	Electrical
Keystone ES (2368) 1B	HEATING UNIT RM D126-HAS A BURNING SMELL-PLANT MGR BYERS 416-0906 KLR	2/25/14			Electrical
Keystone ES (2368) 1B	per Ms. Byers 416-0906 room B118 not coming on at all	1/27/14			Electrical
Keystone ES (2368) 1B	2 bad ballasts in Science lab with a ceiling more that 8 ft high. Science lab is in back mall.	1/28/14	Classroom	Science Lab-Room C111	Electrical

Keystone ES (2368) 1B	Bad ballast in classroom. Light is flickering on and off.	1/24/14	Classroom	Room D110	Electrical
Keystone ES (2368) 1B	HEAT B120, B119, COMPUTER RM, & C118-ALL NOT COMING ON-PLANT MGR BYERS 416-0906 KLR	1/7/14			Electrical
Keystone ES (2368) 1B	HEAT RMS B102 & B104-BOTH NOT COMING ON-PLANT MGR BYERS 416-0906 KLR	1/7/14			Electrical
Keystone ES (2368) 1B	1. Need Dulux D 26 watts Compact fluorescent bulb for hallway lights. Need 24 each. 2. Also need 3 boxes of lamps for ceiling light fixtures-46758 ?	1/9/14	Hallway/Corridor	Entire building	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture in office.	1/7/14	Gym	Coach's Office	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture in hallway. Need replacement.	12/11/13	Hallway/Corridor	3rd/4th Hallway	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture. Need replacement	12/12/13	Classroom	Room B104A	Electrical
Keystone ES (2368) 1B	Fix lights in mall area.	12/20/13			Electrical
Keystone ES (2368) 1B	Fix lights in mall area.	12/20/13			Electrical
Keystone ES (2368) 1B	broken receptical on south wall, unit hanging from wall area (child hazzard)	1/2/14	Cafetorium		Electrical
Keystone ES (2368) 1B	three way light switch on eastwall has broken finger switch with tape over it.	1/2/14	Cafetorium		Electrical

Keystone ES (2368) 1B	light switch not working properly, will not turn off lights	1/2/14	Gym		Electrical
Keystone ES (2368) 1B	light switch on south wall not turning the lights off at night (half on/half off)	1/2/14	Hallway/Corridor	(purple hallway)	Electrical
Keystone ES (2368) 1B	broken thermostat on wall at entrance way.	1/2/14	Restroom (Boys)	by the bluehall	Electrical
Keystone ES (2368) 1B	Sign which says Summer School has been put up on building and it needs to be taken down because summer school is over. Sign is over 8 ft high	7/22/13	Parking Lot	Front of main building	Electrical
Keystone ES (2368) 1B	Three light fixture have bulbs which need to be replaced. Light fixtures are higher than 8ft. May need lift or extension ladder	7/25/13	1st Floor	Common Area	Electrical
Keystone ES (2368) 1B	Plant Manager need light key to turn on lights when coming into building. Principal has no keys and requested this requisition	7/25/13	Administration Area	Entire Building	Electrical
Keystone ES (2368) 1B	Bells need to be reset before the start of school. The times are: 8:55, 9:00, 3:55, 4:00 and 4:15.	7/26/13	Administration Area	Main Office	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture in Library and need to be replaced.	7/29/13	Library	A-125-B	Electrical
Keystone ES (2368) 1B	Plant Manager need two outlets in office. Office only has one outlet at door and electrical cords are running all over floor as well as bulletin boards. Safety hazard.	7/31/13	Administration Area	Plant Manager's Office	Electrical
Keystone ES (2368) 1B	On stairs by stage the outlet cover is broken and needs to be replaced.	8/5/13	Cafeteria	On stage area	Electrical
Keystone ES (2368) 1B	Master clock for bells need to be reset for bells. Not ringing on time.	8/6/13	Administration Area	Master clock for bells	Electrical

Keystone ES (2368) 1B	Emergency lights flickering on and off.	8/7/13	Library	A125	Electrical
Keystone ES (2368) 1B	CEILING A/C UNIT-G COMPUTER RM 117-NOT COMING ON-SBE BYERS 416-0906 KLR	8/12/13			Electrical
Keystone ES (2368) 1B	A/C RM D109-NOT COMING ON-SBE BYERS 416-0906 KLR	8/14/13			Electrical
Keystone ES (2368) 1B	Exhaust fan not working in ladies restroom	8/22/13	Cafeteria	Ladies restroom	Electrical
Keystone ES (2368) 1B	Two outlets not working in Manager's office	8/22/13	Cafeteria	Manager's office	Electrical
Keystone ES (2368) 1B	Bad ballasts in 2 light fixtures.	8/22/13	Classroom	Room C-104 Music	Electrical
Keystone ES (2368) 1B	Check outside lights because grounds are dark and a safety issue.	8/27/13	Grounds	Outside grounds	Electrical
Keystone ES (2368) 1B	Need 5 boxes of lamps for replacement light fixtures	9/3/13	Administration Area	Entire building	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixtures	9/3/13	Classroom	Rooms B103A and B124	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture.	9/3/13	Library	Main Hall	Electrical
Keystone ES (2368) 1B	Bad ballast in mechanical room. very dark.	9/13/13	Mechanical Room	A157-A	Electrical

Keystone ES (2368) 1B	Bad ballast in light fixtures and need ballast replaced.	9/16/13	Classroom	Rooms B124, D108, D104, C117 and Cafeteria	Electrical
Keystone ES (2368) 1B	Need replacement quad-tube fluorescent lamps--13W and 4 Pin. Panasonic model number is FDS13E27/4. Need 1 case of lamps.	9/16/13	Administration Area	Front Mall and Main Office	Electrical
Keystone ES (2368) 1B	Need 3 boxes of lamps for replacement in ceiling all over school.--46807	9/16/13	Administration Area	Entire building	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture at front of office. Need replacement	9/17/13	Administration Area	Room A152	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixtures in each area. Need replacement.	9/25/13	Administration Area	Principal conference room, Bookstore and Fax room	Electrical
Keystone ES (2368) 1B	Light needs a ballast	10/9/13	1st Floor	B120	Electrical
Keystone ES (2368) 1B	Plant Manager needs help with light fixtures in kitchen area.	10/16/13	Kitchen	Food Prep area	Electrical
Keystone ES (2368) 1B	Plant Manager need 3 boxes of lamps for replacement light fixtures.	10/16/13	Administration Area	Plant Manager's office	Electrical
Keystone ES (2368) 1B	Secondary clocks in hallway are not working. Need repairs.	10/29/13	Hallway/Corridor	By main office	Electrical
Keystone ES (2368) 1B	UV IS MAKING NOISE IN RM-D107. PLANT MGR-BYERS/416.0906	10/30/13			Electrical
Keystone ES (2368) 1B	CHILLER NOT COMING ON-PLANT MGR BYERS 416-0906 KLR	10/31/13			Electrical

Keystone ES (2368) 1B	Set clock back for daylight saving time.	11/1/13	Administration Area	Main Office	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture. Need replacement	11/6/13	Classroom	D103	Electrical
Keystone ES (2368) 1B	unit in computer lab is making loud noise per Ms. Byers 416-0906	11/12/13			Electrical
Keystone ES (2368) 1B	LIGHT IN FREEZER HAVE NO POWER PLANT MGR-BYERS/416.6112	11/14/13			Electrical
Keystone ES (2368) 1B	AHU NOT HEATING IN MAIN OFFICE PLANT MGR-BYERS/489.6112	11/14/13			Electrical
Keystone ES (2368) 1B	3 bad ballasts in light fixtures. 1st three fixtures.	11/15/13	Administration Area	Professional Library	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture. Need replacement	11/15/13	Restroom (Boys)	Kindergarten area	Electrical
Keystone ES (2368) 1B	Bad ballast in light fixture. Need replacement	11/15/13	Administration Area	Parent Resource Center	Electrical
Keystone ES (2368) 1B	1 ballast bad in light fixture on stage and lights need replacing on stage which is higher than 8 foot.	11/20/13	Cafeteria	On Stage	Electrical
Keystone ES (2368) 1B	Please deliver 10 fluorescent 26 watt light bulbs. (catalog #10218)	5/14/14		building engineer office	Electrical
Keystone ES (2368) 1B	Five lights in ceiling are not working. Will need a lift to replace lights.	4/15/14	1st Floor	2nd Mall by Gym	Electrical

Keystone ES (2368) 1B	Need a telephone for new SPED clerical employee	10/18/13	Administration Area	SPED clerical	Electrical
Keystone ES (2368) 1B	UNIT NOT COOLING THRU ENTIRE 1ST-2ND GRADE HALLS PLANT MGR-BYERS/489.6112	5/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C OUTSIDE GARDEN CLASSRM- MAKING NOISES-PLANT MGR BYERS 416-0906 KLR	5/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HVAC unit not working in common area behind restrooms on 4th and 5th grade hall.	6/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	AHU #1 in mechanical room A-120 not working. Unit not on and pouring water from bottom. Have water valves at unit in off position to avoid flooding.	6/13/14	Administration Area		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	purchase compressors for main office	6/20/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	main office not cooling	6/23/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	remove freon from chiller so repairs can be made	5/13/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	install new tail bearing in chiller	5/13/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HVAC unit not working. Pre school classroom has no a/c. No power to thermostat.	5/13/14	Classroom	106 A	Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	per Ms. Byers 416-0906 library blowing cold air	12/12/13			Heating/Ventilation /Air Conditioning

Keystone ES (2368) 1B	BOILER MECH RM-NOT HEATING-AFFECTS ENTIRE BLDG-PLANT MGR BYERS 416-0906 KLR	12/13/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	BOILER is NOT COMING ON per Ms. Byers, Plant Mgr. 416.0906	12/2/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	rooms B101A and B103A units will not come on per Ms. Byers 416-0906	12/3/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	The unit in the ISS Building, Room D101 is NOT HEATING per Ms. Byers, Plant Mgr. 416.0906	12/4/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	4-UV NOT HEATING IN RM-C117,D126,B103A,B101A PLANT MGR-BYERS/416.3924	12/10/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HEAT RMS D125, D122, B101A, B106A, B103A, & A153-ALL NOT HEATING PER PRIN-CALLED IN BY PRIN WHEEDON 416-3924 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HEAT RM D126-NOT COMING ON PER PRIN-CALLED IN BY PRIN WHEEDON 416-3924 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HEAT B 105, B101, B103, B106, B121, B122, B125, D102, D104, D103, D106, D108, D121, D125, D122, GUIDANCE OFC, & LIBRARY-ALL NOT HEATING-PLANT MGR BYERS 416-0906 KLR	1/7/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT NOT HEATING IN CAFE PLANT MGR-BYERS/416.3924	12/12/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT NOT COMING ON IN RM-B106A PLANT MGR-BYERS/416.3924	1/24/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	BOILER IS SHOWING FLAME FAILURE PLANT MGR-BYERS/416.3924	1/28/14			Heating/Ventilation /Air Conditioning

Keystone ES (2368) 1B	UV NOT HEATING IN RM-B101,B118,117,B119,B124,B125,ART RM,COMPUTER RM,D108,D109,D122,D124,D125,A124,A153,MAIN OFFICE. PLANT MGR-BYERS/416.3924	1/24/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HEAT RM B103A, B106A, & B101A-ALL NOT HEATING-PLANT MGR BYERS 416-0906 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	BOILER MECH RM-IN ALARM, FLAME FAILURE-PLANT MGR BYERS 416-0906 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	BOILER is NOT HEATING in the ENTIRE BUILDING per Mr. Byers, Plant Mgr. 416.0906	2/7/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT NOT HEATING IN RM-B103A,106A, B101A PLANT MGR-BYERS/416.3924	2/7/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	per ms byers 416-0906 the boiler has been in flame failure all week and has had to be reset every time also room B106A is not blowing hot enough	2/7/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	repair air in main office and principals office	2/19/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Monthly - Filter-Keystone Elementary - Refer to PM schedule details.	2/23/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	per Karen Pyun (asst principal) there is no heat in the entire building - it is blowing cold air	2/11/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	per ms byers 416-0906 room B106A coil is busted on hvac unit	3/25/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning

Keystone ES (2368) 1B	Monthly - AirCompress#066 Mech rm157A/2/9/14 Keystone Elm - Refer to PM schedule details.			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Monthly - Oil Lube & Belt-Keystone Elementary - Refer to PM schedule details.	2/7/14		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HEAT RM B106A-MAKING A SQUEALING NOISE-PLANT MGR BYERS 416-0906 KLR	12/12/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT NOT HEATING IN MAIN OFFICE PLANT MGR-BYERS/416.3924	12/12/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Air Handler unit #5 (which is for the CAFETERIA) is OVERHEATING per Pat Byers, Plant Mgr. 416.0906	1/10/14		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Monthly - Oil Lube & Belt-Keystone Elementary - Refer to PM schedule details.	7/5/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Unit Running but NOT COOLING in the Main office (Principal's office)! Per Mr. Campbell, Sub Plant Mgr. at 901.416.3924. Principal conducting interviews today!	7/9/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Cooling Tower not coming on Entire building is hot Pat Byers 416-3924	7/15/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT IN THE D101,D108, COMMON AREA IS NOT COOLING. SBE BYERS 416-4108	7/22/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT IN THE PRINC OFFICE IS NOT COOLING. SBE BUYERS 416-0906	7/31/13		Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C UNIT RM D110-NOT COOLING-SBE BYERS 416-0906 KLR	7/31/13		Heating/Ventilation /Air Conditioning

Keystone ES (2368) 1B	UNIT VENT - RM B104A - BLOWING NOT COOLING PM/BUYERS 416-9661	8/1/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C UNIT RM D101 & A/C UNIT RM B123-BOTH NOT COOLING-SBE BYERS 416-0906 KLR	8/5/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Six (6) A/C units NOT COOLING in Rooms A122, B117, B119, B123, D101 and D 106 per Ms. Pat Byers at 901.416.0906	8/6/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	chill water valve is stuck in mechanical room ID#100120 per Pat Byers 416-0906	8/7/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C IN RM D100-NOT COOLING-SBE BYERS KLR	8/9/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Monthly - AirCompress#066 Mech rm157A Keystone Elm - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Cafeteria Temp. is too LOW per principal Temp is set at 64 degrees per Pat Byers, Plant Mgr. 901.416.0906.	8/16/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Unit ventilators NOT COOLING in rooms D108 and D110 per Pat Byers, Plant Manager at 901.416.0906	8/22/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UV NOT COOLING IN RM-B119 PLANT MGR-BYERS/416.3924	8/22/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C IN RMS B117, B103A, B101A, C111, B126, B123, B124, B119, A121, D124, D125, D110, D103, D101, & C117-ALL NOT COOLING-PLANT MGR BYERS 416-3924 KLR	8/30/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	chiller is down per Ms. Weeden Principal 416-3924	10/14/13			Heating/Ventilation /Air Conditioning

Keystone ES (2368) 1B	CHILLER NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR BYERS 416-0906 KLR	10/15/13				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UNIT NOT COMING ON IN RM-C102. PLANT MGR-BYERS/416.3924 *Electrician checked running) teacher not satisfied with leavel of cooling.jd	10/22/13				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	HEAT RM B103-NOT HEATING-PLANT MGR BYERS 416-3924 KLR	11/13/13				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	BOILER-NOT HEATING-AFFECTS ENTIRE BLDG-PLANT MGR BYERS 416-0609 KLR	11/19/13				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	BOILER NOT HEATING-AFFECTS ENTIRE BLDG-CALLED BY PRIN WEEDEN 416-3924 KLR	11/25/13				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	UV NOT HEATING IN RM-B103A,B101A PLANT MGR-BYERS/416-4108	11/26/13				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	purchase parts for chiller	5/9/14				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C not working in room C 117. (computer lab)	6/24/14	Classroom		c 117	Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	CHILLER - NOT COMING ON - PRIN/WEEDON 416-3924	6/30/14				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	A/C MAIN OFC-NOT COOLING-PLANT MGR GREGORY KLR	6/17/14				Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Monthly - Filter-Keystone Elementary - Refer to PM schedule details.	10/20/13				Heating/Ventilation /Air Conditioning

Keystone ES (2368) 1B	Yearly - Oil Samples - Keystone Elem - Refer to PM schedule details.	9/6/13			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Yearly - Boiler - Keystone El - Mech Rm A158A - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Yearly - Cooling Towers(STRAINERS)- Keystone Elem - Refer to PM schedule details.	3/15/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Monthly - Filter-Keystone Elementary - Refer to PM schedule details.	6/22/14			Heating/Ventilation /Air Conditioning
Keystone ES (2368) 1B	Paint fence by neighbors house on side of school	4/4/14			Painting
Keystone ES (2368) 1B	touchup hallways thruout	2/5/14			Painting
Keystone ES (2368) 1B	(2) COMMODES G RR KINDERGARTEN AREA-NOT FLUSHING-PLANT MGR BYERS 416-0906 KLR	4/2/14			Plumbing
Keystone ES (2368) 1B	Handwashing sink has very low water pressure in Kitchen	4/3/14	Kitchen	Handwashing sink	Plumbing
Keystone ES (2368) 1B	Hand washing sink is running. Need repairs	4/16/14	Restroom (Girls)	2nd rade hall	Plumbing
Keystone ES (2368) 1B	Commode keeps overflowing when it is flushed	4/23/14	Restroom (Girls)	1st Grade Hall	Plumbing
Keystone ES (2368) 1B	Water cooler in 5th grade hall has no button to push for water. Need repairs.	3/19/14	Hallway/Corridor	Water cooler in 5th Grade hall	Plumbing

Keystone ES (2368) 1B	Flush valve on commode not working. Need repairs.	3/20/14	Administration Area	Teacher's Lounge-Women side	Plumbing
Keystone ES (2368) 1B	Sinks in classrooms D105 and D107 are stopped up and leaking onto floor. Need repairs.	3/20/14	Classroom	Rooms D105 and D107	Plumbing
Keystone ES (2368) 1B	Small water cooler going into Cafeteria is not working and need repairs.	2/21/14	1st Floor	At Cafeteria entrance	Plumbing
Keystone ES (2368) 1B	No cold water--not cooling.	2/21/14	1st Floor	By Science room	Plumbing
Keystone ES (2368) 1B	Big water cooler has no button to push for water. You may find parts for this at Greys Creek.jd	2/21/14	1st Floor	By Computer room	Plumbing
Keystone ES (2368) 1B	URINAL B RR KINDERGARTEN AREA-CONSTANLY OVERFLOWING, CAN'T CONTAIN OR CUT OFF-PLANT MGR BYERS 416-0906 KLR	1/14/14			Plumbing
Keystone ES (2368) 1B	After commode fills up, it continues to run. Need repairs.	1/21/14	Restroom (Boys)	5th Grade Hall	Plumbing
Keystone ES (2368) 1B	Water fountain in main office hallway will not drain.	1/21/14	Hallway/Corridor	In Main Office hallway	Plumbing
Keystone ES (2368) 1B	First commode floods over the floor when commode handle is held down. Needs repairs	1/22/14	Restroom (Boys)	Kindergarten hall	Plumbing
Keystone ES (2368) 1B	aucet is dripping and has been for some time. Principal need repaired	12/11/13	Hallway/Corridor	5th grade area	Plumbing
Keystone ES (2368) 1B	Last commode has problem with flush valve. Commode will not flush at all.	7/18/13	Restroom (Boys)	5th grade hall	Plumbing

Keystone ES (2368) 1B	Commode is stopped up and will not flush. Need repairs immediately	7/18/13	Restroom (Girls)	1st and 2nd grade hall	Plumbing
Keystone ES (2368) 1B	TOILETS BASE IS RUNNING WATER & CAUSING A FLOOD IN G/RR 1ST GRADE HALL. PLANT MGR-BYERS/416.3924	8/5/13			Plumbing
Keystone ES (2368) 1B	UV IS LEAKING WATER INTO COMPUTER LAB RM IN RM-C117. PLANT MGR-BYERS/416.4108	8/6/13			Plumbing
Keystone ES (2368) 1B	Unit ventilator leaking Room D105 per Pat Byers 416-0609	8/8/13			Plumbing
Keystone ES (2368) 1B	KITCHEN SINK IS STOPPED UP, & TOILET IS OVERFLOWING IN KK/RR PLANT MGR-BYERS/416.3924	8/27/13			Plumbing
Keystone ES (2368) 1B	CLASS SINK IS STOPPED UP IN RM- D105 PLANT MGR-BYERS/416.3924	8/27/13			Plumbing
Keystone ES (2368) 1B	COMMODOE B RR KINDERGARTEN HALL 3RD STALL-CONSTANTLY OVERFLOWING-PLANT MGR BYERS 416-3924 KLR	9/3/13			Plumbing
Keystone ES (2368) 1B	Men's RR in the MAIN OFFICE is NOT flushing per Pat Byers, Plant Mgr 416.0690.	9/11/13			Plumbing
Keystone ES (2368) 1B	UV IS LEAKING WATER RM=124 ON CARPET PLANT MGR-BYERS/416.3924	9/13/13			Plumbing
Keystone ES (2368) 1B	Test and repair RP Devices per MLG&W.	10/16/13	Mechanical Room		Plumbing
Keystone ES (2368) 1B	Urinal stopped up in restroom. Need repairs	10/22/13	Restroom (Boys)	4th/5th Grade hall	Plumbing

Keystone ES (2368) 1B	SINK 1ST/2ND GRADES RR AREA-AUTOMATED FAUCET RUNNING AT MORE THAN A FULL FORCE PER PRIN-CAN'T CUT OFF-CALLED IN BY DR WEEEDEN 416-3924 KLR	5/6/14			Plumbing
Keystone ES (2368) 1B	Last commode next to wall has a flush valve problem. Hard to flush	3/24/14	Restroom (Girls)	Kindergarten hallway	Plumbing
Keystone ES (2368) 1B	(2) COMMODES B RR 5TH GR HALL-ARE OVERFLOWING, CAN'T CUT OFF OR CONTAIN PER SBE-PLANT MGR BYERS 416-0609 KLR	11/5/13			Plumbing
Keystone ES (2368) 1B	Pipe in ceiling of back office is leaking and need repairs.	2/5/14	Library	Back office	Roof
Keystone ES (2368) 1B	Ceiling of gym court area is leaking and need repairs.	2/5/14	Gym	Court area	Roof
Keystone ES (2368) 1B	Roof leak in gym and water leaking onto tile floors.	1/9/14	Gym	water leak onto floor	Roof
Keystone ES (2368) 1B	HEAT GYM AREA-LEAKING FROM CEILING ONTO HARDWOOD FLR PER SBE-PLANT MGR BYERS 416-0906 KLR	12/16/13			Roof
Keystone ES (2368) 1B	Please repair roof leak in front of rear exit door in room 101.	5/14/14	Classroom	101	Roof

Count of Craft	Craft						
Location	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
LaRose ES (2395) 1A	22	32	29	1	38	8	130
Grand Total	22	32	29	1	38	8	130

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
LaRose ES (2395) 1A	Im sending this work order per Mr. Hurdle's request. Please come out and remove damage wood where covebase goes.	3/17/14	1st Floor		near main office	Carpentry
LaRose ES (2395) 1A	Mr. Hurdle may I please get 3 boxes of ceiling tile (soft) delivered to Larose . Thanks Mr . Mays	3/19/14	2nd Floor			Carpentry
LaRose ES (2395) 1A	Please come out and rehang stall door in this restroom.	3/19/14	3rd Floor		girls restroom by room 320	Carpentry
LaRose ES (2395) 1A	CAFE DOOR WONT OPEN LEADING TO COOKING AREA. PLANT MGR-MAYES/643.1734	3/24/14				Carpentry
LaRose ES (2395) 1A	Please reeplace chipped tile in this classroom.2 foot section	8/1/13			221	Carpentry
LaRose ES (2395) 1A	Please replace lockset on door.	4/1/14	1st Floor		cafeteria back entry door	Carpentry
LaRose ES (2395) 1A	Please come out and replace several pieces of tile that have came up.	4/30/14	3rd Floor		hallway outside of Teacher's Lounge	Carpentry

LaRose ES (2395) 1A	WINDOW - FRONT OF BLDG REP/REPL WIRE MESH WINDOW GUARD - PM/MAYS 643-1734	5/27/14			Carpentry
LaRose ES (2395) 1A	Baseboard located by main office needs replacing. Wood has been treated for termites thru pest control. Now rotten wood needs to be replaced.	5/28/14			Carpentry
LaRose ES (2395) 1A	Please repair tile in this room.	5/28/14	2nd Floor	208	Carpentry
LaRose ES (2395) 1A	Please install one whiteboard in this room	8/6/13	3rd Floor	327	Carpentry
LaRose ES (2395) 1A	Please install 1 whiteboard in these rooms.	8/6/13	2nd Floor	219 & 221	Carpentry
LaRose ES (2395) 1A	Please install whiteboards in these rooms. 324, 326, 322, and 327. Each room needs at least 2 whiteboards.	8/20/13			Carpentry
LaRose ES (2395) 1A	Repair gate at chiller	8/28/13			Carpentry
LaRose ES (2395) 1A	Adjust door closer	8/29/13			Carpentry

LaRose ES (2395) 1A	Please come and repair emergency window in this room.	9/11/13	2nd Floor	215	Carpentry
LaRose ES (2395) 1A	Please come out and rehang cafeteria door. The door is hanging to one side	9/20/13			Carpentry
LaRose ES (2395) 1A	Teacher needs a whiteboard installed	10/3/13	3rd Floor	325	Carpentry
LaRose ES (2395) 1A	Please come out and repair window. Very hard to secure	7/10/13	2nd Floor	boys restroom	Carpentry
LaRose ES (2395) 1A	Please come out and remove 2ft. section of chipped up floor tile.	7/17/13		220	Carpentry
LaRose ES (2395) 1A	Please come out and secure bar that secures doors .	10/31/13	2nd Floor	Library	Carpentry
LaRose ES (2395) 1A	Entry for ida b wells was meant for larose ele.	10/30/13			Carpentry
LaRose ES (2395) 1A	Mr. Herman, I have a pull station over here at Larose that wont stay closed and it causes the fire alarm to go off almost daily. Near room 315 on wall.	11/14/13	3rd Floor		Electrical

LaRose ES (2395) 1A	Please replace bad ballast in this closet next to room 302	2/3/14	3rd Floor	cust closet	Electrical
LaRose ES (2395) 1A	Please send someone over to replace emergency lights batteries. Some emergency lights are not working properly.	2/6/14		1st ,2nd 3rd floors	Electrical
LaRose ES (2395) 1A	UNIT COMING ON IN RM-202,294 PLANT MGR-MAYES/643.1734	2/10/14			Electrical
LaRose ES (2395) 1A	Please send someone out to replace batteries in emergency lights. there are 7 lights on 1st floor, 7 lights on 2nd floor, and 7 lights on 3rd floor.	3/4/14			Electrical
LaRose ES (2395) 1A	Several sockets in this hallway don't work Please repair. See Plant manager.	3/19/14	2nd Floor		Electrical
LaRose ES (2395) 1A	Check a/c cafe.	5/14/14			Electrical
LaRose ES (2395) 1A	Install new Emerson drive	5/21/14			Electrical
LaRose ES (2395) 1A	Please come out and repair ballast in these 3 rooms. 320, 322, & 324.	5/28/14			Electrical

LaRose ES (2395) 1A	Please repair bad ballast in girls and boys restroom on 2nd floor by library	5/28/14	Restroom (Boys)	by library	Electrical
LaRose ES (2395) 1A	whistling sound is coming from outlet in this room	5/28/14	2nd Floor	208	Electrical
LaRose ES (2395) 1A	Need 3 cases bulbs	6/5/14			Electrical
LaRose ES (2395) 1A	Check lighting in class rooms	6/5/14			Electrical
LaRose ES (2395) 1A	chiller down	6/6/14			Electrical
LaRose ES (2395) 1A	CHILLER will NOT COME ON per Anthony Mayes, Plant Mgr. 643.1734	6/13/14			Electrical
LaRose ES (2395) 1A	Please send 5 cases of flr Rapid start lights. The inventory number is 46807	8/1/13		1st,2nd, & 3rd floors	Electrical
LaRose ES (2395) 1A	Please come out and repair bad ballast in this hallway.	8/1/13	3rd Floor	hallway by elevator (316)	Electrical

LaRose ES (2395) 1A	Please come out and repair bad ballast in this area.	8/1/13	2nd Floor	next to main office	Electrical
LaRose ES (2395) 1A	FCU-2 B BLDG 2ND FLR RM 216 & FCU-1 B BLDG 2ND FLR RM 220-BOTH NOT COMING ON SBE MAYS 416-7848 KLR	8/9/13			Electrical
LaRose ES (2395) 1A	Please come set the clock in the main office to the new school time.	8/9/13	2nd Floor	main office	Electrical
LaRose ES (2395) 1A	Please come out and replace wall clock. Clock doesn't work anymore	8/21/13			Electrical
LaRose ES (2395) 1A	there are 3 sockets that are not working in this room	9/10/13	3rd Floor	328There	Electrical
LaRose ES (2395) 1A	a/c in room 328 not working at all per Anthony Mays 643-1734	9/20/13			Electrical
LaRose ES (2395) 1A	Check power to roof top over kitchen	9/23/13			Electrical
LaRose ES (2395) 1A	P-4 Bad Transformer	9/30/13			Electrical

LaRose ES (2395) 1A	Please come out and repair socket. socket is loose.Very. dangerous	10/3/13	3rd Floor	303	Electrical
LaRose ES (2395) 1A	UNIT NOT COMING ON IN RM-216. PLANT MGR-MAYES/416.7854	7/29/13			Electrical
LaRose ES (2395) 1A	Please replace bad ballast in this room.	10/31/13	2nd Floor	223	Electrical
LaRose ES (2395) 1A	Please come out and replace blown lights in parking lot. Very dark and very dangerous for workers leaving at night	11/6/13	Parking Lot		Electrical
LaRose ES (2395) 1A	There are at least 8 sockets that are not working in this room. See librarian	11/1/13	Library	Storage room in library	Electrical
LaRose ES (2395) 1A	Please deliver 3 boxes of lights to this location. STOCK NUMBER is 46807	11/13/13		1st,2nd,and 3rd floors	Electrical
LaRose ES (2395) 1A	Please deliver 5 cases(25 lights per case) of lights to Larose	7/31/13			Electrical
LaRose ES (2395) 1A	Monthly - Filter-LaRose Elementary - Refer to PM schedule details.	11/19/13			Heating/Ventilation /Air Conditioning

LaRose ES (2395) 1A	boiler down	11/25/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Units are NOT HEATING in ROOM 202 and 312 per Anthony Mayes, Plant Mgr. 643.1734	12/10/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	HEAT PRIN'S OFC-NOT HEATING-PLANT MGR MAYS KLR	12/10/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Units in Rooms 202, 208, 218, 303, 303, 324, and in the Principal's office are NOT HEATING per Anthony Mays, Plant Mgr. 416.2858	1/7/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Monthly - Oil Lube & Belts - LaRose Elem - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	rm 202 coil valved off and actuator laying on ceiling tile	2/13/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	rm 201 not heating	2/13/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	C/O to A/C ---- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning

LaRose ES (2395) 1A	Monthly - Filter-LaRose Elementary - Refer to PM schedule details.	3/25/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Yearly - Air Cool Chillers-Larose Elementary - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	A/C CAFE, MAIN OFC, & SOME CLASSRMS-ALL NOT COOLING PER PRIN-CALLED IN BY PRIN FIELDS 416-7848 KLR	5/12/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Reset chiller	5/19/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	chiller down	6/23/14			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	RTU#1 NOT COOLING THRU ENTIRE 3RD FLR. PLANT MGR-MAYES/416.7848	7/31/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Per Principal Fields 416-7848 kindergarten room 216 is very hot a/c not working	8/7/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	A/C 3RD FLR IS HOT-CALLED IN BY PRIN FIELDS 416-7848 KLR	8/26/13			Heating/Ventilation /Air Conditioning

LaRose ES (2395) 1A	rtu #3 not cooling	8/29/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	UNIT VENT - RMS 202 - RM 205 - MAKING A LOUD HUMMING NOISE - PM/MAYS 416-2858	8/30/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	p-4 bad contactor	9/5/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	P-3 not coming on	9/24/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	RTU # 3 & RTU # 4 DX not working	9/25/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	chiller down	9/30/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	rtu #4 kitchen not cooling	10/3/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning

LaRose ES (2395) 1A	chiller down	7/18/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Monthly - Filter-LaRose Elementary - Refer to PM schedule details.	7/23/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Unit Ventilator in Guidance Complex on the 3rd floor NOT COOLING per Anthony Mayes, Plant Mgr. 901.643.1734.	7/30/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	boiler down	11/7/13			Heating/Ventilation /Air Conditioning
LaRose ES (2395) 1A	Paint trim to match	5/12/14			Painting
LaRose ES (2395) 1A	Please unstop toilet in this restroom.	12/3/13	2nd Floor	girls restroom	Plumbing
LaRose ES (2395) 1A	The 1st toilet is stopped up and plant manager cant unstop this toilet. Please unstop.	12/19/13	3rd Floor	Boys restroom	Plumbing
LaRose ES (2395) 1A	per mr mayes 416-2858 in the cafeteria there is a leak coming from the unit	12/23/13			Plumbing

LaRose ES (2395) 1A	Please come out and unstop mop sink in boiler room. Plant manager used a plunger but water still didnt go through drain	1/23/14		Boiler room	Plumbing
LaRose ES (2395) 1A	Please come and remove cracked toilet seat in bathroom.	3/19/14	3rd Floor	Teacher's Lounge	Plumbing
LaRose ES (2395) 1A	Please come and replace flush valve and pipe under urinal. Every time urinal is flushed water drips from pipe under urinal and sometimes urinal continues to run	3/19/14	1st Floor	boys restroom next to cafeteria	Plumbing
LaRose ES (2395) 1A	Please come out and adjust water pressure for this sink.	3/19/14	1st Floor	wash sink by boys restroom	Plumbing
LaRose ES (2395) 1A	please come out and repair leaking fountain .	3/19/14	2nd Floor	water fountain located next to library	Plumbing
LaRose ES (2395) 1A	Please come out and replace flush valve on toilet in 2nd stall	3/26/14	1st Floor	girls restroom	Plumbing
LaRose ES (2395) 1A	Please come out and replace valve on urinal. Urinal leaks when valve is pulled. also 2 toilets are leaking from pipes in this restroom.	3/26/14	3rd Floor	boys restroom	Plumbing
LaRose ES (2395) 1A	Please come over and repair water fountain . Everytime fountain is used water is on the floor.	3/28/14	1st Floor	next to cafeteria	Plumbing

LaRose ES (2395) 1A	Please come out and unstop toilet in 1st stall.	4/1/14	2nd Floor	girls restroom	Plumbing
LaRose ES (2395) 1A	Test and report on backflow prevention devices.	4/11/14			Plumbing
LaRose ES (2395) 1A	Please come out and check water in handsinks as well as water fountains. Some teachers have complained of water being brown.	4/21/14	1st Floor		Plumbing
LaRose ES (2395) 1A	Test and report on backflow prevention devices.	4/22/14			Plumbing
LaRose ES (2395) 1A	BROWN THRU ENTIRE BLDG PLANT MGR-MAYES/643.1734	5/1/14			Plumbing
LaRose ES (2395) 1A	water fountain is leaking . every time it is used. Water is dripping from small pipe .	5/20/14			Plumbing
LaRose ES (2395) 1A	Toilets in boys restroom is leaking from pipe on 1st floor	5/22/14			Plumbing
LaRose ES (2395) 1A	please repair watr fountain located on 3rd floor near room 328	5/22/14			Plumbing

LaRose ES (2395) 1A	please unstop toilet in girls restroom on 2nd floor near main office. Plant manager has tried to unstop toilet but toilet is still clogged.	5/22/14			Plumbing
LaRose ES (2395) 1A	Please unstop mop sink located in custodial closet on 3rd floor. Water is draining super slow. plant manager used plunger but sink is still stopped up	5/28/14			Plumbing
LaRose ES (2395) 1A	Please come over and reseal toilet. everytime someone uses toilet water comes from the side of toilet.	5/28/14	Cafeteria		Plumbing
LaRose ES (2395) 1A	Please come out and repair bad toilet.	5/29/14	1st Floor	boys restroom	Plumbing
LaRose ES (2395) 1A	Please come out and adjust cold water. Once water is on pipes begin to shake and rattle	5/29/14	1st Floor	wash sink(near boys restroom)	Plumbing
LaRose ES (2395) 1A	Test and report on backflow prevention devices.	6/17/14			Plumbing
LaRose ES (2395) 1A	Pipes under sink are leaking. Please repair. See Cafeteria manager	8/6/13	Cafeteria		Plumbing
LaRose ES (2395) 1A	we have at least 10 toilet seats that need replacing in these restrooms.	8/29/13	Restroom (Boys)	3rd ,2nd , and 1st floors	Plumbing

LaRose ES (2395) 1A	Please come out and replace handles on urinals in boys restroom .	9/6/13	1st Floor	boys restroom	Plumbing
LaRose ES (2395) 1A	please come out and stop leaking urinal. urinal is lweaking from spud	9/6/13	Restroom (Boys)	1st floor	Plumbing
LaRose ES (2395) 1A	Please come out aand adjust water pressure on this sink. Water comes out extremely fast	9/6/13	2nd Floor	wash sink between girls and boys restroom by offic	Plumbing
LaRose ES (2395) 1A	Please come out and unstop toilet in this bathroom. Plant manager used plunger but toilet is still stopped up	9/9/13	2nd Floor	boys restroom by main office	Plumbing
LaRose ES (2395) 1A	RTU is LEAKING and the water is causing a leak in the LIBRARY per Anthony Mays 416.2850.	9/18/13			Plumbing
LaRose ES (2395) 1A	a/c above cafeteria leaking per anthony mays 643-1734	9/20/13			Plumbing
LaRose ES (2395) 1A	unit in the cafeteria cooking area is leaking per Anthony Mays 643-1734	9/20/13			Plumbing
LaRose ES (2395) 1A	Please come out and turn hot water back on.	10/2/13	1st Floor	Boiler room	Plumbing

LaRose ES (2395) 1A	Please unstop 2toilets in this restroom	10/2/13	2nd Floor	boys restroom	Plumbing
LaRose ES (2395) 1A	Please repair pipe under this water fountain. Small hole is in pipe and water leaks on floor everytime water fountain is used	10/23/13	2nd Floor	boys restroom by library	Plumbing
LaRose ES (2395) 1A	Please repair water fountain . Water is coming from pipe under drinking fountain	10/30/13	2nd Floor	boys restroom	Plumbing
LaRose ES (2395) 1A	Please come out and repair leak . Everytime it rains several cieling tiles fall from weight of water . Ive replace at least 30 tiles since September. ALWAYS the same area. 3RD floor	2/3/14	3rd Floor	ENTIRE 3RD Floor	Roof
LaRose ES (2395) 1A	PLEASE COME OUT AND CHECK ROOFTOP. EVERYTIMES IT RAIN WATER DRIPS ON TILES CAUSING TILES TO GIVE IN AND CRUMBLE. ONGOING PROBLEM THAT NEEDS IMMEDIATE ATTENTION!!!	2/5/14	Library	Roof over bldg	Roof
LaRose ES (2395) 1A	HEAT RM 308 3RD FLR- LEAKING-PLANT MGR MAYS 416-2858 KLR	2/21/14			Roof
LaRose ES (2395) 1A	CEILING UNIT IS LEAKING WATER IN LIBRARY PRIN-KAREN FIELDS/416.7848	5/15/14			Roof
LaRose ES (2395) 1A	Water CONTINUES to drip into storage room in library everytime it rains	5/28/14	Library	2nd floor	Roof

LaRose ES (2395) 1A	Water leaks into cafeteria every times it rains. Please come out and reseal Northeast section of roof.	9/20/13	Cafeteria	ROOF	Roof
LaRose ES (2395) 1A	Roof has leak and water is running back into room . Please come out and repair	7/17/13		309	Roof
LaRose ES (2395) 1A	there is a hole in the roof on top of library and water is leaking into library as well as a storage room. Librarian has schools materials in this storage room	7/17/13	2nd Floor	Library	Roof

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Lincoln ES (2440) 1A	3	1	17	27	30	1	18	6	2	105
Grand Total	3	1	17	27	30	1	18	6	2	105

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Lincoln ES (2440) 1A	Please have someone come out to replace several pieces of damage tile. TRIPPING HAZ , THANKS	9/4/13	Administration Area	Hallway C/Wing	Asbestos
Lincoln ES (2440) 1A	Several pieces of floor tile is broken. THANKS (TRIPPING HAZ)	9/9/13	Classroom	310A	Asbestos
Lincoln ES (2440) 1A	install rubber play ground surfacing	4/24/14	Grounds	play grounds	Asbestos
Lincoln ES (2440) 1A	Principal requesting to have internet drops installed for a computer lab in room 204A. THANKS (SCS Network Cabling and Electronics dept.- - "Please See Journal Notes")	1/6/14	Classroom	204A	Cabling
Lincoln ES (2440) 1A	(SCS Network Cabling and Electronics dept.) Exit door next to cafeteria cannot be secured because closure is not working properly per Anita Taylor 416-7860	8/7/13			Carpentry
Lincoln ES (2440) 1A	Please have someone come out to change several damage ceiling tile. THANKS	8/7/13	Hallway/Corridor	1st floor B/Wing	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to change water stain ceiling tile next to PE room. THANKS	8/13/13	Hallway/Corridor	Next to PE ROOM 1st B	Carpentry
Lincoln ES (2440) 1A	Please have someone come out and replace damage ceiling tile, THANKS	8/13/13	Hallway/Corridor	3rd floor B next to elevator.	Carpentry

Lincoln ES (2440) 1A	Door closure is stripped. THANKS	8/14/13	Classroom	155B	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to replace commode seat that is broken. THANKS	9/4/13	Restroom (Boys)	3rd floor B	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to fix damage wood, under damage floor tile.(TRIPPING HAZ.) THANKS	10/14/13	Classroom	310A	Carpentry
Lincoln ES (2440) 1A	Toilet seat broken off. THANKS	11/13/13	Restroom (Boys)	3rd floor B/Wing	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to tighten lock on door. THANKS	11/19/13	Classroom	P E ROOM	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to fix enter door that leaves to the restroom, door is starting to hang off some. THANKS	11/20/13	Restroom (Girls)	3rd floor girls restroom	Carpentry
Lincoln ES (2440) 1A	Repair magnet at hallway exit doors(134,244,157 A/WING) THANKS	3/7/14	Hallway/Corridor	Next to room A134,A244,A157	Carpentry
Lincoln ES (2440) 1A	Repair magnet on back of exit doors(152,325 B/Wing) THANKS	3/7/14	Hallway/Corridor	B122,B325	Carpentry
Lincoln ES (2440) 1A	Hole in wall. from handicap door handle	3/20/14		Boys R/R 3rd floor A wing	Carpentry

Lincoln ES (2440) 1A	Several ceiling tile needs to be change due to water strain. THANKS	4/4/14	Gym	P.E. ROOM	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to repair door that's hanging. THANKS	4/17/14	Restroom (Boys)	2nd and 3rd floor B	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to repair door that's hanging. THANKS	4/17/14	Restroom (Boys)	1st and 3rd floor A	Carpentry
Lincoln ES (2440) 1A	Please have someone come out to place an protect cover over fire alarm pull system in cafe. THANKS	9/16/13	Cafetorium	CAFE.	Carpentry
Lincoln ES (2440) 1A	Principal requesting someone to come back out to reset school bell. THANKS	8/7/13	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	8/7/13	Hallway/Corridor	3rd floor B/Wing	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	8/16/13	Library	Library	Electrical
Lincoln ES (2440) 1A	Fire alarm pulled at the school by a child per Carol Caldwell, Secretary at 901.416.7860.	8/22/13			Electrical
Lincoln ES (2440) 1A	Have four orange outlet that are not working. THANKS	8/23/13	Classroom	208A	Electrical

Lincoln ES (2440) 1A	Please have someone come out to set bells/clocks for school. THANKS	7/9/13	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	Please have someone come out to set bells/clocks for school.(081-053)	7/9/13	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	#081-055) Lights are out due to bad ballast. THANKS	7/23/13	Elevator	Main Hallway	Electrical
Lincoln ES (2440) 1A	Orange outlet making humming sound. THANK	7/23/13	Classroom	244B	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	10/3/13	Kitchen	Cafe.	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	10/3/13	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	10/23/13	Hallway/Corridor	B/Wing back hallway.	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	10/28/13	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	Several lights are out on the employees parking lot. THANKS	11/20/13	Parking Lot	Parking lot	Electrical

Lincoln ES (2440) 1A	HEAT SBE'S OFC-NOT COMING ON-PLANT MGR TAYLOR 416-3634 KLR	1/6/14			Electrical
Lincoln ES (2440) 1A	PE. ROOM needs two light cover replace. THANKS	1/28/14	Gym	PE ROOM	Electrical
Lincoln ES (2440) 1A	Lights out due to bad ballast. THANKS	2/4/14	Hallway/Corridor	2nd floor A/Wing next to 208	Electrical
Lincoln ES (2440) 1A	Lights outside main office are out due to bad ballast. THANKS	2/5/14	Administration Area	Outside Main Office	Electrical
Lincoln ES (2440) 1A	FIRE ALARM IS SHOWING TROUBLE IN MAIN OFFICE PLANT MGR-TAYLOR/315.4670	2/7/14			Electrical
Lincoln ES (2440) 1A	Please have someone come out to change over school clocks due to daylight saving time on(March 9, 2014) THANKS	2/21/14	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	Requesting 3 boxes of ballast for LINCOLN ELEM. THANKS	4/4/14	Administration Area	SBE OFFICE	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	4/8/14	Gym	P.E. ROOM	Electrical
Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	4/8/14	Mechanical Room	BOILER ROOM	Electrical

Lincoln ES (2440) 1A	Several lights are out due to bad ballast. THANKS	4/8/14	Kitchen	KITCHEN	Electrical
Lincoln ES (2440) 1A	Requesting 3boxes of ballast for Lincoln. THANKS	4/21/14	Administration Area	Main Office	Electrical
Lincoln ES (2440) 1A	per ms taylor 416-3634 the a/c in the principal's office is making a loud humming noise	5/19/14			Electrical
Lincoln ES (2440) 1A	Requesting 3boxes of ballast for Lincoln Elem. THANKS	6/24/14	Mechanical Room	SBE Office	Electrical
Lincoln ES (2440) 1A	CHILLER NOT COMING ON(059). PLANT MGR-TAYLOR/416.7860	8/12/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	B hall not cooling	8/13/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	plant manager ofc not cooling	8/19/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	CHILLER NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR TAYLOR 416- 4654 KLR	8/26/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Monthly - Oil Lube & Belt-Lincoln Elementary - Refer to PM schedule details.	9/14/13			Heating/Ventilation /Air Conditioning

Lincoln ES (2440) 1A	UNIT IN THE MAIN OFFICE IS NOT COOLING. SBE TAYLOR 416-4654	7/8/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	chiller down	7/15/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	chiller down	7/22/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Monthly - Filter-Lincoln Elementary - Refer to PM schedule details.	10/12/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Replace Hot Water Differential pressure switch Located Around Room 304 in the hall way ceiling	10/17/13	3rd Floor		Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	B154 unit making loud humming noise per Ms. Taylor 416-3634	10/25/13			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	boiler down	2/3/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	BOILER is NOT COMING ON per Anita Taylor, Plant Mgr. 416.3634	2/7/14			Heating/Ventilation /Air Conditioning

Lincoln ES (2440) 1A	HEAT PRIN'S OFC & SBE'S OFC-BOTH NOT HEATING-PLANT MGR TAYLOR 416-7860 KLR	2/10/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Monthly - Filter-Lincoln Elementary - Refer to PM schedule details.	2/15/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	A/C UNIT is making a LOUD HUMMING SOUND in ROOM B156 per Ms. Taylor, Plant Mgr. 416.7810	2/24/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	C/O to A/C ---- 4 pipe system ?	3/21/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Yearly - Air Cool Chillers-Lincoln Elementary - Refer to PM schedule details.	3/31/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	per ms taylor 416-3634 room B154 a/c unit has loud humming noise that is heard through out bldg	4/2/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	per ms taylor 416-4654 B154 unit making a humming noise	4/7/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Monthly - Oil Lube & Belt-Lincoln Elementary - Refer to PM schedule details.	4/12/14			Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	A/C B WING RMS B327, B242, B243, B329, B239, & B241-ALL NOT COOLING-PLANT MGR TAYLOR 416-7860 KLR	5/6/14			Heating/Ventilation /Air Conditioning

Lincoln ES (2440) 1A	chiller down	5/7/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	SBE office	5/7/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	A/C A WING ABOUT (8) RMS-ALL NOT COOLING-PLANT MGR TAYLOR 416-3634 KLR	5/13/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	COOLING TOWER-NOT COMING ON-AFFECTS THE AIR IN THE ENTIRE BLDG-PLANT MGR TAYLOR 416-3634 KLR	5/14/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	AHU #2 not cooling	5/15/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Monthly - Filter-Lincoln Elementary - Refer to PM schedule details.	6/14/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	CHILLER MECH RM-NOT COMING ON-PLANT MGR TAYLOR 416-3634 KLR	6/24/14				Heating/Ventilation /Air Conditioning
Lincoln ES (2440) 1A	Requesting someone to come out to look at damage wall. (Plaster is damage)	7/23/13	Classroom		308A	Painting
Lincoln ES (2440) 1A	Toilets stopped up and running over.	8/20/13				Plumbing

Lincoln ES (2440) 1A	FLOOR DRAIN BACKING UP IN TEACHER'S LOUNGE MAIN HALL BY MAIN OFC-PLANT MGR TAYLOR 416-4654 KLR	8/29/13			Plumbing
Lincoln ES (2440) 1A	SEWAGE BACKING UP THRU FLOOR DRAIN IN MAIN HALL-PLANT MGR TAYLOR 416-7810 KLR	9/9/13			Plumbing
Lincoln ES (2440) 1A	Please have someone come out to unstop restroom in Teacher lounge(MENS). THANKS	9/17/13	1st Floor	Teacher lounge	Plumbing
Lincoln ES (2440) 1A	Please have someone come out to unstop commode. THANKS	9/26/13	Restroom (Boys)	Teacher Lounge(MENS)	Plumbing
Lincoln ES (2440) 1A	sewer backing up in main hallway by office per Ms. Taylor 315-4670	10/24/13			Plumbing
Lincoln ES (2440) 1A	FLR DRAIN IS BACKING UP BY MAIN OFFICE. PLANT MGR-TAYLOR/315.4670	11/5/13			Plumbing
Lincoln ES (2440) 1A	Sink leaking in girls restroom. THANKS	11/13/13	Restroom (Girls)	3rd floor B/Wing	Plumbing
Lincoln ES (2440) 1A	Last stall next to window is leaking underneath.	1/6/14	Restroom (Girls)	A WING 1ST. FLOOR	Plumbing
Lincoln ES (2440) 1A	1st urinal keeps over flooding.THANKS	1/6/14	Restroom (Boys)	1st floor A WING	Plumbing

Lincoln ES (2440) 1A	Please have someone come out to unstop commode on 1st. floor girls restroom B/WING keeps stopping up.. THANKS	2/20/14	Restroom (Girls)	1st. floor B/WING	Plumbing
Lincoln ES (2440) 1A	Water fountain is broken on 3rd floor A/WING next to girls restroom. THANKS	3/7/14	Hallway/Corridor	3rd. floor A	Plumbing
Lincoln ES (2440) 1A	Water fountain on 1st floor B is leaking underneath. THANKS	3/25/14	Hallway/Corridor	Next to PE ROOM	Plumbing
Lincoln ES (2440) 1A	Teacher requesting water to be turn off in her room. THANKS	3/27/14	Classroom	kk-02	Plumbing
Lincoln ES (2440) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	4/8/14			Plumbing
Lincoln ES (2440) 1A	FLR DRAIN COVER IS MISSING IN B/RR 2ND FLR PLANT MGR-TAYLOR/416.7860	4/11/14			Plumbing
Lincoln ES (2440) 1A	1ST Stall keeps stopping up. THANKS	5/2/14	Restroom (Girls)	1st floor B	Plumbing
Lincoln ES (2440) 1A	Repair commode teacher lounge. THANKS	5/5/14	Restroom (Boys)	Teacher lounge	Plumbing
Lincoln ES (2440) 1A	Please have someone come out to check roof for several leaks. THANKS	11/22/13	Classroom	A136	Roof

Lincoln ES (2440) 1A	Please have someone come back out to fix roof leak. RAIN IS POURING DOWN LIKE CRAZY IN CLASSROOM...	12/5/13	Classroom	136A	Roof
Lincoln ES (2440) 1A	Please have someone come out to fix roof leak. THANKS	1/13/14	Classroom	A136	Roof
Lincoln ES (2440) 1A	Please have someone come out to fix roof leak in classroom, restroom both are in A136. THANKS	2/5/14	Classroom	A136	Roof
Lincoln ES (2440) 1A	P. E. ROOM has a roof leak. THANKS	4/1/14	Gym	PE ROOM	Roof
Lincoln ES (2440) 1A	Please have someone come out to fix roof leak in Per -K restroom. THANKS	5/14/14	Classroom	A136	Roof
Lincoln ES (2440) 1A	Fabricate floor drain cover 8". Support Frank wo 428841.	4/11/14	Restroom (Boys)		Sheet Metal
Lincoln ES (2440) 1A	Principal ac in office remove dampers.	6/10/14	Administration Area		Sheet Metal

Count of Craft	Craft								
	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Location									
Lucy ES (0115) 1B	2	17	49	22	1	57	20	3	171
Grand Total	2	17	49	22	1	57	20	3	171

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Lucy ES (0115) 1B	Carpet need replace .	4/14/14	1st Floor	office	Asbestos
Lucy ES (0115) 1B	Carpet need to be replace(guidance office).	4/14/14		old wing office	Asbestos
Lucy ES (0115) 1B	Tile :Three places .one near room 106, near T W A, near stare way door, entrance door down stair way, Kitchen service door entrance, (first floor room,101,108 Base board need replace) And front office back of counter tile is up).	6/10/14	Hallway/Corridor	second flour	Carpentry
Lucy ES (0115) 1B	Rubber covering on stairway continuing to come lose it's very dangerous when it come lose because peoples are using stairway all the time.	4/15/14	Stairway	First floor lobby to second lobby	Carpentry
Lucy ES (0115) 1B	Hole in sheetrock (were door knob stop).	4/25/14	Hallway/Corridor	near 302	Carpentry
Lucy ES (0115) 1B	A number of peaces of base board need to be replace.	4/29/14	Hallway/Corridor	First floor/second floor	Carpentry
Lucy ES (0115) 1B	Adjust all lab tables to ADA height.	5/28/14			Carpentry

Lucy ES (0115) 1B	Clock is not working W/ O ref:402231 (Clock Location hallway next to room 312).	12/10/13	Hallway/Corridor	By room 312	Carpentry
Lucy ES (0115) 1B	Storage room is about 8'x4' (need shelves to be able to stack things) C D C preschool class room thanks.	1/24/14	Classroom	101	Carpentry
Lucy ES (0115) 1B	replace sheetrock in water heater room on back dock	1/30/14			Carpentry
Lucy ES (0115) 1B	door Closure not pulling door alway close.	1/31/14	Stairway	near gym	Carpentry
Lucy ES (0115) 1B	Flag cable hooks are broken off.	2/3/14	Parking Lot	front of school	Carpentry
Lucy ES (0115) 1B	Entrance ,Doors closure need adjusting (door closed to fast).	2/5/14	2nd Floor	lobby	Carpentry
Lucy ES (0115) 1B	Door latch will not properly work door is hard to open.	2/26/14	Gym	west entrance door	Carpentry
Lucy ES (0115) 1B	water leaking through emergence window.	10/3/13	Classroom	311	Carpentry

Lucy ES (0115) 1B	Tile on floor has come up (about 8 pcs need replace) white.	11/26/13	Gym	by water fountain	Carpentry
Lucy ES (0115) 1B	Door need a threshold .	12/2/13	Gym		Carpentry
Lucy ES (0115) 1B	Hallway first double fire doors (latch catch) in floor need to be repaired.	4/15/14	1st Floor	near office	Carpentry
Lucy ES (0115) 1B	Clock is not working. Which clock is not working. Be specific!	12/9/13	Hallway/Corridor	by room 312	Carpentry
Lucy ES (0115) 1B	Exhaust fan not working.	4/24/14	Restroom (Boys)	near313	Electrical
Lucy ES (0115) 1B	Light will not work.	4/24/14	Kitchen	service lain	Electrical
Lucy ES (0115) 1B	Three light will not work.	4/24/14		west end/ wall out side	Electrical
Lucy ES (0115) 1B	Dirty smoke detector .	4/28/14	Classroom	103	Electrical

Lucy ES (0115) 1B	Exhaust fans are not working .	5/15/14	Gym	boys and girls rest room	Electrical
Lucy ES (0115) 1B	trouble :strobe 101 open ckt.	5/27/14		New part	Electrical
Lucy ES (0115) 1B	Please run Test. Generator Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical
Lucy ES (0115) 1B	Changing school bell schedule	7/16/13	1st Floor	main office	Electrical
Lucy ES (0115) 1B	Check the power to the desk in the library.	7/16/13			Electrical
Lucy ES (0115) 1B	Light need to be repaired .	7/19/13		plant manager office	Electrical
Lucy ES (0115) 1B	Light need to be repaired .	12/19/13	1st Floor	girls rest room	Electrical
Lucy ES (0115) 1B	Fire alarm pull down will not work,	1/6/14	Gym	by back exit door	Electrical

Lucy ES (0115) 1B	Light need to be repaired.	1/6/14	Hallway/Corridor	old ramp	Electrical
Lucy ES (0115) 1B	Light will not work.	1/7/14	Elevator		Electrical
Lucy ES (0115) 1B	Clock not working.	1/15/14	2nd Floor	near 220	Electrical
Lucy ES (0115) 1B	ovens periodically shut off. have to reset breaker behind oven to turn back on	1/16/14	Cafeteria		Electrical
Lucy ES (0115) 1B	Riser room (Ech-1 heater is not working..	1/21/14	Mechanical Room	Near lawn room on back	Electrical
Lucy ES (0115) 1B	Showing transmit trouble (Need to be checked).	1/22/14		school	Electrical
Lucy ES (0115) 1B	Exhaust fan is not working (Range hood).	1/24/14	Kitchen		Electrical
Lucy ES (0115) 1B	Ceiling heater making loud noise.	1/28/14	2nd Floor	near 220	Electrical

Lucy ES (0115) 1B	Light need to be repaired .	1/30/14	Cafeteria	stage	Electrical
Lucy ES (0115) 1B	Need two light repair .	2/6/14	Kitchen		Electrical
Lucy ES (0115) 1B	garbage disposal in the dishroom is not working, water flows but disposal doesnt come on	2/19/14	Cafeteria		Electrical
Lucy ES (0115) 1B	Light is not working.	2/24/14	1st Floor	elevator	Electrical
Lucy ES (0115) 1B	one light will not work.	3/19/14		plant manager office	Electrical
Lucy ES (0115) 1B	Clock is not working.	3/20/14	Hallway/Corridor	by room 309	Electrical
Lucy ES (0115) 1B	1,10221 fluorescent lamp F32T8 Qty 5case. #2.10440 incndscnt lamp 60 watt A130 V Qty.30 #3.10283 gloves, powder free vinyl exam, med QTY. 2 packages. #4.10531 Metal halidelamp 100 watt ,clear QTY.21 #5.10247 fluorescent	3/26/14	2nd Floor		Electrical
Lucy ES (0115) 1B	light need to be repair.	8/8/13	Hallway/Corridor	neer room 204	Electrical

Lucy ES (0115) 1B	Light is not working.	8/19/13		office/Sanders	Electrical
Lucy ES (0115) 1B	Three light is not working.	8/19/13		on back wall	Electrical
Lucy ES (0115) 1B	Door bell do not ring to let office no some one is at door.	8/21/13		front door	Electrical
Lucy ES (0115) 1B	Exhaust fan is not working.	8/22/13	2nd Floor	Rest rooms boys	Electrical
Lucy ES (0115) 1B	Light is not working.	8/23/13		over back entrance door	Electrical
Lucy ES (0115) 1B	#1. 10531, METAL HALIDE LAMP100WATT,MH100/U MED CLEAR.QTY.15.	8/26/13		school	Electrical
Lucy ES (0115) 1B	Exit lights need to be repaired .	9/4/13	Library	Entrance door by room 314	Electrical
Lucy ES (0115) 1B	Exit light need repair.	9/17/13		entrance door by 314	Electrical

Lucy ES (0115) 1B	Need three lights repair.	10/17/13	Parking Lot	front	Electrical
Lucy ES (0115) 1B	Need two lights repair	10/17/13		front wall	Electrical
Lucy ES (0115) 1B	Need two light repair.	10/17/13	Parking Lot	front	Electrical
Lucy ES (0115) 1B	Check air compressor on fire sprinkler system, tripping breaker	10/23/13			Electrical
Lucy ES (0115) 1B	Verify data base in burglar alarm panel.	11/1/13			Electrical
Lucy ES (0115) 1B	Exhaust fan #1 is not working.	11/5/13	2nd Floor	restrooms	Electrical
Lucy ES (0115) 1B	Entrance door exit light is not working.	11/5/13	Library		Electrical
Lucy ES (0115) 1B	Please enter an alarm code for Assistant Principal Robert LeGault.	11/7/13			Electrical

Lucy ES (0115) 1B	Alarm Motion trouble .	11/19/13	Hallway/Corridor	by 220	Electrical
Lucy ES (0115) 1B	Ket pad is not working.	4/11/14	Hallway/Corridor	by room 314	Electrical
Lucy ES (0115) 1B	Out let is not working (Power for key pad).	4/11/14		Mechanical room near room 312	Electrical
Lucy ES (0115) 1B	Smoke detector M2-87 dirty	4/14/14	Hallway/Corridor	near 314	Electrical
Lucy ES (0115) 1B	#1. 10465 Liners compactor ,gladco 31x50 Qty.1 Case. #2.10480 Mats ,floor, 3x4 QTy. 8	3/28/14	2nd Floor		Electrical
Lucy ES (0115) 1B	UNIT NOT COOLING IN RM-307 PLANT MGR-WILLIE/873.8187	5/12/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	A/C UNIT is NOT COOLING in PRINCIPAL'S OFFICE per Willie Hampton, Plant Mgr. 873.8175	5/21/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	PM a/c units	6/3/14			Heating/Ventilation /Air Conditioning

Lucy ES (0115) 1B	HEAT RM 305-NOT HEATING- PLANT MGR HAMPTON 873- 8175 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	Heater is not heating (Boiler rm).	1/21/14		Back dock	Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	HEAT FRONT LOBBY AREA- NOT COMING ON-PLANT MGR HAMPTON 873-9175 KLR	1/22/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	UNIT NOT HEATING IN RM- 302 PLANT MGR- HAMPTON/873.8187	1/29/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	HEAT RM 313-NOT COMING ON-PLANT MGR HAMPTON 873-8175 KLR	1/31/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	Change filters	2/6/14		Whole building	Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	HEAT 1ST/2ND FLR LOBBIES- BOTH NOT COMING ON- PLANT MGR HAMPTON 873- 8175 KLR	2/11/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	HEAT RM 107-NOT COMING ON-PLANT MGR HAMPTON 872-8175 KLR	3/7/14			Heating/Ventilation /Air Conditioning

Lucy ES (0115) 1B	HEAT RM 107 & 108-BOTH NOT HEATING-PLANT MGR HAMPTON 873-8175 KLR	3/18/14			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	UNIT NOT COOLING IN LOBBY 2ND FLR PLANT MGR- HAMPTON/353.8592	8/13/13			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	A/C unit NOT COOLING in Room 305 per Mr. Willie Hampton, Plant Mgr. @ 901.416.8175	8/27/13			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	the ceiling is leaking brown water into line # 1 serving well. I will not be able to put any food in that serving line. I only have 2 serving lines and I serve around 650 kids lunch every day.	9/11/13	Kitchen		Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	A/C UNIT CAFE AREA- CONDENSATION IS LEAKING DOWN INTO SERVING LINE OVER FOOD-PLANT MGR HAMPTON 8738175 KLR	9/11/13			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	Per Willie Hampton 873-8175 guidance office, rooms 304, 305, 306, 307 a/c not coming on at all	9/17/13			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	HEAT RMS 105 & 107-BOTH NOT COMING ON-PLANT MGR HAMPTON 872-8175 KLR	11/14/13			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	A/C RM 212-NOT COOLING- PLANT MGR HAMPTON 873- 8175 KLR	4/4/14			Heating/Ventilation /Air Conditioning

Lucy ES (0115) 1B	ROOM 309 IS NOT COOLING	8/1/13		ROOM 309	Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	UNIT NOT COMING ON IN RM-309. PLANT MGR-HAMILTON/873-8175	8/1/13			Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	A/C in room 310 not cooling	8/3/13		Rm 310	Heating/Ventilation /Air Conditioning
Lucy ES (0115) 1B	need to be repainted were bulletin board were removed to install new equipment ,(rooms 100, 102, 103,107,110, 111,).	8/9/13	Classroom		Painting
Lucy ES (0115) 1B	Faucet need to be repaired.	4/24/14	Clinic	office	Plumbing
Lucy ES (0115) 1B	Faucet need to be repaired.	4/24/14	Restroom (Boys)	Near 307	Plumbing
Lucy ES (0115) 1B	Water fountain have come loose from wall leaking water.	4/24/14	1st Floor	near 106	Plumbing
Lucy ES (0115) 1B	per willie hampton 873-8175 sewer backing up in the kitchen	5/1/14			Plumbing

Lucy ES (0115) 1B	Faucet need to be repaired.	5/13/14		Janitor room near 312	Plumbing
Lucy ES (0115) 1B	SEWAGE BACKING UP IN KITCHEN PLANT MGR- HAMPTON/353.8596	5/15/14			Plumbing
Lucy ES (0115) 1B	Booster heater leaking in the kitchen.	7/22/13			Plumbing
Lucy ES (0115) 1B	Repair Toilet seat Clinic.	7/25/13			Plumbing
Lucy ES (0115) 1B	Repair Toilet seat Office.	7/25/13			Plumbing
Lucy ES (0115) 1B	Repair Toilet seat Boys near Rm. 306.	7/25/13			Plumbing
Lucy ES (0115) 1B	Repair Toilet seat Girls near Rm. 101.Stall # 3 and stall #5.	7/25/13			Plumbing
Lucy ES (0115) 1B	Commodes will not flush(low water flow).	7/30/13	2nd Floor	T W A rest room	Plumbing

Lucy ES (0115) 1B	check water to commode may be hot.	7/31/13	2nd Floor	T W A room	Plumbing
Lucy ES (0115) 1B	Repair commode .	7/31/13	Restroom (Girls)	by 101	Plumbing
Lucy ES (0115) 1B	Sink ne to be unclogged.	12/10/13	1st Floor	106	Plumbing
Lucy ES (0115) 1B	Rest room last repair commode	1/14/14	1st Floor	T W A	Plumbing
Lucy ES (0115) 1B	Unstop kitchen sink.	1/14/14	1st Floor	T W A	Plumbing
Lucy ES (0115) 1B	Repair first water fountain.	1/14/14	1st Floor	near 101	Plumbing
Lucy ES (0115) 1B	First urinal handle leaking.	1/14/14	1st Floor	boys rest room	Plumbing
Lucy ES (0115) 1B	Rest room unstop sink.	1/14/14	2nd Floor	near 200	Plumbing

Lucy ES (0115) 1B	Handle leaking commode .	1/14/14	2nd Floor	T W A	Plumbing
Lucy ES (0115) 1B	Repair commode seat.	1/14/14	Restroom (Boys)	Near 306	Plumbing
Lucy ES (0115) 1B	Repair two water fountain.	1/14/14	Hallway/Corridor	near311	Plumbing
Lucy ES (0115) 1B	Commode will not flush.	1/17/14	1st Floor	offices restroom	Plumbing
Lucy ES (0115) 1B	Pipe leaking water to water fountain .	1/27/14		Back dock	Plumbing
Lucy ES (0115) 1B	Need to check 3' pipe on wall is leaking water.	1/27/14	Mechanical Room	Back dock	Plumbing
Lucy ES (0115) 1B	RP leaking at the vent.	1/27/14			Plumbing
Lucy ES (0115) 1B	Commode # 3 very weak flush.	1/30/14	2nd Floor	Girls rest room	Plumbing

Lucy ES (0115) 1B	Commode # 1 clog up .	1/30/14	Restroom (Girls)	near313	Plumbing
Lucy ES (0115) 1B	water fountain cover is coming off.	1/30/14	1st Floor		Plumbing
Lucy ES (0115) 1B	Urinal leaking from base (Middle).	2/10/14	2nd Floor	Boys rest room	Plumbing
Lucy ES (0115) 1B	Leaking water from under neat sink ,cover to under sink in plant Manager office).	2/19/14	Restroom (Girls)	near 304	Plumbing
Lucy ES (0115) 1B	Toilet seat need to be repaired .	3/25/14	1st Floor	boys rest room	Plumbing
Lucy ES (0115) 1B	Urinal leaking water from under,middle.	8/7/13	Restroom (Boys)	second floor	Plumbing
Lucy ES (0115) 1B	repair commode .	8/7/13	Restroom (Boys)	first floor	Plumbing
Lucy ES (0115) 1B	Repair commode.	8/7/13	Clinic	first floor	Plumbing

Lucy ES (0115) 1B	SINKS ARE STOPPED UP IN KITCHEN. PLANT MGR- HAMPTON/353.8592	8/20/13			Plumbing
Lucy ES (0115) 1B	small urinal will not flush.	8/29/13	1st Floor	boys rest room	Plumbing
Lucy ES (0115) 1B	Water will not turn off commode	8/30/13	Gym	girls rest room	Plumbing
Lucy ES (0115) 1B	Shower need to be repaired.	9/17/13	Gym	girls locker	Plumbing
Lucy ES (0115) 1B	Please test the following RP 379200 1 1/4" 909 Watts	9/19/13			Plumbing
Lucy ES (0115) 1B	Please test the following RP 534569 3/4" 909 Watts	9/19/13			Plumbing
Lucy ES (0115) 1B	Please test the following RP 1242423 2" 975 XL W/Z	9/19/13			Plumbing
Lucy ES (0115) 1B	Please test the following RP 1255394 2" 975 XL W/Z	9/19/13			Plumbing

Lucy ES (0115) 1B	Please test the following RP 1255392 2" 975 XL W/Z	9/19/13			Plumbing
Lucy ES (0115) 1B	Please test the following RP 1242418 2" 975 XL W/Z	9/19/13			Plumbing
Lucy ES (0115) 1B	Commode seat need to be repaired.	9/20/13	Restroom (Boys)	by room 306	Plumbing
Lucy ES (0115) 1B	Water leaking through back center light.	10/3/13	Classroom	215	Plumbing
Lucy ES (0115) 1B	Water fountain have come loose from wall.	10/17/13	1st Floor	hallway	Plumbing
Lucy ES (0115) 1B	WATER FOUNTAIN 1ST FLR FRONT OF B RR-IS FALLING OFF THE WALL-SBE IS AFRAID IT WILL FALL AND HIT SOMEONE-PLANT MGR HAMPTON 373-8175 KLR	10/23/13			Plumbing
Lucy ES (0115) 1B	Rest room repair toilet.	11/11/13	2nd Floor	T W A rest room	Plumbing
Lucy ES (0115) 1B	Repair toilet.	11/11/13	Restroom (Boys)	by 306	Plumbing

Lucy ES (0115) 1B	Repair toilet.	11/11/13	Restroom (Girls)	by 207	Plumbing
Lucy ES (0115) 1B	Need commode seat.	11/12/13	1st Floor	boys rest room	Plumbing
Lucy ES (0115) 1B	No water is coming into urinal.	11/26/13	2nd Floor	boys rest room	Plumbing
Lucy ES (0115) 1B	Faucet need to be repaired. #2,boys rest room handicap need to be repaired,(by room 306).	4/10/14	Clinic		Plumbing
Lucy ES (0115) 1B	Commode leaking water fro top.	4/14/14	Restroom (Girls)	first floor	Plumbing
Lucy ES (0115) 1B	Water leaking between the two light .	5/21/14		Office plant manager	Roof
Lucy ES (0115) 1B	Leaking near A/C vent , west down stair way end.	5/28/14	Classroom	207 & west end of hallway	Roof
Lucy ES (0115) 1B	Water leaking from ceiling #2 East end also water leaking from ceiling.	1/14/14	Stairway	west end	Roof

Lucy ES (0115) 1B	Leaking water right corner from entrance door.	2/18/14	Classroom	300	Roof
Lucy ES (0115) 1B	Leaking water leave old it on right side.	2/18/14	Hallway/Corridor	were old & new join	Roof
Lucy ES (0115) 1B	Water is leaking.	2/18/14	Stairway	East & west end	Roof
Lucy ES (0115) 1B	water leaking over top of window.	8/6/13	Classroom	206	Roof
Lucy ES (0115) 1B	Leaking around A/C tube.	9/26/13	Gym	coach office	Roof
Lucy ES (0115) 1B	Leaking water back wall right side.	9/26/13	Classroom	212	Roof
Lucy ES (0115) 1B	water leaking first light come into entrance door.	10/3/13	Classroom	300	Roof
Lucy ES (0115) 1B	water come in over entrance door.	10/3/13	Hallway/Corridor	by room 301	Roof

Lucy ES (0115) 1B	two water leaks about two feet from back window .	10/3/13	Classroom	204	Roof
Lucy ES (0115) 1B	side door water come in at first light.	10/3/13	Classroom	304	Roof
Lucy ES (0115) 1B	water leaking close around A/C vent.	10/3/13	Classroom	201	Roof
Lucy ES (0115) 1B	water leak come through back center light (VOID W/O388152 sent wrong place).	10/3/13	Classroom	215	Roof
Lucy ES (0115) 1B	Second door first light water leaking into (old area).	10/17/13	Classroom	304	Roof
Lucy ES (0115) 1B	Water leaking from ceiling ,300, 200, 302 (Hallway by room 301 leaking over entrance door old leak) all are old leaks have been work on many time but never stop).	10/17/13	Classroom		Roof
Lucy ES (0115) 1B	Repair roof leak in classroom 215, leaking in back center light	11/1/13			Roof
Lucy ES (0115) 1B	#1Cafeteria By line #2 in front of light #4water come in / #2 room 304 old next to light. #3second floor in hallway out in front of t w a Room.	11/5/13	Cafeteria	#2 room304 #3 hallway	Roof

Lucy ES (0115) 1B	200 water leaking next to speaker , 300 first light coming into door.	11/25/13	Classroom	200, 300	Roof
Lucy ES (0115) 1B	i have a drawer pull that has broken. Front slide rail on the serving line is broken.	7/17/13			Sheet Metal
Lucy ES (0115) 1B	Make brackets for Marshal Stutes	2/18/14			Sheet Metal
Lucy ES (0115) 1B	Please make 5 covers for drinking fountains. Use pattern provided.	8/13/13			Sheet Metal

Count of Craft	Craft							
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Magnolia ES (2470) 1A	1	13	39	26	3	31	3	116
Grand Total	1	13	39	26	3	31	3	116

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Magnolia ES (2470) 1A	please remove 9x9 flr tile and mastic under a/c units for contractors,throughout bldg. they will call as needed.	3/5/14			Asbestos
Magnolia ES (2470) 1A	ceiling tile in the cafeteria need to be replace	7/12/13			Carpentry
Magnolia ES (2470) 1A	on the green hall, the stair by the elevator. The stair mat came up and very unsafe.	9/26/13			Carpentry
Magnolia ES (2470) 1A	The flag pole need a cable on it, the rope is broken.	10/4/13			Carpentry
Magnolia ES (2470) 1A	room 9 child thru backpack thru window - glass is out per Mr. Haslett 416-1743	12/4/13			Carpentry
Magnolia ES (2470) 1A	GIRL RESTROOM STALL DOOR BROKEN OFF ON THE BLUE HALL.	2/10/14			Carpentry
Magnolia ES (2470) 1A	i need a 2 box 4ft fiberglass ceiling tiles.	8/7/13			Carpentry

Magnolia ES (2470) 1A	on the blue hall the clock is about to fall from the ceiling tile.	4/21/14			Carpentry
Magnolia ES (2470) 1A	the blue hall girl restroom stall door broken.	5/5/14			Carpentry
Magnolia ES (2470) 1A	the double door in the cafe bar handle broken.	5/15/14			Carpentry
Magnolia ES (2470) 1A	in cafe area need ceiling tile need a lift	6/2/14			Carpentry
Magnolia ES (2470) 1A	need ceiling tiles	8/6/13			Carpentry
Magnolia ES (2470) 1A	need ceiling tiles	7/5/13			Carpentry
Magnolia ES (2470) 1A	The sheetrock in the main office need replace cause by roof leak. The roof has been fix.	8/26/13			Carpentry
Magnolia ES (2470) 1A	Their r 8 light fixture out in the cafetera, 2 light fixture cover need to be need closeing	7/12/13			Electrical

Magnolia ES (2470) 1A	clock on 2nd floor not working, clock on the green hall come a part from the ceiling tile.	7/23/13			Electrical
Magnolia ES (2470) 1A	Repair wiring to PIV and check for ground faults to building.	7/23/13			Electrical
Magnolia ES (2470) 1A	emergency lights not working{ yellow hall 3} blue hall 1 across from room 14} purple hall 4} P.E. broken need replace.	7/26/13			Electrical
Magnolia ES (2470) 1A	2-UV NOT COMING ON IN RM-2A(017) RM-203(057). PLANT MGR- HASSETT/416.4578	7/29/13			Electrical
Magnolia ES (2470) 1A	Two (2) RTU's in Cafeteria NOT COMING ON per Jessie, Plant Mgr. at 901.416.5070.	7/30/13			Electrical
Magnolia ES (2470) 1A	UNIT VENT - 082-042 RM 108B BURNT WIRES SMELL - PM/HAYSLETT 416-4570	7/30/13			Electrical
Magnolia ES (2470) 1A	Fire alarm tech reports that we need electricians to repair the broken conduit and wiring at the PIV.	8/5/13			Electrical
Magnolia ES (2470) 1A	room 2c need a emergency light and a fire extinguisher in for pre k.	8/5/13			Electrical

Magnolia ES (2470) 1A	i need 16 wallclocks and batteries.	9/10/13			Electrical
Magnolia ES (2470) 1A	Bad ballet on 2nd grade hall, one the yellow hall, and green hall, and in cafe hall.	10/10/13			Electrical
Magnolia ES (2470) 1A	rooms 105 and 6A the a/c units are not coming on per Mr. Haslett 416-4578	10/17/13			Electrical
Magnolia ES (2470) 1A	ballet in the girl restroom make a very loud noise, on the main hall.	10/17/13			Electrical
Magnolia ES (2470) 1A	the light on the back of the school, the side of pe room and cafe broken out.	10/22/13			Electrical
Magnolia ES (2470) 1A	need 4 box flr lamp 4ft long 28/ watt	10/25/13			Electrical
Magnolia ES (2470) 1A	main office clock need set. Also outside timmer light need set.	11/4/13			Electrical
Magnolia ES (2470) 1A	the light on the bldg face the park lot not come on it very dark at night.	11/22/13			Electrical

Magnolia ES (2470) 1A	yellow hall, 2 emergency light out, (green hall 4 emergency light out, stair well 2 emergency light out) (purple hall 5 emergency light out) (1 in front of the main office) (1 in front of the kindergarden restroom)	1/6/14			Electrical
Magnolia ES (2470) 1A	half the hall clock need seting!	3/19/14			Electrical
Magnolia ES (2470) 1A	RECEPTACLE KITCHEN AREA FOR HOT BOXES-BURNED OUT PER SBE-PLANT MGR HASLETT 416-7493 KLR	1/16/14			Electrical
Magnolia ES (2470) 1A	conferance room need 2 to 4 ballet .	1/24/14			Electrical
Magnolia ES (2470) 1A	In the boy restroom need ballest	2/6/14			Electrical
Magnolia ES (2470) 1A	ROOM 6C NEED A BALLETT	2/10/14			Electrical
Magnolia ES (2470) 1A	VENT-A-HOOD KITCHEN AREA- NOT COMING ON AT ALL- PLANT MGR HASLETT KLR	2/24/14			Electrical
Magnolia ES (2470) 1A	case of bulb (F32 T8) u shape 5box of MH400/U/MOG 5box of 75 watt	2/28/14			Electrical

Magnolia ES (2470) 1A	FCU RM 2A & FCU 2ND FLR RM 203B-BOTH NOT COMING ON-SBE HASSLETT 416-4578 KLR	8/12/13			Electrical
Magnolia ES (2470) 1A	LIGHT FIXTURE HAS SMOKE COMING IT IN RM-108 PLANT MGR-HAYSETT/416.4578	8/14/13			Electrical
Magnolia ES (2470) 1A	Per Haslett 416-4570 the following rooms a/c not coming on: 1C, 3C, 4C	8/19/13			Electrical
Magnolia ES (2470) 1A	FCU RM 4A-NOT COMING ON- PLANT MGR HASSLET 416-4570 KLR	8/21/13			Electrical
Magnolia ES (2470) 1A	POWER OUTAGE throughout the ENTIRE BUILDING per Jessie Haslett, Plant Mgr. 416.1743	3/27/14			Electrical
Magnolia ES (2470) 1A	RECEPTACLE RM 105- SPARKED FIRE AND KNOCKED POWER OUT-SBE CAN'T FIND BREAKER TO RM-PLANT MGR HASLETT 416-1743 KLR	4/25/14			Electrical
Magnolia ES (2470) 1A	per hayslip 416-1743 in the kitchen the a/c is not coming on at all	5/12/14			Electrical
Magnolia ES (2470) 1A	HAS A COMPLETE POWER OUTAGE-PLANT MGR HASLETT 416-1743 KLR	6/5/14			Electrical

Magnolia ES (2470) 1A	i need 3 box flr lamp 4ft long / 28 watt / 25 in a boxs.	8/6/13			Electrical
Magnolia ES (2470) 1A	Room 2A and Room 203B the a/c is not working at all per Jesse Hazlip 416-4507	8/7/13			Electrical
Magnolia ES (2470) 1A	need flr lamps please.	8/6/13			Electrical
Magnolia ES (2470) 1A	need lamp flr rapid start 25	7/5/13			Electrical
Magnolia ES (2470) 1A	need lamp flr rapid start 25	7/5/13			Electrical
Magnolia ES (2470) 1A	Unit Ventilators NOT COMING ON in RoomS 2A & 203B per Jessie, Plant Mgr. at 901.416.4570	8/7/13			Electrical
Magnolia ES (2470) 1A	Monthly - Filter-Magnolia Elementary - Refer to PM schedule details.	7/20/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	UNIT INR RM 10,11,2C,4C,206 IS NOT COOLING. SBE HASSLETT	7/23/13			Heating/Ventilation /Air Conditioning

Magnolia ES (2470) 1A	UNIT IN RM 105,2A,4A IS NOT COMING ON. . SBE HASSLETT	7/23/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	6-UV NOT COOLING IN RM-105,102,3C,11,13,203. PLANT MGR-HASLETT/416.4578	9/4/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	A/C units are NOT COOLING in ROOMS 7A and 1C per Mr. Haslett, Plant Mgr. 416.4570	10/2/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	A/C RM 6A-NOT COOLING- PLANT MGR HASLETT 416-4570 KLR	10/14/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Monthly - Oil Lube & Belt- Magnolia Elementary - Refer to PM schedule details.	11/4/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Replace safety valves T17284	11/25/13	Mechanical Room		Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Monthly - Air Compressor PMs - Magnolia Elementary - Refer to PM schedule details.	12/2/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	rooms 15A, 13A, 14A, 17A, 8A, 10, 11, 2C all blowing cold air per Jessie Haslett 416-1743	12/2/13			Heating/Ventilation /Air Conditioning

Magnolia ES (2470) 1A	HEAT RMS 112, 108, 107, & 12-ALL NOT HEATING-PLANT MGR HASLETT 416-5012 KLR	12/10/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	HEAT RMS 107B, 105, 209, & 12A-ALL NOT HEATING-PLANT MGR HASLETT 416-1543 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	HEAT MAIN OFC-NOT HEATING-PLANT MGR HASLETT 416-1743 KLR	1/7/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	HEAT SBE'S OFC-NOT HEATING-PLANT MGR HASLETT 416-1743 KLR	3/5/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Remove freon from old units	3/10/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	FCU RM 1C & RM 4C-BOTH NOT COOLING-SBE HASSLETT 416-4578 KLR	8/12/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	FCU RMS 13A, 3C, & 4C-ALL NOT COOLING-PLANT MGR HASSLET 416-4570 KLR	8/21/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Three (3) Rooftop units over the CAFETERIA are NOT COOLING per Mr. Haslett, Plant Mgr. 901.416.1743.	8/23/13			Heating/Ventilation /Air Conditioning

Magnolia ES (2470) 1A	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Monthly - Air Compressor PMs - Magnolia Elementary - Refer to PM schedule details.	6/2/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Monthly - Oil Lube & Belt- Magnolia Elementary - Refer to PM schedule details.	6/2/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Room 1C a/c not cooling per Jesse Hazlip 416-4507	8/7/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Unit Ventilator NOT COOLING in Room 1C per Jessie, Plant Mgr. at 901.416.4570	8/7/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Monthly - Filter-Magnolia Elementary - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Monthly - Filter-Magnolia Elementary - Refer to PM schedule details.	11/23/13			Heating/Ventilation /Air Conditioning
Magnolia ES (2470) 1A	Yearly - Boiler - Magnolia Elem - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning

Magnolia ES (2470) 1A	wall paper in the conference room fall down do to water damager.	7/23/13			Painting
Magnolia ES (2470) 1A	EGGS THROWN ON LEFT FRONT DOOR, & NORTH-END BLDG DOOR. PLANT MGR-HASLETT/416.5012	10/29/13			Painting
Magnolia ES (2470) 1A	paint walls principal office & con.rm.	8/13/13			Painting
Magnolia ES (2470) 1A	The water founding in the cafeteria front cover broken off.	7/12/13			Plumbing
Magnolia ES (2470) 1A	UNIT IN RM 4C & IN 109 IS LEAKING SBE HASSLET 416-	7/26/13			Plumbing
Magnolia ES (2470) 1A	in boy restroom blue hall toilet seat broken off.	8/26/13			Plumbing
Magnolia ES (2470) 1A	no the blue hall girl restroom won't flush. and same hall boy rest room seat broken off.	8/30/13			Plumbing
Magnolia ES (2470) 1A	Request back flow test.	9/5/13			Plumbing

Magnolia ES (2470) 1A	blue hall boy restroom sink water can't turn off. GIRL restroom stall door broken .	9/13/13			Plumbing
Magnolia ES (2470) 1A	Hot Water Heater is LEAKING water on the BLUE hall behind the office per Jessie Haslett, Plant Mgr. 416.4578	9/19/13			Plumbing
Magnolia ES (2470) 1A	boy restroom stall door broken need replace.	9/24/13			Plumbing
Magnolia ES (2470) 1A	A/C IN RMS 2C & 4C-BOTH ARE LEAKING-PLANT MGR 416-4578 KLR	10/10/13			Plumbing
Magnolia ES (2470) 1A	in room 2c sink has no water pressure	10/14/13			Plumbing
Magnolia ES (2470) 1A	UNIT IS LEAKING WATER CONTINUOUSLY IN RM-207. PLANT MGR-HASLETT/416.5012	10/29/13			Plumbing
Magnolia ES (2470) 1A	GAS SMELL IN CAFE DINING AREA-PLANT MGR HASLETT 416-4578 KLR	11/6/13			Plumbing
Magnolia ES (2470) 1A	GAS LEAK IN KITCHEN. PLANT MGR-JESSIE/416.4578	11/11/13			Plumbing

Magnolia ES (2470) 1A	boy restroom on 4th 5 th grade hall, toilet won't flush and the urinals won't flush.	11/13/13			Plumbing
Magnolia ES (2470) 1A	the water founder in by the P.E. room , has on pressure for the water to come out.	11/13/13			Plumbing
Magnolia ES (2470) 1A	boy rest on blue hall	12/9/13			Plumbing
Magnolia ES (2470) 1A	the big round hand sink is broken hall by the P.E.	12/10/13			Plumbing
Magnolia ES (2470) 1A	WATER TANK IS LEAKING WATER BY CAFE PLANT MGR-HASLETT/416.5012	12/18/13			Plumbing
Magnolia ES (2470) 1A	per Ms. Haslett 416-1743 the water tank in the closet in front of cafeteria is leaking all over the floor	12/23/13			Plumbing
Magnolia ES (2470) 1A	on the end of green hall restroom toilet flush valve not work.	1/14/14			Plumbing
Magnolia ES (2470) 1A	i have 2 urinal flush valve bad leaking water	2/3/14			Plumbing

Magnolia ES (2470) 1A	Remove valve arm.	2/4/14			Plumbing
Magnolia ES (2470) 1A	BOY RESTROOM IN FRONT OF THE CAFE URINAL AND TOILET LEAK WATER CAN'T FLUSH.	2/10/14			Plumbing
Magnolia ES (2470) 1A	in the kitchen the sink has a bad leak.	2/28/14			Plumbing
Magnolia ES (2470) 1A	the big round sink has on pressure! in the hall by the cafe .	3/19/14			Plumbing
Magnolia ES (2470) 1A	in the serviceline in kitchen the drains are clogup.	8/14/13			Plumbing
Magnolia ES (2470) 1A	girl restroom in front of the cafe 3rd stall seat broken.	3/26/14			Plumbing
Magnolia ES (2470) 1A	RETURN PIPE VALVE MECH RM HAS WATER RUNNING OUT OF IT-CAN'T CONTAIN OR CUT OFF PLANT MGR HASLETT 416-1743 KLR	3/26/14			Plumbing
Magnolia ES (2470) 1A	GAS SMELL KITCHEN AREA- PLANT MGR HASLETT 416-4578 KLR	4/16/14			Plumbing

Magnolia ES (2470) 1A	girl restroom on the blue hall won't flush .	5/5/14			Plumbing
Magnolia ES (2470) 1A	in room 2c the handle broken	8/6/13			Plumbing
Magnolia ES (2470) 1A	their leak in the main office from the roof.	7/24/13			Roof
Magnolia ES (2470) 1A	the gutter and roof need cleaning because of leaves	12/5/13			Roof
Magnolia ES (2470) 1A	roof drain need cleaning.	3/19/14			Roof

Count of Craft	Craft								
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Manassas HS (2480) 1B	2	55	89	103	12	47	15	3	326
Grand Total	2	55	89	103	12	47	15	3	326

Location	Request Description	Submittal Dat	Area Descript	Area Number	Craft
Manassas HS (2480) 1B	Need to have the gym floor refinished(SHINE ONLY), but the coaches do not want a buffer on the floor. Just had school tiger put on floor and do not want it removed or damaged.	10/2/13	Gym	Refinish Gym floors	Asbestos
Manassas HS (2480) 1B	The ceiling in the locker room near the stalls, has this white stuff fallen from the ceiling. The coaches think it's Abeseto? Please check on this. I have a picture in my phone. He won't let them use the locker room until this is fix. Urgent reply needed.	10/10/13	Restroom (Boys)	locker room	Asbestos
Manassas HS (2480) 1B	INSTALL WIRE ON TOP OF CHAIN LINK FENCE AT REAR OF SCHOOL. FENCE AROUND REFRIGERATION UNITS.	8/2/13			Carpentry
Manassas HS (2480) 1B	Repair cabinet doors	7/1/13		1056, 1073	Carpentry
Manassas HS (2480) 1B	Repair cabinet doors	7/1/13		1161,1163	Carpentry
Manassas HS (2480) 1B	Repair cabinet doors	7/1/13		1164,1167	Carpentry
Manassas HS (2480) 1B	Need to have 4 pcs. of ceiling tile replaced in the hall mold is present.	7/12/13	Hallway/Corridor	in front of room 1164	Carpentry

Manassas HS (2480) 1B	Leak has been repaired. Ceiling tile needs to be replaced in the front entrance of door and over the computer table.	7/12/13	Classroom	1168	Carpentry
Manassas HS (2480) 1B	Sergant request that bulletin board be install on wall. The board just got here, just need to be put up ASAP	8/1/13	Classroom	ROTC area	Carpentry
Manassas HS (2480) 1B	Install hasp on cabinet door to protect main gas cutoff. Student turned on and filled classroom.	8/16/13			Carpentry
Manassas HS (2480) 1B	need to have a lock placed on this cabinet also, so the students won't turn the gas on in here! room 1162	8/19/13	Classroom	science lab 1st floor room 1162	Carpentry
Manassas HS (2480) 1B	Exit door in men locker room is hard to secure. The hinge is off track. Makes it very hard to close door.	8/21/13	Gym	locker room	Carpentry
Manassas HS (2480) 1B	Hinge is also bad on this door. Need to be replaced.	8/21/13	Administration Area	Conference room	Carpentry
Manassas HS (2480) 1B	The door is off the hinge and will not secure. Someone is taking food out of this area. The instructor is concerned about this. The students have been caught at the ovens. Urgent reply needed to protect gas exposure and thief of food items.	8/29/13	Kitchen	1022 Culinary Arts	Carpentry
Manassas HS (2480) 1B	There is another cork board that needs to be installed in hallway area for the ROTC team. Ask teacher in 1071 where to hang it. I think its next to the restroom on that hall?	9/4/13	Hallway/Corridor	ROTC	Carpentry

Manassas HS (2480) 1B	Cabinet door has fallen off hinge. Urgent reply needed. I had two workers trying to help me put door back up, but we couldn't get it back up.	9/9/13	Kitchen	Tiger Den 1026	Carpentry
Manassas HS (2480) 1B	Ceiling tile needs to be change around sprinkler heads. I can't do it. I tried. I change the parts that had mold or was wet/damage. Some need to be cut around small corners in 2027.	9/19/13	Classroom	1169, 2006, 2027,2029	Carpentry
Manassas HS (2480) 1B	Ceiling tile needs to be cut around sprinkler heads. We tried and couldn't do it. We replaced what we could. Uregnt reply needed, some is stain and starting to turn moldly	9/23/13	Classroom	1164, 1169, 2004, 2006, 2025, 2029	Carpentry
Manassas HS (2480) 1B	Need to have ceiling tile cut and replaced outside of room in the hall area. Mold is starting to form.	9/23/13	Classroom	outside 1164	Carpentry
Manassas HS (2480) 1B	Need to have bullentine board install on Main Hall	10/3/13	Hallway/Corridor	Main Hall	Carpentry
Manassas HS (2480) 1B	HARDWARE ON DOOR IN CAFE LEADING TO SERVING LINE-HAS BEEN DAMAGED-CAN'T SECURE-PLANT MGR FIFER 416-3244 KLR	10/21/13			Carpentry
Manassas HS (2480) 1B	Something is stuck inside the combination lock in the girls locker room. It's locker 51, a student said her purse and stuff in there. Ask For Coach Jackson, he can let you in the girls locker room. All the other lockers have been open.	10/23/13	Restroom (Girls)	Locker Room	Carpentry
Manassas HS (2480) 1B	The cabinet door has fallen off the hinge. Students could get hurt. I tried to fix it but the door is too heavy for me to lift.	10/31/13	Classroom	2006	Carpentry

Manassas HS (2480) 1B	The heavy cabinet doors has fallen off the cabinets. Urgent reply. one room is a sped room and the other is a new teacher trying to get her supplies locked up	11/5/13	Classroom	2006 and 1062	Carpentry
Manassas HS (2480) 1B	PROVIDE HEAVY DUTY LOCK AND CHAIN FOR CAGE AREA IN REAR OF SCHOOL. AREA CONTAINS COMPRESSORS AND A/C EQUIPMENT.	11/12/13			Carpentry
Manassas HS (2480) 1B	When you open door with ID the door will not shut back all way, it's not catching to the latch, People are just walking in the building. It's The side with the ID swipe will not shut properly.	11/18/13	Administration Area	Front Main Entrance	Carpentry
Manassas HS (2480) 1B	The door knob fell off the door, when they go in the wash room and the door closes they can't get out! urgent reply needed.	12/10/13	Kitchen	Washing Closet	Carpentry
Manassas HS (2480) 1B	Someone has kicked the door open to the back of the stage area. This leads into the wood shop area, that should kept locked. Maybe cause it was so cold in there they kicked their way out?	12/11/13	Auditorium	back of stage	Carpentry
Manassas HS (2480) 1B	The big blue cabinet doors will not close. The Teachers is afraid that it will fall on a student. She has tape trying to keep it close. Urgent reply needed.	12/19/13	Classroom	1027	Carpentry
Manassas HS (2480) 1B	latch on cabinet door broken	12/20/13	1st Floor	1173	Carpentry
Manassas HS (2480) 1B	The big blue cabinet doors has fallen off the hinge. Urgent reply needed. This is the staff conference room.	1/9/14	Administration Area	1033	Carpentry

Manassas HS (2480) 1B	Someone pull the entire handle off the fire door entrance near metal detectors. This outside door is located near the football field entrance. Urgent reply needed. The part will be in the custodial breakroom. If it can be used again.	1/10/14	1st Floor	Outside of Metal Detector door	Carpentry
Manassas HS (2480) 1B	Another big cabinet door has fallen off the hinge. Urgent reply needed. These doors are very heavy and will fall and hurt someone. I tried to move it, but it's right near the cabinet.	1/21/14	Classroom	1163	Carpentry
Manassas HS (2480) 1B	repair door in room 2023 Asst. Principal office	6/12/14	Classroom	2023	Carpentry
Manassas HS (2480) 1B	Need to have ceiling tile replaced in this area. The holes where plug where the water leak was coming from. The ceiling tile is around the duct detector and needs to be replace. They will need a lift.	6/18/14	Classroom	Band room 1093	Carpentry
Manassas HS (2480) 1B	Both of the crash bars on the fire doors has failed. The techs been here all day. This is preventing the ID wipes from opening the doors.	6/19/14	Administration Area	Student Main entrance and Side door football field	Carpentry
Manassas HS (2480) 1B	remove shelving from room 1058 to strg room 1065 which is custodial break room gca supplies (thanks)	6/27/14			Carpentry
Manassas HS (2480) 1B	There are several ceiling tiles that I did replace this morn and There are others I can't cut and measure around area. Teachers states she is having respiratory problems. She also states she wants the filters changed, cause she is running back and forth to the hospital. Urgent reply needed.	8/26/13	Classroom	2027	Carpentry
Manassas HS (2480) 1B	There were several ceiling tiles that has fallen down. It it also wet and hanging around the system duct detectors. You will need a lift to reach the ceiling to replace tile. Urgent reply needed.	4/28/14	Classroom	Band Room 1093	Carpentry

Manassas HS (2480) 1B	damage ceiling tile fell out total of 5 need replacing over 15' in band room teacher complaining	4/29/14	1st Floor	BAND ROOM	Carpentry
Manassas HS (2480) 1B	The door is locking from the lock, but the door is not catching to lock when it closed. Students are stealing admit to class slips, etc and going in the secretaries purses. Urgent reply needed today.	4/30/14	Administration Area	Attendance Office	Carpentry
Manassas HS (2480) 1B	The top of the door hinge has falling off. This is a hazard when the teacher opens the door, it flies open and will the person from the other side of door.	4/30/14	Classroom	2024	Carpentry
Manassas HS (2480) 1B	door to tall cabinet fell off teacher not able to secure items special ed room	5/13/14	1st Floor	1052	Carpentry
Manassas HS (2480) 1B	the supervisor request that something be placed over the window that's not being used. The students are climbing through the window and taking items for this Kitchen.	3/26/14	Kitchen	Back area	Carpentry
Manassas HS (2480) 1B	room 1033 has several big cabinet doors that has fallen down urgent reply needed. These cabinets are right in front of the conference table.	3/26/14	Administration Area	Asst Principal	Carpentry
Manassas HS (2480) 1B	ROTC Hall room 1073 tall cabinet door is broken off need repair	5/27/14	1st Floor		Carpentry
Manassas HS (2480) 1B	DOOR - EXIT DR BY METAL DETECTORS - PIN HAS FALLEN OUT - CAN'T SECURE - PM/FIFER 416-2762	2/12/14			Carpentry

Manassas HS (2480) 1B	The big blue cabinet door fell on a student this morning when they tried to open the door!!!. Urgent reply needed. The other door is fallen off the hinge as well. Teacher is very concern	2/13/14	Classroom	1163	Carpentry
Manassas HS (2480) 1B	Need to have something put at the bottom of the door. A RAT chewed 1/2 of the bottom of the door off to get under the door.	2/18/14	Library	Office door	Carpentry
Manassas HS (2480) 1B	Repair fence area around MLGW meter/transformer.	2/26/14	Grounds		Carpentry
Manassas HS (2480) 1B	per ms fifer 416-2720 room 1140 broken out window due to vandalism can't secure	2/27/14			Carpentry
Manassas HS (2480) 1B	Two of the big blue cabinet doors has fallen off the hinge. Urgent reply. We can't move these doors cause they are so heavy.	2/28/14	Administration Area	1033	Carpentry
Manassas HS (2480) 1B	There are two large blue cabinet doors that have fallen down. Urgent reply needed. The hinge has broke on both of the doors. It almost fell on the teacher when she went to open the door this morning.	3/24/14	Classroom	1141	Carpentry
Manassas HS (2480) 1B	outside cafeteria door baseboard need repaing beige color	5/15/14	Cafeteria		Carpentry
Manassas HS (2480) 1B	Need to have barb wire install over fence area. The Air unit has been repaired. Now, we need to keep it secured and in tack.	7/22/13	Courtyard	behind cafe area	Carpentry

Manassas HS (2480) 1B	Magnets on fire doors need to be lowered. I can't reach them to hold the door open. They are too high, can they be moved down.	8/21/13	Hallway/Corridor	Across from Main Office	Carpentry
Manassas HS (2480) 1B	Coach Moore request a 4x6 or 8x10 plexy glass to cover the board outside his room. The student work data is being torn down. We want to protect the work.	1/29/14	Hallway/Corridor	2019	Carpentry
Manassas HS (2480) 1B	There's a burning smell coming from the light fixture in front of the guidance office in the hall. Waiting on bulbs to replace light. Urgent reply needed	8/8/13	Hallway/Corridor	1st floor hall	Electrical
Manassas HS (2480) 1B	Bells needs to be reset for new school time 7:30-2:30	7/5/13	Administration Area		Electrical
Manassas HS (2480) 1B	There are two sets of ballast that has burn out in cafe. The front lobby near principal has several burn out bulbs as well. Urgent reply need for front lobby. Its very dark in here when I arrive. Urgent Reply needed.	7/5/13	Cafetorium	and front lobby	Electrical
Manassas HS (2480) 1B	Check/clean smoke detectors.	7/25/13	Auditorium		Electrical
Manassas HS (2480) 1B	I'm sorry, this number should be for manassas 368368 and not cladwell guthrie. Mind freeze	7/29/13	Cafeteria	kitchen serving area	Electrical
Manassas HS (2480) 1B	COPPER WIRE FROM UNIT HAS BEEN STOLEN AGAIN AND CAUSE FREEZER & REFRIGERATOR HAVE NO POWER . PLANT MGR-FIFTER/416.3244	7/31/13			Electrical

Manassas HS (2480) 1B	Principal request that bulbs be replaced on stage area. It's very dark. I have no bulbs on site to replace them .	7/12/13	Auditorium	stage area	Electrical
Manassas HS (2480) 1B	work order number 364412 was declined because I didn't have bulb number/count. I need the following bulbs and here's the number 46807 rapid start lamps need 72 bulbs and 2 boxes of 42w 4 pin Blax T/E Eco in green box	7/16/13	Hallway/Corridor	and classrooms and cafe	Electrical
Manassas HS (2480) 1B	A/C KITCHEN AREA-NOT COMING ON-VERY HOT IN AREA-CAFE MGR HAS GOTTEN SICK PER PLANT MGR-PLANT MGR FIFER 416-3244 KLR	8/20/13			Electrical
Manassas HS (2480) 1B	Power outage. set clocks. Check elevator circuits.	9/10/13			Electrical
Manassas HS (2480) 1B	The light is out on the pole where the double camera are housed. It's dark and camera can't pick up criminal acts on school property. Urgent reply	9/11/13		back parking lot near field	Electrical
Manassas HS (2480) 1B	LIGHTS HAVE NO POWER IN AUDIT. PLANT MGR-FIFER/416.3244	9/12/13			Electrical
Manassas HS (2480) 1B	NO POWER IN KITCHEN DEN PLANT MGR-FIFER/416.3244	9/12/13			Electrical
Manassas HS (2480) 1B	Bad sockets in classrooms. Check the breakers, power didn't come on.	9/23/13	Classroom	2019	Electrical

Manassas HS (2480) 1B	The nreaker keeps tripping the serving line out. Urgent reply needed. The breaker is located in the closet of 1186. There has to be a real problem for this breaker to keep tripping.	9/24/13	Kitchen	Kitchen serving line	Electrical
Manassas HS (2480) 1B	a/c in kitchen is not coming on and very hot per Ms. Fifer 416-2762	9/30/13			Electrical
Manassas HS (2480) 1B	room 1140 there is a strong burning smell per Ms. Fifer 416-2762	9/30/13			Electrical
Manassas HS (2480) 1B	kitchen serving area and plant manager's office a/c is not coming on per Ms. Fifer 416-2762	10/2/13			Electrical
Manassas HS (2480) 1B	Kitchen and plant manager's office breaker keeps tripping out on roof top units and there is no a/c per Ms. Fifer 416-2762	10/4/13			Electrical
Manassas HS (2480) 1B	HAD A POWER OUTAGE THIS MORNING AND A LOT OF THINGS DIDN'T COME BACK UP SUCH AS BELLS, AIR, KITCHEN EQUIPMENT- PLANT MGR FIFER 416-3244 KLR	10/31/13			Electrical
Manassas HS (2480) 1B	I sent Mr. White a email on 9/19 stating we needed 3 boxes of rapid start bulbs. The ticket was declined? We need bulbs to replace burn out lamps, so we will know if it's the ballast Uregent Reply ASAP. w/o 384942	11/1/13	Administration Area	Main Office, Classrooms, Hallways	Electrical
Manassas HS (2480) 1B	HAS A BURNING SMELL ON THE 1ST FLR HALL NEAR THE TIGER DEN - PM IS NOT SURE WHAT IS BURNING - PM/FIFER 416-2762	11/8/13			Electrical

Manassas HS (2480) 1B	RTU 59 No Power Possible blown Fuses or Safety No 24v	11/8/13			Electrical
Manassas HS (2480) 1B	RTU 55 No Power Possible blown Fuses or Safety No 24v	11/8/13			Electrical
Manassas HS (2480) 1B	RTU 57 No Power Possible blown Fuses or Safety No 24v	11/8/13			Electrical
Manassas HS (2480) 1B	RTU 64 No Power Possible blown Fuses or Safety No 24v	11/8/13			Electrical
Manassas HS (2480) 1B	per ms fifer 416-2740 burning smell in main hallway and 1st floor hallway very strong	11/14/13			Electrical
Manassas HS (2480) 1B	This area is VERY dark when the cafe manager and I arrive. The lights on the dock have burned out. There are 3 lights. I don't have for and can't reach. Urgent reply to keep us safe as we enter the work place.	11/15/13	Administration Area	Back dock	Electrical
Manassas HS (2480) 1B	The ballast has burned out in the restroom in the Director office 1130 inside the Gyn area	11/18/13	Administration Area	Director Office Restroom	Electrical
Manassas HS (2480) 1B	The ballast has burned out in the restroom in 1130 the Directors office restrooms	11/18/13	Administration Area	coaches area	Electrical

Manassas HS (2480) 1B	magnet will not hold fire door open	11/21/13	1st Floor	main lobby west door	Electrical
Manassas HS (2480) 1B	Night Manager changed out bulbs and they didn't come on. Ballast is out.	11/27/13	Classroom	1033	Electrical
Manassas HS (2480) 1B	Ballast is out in girls restroom. The entrance of door.	11/27/13	Restroom (Girls)	2nd floor hall	Electrical
Manassas HS (2480) 1B	Front of school facing east light pole light is out on the building. It's very dark will I arrive at 5:55am. Urgent reply needed	11/27/13	Parking Lot	Front of school	Electrical
Manassas HS (2480) 1B	There are three lights out in the front Main lobby. The other lights were change out, now these have burned out. Will need a lift to reach them. I may have bulbs?	11/27/13	Hallway/Corridor	Main Hall Entrance	Electrical
Manassas HS (2480) 1B	Electrical outlets not working in these area.	11/27/13	Classroom	1052, 1033 and library	Electrical
Manassas HS (2480) 1B	Bad sockets in classrooms. Check the breakers, power didn't come on.	11/27/13	Classroom	2019	Electrical
Manassas HS (2480) 1B	RECEPTACLE RM 1169-SPARKED FIRE & PRONGS STILL INSIDE OF IT AND WIRES EXPOSED-PLANT MGR HAWKINS-TAYLOR 416-3244 KLR	12/9/13			Electrical

Manassas HS (2480) 1B	Can lights in girls locerroom 1121 in shower area will not come on (3)	12/9/13	Gym	girls locker rm 1121	Electrical
Manassas HS (2480) 1B	can lights in shower area in girls lockerm 1122 will com on	12/9/13	Gym	girls lockerm 1122	Electrical
Manassas HS (2480) 1B	light fixture in hall front of lockerrooms bad ballast	12/9/13	Hallway/Corridor	front of locker rooms	Electrical
Manassas HS (2480) 1B	bad ballast front of lockers	12/9/13	Gym	girls lockerm 1122	Electrical
Manassas HS (2480) 1B	two section of lights out in gym and auditorium lobby out over 10'	12/9/13	Hallway/Corridor	gym & aud lobby	Electrical
Manassas HS (2480) 1B	fire door will not stay open where the students come through the metal detectors. Urgent reply needed.	12/17/13	Hallway/Corridor	near metal detector	Electrical
Manassas HS (2480) 1B	Ballast has burned out over the copier machine in the main office.	12/17/13	Administration Area	main office	Electrical
Manassas HS (2480) 1B	Receptacles in the CAFETERIA are not working per Ms. Taylor, Plant Mgr. 416.3244	1/6/14			Electrical

Manassas HS (2480) 1B	Rooftop Unit is NOT COMING ON in the GYM per Ms. Fifer, Plant Mgr. 416.2762	1/8/14			Electrical
Manassas HS (2480) 1B	The bleachers are not pulling all the way out. This is Basketball season and we need these bleachers working properly. Urgent reply needed. The far left side top near the entrance door.	1/8/14	Gym	Sitting area	Electrical
Manassas HS (2480) 1B	light fixture in ceiling left socket is out	1/9/14	2nd Floor	front of rm 2033	Electrical
Manassas HS (2480) 1B	bad socket in ceiling light inside classroom 2019	1/9/14	Classroom	2019	Electrical
Manassas HS (2480) 1B	A/C RM 1033 FACILITATOR'S OFC-NOT COMING ON-PLANT MGR FIFER 416-3244 KLR	6/20/14			Electrical
Manassas HS (2480) 1B	prong from the cord is broken off in floor socket causing a shortage in room	5/13/14	1st Floor	1033	Electrical
Manassas HS (2480) 1B	north wall west entrance prong from cord broken off into socket	5/13/14	1st Floor	west entrance	Electrical
Manassas HS (2480) 1B	The electrician came out this morn looking for a plug stuck in the wall. After he left, I did see it in the floor in the big gray outlet. The night Plant Manager wrote it up wrong. Can you have him to come back out to remove the plug.	5/14/14	Administration Area	1033	Electrical

Manassas HS (2480) 1B	Repair/Replace lights in Wall Pack units on North side of building.	3/24/14	Grounds		Electrical
Manassas HS (2480) 1B	The outside lights around the building are turning off at 6:10. Can someone reset the lights to go off at 7:00 its still dark when staff arrives. Urgent reply needed	4/3/14	Administration Area	Outside of building	Electrical
Manassas HS (2480) 1B	Light out where the cafe units are housed where they stole the cooper wire. The light in the front main lobby is also out.	4/3/14	Courtyard	side of building and front lobby area	Electrical
Manassas HS (2480) 1B	A set of lights have burned out in the 2nd floor stairwell. Its the middle stairwell next to the elevator. They will need a lift to reach the lights.	5/23/14	Stairway	2nd floor hall	Electrical
Manassas HS (2480) 1B	BETWEEN ROOMS 1072 AND 1073 ON ROTC HALL BAD BALLAST NEW BULBS IN LIGHT FIXTURE (donot replace bulbs)	5/27/14	1st Floor	ROTC HALL	Electrical
Manassas HS (2480) 1B	baroken lens and frame in cafeteria eating area	4/7/14	Cafeteria	eating area	Electrical
Manassas HS (2480) 1B	The lights have blown over the big heaters in this area. It's dark and I can't reach that high.	4/9/14	Mechanical Room	outside of west entrance	Electrical
Manassas HS (2480) 1B	Repair lights on North canopy.	4/22/14	Grounds		Electrical

Manassas HS (2480) 1B	Repair lights on west canopy.	4/22/14	Grounds		Electrical
Manassas HS (2480) 1B	Repair lights on east canopy.	4/22/14	Grounds		Electrical
Manassas HS (2480) 1B	STEAM TABLE is NOT ENOUGH GETTING POWER per Ms. Fifer, Plant Mgr. 416.2762	4/25/14			Electrical
Manassas HS (2480) 1B	No power voltage to serving table. CNC tech is here NOW waiting. Urgent reply	4/25/14	Kitchen		Electrical
Manassas HS (2480) 1B	Steve Harvey will be here in two weeks! The lights in the stairwell is out. We can't reach it due to the stairs. You gone need a lift to change the lights. Stairwell has 2 set of ballast out. Urgent reply. Mr. Harvey will be in this area when he arrives. Urgent reply needed	1/29/14	Hallway/Corridor	near metal detectors	Electrical
Manassas HS (2480) 1B	RTU NOT COMING ON THRU BLDG. PLANT MGR-FIFER/416.3244	2/7/14			Electrical
Manassas HS (2480) 1B	Need to have about 40 bulbs replaced in the high ceiling. I will require a lift.	2/7/14	Auditorium		Electrical
Manassas HS (2480) 1B	North side of eating area in cafeteria four sections of lights out	2/17/14	Cafetorium	eating area N side	Electrical

Manassas HS (2480) 1B	gym lobby near restrooms two sections of lights out over 10'and cafeteria over 10'	2/17/14	Hallway/Corridor	gym lobby area	Electrical
Manassas HS (2480) 1B	One entire row of lights are out. There is a shortage in the switch and it's sparks fire when you stick the key in there to turn on/off. We have to leave the lights on! I did cover that part with paper and tape, so no one would get shock. Urgent reply	2/21/14	Gym	Entire Gym	Electrical
Manassas HS (2480) 1B	I need 3 boxes of rapid start tubs for the classrooms, halls, office area.The last couple of boxes that were sent are all bad. We could not use them. You can pick them back up.	2/26/14	Administration Area	Main Office	Electrical
Manassas HS (2480) 1B	Deliver man lift to Manassas high. To support Tony Wright.	3/19/14			Electrical
Manassas HS (2480) 1B	There are 5 lights that's out on the front of the building. It's dark when I arrive. I have place several request in the past when there were only 2 out. Not more lights have burned out.	3/20/14	Parking Lot		Electrical
Manassas HS (2480) 1B	There are 5 inside lights out on the wall that keep this hall bright. Urgent reply needed while they have a lift over here. These lights make all the different, it's dark on the inside hall until the sun comes up and shines through the windows	3/20/14	Hallway/Corridor	Main hall	Electrical
Manassas HS (2480) 1B	Replace outside lights under canopy in front of school. East side	3/24/14	Administration Area	Canopy	Electrical
Manassas HS (2480) 1B	West canopy need to have bulbs replaced.	3/24/14	Administration Area	West canopy- Student entrance	Electrical

Manassas HS (2480) 1B	The bulbs on the North canopy needs to be replaced	3/24/14	Administration Area	North side canopy	Electrical
Manassas HS (2480) 1B	Electrical outlets not working in these area.	9/19/13	Classroom	1052, 1033 and library	Electrical
Manassas HS (2480) 1B	Front of school facing east light pole light is out on the building. It's very dark will I arrive at 5:55am. Urgent reply needed	9/5/13	Parking Lot	Front of school	Electrical
Manassas HS (2480) 1B	There are three lights out in the front Main lobby. The other lights were change out, now these have burned out. Will need a lift to reach them. I may have bulbs?	9/5/13	Hallway/Corridor	Main Hall Entrance	Electrical
Manassas HS (2480) 1B	Ballast is out in girls restroom. The entrance of door.	8/21/13	Restroom (Girls)	2nd floor hall	Electrical
Manassas HS (2480) 1B	Night Manager changed out bulbs and they didn't come on. Ballast is out.	8/20/13	Classroom	1033	Electrical
Manassas HS (2480) 1B	Need three more boxes of rapid start bulbs to finish changing out lights in office, classrooms, storage closets and hallway	9/19/13	Administration Area	entire building	Electrical
Manassas HS (2480) 1B	I need several boxes of rapid start bulbs at Manassas and Caldwell to replace all the burned out lights. If bulbs can be delivered at both locations I can replace them.	7/12/13	Cafetorium	Hall and classroom areas	Electrical

Manassas HS (2480) 1B	I need two boxes of rapid start tubes for the classrooms.	1/21/14	Classroom		Electrical
Manassas HS (2480) 1B	Need about 30 lights for the house seats. The front of house needs need about 20 spot lights replace also. Programs are scheduled for these areas.	8/28/13	Auditorium	House seats	Electrical
Manassas HS (2480) 1B	room 1186 right outside the Plant Manager Office where the breakers are.	4/25/14	Mechanical Room		Electrical
Manassas HS (2480) 1B	The roofers and HVAC were out last week, but there is still several leaks coming from the library. Urgent reply needed. Starting to smell like mold.	8/5/13	Library		Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Room is not cooling.	8/6/13	Classroom	1144	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	CHILLERS ARE NOT COMING ON ENTIRE BLDG IS HOT. SBE FIFER	7/1/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	aud. units filters	7/24/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Need to have filter replace. Dirty filter set off alarm, fire Dept had to shut unit off. It needs to be turned back on once filter is changed. Urgent reply	7/24/13	Auditorium	top of roof	Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	Most of the rooms are not cooling. I call energy management. Need someone to show me how to work this system to get air. Teachers in building and registration today and tomorrow	7/29/13	Classroom	tiger den, 2004, 2005, 2006	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Room 2025 and 1062 is so hot you can't breathe. Durning the day it's very hot. Teachers couldn't work in room. Thermostat in room may not be working properly, then this must be the case for 1/2 of the building.	7/30/13	Classroom	2nd floor and 1st floor	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	This room is very HOT. I tried to reset the thermostat box but it did work.	7/31/13	Classroom	room 1052	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Room is very hot, fan blowing, but not cooling at all.	8/1/13	Classroom	1144	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	room is not cooling at all. It very hot. This is a special need class.	8/1/13	Classroom	1056	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	the compressor has went out in this room, fan not blowing, room very hot.	8/1/13	Classroom	2024	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	This room is very hot. Air not cooling blowing warm air.	8/1/13	Classroom	1161	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	clean rtu's	8/13/13			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	clean rtu coils	8/15/13				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	check job for install of controls	8/15/13				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	A/C IN ENTIRE BLDG-NOT COOLING PER PLANT MGR-PLANT MGR FIFER 416-3220 KLR	8/19/13				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	The air has gone out. There is also a foul odor present.	8/30/13	Classroom	1141		Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Teachers is complaining about the air and it's hot in her room. Principal is also concern. And it has a funny smell	8/30/13	Classroom	1141		Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Room is very hot reading 79 degress. No air is blowing. I tried to reset panel, but no luck.	9/9/13	Classroom	ROTC room 1071		Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	UNIT NOT COOLING IN KITCHEN PLANT MGR-FIFER/416.3220	9/16/13				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1061 and 1062 not cooling	9/18/13				Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	rm 2024 has restriction	9/18/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu #45 has bad contactor	9/23/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Monthly - Filter-Manassas High - Refer to PM schedule details.	9/28/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	comp. rack room freezing up	9/30/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu 37 not cooling	9/30/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu 38 not cooling	9/30/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1140 rtu #46 IFM burnt up	9/30/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1059 not cooling	10/1/13			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	2- mini-splits not cooling	10/1/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Unit #14 which control the air to the Kitchen and Plant Manager office keeps tripping out. Bobby Barlow was here today to look at the unit to see why it keeps tripping out. It need gages and wires to keep from tripping out. Urgent reply needed.	10/14/13	Kitchen	Serving area	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Assist floor crew.	10/15/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU #58 no fan section	10/25/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU # 38 No Power NO 24 VOLTS	11/7/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU # 40 No Power NOT 24 VOLTS	11/7/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU 49 Bad Fan Motor	11/8/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	the units 50, 8, 49, 54 has tripped out. Need someone to repair this, so we can get heat. Urgent reply needed. I got this info from energy management when I called about the heat	11/13/13	Mechanical Room	Roof top units	Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	The roofer is out here now, These leaks has nothing to do with the roof. He states, there are holes in the unit in the Main office and the duct work in leaking in the Library. He left the ceiling tile back so you can see the holes and the leaks. Urgent reply needed to keep more damage from happening in the Main Office etc. Carpet library unit not firing	11/25/13	Administration Area	Main Office & Library	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B		12/4/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Teacher states this rooms gets to hot!! He has headaches. He just wants to heat to be turned off. The stat box does not work, but its reads 80 everyday. Urgent reply to get this problem solved.	12/9/13	Classroom	1093	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	This room 2011 is reading 66 and blowing cold air. Energy Management said its down. Urgent reply needed.	12/9/13	Classroom	2011	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	4 PIPE SYSTEM - COVERS ENTIRE SCHOOL - BLOWING COLD - BLDG IS FREEZING - PM IS REQUESTING THE SUPERVISOR TO COME OUT AND CHECK THE RMS PM/FIFER 416-2760	12/10/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 2024 regulator froze up	12/10/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Roof top unit 17, 34 and 15 is down. Urgent reply needed. Its freezing in this building! Most of the new stats are reading 66-67 That's cold and it 27 outside. Help!!!	12/11/13	Mechanical Room	Roof Top unitis	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	It's freezing in there! We can not have the Christmas program because it's so cold. You can feel the AIR blowing!!There is NO heat is coming from anywhere. This entire building is Freezing COLD	12/11/13	Auditorium	Entire area	Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	It's 6:45am the Auditorium is FREEZING!, the Gym is HOT, The hall near gym is freezing, most of the classrooms are freezing, please help. I know this couldn't be rite for the air to be blowing on the set point of 70?? at 1:00 they say it gets even colder in this building. I know something can be done. I know they wanted air this	12/12/13	Administration Area	Entire Building	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu #60 not heating	12/20/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu #61 not heating	12/20/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU #62 not heating	12/20/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	help EMS drop cables	12/20/13			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	The following roof top units are down. We have no Heat. rooftop 14, 8, 20, 22, 23, 32, 40, 38, 17 and room 1075. The units needs to be reset in order for us to have heat. Then I can call Booby back to see if its been reset to give a reading. Urgent reply. The since will bust its so cold!	1/6/14	Classroom	roof top units	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1071 not heating	1/10/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1072 not heating	1/10/14			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	rm 1073 not heating	1/10/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	2006 not heating	1/10/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	2025 not heating	1/10/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	31 not heating	1/10/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	verify power to ems controls	1/16/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu #8 not heating	1/17/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rtu #38 not heating	1/17/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU #40 not heating	1/17/14			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	This room had air before, now is burning up! Asst. Principal states she need someone out here. Urgent reply needed.	8/26/13	Administration Area	1033	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Rooms are not cooling, it's 80 in these rooms. Olt's 72 outside. It's muggy in this building. EM said the air is on?????	4/28/14	Classroom	1154 & 1140	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	They will be testing in this room. There is NO AIR Urgent reply needed today.	4/29/14	Administration Area	1033	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Top units 15, 23, 40, 55,57 and kitchen is not cooling. These kids are testing and it's very hot. Please help. EM said the units came on at 5:30 but it's not cooling in this building. Urgent reply needed	5/5/14	Mechanical Room	Most Classrooms	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	These following rooms are reading 80. It's very hot for these students to be testing. Urgent reply needed.	5/6/14	Classroom	1033, 1029, 1027	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Rooms are reading 77 and teacher and students are complaining it's hot. EM said its a HVAC problem.	4/3/14	Classroom	2023 and 2030	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Please send someone to see why 2006 is not cooling. The teacher being emailing me all day about them being hot and the students comes to my office complaining. We went through this with the air the entire time I've been there! It's not working. We get air when it's cold and heat when it's hot????? EM said the unit	4/4/14	Classroom	2006	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	A/C UNITS are NOT COOLING in ROOMS 1028, 1029, and 1033 per Ms. Hawkins, Plant Mgr. 416.3244	5/28/14			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	Monthly - Filter-Manassas High - Refer to PM schedule details.	5/31/14				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	UNIT NOT COOLING IN CAFE, LIBRARY, NORTH HALL-END 1ST FLR 10-RMS PLANT MGR-TAYLOR/416.3244	6/3/14				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	A/C RM 2030, RM 2002 & CAFE-ALL NOT COOLING-PLANT MGR TAYLOR 416-3244 KLR	6/9/14				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	These two rooms are ready 77 & 79. The heat is blowing in these rooms Very HOT. Urgent reply needed	4/14/14	Classroom	2024 & 2025		Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	UNIT NOT COOLING THRU ENTIRE 2ND FLR PLANT MGR-FIFER/416.3220	4/14/14				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU # 31 not cooling	4/16/14				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU #32 not cooling	4/16/14				Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU #34 not cooling	4/16/14				Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	RTU # 41 not cooling	4/16/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	per ms fifer 416-3248 the a/c in the gym unit #64 has failed they have no air and there is a talent show in there this afternoon	4/17/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	4-RTU NOT HEATING IN AUDIT, CAFE. PLANT MGR-FIFER/416.3244	1/21/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Cafeteria and Auditorium are blowing cold air - feels like igloo per ms fifer 416-2752	1/22/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1117 not heating	1/22/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 1121 not heating	1/22/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 17 not heating	1/22/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	rm 16 not heating	1/22/14			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	These 3 areas need to be addressed. It's very cold. The students can't go in there at all. It's like an meat freezer! The rest of the building feels warm.	1/23/14	Auditorium	and room 1071, coaches office area	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Room is reading 60 and its freezing. EM says they good on their end, so it's got to be something else?? Help these students. Its too cold to learn in there!	1/29/14	Classroom	2024	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	replace gas regulator on rtu for rm 2024	1/30/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	not heating rtu #61	1/30/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	not heating RTU #60	1/30/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Monthly - Oil Lube & Belt-Manassas High - Refer to PM schedule details.	2/1/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	Monthly - Filter-Manassas High - Refer to PM schedule details.	2/1/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	HEAT GYM AREA-NOT HEATING-THEY ARE HAVING A GAME TONIGHT PER SBE-PLANT MGR FIFER 416-3220 KLR	2/3/14			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	aud. is overheating	2/20/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	These areas are very cold. We have a game today and the gym is freezing. The Auditorium is cold along with the coaches area is freezing. Urgent reply needed do the players can practice before the game.	3/6/14	Auxiliary Gym	Gym, coaches area and auditorium	Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	BOILER-1 & BOILER-2-BOTH NOT HEATING-PLANT MGR FIFER 416-3244 KLR	3/7/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU 55 --- blown fuse	3/11/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU 57 --- bad transformer	3/11/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU 47 --- short	3/11/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU - GYM - BLOWING COLD AIR - NOT HEATING - HAVING ACT TESTING IN THAT LOCATION THIS MORNING PM/FIFER 416-2762	3/18/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	RTU - COVERS THE KITC AREA & SBE OFC - BLOWING COLD AIR - PM/FIFER 416-2762	3/20/14			Heating/Ventilation /Air Conditioning

Manassas HS (2480) 1B	assist EMS	3/20/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Manassas HS (2480) 1B	plaster work is needed to keep the ceiling from falling down. It's crumbling and needs to be repaired in the girls locker room. Urgent reply needed. The students/coaches think its something wrong. Urgent reply needed Girls locker room	2/4/14	Restroom (Girls)	girls locker room	Painting
Manassas HS (2480) 1B	ceiling has fallen in girls lockerroom due to rain need re-plaster and painted will completely fall down soon	4/7/14	Gym	girls lockerroom	Painting
Manassas HS (2480) 1B	school received grant to paint several areas at Principal request he need several areas painted school will purchase materials etc.	6/12/14	Classroom	parent center	Painting
Manassas HS (2480) 1B	please burn and stripe football field once for upcoming season. coaches will handle the rest of the season	7/29/13	Athletic Field		Painting
Manassas HS (2480) 1B	paint lines on football field	7/30/13			Painting
Manassas HS (2480) 1B	Paint gutters/downspouts, for James H.	9/5/13			Painting

Manassas HS (2480) 1B	paint lines on football field	9/10/13			Painting
Manassas HS (2480) 1B	Principal request that drive be clearly mark drop off entrance only. Arrows are needs for direction, parents are driving the wrong way, students are in danger of being hit when parents come throught the wrong drive. It's really bad in the evening at dimissal. Urgent repy needed.	9/11/13	Parking Lot	Student drop off area	Painting
Manassas HS (2480) 1B	someone has wrote on the yellow bleachers paint, markers. This is an eye sore and it's basketball season we need that removed ASAP..The side near the far wall.	1/13/14	Gym	Yellow Bleachers	Painting
Manassas HS (2480) 1B	paint lines on football field	5/8/14			Painting
Manassas HS (2480) 1B	Paint new wood white. Support WO 424727, Phillip H.	3/27/14	Kitchen		Painting
Manassas HS (2480) 1B	paint lines on football field	5/19/14			Painting
Manassas HS (2480) 1B	There is aleak in the entrance of the Auditorium. It's very hot in there also.	8/6/13	Auditorium	front area	Plumbing
Manassas HS (2480) 1B	Urinal is leaking inside the wall. I turn the water off, it's still behind the fixture. Urgent Reply needed.	8/6/13	Restroom (Boys)	2nd floor	Plumbing

Manassas HS (2480) 1B	Water fountain won't cut off. Students are putting paper, etc. in the drain and its keeps flooding the hall. Urgent reply needed.	8/7/13	Hallway/Corridor	2nd floor rear restrooms	Plumbing
Manassas HS (2480) 1B	Pipe leaking in two different areas a couple of ceiling tiles have fallen in Room 1168 per Ms. Fifer, Plant Mgr. at 416.3244.	7/5/13	1st Floor		Plumbing
Manassas HS (2480) 1B	Repair two overhead pipes that are leaking.	7/5/13			Plumbing
Manassas HS (2480) 1B	gas smell (auditorium) fire dept is there per Ms. Fifer 413-8202	7/24/13			Plumbing
Manassas HS (2480) 1B	There are several leaks in the library ceiling. It's damp and hot in there.	7/30/13	Library	media area	Plumbing
Manassas HS (2480) 1B	RTU leak.	8/13/13	Auditorium		Plumbing
Manassas HS (2480) 1B	Gutters stopped up. Need wash truck and elec. van with bucket to clean out.	8/14/13			Plumbing
Manassas HS (2480) 1B	GAS LEAK IN SCIENCE RM. PLANT MGR-FIFER/416.3220	8/16/13			Plumbing

Manassas HS (2480) 1B	Handi cap stall/toilet in men locker room will not flush properly.	8/21/13	Gym	Men locker room	Plumbing
Manassas HS (2480) 1B	Unstop gutter downspouts	8/30/13			Plumbing
Manassas HS (2480) 1B	water leaking from ceiling tile/sprinkler. Dnt know if it was from rain or pipe leaking. over student desks. Urgent reply needed.	9/26/13	Classroom	1164	Plumbing
Manassas HS (2480) 1B	Flush Downspouts	9/26/13			Plumbing
Manassas HS (2480) 1B	Hot water will not turn off on the hand sink. It's keeps running. I tried to cut it off, but it wouldn't.	10/4/13	Restroom (Boys)	1st floor hall	Plumbing
Manassas HS (2480) 1B	garbage disposal is stopped up. It's full of food and it's stinks. I tried to unstopp it. Urgent reply needed	10/22/13	Kitchen	Garbage Disposal	Plumbing
Manassas HS (2480) 1B	Girls rr 1st floor hall, girls Locker room, boys locker room, and boys rr restroom urnial on 2nd floor hall.	10/30/13	Restroom (Girls)		Plumbing
Manassas HS (2480) 1B	The senond stall in not flushing. I have tried to trun water off, put bag and signs in toilet, but students kkep putting stuff in there. We have use auger and its not working. Urgent reply before they flood the hall area.	11/5/13	Restroom (Girls)	1st floor hall near Plant Manager office	Plumbing

Manassas HS (2480) 1B	INSTALL GAS VALVES IN SCIENCE LABS.	11/6/13			Plumbing
Manassas HS (2480) 1B	First urinal on left will not flush over flows	11/21/13	Restroom (Boys)	2nd floor	Plumbing
Manassas HS (2480) 1B	GAS SMELL IN LIBRARY PLANT MGR-FIFER/416.3244	12/3/13			Plumbing
Manassas HS (2480) 1B	girls lockerroom toilet stopped will not flush stopped up in line	12/3/13	Gym	girls lockerroom	Plumbing
Manassas HS (2480) 1B	gas smell in main hall per Ms. Fifer 416-2732	12/9/13			Plumbing
Manassas HS (2480) 1B	back hall boys rr 3rd urinal is stopped up water overflows	12/11/13	Restroom (Boys)	back hall 1st flr	Plumbing
Manassas HS (2480) 1B	2nd floor back hall boys rr 2nd urinal water over flows will not go down	12/11/13	Restroom (Boys)	2nd flr back hall	Plumbing
Manassas HS (2480) 1B	front hall girls restroom 3rd stall toilet seat is broken in pcs need replacing special needs hall	12/13/13	1st Floor	front hall girls restroom	Plumbing

Manassas HS (2480) 1B	Toilet leaks when it's flushed. Water runs on the floor. The plumber is here working on other repairs, he will fix this also.	12/16/13	Classroom	1052 special Ed	Plumbing
Manassas HS (2480) 1B	Test and report on backflow prevention devices.	6/17/14			Plumbing
Manassas HS (2480) 1B	third urinal will not flush or drain kids keep using it	6/27/14	Restroom (Boys)	backhall firstfir	Plumbing
Manassas HS (2480) 1B	The first stall in the girls restroom, is stopping up. Someone has put something in there and we tried to unstop it. urgent reply needed	5/7/14	Classroom	ROTC hall	Plumbing
Manassas HS (2480) 1B	RTU 37 ---- replace gas cut off at unit	2/20/14			Plumbing
Manassas HS (2480) 1B	The hot water in the sink boys restroom will not cut off! I wrote this up 3/28/2014 the work order number was 422142. Urgent reply. Its the last days of school and the students have started to flood the restroom. I wish I could cut if off, but I cant. There is no cut off unless, I cut all the water off on the 2nd floor	5/12/14	Restroom (Boys)	2nd floor hall	Plumbing
Manassas HS (2480) 1B	Principal toilet seat is broken restroom in his office	4/7/14	Administration Area	principal office	Plumbing
Manassas HS (2480) 1B	bottle of deoderant stuck in trap of toilet cannot get out several attempts	4/7/14	Gym	lockerroom/1121	Plumbing

Manassas HS (2480) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	5/19/14			Plumbing
Manassas HS (2480) 1B	The urinal in the restrooms runs over and flood the floor. I can't turn it off so so reason. Urgent reply needed. Students slip and fell. I have wet floor sign down and had a bag over it, but someone keeps taken it off. Please come fix this problem	4/11/14	Restroom (Boys)	2nd floor hall	Plumbing
Manassas HS (2480) 1B	The 3rd urinal is over flowing again and the 2nd toilet is stopped up. I did auger but it's still stopped up with something. Urgent reply before the hall floods	4/24/14	Restroom (Boys)	2nd floor hall	Plumbing
Manassas HS (2480) 1B	urinal on left is leaking underneath	1/29/14	Restroom (Boys)	2nd flr	Plumbing
Manassas HS (2480) 1B	GAS SMELL IN RM-1161 PLANT MGR-FIFER/416.3244	2/6/14			Plumbing
Manassas HS (2480) 1B	I had to turn the breaker off. The water fountains just keeps running and the students are putting paper in the drain. This is flooding the hall over night. The water fountain near the girls restroom on 2nd floor.	2/13/14	Hallway/Corridor	2nd floor hall	Plumbing
Manassas HS (2480) 1B	RTU 34 --- regulator needs vent	2/20/14			Plumbing
Manassas HS (2480) 1B	RTU 62 ---- regulator needs vent	2/20/14			Plumbing

Manassas HS (2480) 1B	1st and 2nd urinal is leaking underneath the urinals causing urine to run over floor	3/4/14	2nd Floor	boys restroom	Plumbing
Manassas HS (2480) 1B	someone tried to flush a bottle of deoderant in toilet it's stuck not able to remove	3/4/14	Gym	boys lockerroom	Plumbing
Manassas HS (2480) 1B	The Kitchen is stopped up. Urgent reply needed. They need to use the sink 3 way to wash the dishes.	3/7/14	Kitchen	Prep Are	Plumbing
Manassas HS (2480) 1B	The hot water in the sink will not cut off!! That water is running very HOT. I can't turn it off. I tried. Urgent reply before some one gets burn.	3/17/14	Restroom (Boys)	2nd floor hall	Plumbing
Manassas HS (2480) 1B	The washer will not spin out the water when they wash the clothes for the student.	8/9/13	Classroom	room 1056 CDC-Sped aroom	Plumbing
Manassas HS (2480) 1B	The library is leaking in 5-6 different places. I had this problem when I 1st came here in July. I don't remember if it had holes somewhere in the roof or it was the pipes, but whatever it was it's leaking again. Urgent reply.	10/16/13	Library	computer area	Roof
Manassas HS (2480) 1B	room 2027 very bad roof leak 2006 leaking	11/21/13	Classroom	2027	Roof
Manassas HS (2480) 1B	ceiling leaking tiles fell down	11/21/13	1st Floor	library	Roof

Manassas HS (2480) 1B	center panel light water leaking from rain	11/21/13	Classroom	2005	Roof
Manassas HS (2480) 1B	roof leaking bad several tiles	11/21/13	2nd Floor	frnt of elevator	Roof
Manassas HS (2480) 1B	roof leaking	11/21/13	Administration Area	main office	Roof
Manassas HS (2480) 1B	roof leaking in gym lobby near restroom and concessions	11/25/13	Hallway/Corridor	gym lobby	Roof
Manassas HS (2480) 1B	Holes need to be repaired, so we can change the tile out, that has mold and stains on it. I will take the tile down today, it's holding a foul odor in this rooms. Urgent reply needed	12/9/13	Classroom	2027	Roof
Manassas HS (2480) 1B	The gutters are stopped up in front of school and the south end of the building. Urgent reply needed. Don't want roof the cave ceiling in	8/26/13	Courtyard	Front of school	Roof
Manassas HS (2480) 1B	need to have the roof checked over the band room. Ceiling tile has fallen in several places. Urgent reply to check this area	4/28/14	Classroom	band Room 1093	Roof
Manassas HS (2480) 1B	There are leaks all over the Auditorium and Library. Everytime the roofers comes, they say don't see anything or nothing has been repaired. It has to be leaks, when it rains there is proof. If it was a duct leak, then it will leak without the rain.	5/15/14	Library	Library & Auditorium	Roof

Manassas HS (2480) 1B	roof leaking on auditorium stage messing up wood on stage	4/7/14	Auditorium	stage area	Roof
Manassas HS (2480) 1B	bad leak in girls lockerroom	4/7/14	Gym	girls lockerroom	Roof
Manassas HS (2480) 1B	big hole in roof you can see the sky this room is being used for summer school 6/2/2014 keep flooding	5/29/14	Classroom	2027	Roof
Manassas HS (2480) 1B	There are some roof leaks in these areas that need to be taken care of before mold build up in these areas. Room 2027, Gym area lobby near restrooms. Plug the holes or sum.	2/4/14	Classroom	2027, gym lobby by restrooms	Roof
Manassas HS (2480) 1B	GUTTER OFF PARKING LOT GOING TOWARDS FOOTBALL FIELD-HAS FALLEN OFF BLDG AND WATER IS POURING DOWN RUNNING OUT INTO STREET PER SBE-PLANT MGR FIFER 416-3244 KLR	8/29/13			Sheet Metal
Manassas HS (2480) 1B	Repair downspouts.	9/3/13			Sheet Metal
Manassas HS (2480) 1B	The band room has a leak from the duct work or roof? I also have leaks in the Auditorium, Library. The roofers say they don't see leaks, but they are very present when it rains. There are two sets of craftman that can determine the leaks. The plumbers and roofers. Urgent reply. It has the band room with a awful smell	5/15/14	Classroom	Band Room 1093	Sheet Metal

Count of Craft	Craft							Grand Total
	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	
MLK Transition Ctr (8919) 1A	1	30	19	27	3	7	3	90
Grand Total	1	30	19	27	3	7	3	90

Location	Request Description	Submittal Date	Area Descript	Area Number	Craft
MLK Transition Ctr (8919) 1A	Remove 9x9 acm floor tile in room 113. Wood cabinets/sinks removed leaving 9x9 tile. Approx. 40 to 50 sq.ft. Need by 4-24-2014 if possible. Thank you	4/16/14	1st Floor		Asbestos
MLK Transition Ctr (8919) 1A	there are three small offices that to be taken down to make this space back to a classroom	4/21/14		room 102	Carpentry
MLK Transition Ctr (8919) 1A	Repair floor tile in old home ec. room # 113. Existing tile is not ACM.	4/23/14	1st Floor		Carpentry
MLK Transition Ctr (8919) 1A	door handle keep sticking	4/25/14	Gym	weight room	Carpentry
MLK Transition Ctr (8919) 1A	need two marker boards in this classroom	6/11/14	Classroom	room 113	Carpentry
MLK Transition Ctr (8919) 1A	Install window unit in SBE office.	9/4/13			Carpentry
MLK Transition Ctr (8919) 1A	In the gym the first section of bleachers the front row has come a loose from the foundation it is a health hazard.	9/26/13			Carpentry

MLK Transition Ctr (8919) 1A	MAIN FRONT WINDOW DOOR HAS BROKEN. PLANT MGR-HAWKINS/416.0086	10/3/13			Carpentry
MLK Transition Ctr (8919) 1A	Repair front main door glass.	10/7/13			Carpentry
MLK Transition Ctr (8919) 1A	Room 103 the door want lock the latch will not catch.	10/24/13			Carpentry
MLK Transition Ctr (8919) 1A	Hydraulic door closer has been broken off the entrance door of the cafeteria/auditorium. Requesting it to be fixed.	11/18/13			Carpentry
MLK Transition Ctr (8919) 1A	Hydraulic door closer has been broken in the girls bathroom. Requesting it to be fixed.	11/18/13			Carpentry
MLK Transition Ctr (8919) 1A	all entrance need weather strips at bottom of doors a total of 12 doors	12/16/13	Hallway/Corri dor	all entrance doors	Carpentry
MLK Transition Ctr (8919) 1A	door handle broken need be replaced can not be tighten	1/8/14	Classroom	room -112	Carpentry
MLK Transition Ctr (8919) 1A	closer at top of door has broken off	1/8/14	Cafeteria	entrance door	Carpentry

MLK Transition Ctr (8919) 1A	there two stall doors need to be replaced	1/14/14	Restroom (Boys)	boys restroom at southside of building	Carpentry
MLK Transition Ctr (8919) 1A	theres a broken window that need to be replaced	2/20/14	Gym	boys restroom	Carpentry
MLK Transition Ctr (8919) 1A	there are two doors that are of the hinges these are the second set of doors	2/20/14	Gym	front entrance	Carpentry
MLK Transition Ctr (8919) 1A	door is sticking you have to lift up on to close it	3/25/14	Classroom	room 105	Carpentry
MLK Transition Ctr (8919) 1A	door to restroom is sticking will not close	3/25/14	Gym	boys restroom in front	Carpentry
MLK Transition Ctr (8919) 1A	Repair rr door.	3/26/14			Carpentry
MLK Transition Ctr (8919) 1A	the kitchen back door need a peep hole	3/31/14	Cafeteria	kitchen back door	Carpentry
MLK Transition Ctr (8919) 1A	door knobs have come off can not secure classroom	4/2/14	Cafetorium	room 105	Carpentry

MLK Transition Ctr (8919) 1A	requesting that the centre island in classroom be removed	4/14/14	1st Floor	room 114	Carpentry
MLK Transition Ctr (8919) 1A	need a 4 by 8 marker board in room 113	4/16/14	Classroom	room-114	Carpentry
MLK Transition Ctr (8919) 1A	we need a 4 by 6 marker board in the front office	6/5/14	Administration Area	main office	Carpentry
MLK Transition Ctr (8919) 1A	need 4 by 8 marker board for p e class	6/11/14	Gym	gym	Carpentry
MLK Transition Ctr (8919) 1A	need door and lock installed	6/11/14	Gym	pe teachers office	Carpentry
MLK Transition Ctr (8919) 1A	classroom need 2 4 by 8 marker boards	5/19/14	Classroom	room-102	Carpentry
MLK Transition Ctr (8919) 1A	need a gate to put up at entrance to restrooms	6/11/14	Gym	boys and girls restroom	Carpentry
MLK Transition Ctr (8919) 1A	Principal C. Daniel requesting a chain gate to be put up at the doorway on the west side of the gym.	8/8/13			Carpentry

MLK Transition Ctr (8919) 1A	2-WINDOW UNITS NOT COMING ON IN RM-107(072) PLANT MANAGER OFFICE (047). SBE-HAWKINS/416-0086	7/17/13			Electrical
MLK Transition Ctr (8919) 1A	Provide elec. assist to support Frank.	4/21/14			Electrical
MLK Transition Ctr (8919) 1A	ELECTRICAL OUTLET has BURNED in the KITCHEN AREA per Linda Powell, Plant Mgr. 416.0086	5/20/14			Electrical
MLK Transition Ctr (8919) 1A	Room 102 remove/roll up Elec. wires. To Support Jason.	5/27/14	Classroom		Electrical
MLK Transition Ctr (8919) 1A	WINDOW UNIT NOT COOLING IN PRIN OFFICE(300). PLANT MGR-HAWKINS/416.0086	8/12/13			Electrical
MLK Transition Ctr (8919) 1A	WINDOW UNIT NOT COMING ON PLANT MGR(047) PLANT MGR-HAWKINS/416.0086	8/12/13			Electrical
MLK Transition Ctr (8919) 1A	A/C UNIT GYM AREA-NOT COMING ON-PLANT MGR HAWKINS 416-7430 KLR	8/21/13			Electrical
MLK Transition Ctr (8919) 1A	Program master clock.	9/20/13			Electrical

MLK Transition Ctr (8919) 1A	asst principal's office has not lights - blown ballast per Ms. Hawkins 416- 7320	10/14/13			Electrical
MLK Transition Ctr (8919) 1A	power is out in main office, breaker tripped in main box per Ms. Hawkins 416-7320	10/24/13			Electrical
MLK Transition Ctr (8919) 1A	there are 12 lights out in one row in dining area and 10 out in the auditorium area	12/16/13	Cafetorium	dining area	Electrical
MLK Transition Ctr (8919) 1A	lights will not come bulbs have been replaced	1/8/14	Gym	boiler room	Electrical
MLK Transition Ctr (8919) 1A	the cold box is not working	1/14/14	Cafeteria	serving line	Electrical
MLK Transition Ctr (8919) 1A	ballast out over secretary desk	1/28/14	Administration Area	front office	Electrical
MLK Transition Ctr (8919) 1A	(2) ROWS OF LIGHT OUT IN MAIN OFC AREA-PLANT MGR POWELL 416-7430 KLR	1/30/14			Electrical
MLK Transition Ctr (8919) 1A	change clocks for daylight savingvtime	3/11/14	Administration Area	clocks	Electrical

MLK Transition Ctr (8919) 1A	there are two electric stove that need be disconnected	4/14/14	1st Floor	room 114	Electrical
MLK Transition Ctr (8919) 1A	need electrical in floor removed were the two stove removed	4/15/14	Classroom	room -113	Electrical
MLK Transition Ctr (8919) 1A	disconnect and demo all outlet in island	4/15/14	Classroom	room- 113	Electrical
MLK Transition Ctr (8919) 1A	5-WINDOW UNITS NOT COOLING IN RM-110(067) RM-112 (111,073)RM-113 (031) AUDIT (273). SBE-HAWKINS/416-0086	7/17/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	Monthly - Filter-King Cultural Ctr - Refer to PM schedule details.	6/21/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	OTHER A/C UNIT GYM AREA-NOT COOLING-PLANT MGR HAWKINS 416-7430 KLR	8/21/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	WINDOW UNITS NOT COOLING DUE TO THAT ALL FILTERS NEED TO BE CLEAN THRU ENTIRE BLDG PLANT MGR-HAWKINS/416.0086	8/30/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	Monthly - Oil Lube & Belt-King Cultural Ctr - Refer to PM schedule details.	9/2/13			Heating/Ventilation /Air Conditioning

MLK Transition Ctr (8919) 1A	WINDOW UNIT NOT COOLING IN RM-114 PLANT MGR-HAWKINS/416.0086	9/9/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	A/C WINDOW UNIT RM 115-NOT COOLING-PLANT MGR HAWKINS 416-0086 KLR	9/10/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	a/c in gym is not cooling and there is a game in there tomorrow per Ms. Hawkins 416-7320	9/26/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	Monthly - Filter-King Cultural Ctr - Refer to PM schedule details.	10/19/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	3-BOILERS NOT COMING ON. PLANT MGR-HAWKINS/416.7320	10/28/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	BOILER is NOT HEATING per Linda Powell, Plant Mgr. 416.0086	12/9/13			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	BOILER MECH RM-HAS SHUT DOWN-PLANT MGR POWELL 416- 7320 KLR	1/6/14			Heating/Ventilation /Air Conditioning

MLK Transition Ctr (8919) 1A	BOILER CAFE AREA-NOT COMING ON-PLANT MGR POWELL 416- 7230 KLR	1/7/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	replace belt on cafe ahu	1/8/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	cafe not heating	1/9/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	clean R/A grill in cafe and remount	1/10/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	UNIT NOT HEATING IN GYM PLANT MGR-POWELL/416.0086	1/29/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	pump coupling below gym --- replace	2/4/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	ahu in gym not heating	2/4/14			Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	Monthly - Filter-King Cultural Ctr - Refer to PM schedule details.	2/22/14			Heating/Ventilation /Air Conditioning

MLK Transition Ctr (8919) 1A	BOILER is NOT COMING ON per Linda Powell, Plant Mgr. 416.0086	3/4/14				Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	boiler shutting off at 200 degrees	3/6/14				Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	C/O to A/C	3/21/14				Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	BOILER MECH RM-MAKING A LOUD NOISE-SBE DON'T KNOW WHAT TO DO-PLANT MGR POWELL 416-7320 KLR	3/25/14				Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	Monthly - Oil Lube & Belt-King Cultural Ctr - Refer to PM schedule details.	3/31/14				Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	pump leaking in basement boiler rm	4/10/14				Heating/Ventilation /Air Conditioning
MLK Transition Ctr (8919) 1A	classroom need painting	5/19/14	Classroom	room-113		Painting
MLK Transition Ctr (8919) 1A	classroom need painting	5/19/14	Classroom	room -102		Painting

MLK Transition Ctr (8919) 1A	Paint two stall doors, southside of building. Support WO # 408661 Phillip H.	1/24/14	Restroom (Boys)		Painting
MLK Transition Ctr (8919) 1A	in the gym the a/c unit is leaking bad per Ms. Hawkins 416-7320	9/3/13			Plumbing
MLK Transition Ctr (8919) 1A	Test and report on backflow prevention devices.	1/9/14			Plumbing
MLK Transition Ctr (8919) 1A	system pump leaking water	1/9/14	Cafeteria	lower boiler room	Plumbing
MLK Transition Ctr (8919) 1A	the sink near window leaking from bottom	2/20/14	Gym	boys restroom	Plumbing
MLK Transition Ctr (8919) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing
MLK Transition Ctr (8919) 1A	theres very strong sewerage smell coming from boys restroom one of the toilet loose	4/2/14	Hallway/Corridor	boys restroom	Plumbing
MLK Transition Ctr (8919) 1A	Disconnect any/all pipes from center island room 114. Support Jason and Rusty.	4/15/14	1st Floor		Plumbing

MLK Transition Ctr (8919) 1A	roof leaking in gym all over have damaged the floors	6/11/14	Gym	from main building to gym	Roof
MLK Transition Ctr (8919) 1A	there is a leak on the back wall over computers	4/16/14	Gym	computer room	Roof
MLK Transition Ctr (8919) 1A	roof leaks all through the back of building over pool table and classrooms and storage room	4/16/14	Gym	in back gym	Roof

Count of Craft	Craft								
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Northaven ES (0145) 1B	2	19	59	39	2	73	10	4	208
Grand Total	2	19	59	39	2	73	10	4	208

Location	Request Description	Submittal Dat	Area Descript	Area Number	Craft
Northaven ES (0145) 1B	The baseboard plates in the girls restroom near the main office are coming off in some areas. THIS IS CERAMIC BASE	2/26/14		girls restroom near main office.	Asbestos
Northaven ES (0145) 1B	Some of the baseboard plates are missing and needs replacing in the boys locker room located in the gymnasium. THIS IS CERAMIC BASE	2/26/14		boys locker room/gymnasium.	Asbestos
Northaven ES (0145) 1B	PANIC BAR MAIN ENTRANCE DOOR-DAMAGED, NOT LOCKING-WON'T BE ABLE TO SECURE BLDG-SBE WILLIAMS 353-8580 KLR	7/31/13		Front main entrance door /near office.	Carpentry
Northaven ES (0145) 1B	We need round reflection mirror installed in the southwest corner of the library. we have the mirror already here at school.	8/8/13		library.	Carpentry
Northaven ES (0145) 1B	HARDWARE DAMAGED ON DOOR TO GYM TEACHER'S OFC-HANDLE IS HARD TO TURN-NEED TO HAVE ACCESS-WAITING TO GET IN-PLANT MGR WILLIAMS 347-5185 KLR	8/29/13			Carpentry
Northaven ES (0145) 1B	Please replace broken floor tile located on the hallway in front of the plant managers office.	9/11/13		Hallway/in front of plantmanagers office.	Carpentry
Northaven ES (0145) 1B	There are several broken floor tiles in the cafeteria dining area, please replace.	9/11/13		Cafe. dining room.	Carpentry
Northaven ES (0145) 1B	The handle and lock on the back face of the janitorial closet door is torn up please replace it,because if the doors shuts on a person while inside,he or she will not be able to get out on their own.	10/1/13		Janitorial closet by plantmanagers office.	Carpentry

Northaven ES (0145) 1B	The inside entire door handle has came off the door in classroom *31, if teacher and students go in and the door shuts for some reason, they want be able to get out from the inside.	10/23/13		Classroom *31	Carpentry
Northaven ES (0145) 1B	The thrust plate in the door way leading off the gym floor going in the boys locker room is broken.Please replace it, i'm afraid someone will trip on it or get cut on it. unsafe.	11/6/13		Gymnasium.	Carpentry
Northaven ES (0145) 1B	There are a couple of doors on the north end of our school that has broken and bent kick plates. We would like to have those replaced.	11/7/13		double doors/north hallway.	Carpentry
Northaven ES (0145) 1B	The flat steel plate on the side of the door that surrounds lock switch is about to come off the door in classroom *1,located on the first hall wing.	12/9/13		classroom*1/on first wing.	Carpentry
Northaven ES (0145) 1B	Ceiling tile out bookroom and hallway. Caused by roof leak	12/23/13			Carpentry
Northaven ES (0145) 1B	Please replace the weather strips on the back exit doors, located on the northwest side of the cafeteria.	1/23/14		Back exit door/northwest side of cafeteria.	Carpentry
Northaven ES (0145) 1B	Please repair the wooden gate leading to the generator area located in the northwest end of the school.	1/23/14			Carpentry
Northaven ES (0145) 1B	We cannot lock or unlock the door on the computer lab due to not being able to turn the door handle.	2/7/14		ROOM*29/COMPUTER LAB.	Carpentry
Northaven ES (0145) 1B	Please replace the hooks on the flag pole outside, we are unable to fly the flag.	2/11/14		Outside/ flag pole.	Carpentry

Northaven ES (0145) 1B	We have a few broken tiles on the gym floor, perhaps five or six.	2/18/14		gymnasium.	Carpentry
Northaven ES (0145) 1B	The inside door handle on the plant managers office door has come off, making it hard to open the door from the inside.	4/16/14		plantmanagers office.	Carpentry
Northaven ES (0145) 1B	The handle has broken on the door that go's into the cafeteria from the hallway.	4/25/14			Carpentry
Northaven ES (0145) 1B	The door handle has come off the door in classroom*22/please assist ASAP,we don't want the class to get trapped inside.	5/2/14		Classroom *22	Carpentry
Northaven ES (0145) 1B	The hallway clock on the outside wall of plant managers office needs setting to correct time.	7/29/13		Hallway DN. from plantmanagers office.	Electrical
Northaven ES (0145) 1B	The clock down the hall from the plant managers office has the wrong time.	7/29/13	1st Floor	Hallway Dn. from plantmanagers office.	Electrical
Northaven ES (0145) 1B	The light switch needs to be replaced in the mop room, located in the cafeteria kitchen.	7/30/13		Mop rm./in cafe. kitchen.	Electrical
Northaven ES (0145) 1B	The lights will not work in the fixture located in the storage rm. of the cafeteria kitchen, perhaps ballast needed.	7/30/13		Storage rm. cafe. kitchen.	Electrical
Northaven ES (0145) 1B	Please run Test. Generator Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical

Northaven ES (0145) 1B	Time clock to the outside lights is not turning off.	7/16/13			Electrical
Northaven ES (0145) 1B	Urgent test and turn in by 7/29/2013. Retest Generator.	7/25/13			Electrical
Northaven ES (0145) 1B	We have a few lights out on the front porch of our school.please assist me with replacing them.	7/26/13		Front porch lights.	Electrical
Northaven ES (0145) 1B	The hallway light fixture near the double doors leaving gym and plantmanagers office going toward the main office needs a ballast.	8/7/13		Hallway lights/near double doors near plantmanager	Electrical
Northaven ES (0145) 1B	The clocks repaired located on the wall of plantmanagers office and also southward down the hall from plant manager time is still off.	8/8/13		At plantmanagers office and down south hall way of	Electrical
Northaven ES (0145) 1B	The light fixture on the kitchen porch needs a ballast.	8/8/13		Back kitchen porch.	Electrical
Northaven ES (0145) 1B	the lights are out underneath the side outside door that leads into the cafeteria hallway.	8/8/13		Side door/coming into cafeteria.	Electrical
Northaven ES (0145) 1B	Classroom *36 needs a new ballast in the light fixture in the back of the room.	9/26/13		Classroom *36	Electrical
Northaven ES (0145) 1B	A prong has broken off a cord and remains in the outlet on the east wall of the class room. The outlet is located at the bottom of the bulletin board in front of the room,this is classroom *30.	10/1/13		Classroom*30	Electrical

Northaven ES (0145) 1B	The light fixture over the toilet in the girls restroom located on wing *4 needs a ballast.	10/2/13		Girls rst.rm./hall*4	Electrical
Northaven ES (0145) 1B	Please replace the ballast in two light fixtures in classroom *31.	10/16/13		Classroom *31	Electrical
Northaven ES (0145) 1B	The conference room located across from the restrooms near the main office needs ballast replacement in the light fixture. It's so dim in there, the principal can hardly see how to do his work.	10/21/13		Conference room.	Electrical
Northaven ES (0145) 1B	The hallway clock on the wall of plantmanagers office and also the clock down the southward hall from the plantmanagers office still does not have correct time/please repair.	10/21/13		Hallway.	Electrical
Northaven ES (0145) 1B	cafeteria lights will not come on per Will Williams 353-8580	10/28/13			Electrical
Northaven ES (0145) 1B	Verify data base in burglar alarm panel.	11/1/13			Electrical
Northaven ES (0145) 1B	Clocks did not set to savings time.	11/5/13			Electrical
Northaven ES (0145) 1B	Please set the outside pole lights to come at 5:00 p.m. now that it gets dark early.	11/5/13		Outside lights.	Electrical
Northaven ES (0145) 1B	There are three pole light on the front that blown and needs replacing.here are the one's; the second pole light to the left as you enter into the drive approaching the front of the school, the pole light about mid front of the building and the pole light down from the	11/5/13		outside pole lights.	Electrical

Northaven ES (0145) 1B	The door bell on the back cafeteria door is not ringing.	12/9/13			Electrical
Northaven ES (0145) 1B	The outlet on the front wall has a prong broken off in it.	12/9/13		Classroom*1/on first wing.	Electrical
Northaven ES (0145) 1B	Please repair the wall clock located in the cafeteria, it does not have the correct time.	12/12/13		cafeteria.	Electrical
Northaven ES (0145) 1B	Please repair the hallway clock located across from or close near the mechanical room. It does not have the correct time.	12/12/13		Hallway.	Electrical
Northaven ES (0145) 1B	Please put ballast in the fifth light fixture on the front track.	12/16/13		front porge track lights.	Electrical
Northaven ES (0145) 1B	HEAT RM 35 & 46-BOTH NOT COMING ON-PLANT MGR WILLIAMS 353-8580 KLR	12/19/13			Electrical
Northaven ES (0145) 1B	The outside wall light over the cafeteria kitchen porch is out.	1/7/14		North wall of outside blding.	Electrical
Northaven ES (0145) 1B	The outside wall light on the building in the area where the outside shed is located is out.	1/7/14		North outside wall.	Electrical
Northaven ES (0145) 1B	The outside light between the 1st and 2nd wing across the back of the building is out and also the light on the wall over the steps of the 2nd wing is out.	1/7/14		West wall/across the back of blding.	Electrical

Northaven ES (0145) 1B	The lights between the 2nd and 3rd wing is out and the lights are also out between the 3rd and 4th wing.	1/7/14		Outside lights on back of building.	Electrical
Northaven ES (0145) 1B	The outside wall lights above the 4th and 5th wings outside steps are out.	1/7/14		Outside lights on back of building.	Electrical
Northaven ES (0145) 1B	Light fixture is in need of new ballast in classroom *41.	1/14/14		classroom *41	Electrical
Northaven ES (0145) 1B	The boys rstrm. located near the main office,across from the conference room does not have a working ventilation fan,which causes the floor to stay moist,putting the little boys in a dangerous situation for slipping and falling on their water.	1/17/14		boys restroom near main office.	Electrical
Northaven ES (0145) 1B	Install heater in water heater room on dock	1/30/14			Electrical
Northaven ES (0145) 1B	The outlet on the wall of the cafeteria's managers office has a prong broken off in it/the outlet located below the window of the office.	1/30/14		kitchen.	Electrical
Northaven ES (0145) 1B	PLEASE repair breaker *14 in the electric rm. at the north end of the hall/ it operates the lights in offices on each side of the stage. However; it trips back as fast as one can set it.	2/4/14		Electric room/north end of hallway.	Electrical
Northaven ES (0145) 1B	The outlet located underneath the clock in classroom *13 does not work.	2/4/14		Classroom *13	Electrical
Northaven ES (0145) 1B	The pole lights on the north end parking lot is out due to breaker *13 in the electric panel box constantly tripping.	2/18/14		North end parking lot.	Electrical

Northaven ES (0145) 1B	Please deliver the following bulbs; 1 nd. 16 of 10460 lamp,metal halide mvr 400/u base sub.- 1 nd. 30 of the 10515 mercury lamps, h38-ht 100.100w and 10 of the 10533mtl halide lamps,250 watt,mvr250u,mogul clear.	2/19/14		School.	Electrical
Northaven ES (0145) 1B	The double doors on the northwest end of the building has a broken magnet device and will not lock, the magnet will not catch.	2/28/14		Northwest exit double doors.	Electrical
Northaven ES (0145) 1B	The outside lights between the 1st and 2nd wing is out,and also the light above the steps of the 2nd wing is out.	3/21/14		outside of school./Across the back.	Electrical
Northaven ES (0145) 1B	The lights between the 2nd and 3rd wing is out. The light above the step of the 2nd wing is out.	3/21/14			Electrical
Northaven ES (0145) 1B	The outside wall light above the 4th wing is out.	3/21/14			Electrical
Northaven ES (0145) 1B	The outside light above the 5th wing is out.	3/21/14			Electrical
Northaven ES (0145) 1B	Please reset the outside lights to go off at 7:00am in the morning and come on at 7:00pm in the afternoon.	3/21/14		outside of school.	Electrical
Northaven ES (0145) 1B	On the hallway between classroom *27 and 28 the hall light is out. It needs a ballast.	3/28/14		Hallway between room *27 and 28.	Electrical
Northaven ES (0145) 1B	The light above the generator is out.	4/1/14		wall above generator.	Electrical

Northaven ES (0145) 1B	Please replace the light outside of rm. *19.	4/1/14		outside of room *19	Electrical
Northaven ES (0145) 1B	The light in the conference room needs repairing.	4/1/14		conference room.	Electrical
Northaven ES (0145) 1B	ROOMS *5, *22,*32 AND*41 has light problems.	4/1/14		Classrooms.	Electrical
Northaven ES (0145) 1B	Pole light out on the north end parking lot.	4/1/14		North end parking lot.	Electrical
Northaven ES (0145) 1B	Please replace the ballast in the light fixture on the end of the hallway in the 4th wing.	4/17/14		End of haalway/in front of lib. wing 4.	Electrical
Northaven ES (0145) 1B	The outlet on the upfront wall underneath the board is not working.	4/25/14		Classroom*43t	Electrical
Northaven ES (0145) 1B	We have two lights out in classroom *30 thats in need of ballast, please help, it is urgent that the lights are repaired prior to tuesday may,6 because on this date T-Cap will be taken in this room.	5/2/14		classroom*30	Electrical
Northaven ES (0145) 1B	The light in the cafeteria managers office blew out during a power outage and will not come back on,perhaps in need of new ballast.	5/2/14		cafeteria mngrs. office.	Electrical
Northaven ES (0145) 1B	We have three light fixtures in the kitchen in need of ballast.	5/29/14		kitchen.	Electrical

Northaven ES (0145) 1B	THE EMS PANEL NEEDS TO BE RESET	6/10/14		EMS	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	The air will not come on in classroom * 20, it's very hot in there.	8/2/13		classroom *20	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	Our computer rm. is hot, really too hot for the computers. The air is blowing but not cool, perhaps it needs fre/on and sometimes it just shuts off and will not come back on unless it's over ridden. This is room *29.	8/7/13		Room*29/computer rm.	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C IN MAIN HALL RM 29 COMPUTER RM-NOT COOLING-SBE WILLIAMS 353-8580 KLR	8/7/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	The vent in the boys rst.rm. area is constantly blowing out heat. Something is not right in that area, it is very hot all the time. I am concerned and don't want any unfortunates to happen. Please check this out and give me some feedback.	8/9/13		boys restroom next to plantmanagers office.	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C IN 1ST HALL 3RD WING RM 23-BLOWING TOO COLD-TEMP IS BETWN 69 & 70-SBE WILLIAMKS 353-8580 KLR	8/13/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HAS A COMPLETE POWER OUTAGE-PLANT MGR WILLIAMS 347-5185 KLR	8/29/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C RMS 30, 31, 32, 33, 34, & 35 ON THE 4TH HALL-ALL NOT COMING ON-PLANT MGR WILLIAMS 353-8580 KLR	9/3/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C RM 46 5TH HALL-COMES ON BUT CYCLES OFF FOR A LONG PERIOD OF TIME BEFORE IT COMES BACK ON-PLANT MGR WILLIAMS 353-8580 KLR	9/3/13			Heating/Ventilation /Air Conditioning

Northaven ES (0145) 1B	A/C RM 32-NOT COMING ON-PLANT MGR WILLIAMS 347-5185 KLR	9/25/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C 2ND WING RMS 10 - 17-ALL NOT COMING ON-PLANT MGR WILLIAMS KLR	10/21/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C RM 23-NOT COMING ON-PLANT MGR WILLIAMS KLR	10/22/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT RM 37-NOT HEATING-PLANT MGR WILLIAMS 353-8580 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT RM 35-NOT COMING ON-PLANT MGR WILLIAMS 353-8580 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	Please unlock and reset the thermostat in classroom *3, it is cold in there.	11/21/13		Classroom*3	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	2-UNITS NOT HEATING IN RM-23,24. PLANT MGR-WILLIAMS/873.8171	11/26/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT 43-NOT HEATING & RM 44-NOT HEATING AND SOMETIMES WON'T COME ON-PLANT MGR WILLIAMS 353-8580 KLR	11/26/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	room 43 unit will not come on may be problem with t'stat per Will Williams 353-8580	12/3/13			Heating/Ventilation /Air Conditioning

Northaven ES (0145) 1B	Unit in Room 35 is NOT HEATING per Mr. Williams, Plant Mgr. 353.8580	12/9/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT RM 17-NOT HEATING-PLANT MGR WILLIAMS 353-8580 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	room 35 blowing cold air per will williams 353-8580	12/11/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT HALLWAY 1 RMS 2 - 8-ALL NOT HEATING-PLANT MGR WILLIAMS 353-8580 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	per Will Williams 873-8171 rooms 2, 4, 5, 6, 13, 43, 44, 18 are cold blowing cold air	1/7/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT RM 28 SPECIAL NEEDS & RM 23-BOTH NOT HEATING-PLANT MGR WILLIAMS 353-8580 KLR	1/9/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	UNIT NOT HEATING IN RM-23,27,33,44 PLANT MGR-WILLIAMS/8738172	1/21/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	HEAT RM 33-NOT HEATING-PLANT MGR WILLIAMS 353-8580 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	UNIT NOT HEATING IN RM-2,3,4,5,6,7 PLANT MGR-WILLIAMS/873.8172	3/7/14			Heating/Ventilation /Air Conditioning

Northaven ES (0145) 1B	The magnet door in the foyer near the gym is not opening when we scan our badges across. Plantmanager/Principal.	3/21/14		magnet door/in foyer location near gymnasium.	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	RMS 1 - 8 KINDERGARTEN WING- ALL NOT COOLING-PLANT MGR WILLIAMS 353-8580 KLR	4/3/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	A/C RM 46-NOT COMING ON- PLANT MGR WILLIAMS 353-8580 KLR	4/25/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	Please repair the thermostat that's located on the southeast wall of the gym, all of the facing is off of it and fixture hangs out of the wall.	5/7/14		Gymnasium.	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	UNIT NOT COOLING IN RM-5 PLANT MGR-WILLIAMS/873.8172	5/12/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	UNIT NOT COMING ON IN SERVING LINE PLANT MGR-WILLIAMS/873.8172	5/12/14			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	Wash units	5/28/14		Gym cafe library	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	The A/C in the library is not working sufficiently.I will arrive at northaven between 12-12:30 noonish, please wait or allow me to be to there to go over with me the the operating of some of those thermostats in the building.	7/26/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	UNIT IN RM 20 & 46 IS NOT ON,. SBE WILLIAMS 353-8580	8/2/13			Heating/Ventilation /Air Conditioning

Northaven ES (0145) 1B	UNIT IN RM 41 IS NOT COMING ON. SBE WILLIAMS	7/30/13			Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	The A/C will not come on in classroom *46, it's very hot.	8/2/13		classroom *46	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	The AC is not working in classroom *41,it is hot in there.Please if possible have it repaired before students comes on monday.	7/29/13	1st Floor	classroom*41	Heating/Ventilation /Air Conditioning
Northaven ES (0145) 1B	Could we get all the restrooms in the school painted? per principals request.	6/5/14		entirety.	Painting
Northaven ES (0145) 1B	Please touch up paint on the hallways as necessary.	6/27/14		hallways/ entireties	Painting
Northaven ES (0145) 1B	The toilet in the first stall of the boys rst.rm. located north of the main office across from the conference room. Water comes out of that top ring on the back whenever it's flushed.	7/29/13			Plumbing
Northaven ES (0145) 1B	In the last stall of the girls rst.rm located across from the conference room, the toilet needs a toilet seat.	7/29/13		Girls rst.rm./across from conference room.	Plumbing
Northaven ES (0145) 1B	The clean out on the front of the building has been ran over and torn.	7/29/13		Clean out/on front ground of building.	Plumbing
Northaven ES (0145) 1B	The cold water does not work in the first sink of the woman rst.rm next to the plant managers office.	7/30/13		womans rst.rm./next to plant managers office.	Plumbing

Northaven ES (0145) 1B	The covering or siding is coming off of the water faucet on hall 4 right outside the girls rst.rm.	7/30/13		hall 4/outside girls rst.rm.	Plumbing
Northaven ES (0145) 1B	The water faucet on hallway 5 does not work, it's the first one, the lowest one in height placed on the wall.	7/30/13		hall 5.	Plumbing
Northaven ES (0145) 1B	Please show plant manager plumbing and gas shut off valves. Also show them problem areas of sewers.	7/12/13			Plumbing
Northaven ES (0145) 1B	Repair 3rd toilet seat. Girls near Rm. 40	7/19/13			Plumbing
Northaven ES (0145) 1B	Repair 4th toilet seat. Girls near Rm. 40	7/19/13			Plumbing
Northaven ES (0145) 1B	Repair 1st toilet seat. Boys near Rm. 29	7/19/13			Plumbing
Northaven ES (0145) 1B	Repair 4th toilet seat. Boys near Rm. 29	7/19/13			Plumbing
Northaven ES (0145) 1B	Repair flush valve 1st toilet. Boys near Rm. 29	7/19/13			Plumbing
Northaven ES (0145) 1B	Replace toilet seat #1 girls near rm. 29.	7/25/13			Plumbing

Northaven ES (0145) 1B	Replace toilet seat #4 girls near rm. 29.	7/25/13			Plumbing
Northaven ES (0145) 1B	Replace toilet seat # boys near rm. 29.	7/25/13			Plumbing
Northaven ES (0145) 1B	Replace toilet seat #3 girls near rm. 40.	7/25/13			Plumbing
Northaven ES (0145) 1B	Replace toilet seat #4 girls near rm. 40.	7/25/13			Plumbing
Northaven ES (0145) 1B	Replace toilet seat #1 boys near rm. 40.	7/25/13			Plumbing
Northaven ES (0145) 1B	The water faucet in the boys rst.rm. located across from the conference room is constantly draining.	8/8/13		boys rst.rm./across from conference rm.	Plumbing
Northaven ES (0145) 1B	The faucet in sink located in the teachers lounge has a constant drip.	8/13/13		Teachers lounge.	Plumbing
Northaven ES (0145) 1B	The sink in room *24/art room, the water want go down,it's backing up into the sink, it's stopped up badly.	8/22/13		Classroom *24/art.	Plumbing
Northaven ES (0145) 1B	There is an upper pipe leaking in the storage room located across the hall from room*29/computer room.	8/22/13		storage closet/across from computer lab.	Plumbing

Northaven ES (0145) 1B	The lowest urinal in the boys rst.rm. near the fish tank over flows onto the floor every time it's flushed.This is unsafe accidental factor for the children causing them to slip and fall frequently.	8/23/13		boys rst.rm./near fish tank.	Plumbing
Northaven ES (0145) 1B	The faucet in the teachers lounge is leaking.	8/26/13		Teachers lounge.	Plumbing
Northaven ES (0145) 1B	The girls rst.rm. near the main office needs a toilet seat.	9/3/13		girls rst.rm. near the office.	Plumbing
Northaven ES (0145) 1B	The second toilet in the girls rst.rm. near the office needs repairing.	9/3/13		girls rst.rm. near the office.	Plumbing
Northaven ES (0145) 1B	The first toilet in the boys rst.rm. near the office needs repairing.	9/3/13		boys rst.rm. near the office.	Plumbing
Northaven ES (0145) 1B	The water is backing up badly when the art teacher uses THE SINK IN THE ART ROOM.	9/11/13		Classroom *24/art.	Plumbing
Northaven ES (0145) 1B	2-COM SINK IS RUNNING WATER FROM FAUCET CONTINUOUSLY PLANT MGR-WILLIAMS/873.8172	9/17/13			Plumbing
Northaven ES (0145) 1B	Please repair the water drip coming from the clinic sink,located in the main office.	10/16/13		Clinic/main office.	Plumbing
Northaven ES (0145) 1B	Please repair the second toilet in the girls restroom near the main office.	11/5/13		girl restroom/near office.	Plumbing

Northaven ES (0145) 1B	please repair the leak in the fourth toilet of the girls restroom located near the main office.	11/5/13		girls rst.rm. near the office.	Plumbing
Northaven ES (0145) 1B	Please repair the toilet in the teachers work room near the main office.	11/5/13		Teachers work room.	Plumbing
Northaven ES (0145) 1B	Please repair the drain in the teachers work area kitchen sink.	11/5/13		Teachers work room.	Plumbing
Northaven ES (0145) 1B	The water does not get hot in the janitorial closet located near the plantmanagers office.	11/5/13		janitorial closet by plantmanagers office.	Plumbing
Northaven ES (0145) 1B	The third stall in the girls restroom located near the fish tank toilet is stopped up and want flush properly.	11/19/13		girls restroom./near fish tank.	Plumbing
Northaven ES (0145) 1B	The toilet in the first stall of the boys restroom near the fish tank will not flush.	12/18/13		boys restroom/near fish tank.	Plumbing
Northaven ES (0145) 1B	The sink in the main office near the clinic does not have any pressure on the hot water side.	12/18/13		main office/in clinic area.	Plumbing
Northaven ES (0145) 1B	Please repair leak in the 4th toilet of girls restroom near main office.	12/18/13		girls restroom near main office.	Plumbing
Northaven ES (0145) 1B	please repair the leak in 2nd toilet of the boys restroom near the main office.	12/18/13		boys restroom near main office.	Plumbing

Northaven ES (0145) 1B	Repair the leak in the 1st toilet of the boys restroom, located near the main office.	12/18/13		boys restroom near main office.	Plumbing
Northaven ES (0145) 1B	Please repair the toilet in the teachers work area.	12/18/13		TWA.	Plumbing
Northaven ES (0145) 1B	Please repair the leaking toilet, 1st stall/boys restroom near rm*29.	12/18/13		boys restroom near RM*29	Plumbing
Northaven ES (0145) 1B	The kitchen floor drains are stopped up.	12/20/13		Kitchen floor.	Plumbing
Northaven ES (0145) 1B	Please clean down spout drains and above ground level around the back of the building and near plant managers office etc.	1/7/14		Near plant mngrs. office and around back of buildi	Plumbing
Northaven ES (0145) 1B	Test the following RP Serial # 340051 1 1/4" 909 Watts Science Lab	1/7/14			Plumbing
Northaven ES (0145) 1B	Test the following RP Serial # 479428 3/4" 909 Watts Science Lab	1/7/14			Plumbing
Northaven ES (0145) 1B	Test the following RP Serial # 3222079 2" 975XL Wilkens Zurn Closet girls restroom South	1/7/14			Plumbing
Northaven ES (0145) 1B	Test the following RP Serial # 333079 2" 909 Watts Riser Room	1/7/14			Plumbing

Northaven ES (0145) 1B	Test the following RP Serial # 334340 2" 909 Watts Riser Room	1/7/14			Plumbing
Northaven ES (0145) 1B	Test the following RP Serial # 204075 2" 909 Watts Closet girls restroom North	1/7/14			Plumbing
Northaven ES (0145) 1B	The roof drains on the roof located in the area over classroom *27 on the front side of the building is clogged and soon to cause a in house leak if not cleared.	1/13/14		Roof drains.	Plumbing
Northaven ES (0145) 1B	Please repair leak in 2nd toilet in the girls restroom near *18.	1/14/14		Girls restroom near *18	Plumbing
Northaven ES (0145) 1B	Please repair 3rd toilet in the girls restroom near *18.	1/14/14		girls restroom near *18	Plumbing
Northaven ES (0145) 1B	Please repair the sink faucet in the break room.	1/14/14		Break room.	Plumbing
Northaven ES (0145) 1B	The toilet in classroom *28/functional skill room rocks when the children set on it, also the seat needs replacing on it.	1/15/14		Classroom *28	Plumbing
Northaven ES (0145) 1B	SEWAGE IS BACKING UP IN B/RR ACROSS FROM COMPUTER LAB PLANT MGR-WILLIAMS/873.8170	1/29/14			Plumbing
Northaven ES (0145) 1B	Repair water leak in water heater room on the dock	1/30/14			Plumbing

Northaven ES (0145) 1B	A water main has burst in the utility room located on the back dock, back of the cafeteria.	1/30/14		Utility room /off back dock.	Plumbing
Northaven ES (0145) 1B	Install temp heater in water heater room with no heat.	1/30/14			Plumbing
Northaven ES (0145) 1B	The sink is stopped up in the utility closet on the girls side in the rstrm located near the main office.	2/3/14		Utility closet/rstrm. near the main office.	Plumbing
Northaven ES (0145) 1B	The toilet seat needs replacing in the last stall of the boys restroom located near the fish tank.	2/14/14		BOYS RST.RM/NEAR FISH TANK.	Plumbing
Northaven ES (0145) 1B	The water fountain in the gym is leaking water from the lower right corner, the corner nearest the boys locker room entrance.	2/18/14		gymnasium.	Plumbing
Northaven ES (0145) 1B	Please repair the grease trap located near the northaven school sign, east side of the cafeteria, it is broken and has sharp edges. safety problem.	3/18/14		near the northaven school sign.	Plumbing
Northaven ES (0145) 1B	Sink in kitchen custodial closet is leaking, cafeteria mngr. says she notice water on the floor in this area every morning.	3/20/14		Kitchen./custodial closet.	Plumbing
Northaven ES (0145) 1B	The small urinal in the boys restroom located near the main office, across from the conference room, this urinal holds water, the water go's down really, really slow and sometimes overflows.	3/31/14		boys restroom near main office.	Plumbing
Northaven ES (0145) 1B	The kitchen floor drain is stopped up, water puddles on the floor/dangerous work situation for employees.	4/7/14		Kitchen floor. /floor drain.	Plumbing

Northaven ES (0145) 1B	Please repair the kitchen sink leak.	4/9/14		Sink in kitchen.	Plumbing
Northaven ES (0145) 1B	The first toilet in the boys restroom near the fish tank is over flowing and will not go down when flushed.	4/11/14		boys restroom near fish tank.	Plumbing
Northaven ES (0145) 1B	The pressing device that makes the water come out of the faucet has came off the water fountain located in the gym.	4/16/14		gymnasium.	Plumbing
Northaven ES (0145) 1B	The sink is stopped up and backs up in the janitorial closet located across from the conference room near the main office.	4/22/14		sink/janitorial closet.	Plumbing
Northaven ES (0145) 1B	The sink in the utility closet located in the kitchen at northaven is stopped up and draining slowly, also the floor drains in the kitchen is backing up in the floor again.	4/30/14		Kitchen floor. /floor drain.	Plumbing
Northaven ES (0145) 1B	On the hallway across from the library, the water fountain is constantly running.	5/14/14		hall or wing*3	Plumbing
Northaven ES (0145) 1B	It leaks very bad in the plantmanagers office whenever it rains.	8/12/13		Plantmanagers office.	Roof
Northaven ES (0145) 1B	We have a bad ceiling leak in our text book room.We are mopping every time it rains.	8/12/13			Roof
Northaven ES (0145) 1B	Whenever it rains, the following locations are trenched, plantmanagers office, text book room,gymnasium and classroom *46. It's concerning due to health issues thats caused by dampness and perhaps mold. Your assistance in this matter will be greatly	10/1/13		Plantmanagers office/gymnasium/text book room and	Roof

Northaven ES (0145) 1B	There is a water leak in the girls restroom located near the plantmanagers office,the ceiling is peeling.	11/5/13		Girls restroom near the plantmanagers office.	Roof
Northaven ES (0145) 1B	The last time it rained, it rained in the gym, in same area as before.	11/25/13		gymnasium.	Roof
Northaven ES (0145) 1B	The ceiling is still leaking in the plantmanagers office when it rains.	11/25/13		Plantmanagers office.	Roof
Northaven ES (0145) 1B	The leak has not stopped completely in the book room when it rains.I will say that it has slowed down.	11/25/13		Book room.	Roof
Northaven ES (0145) 1B	Roof leak @ bookroom an adjacent hallway.	12/23/13			Roof
Northaven ES (0145) 1B	Classroom *20 has a water leak from the ceiling due to water coming from the roof.	3/24/14		Classroom *20	Roof
Northaven ES (0145) 1B	The following locations are yet leaking when it rains:plantmanagers office, text book room and the gymnasium. The girls restroom located near the plantmanagers office has a ceiling leak also.	5/7/14		book room/plant mngrs. office /gym.	Roof
Northaven ES (0145) 1B	The boys rstrm. on the north side of the main office has rusted out stall dividers ,metal hanging on the floor,this is a safety hazard for the children.	7/26/13			Sheet Metal
Northaven ES (0145) 1B	Please repair the fence on our playground for the smaller kids,it's like disconnected in places,this is the black fence that closes in the smaller kids play equipment.	10/16/13		Playground./Small kids.	Sheet Metal

Northaven ES (0145) 1B	The gym bleachers will not go back in , perhaps they need oiling. Please help with this concern ASAP. Per teachers request.	10/30/13		gymnasium.	Sheet Metal
Northaven ES (0145) 1B	I don't know who's responsibility it is to rectify this concern.However; the fence has fallen on the transformer that's located in the area where our school speed light is and also the crossing guard stands in this location.	4/25/14		outside.	Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Northside HS (2535) 1B	3	3	25	49	53	4	57	4	1	199
Grand Total	3	3	25	49	53	4	57	4	1	199

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Northside HS (2535) 1B	Insulate line on cooling tower	4/2/14			Asbestos
Northside HS (2535) 1B	Insulate pipes on 1st in 3rd floor see Daniel Hurdle	9/30/13			Asbestos
Northside HS (2535) 1B	insulate pipe band room rear closet	6/19/14			Asbestos
Northside HS (2535) 1B	We need a computer drop for the office area for a printer to hooked up.	9/4/13	Administration Area	Main -Office	Cabling
Northside HS (2535) 1B	Northside Sr. WO380781- We also need a computer drop for this area for guidance to have access to their on processing of information. (SCS Network Cabling and Electronics dept. "Please See	9/4/13	Administration Area	Student Services	Cabling
Northside HS (2535) 1B	We need computer drops in this area for principal setting, when meeting with staff.	9/4/13	Administration Area	Principal Conference Rm	Cabling
Northside HS (2535) 1B	Need to get all white marker boards relocated to the second floor	6/10/14	3rd Floor	All rooms	Carpentry

Northside HS (2535) 1B	Wall has been damaged by paper towel dispenser, from constantly remounting. Need repairing. Thanks	2/13/14	Administration Area	Teacher Lounge Women Restroom	Carpentry
Northside HS (2535) 1B	We have a window that has been broken out and need repairing. Thanks, thats girls restroom.	2/21/14	Gym	Girls restroom	Carpentry
Northside HS (2535) 1B	REPAIR FENCE ON PROPERTY LINE. LOCATED BETWEEN SCHOOL AND LIBRARY.	3/21/14			Carpentry
Northside HS (2535) 1B	We have some windows that has been damaged due to vandalism, to school front view entry glass of bldg. Need atech to fix problem, thanks.	3/24/14	Administration Area	Main Entry Of Bldg	Carpentry
Northside HS (2535) 1B	VIEW WINDOW HAS SCATTER IN FRONT OF BLDG PLANT MGR- FOSSETT/416.4582	3/24/14			Carpentry
Northside HS (2535) 1B	Mull is missing a piece in door and not closing.	9/10/13	1st Floor	Rotc Rm 112	Carpentry
Northside HS (2535) 1B	Fence was torn down by drunk driver and need to be fixed, to keep public from getting onto parking lot were cars are help keep down vandalism.	9/3/13	Grounds	Parking lot	Carpentry
Northside HS (2535) 1B	We need cieling tiles replaced in the library, corrugated compacted kind. Thanks	1/30/14	Library	Library Rm.220	Carpentry

Northside HS (2535) 1B	door is not closing alarm will not set.	2/6/14	Mechanical Room	generator room	Carpentry
Northside HS (2535) 1B	We have a bulletin board that's decaying and need to come down and replaced with another, per principal request.	4/3/14	Administration Area	Principal Office- 200	Carpentry
Northside HS (2535) 1B	Door has been damaged due to vandalism, need repairing (asap) sharp edges are relevant. Thanks	5/6/14	Gym	Gym Main Entry	Carpentry
Northside HS (2535) 1B	Need white board installed.	9/11/13	Classroom	Rotc -basement	Carpentry
Northside HS (2535) 1B	We need a white board installed in place of the black board that there now.	9/11/13	Classroom	Rm 220	Carpentry
Northside HS (2535) 1B	Ceiling tile replacement.	9/13/13	Hallway/Corridor	Hallways 3rd Floor	Carpentry
Northside HS (2535) 1B	Replace ceiling tile RM 226	10/3/13			Carpentry
Northside HS (2535) 1B	We have a crack in the wall, need repairing. Thanks	10/25/13	Kitchen	kitchen- Prep Area	Carpentry

Northside HS (2535) 1B	need 4 whiteboards installed in classroom 218 to replace black chalk boards (safety hazard)	11/14/13	Classroom	218	Carpentry
Northside HS (2535) 1B	need (4) chalk boards in classroom replaced with whiteboards	11/14/13	Classroom	218	Carpentry
Northside HS (2535) 1B	hydraulic door closer needs replacing.(arm broken)	11/14/13	Hallway/Corridor	Basement	Carpentry
Northside HS (2535) 1B	door closer on exit door outside of band room in basement needs replacing(arm broken)(editted ticket for #397770)	11/14/13	Hallway/Corridor	BASEMENT	Carpentry
Northside HS (2535) 1B	Were experiencing mold in this room due to, wet climate like conditions. Need a tech to come out to fix this problem. Thanks, bldg Maintenance.	7/26/13	Classroom	3rd Floor Rm 220	Carpentry
Northside HS (2535) 1B	Flag pole line need changing out plastic line covering is peeling and causing line to be caught in pulley when letting flag up and down. Also flag is caught up on line now. Need a tech.	8/12/13	Grounds	outside flag pole	Carpentry
Northside HS (2535) 1B	We had amajor flood. From 3rd floor to the basement, it damaged a lot of tiles were requesting for some cieling tiles. To replace those damaged tiles. Thanks Bldg Maintenance.	8/16/13	Hallway/Corridor	Hallways/Corridors	Carpentry
Northside HS (2535) 1B	interior and outer doors of girls locker room in gym need hinges reattached and tighten.	12/2/13	Gym	girls locker room	Carpentry

Northside HS (2535) 1B	Disconnect electrical on air handler in band room	2/10/14			Electrical
Northside HS (2535) 1B	We have outlet problems no power on the southwall by exit doors. Need tech, thanks	2/24/14	Cafeteria	Dining Rm.	Electrical
Northside HS (2535) 1B	Central clock will need setting for daylight saving time. Thanks	2/26/14	Administration Area	Main- Office Clock	Electrical
Northside HS (2535) 1B	Outlets are not working, need a tech thanks.	3/17/14	Classroom	2nd Floor Rm 222	Electrical
Northside HS (2535) 1B	Remove in replace heat trace	3/20/14			Electrical
Northside HS (2535) 1B	POSSIBLY FCU IN LIB OFC- HAS A BURNING SMELL-SBE NOT SURE-PLANT MGR FOSSETT 416-4582 KLR	3/24/14			Electrical
Northside HS (2535) 1B	We have some ballast out in this room. Need more lighting, Thanks.	1/23/14	Classroom	2nd Floor Rm 215	Electrical
Northside HS (2535) 1B	Repair lights in rear of auditorium	1/27/14			Electrical

Northside HS (2535) 1B	Connect wiring for waterheater	2/4/14			Electrical
Northside HS (2535) 1B	Repair lights in auditorium. Lighting level is too low.	4/8/14			Electrical
Northside HS (2535) 1B	Emergency lights need batteries in this area, bldg entirety. Thanks	4/10/14	Clinic	Annex- Clinic	Electrical
Northside HS (2535) 1B	Locate wiring for outside lighting	4/15/14			Electrical
Northside HS (2535) 1B	Clocks need resetting bldg entirety. Thanks	4/15/14	Hallway/Corridor	Hallways/Corridor	Electrical
Northside HS (2535) 1B	BELLS NOT RINGING AT ALL- AFFECTS THE CHANGING OF CLASSES PER ASST PRIN-CALLED BY ASST PRIN P MOSBY 416-4582 KLR	4/15/14			Electrical
Northside HS (2535) 1B	Repair aud. lights	4/22/14			Electrical
Northside HS (2535) 1B	We have a couple of receptacles thats not working and need repairing.	4/24/14	Library	Main- Floor Library	Electrical

Northside HS (2535) 1B	Need 15 60 watt bulbs	5/8/14			Electrical
Northside HS (2535) 1B	per fossett 416-4582 gym a/c not coming on at all	5/8/14			Electrical
Northside HS (2535) 1B	Check main office A/C	5/12/14			Electrical
Northside HS (2535) 1B	room 207 a/c not coming on per Mr. Fossett 416-4582	9/11/13			Electrical
Northside HS (2535) 1B	Fire Alarm Pull Station needs repairing on 1st floor near Clinic per Mr. Fossett, Plant Mgr. 416.4582	9/26/13			Electrical
Northside HS (2535) 1B	Were having problems with some outlets on this hall, in the classrooms 205, 207, 209	10/21/13	Classroom	10th Grade Hall	Electrical
Northside HS (2535) 1B	2 ballast need replacing in 2 of the front lobby light fixtures	10/24/13	Hallway/Corridor	front lobbyentrance way	Electrical
Northside HS (2535) 1B	Pull station need repairing will not reset properly when used. Thanks	10/25/13	Hallway/Corridor	Hallway Area/ East of Cafe	Electrical

Northside HS (2535) 1B	4 lights in ROTC classroom need ballast replaced	10/29/13	Classroom	ROTC	Electrical
Northside HS (2535) 1B	need 2 boxes (50) lamps(#46807)for classrooms on the second floor hall of building. Email has been sent to Ken White as well.	10/29/13	2nd Floor	classrooms	Electrical
Northside HS (2535) 1B	bad smoke detector in mechanical room and alarm going off per Mr. Fossett 416-4582	11/7/13			Electrical
Northside HS (2535) 1B	Clocks and bells need resetting for passing of classes. Thanks	11/14/13	Administration Area	Main - Office	Electrical
Northside HS (2535) 1B	Bells are ten behind the actual time need resetting principal request.	11/18/13	Administration Area	Main Office	Electrical
Northside HS (2535) 1B	cond. pump not coming on	7/9/13			Electrical
Northside HS (2535) 1B	We have a unit thats contiuiuing to run and put out heat. need tech to fix problem. Thanks Bldg Maintenance.	8/1/13	Administration Area	Assitant Principal office Rm 212	Electrical
Northside HS (2535) 1B	Were requesting light bulbs for hall lighting and auditorium lighting. Also we need light bulbs from 60 watts to 100, and 150 watt. We need slim flourescent light bulbs. Thanks Bldg Maintenance.	8/5/13			Electrical

Northside HS (2535) 1B	UNIT IN RM 234 IS NOT COMING. SBE FOSSETT 416-4582	8/5/13			Electrical
Northside HS (2535) 1B	We have a burned out receptacle that need repairing. Thanks Bldg Maintenance.	8/7/13	Classroom	Freshman - Hall Rm208	Electrical
Northside HS (2535) 1B	Clocks need setting in hallways for changing of classes. Thanks Bldg Maintenance.	8/9/13	Administration Area	Clocks In hallways	Electrical
Northside HS (2535) 1B	Bells need to be reset for sounding and passing of classes. Thanks Bldg Maintenance.	8/9/13	Administration Area	Admin Bldg 200	Electrical
Northside HS (2535) 1B	We have a receptacle thats out. Thanks Bldg Maintenance	8/14/13	Classroom	2nd Floor Rm. 208	Electrical
Northside HS (2535) 1B	We need lights around the bldg for safety reasons. Thanks Bldg Maintenance.	8/19/13	Grounds	Perimeter- Lighting	Electrical
Northside HS (2535) 1B	ballast need replacing in hallway outside of rifle range in back hallway	12/2/13	Hallway/Corridor	basement	Electrical
Northside HS (2535) 1B	In the assitant principal office the power is off, also there are other rooms without power. Need a tech to take care of the problem. Thanks	12/11/13	Administration Area	Administrative Area	Electrical

Northside HS (2535) 1B	We've requested for lights to be repaired and haven't any responses been made so therefore were requesting again that these ballast be repaired so that the lighting in this area can have a unified look. Thanks plant manager	12/18/13	Hallway/Corridor	Main- Entrance	Electrical
Northside HS (2535) 1B	Were requesting that the lighting in this area be highlighted so the visibility be better for the players and public to view/play game better.	12/18/13	Gym	Gymnasium - Lighting	Electrical
Northside HS (2535) 1B	FIRE ALARM SYSTEM SHOWING TROUBLE - PM/FOSSETT 416-4582	1/15/14			Electrical
Northside HS (2535) 1B	Were having a program on the 3rd of february with the community and the (Superintendent) will be here to speak to the public.	1/21/14	Auditorium	Auditorium Lighting	Electrical
Northside HS (2535) 1B	We need lights in this area too high to reach with a 8or 10 foot ladder. Thanks plant manger.	1/21/14	Library	Library Lighting	Electrical
Northside HS (2535) 1B	We had a power outage and it off set the main clock. Thanks	6/30/14	Administration Area	Main Office Rm 200a	Electrical
Northside HS (2535) 1B	FIRE ALARM IS IN ALARM . PLANT MGR- FOSSETT/416.4572	1/21/14			Electrical
Northside HS (2535) 1B	We need lights a lot of bulbs blown.	11/20/13	Gym	Lighting-Need Lights	Electrical

Northside HS (2535) 1B	Score board is not functioning properly.	9/10/13	Gym	Gymnasuim	Electrical
Northside HS (2535) 1B	Monthly - NORTHSIDE HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	6/22/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	UNIT is NOT HEATING in the MAIN OFFICE AND PRINCIPAL'S OFFICE per Mr. Fossett, Plant Mgr. 416.4582.	2/10/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Check air room 226	2/19/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	change filter in room 226	2/20/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Monthly - Oil Lube & Belt- Northside High - Refer to PM schedule details.	2/22/14			Heating/Ventilation /Air Conditioning

Northside HS (2535) 1B	Monthly - Filter-Northside High - Refer to PM schedule details.	2/24/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Monthly - NORTHSIDE HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Yearly - Water-Cool Chiller Filter-Northside High - Refer to PM schedule details.	3/4/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Check boiler	3/7/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	C/O to A/C ---- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Yearly - Cooling Towers(STRAINERS)- Northside High - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning

Northside HS (2535) 1B	Yearly - Rod Chiller - Northside High - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	clean cooling tower	3/27/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	FCU NOT COMING ON IN RM-226. PLANT MGR- FOSSETT/416.4572	9/5/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Room 217 is not cooling per Fossett 416-4582	8/26/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	boilers down	1/27/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	HEAT GYM AREA-NOT HEATING-PLANT MGR FOSSETT 416-4582 KLR	1/28/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	boiler down	1/30/14			Heating/Ventilation /Air Conditioning

Northside HS (2535) 1B	boilers down	1/31/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	2/2/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Monthly - NORTHSIDE HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	4/27/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Monthly - NORTHSIDE HIGH LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	check filters on gym units	5/13/14			Heating/Ventilation /Air Conditioning

Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	5/25/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	rm 207 actuator -- not cooling	9/13/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Yearly - Oil Samples-Northside High - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	chiller down	9/26/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Monthly - Filter-Northside High - Refer to PM schedule details.	10/21/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Cafeteria is cold tech is needed. Thanks, that even with the boiler running.	11/5/13	Cafeteria	Dining Rm.	Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	CHILLERS ARE NOT COMING ON,. SBE FOSSETT 416-9822	7/9/13			Heating/Ventilation /Air Conditioning

Northside HS (2535) 1B	Monthly - Oil Lube & Belt- Northside High - Refer to PM schedule details.	7/27/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	A/C Units NOT COOLING in ROOMS 206, 208, 215, 216, 217, 218, 219, 220, and 224 per Mr. Fossett, Plant Mgr.	8/1/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	UNIT IN RM 204 IS NOT COOLING. . SBE FOSSETT 416-4582	8/5/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	UNIT NOT COOLING IN BASEMENT(211). PLANT MGR- FOSSETT/416.4582	8/5/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	FCU BASEMENT RIFLE RANGE-NOT COOLING-SBE FOSSETT 416-4582 KLR	8/9/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	FCU NOT COOLING IN GYM PLANT MGR- FOSSETT/416.4572	8/12/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Rm 301 and 313 not cooling	8/15/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	BOILER NOT HEATING IN GYM (HAVING A GAME TONIGHT) PLANT MGR- FOSSETT/416.4582	12/10/13			Heating/Ventilation /Air Conditioning

Northside HS (2535) 1B	FCU NOT HEATING IN CLINIC AREA PLANT MGR- FOSSETT/463.5448	12/11/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	the basement and the ROTC room both are blowing cold per Mr. Fossett 416-4582	12/16/13			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Unit in Gym is NOT COMING ON per Mr. Fossett, Plant Mgr. 416.4582	1/6/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Monthly - Filter-Northside High - Refer to PM schedule details.	6/23/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Daily - Northside High Level 1 Water Treatment - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Northside HS (2535) 1B	Frayser Success Academy wants to create a safe and pleasant environment for our students, faculty, staff, parents, community stakeholders, and visitors. In doing so, we would like to assure that our building	8/23/13	1st Floor	Innovative Academy	Painting
Northside HS (2535) 1B	Cafeteria need painting due to paint has been damaged, thanks.	4/1/14	Cafeteria	Dining Rm. Cafeteria	Painting

Northside HS (2535) 1B	Repair plaster in room 226	11/25/13			Painting
Northside HS (2535) 1B	Paint room 226	11/25/13			Painting
Northside HS (2535) 1B	Band room --- busted coil	2/13/14			Plumbing
Northside HS (2535) 1B	per mr fossett 416-4582 gas smell in room 224	2/13/14			Plumbing
Northside HS (2535) 1B	We have a faucet thats leaking. And its running onto boiler room area, need a tech. Thanks	2/27/14	Machine Shop	boiler Rm Restroom.	Plumbing
Northside HS (2535) 1B	Mop sink has a leak on it.	2/28/14	Machine Shop	boiler room mop sink	Plumbing
Northside HS (2535) 1B	Water fountain has a leak on it.	2/28/14	Hallway/Corridor	Basement 111	Plumbing
Northside HS (2535) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	3/11/14			Plumbing

Northside HS (2535) 1B	We have a toilet in this office that will not flush.	3/17/14	Administration Area	2nd Floor-Attendance	Plumbing
Northside HS (2535) 1B	We have a toilet that will not flush in this area also.	3/17/14	Clinic	Clinic - Adjacent Bldg	Plumbing
Northside HS (2535) 1B	COMMODE G RR 2ND FLR EAST-CONSTANTLY OVERFLOWING, CAN'T CUT OFF OR CONTAIN-PLANT MGR FOSSETT 416-4582 KLR	3/25/14			Plumbing
Northside HS (2535) 1B	PIPE IS LEAKING WATER IN B/LOCKER RM GYM. PLANT MGR-FOSSETT/416.4582	3/28/14			Plumbing
Northside HS (2535) 1B	Check chemical feed system for cooling tower. The #1 tower blowdown is plugged or the solenoid valve is stopped up.	8/29/13			Plumbing
Northside HS (2535) 1B	Flush valve leaking when flush, water all over floor.	9/3/13	Restroom (Girls)	3rd floor Girls Restroom	Plumbing
Northside HS (2535) 1B	Test and report on backflow prevention devices.	1/21/14			Plumbing
Northside HS (2535) 1B	Toilet stop up. Need tech a.s.a.p	1/22/14	Gym	Girls Lockerroom	Plumbing

Northside HS (2535) 1B	PUMP IS STOPPED UP & WATER IS LEAKING IN BOILER RM PLANT MGR- FOSSETT/416.4582	1/28/14			Plumbing
Northside HS (2535) 1B	HOT WATER TANK FOR KITCHEN AREA-NOT HEATING-NO HOT WATER TO KITCHEN-PLANT MGR FOSSETT 416-4572 KLR	1/31/14			Plumbing
Northside HS (2535) 1B	Sink stop up very bad.	2/6/14	Kitchen	Mop Closet Kitchen	Plumbing
Northside HS (2535) 1B	REPLACE BLOW DOWN SOLENOID. WATER TREATMENT SYSTEM. SEE MIKE SIMMONS FOR LOCATION.	4/16/14			Plumbing
Northside HS (2535) 1B	SENSOR LOOP PLUGGED ON DISCHARGE SIDE. SEE MIKE SIMMONS FOR LOCATION.	4/16/14			Plumbing
Northside HS (2535) 1B	Check storm drain	5/14/14			Plumbing
Northside HS (2535) 1B	Reinstall A/C air handier band room	5/28/14			Plumbing
Northside HS (2535) 1B	Drain is backing up with dirty water.	9/10/13	Cafeteria	Cafeteria Entrance	Plumbing

Northside HS (2535) 1B	Rooms 217, 216 a/c not cooling per Mr. Fossett 416-4582	9/11/13			Plumbing
Northside HS (2535) 1B	A/C RM 302-LEAKING-PLANT MGR FOSSETT 416-4582 KLR	9/11/13			Plumbing
Northside HS (2535) 1B	Unit Ventilator room 305 a/c leaking per Mr. Fossett 416-4582	9/24/13			Plumbing
Northside HS (2535) 1B	A/C RM 320-LEAKING-PLANT MGR FOSSETT 416-4582 KLR	9/25/13			Plumbing
Northside HS (2535) 1B	We have a couple of sinks thats stop up. Need unclogging.	9/30/13	Classroom	Cosmotology-Rm.205	Plumbing
Northside HS (2535) 1B	We have a leaking faucet. Thanks	10/25/13	Kitchen	kitchen- prep sink	Plumbing
Northside HS (2535) 1B	Custodial closet on the west hall of the 2nd floor mop sink needs cleaning (very slow drain)	10/29/13	Custodial Closet	227	Plumbing
Northside HS (2535) 1B	We have a sink that has a leak on it and need repairing. Thanks	11/1/13	Mechanical Room	Bioler Rm. Restroom	Plumbing

Northside HS (2535) 1B	WATER LINE IS LEAKING WATER IN MECH RM 1ST FLR. PLANT MGR- FOSSETT/416.4572	11/13/13			Plumbing
Northside HS (2535) 1B	Unit Ventilator as you at the front entrance LEAKING WATER per Mr. Fossett, Plant Mgr. at 901.416.9522.	7/17/13			Plumbing
Northside HS (2535) 1B	Water is escaping from floor when waste water is pour into drain, also when running water is poured into drain. Hazardous condition. Need tech, thanks bldg maintenance.	7/25/13	Custodial Closet	3rd Floor Custodial Closet	Plumbing
Northside HS (2535) 1B	FCU 3RD FLR ELECT SHOP RM 314-LEAKING-SBE FOSSETT 416-4582 KLR	8/8/13			Plumbing
Northside HS (2535) 1B	B09 ROTC office a/c not cooling per Mr. Fosset 416- 4582	8/12/13			Plumbing
Northside HS (2535) 1B	ROTC office B09 a/c not cooling per Mr. Fossett 416- 4582	8/12/13			Plumbing
Northside HS (2535) 1B	ROTC office B09 a/c not cooling per Mr. Fossett 416- 4582	8/12/13			Plumbing
Northside HS (2535) 1B	6-FCU NOT COOLING IN RM- 301(132) RM-305(134) RM- 311(137) RM-313(139) RM- 318(113) RM-321(144). PLANT MGR- FOSSETT/416.4582	8/15/13			Plumbing

Northside HS (2535) 1B	FCU 144-144 - 3RD FLR RM 319 - LEAKING FLOODED FLR - PM/FOSSETT 416-4582	8/16/13			Plumbing
Northside HS (2535) 1B	TOILET IS OVERFLOWING G/RR ACROSS FROM GYM. PLANT MGR-FOSSETT/416.4572	8/16/13			Plumbing
Northside HS (2535) 1B	pipe leaking above ceiling onto floor in main office outside financial secretary office door	11/20/13	Administration Area	main office	Plumbing
Northside HS (2535) 1B	We have a leak in this restroom on a basin thats leaking from supply line when the water is turn on. Thanks	11/21/13	Restroom (Boys)	1st Floor Cafeteria Hall Entrance	Plumbing
Northside HS (2535) 1B	MECH PIPE LINE IS LEAKING WATER IN MAIN OFFICE PLANT MGR-FOSSETT/416-4572	11/21/13			Plumbing
Northside HS (2535) 1B	Remove sink cap connection	11/25/13			Plumbing
Northside HS (2535) 1B	3rd floor girls restroom toilet leaking around flush valve per Mr. Fossett 416-4582	12/4/13			Plumbing
Northside HS (2535) 1B	We have a toilet that will not stop running. Need a tech, thanks.	12/13/13	Restroom (Boys)	2nd Floor B-RR	Plumbing

Northside HS (2535) 1B	Test and report on backflow prevention devices.	12/19/13				Plumbing
Northside HS (2535) 1B	PIPE MECH RM-HAS BURST-WATER EVERYWHERE-PLANT MGR FOSSETT 416-4582 KLR	1/8/14				Plumbing
Northside HS (2535) 1B	Sink stopped up in custodial closet	6/11/14	2nd Floor		Rm. 243 custodial closet	Plumbing
Northside HS (2535) 1B	Urinal constantly runs	6/13/14	2nd Floor		across from rm 215	Plumbing
Northside HS (2535) 1B	urinal running in 3rd floor boys restroom	6/13/14	3rd Floor		across from rm 215	Plumbing
Northside HS (2535) 1B	toilet stopped up in 3rd floor boys restroom	6/13/14	3rd Floor		across from rm 215	Plumbing
Northside HS (2535) 1B	sink leaking in 3rd floor girls restroom	6/13/14	3rd Floor		across from rm 215	Plumbing
Northside HS (2535) 1B	2nd urinal in boys restroom not shutting off	6/13/14	2nd Floor		across from rm 215	Plumbing

Northside HS (2535) 1B	toilet leaking in teachers restroom beside ROTC room	6/13/14	1st Floor	across from rm 215	Plumbing
Northside HS (2535) 1B	Wire a/c unit band room	6/16/14			Plumbing
Northside HS (2535) 1B	Sink handles are damaged, no water flow.	6/17/14	1st Floor	across from rm 230	Plumbing
Northside HS (2535) 1B	We have a leak in this room due to the rain need a tech. Thanks	4/22/14	Administration Area	Multi- purpose	Roof
Northside HS (2535) 1B	Needed roof top drains checked, thanks.	5/5/14	Gym	Roof Top Drains	Roof
Northside HS (2535) 1B	We have a very bad leak into the hallway area between klondike and perea. Need tech asap.	9/20/13	Hallway/Corridor	1st floor	Roof
Northside HS (2535) 1B	Roof leaking	6/10/14	Gym	Roof	Roof
Northside HS (2535) 1B	Remount locker	1/15/14			Sheet Metal

Count of Craft	Craft									
	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Northwest Prep Academy (2824) 1A	6	4	57	78	103	16	48	2	1	315
Grand Total	6	4	57	78	103	16	48	2	1	315

Location	Request Description	Submittal Date	Area Descript	Area Number	Craft
Northwest Prep Academy (2824) 1A	In room 304, and 306 remove and replace tile on 3rd floor. thank you	2/27/14			Asbestos
Northwest Prep Academy (2824) 1A	Replace and remove tile on the hallway going toward the caf. thank you	2/27/14			Asbestos
Northwest Prep Academy (2824) 1A	Replace missing and danger asbestos tile on the 1st floor and 2nd floor and 3rd floor as well. thank you	2/3/14			Asbestos
Northwest Prep Academy (2824) 1A	In Mrs. Hill room 206 the tilte need to be replace in her office area under her deck. thank you That located in the main part of the building	2/7/14			Asbestos
Northwest Prep Academy (2824) 1A	Insulate pipe in mens RR near room 300.	10/2/13			Asbestos
Northwest Prep Academy (2824) 1A	Insulate overhead pipe in main office. F.Owens has applied some insulation.	10/17/13	Administration Area		Asbestos
Northwest Prep Academy (2824) 1A	In room 202 on the 2nd floor of northwest prep part of the building in the computar room I need five jacks install in this room. thank you (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	12/16/13			Cabling

Northwest Prep Academy (2824) 1A	In room 204 on the 2nd floor of the main building this room need ten jacks install in this area for computar.thank you (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	12/17/13			Cabling
Northwest Prep Academy (2824) 1A	new drop[and outlet for sign in computer (Request Network Cabling Project Management).	7/9/13	Administration Area		Cabling
Northwest Prep Academy (2824) 1A	I have a T.V. that is mount on the wall that need to be take down away from the wall itself, thank you.	7/22/13			Cabling
Northwest Prep Academy (2824) 1A	I need blind for room 208 by Mr. brooker. thank you "must have something for brackets "	6/23/14			Carpentry
Northwest Prep Academy (2824) 1A	Glass broken out of classroom door in Room 202 per Mr. Lucious Stout, Plant Mgr. 416.4400	10/25/13			Carpentry
Northwest Prep Academy (2824) 1A	The ceiling in the caf. need to be drop, because it is a hazard for the student that is eating in the caf. as well as the food being on the line that they are serving to the student the material from the ceiling is falling in it. thank you	2/13/14			Carpentry
Northwest Prep Academy (2824) 1A	GYM DOOR CANT SECURE PLANT MGR-STOUT/416.4400	6/12/14			Carpentry
Northwest Prep Academy (2824) 1A	In the R.O.T.C. building the door toward the street willnot close properly it will hange up sometime.	7/22/13			Carpentry

Northwest Prep Academy (2824) 1A	I need a screen install in room 205 in the APP building it is projector screen. no wires	7/22/13				Carpentry
Northwest Prep Academy (2824) 1A	Remove existing ceiling tiles from serveing line area. Approx. 9' by 70' long.	6/2/14	Cafetorium			Carpentry
Northwest Prep Academy (2824) 1A	Install new 2' by 4' grid system over serve line.	6/2/14	Cafetorium			Carpentry
Northwest Prep Academy (2824) 1A	Install new 2' by 4' lay-in ceiling over serve line.	6/2/14	Cafetorium			Carpentry
Northwest Prep Academy (2824) 1A	Mull in door loose , making it hard to secure doors to the outside.	6/5/14	Gym	Exit doors		Carpentry
Northwest Prep Academy (2824) 1A	Weld bracket on sewer wash truck	2/18/14				Carpentry
Northwest Prep Academy (2824) 1A	In the APP building in room 209 the door is coming off the hinge need to be fixed. thank you	2/19/14				Carpentry
Northwest Prep Academy (2824) 1A	The cabnet doors in the APP building on the 1st floor in the Infant daycare need to be fixed. thank you	2/27/14				Carpentry

Northwest Prep Academy (2824) 1A	In room 108 the hinge to the door need to be work on, the 1st floor. thank you	3/17/14			Carpentry
Northwest Prep Academy (2824) 1A	In Mr. Booker office in room 206 the windows need to caulked and sealed, because when it rain it come in , and water get on the PC, Printer, etc. thank you.	4/15/14			Carpentry
Northwest Prep Academy (2824) 1A	In the auditorm the doors class has been broken out and need be replace. It located on the 1st floor. thank you	4/21/14			Carpentry
Northwest Prep Academy (2824) 1A	In Ms. Johnson's room 303 the window is broken on the 3rd floor, northest prep part of building. thank you	5/15/14			Carpentry
Northwest Prep Academy (2824) 1A	GARAGE DOOR WON'T SHUT PLANT MGR-STOUT/416.3206	5/21/14			Carpentry
Northwest Prep Academy (2824) 1A	Door bar is BROKEN on 3rd floor by stairwell per Mr. Stout, Plant Mgr. 416.4400	12/11/13			Carpentry
Northwest Prep Academy (2824) 1A	The window is broken on the 2nd floor across from Mr. Pope office room 201 it need to be fixed. thank you	12/12/13			Carpentry
Northwest Prep Academy (2824) 1A	On the 2nd floor I have two crash bar on too door that is coming apart need to fixed in northwest prep part of the building.	12/12/13			Carpentry

Northwest Prep Academy (2824) 1A	On the 2nd floor around from Mr. pope office I have a window that is broken in room 204. thank you	12/16/13			Carpentry
Northwest Prep Academy (2824) 1A	I have blinds that need to be put up in room 107 main part of th building 1st floor, thank you.	1/21/14			Carpentry
Northwest Prep Academy (2824) 1A	I have some blinds that need be put up in room 108 in the main part of the building 1st floor, thank you	1/21/14			Carpentry
Northwest Prep Academy (2824) 1A	The office door,inside the library will not lock properly.It is located on the 2nd floor of main building. thank you	2/7/14			Carpentry
Northwest Prep Academy (2824) 1A	DOCK DOOR HINGES ARE LOOSE, CANT SECURE IN ROTC BLDG. PLANT MGR-STOUT/416.4400	10/29/13			Carpentry
Northwest Prep Academy (2824) 1A	The door by the caf. where the people come in the door it is not closing it is located where the card swipe is. thank you	11/5/13			Carpentry
Northwest Prep Academy (2824) 1A	On the 3rd floor room 301 the computar room the tile is coming up off the floor it need to be replace. thank you	11/21/13			Carpentry
Northwest Prep Academy (2824) 1A	On the 2nd floor in room 204 the tile is coming up off the floor and need to be replace as soon as you can. thank you	11/21/13			Carpentry

Northwest Prep Academy (2824) 1A	In the room 210 on the 2nd floor the door will not lock and the frame is inside the door making it impossible to lock. thank you	11/22/13			Carpentry
Northwest Prep Academy (2824) 1A	window broken out 2nd floor room 202 per Mr. Stout 416-4400	12/2/13			Carpentry
Northwest Prep Academy (2824) 1A	DOOR HINGES ARE LOOSE, CANT SHUT IN RM-303 PLANT MGR-STOUT/416.4400	12/3/13			Carpentry
Northwest Prep Academy (2824) 1A	The boy bathroom on the 3rd floor of the northwest prep part of the building is not working like it should, need to look at. thank you	12/9/13			Carpentry
Northwest Prep Academy (2824) 1A	The room 110 on the 1st floor of main building the door will not lock. thank you	12/10/13			Carpentry
Northwest Prep Academy (2824) 1A	Repair HVAC door lock in APA.	7/9/13	2nd Floor		Carpentry
Northwest Prep Academy (2824) 1A	Repair door in stairwell in APA.	7/9/13	2nd Floor		Carpentry
Northwest Prep Academy (2824) 1A	Replace door closer N., APA.	7/9/13	1st Floor		Carpentry

Northwest Prep Academy (2824) 1A	Repair door hard to open/close APA.	7/9/13	Restroom (Girls)		Carpentry
Northwest Prep Academy (2824) 1A	Replace door sweep in south stairs APA.	7/9/13	Stairway		Carpentry
Northwest Prep Academy (2824) 1A	Repair E. handrail.	7/10/13	Cafetorium		Carpentry
Northwest Prep Academy (2824) 1A	Replace hardware on RCA door.	7/10/13	Hallway/Corri dor		Carpentry
Northwest Prep Academy (2824) 1A	Repair door.	7/10/13	Gym		Carpentry
Northwest Prep Academy (2824) 1A	Install cut ceiling tile.	7/15/13	1st Floor		Carpentry
Northwest Prep Academy (2824) 1A	Install cut ceiling tile.	7/15/13	2nd Floor		Carpentry
Northwest Prep Academy (2824) 1A	Install kick plates on door boy/girl.	7/16/13	2nd Floor		Carpentry

Northwest Prep Academy (2824) 1A	Install kick plates on door boy/girl.	7/16/13	3rd Floor		Carpentry
Northwest Prep Academy (2824) 1A	In the AAP building room208 the hinge to the door need be repaired it is very loose. thank you.	8/1/13			Carpentry
Northwest Prep Academy (2824) 1A	In the R.O.T.C building the door to the garage need to be check out, because it look to be falling from the hinge. thank you	8/14/13			Carpentry
Northwest Prep Academy (2824) 1A	On the stairwell that go down the crash bar is broken and need to be fixed as soon as possible. thank you	8/16/13			Carpentry
Northwest Prep Academy (2824) 1A	On the stairwell the hand rail need to be replace that the kids use to hold on to going down the stair as well as going up. thank you	8/16/13			Carpentry
Northwest Prep Academy (2824) 1A	Door closer APA.	8/28/13			Carpentry
Northwest Prep Academy (2824) 1A	Per Mr. Bell 292-6530 in the main lobby there is a window pane broken out	9/10/13			Carpentry
Northwest Prep Academy (2824) 1A	the doors in Mr. Hawkin room is broken that is in the back of the room it need another lock on it, that in room 110 in the art room.	10/15/13			Carpentry

Northwest Prep Academy (2824) 1A	The Guidance Counseor in side of her room, which the room number is 206 on the 2nd floor the door need to replace, because of the damage to the door and it need new hardware as well.It have important record in this room, and she would like to lock the door	10/23/13			Carpentry
Northwest Prep Academy (2824) 1A	In the caf. I need a door handle on one of the door come from the enter to th back of the caf. thank you	6/11/14			Carpentry
Northwest Prep Academy (2824) 1A	Install barb wire on fence on popular side to prevent students from climbing fence and breaking into school.	10/25/13			Carpentry
Northwest Prep Academy (2824) 1A	Install fence with gate to stop entry to third floor GYM area student are smoking and hiding in this upper level. This will be on bith sides of GYM stairwell. thank you	10/25/13			Carpentry
Northwest Prep Academy (2824) 1A	RECEPTACLES SAFE SCHOOLS RM ON MONTGOMERY SIDE-HAVE NO POWER-PLANT MGR STOUT 416-4400 KLR	6/24/14			Electrical
Northwest Prep Academy (2824) 1A	UNIT NOT COMING ON 3RD FLR PLANT MGR-STOUT/416.4400	6/17/14			Electrical
Northwest Prep Academy (2824) 1A	On the mainfloor which is 1st floor as you come threw the front door there is a light out. The light is on the out side of the building. thank you	10/25/13			Electrical
Northwest Prep Academy (2824) 1A	Remove existing stem lights over serve line.	6/2/14	Cafetorium		Electrical

Northwest Prep Academy (2824) 1A	Install new 2' by 4' lay-in light fixtures over serve line.	6/2/14	Cafetorium		Electrical
Northwest Prep Academy (2824) 1A	The light in the caf. area where the children eat at need to be change the ballast has gone bad. thank you	2/17/14			Electrical
Northwest Prep Academy (2824) 1A	In the APP building I have two light in room 209 on the 2nd floor the ballast bad. thank you	2/19/14			Electrical
Northwest Prep Academy (2824) 1A	the plug in socket donot work in room 301 on the 3rd floor. thank you	2/25/14			Electrical
Northwest Prep Academy (2824) 1A	LIGHTS RM 302-NOT COMING ON-COMpletely DARK IN ROOM & NO WHERE ELSE FOR CLASS TO GO-PLANT MGR STOUT 416-4400 KLR	2/28/14			Electrical
Northwest Prep Academy (2824) 1A	I have a light out on the 1st floor hallway by the front door enter come in. thank you	2/28/14			Electrical
Northwest Prep Academy (2824) 1A	The clock need to be reset for day light saving time for March 9, 2014 and the clock is not working. thank you	3/6/14			Electrical
Northwest Prep Academy (2824) 1A	It is a light out on the basement floor by sercuity the ballast is bad. thank you	3/6/14			Electrical

Northwest Prep Academy (2824) 1A	POWER OUTAGE throughout the ENTIRE BUILDING per Mr. Stout, Plant Mgr. 416.4400.	3/6/14			Electrical
Northwest Prep Academy (2824) 1A	Cond. water pump #2 has bad transformer ---- check pump #1 while on site	3/6/14			Electrical
Northwest Prep Academy (2824) 1A	Provide # of fixtures to light this area with 2 x 4 lay-in ceiling (new). And other items needed to complete all new lights.	3/18/14	Cafetorium		Electrical
Northwest Prep Academy (2824) 1A	Northwest prep in the old GYM there are three bulb in a room that need to fixed cannot change them or replace them. thank you	3/24/14			Electrical
Northwest Prep Academy (2824) 1A	The emer. light in the stairwell at APP building is out need to be fixed. thank you	3/25/14			Electrical
Northwest Prep Academy (2824) 1A	In the APP building in the stairwell the light out. thank you	3/25/14			Electrical
Northwest Prep Academy (2824) 1A	On the basement floor by where the drink and stack machine is located there is a socket that is not working.thank you	4/4/14			Electrical
Northwest Prep Academy (2824) 1A	LIGHTS KITCHEN PANTRY AREA-NOT COMING ON-VERY DARK, CAFE MGR CAN'T SEE-PLANT MGR STOUT 416-3206 KLR	4/14/14			Electrical

Northwest Prep Academy (2824) 1A	In room 111-C2 the light is out the ballast is bad right across from the plant manger office. thank you	4/15/14			Electrical
Northwest Prep Academy (2824) 1A	In the room 206 Mr. booker office I have a light out the ballast is bad already got new bulb in it. thank you	4/15/14			Electrical
Northwest Prep Academy (2824) 1A	AHU-5 (VFD) IN ALARM-PLANT MGR STOUT 416-4400 KLR	5/6/14			Electrical
Northwest Prep Academy (2824) 1A	checking on the fire alarm system calling the air to go out, thank you.	5/7/14			Electrical
Northwest Prep Academy (2824) 1A	A/C JROTC BLDG-NOT COMING ON-PLANT STOUT 416-4400 KLR	5/8/14			Electrical
Northwest Prep Academy (2824) 1A	In the caf. in the cooking area I have two clock that are not working that need to be replace. thank you	5/15/14			Electrical
Northwest Prep Academy (2824) 1A	A STRONG BURNING SMELL IN RM 104-MAY BE COMING FROM AN OUTLET-PLANT MGR STOUT 416-4400 KLR	5/22/14			Electrical
Northwest Prep Academy (2824) 1A	NO POWER IN G/RR & RM- 314A,312A 3RD FLR MAIN BLDG PLANT MGR-STOUT/416.4400	12/17/13			Electrical

Northwest Prep Academy (2824) 1A	In room 206 Mr. Brooker office in his conference room there is a light out. The ballast is bad.thank you	12/19/13			Electrical
Northwest Prep Academy (2824) 1A	APP building AHU 2 no power. see mikefor info.	1/10/14			Electrical
Northwest Prep Academy (2824) 1A	ahu #2 replace starter	1/30/14			Electrical
Northwest Prep Academy (2824) 1A	On outside of the building of the APP building the light are out on the claybrook side of the building.	1/31/14			Electrical
Northwest Prep Academy (2824) 1A	I have a light out 1st floor hallway down from the main office the ballast is bad. thank you	2/3/14			Electrical
Northwest Prep Academy (2824) 1A	In the back of the caf. I have some light out.They need to be change. thank you	2/4/14			Electrical
Northwest Prep Academy (2824) 1A	I have two outside light out in the back of the APP building. thank you	2/5/14			Electrical
Northwest Prep Academy (2824) 1A	The lights in front of the APP building are set on a timer it need to be replace, because the light are staying on. thank you	2/13/14			Electrical

Northwest Prep Academy (2824) 1A	NO POWER IN RM-117. PLANT MGR-STOUT/416.4400	10/29/13			Electrical
Northwest Prep Academy (2824) 1A	BURNING SMELL 1ST FLR RM 110 PER SBE-DON'T KNOW WHAT OR WHERE IT'S COMING FROM- PLANT MGR STOUT 416-4400 KLR	11/7/13			Electrical
Northwest Prep Academy (2824) 1A	In the main building 1st floor the emer- light are out they do not work.	11/7/13			Electrical
Northwest Prep Academy (2824) 1A	In the cafeteria front and back of it the emer-light are out, they do not work.	11/7/13			Electrical
Northwest Prep Academy (2824) 1A	In the R.O.T.C building the emer-light are all out they do not work.	11/7/13			Electrical
Northwest Prep Academy (2824) 1A	In the main building 2nd floor the emer- light donot work at all.	11/7/13			Electrical
Northwest Prep Academy (2824) 1A	In the main building on the 3rd floor the emer-light donot work at all.	11/7/13			Electrical
Northwest Prep Academy (2824) 1A	I have three lights out in room 201 Mr.Pope, derector of student safety the ballast donot work with in the light. thank you	11/12/13			Electrical

Northwest Prep Academy (2824) 1A	ROTC bldg safe school office the lights are out and very dark per Mr. Williams 416-9965	11/13/13			Electrical
Northwest Prep Academy (2824) 1A	I have a light out in the bathroom by room 206 student support which is Mr. Brooker office. The ballast is out.	11/14/13			Electrical
Northwest Prep Academy (2824) 1A	On the 2nd floor the ele. plug by teacher lounge the socket pop fire from it.thank you	11/22/13			Electrical
Northwest Prep Academy (2824) 1A	In room 106 I have two light out the ballast do not work. thank you	12/5/13			Electrical
Northwest Prep Academy (2824) 1A	There is a light out in the hallway 1st floor of the northwest prep building. by the main office	12/5/13			Electrical
Northwest Prep Academy (2824) 1A	It is a light out in the stairwell by the principal office it need to be fixed. thank you	12/9/13			Electrical
Northwest Prep Academy (2824) 1A	It is a light out in the stairwell by Mrs. Herenton room 1st floor. thank you	12/9/13			Electrical
Northwest Prep Academy (2824) 1A	I have four outside light out on the claybrook side of the building. It is very hard to see in the early morning time.thank you	12/10/13			Electrical

Northwest Prep Academy (2824) 1A	I have two light out in the hallway by Mr. Brooker office.thank you	12/10/13			Electrical
Northwest Prep Academy (2824) 1A	NO POWER IN RM-110 ROTC BLDG PLANT MGR-STOUT/416.4690	12/10/13			Electrical
Northwest Prep Academy (2824) 1A	FIRE ALARM IS SHOWING TROUBLE (051). SBE-PATTERSON/416-4400	7/3/13			Electrical
Northwest Prep Academy (2824) 1A	The night light in courtyard is not working.	7/5/13	Courtyard		Electrical
Northwest Prep Academy (2824) 1A	I need some light bulbs two boxes three six in them the number is 46807 lamb,flr. rapid start25 I need them as soon as possilbe the building is dark. thank you	7/18/13			Electrical
Northwest Prep Academy (2824) 1A	UNIT IN THE NOT COMING ON IN THE TRUANCY OFFICE. SBE STOUT	7/26/13			Electrical
Northwest Prep Academy (2824) 1A	I have light out in truancy room 115 the ballast is gone bad need to be replace. thank you	8/20/13			Electrical
Northwest Prep Academy (2824) 1A	the bells for the school need to be change as soon as possible. thank you	8/23/13			Electrical

Northwest Prep Academy (2824) 1A	The JR ROTC Warehouse at 1257 Larkins & Montgomery the a/c is not working at all. you must go to ROTC bldg and see Col Haywood or 1st Shye per Mr. Stout	8/29/13			Electrical
Northwest Prep Academy (2824) 1A	In Mr. brooker office area we lights out, they are out because the ballast is bad in them they really need to be change as soon as possible. thank you	9/12/13			Electrical
Northwest Prep Academy (2824) 1A	In rooms 101,102,103,104,105,106,107,108, I have light out the ballast is gone in the light fixture, this is on the 1st floor of the building they have new light bulb in them. thank you	9/23/13			Electrical
Northwest Prep Academy (2824) 1A	I have two light out in the hallway on the 1st floor mainhall were the office is.thank you	9/23/13			Electrical
Northwest Prep Academy (2824) 1A	In the R.O.T.C building in room 101 the storage room the light is out it need a ballast. thank you	9/30/13			Electrical
Northwest Prep Academy (2824) 1A	In The library have four light out the ballast are out this located on the 2nd floor of the northwest prep building.	10/2/13			Electrical
Northwest Prep Academy (2824) 1A	On the 2nd floor in room 204A I have a light out the ballast is bad.	10/2/13			Electrical
Northwest Prep Academy (2824) 1A	Replace lights on the southside of back porch, need a ballast. thank you	10/3/13			Electrical

Northwest Prep Academy (2824) 1A	Repair outside post lamp on the building at 1257 larkin st. thank you	10/3/13			Electrical
Northwest Prep Academy (2824) 1A	Replace light in the building at 1257 larkin the ballast has gone bad. thank you	10/3/13			Electrical
Northwest Prep Academy (2824) 1A	In the APP building on the 1st floor where the day care is located in the toddler bathroom the light do not work,it need a ballast. thank you.	10/18/13			Electrical
Northwest Prep Academy (2824) 1A	I have a hallway light out in the APP building on the 2nd floor. thank you	10/23/13			Electrical
Northwest Prep Academy (2824) 1A	In the principal office in the APP building I have two light out.thank you	10/23/13			Electrical
Northwest Prep Academy (2824) 1A	I need some light bulb for the cabnet top in the A.P.P. building on the 1st floor of that building the bulb side is F15T8-CW pro-start, and I need at lest 12 of them.thank you	8/30/13			Electrical
Northwest Prep Academy (2824) 1A	inew light bulb	10/28/13			Electrical
Northwest Prep Academy (2824) 1A	I need about twenty 100 watt light bulb for my building, R.O.T.C part and the APP part the northwest prep part of as well and my boiler room. thank you	10/24/13			Electrical

Northwest Prep Academy (2824) 1A	I need some light bulbs and this are the kind of bulb I need F40W/RS/EW 34watt. I need three box of these 20-24 each in a box. thank you	10/1/13			Electrical
Northwest Prep Academy (2824) 1A	I need a light bulbs of this can F15T8-CW and I need 12 each. thank you	10/1/13			Electrical
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C UNIT IN ROTC BLDG - MONTGOMERY SIDE - BLOWING NOT COOLING - PM/STOUT 416-4400	6/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	chiller down	6/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	ahu#8 not cooling	6/25/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C ROTC BLDG-NOT COOLING- PLANT MGR STOUT 416-4400 KLR	6/16/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	chiller down	6/16/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	A/C RM 208 2ND FLR BY MR BOOKER'S OFC-NOT COOLING- PLANT MGR STOUT 416-4400 KLR	6/17/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	UNIT NOT COOLING IN ROTC BLDG PLANT MGR-STOUT/416.4400	6/11/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	clean coils	6/12/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - Filter-Northwest Prep Academy - Refer to PM schedule details.	6/15/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	boiler not coming on	10/25/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C UNIT is NOT COOLING in SAFE SCHOOLS per Mr. Stout, Plant Mgr. 416.4400	5/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	CHILLER DOWN	5/27/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C RM 101-NOT COOLING-PLANT MGR STOUT 416-4400 KLR	5/29/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	pupil services 146-353 cond. unit -- bad comp.	6/2/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	6/6/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU ENTIRE 3RD FLR-NOT COOLING-ABOUT (8) RMS AND THEY ARE HAVING SUMMER SCHOOL IN AREA-PLANT MGR PATTERSON 416-4400 KLR	6/6/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C ENTIRE 3RD FLR ABOUT (12) RMS-ALL NOT COOLING-PLANT MGR STOUT 416-4400 KLR	6/9/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C ROTC BLDG-NOT COOLING- PLANT MGR STOUT 416-4400 KLR	6/9/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	ahu #3 not coming on	6/11/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	rm 208 not cooling	6/11/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	ROTC --- computer rm --- wire up actuator and check operation	2/13/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - Filter-Northwest Prep Academy - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - NORTHWEST PREP LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Yearly - W.C.C. Filter-Northwest Prep Academy - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	basement heater not heating	3/6/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	clean cooling tower	3/10/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	no heat in bldg.	3/18/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - Oil Lube & Belt-Northwest Prep Academy - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Yearly - Cooling Towers-Northwest Prep Acad - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Yearly - Rod Chiller - Northwest Prep Academy - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - NORTHWEST PREP LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	check chiller	4/14/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C RM 103 ROTC BLDG-NOT COOLING-PLANT MGR STOUT 416-3361 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Yearly - Air Cool Chillers-Northwest Prep Academy - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - NORTHWEST PREP LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	per mr stout 416-4400 3rd floor is not cooling	5/7/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C APP BLDG TODDLER RM-AIR NOT BLOWING IN RM-PLANT MGR STOUT 416-4400 KLR	5/7/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C PUPIL SERVICES RM 111-NOT COOLING-PLANT MGR STOUT 416-4400 KLR	5/7/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	CHILLER 1 --- LO ON FREON	5/8/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C UNIT is NOT COMING ON in ROOM 208 per Mr. Stout, Plant Mgr. 416.4400	5/15/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	chiller down	5/22/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	ahu #4 & 5 overheating	12/12/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	boiler east end of building in alarm	12/18/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	main boiler room ---- pressure too high	12/18/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	boiler down	12/23/13			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	pupil services not heating	1/6/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	per Mr. Stout 416-4400 in the APB building room 207 is blowing cold air (this is the toddler room)	1/7/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	per Mr. Stout 416-4400 the APP building has no heat it is blowing cold air	1/8/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU #2 not coming on	1/14/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	PIPE - APP BLDG 2ND RM 209 - RR PIPE LEAKING - PM/STOUT 416-4400	1/21/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	per mr stout 416-4400 entire building no heat	1/28/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	HAS NO HEAT IN THE APP BLDG - & CAFE - PM/STOUT 416-4400	1/29/14			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU #4 bad actuator	2/4/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU #6 overheating	2/4/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU #7 overheating	2/4/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU #3 overheating	2/4/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU #2 overheating	2/4/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	UNIT NOT HEATING IN ROTC BLDG. PLANT MGR-STOUT/416.4690	2/10/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	heat off due to EMS	11/4/13			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	Chilled water Pump cwp-2 has bad transformer	11/14/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	heater in basement not working -- no gas piped to unit.	11/19/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	no heat	11/19/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Replace all 3 safety valves on boiler	11/25/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	boiler down	11/25/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	HEAT CAFE-NOT HEATING-PLANT MGR STOUT 416-4400 KLR	11/26/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	actuator in boiler rm	12/3/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	BOILER - IN ALARM MAKING A LOUD NOISE - PM/STOUT 416- 4400	12/3/13			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	boiler not coming on 1st flr PLANT MGR-stout/416.4400	12/5/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	UNIT NOT HEATING IN COMPUTER RM ROTC BLDG PLANT MGR-STOUT/416.4690	12/5/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	No A/C in Student Services building.	7/5/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	2-AHU NOT COMING ON FOR ENTIRE BLDG. PLANT MGR-STOUT/416.4400	7/29/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	in the back building on the roof there are several RTU's that need to be checked these feed the nursery - I think. we need to be sure these babies are comfortable	8/5/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	There may be a fire damper that is In the APP area of the building it is not cooling at all and there are little babies in that area per Mr. Stout 416- 4400	8/7/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	RTU NOT COOLING IN DAYCARE CTR BLDG PLANT MGR-STOUT/416.3206	8/12/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	main bldg not cooling	8/13/13			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	In the R.O.T.C building the air is not working in the ware house area. thank you.	8/14/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	AHU#3 IS IN ALARM IN MAIN OFFICE PLANT MGR-STOUT/416.3206	8/19/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	CEILING UNIT NOT COOLING IN RM-203 COUNSELING SERVICE 2ND FLR PLANT MGR- SLAUGHTER/416.8080	8/23/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - Oil Lube & Belt-Northwest Prep Academy - Refer to PM schedule details.	8/25/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C MAIN OFC-NOT COOLING- PLANT MGR STOUT 416-4400 KLR	8/28/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C not cooling in entire main building per Milton Bell 292-6530	9/3/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Purchase Visual IR Thermometer	9/6/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C UNIT APP BLDG RM 209-HAS AN ODOR COMING FROM IT- PLANT MGR STOUT 416-4400 KLR	9/12/13			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	clean coil and change filter -- in room 209 App. bldg	9/12/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Yearly - Oil Samples-Northwest Prep Acad. - Refer to PM schedule details.	9/13/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C TRUANCY OFC & ADOLESCENT PARENTING OFC- BOTH NOT COOLING-PLANT MGR STOUT 416-4400 KLR	9/13/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	chiller down	9/19/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	A/C unit is NOT COOLING in the entire APP building per Lucious Stout, Plant Mgr. 416.4400	9/24/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	Monthly - Filter-Northwest Prep Academy - Refer to PM schedule details.	10/13/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	chiller down	10/17/13			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning

Northwest Prep Academy (2824) 1A	Daily - Northwest Prep Level 1 Water Treatment - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Northwest Prep Academy (2824) 1A	In the R.O.T.C building room 100 need to be painted the paint is chipping off the wall	12/10/13			Painting
Northwest Prep Academy (2824) 1A	The classrooms 1st floor need to be painted and it is 11 classroom on that floor. thank you	2/13/14			Painting
Northwest Prep Academy (2824) 1A	The classroom on the 2nd floor all of them need to paint as well, and there are 10 on that floor. thank you	2/13/14			Painting
Northwest Prep Academy (2824) 1A	On the 3rd floor the classrooms need to be painted and there are 11 room that really need it. thank you	2/13/14			Painting
Northwest Prep Academy (2824) 1A	In the R.O.T.C building the paint is chipping off the wall very bad something did to be done about it.	7/22/13			Painting
Northwest Prep Academy (2824) 1A	On the 1st floor the class rooms doors need to be painted on the inside and out and it is 11 door. thank you	2/13/14			Painting
Northwest Prep Academy (2824) 1A	On the 2nd floor the class room door need to be painted and it is 13 door and they need be painted inside and out. thank you	2/13/14			Painting

Northwest Prep Academy (2824) 1A	On the 3rd floor the class room doors need to be painted and it is 12 door on that floor and it need to paint inside and out.thank you	2/13/14			Painting
Northwest Prep Academy (2824) 1A	VULGAR GANG GRAFFITI OUTSIDE ON CONCRETE STEPS FRONT OF BLDG ON POPLAR SIDE-GETTING COMPLAINTS PER SBE-PLANT MGR STOUT 416-4400 KLR	5/13/14			Painting
Northwest Prep Academy (2824) 1A	GRAFFITI ON 3RD FLR STAIRWAY. PLANT MGR-STOUT/416.4400	5/16/14			Painting
Northwest Prep Academy (2824) 1A	Paint wood stripes (stain). Ref #430486 Phillip H.	5/21/14	Auditorium		Painting
Northwest Prep Academy (2824) 1A	The caf. walls need to be plaster before it can be painted, however it really need to be painted.	12/10/13			Painting
Northwest Prep Academy (2824) 1A	In the Auditorium on the stage need to be plaster, and it need to be painted as well. thank you	12/10/13			Painting
Northwest Prep Academy (2824) 1A	Graffiti on the walls in the GIRL'S RR in the MAIN BUILDING on the 3RD FLOOR per Mr. Stout, Plant Mgr. 416.4400.	1/29/14			Painting
Northwest Prep Academy (2824) 1A	In the Northwest prep part of the building on the 2nd floor in room 211 the room need to be painted it look very bad. I hope that you can get to as soon as possible,or let me know when. thank you	11/1/13			Painting

Northwest Prep Academy (2824) 1A	The main hall 1st floor need to be painted it is chipping paint off the wall next to the Auditorium. thank you	11/13/13			Painting
Northwest Prep Academy (2824) 1A	A/C UNIT IN WAITING RM -PUPIL SERVICE CLAY BROOK SIDE- - LEAKING FROM CEILING - TILE IS COMING DOWN - PM/STOUT 416-4400	6/23/14			Plumbing
Northwest Prep Academy (2824) 1A	AHU -IN CEILING - MAIN OFC AREA - LEAKING ON COUNTER - PM/STOUT 416-3206	6/23/14			Plumbing
Northwest Prep Academy (2824) 1A	Ceiling leak room 105 - Need help Monday morning	6/16/14			Plumbing
Northwest Prep Academy (2824) 1A	In the R.O.T.C building I have a leak in the conference room , it need immediate attention.	7/22/13			Plumbing
Northwest Prep Academy (2824) 1A	Clean area drains	10/28/13			Plumbing
Northwest Prep Academy (2824) 1A	A/C UNISEX RR 2ND FLR BY RM 204-LEAKING-PLANT MGR STOUT 416-4400 KLR	6/2/14			Plumbing
Northwest Prep Academy (2824) 1A	In the bathroom girl by pupal service it is stop up.thank you	6/3/14			Plumbing

Northwest Prep Academy (2824) 1A	PIPES - ROTC BLDG COME IN ON THE MONTGOMERY SIDE - LEAKING THRU CEILING - PM/STOUT 416-4400	6/4/14			Plumbing
Northwest Prep Academy (2824) 1A	UNIT IS LEAKING WATER IN TRUANCY AREA PLANT MGR-STOUT/416.3206	2/19/14			Plumbing
Northwest Prep Academy (2824) 1A	UNIT NOT HEATING IN TRUANCY RM. PLANT MGR-STOUT/416.4400	2/26/14			Plumbing
Northwest Prep Academy (2824) 1A	The mop sink in the APP building willnot stop running on the 1st floor. thank you	2/27/14			Plumbing
Northwest Prep Academy (2824) 1A	On the 1st floor by assessment team the break room toilet is stop up. thank you	2/28/14			Plumbing
Northwest Prep Academy (2824) 1A	teacher lounge man restroom repair toilet want flush.	3/5/14			Plumbing
Northwest Prep Academy (2824) 1A	per stout 416-4400 pipe in ceiling leaking in ROTC building (Montgomery side)	3/7/14			Plumbing
Northwest Prep Academy (2824) 1A	In the teacher lounge the men bathroom toilet is stop up the bathroom is located on the 2nd floor of the northwest prep part building. thank you	4/1/14			Plumbing

Northwest Prep Academy (2824) 1A	The sink in room 314A is stop up and it very well need.It is located on the 3rd floor of northwest prep part of the building. thank you	4/7/14			Plumbing
Northwest Prep Academy (2824) 1A	APP BLDG 1ST FLR RM 106-PIPE IN CEILING LEAKING-PLANT MGR STOUT 416-3361 KLR	4/23/14			Plumbing
Northwest Prep Academy (2824) 1A	Upstair in Mr. brooker area in room 204 the bathroom right beside it is a real got a bad drip coming from ceiling need to be look at as soon as possible. thank you	5/15/14			Plumbing
Northwest Prep Academy (2824) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	5/19/14			Plumbing
Northwest Prep Academy (2824) 1A	The toilet in the basement by pubic service boy bathroom is stop up. thank you	5/19/14			Plumbing
Northwest Prep Academy (2824) 1A	per Mr. Stout 416-4400 on the 2nd floor main building teacher's lounge toilet overflowing and water everywhere	12/16/13			Plumbing
Northwest Prep Academy (2824) 1A	In the teacher lounge the boy bathroom toilet is stop up will not flush, it need to be fixed. On 2nd floor main part of northwest part of building.	1/10/14			Plumbing
Northwest Prep Academy (2824) 1A	WATER PIPE ROTC BLDG COMPUTER RM-LEAKING IN CEILING-PLANT MGR STOUT 416-4400 KLR	1/13/14			Plumbing

Northwest Prep Academy (2824) 1A	COMMODES APP BLDG 2ND FLR NURSERY AREA & SINKS & WATER FOUNTAINS TRUANCY OFC AREA MAIN BLDG-ARE BACKING UP-PLANT MGR STOUT 416-4400 KLR	1/21/14			Plumbing
Northwest Prep Academy (2824) 1A	basement --- Hanging heater needs gas line installed	1/21/14			Plumbing
Northwest Prep Academy (2824) 1A	Water Fountains Truancy off in Main building backing up.	1/21/14			Plumbing
Northwest Prep Academy (2824) 1A	On the base floor where pupil services is located in the break room the girl bathroom toilet is stop up.thank you	1/31/14			Plumbing
Northwest Prep Academy (2824) 1A	On the 1st floor by main office the boy bathroom toilet is stop up. thank you	1/31/14			Plumbing
Northwest Prep Academy (2824) 1A	On the 1st floor down from the main office the girls bathroom toilet will not flush. thank you	1/31/14			Plumbing
Northwest Prep Academy (2824) 1A	I have a leak coming from the ceiling in office area 2nd floor of APP building. thank you	2/5/14			Plumbing
Northwest Prep Academy (2824) 1A	in the Jr ROTC Building in the computer lab in the ceiling the pipes are leaking per Mr. Stout 416-4400	2/11/14			Plumbing

Northwest Prep Academy (2824) 1A	CEILING PIPE IS LEAKING WATER IN ROTC BLDG COMPUTER LAB PLANT MGR-STOUT/416.3206	2/13/14			Plumbing
Northwest Prep Academy (2824) 1A	AHU IS LEAKING WATER CONTINUOUSLY IN ROTC BLDG, CANT CONTROL. PLANT MGR-STOUT/416.4400	10/29/13			Plumbing
Northwest Prep Academy (2824) 1A	on the 1st floor of the Northwest prep part of building the boy bathroom toilet is stop up by the principal office.	11/1/13			Plumbing
Northwest Prep Academy (2824) 1A	SINK B RR 1ST FLR BY MAIN OFC- LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF PER SBE- PLANT MGR STOUT 416-4500 KLR	11/7/13			Plumbing
Northwest Prep Academy (2824) 1A	UNIT IS LEAKING WATER IN BOILER RM ROTC BLDG. PLANT MGR-STOUT/416-4690	11/12/13			Plumbing
Northwest Prep Academy (2824) 1A	MEN/RR TOILET IS OVERFLOWING IN TEACHERS' LOUNGE 2ND FLR . PLANT MGR-STOUT/416.4400	11/26/13			Plumbing
Northwest Prep Academy (2824) 1A	FCU IS LEAKING WATER IN B/RR BY RM-206 (270). SBE-PATTERSON/416-4400	7/15/13			Plumbing
Northwest Prep Academy (2824) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/31/13			Plumbing

Northwest Prep Academy (2824) 1A	On the 3rd floor of the northwest prep part of the building the mop sink is stop up and need to be fixed as soon as possible it have a bad smell it located in the jounal closed.thank you.	8/21/13			Plumbing
Northwest Prep Academy (2824) 1A	In the J-R.O.T.C warehouse the water donot work it is located on 1257 larkin st. however you have to go to the R.O.T.C part of the building to see 1st sergent to get the key to get in the building. thank you	8/29/13			Plumbing
Northwest Prep Academy (2824) 1A	The cooling tower is overflowing and the make up valve is leaking.	8/29/13			Plumbing
Northwest Prep Academy (2824) 1A	The water fountain in the northwest prep part of the main building on the 3rd floor do not work it need to be fixed as soon as possible. thank you	9/24/13			Plumbing
Northwest Prep Academy (2824) 1A	CEILING PIPE IS LEAKING IN B/RR 3RD FLR BY RM-300 PLANT MGR-STOUT/416.4400	9/25/13			Plumbing
Northwest Prep Academy (2824) 1A	Shut-off gas & water	9/26/13			Plumbing
Northwest Prep Academy (2824) 1A	CEILING LEAK IN MAIN OFFICE. PLANT MGR-STOUT/649.4620	10/17/13			Plumbing
Northwest Prep Academy (2824) 1A	Boiler #1 needs pop-off replaced --- boiler is already shut off and valved off....	10/21/13			Plumbing

Northwest Prep Academy (2824) 1A	CEILING PIPE IS LEAKING WATER IN PUPIL SERVICE AREA. PLANT MGR-STOUT/416.4400	6/16/14			Plumbing
Northwest Prep Academy (2824) 1A	There is a leak in the R.O.T.C building on the montgomery side of the building need to fixed as soon as possible. thank you	6/9/14			Roof
Northwest Prep Academy (2824) 1A	I have a roof leak in the APP building over the office area inside the office on the 2nd floor. thank you	2/10/14			Roof
Northwest Prep Academy (2824) 1A	Teen parenting center building. Curb for Hvac unit leaking in center hall	9/25/13			Sheet Metal

Count of Craft	Craft				Grand Total
	Location	Carpentry	Electrical	HVAC	
Orleans ES (2560) 1A	7	1	32	4	44
Grand Total	7	1	32	4	44

Location	Request Description	Submittal Date	Area Descript	Area Number	Craft
Orleans ES (2560) 1A	Acquire and Install barrel bolts (inside) to all outside doors. Including common zone master locks.	11/15/13	1st Floor		Carpentry
Orleans ES (2560) 1A	Storage door on back dock open. Repair door/lock.	12/3/13			Carpentry
Orleans ES (2560) 1A	Repair front entrance door. Vandalized over weekend.	3/10/14			Carpentry
Orleans ES (2560) 1A	Break-in at front main entrance, Repair as needed.	3/26/14	1st Floor		Carpentry
Orleans ES (2560) 1A	Secure window in back with screws, from outside. Do not enter building. (open window was reported).	4/23/14	1st Floor		Carpentry
Orleans ES (2560) 1A	Replace window on south side of school. Vandal broke in.	4/24/14			Carpentry
Orleans ES (2560) 1A	Window open break-in on play ground side. Secure from outside, heavy plywood.	5/6/14	1st Floor		Carpentry

Orleans ES (2560) 1A	hot water pump tripping breaker	1/21/14			Electrical
Orleans ES (2560) 1A	c/o to heat	11/6/13			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	check on heat	1/17/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	2/2/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Drain and winterize heating and cooling systems	2/18/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Monthly - ORLEANS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Put on blanks on gas	4/2/14	Mechanical Room		Heating/Ventilation /Air Conditioning

Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	4/27/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Monthly - ORLEANS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	5/25/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Monthly - ORLEANS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Monthly - Filter-Orleans Elementary - Refer to PM schedule details.	6/17/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	6/22/14			Heating/Ventilation /Air Conditioning

Orleans ES (2560) 1A	Monthly - ORLEANS ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Yearly - Water-Cool Chiller Filter-Orleans Elem - Refer to PM schedule details.	3/11/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Yearly - Cooling Towers- Orleans Elem - Refer to PM schedule details.	3/21/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Monthly - Filter-Orleans Elementary - Refer to PM schedule details.	10/15/13			Heating/Ventilation /Air Conditioning

Orleans ES (2560) 1A	Monthly - Oil Lube & Belt- Orleans Elementary - Refer to PM schedule details.	7/15/13			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Monthly - Air Compressor #006 - Orleans Elem - Refer to PM schedule details.	8/13/13			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Yearly - Oil Samples- Orleans Elem - Refer to PM schedule details.	9/14/13			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Daily - Orleans Elem Level 1 Water Treatment - Refer to PM schedule details.	2/16/14			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Monthly - Oil Lube & Belt- Orleans Elementary - Refer to PM schedule details.	2/17/14			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Monthly - Air Compressor #006 - Orleans Elem - Refer to PM schedule details.	2/18/14			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Monthly - Filter-Orleans Elementary - Refer to PM schedule details.	2/18/14			Heating/Ventil ation /Air Conditioning
Orleans ES (2560) 1A	Yearly - Rod Chiller - Orleans Elementary - Refer to PM schedule details.	3/25/14			Heating/Ventil ation /Air Conditioning

Orleans ES (2560) 1A	Yearly - Boiler - Orleans Elem - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Orleans ES (2560) 1A	Drain plumbing and mechanical systems and winterize school. HVAC to support - Josh.	2/14/14			Plumbing
Orleans ES (2560) 1A	Test and report on backflow prevention devices.	7/5/13			Plumbing
Orleans ES (2560) 1A	Test and report on backflow prevention devices.	9/25/13			Plumbing
Orleans ES (2560) 1A	Cap water lines at water meter	4/14/14			Plumbing

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Peabody ES (2570) 1A	16	1	41	37	23	12	62	3	1	196
Grand Total	16	1	41	37	23	12	62	3	1	196

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Peabody ES (2570) 1A	principal nelson is requesting that the main office be retiled a darker color the same as her office.	6/13/14	2nd Floor	the main office	Asbestos
Peabody ES (2570) 1A	principal nelson is requesting a darker floor tile be put in her office.	6/9/14	2nd Floor	principals office floor	Asbestos
Peabody ES (2570) 1A	there are 4 pieces of floor tiles that need to be replaced in the elevator because they are cracked and its a tripping hazard, per principal nelson.	6/9/14		elevator	Asbestos
Peabody ES (2570) 1A	there are several floor tiles that have come up causing a tripping hazard.	5/19/14	3rd Floor	rm318	Asbestos
Peabody ES (2570) 1A	these rooms has some broken floor tiles that pose a tripping hazard as they need replacing.	6/13/14	3rd Floor	rms,303,306,307	Asbestos
Peabody ES (2570) 1A	these rooms have broken floor tiles that are posing a tripping hazard and need to be replaced.	6/13/14	3rd Floor	rms,310,311,314	Asbestos
Peabody ES (2570) 1A	this room has some broken floor tiles and it poses a tripping hazard and need to be replaced.	6/13/14	2nd Floor	rm216a	Asbestos

Peabody ES (2570) 1A	per principle nelson, the stage in the cafetorium needs to be refinished.	10/2/13	Cafetorium	1st.floor	Asbestos
Peabody ES (2570) 1A	there is a pipe leaking from the air unit. HVAC came out and said that pipe needs to be insulated.	10/24/13	Cafetorium	1stfloor	Asbestos
Peabody ES (2570) 1A	there are broken tiles in the cafetorium causing a tripping hazard.	11/1/13	1st Floor	cafetorium	Asbestos
Peabody ES (2570) 1A	there are loose tiles outside of main office.	11/1/13	2nd Floor	outside of main office	Asbestos
Peabody ES (2570) 1A	there is a pipe in this room that mr.means says has been repaired and now needs to be insulated.	11/14/13	3rd Floor	rm304	Asbestos
Peabody ES (2570) 1A	there was a bad water leak on the 3rd floor hallway and some of the floor tiles are buckling. It has caused a tripping hazard.	3/6/14	3rd Floor	3rd floorhallway	Asbestos
Peabody ES (2570) 1A	there is a large piece/chunk of tile missing at this doorway that leads to the stairwell and it is a major tripping hazard,per principal Nelson.	4/25/14	2nd Floor	northeast hallway	Asbestos
Peabody ES (2570) 1A	Plant mgr. has possible "AMG" in rooms 318,111	1/21/14			Asbestos

Peabody ES (2570) 1A	Stage floor need's sanding and refinished	8/5/13			Asbestos
Peabody ES (2570) 1A	in room 101 drops 101-1 and 101-7 have shortages from the classroom to the patch panel. the tech has tried multiple cables and devices and cannot get a stable network connection from the drops in classroom.	1/14/14	1st Floor	rm101	Cabling
Peabody ES (2570) 1A	there is a stall door that has come completely off of the wall.	5/19/14	1st Floor	boysr/r	Carpentry
Peabody ES (2570) 1A	this room needs several cork boards,per principal nelson.	5/20/14	3rd Floor	rm304	Carpentry
Peabody ES (2570) 1A	this door is not closing properly. the secretary opened it and went back to it and it still was opened.	6/18/14	Grounds	northwest entrance	Carpentry
Peabody ES (2570) 1A	these doors are to tight that the badges dont work. also these doors are not locking properly everytime they close. sometimes they do and sometimes they dont close all the way.	6/23/14		north/west entrance	Carpentry
Peabody ES (2570) 1A	there are a couple of small windows broken.	7/30/13	Grounds	south main entrance	Carpentry
Peabody ES (2570) 1A	there are not any lockers or coat rooms in this classrooms or storage for the students belongings, we are requesting shelves to be put/added in this room so that children will have a place to store thier things.	7/31/13	2nd Floor	rm216a	Carpentry

Peabody ES (2570) 1A	there is a big gap in the top of the window in this room allowing rodents wasp to enter in a leisure. this is a hazard.	7/31/13	2nd Floor	rm216a	Carpentry
Peabody ES (2570) 1A	there are 4 commode stalls that dont have stall doors and they are in need of stall doors.	8/5/13	1st Floor	boys r/r	Carpentry
Peabody ES (2570) 1A	NORTH-WEST BACK DOOR, CANT SECURE BY PARKING LOT. SBE-HAYES/416-4606/378-2478	7/2/13			Carpentry
Peabody ES (2570) 1A	the door knob is broken.	7/15/13		southwest entrance	Carpentry
Peabody ES (2570) 1A	The Principal is requesting that a small post holder and flag be installed in the main office.	9/3/13	Administration Area		Carpentry
Peabody ES (2570) 1A	per principal nelson she wants a lock put on the first stall door in the girls r/r on the second floor.	9/10/13	2nd Floor	girls/r/r	Carpentry
Peabody ES (2570) 1A	we need 3cases of the insulated ceiling tiles.	9/11/13			Carpentry
Peabody ES (2570) 1A	there are lockers splitting from foundation.I believe it is hazardous.	10/8/13	3rd Floor	rm306	Carpentry

Peabody ES (2570) 1A	there are broken tiles in the cafeteria and its a tripping hazard.	10/23/13	Cafetorium	1stfloor	Carpentry
Peabody ES (2570) 1A	Request stall door be painted	10/23/13			Carpentry
Peabody ES (2570) 1A	there is a window that has a large gap at the top of the window. we just noticed it because wasp an other pest were in the room.	11/1/13	2nd Floor	rm.205	Carpentry
Peabody ES (2570) 1A	MATERIALS FOR HARDWOOD FLOORING PER BRIAN SHIPP	11/11/13			Carpentry
Peabody ES (2570) 1A	DOOR HINGES HAS CAME OFF FOR KITCHEN, CANT SECURE. PLANT MGR-/416.4606	11/15/13			Carpentry
Peabody ES (2570) 1A	Replace ceiling tile in the cafe.	2/7/14			Carpentry
Peabody ES (2570) 1A	the metal poles has come off of the top of the wire fences both on the play ground side and the attached basketball court side. the children are picking the poles up playing with them and this is very hazardous.	3/24/14	Grounds	playground/basketball crt	Carpentry
Peabody ES (2570) 1A	there is fencing outside of the kitchen door that needs to be repaired.	3/25/14	Grounds	outside of kitchen door	Carpentry

Peabody ES (2570) 1A	NORTH ENTRANCE DOOR-LATCH NOT CATCHING-WON'T BE ABLE TO SECURE BLDG-PLANT MGR HAYES 416-4806 KLR	4/1/14			Carpentry
Peabody ES (2570) 1A	this room needs several cork boards.	4/7/14	3rd Floor	rm.303	Carpentry
Peabody ES (2570) 1A	there are a couple of tables that are bent and missing screws we need all of the tables working properly to serve the appropriate number of students at lunch time. the tables that are not working properly pose can be a hazard.	4/8/14	Cafetorium	1stfloor	Carpentry
Peabody ES (2570) 1A	NE ENTRANCE DOOR-NOT LOCKING-WON'T BE ABLE TO SECURE FOR THE WEEKEND-PLANT MGR HAYES 416-4606 KLR	4/11/14			Carpentry
Peabody ES (2570) 1A	the door to the school sign came off hingde/broke this morning. we need it repaired as soon as possible because children can easily vandalize and misspell the words to read profanity.	4/17/14	Grounds	south main entrance	Carpentry
Peabody ES (2570) 1A	section of floor tile loose due to a/c leaking. (tripping hazard)	8/7/13	3rd Floor	316	Carpentry
Peabody ES (2570) 1A	there are 4 broken/cracked windows in the cafeteria.	8/16/13	Cafeteria	1st fl.	Carpentry
Peabody ES (2570) 1A	rm 111- replace base board-os	8/19/13			Carpentry

Peabody ES (2570) 1A	there are lockers in this room that need to be repaired.	8/21/13	3rd Floor	rm306	Carpentry
Peabody ES (2570) 1A	when it rains there is a leak on the side of the room.	8/21/13	2nd Floor	rm204	Carpentry
Peabody ES (2570) 1A	there is crumbling and cracking floor tile in the doorway leading from the stairway and it is a tripping hazard."Threshold plate".	1/21/14	2nd Floor	north/east stairs	Carpentry
Peabody ES (2570) 1A	Broken window	8/13/13	1st Floor	main office	Carpentry
Peabody ES (2570) 1A	Baseboard need to be fixed	8/13/13	1st Floor	Rms 111 & 120	Carpentry
Peabody ES (2570) 1A	we need a threshold on the doorway leading to the northeast stairwell.	4/29/14			Carpentry
Peabody ES (2570) 1A	Floor tile coming up	8/13/13	2nd Floor	By main office	Carpentry
Peabody ES (2570) 1A	Loose tile (tripping hazard)	8/13/13	2nd Floor	Stairwell	Carpentry

Peabody ES (2570) 1A	there is a smart board that needs to be hung up.	8/26/13	1st Floor	rm111	Carpentry
Peabody ES (2570) 1A	there is a smart board that needs to be hung up.	8/26/13	1st Floor	rm111	Carpentry
Peabody ES (2570) 1A	replace the strikes with crash bars.	6/9/14		north entrance and north west entrance	Carpentry
Peabody ES (2570) 1A	we need the electricity disconnected from the dishwashing machine in preparation for it to be moved out.	6/19/14	Kitchen		Electrical
Peabody ES (2570) 1A	the cafeteria is too dark especially where the children eat. the principal is requesting the cafe be much brighter it also is the auditorium. per principal nelson.	7/22/13	Cafetorium	1st fl	Electrical
Peabody ES (2570) 1A	the main entrance is too dark, it needs to be a lot brighter. per principal nelson.	7/22/13	2nd Floor	main entrance	Electrical
Peabody ES (2570) 1A	Lights in Cafe need to be replaced	8/2/13			Electrical
Peabody ES (2570) 1A	the vent fan does not come on anymore.	7/16/13	1st Floor	teachers lounge	Electrical

Peabody ES (2570) 1A	per principal nelson, she is requesting 2 plastic covers/stoppers to be placed over the fire pull station. so that children wont be able pull the fire station. mr.albert herman said he would supply these 2. there are only 2 on the 2nd floor she would like these two to go there	9/11/13	2nd Floor	hallway	Electrical
Peabody ES (2570) 1A	we dont have any lights. we need 3 cases of the T-8 lights.	9/11/13			Electrical
Peabody ES (2570) 1A	there is a big light out right outside the main office and it has a dark spot in the main entrance.	9/23/13	2nd Floor	hallway	Electrical
Peabody ES (2570) 1A	in the kitchen r/r the light bulb has been changed and the light still wont come on.	10/22/13	Kitchen	1stfl.	Electrical
Peabody ES (2570) 1A	there is a 4 light fixture that has been changed out and still wont come on.	10/22/13	Kitchen	1stfl.	Electrical
Peabody ES (2570) 1A	POWER OUTAGE THRU BLDG. PLANT MGR-HAYES/378.2478	10/31/13			Electrical
Peabody ES (2570) 1A	we need the main clock set for the new time, the bells are off.	11/4/13			Electrical
Peabody ES (2570) 1A	LIGHT FIXTURE KITCHEN AREA-SMOKING PER SBE-PLANT MGR HAYES 416-4606 KLR	11/13/13			Electrical

Peabody ES (2570) 1A	4 new lights have been changed out in a fixture but the lights still wont come on.	11/18/13	2nd Floor	rm203	Electrical
Peabody ES (2570) 1A	Lights are completely OUT in ROOM 100 (P.E. Room) in the cafeteria per Mr. Hayes, Plant Mgr. 416.8859	12/3/13			Electrical
Peabody ES (2570) 1A	the southeast entrance doors need a light at that door because the office and the before/after care cant see who is outside those doors when they buzz the door. It has become a security issue not being able to see and making sure that the wrong person is not buzzed in.	12/11/13	Grounds	southeast entrance	Electrical
Peabody ES (2570) 1A	we are having an electrical problem in the teachers lounge. if the printer/copiermachine is on then the microwave cant be on it throws a breaker and yesturday principal nelson was using the copier and fire shot out of the socket.we believe its very hazardous	12/18/13	1st Floor	teachers lounge	Electrical
Peabody ES (2570) 1A	HEAT RM 306-NOT COMING ON- PLANT MGR HAYES 416-4606 KLR	1/6/14			Electrical
Peabody ES (2570) 1A	there are wires hanging over this stairway from the wall, coming from 1st floor up to the 2nd floor. children might try to touch them per principal nelson.	2/3/14	Stairway	northeast stairs	Electrical
Peabody ES (2570) 1A	the light ballast needs to be changed out in the main office restroom.	2/7/14	2nd Floor	main office	Electrical
Peabody ES (2570) 1A	needs a light ballast.	2/7/14	1st Floor	rm101	Electrical

Peabody ES (2570) 1A	the lights have been changed out but 4 fixtures still wont come on. the cafe manager says the health department will write that as a violation.it is believed to be the ballast	2/25/14		kitchen/serving line	Electrical
Peabody ES (2570) 1A	the master clock needs to be set for daylight savings time march 9,2014.	2/27/14		mainoffice	Electrical
Peabody ES (2570) 1A	HAS A COMPLETE POWER OUTAGE-PLANT MGR HAYES 416-8775 KLR	3/27/14			Electrical
Peabody ES (2570) 1A	A/C KITCHEN AREA-NOT COMING ON-PLANT MGR HAYES 416-4606 KLR	4/8/14			Electrical
Peabody ES (2570) 1A	the lights has been changed out in this pantry,there are only 2 lights in this pantry and they still wont come on. the cafe manager says its to dark in this pantry and she needs access to it.	4/16/14	Kitchen		Electrical
Peabody ES (2570) 1A	the master clock is 3 min. off and its causing a lot of confusion. per principal nelson.	4/17/14	2nd Floor	main office	Electrical
Peabody ES (2570) 1A	there is a light out on the westside of the 2nd floor hall right outside the boys restroom its over 10ft. Its pretty dark right there and its also by the steps.	4/25/14	2nd Floor	west hallway	Electrical
Peabody ES (2570) 1A	SCHOOL BELL NEEDS TO BE RESET. (PER: LESLIE NEEDS AN ELECTRICIAN) PLANT MGR- PATTERSON/416.4606	8/9/13			Electrical

Peabody ES (2570) 1A	Light bulb is broken off in socket	8/13/13	2nd Floor	main hall	Electrical
Peabody ES (2570) 1A	there is an outlet exposed and children are trying to stick there finger in.	8/21/13	3rd Floor	rm306	Electrical
Peabody ES (2570) 1A	it is too dark at that entrance early morning and evenings for the before care/after care to see people when they are trying to access entry. they report not feeling safe, they dont want to let the wrong person in.	1/14/14	Grounds	east cafe entrance	Electrical
Peabody ES (2570) 1A	the receptacles in this room is not working,cant get power.	1/16/14	2nd Floor	rm206	Electrical
Peabody ES (2570) 1A	there is an outlet where the lid is off . it is very dangerous for the children.	8/5/13	2nd Floor	rm306	Electrical
Peabody ES (2570) 1A	there is an outlet that doesnt have a cover and needs one it is dangerous for the kids.	8/5/13	3rd Floor	girls/r	Electrical
Peabody ES (2570) 1A	there is a spot light out on a city pole in front of the main entrance. the city light is facing the street and the spot light is on the back of the pole. however it is very dark at the front of the building which makes it a very,very dangerous situation.	5/14/14	Grounds	south main entrance	Electrical
Peabody ES (2570) 1A	HEAT CAFE & RM 100 INSIDE OF CAFE-BOTH NOT COMING ON-PLANT MGR HAYES 416-4606 KLR	1/7/14			Electrical

Peabody ES (2570) 1A	CHILLER-1 & CHILLER-2-BOTH NOT COOLING-ENTIRE BLDG HOT-PLANT MGR HAYES 416-8859 KLR	6/4/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	CLEAN CHILLER (PER BRIAN SHIPP)	6/30/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Oil Lube & Belt-Peabody Elementary - Refer to PM schedule details.	7/23/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	UNIT IN RM 306 MAKING A LOUD NOISE . SBE HAYES 416-8859	7/29/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	2-AHU NOT COOLING IN RM-303, RM-206 PLANT MGR-HAYES/416.4606	8/5/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	6-AHU NOT COOLING IN RM-206,204,304,310,311(NO ID) . SBE-HAYES/416-4606	7/15/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Filter-Peabody Elementary - Refer to PM schedule details.	9/24/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	AHU NOT HEATING IN RM-101. PLANT MGR-HAYES/416.8859	11/8/13			Heating/Ventilation /Air Conditioning

Peabody ES (2570) 1A	BOILER MECH RM-NOT COMING ON-PLANT MGR HAYES 416-4606 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Peabody Elm AirCompressor #046054 - Refer to PM schedule details.	2/21/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Oil Lube & Belt-Peabody Elementary - Refer to PM schedule details.	2/25/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	UNIT IS LEAKING WATER IN CAFE & RM-100 PLANT MGR-HAYES/416.4606	3/25/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	A/C RM 316-HAS AN ODOR COMING FROM IT-PLANT MGR HAYES 416-4606 KLR	4/8/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	A/C RM 314-NOT COOLING-PLANT MGR HAYES 416-4606 KLR	4/23/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	A/C RM 205-NOT COOLING-PLANT MGR HAYES 416-8859 KLR	4/25/14			Heating/Ventilation /Air Conditioning

Peabody ES (2570) 1A	No A/C in room 306 per principal Mrs. Nelson	8/6/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Room 307 too cold per Patterson 416-4606	8/13/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Peabody Elm AirCompressor #046054 - Refer to PM schedule details.	8/23/13			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	per Mr. Hayes 416-8858 the library is blowing cold	1/7/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Replace busted coils	1/14/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Filter-Peabody Elementary - Refer to PM schedule details.	1/28/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	Monthly - Filter-Peabody Elementary - Refer to PM schedule details.	5/27/14			Heating/Ventilation /Air Conditioning
Peabody ES (2570) 1A	the first floor hallway needs to be painted per principal nelson.	7/22/13	1st Floor	hallway	Painting

Peabody ES (2570) 1A	the second floor hallway need to be painted per principal nelson	7/22/13	2nd Floor	hallway	Painting
Peabody ES (2570) 1A	the 3rd floor hallway needs to be painted per principal nelson.	7/22/13	3rd Floor	hallway	Painting
Peabody ES (2570) 1A	the hallways need to be painted/ touched up.	6/9/14	Hallway/Corridor		Painting
Peabody ES (2570) 1A	these rooms need to be painted, per principal nelson	6/13/14	1st Floor	rms103,109,111,120	Painting
Peabody ES (2570) 1A	these rooms need to be painted,per principal nelson	6/13/14	2nd Floor	rms.203,205,209	Painting
Peabody ES (2570) 1A	this room needs the walls to be touched up.	6/13/14	3rd Floor	rm,318	Painting
Peabody ES (2570) 1A	the plaster has come off the wall in this room and there are holes in the wall. principal nelson is requesting this be fixed a.s.a.p. because children might pick at it and try to eat it, a hazard.	6/23/14	1st Floor	rm120	Painting
Peabody ES (2570) 1A	Graffiti is on the outdoor on the entrance area of the CAFETERIA per Mr. Hayes, Plant Mgr. 416.8858	10/11/13			Painting

Peabody ES (2570) 1A	touchup hallway on 2nd floor	11/12/13			Painting
Peabody ES (2570) 1A	paint classroom walls rm. 111	8/12/13			Painting
Peabody ES (2570) 1A	paint walls in rm.111	8/12/13			Painting
Peabody ES (2570) 1A	we cant cut the water hydrant on and we need to water the vegetation.	5/19/14	Grounds	inside fenced area around back	Plumbing
Peabody ES (2570) 1A	Clean area drains	5/20/14			Plumbing
Peabody ES (2570) 1A	we need the plumbing disconnected from the diswashing machine in preparations to being removed. there is a sewer smell that comes from this machine so if anything needs to be sealed off or closed off we would ask that to be done as well as that smell can leave the	6/19/14	Kitchen		Plumbing
Peabody ES (2570) 1A	UNIT IN RM 316 IS LEAKING. SBE HAYES 416-8859	7/29/13			Plumbing
Peabody ES (2570) 1A	AHU IS LEAKING WATER IN RM-316 PLANT MGR-HAYES/412.4606	7/31/13			Plumbing

Peabody ES (2570) 1A	AHU IS LEAKING WATER IN CAFE. PLANT MGR-HAYES/416.4606	8/1/13			Plumbing
Peabody ES (2570) 1A	1 commode wont flush.	7/15/13	1st Floor	boysr/r	Plumbing
Peabody ES (2570) 1A	3 toilets wont flush. 1 sink wont come.	7/15/13	1st Floor	girls r/r	Plumbing
Peabody ES (2570) 1A	1 sink wont cut off.	7/15/13	2nd Floor	girls r/r	Plumbing
Peabody ES (2570) 1A	1sink no knob	7/15/13	2nd Floor	boysr/r	Plumbing
Peabody ES (2570) 1A	1 urinal thats running water,it wont stop.	7/15/13	2nd Floor	boys r/r	Plumbing
Peabody ES (2570) 1A	sink dripping water.	7/15/13	3rd Floor	boysr/r	Plumbing
Peabody ES (2570) 1A	1 urinal thats running	7/15/13	3rd Floor	boysr/r	Plumbing

Peabody ES (2570) 1A	there are 2 sinks that are leaking very bad and 1 water fountain is leaking as well.	7/15/13	1st Floor	hallway	Plumbing
Peabody ES (2570) 1A	the bathroom sink wont cut off completely.	7/16/13	1st Floor	teachers lounge	Plumbing
Peabody ES (2570) 1A	AHU IS LEAKING WATER IN RM-209(NO ID). SBE-HAYES/416-4606	7/16/13			Plumbing
Peabody ES (2570) 1A	UNIT IN RM 311 IS LEAKING. SBE HAYES 416-8859	7/16/13			Plumbing
Peabody ES (2570) 1A	the toilet in the 2nd r/r the commode doesnt flush correctly or all the way.	7/17/13	1st Floor	teachers lounge	Plumbing
Peabody ES (2570) 1A	the toilet in the lounge is leaking very bad.	7/18/13	1st Floor	teachers lounge	Plumbing
Peabody ES (2570) 1A	Restrooms, floor drains, mop drain in kitchen/cafeteria are backing up per Andre Hayes 416-8859	8/27/13			Plumbing
Peabody ES (2570) 1A	Unstop main sewer on East side of school	8/30/13			Plumbing

Peabody ES (2570) 1A	The faucet handles will not turn the water off.	9/3/13	Restroom (Girls)	Teacher Lounge 1st floor	Plumbing
Peabody ES (2570) 1A	AHU RM 304-LEAKING-PLANT MGR SANDERS 416-4606 KLR	9/4/13			Plumbing
Peabody ES (2570) 1A	The commode in the 3rd stall is stopped up.	9/5/13	Restroom (Boys)	3rd floor west	Plumbing
Peabody ES (2570) 1A	the hot water faucet wont come on and the cold water is very hard to turn off.	9/11/13	1st Floor	teachers lounge/r	Plumbing
Peabody ES (2570) 1A	9-TOILETS ARE BACKING IN B/RR 1ST FLR. PLANT MGR-HAYES/416.4606	9/18/13			Plumbing
Peabody ES (2570) 1A	Repair cleanouts on Sewer Lines	9/26/13			Plumbing
Peabody ES (2570) 1A	Flush sewer	10/14/13			Plumbing
Peabody ES (2570) 1A	AHU IS LEAKING WATER IN CAFE . PLANT MGR-HAYES/416.4606	10/22/13			Plumbing

Peabody ES (2570) 1A	A/C LIBRARY-LEAKING-PLANT MGR HAYES 416-4606 KLR	11/5/13			Plumbing
Peabody ES (2570) 1A	there is a toilet that keeps running over.	11/6/13	1st Floor	girls/r	Plumbing
Peabody ES (2570) 1A	A/C-HEAT UNIT RM 304-LEAKING-PLANT MGR HAYES 416-4606 KLR	11/6/13			Plumbing
Peabody ES (2570) 1A	STRONG SEWER SMELL COMING OUT OF 3RD FLR G RR-PLANT MGR HAYES 416-4606 KLR	11/14/13			Plumbing
Peabody ES (2570) 1A	Preform back flow test.	12/23/13			Plumbing
Peabody ES (2570) 1A	there is a pipe leaking very bad under the water fountain.	2/5/14	3rd Floor	hallway	Plumbing
Peabody ES (2570) 1A	there is a leak running down the wall as well from the bottom of the wall and from the floor in the cafetorium.	2/5/14	Cafetorium		Plumbing
Peabody ES (2570) 1A	there is a urinal that keeps flooding.	2/5/14	1st Floor	boys r/r	Plumbing

Peabody ES (2570) 1A	there is a toilet that water is pouring out from the bottom onto the floor.	2/5/14	1st Floor	girls r/r	Plumbing
Peabody ES (2570) 1A	there is a commode the will not flush.	2/5/14	2nd Floor	boys r/r	Plumbing
Peabody ES (2570) 1A	HEATING UNIT KITCHEN SERVING LINE-LEAKING-PLANT MGR HAYES 416-4606 KLR	2/5/14			Plumbing
Peabody ES (2570) 1A	NO HOT WATER TO KITCHEN AREA-PLANT MGR HAYES 416-4606 KLR	2/20/14			Plumbing
Peabody ES (2570) 1A	Repair leak in the wall.	3/11/14	3rd Floor		Plumbing
Peabody ES (2570) 1A	there is water coming in through a light fixture.	3/24/14	Cafetorium	1st floor	Plumbing
Peabody ES (2570) 1A	UNIT IS LEAKING WATER IN CAFE. PLANT MGR-HAYES/378.2478	3/27/14			Plumbing
Peabody ES (2570) 1A	WATER FOUNTAIN CAFE AREA-LEAKING FROM BOTTOM-CAN'T CUT OFF OR CONTAIN-PLANT MGR HAYES 416-4606 KLR	3/28/14			Plumbing

Peabody ES (2570) 1A	SINK IS HANGING & WATER IS RUNNING IN G/RR 1ST FLR. PLANT MGR-HAYES/416.4606	3/28/14			Plumbing
Peabody ES (2570) 1A	the handicapped stall in this r/r is not working and we have 2 students in wheel chairs that must use this stall because of their handicap. we need this stall work asap. per principal johnson.	4/11/14	3rd Floor	boysr/r	Plumbing
Peabody ES (2570) 1A	A/C RM 311-LEAKING-PLANT MGR HAYES 416-4606 KLR	4/28/14			Plumbing
Peabody ES (2570) 1A	Sink constantly running	8/6/13	3rd Floor	Center of wall in hallway	Plumbing
Peabody ES (2570) 1A	Toilet will not flush	8/7/13	2nd Floor	Boys restroom	Plumbing
Peabody ES (2570) 1A	Room 316 AHU leaking per Patterson 416-4606	8/7/13			Plumbing
Peabody ES (2570) 1A	Toilet not flushing (last stall)	8/8/13	2nd Floor	Boys restroom	Plumbing
Peabody ES (2570) 1A	there is a water fountain leaking in the cafeteria. it poses a slipping hazard.	8/15/13	Cafeteria	1st fl.	Plumbing

Peabody ES (2570) 1A	FLOOR DRAIN KITCHEN- BACKING UP-PLANT MGR HAYES 416-8859 KLR	8/21/13				Plumbing
Peabody ES (2570) 1A	AHU'S CAFE, RMS 204, 311, & 304- ALL ARE LEAKING PER SBE- PLANT MGR HAYES 416-8859 KLR	8/21/13				Plumbing
Peabody ES (2570) 1A	there is a urinal that wont flush	1/7/14	1st Floor	boys/r		Plumbing
Peabody ES (2570) 1A	there is a urinal in the boys r/r that doesnt flush properly	1/7/14	2nd Floor	boys/r		Plumbing
Peabody ES (2570) 1A	there is a urinal that wont flush.	1/7/14	3rd Floor	boys r/r		Plumbing
Peabody ES (2570) 1A	there are 2 commodes thats stopped up and wont flush properly.	1/7/14	1st Floor	girls/r		Plumbing
Peabody ES (2570) 1A	the faucet is getting stuck/hard to turn on.	5/9/14	Grounds	north near chiller/in fence		Plumbing
Peabody ES (2570) 1A	AHU IN RM316 IS LEAKING., SBE HAYES 416-8859	8/5/13				Plumbing

Peabody ES (2570) 1A	we need a new water faucet with a key right outside of the cafeteria nearest the garden because the vegetation dies if we cant get water to it.	5/9/14	Grounds	north/east campus	Plumbing
Peabody ES (2570) 1A	per mr hayes 416-8859 roof in kitchen on serving line is leaking	3/6/14			Roof
Peabody ES (2570) 1A	HEAT SERVING LINE AREA-LEAKING-PLANT MGR HAYES 416-4606 KLR	3/28/14			Roof
Peabody ES (2570) 1A	ROOF STILL LEAKING IN SERVING LINE AREA-PLANT MGR HAYES 416-4606 KLR	4/9/14			Roof
Peabody ES (2570) 1A	Request pan be made for the unit in the cafe. over the serving line.	4/29/14			Sheet Metal

Count of Craft	Craft								Grand Total
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	
I-Egypt Sr (2598)	4	6	29	71	34	4	44	8	200
Grand Total	4	6	29	71	34	4	44	8	200

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Ral-Egypt Sr (2598) 1B	Need wooden blocks put up to install pencil sharpeners in various classrooms. Rooms are 117, 123, 126, 127, 128 and 200.	9/11/13	Classroom	Various classrooms	Asbestos
Ral-Egypt Sr (2598) 1B	Principal requesting that Basement be inspected /tested for abestos because we found the area flooded on yesterday.	1/16/14	Annex	Basement	Asbestos
Ral-Egypt Sr (2598) 1B	Pipe leading from hot water heater to ceiling need insulation replaced.	2/13/14	Cafeteria	Laundry room	Asbestos
Ral-Egypt Sr (2598) 1B	Refinish wooden court area and wooden stage area.	11/21/13	Gym	Wooden court area and wooden stage area	Asbestos
Ral-Egypt Sr (2598) 1B	Ral-Egypt- Sr. --WO-374568-- No internet connection for cable box OFF3 by printer(Request Network Cabling Maintenance Repair). (SCS Network Cabling and Electronics dept.--Response -- "Please See Journal Note")	8/14/13	Administration Area	Main Office	Cabling
Ral-Egypt Sr (2598) 1B	Drop number 6 is not working in classroom. Need repairs(Request Network Cabling Maintenance Repair).	8/14/13	Classroom	Room 124	Cabling
Ral-Egypt Sr (2598) 1B	Drops in cable boxes are not working. Need repairs in Room 113 (Request Network Cabling Maintenance Repair).	8/19/13	Classroom	Room 113	Cabling
Ral-Egypt Sr (2598) 1B	Drops number 3 and 4 are not active in classroom and in the internet closet per computer tech	10/30/13	Classroom	Room 124	Cabling
Ral-Egypt Sr (2598) 1B	SCS FP-3500 Network Cabling Project- Provide project management for Access DNSI to install network cabling installations and any associated electrical wiring. (Request Network Cabling Project Management).	7/26/13			Cabling

Ral-Egypt Sr (2598) 1B	Two boxes for internet drops need to be repaired for classroom use per computer tech. Teacher has 10 computers and 2 printers not connected to internet.(Request Network Cabling Maintenance Repair).	8/7/13	Classroom	Room 124	Cabling
Ral-Egypt Sr (2598) 1B	Need 6 boxes of soft ceiling tiles for replacement tiles. 4x8 ?	8/21/13	Administration Area	Entire building	Carpentry
Ral-Egypt Sr (2598) 1B	Exit door to ledge will not lock. Hazard if used.	8/21/13	Classroom	Room 229	Carpentry
Ral-Egypt Sr (2598) 1B	Install hasps on 2 metal teacher cabinets and on a metal 4drawer file cabinet	8/21/13	Classroom	Room 202	Carpentry
Ral-Egypt Sr (2598) 1B	Metal plates on outside of window have been taken off and need to be reinstalled. Had break-in in classroom twice. Plant Manager has metal plates which were removed in office.	9/3/13	Classroom	Window to outside-Room 103	Carpentry
Ral-Egypt Sr (2598) 1B	window broken out room 201 (vandalism) per Ms. Byers 416-9661	9/10/13			Carpentry
Ral-Egypt Sr (2598) 1B	Need a welder to weld the bottom hook back on for flag pole line.	10/29/13	Grounds	Flag pole in front of school	Carpentry
Ral-Egypt Sr (2598) 1B	Having breakins on 2nd floor and need to secure room windows and window screens. Rooms are 202, 204, 205, 207, 208, 209, 212, 213, 214, and 215.	9/11/13	Classroom	Various classrooms	Carpentry
Ral-Egypt Sr (2598) 1B	Please repair holes in walls on 2nd floor hallway.	6/2/14	Hallway/Corridor	2nd floor	Carpentry
Ral-Egypt Sr (2598) 1B	Please repair main entrance door. Does not latch.	6/10/14		main office	Carpentry

Ral-Egypt Sr (2598) 1B	ENTRANCE DOOR TO ROTC BLDG- NOT LOCKING, WON'T BE ABLE TO SECURE & CAFE ENTRANCE CTR MULL DAMAGED, WON'T BE ABLE TO SECURE-PLANT MGR BYERS 416-9661 KLR	10/29/13			Carpentry
Ral-Egypt Sr (2598) 1B	Teacher needs a 4x8 white board over the cork board board in classroom .	9/13/13	Classroom	Room 125	Carpentry
Ral-Egypt Sr (2598) 1B	Need door knob replaced with new one according to locksmith Darryl. Old knob is out dated and broken.	2/21/14	Administration Area	AP office-Room 225	Carpentry
Ral-Egypt Sr (2598) 1B	Front door closes too quickly on people. Need adjustment.	4/2/14	1st Floor	By Main Office	Carpentry
Ral-Egypt Sr (2598) 1B	Door closure at stairwell is broken and need repairs	4/2/14	1st Floor	Stairwell next to Parent Center	Carpentry
Ral-Egypt Sr (2598) 1B	Window in classroom fell out when to wind hit it on yesterday.	4/16/14	Classroom	Room 227	Carpentry
Ral-Egypt Sr (2598) 1B	Cylinder lock came out of door and is in Plant Manager's office	4/21/14	Cafeteria	Entrance door	Carpentry
Ral-Egypt Sr (2598) 1B	Please repair main entrance card access door. Does not latch when closed.	4/21/14			Carpentry
Ral-Egypt Sr (2598) 1B	Need floor retiled because of flood. All tile is coming up.	1/16/14	Hallway/Corridor	Basement by Bandroom	Carpentry
Ral-Egypt Sr (2598) 1B	Need 4x8 white board to replace a bullentine/chalk board.	1/29/14	Classroom	Room 124	Carpentry

Ral-Egypt Sr (2598) 1B	View glass in door is loose. Will need a frame and the glass is not broken.	2/10/14	2nd Floor	Room 213	Carpentry
Ral-Egypt Sr (2598) 1B	Per Ms. Byers 416-9661 in the cafeteria, exterior door center mullion only has 1 screw in it and needs securing	11/26/13			Carpentry
Ral-Egypt Sr (2598) 1B	Window out in boys basketball locker room per ms byers 416-9661	11/27/13			Carpentry
Ral-Egypt Sr (2598) 1B	Door knob is broken and needs to be replaced.	12/4/13	Classroom	Room 126	Carpentry
Ral-Egypt Sr (2598) 1B	latch stuck on door bar. the door will not close o lock,	1/16/14	Auxiliary Gym	front door	Carpentry
Ral-Egypt Sr (2598) 1B	Door knob is falling off and a hazard for students being locked in class.	11/6/13	Classroom	Room 126	Carpentry
Ral-Egypt Sr (2598) 1B	Need a hole repaired in wall behind door and also need a doorstop put on wall to prevent another hole.	9/26/13	Administration Area	Attendance Office	Carpentry
Ral-Egypt Sr (2598) 1B	WINDOW BRACKETS ARE OFF, CANT SECURE IN RM-115. SBE-GREGORY/416-4108	7/1/13			Carpentry
Ral-Egypt Sr (2598) 1B	Repair drywall, holes in cafe. foyer and in cafe.	7/8/13			Carpentry
Ral-Egypt Sr (2598) 1B	Screens on windows to outside are bent and screens do not close.	8/7/13	Classroom	Rooms 203 and 205	Carpentry

Ral-Egypt Sr (2598) 1B	Broken light hanging down in gym	8/15/13	Gym	Court area	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Need repairs	8/19/13	Administration Area	Room 113 1/2	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Need repairs	8/19/13	Classroom	Room 113	Electrical
Ral-Egypt Sr (2598) 1B	Need 6 boxes of 46807 lamps for light fixtures.	8/21/13	Administration Area	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Teacher states that kight is driving students crazy.	8/21/13	Classroom	Room 201	Electrical
Ral-Egypt Sr (2598) 1B	Outside light fixtures not working. Need repairs.	8/21/13	Gym	Back side and front side	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in these 3 areas. Need repairs	8/21/13	Gym	Football locker room Laundry room and Weight room	Electrical
Ral-Egypt Sr (2598) 1B	Broken exit sign which needs to be replaced.	8/21/13	Gym	Football locker room	Electrical
Ral-Egypt Sr (2598) 1B	Lights on court area of gym need replacement.	8/21/13	Gym	Court area	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture on stage	8/21/13	Gym	Stage area	Electrical

Ral-Egypt Sr (2598) 1B	Broken emergency light in gym	8/21/13	Gym	Lobby area of gym by girls restroom	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Need replacement	8/21/13	Hallway/Corridor	By room 213	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture.	8/21/13	Administration Area	Plant Manager Office	Electrical
Ral-Egypt Sr (2598) 1B	Security lights are out in these 3 areas. Need replacement. Need bucket truck	8/21/13	Grounds	Behind ROTC, behind gym by dumpsters, in front of	Electrical
Ral-Egypt Sr (2598) 1B	There is no power to scoreboard clock. Have a volleyball game today. This is urgent.	8/26/13	Gym	Power to scoreboard clock	Electrical
Ral-Egypt Sr (2598) 1B	Need three boxes of lamps for 4x8 light fixtures-46807.	8/26/13	Administration Area	Entire school	Electrical
Ral-Egypt Sr (2598) 1B	Check all outside parking lot lights-upper and lower lots.	8/27/13	Grounds	Check parking lot lights	Electrical
Ral-Egypt Sr (2598) 1B	Possible power outage, school reported a loud boom.	9/4/13			Electrical
Ral-Egypt Sr (2598) 1B	RTU NOT COMING ON IN GYM. PLANT MGR-BYERS/416.4108	9/4/13			Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture by Rooms 204 and 215	9/11/13	2nd Floor	Hallway	Electrical

Ral-Egypt Sr (2598) 1B	Exit sign in front of Cafeteria is broken and hanging down.	9/11/13	Hallway/Corridor	In front of Cafeteria	Electrical
Ral-Egypt Sr (2598) 1B	Light out in ceiling of gym. Need replacement.	11/20/13	Gym	Court area	Electrical
Ral-Egypt Sr (2598) 1B	Please replace ballast in light fixture on 1st floor hallway between lockers 1411 and 1461.	6/10/14	Hallway/Corridor		Electrical
Ral-Egypt Sr (2598) 1B	5 Light fixtures have bad ballast. Need replacements.	9/13/13	Library	Main seating area	Electrical
Ral-Egypt Sr (2598) 1B	Need meta lcover over exposed wires.	9/13/13	Hallway/Corridor	Wall outside Room 215	Electrical
Ral-Egypt Sr (2598) 1B	Need 5 boxes of 46677? lamps for ceiling light fixtures.	4/2/14	Hallway/Corridor	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Need bulb replacement in outside light fixture between Cafe and the Gym	4/2/14	Grounds	Outside between Cafe and Gym	Electrical
Ral-Egypt Sr (2598) 1B	UNIT ARE MAKING NOISE IN RM- 225,129 PLANT MGR-BYERS/416.4108	4/2/14			Electrical
Ral-Egypt Sr (2598) 1B	Please deliver 5 cases of fluorescent (32T8) light bulbs.	4/16/14		building engineer office	Electrical
Ral-Egypt Sr (2598) 1B	Please replace 1 light ballast in hallway by room 108.	4/29/14	Hallway/Corridor		Electrical

Ral-Egypt Sr (2598) 1B	Unit Ventilator not working.	5/7/14	Classroom	Rm 227	Electrical
Ral-Egypt Sr (2598) 1B	Please deliver 5 cases of fluorescent light bulbs (3218). Catalog #10221.	5/29/14		main office	Electrical
Ral-Egypt Sr (2598) 1B	Please replace 4 bulbs in gym.	6/2/14	Gym		Electrical
Ral-Egypt Sr (2598) 1B	Please disconnect power to welder and grinder to be removed from old auto shop that has been converted to weight and fitness room.	6/2/14		auto shop	Electrical
Ral-Egypt Sr (2598) 1B	Need 8 light fixture 100 watt bulbs changed out which are higher than 8 ft. Plant Manager has bulbs.	1/16/14	Gym	Girls locker room shower	Electrical
Ral-Egypt Sr (2598) 1B	1. Need 4 boxes of 46758 lamps for light fixtures in ceiling 2. Need 24 boxes of DULUX D 26watt for light fixtures.	1/16/14	Hallway/Corridor	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	per ms byers total power outage See wo's 414208 & 414209 that time is logged under this wo 414206.jd	2/4/14			Electrical
Ral-Egypt Sr (2598) 1B	5-RTU NOT COMING ON IN CAFE, CEILING UNITS RM-126 THRU 129, & RM-222 THRU 229 PLANT MGR-BYERS/416.4108	2/5/14			Electrical
Ral-Egypt Sr (2598) 1B	Emergency lights not working during power outage on yesterday in Main office by Principal's Office and also Guidance area.	2/5/14	Administration Area	Main Office and Guidance	Electrical
Ral-Egypt Sr (2598) 1B	Emergency lights did not come on with power outage on yesterday	2/5/14	Hallway/Corridor	By room 116 and room 126	Electrical

Ral-Egypt Sr (2598) 1B	Emergency light not working on 2nd floor hallway by Room 100	2/5/14	2nd Floor	By Room 101	Electrical
Ral-Egypt Sr (2598) 1B	AHU#1 IS MAKING NOISE IN MAIN HALL PLANT MGR-BYERS/416.4108	2/6/14			Electrical
Ral-Egypt Sr (2598) 1B	NO POWER TO LIGHTS IN RM-104, ALL RECEPTACLES HAVE NO POWER RM-220,222,224 PLANT MGR-BYERS/489.6112	2/10/14			Electrical
Ral-Egypt Sr (2598) 1B	No lights in ceiling. It is very dark in the closet. Ceiling is higher than 8 feet.	2/10/14	Custodial Closet	9TH Grade Academy	Electrical
Ral-Egypt Sr (2598) 1B	Air compressor that controls ANNEX building all three floors is not blowing and the building is cold also the vocational building is cold because the AHU is not running per Pat Byers 416-9661	11/26/13			Electrical
Ral-Egypt Sr (2598) 1B	vocational building rooms 130 thru 134 heat not coming on at all per Ms Byers 416-9661	12/2/13			Electrical
Ral-Egypt Sr (2598) 1B	Two light fixtures have bad ballast. One over teacher's desk and the other in the isle.	1/7/14	Classroom	Room 102	Electrical
Ral-Egypt Sr (2598) 1B	AHU#1 not running.	1/7/14			Electrical
Ral-Egypt Sr (2598) 1B	Need 3 lights replaced because it is dark at night. Higher than 8ft. Will NOT need a lift.	1/16/14	Grounds	Under canopy from Annex to Gym	Electrical
Ral-Egypt Sr (2598) 1B	2 light fixtures with bad ballast. one is in front of Parent Center and the other is across from Principal's Conference room.	11/1/13	1st Floor	Hallway	Electrical

Ral-Egypt Sr (2598) 1B	Set clock back for day light saving time	11/1/13	Administration Area	Main Office	Electrical
Ral-Egypt Sr (2598) 1B	HEAT VOC BLDG-NOT HEATING-PLANT MGR BYERS 416-9661 KLR	11/13/13			Electrical
Ral-Egypt Sr (2598) 1B	Two bad ballasts in Assistant Principal's Office-Room 116. Need replacement	11/13/13	Administration Area	Assistant Principal's Office-Room 116	Electrical
Ral-Egypt Sr (2598) 1B	2 bad ballast in light fixtures and lamps need replacing which are higher than 8 ft.	11/20/13	Gym	Concession Stand	Electrical
Ral-Egypt Sr (2598) 1B	Need 3 boxes of lamps for replacement in ceiling of school.	9/16/13	Administration Area	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Repair or replace B&G pump motor on domestic hot water pump.	9/18/13	Gym		Electrical
Ral-Egypt Sr (2598) 1B	Circuit breaker 18 which controls gym concession and some other areas need to be replaced according to Coaches. Sparks when on and you must giggle.	9/25/13	Gym	Breaker box	Electrical
Ral-Egypt Sr (2598) 1B	Outside security lights not working: 1. Front side side of gym 2. Back side of main building in front of gym parking area 3. south side of Auto Shop 4. West side corner of main building outside of cooling towers 5. Lower parking lot by street with fence	10/3/13	Grounds	Outside security lights	Electrical
Ral-Egypt Sr (2598) 1B	Need ballast in hallway. Dark in hall	10/3/13	2nd Floor	Hallway by Rm 204, 209 and 219	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in hallway by Room 213 instead of 219. Please correct.	10/3/13	2nd Floor	By Room 213	Electrical

Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture front lobby by boys restroom	10/4/13	Gym	Front lobby by boys restroom	Electrical
Ral-Egypt Sr (2598) 1B	Emergency lights not working in 3 areas. 1. Front lobby of gym by boys restroom. 2. By girls restroom 3. East side exit doors by bleachers	10/4/13	Gym	Emergency lights in gym	Electrical
Ral-Egypt Sr (2598) 1B	need 3 boxes of lamps for classroom areas projects(12 rooms to complete)	10/7/13			Electrical
Ral-Egypt Sr (2598) 1B	Flag line is stuck and flag is at half mast per Ms. Pat Byers, Plant Mgr. 416.9661	10/14/13			Electrical
Ral-Egypt Sr (2598) 1B	Need 3 boxes of lamps for replacement light fixtures.	10/16/13	Administration Area	Plant Manager's office	Electrical
Ral-Egypt Sr (2598) 1B	AIR COMPRESSOR 241-235 IN BASEMENT IS NOT WORKING PROPERLY - CONTROLS THE BASEMENT 2ND FLR & 3RD FLR - RMS ON THE 3RD FLR IS CONDENSATING - PM/BUYERS 416-9661	8/1/13			Electrical
Ral-Egypt Sr (2598) 1B	Need 5 boxes of I46807 lamps for ceiling fixtures and 5 boxes of ceiling tiles for replacement tile.	8/2/13	Administration Area	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Air Handler unit #1, when she turned the unit shot out through motor per Mr. Pat Byers, Plant Mgr. 901.416.9661.	8/6/13			Electrical
Ral-Egypt Sr (2598) 1B	Four lights on front porch are not lighting up. Need replacements.	8/7/13	Administration Area	Outside front proch	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture in hallway. Need replacement	8/9/13	Hallway/Corridor	By Room 213	Electrical

Ral-Egypt Sr (2598) 1B	Need replacement exit signs in Library and in Room 215.	8/9/13	2nd Floor	Library and Room 215	Electrical
Ral-Egypt Sr (2598) 1B	Monthly - Oil Lube & Belt-Raleigh Egypt High - Refer to PM schedule details.	8/16/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	uv not cooling in rooms, 116, 117, 118, 120, 126, 128, 129 per pat byers 416-9661	9/4/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	RTU NOT COoling IN GYM. PLANT MGR-BYERS/416.4108	9/4/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Yearly - Oil Samples-Raleigh-Egypt High - Refer to PM schedule details.	9/16/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Filter-Raleigh Egypt High - Refer to PM schedule details.	2/21/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Filter-Raleigh Egypt High - Refer to PM schedule details.	10/25/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Yearly - Cooling Towers(STRAINERS)-Ral Egypt High - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex 1st Fir Mech-Ral Egypt Hi - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-2nd Fir Auto Shop-Ral Egypt Hi - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning

Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex by BandRm- Ral Egypt Hi - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Filter-Raleigh Egypt High - Refer to PM schedule details.	6/27/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Oil Lube & Belt-Raleigh Egypt High - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Rooms 15 and 16 in basement not cooling per Pat Byers 416-9661	9/11/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	check boiler per sbe	2/27/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	REPAIR AHU SHAFT AND BEARINGS	3/27/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHILLER MECH RM-IN ALARM-PLANT MGR BYERS 416-9661 KLR	4/14/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHILLER IS IN ALARM - PM/BUYERS 416-9661	4/21/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	a/c not working in main office.	5/12/14	Administration Area	main office	Heating/Ventilation /Air Conditioning

Ral-Egypt Sr (2598) 1B	a/c not working in kitchen.	5/13/14	Kitchen		Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	per ms davis 416-9677 the boiler is not coming on building is cold	2/3/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	RTU's Cafe running not heating.jd	2/5/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Repair boilers	12/10/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Boiler reading message has: NO FLAME per George Dean, Zone Supervisor at 901.606.2780.	12/13/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	HEAT RMS 126, 127, 128, 129, 216, 217, 220, 221, 222, 227, 228, & 229- ALL NOT HEATING-PLANT MGR BYERS 416-9661 KLR	1/14/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHILLER IS IN ALARM. PLANT MGR-BYERS/489.6112	10/31/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	no heat in room 132 vocational bldg per ms. byers 416-9661	11/12/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex 1st Flr Mech- Ral Egypt Hi - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-2nd Flr Auto Shop- Ral Egypt Hi - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning

Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex by BandRm- Ral Egypt Hi - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Chiller NOT COMING ON! Per Mr. Campbell at 901.826.7298.	7/8/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	chiller down per EMS 7.8.13	7/8/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Annex Building Rooms 118, 224, 225 not cooling per Pat Byers 416-4108	7/25/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	GAS PKG UNIT VOC LOW ROOF WEST CTR SERVES RM 132-NOT COOLING-SBE BYERS 416-9661 KLR	8/12/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	GRAFFITI IN B/RR-G/RR 1ST & 2ND FLRS. PLANT MGR-BYERS/416.4108	2/14/14			Painting
Ral-Egypt Sr (2598) 1B	paint new doors	9/26/13			Painting
Ral-Egypt Sr (2598) 1B	paint wall in hallway by bandroom	9/30/13			Painting
Ral-Egypt Sr (2598) 1B	Finish and paint drywall in cafe. and foyer.	7/8/13			Painting
Ral-Egypt Sr (2598) 1B	1st comode is not flushing. Need repairs	8/21/13	Restroom (Boys)	9th Grade Academy	Plumbing

Ral-Egypt Sr (2598) 1B	Urinal flush valve sticks and water continues to run. Need repairs	8/21/13	Restroom (Boys)	By Attendance Office	Plumbing
Ral-Egypt Sr (2598) 1B	3rd commode water is overflowing when flushed and 4th commode has no water pressure.	8/21/13	Restroom (Girls)	Restroom in Annex hallway	Plumbing
Ral-Egypt Sr (2598) 1B	Repair/replace drain on drinkr fountain.	8/21/13	Annex	3rd Flr.	Plumbing
Ral-Egypt Sr (2598) 1B	Water leak from pipe in front entrance of gym by boys restroom	8/21/13	Gym	Lobby of gym by boys restroom	Plumbing
Ral-Egypt Sr (2598) 1B	Water faucets running and will not cut off.	8/21/13	Restroom (Boys)	By Room 207	Plumbing
Ral-Egypt Sr (2598) 1B	TOILET CONTINUES TO RUN, CANT SHUT OFF IN B/RR 1ST FLR. PLANT MGR-BYERS/416.4108	9/5/13			Plumbing
Ral-Egypt Sr (2598) 1B	1st floor (ANNEX) Girls' RR, 1st stahl will NOT flush per Pat Byers, Plant Mgr 416.9661.	9/10/13			Plumbing
Ral-Egypt Sr (2598) 1B	Sink in Main Office stopped up with coffee grinds.	9/11/13	Administration Area	Main Office	Plumbing
Ral-Egypt Sr (2598) 1B	hot water tank is leaking water.	3/7/14	Cafeteria		Plumbing
Ral-Egypt Sr (2598) 1B	Pipe under sink in prep area is leaking in mop room.	10/29/13	Cafeteria	Mop room	Plumbing

Ral-Egypt Sr (2598) 1B	per ms byers 416-9661 no hot water in building	3/19/14			Plumbing
Ral-Egypt Sr (2598) 1B	Metal plate over floor drain is loose and has no screws.	9/13/13	Restroom (Boys)	1st floor by Conference Room	Plumbing
Ral-Egypt Sr (2598) 1B	3-SINKS ARE STOPPED UP ON 2ND FLR BY LIBRARY. PLANT MGR-BYERS/489.6112	2/26/14			Plumbing
Ral-Egypt Sr (2598) 1B	Pipe underneath the last handwashing sink is loose and leaking.	2/14/14	Restroom (Boys)	2nd floor by Rm 209	Plumbing
Ral-Egypt Sr (2598) 1B	Pipe underneath 1st handwashing sink is loose and leaking.	2/14/14	Restroom (Girls)	2nd floor by Rm 214	Plumbing
Ral-Egypt Sr (2598) 1B	Unstop roof drains, meet James King at 12:30 Wed.	2/19/14			Plumbing
Ral-Egypt Sr (2598) 1B	3-SINKS ARE STOPPED UP IN G/RR 2ND FLR BY LIBRARY. PLANT MGR-BYERS/416.4108	2/19/14			Plumbing
Ral-Egypt Sr (2598) 1B	Repair valves and/or other components to the make up water for the cooling towers.	4/2/14			Plumbing
Ral-Egypt Sr (2598) 1B	NO HOT WATER THRU BLDG PLANT MGR-BYERS/416.4108	4/17/14			Plumbing
Ral-Egypt Sr (2598) 1B	Please repair 2nd toilet in girls restroom next to room 207.	4/22/14	Restroom (Girls)		Plumbing

Ral-Egypt Sr (2598) 1B	Please repair 1st toilet in boys restroom.(across from conference room) Over flows into hallway when flushed and cut off not working.	5/14/14	Restroom (Boys)	1st floor	Plumbing
Ral-Egypt Sr (2598) 1B	Mop sink in custodial closet in 9th Grade Academy is stopped up and plunging does not help.	1/30/14	Custodial Closet	9th Grade Academy	Plumbing
Ral-Egypt Sr (2598) 1B	per ms byers 416-9661 there is no hot water in the entire building	2/13/14			Plumbing
Ral-Egypt Sr (2598) 1B	Water constantly running in commode. Need repairs	11/26/13	Gym	girls restroom in lobby	Plumbing
Ral-Egypt Sr (2598) 1B	Hand washing sink is stopped up.	11/26/13	Gym	Football locker room	Plumbing
Ral-Egypt Sr (2598) 1B	BURST PIPE in CLOSET BEHIND the GYM, but water is RUNNING THROUGH THE WALL onto the GYM FLOOR per Gloria Davis, Plant Mgr. 463.4208	1/10/14			Plumbing
Ral-Egypt Sr (2598) 1B	toilet runs constantly	1/16/14	Auxiliary Gym	boys locker room bathroom	Plumbing
Ral-Egypt Sr (2598) 1B	2-FLR DRAINS ARE BACKING UP IN B/RR-G/RR BASEMENT PLANT MGR-BYERS/416.3924	1/16/14			Plumbing
Ral-Egypt Sr (2598) 1B	Button to dispense water is missing ID # 241-130	11/6/13	Hallway/Corridor	By room 208	Plumbing
Ral-Egypt Sr (2598) 1B	FURNACES IN AUTO MECH SHOP VOC BLDG-PILOT NEEDS TO BE LIT- PLANT MGR BYERS 416-9661 KLR	11/13/13			Plumbing

Ral-Egypt Sr (2598) 1B	Handwashing sink is stopped up in football locker and can't be plunged.	11/13/13	Gym	Football Locker room	Plumbing
Ral-Egypt Sr (2598) 1B	Handwashing sink is running water which is presently turned off. This is Vistor's locker room and restroom for basketball games	11/13/13	Gym	Boys PE locker room	Plumbing
Ral-Egypt Sr (2598) 1B	SINK RM 114 HOME EC-LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF PER SBE-PLANT MGR BYERS 416-9661 KLR	11/14/13			Plumbing
Ral-Egypt Sr (2598) 1B	Commode leaking from neck--last commode. Need repairs.	9/16/13	Restroom (Girls)	Across from Teacher's Lounge	Plumbing
Ral-Egypt Sr (2598) 1B	UV IS LEAKING WATER IN RM-229. PLANT MGR-BYERS/416.4108	9/18/13			Plumbing
Ral-Egypt Sr (2598) 1B	Main Gas lines have been repaired, make necessary test and repairs , before lighting equipment.	9/18/13			Plumbing
Ral-Egypt Sr (2598) 1B	Test and repair RP Devices per MLG&W.	10/10/13	Mechanical Room		Plumbing
Ral-Egypt Sr (2598) 1B	Commode at Stadium constantly overflowing onto floor. Football game on Friday.	10/21/13	Restroom (Boys)	Stadium boys restroom	Plumbing
Ral-Egypt Sr (2598) 1B	SINK G RR BY RM 114 & SINK TEACHER'S LOUNGE MEN'S RR- BOTH LEAKING FROM U-JOINT PER SBE-PLANT MGR BYERS 416-9661 KLR	10/22/13			Plumbing
Ral-Egypt Sr (2598) 1B	tower over flowing.	7/22/13	Parking Lot	Cooling tower	Plumbing

Ral-Egypt Sr (2598) 1B	Towel overflow when flush in the Men's RR on the 1st floor Annex Teacher's Lounge per Mr. Pat Byers, Plant Mgr. 901.416.9661.	8/6/13			Plumbing
Ral-Egypt Sr (2598) 1B	Commode leaking around neck area	8/7/13	Restroom (Boys)	9th grade academy	Plumbing
Ral-Egypt Sr (2598) 1B	PIPE IN CEILING BY SERVING LINE PER SBE, LEAKING-SBE BYERS KLR	8/9/13			Plumbing
Ral-Egypt Sr (2598) 1B	severe leak at the door on the inside of the gym	3/7/14	Auxiliary Gym		Roof
Ral-Egypt Sr (2598) 1B	Roof leaks in lobby of gym by boys restroom and also stage area.	2/13/14	Gym	Lobby by boys restroom and stage area	Roof
Ral-Egypt Sr (2598) 1B	Roof leak in middle of classroom floor. Need repairs	2/10/14	2nd Floor	Room 228	Roof
Ral-Egypt Sr (2598) 1B	Roof leaks in both dining area and food prep area in Cafeteria	2/13/14	Cafeteria	Dining and Prep areas	Roof
Ral-Egypt Sr (2598) 1B	Roof leak in ceiling by hot water heater	2/13/14	Cafeteria	Laundry room	Roof
Ral-Egypt Sr (2598) 1B	ceiling pipe in gym lobby is leaking water all over floor per Ms. Byers 416-9661	11/26/13			Roof
Ral-Egypt Sr (2598) 1B	A/C leak in room 211 and hallway per Ms. Byers 416-9661	12/10/13			Roof

Ral-Egypt Sr (2598) 1B	Roof leak rm #227	1/8/14			Roof
------------------------	-------------------	--------	--	--	------

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Egypt Middle (259)	6	3	46	73	52	3	63	3	2	251
Grand Total	6	3	46	73	52	3	63	3	2	251

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Ral-Egypt Sr (2598) 1B	Need wooden blocks put up to install pencil sharpeners in various classrooms. Rooms are 117, 123, 126, 127, 128 and 200.	9/11/13	Classroom	Various classrooms	Asbestos
Ral-Egypt Sr (2598) 1B	Principal requesting that Basement be inspected /tested for abestos because we found the area flooded on yesterday.	1/16/14	Annex	Basement	Asbestos
Ral-Egypt Sr (2598) 1B	Pipe leading from hot water heater to ceiling need insulation replaced.	2/13/14	Cafeteria	Laundry room	Asbestos
Ral-Egypt Sr (2598) 1B	Refinish wooden court area and wooden stage area.	11/21/13	Gym	Wooden court area and wooden stage area	Asbestos
Ral-Egypt Sr (2598) 1B	Ral-Egypt- Sr. --WO-374568-- No internet connection for cable box OFF3 by printer(Request Network Cabling Maintenance Repair). (SCS Network Cabling and Electronics dept.--Response -- "Please See Journal Note")	8/14/13	Administration Area	Main Office	Cabling
Ral-Egypt Sr (2598) 1B	Drop number 6 is not working in classroom. Need repairs(Request Network Cabling Maintenance Repair).	8/14/13	Classroom	Room 124	Cabling
Ral-Egypt Sr (2598) 1B	Drops in cable boxes are not working. Need repairs in Room 113 (Request Network Cabling Maintenance Repair).	8/19/13	Classroom	Room 113	Cabling
Ral-Egypt Sr (2598) 1B	Drops number 3 and 4 are not active in classroom and in the internet closet per computer tech	10/30/13	Classroom	Room 124	Cabling
Ral-Egypt Sr (2598) 1B	SCS FP-3500 Network Cabling Project- Provide project management for Access DNSI to install network cabling installations and any associated electrical wiring. (Request Network Cabling Project Management).	7/26/13			Cabling

Ral-Egypt Sr (2598) 1B	Two boxes for internet drops need to be repaired for classroom use per computer tech. Teacher has 10 computers and 2 printers not connected to internet.(Request Network Cabling Maintenance Repair).	8/7/13	Classroom	Room 124	Cabling
Ral-Egypt Sr (2598) 1B	Need 6 boxes of soft ceiling tiles for replacement tiles. 4x8 ?	8/21/13	Administration Area	Entire building	Carpentry
Ral-Egypt Sr (2598) 1B	Exit door to ledge will not lock. Hazard if used.	8/21/13	Classroom	Room 229	Carpentry
Ral-Egypt Sr (2598) 1B	Install hasps on 2 metal teacher cabinets and on a metal 4drawer file cabinet	8/21/13	Classroom	Room 202	Carpentry
Ral-Egypt Sr (2598) 1B	Metal plates on outside of window have been taken off and need to be reinstalled. Had break-in in classroom twice. Plant Manager has metal plates which were removed in office.	9/3/13	Classroom	Window to outside-Room 103	Carpentry
Ral-Egypt Sr (2598) 1B	window broken out room 201 (vandalism) per Ms. Byers 416-9661	9/10/13			Carpentry
Ral-Egypt Sr (2598) 1B	Need a welder to weld the bottom hook back on for flag pole line.	10/29/13	Grounds	Flag pole in front of school	Carpentry
Ral-Egypt Sr (2598) 1B	Having breakins on 2nd floor and need to secure room windows and window screens. Rooms are 202, 204, 205, 207, 208, 209, 212, 213, 214, and 215.	9/11/13	Classroom	Various classrooms	Carpentry
Ral-Egypt Sr (2598) 1B	Please repair holes in walls on 2nd floor hallway.	6/2/14	Hallway/Corridor	2nd floor	Carpentry
Ral-Egypt Sr (2598) 1B	Please repair main entrance door. Does not latch.	6/10/14		main office	Carpentry

Ral-Egypt Sr (2598) 1B	ENTRANCE DOOR TO ROTC BLDG- NOT LOCKING, WON'T BE ABLE TO SECURE & CAFE ENTRANCE CTR MULL DAMAGED, WON'T BE ABLE TO SECURE-PLANT MGR BYERS 416-9661 KLR	10/29/13			Carpentry
Ral-Egypt Sr (2598) 1B	Teacher needs a 4x8 white board over the cork board board in classroom .	9/13/13	Classroom	Room 125	Carpentry
Ral-Egypt Sr (2598) 1B	Need door knob replaced with new one according to locksmith Darryl. Old knob is out dated and broken.	2/21/14	Administration Area	AP office-Room 225	Carpentry
Ral-Egypt Sr (2598) 1B	Front door closes too quickly on people. Need adjustment.	4/2/14	1st Floor	By Main Office	Carpentry
Ral-Egypt Sr (2598) 1B	Door closure at stairwell is broken and need repairs	4/2/14	1st Floor	Stairwell next to Parent Center	Carpentry
Ral-Egypt Sr (2598) 1B	Window in classroom fell out when to wind hit it on yesterday.	4/16/14	Classroom	Room 227	Carpentry
Ral-Egypt Sr (2598) 1B	Cylinder lock came out of door and is in Plant Manager's office	4/21/14	Cafeteria	Entrance door	Carpentry
Ral-Egypt Sr (2598) 1B	Please repair main entrance card access door. Does not latch when closed.	4/21/14			Carpentry
Ral-Egypt Sr (2598) 1B	Need floor retiled because of flood. All tile is coming up.	1/16/14	Hallway/Corridor	Basement by Bandroom	Carpentry
Ral-Egypt Sr (2598) 1B	Need 4x8 white board to replace a bullentine/chalk board.	1/29/14	Classroom	Room 124	Carpentry

Ral-Egypt Sr (2598) 1B	View glass in door is loose. Will need a frame and the glass is not broken.	2/10/14	2nd Floor	Room 213	Carpentry
Ral-Egypt Sr (2598) 1B	Per Ms. Byers 416-9661 in the cafeteria, exterior door center mullion only has 1 screw in it and needs securing	11/26/13			Carpentry
Ral-Egypt Sr (2598) 1B	Window out in boys basketball locker room per ms byers 416-9661	11/27/13			Carpentry
Ral-Egypt Sr (2598) 1B	Door knob is broken and needs to be replaced.	12/4/13	Classroom	Room 126	Carpentry
Ral-Egypt Sr (2598) 1B	latch stuck on door bar. the door will not close o lock,	1/16/14	Auxiliary Gym	front door	Carpentry
Ral-Egypt Sr (2598) 1B	Door knob is falling off and a hazard for students being locked in class.	11/6/13	Classroom	Room 126	Carpentry
Ral-Egypt Sr (2598) 1B	Need a hole repaired in wall behind door and also need a doorstop put on wall to prevent another hole.	9/26/13	Administration Area	Attendance Office	Carpentry
Ral-Egypt Sr (2598) 1B	WINDOW BRACKETS ARE OFF, CANT SECURE IN RM-115. SBE-GREGORY/416-4108	7/1/13			Carpentry
Ral-Egypt Sr (2598) 1B	Repair drywall, holes in cafe. foyer and in cafe.	7/8/13			Carpentry
Ral-Egypt Sr (2598) 1B	Screens on windows to outside are bent and screens do not close.	8/7/13	Classroom	Rooms 203 and 205	Carpentry

Ral-Egypt Sr (2598) 1B	Broken light hanging down in gym	8/15/13	Gym	Court area	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Need repairs	8/19/13	Administration Area	Room 113 1/2	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Need repairs	8/19/13	Classroom	Room 113	Electrical
Ral-Egypt Sr (2598) 1B	Need 6 boxes of 46807 lamps for light fixtures.	8/21/13	Administration Area	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Teacher states that kight is driving students crazy.	8/21/13	Classroom	Room 201	Electrical
Ral-Egypt Sr (2598) 1B	Outside light fixtures not working. Need repairs.	8/21/13	Gym	Back side and front side	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in these 3 areas. Need repairs	8/21/13	Gym	Football locker room Laundry room and Weight room	Electrical
Ral-Egypt Sr (2598) 1B	Broken exit sign which needs to be replaced.	8/21/13	Gym	Football locker room	Electrical
Ral-Egypt Sr (2598) 1B	Lights on court area of gym need replacement.	8/21/13	Gym	Court area	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture on stage	8/21/13	Gym	Stage area	Electrical

Ral-Egypt Sr (2598) 1B	Broken emergency light in gym	8/21/13	Gym	Lobby area of gym by girls restroom	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture. Need replacement	8/21/13	Hallway/Corridor	By room 213	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture.	8/21/13	Administration Area	Plant Manager Office	Electrical
Ral-Egypt Sr (2598) 1B	Security lights are out in these 3 areas. Need replacement. Need bucket truck	8/21/13	Grounds	Behind ROTC, behind gym by dumpsters, in front of	Electrical
Ral-Egypt Sr (2598) 1B	There is no power to scoreboard clock. Have a volleyball game today. This is urgent.	8/26/13	Gym	Power to scoreboard clock	Electrical
Ral-Egypt Sr (2598) 1B	Need three boxes of lamps for 4x8 light fixtures-46807.	8/26/13	Administration Area	Entire school	Electrical
Ral-Egypt Sr (2598) 1B	Check all outside parking lot lights-upper and lower lots.	8/27/13	Grounds	Check parking lot lights	Electrical
Ral-Egypt Sr (2598) 1B	Possible power outage, school reported a loud boom.	9/4/13			Electrical
Ral-Egypt Sr (2598) 1B	RTU NOT COMING ON IN GYM. PLANT MGR-BYERS/416.4108	9/4/13			Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture by Rooms 204 and 215	9/11/13	2nd Floor	Hallway	Electrical

Ral-Egypt Sr (2598) 1B	Exit sign in front of Cafeteria is broken and hanging down.	9/11/13	Hallway/Corridor	In front of Cafeteria	Electrical
Ral-Egypt Sr (2598) 1B	Light out in ceiling of gym. Need replacement.	11/20/13	Gym	Court area	Electrical
Ral-Egypt Sr (2598) 1B	Please replace ballast in light fixture on 1st floor hallway between lockers 1411 and 1461.	6/10/14	Hallway/Corridor		Electrical
Ral-Egypt Sr (2598) 1B	5 Light fixtures have bad ballast. Need replacements.	9/13/13	Library	Main seating area	Electrical
Ral-Egypt Sr (2598) 1B	Need meta lcover over exposed wires.	9/13/13	Hallway/Corridor	Wall outside Room 215	Electrical
Ral-Egypt Sr (2598) 1B	Need 5 boxes of 46677? lamps for ceiling light fixtures.	4/2/14	Hallway/Corridor	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Need bulb replacement in outside light fixture between Cafe and the Gym	4/2/14	Grounds	Outside between Cafe and Gym	Electrical
Ral-Egypt Sr (2598) 1B	UNIT ARE MAKING NOISE IN RM- 225,129 PLANT MGR-BYERS/416.4108	4/2/14			Electrical
Ral-Egypt Sr (2598) 1B	Please deliver 5 cases of fluorescent (32T8) light bulbs.	4/16/14		building engineer office	Electrical
Ral-Egypt Sr (2598) 1B	Please replace 1 light ballast in hallway by room 108.	4/29/14	Hallway/Corridor		Electrical

Ral-Egypt Sr (2598) 1B	Unit Ventilator not working.	5/7/14	Classroom	Rm 227	Electrical
Ral-Egypt Sr (2598) 1B	Please deliver 5 cases of fluorescent light bulbs (3218). Catalog #10221.	5/29/14		main office	Electrical
Ral-Egypt Sr (2598) 1B	Please replace 4 bulbs in gym.	6/2/14	Gym		Electrical
Ral-Egypt Sr (2598) 1B	Please disconnect power to welder and grinder to be removed from old auto shop that has been converted to weight and fitness room.	6/2/14		auto shop	Electrical
Ral-Egypt Sr (2598) 1B	Need 8 light fixture 100 watt bulbs changed out which are higher than 8 ft. Plant Manager has bulbs.	1/16/14	Gym	Girls locker room shower	Electrical
Ral-Egypt Sr (2598) 1B	1. Need 4 boxes of 46758 lamps for light fixtures in ceiling 2. Need 24 boxes of DULUX D 26watt for light fixtures.	1/16/14	Hallway/Corridor	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	per ms byers total power outage See wo's 414208 & 414209 that time is logged under this wo 414206.jd	2/4/14			Electrical
Ral-Egypt Sr (2598) 1B	5-RTU NOT COMING ON IN CAFE, CEILING UNITS RM-126 THRU 129, & RM-222 THRU 229 PLANT MGR-BYERS/416.4108	2/5/14			Electrical
Ral-Egypt Sr (2598) 1B	Emergency lights not working during power outage on yesterday in Main office by Principal's Office and also Guidance area.	2/5/14	Administration Area	Main Office and Guidance	Electrical
Ral-Egypt Sr (2598) 1B	Emergency lights did not come on with power outage on yesterday	2/5/14	Hallway/Corridor	By room 116 and room 126	Electrical

Ral-Egypt Sr (2598) 1B	Emergency light not working on 2nd floor hallway by Room 100	2/5/14	2nd Floor	By Room 101	Electrical
Ral-Egypt Sr (2598) 1B	AHU#1 IS MAKING NOISE IN MAIN HALL PLANT MGR-BYERS/416.4108	2/6/14			Electrical
Ral-Egypt Sr (2598) 1B	NO POWER TO LIGHTS IN RM-104, ALL RECEPTACLES HAVE NO POWER RM-220,222,224 PLANT MGR-BYERS/489.6112	2/10/14			Electrical
Ral-Egypt Sr (2598) 1B	No lights in ceiling. It is very dark in the closet. Ceiling is higher than 8 feet.	2/10/14	Custodial Closet	9TH Grade Academy	Electrical
Ral-Egypt Sr (2598) 1B	Air compressor that controls ANNEX building all three floors is not blowing and the building is cold also the vocational building is cold because the AHU is not running per Pat Byers 416-9661	11/26/13			Electrical
Ral-Egypt Sr (2598) 1B	vocational building rooms 130 thru 134 heat not coming on at all per Ms Byers 416-9661	12/2/13			Electrical
Ral-Egypt Sr (2598) 1B	Two light fixtures have bad ballast. One over teacher's desk and the other in the isle.	1/7/14	Classroom	Room 102	Electrical
Ral-Egypt Sr (2598) 1B	AHU#1 not running.	1/7/14			Electrical
Ral-Egypt Sr (2598) 1B	Need 3 lights replaced because it is dark at night. Higher than 8ft. Will NOT need a lift.	1/16/14	Grounds	Under canopy from Annex to Gym	Electrical
Ral-Egypt Sr (2598) 1B	2 light fixtures with bad ballast. one is in front of Parent Center and the other is across from Principal's Conference room.	11/1/13	1st Floor	Hallway	Electrical

Ral-Egypt Sr (2598) 1B	Set clock back for day light saving time	11/1/13	Administration Area	Main Office	Electrical
Ral-Egypt Sr (2598) 1B	HEAT VOC BLDG-NOT HEATING-PLANT MGR BYERS 416-9661 KLR	11/13/13			Electrical
Ral-Egypt Sr (2598) 1B	Two bad ballasts in Assistant Principal's Office-Room 116. Need replacement	11/13/13	Administration Area	Assistant Principal's Office-Room 116	Electrical
Ral-Egypt Sr (2598) 1B	2 bad ballast in light fixtures and lamps need replacing which are higher than 8 ft.	11/20/13	Gym	Concession Stand	Electrical
Ral-Egypt Sr (2598) 1B	Need 3 boxes of lamps for replacement in ceiling of school.	9/16/13	Administration Area	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Repair or replace B&G pump motor on domestic hot water pump.	9/18/13	Gym		Electrical
Ral-Egypt Sr (2598) 1B	Circuit breaker 18 which controls gym concession and some other areas need to be replaced according to Coaches. Sparks when on and you must giggle.	9/25/13	Gym	Breaker box	Electrical
Ral-Egypt Sr (2598) 1B	Outside security lights not working: 1. Front side side of gym 2. Back side of main building in front of gym parking area 3. south side of Auto Shop 4. West side corner of main building outside of cooling towers 5. Lower parking lot by street with fence	10/3/13	Grounds	Outside security lights	Electrical
Ral-Egypt Sr (2598) 1B	Need ballast in hallway. Dark in hall	10/3/13	2nd Floor	Hallway by Rm 204, 209 and 219	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in hallway by Room 213 instead of 219. Please correct.	10/3/13	2nd Floor	By Room 213	Electrical

Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture front lobby by boys restroom	10/4/13	Gym	Front lobby by boys restroom	Electrical
Ral-Egypt Sr (2598) 1B	Emergency lights not working in 3 areas. 1. Front lobby of gym by boys restroom. 2. By girls restroom 3. East side exit doors by bleachers	10/4/13	Gym	Emergency lights in gym	Electrical
Ral-Egypt Sr (2598) 1B	need 3 boxes of lamps for classroom areas projects(12 rooms to complete)	10/7/13			Electrical
Ral-Egypt Sr (2598) 1B	Flag line is stuck and flag is at half mast per Ms. Pat Byers, Plant Mgr. 416.9661	10/14/13			Electrical
Ral-Egypt Sr (2598) 1B	Need 3 boxes of lamps for replacement light fixtures.	10/16/13	Administration Area	Plant Manager's office	Electrical
Ral-Egypt Sr (2598) 1B	AIR COMPRESSOR 241-235 IN BASEMENT IS NOT WORKING PROPERLY - CONTROLS THE BASEMENT 2ND FLR & 3RD FLR - RMS ON THE 3RD FLR IS CONDENSATING - PM/BUYERS 416-9661	8/1/13			Electrical
Ral-Egypt Sr (2598) 1B	Need 5 boxes of I46807 lamps for ceiling fixtures and 5 boxes of ceiling tiles for replacement tile.	8/2/13	Administration Area	Entire building	Electrical
Ral-Egypt Sr (2598) 1B	Air Handler unit #1, when she turned the unit shot out through motor per Mr. Pat Byers, Plant Mgr. 901.416.9661.	8/6/13			Electrical
Ral-Egypt Sr (2598) 1B	Four lights on front porch are not lighting up. Need replacements.	8/7/13	Administration Area	Outside front proch	Electrical
Ral-Egypt Sr (2598) 1B	Bad ballast in light fixture in hallway. Need replacement	8/9/13	Hallway/Corridor	By Room 213	Electrical

Ral-Egypt Sr (2598) 1B	Need replacement exit signs in Library and in Room 215.	8/9/13	2nd Floor	Library and Room 215	Electrical
Ral-Egypt Sr (2598) 1B	Monthly - Oil Lube & Belt-Raleigh Egypt High - Refer to PM schedule details.	8/16/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	uv not cooling in rooms, 116, 117, 118, 120, 126, 128, 129 per pat byers 416-9661	9/4/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	RTU NOT COoling IN GYM. PLANT MGR-BYERS/416.4108	9/4/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Yearly - Oil Samples-Raleigh-Egypt High - Refer to PM schedule details.	9/16/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Filter-Raleigh Egypt High - Refer to PM schedule details.	2/21/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Filter-Raleigh Egypt High - Refer to PM schedule details.	10/25/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Yearly - Cooling Towers(STRAINERS)-Ral Egypt High - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex 1st Fir Mech-Ral Egypt Hi - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-2nd Fir Auto Shop-Ral Egypt Hi - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning

Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex by BandRm- Ral Egypt Hi - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Filter-Raleigh Egypt High - Refer to PM schedule details.	6/27/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Oil Lube & Belt-Raleigh Egypt High - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Rooms 15 and 16 in basement not cooling per Pat Byers 416-9661	9/11/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	check boiler per sbe	2/27/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	REPAIR AHU SHAFT AND BEARINGS	3/27/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHILLER MECH RM-IN ALARM-PLANT MGR BYERS 416-9661 KLR	4/14/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHILLER IS IN ALARM - PM/BUYERS 416-9661	4/21/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	a/c not working in main office.	5/12/14	Administration Area	main office	Heating/Ventilation /Air Conditioning

Ral-Egypt Sr (2598) 1B	a/c not working in kitchen.	5/13/14	Kitchen		Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	per ms davis 416-9677 the boiler is not coming on building is cold	2/3/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	RTU's Cafe running not heating.jd	2/5/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Repair boilers	12/10/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Boiler reading message has: NO FLAME per George Dean, Zone Supervisor at 901.606.2780.	12/13/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	HEAT RMS 126, 127, 128, 129, 216, 217, 220, 221, 222, 227, 228, & 229- ALL NOT HEATING-PLANT MGR BYERS 416-9661 KLR	1/14/14			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	CHILLER IS IN ALARM. PLANT MGR-BYERS/489.6112	10/31/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	no heat in room 132 vocational bldg per ms. byers 416-9661	11/12/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex 1st Flr Mech- Ral Egypt Hi - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-2nd Flr Auto Shop- Ral Egypt Hi - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning

Ral-Egypt Sr (2598) 1B	Monthly - Air Comp-Annex by BandRm- Ral Egypt Hi - Refer to PM schedule details.	9/17/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Chiller NOT COMING ON! Per Mr. Campbell at 901.826.7298.	7/8/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	chiller down per EMS 7.8.13	7/8/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	Annex Building Rooms 118, 224, 225 not cooling per Pat Byers 416-4108	7/25/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	GAS PKG UNIT VOC LOW ROOF WEST CTR SERVES RM 132-NOT COOLING-SBE BYERS 416-9661 KLR	8/12/13			Heating/Ventilation /Air Conditioning
Ral-Egypt Sr (2598) 1B	GRAFFITI IN B/RR-G/RR 1ST & 2ND FLRS. PLANT MGR-BYERS/416.4108	2/14/14			Painting
Ral-Egypt Sr (2598) 1B	paint new doors	9/26/13			Painting
Ral-Egypt Sr (2598) 1B	paint wall in hallway by bandroom	9/30/13			Painting
Ral-Egypt Sr (2598) 1B	Finish and paint drywall in cafe. and foyer.	7/8/13			Painting
Ral-Egypt Sr (2598) 1B	1st commode is not flushing. Need repairs	8/21/13	Restroom (Boys)	9th Grade Academy	Plumbing

Ral-Egypt Sr (2598) 1B	Urinal flush valve sticks and water continues to run. Need repairs	8/21/13	Restroom (Boys)	By Attendance Office	Plumbing
Ral-Egypt Sr (2598) 1B	3rd commode water is overflowing when flushed and 4th commode has no water pressure.	8/21/13	Restroom (Girls)	Restroom in Annex hallway	Plumbing
Ral-Egypt Sr (2598) 1B	Repair/replace drain on drinkr fountain.	8/21/13	Annex	3rd Flr.	Plumbing
Ral-Egypt Sr (2598) 1B	Water leak from pipe in front entrance of gym by boys restroom	8/21/13	Gym	Lobby of gym by boys restroom	Plumbing
Ral-Egypt Sr (2598) 1B	Water faucets running and will not cut off.	8/21/13	Restroom (Boys)	By Room 207	Plumbing
Ral-Egypt Sr (2598) 1B	TOILET CONTINUES TO RUN, CANT SHUT OFF IN B/RR 1ST FLR. PLANT MGR-BYERS/416.4108	9/5/13			Plumbing
Ral-Egypt Sr (2598) 1B	1st floor (ANNEX) Girls' RR, 1st stahl will NOT flush per Pat Byers, Plant Mgr 416.9661.	9/10/13			Plumbing
Ral-Egypt Sr (2598) 1B	Sink in Main Office stopped up with coffee grinds.	9/11/13	Administration Area	Main Office	Plumbing
Ral-Egypt Sr (2598) 1B	hot water tank is leaking water.	3/7/14	Cafeteria		Plumbing
Ral-Egypt Sr (2598) 1B	Pipe under sink in prep area is leaking in mop room.	10/29/13	Cafeteria	Mop room	Plumbing

Ral-Egypt Sr (2598) 1B	per ms byers 416-9661 no hot water in building	3/19/14			Plumbing
Ral-Egypt Sr (2598) 1B	Metal plate over floor drain is loose and has no screws.	9/13/13	Restroom (Boys)	1st floor by Conference Room	Plumbing
Ral-Egypt Sr (2598) 1B	3-SINKS ARE STOPPED UP ON 2ND FLR BY LIBRARY. PLANT MGR-BYERS/489.6112	2/26/14			Plumbing
Ral-Egypt Sr (2598) 1B	Pipe underneath the last handwashing sink is loose and leaking.	2/14/14	Restroom (Boys)	2nd floor by Rm 209	Plumbing
Ral-Egypt Sr (2598) 1B	Pipe underneath 1st handwashing sink is loose and leaking.	2/14/14	Restroom (Girls)	2nd floor by Rm 214	Plumbing
Ral-Egypt Sr (2598) 1B	Unstop roof drains, meet James King at 12:30 Wed.	2/19/14			Plumbing
Ral-Egypt Sr (2598) 1B	3-SINKS ARE STOPPED UP IN G/RR 2ND FLR BY LIBRARY. PLANT MGR-BYERS/416.4108	2/19/14			Plumbing
Ral-Egypt Sr (2598) 1B	Repair valves and/or other components to the make up water for the cooling towers.	4/2/14			Plumbing
Ral-Egypt Sr (2598) 1B	NO HOT WATER THRU BLDG PLANT MGR-BYERS/416.4108	4/17/14			Plumbing
Ral-Egypt Sr (2598) 1B	Please repair 2nd toilet in girls restroom next to room 207.	4/22/14	Restroom (Girls)		Plumbing

Ral-Egypt Sr (2598) 1B	Please repair 1st toilet in boys restroom.(across from conference room) Over flows into hallway when flushed and cut off not working.	5/14/14	Restroom (Boys)	1st floor	Plumbing
Ral-Egypt Sr (2598) 1B	Mop sink in custodial closet in 9th Grade Academy is stopped up and plunging does not help.	1/30/14	Custodial Closet	9th Grade Academy	Plumbing
Ral-Egypt Sr (2598) 1B	per ms byers 416-9661 there is no hot water in the entire building	2/13/14			Plumbing
Ral-Egypt Sr (2598) 1B	Water constantly running in commode. Need repairs	11/26/13	Gym	girls restroom in lobby	Plumbing
Ral-Egypt Sr (2598) 1B	Hand washing sink is stopped up.	11/26/13	Gym	Football locker room	Plumbing
Ral-Egypt Sr (2598) 1B	BURST PIPE in CLOSET BEHIND the GYM, but water is RUNNING THROUGH THE WALL onto the GYM FLOOR per Gloria Davis, Plant Mgr. 463.4208	1/10/14			Plumbing
Ral-Egypt Sr (2598) 1B	toilet runs constantly	1/16/14	Auxiliary Gym	boys locker room bathroom	Plumbing
Ral-Egypt Sr (2598) 1B	2-FLR DRAINS ARE BACKING UP IN B/RR-G/RR BASEMENT PLANT MGR-BYERS/416.3924	1/16/14			Plumbing
Ral-Egypt Sr (2598) 1B	Button to dispense water is missing ID # 241-130	11/6/13	Hallway/Corridor	By room 208	Plumbing
Ral-Egypt Sr (2598) 1B	FURNACES IN AUTO MECH SHOP VOC BLDG-PILOT NEEDS TO BE LIT- PLANT MGR BYERS 416-9661 KLR	11/13/13			Plumbing

Ral-Egypt Sr (2598) 1B	Handwashing sink is stopped up in football locker and can't be plunged.	11/13/13	Gym	Football Locker room	Plumbing
Ral-Egypt Sr (2598) 1B	Handwashing sink is running water which is presently turned off. This is Vistor's locker room and restroom for basketball games	11/13/13	Gym	Boys PE locker room	Plumbing
Ral-Egypt Sr (2598) 1B	SINK RM 114 HOME EC-LEAKING FROM BOTTOM, CAN'T CONTAIN OR CUT OFF PER SBE-PLANT MGR BYERS 416-9661 KLR	11/14/13			Plumbing
Ral-Egypt Sr (2598) 1B	Commode leaking from neck--last commode. Need repairs.	9/16/13	Restroom (Girls)	Across from Teacher's Lounge	Plumbing
Ral-Egypt Sr (2598) 1B	UV IS LEAKING WATER IN RM-229. PLANT MGR-BYERS/416.4108	9/18/13			Plumbing
Ral-Egypt Sr (2598) 1B	Main Gas lines have been repaired, make necessary test and repairs , before lighting equipment.	9/18/13			Plumbing
Ral-Egypt Sr (2598) 1B	Test and repair RP Devices per MLG&W.	10/10/13	Mechanical Room		Plumbing
Ral-Egypt Sr (2598) 1B	Commode at Stadium constantly overflowing onto floor. Football game on Friday.	10/21/13	Restroom (Boys)	Stadium boys restroom	Plumbing
Ral-Egypt Sr (2598) 1B	SINK G RR BY RM 114 & SINK TEACHER'S LOUNGE MEN'S RR- BOTH LEAKING FROM U-JOINT PER SBE-PLANT MGR BYERS 416-9661 KLR	10/22/13			Plumbing
Ral-Egypt Sr (2598) 1B	tower over flowing.	7/22/13	Parking Lot	Cooling tower	Plumbing

Ral-Egypt Sr (2598) 1B	Towel overflow when flush in the Men's RR on the 1st floor Annex Teacher's Lounge per Mr. Pat Byers, Plant Mgr. 901.416.9661.	8/6/13			Plumbing
Ral-Egypt Sr (2598) 1B	Commode leaking around neck area	8/7/13	Restroom (Boys)	9th grade academy	Plumbing
Ral-Egypt Sr (2598) 1B	PIPE IN CEILING BY SERVING LINE PER SBE, LEAKING-SBE BYERS KLR	8/9/13			Plumbing
Ral-Egypt Sr (2598) 1B	severe leak at the door on the inside of the gym	3/7/14	Auxiliary Gym		Roof
Ral-Egypt Sr (2598) 1B	Roof leaks in lobby of gym by boys restroom and also stage area.	2/13/14	Gym	Lobby by boys restroom and stage area	Roof
Ral-Egypt Sr (2598) 1B	Roof leak in middle of classroom floor. Need repairs	2/10/14	2nd Floor	Room 228	Roof
Ral-Egypt Sr (2598) 1B	Roof leaks in both dining area and food prep area in Cafeteria	2/13/14	Cafeteria	Dining and Prep areas	Roof
Ral-Egypt Sr (2598) 1B	Roof leak in ceiling by hot water heater	2/13/14	Cafeteria	Laundry room	Roof
Ral-Egypt Sr (2598) 1B	ceiling pipe in gym lobby is leaking water all over floor per Ms. Byers 416-9661	11/26/13			Roof
Ral-Egypt Sr (2598) 1B	A/C leak in room 211 and hallway per Ms. Byers 416-9661	12/10/13			Roof

Ral-Egypt Sr (2598) 1B	Roof leak rm #227	1/8/14			Roof
------------------------	-------------------	--------	--	--	------

Count of Craft	Craft								
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Plumbing	Roof	Sheet Metal	Grand Total
Riverview El (2620) 1A	1	1	9	32	46	14	15	4	122
Grand Total	1	1	9	32	46	14	15	4	122

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
Riverview EI (2620) 1A	Remove blown in insulation	1/15/14				Asbestos
Riverview EI (2620) 1A	Description: Entered on 01/14/2014 at 12:34:31 CST (GMT-0600) by EVERETT DUKE: Location: Riverview Elem - 2620	1/16/14	Cafeteria	CAFE MGR OFFICE		Cabling
Riverview EI (2620) 1A	Repair fence around A/C	9/18/13				Carpentry
Riverview EI (2620) 1A	Install fence around A/C units on east side of front door.	8/28/13				Carpentry
Riverview EI (2620) 1A	per Mr. Jackson 416-7340 room 110 the ceiling is caving in	1/13/14				Carpentry
Riverview EI (2620) 1A	cut 2 3ft lengths of harden steele chain	9/9/13				Carpentry
Riverview EI (2620) 1A	stall door and hinges have fallen off (need to be re-installed to wall)	9/11/13	Restroom (Boys)	B building 119		Carpentry

Riverview EI (2620) 1A	Principal Parish request Large Bulletin Board to be mounted on the wall from across the Main Office. This is the second time being submitted.	7/17/13	Hallway/Corridor	1st. flr. by Cafe.	Carpentry
Riverview EI (2620) 1A	DOOR - ENTRY DR ON EAST SIDE OF BLDG - NOT LOCKING - CAN'T SECURE BLDG - SBE/MCFARLAND 650-0389	7/23/13			Carpentry
Riverview EI (2620) 1A	In all rooms and hallway Ceiling Tiles need repairing.	7/24/13	Hallway/Corridor	1st. Flr. & Rms.	Carpentry
Riverview EI (2620) 1A	Install fence around A/C units at front of school.	8/6/13			Carpentry
Riverview EI (2620) 1A	Remove in replace lights	1/17/14			Electrical
Riverview EI (2620) 1A	chiller down	9/4/13			Electrical
Riverview EI (2620) 1A	A/C PRIN'S OFC-NOT COMING ON-PLANT MGR JEFFERSON 416-7360 KLR	9/9/13			Electrical
Riverview EI (2620) 1A	ballast needs replacing in front of classroom	1/21/14	Classroom	137	Electrical

Riverview EI (2620) 1A	ballast need replacing in lights in the kitchen bathroom and office. Water damage	1/21/14	Kitchen	office and bathroom	Electrical
Riverview EI (2620) 1A	ballast need replacing in main hallway, outside main office (A building)	1/30/14	Hallway/Corridor		Electrical
Riverview EI (2620) 1A	two(2) ballast need replacing in cafeteria	1/30/14	Cafeteria		Electrical
Riverview EI (2620) 1A	ballast needs replacing in light fixture in front of classroom	2/27/14	Classroom	109	Electrical
Riverview EI (2620) 1A	master clock needs resetting due to time change	3/11/14	Administration Area	main office	Electrical
Riverview EI (2620) 1A	ballast in 2 fixtures need replacing in front lobby area of building(entrance way and outside main office)	3/12/14	Hallway/Corridor	front lobby and hallway	Electrical
Riverview EI (2620) 1A	Ballst need replacing in two fixtures in guidance coueslor suite(office)	3/25/14	Administration Area	guidance office	Electrical
Riverview EI (2620) 1A	FIRE ALARM SYSTEM SHOWING TROUBLE-PLANT MGR JEFFERSON 416-7630 KLR	3/31/14			Electrical

Riverview EI (2620) 1A	HEAT RM 111-NOT COMING ON- PLANT MGR JEFFERSON 416- 7630 KLR	3/31/14			Electrical
Riverview EI (2620) 1A	need 1 box of light bulbs (26), to replace lights throughout school for TCAP testing.	4/17/14	1st Floor	SBE office	Electrical
Riverview EI (2620) 1A	PUMP-1 MECH RM CEILING- MAKING NOISES-PLANT MGR JEFFERSON 416-7320 KLR	4/28/14			Electrical
Riverview EI (2620) 1A	ballast needs replacing in light (bathroom in the teacher's lounge)	4/29/14	1st Floor	teacher's lounge	Electrical
Riverview EI (2620) 1A	ballast needs replacing in light (bathroom in the teacher's lounge)	4/29/14	1st Floor	teacher's lounge	Electrical
Riverview EI (2620) 1A	CHILLER DOWN	5/5/14			Electrical
Riverview EI (2620) 1A	CHILLER DOWN	5/6/14			Electrical
Riverview EI (2620) 1A	Check chiller	5/19/14			Electrical

Riverview EI (2620) 1A	Disconnect all kitchen equipment still in kitchen area (per Jim Cruthirds).	6/18/14			Electrical
Riverview EI (2620) 1A	chiller down	9/30/13			Electrical
Riverview EI (2620) 1A	Check a/c out front	10/15/13			Electrical
Riverview EI (2620) 1A	bad ballast	12/2/13	1st Floor	rm 134	Electrical
Riverview EI (2620) 1A	Electrical Control Box ID# 051-029 is constantly beeping theirs two one as you come in the front door.	7/19/13	Administration Area	First Floor	Electrical
Riverview EI (2620) 1A	Types of Fluorescent Bulbs 46823/ 25 watt, Attention Ken White.	7/19/13	Classroom	First Floor	Electrical
Riverview EI (2620) 1A	UNITS ARE NOT COMING ON IN RMS E136,E138,E140,E142. SBE JEFFERSON 416-7360	8/5/13			Electrical
Riverview EI (2620) 1A	4-RTU NOT COMING ON IN RM-136,138,140,142. PLANT MGR-JEFFERSON/416.7620	8/8/13			Electrical

Riverview EI (2620) 1A	FCU-1 RM A106, RM A107, RM C122, RM 148, RM 132, RM 136, & RM 138-ALL NOT COMING ON-SBE JEFFERSON 416-7340 KLR	8/9/13			Electrical
Riverview EI (2620) 1A	FCU-1 RM A111-NOT COOLING-SBE JEFFERSON 416-7340 KLR	8/9/13			Electrical
Riverview EI (2620) 1A	FIRE ALARM IS IN TROUBLE. PLANT MGR-JEFFERSON/416.7340	8/12/13			Electrical
Riverview EI (2620) 1A	Large amount of lights out all around the building and the play ground area.	7/9/13	Grounds	Out side area	Electrical
Riverview EI (2620) 1A	Monthly - Filter-Riverview Elementary - Refer to PM schedule details.	7/2/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	UNIT VENT IN PRINC. OFFICE IS NOT COMING ON. SBE MCFARLAND 650-0389	7/3/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	7/8/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	7/9/13			Heating/Ventilation /Air Conditioning

Riverview EI (2620) 1A	replace and repair cond. units on southwest corner of school	7/9/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	Replace three stolen cond. units	9/3/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	RTU#1,3 NOT COOLING IN CAFE. PLANT MGR- JEFFERSON/416.7360	9/3/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	9/3/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	A/C PRIN'S OFC-NOT COMING ON-PLANT MGR JEFFERSON 416-7360 KLR	9/5/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	install 2 locks and chains on gates	9/9/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller in alarm and down and RTU 1, 2, 3 are not cooling cafeteria per Mr. Jefferson 416-7630	9/11/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	A/C units in the KITCHEN and in ROOM C121 are NOT COOLING per Mr. Jefferson, Plant Mgr. 416.7350.	9/18/13			Heating/Ventilation /Air Conditioning

Riverview EI (2620) 1A	UNIT is NOT HEATING in ROOM D130 per Mr. Jefferson, Plant Mgr. 416.7360	2/11/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	Monthly - Filter-Riverview Elementary - Refer to PM schedule details.	3/4/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	C/O to A/C ---- 4 pipe system ?	3/21/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	Yearly - Air Cool Chillers-Riverview Elementary - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	4/14/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	4/21/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	4/23/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	4/25/14			Heating/Ventilation /Air Conditioning

Riverview EI (2620) 1A	Monthly - Oil Lube & Belt- Riverview Elementary - Refer to PM schedule details.	4/28/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	4/30/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	5/2/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	5/7/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down per mr jefferson 416-7630	5/12/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	5/28/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	6/5/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	6/6/14			Heating/Ventilation /Air Conditioning

Riverview EI (2620) 1A	chiller down	6/10/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	6/17/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	AHU#1,3 NOT COOLING IN KITCHEN ,CAFE. PLANT MGR- JEFFERSON/416.7360	9/18/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	copper stolen on ofc units	9/18/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	A/C unit in the Teacher's Lounge NOT COOLING per Mr. Jefferson, Plant Mgr. 416.7360.	9/20/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	9/29/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	Monthly - Oil Lube & Belt- Riverview Elementary - Refer to PM schedule details.	9/30/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	A/C RM 108 TCHR'S LOUNGE- NOT COMING ON-PLANT MGR JEFFERSON 416-7360 KLR	10/2/13			Heating/Ventilation /Air Conditioning

Riverview EI (2620) 1A	CHILLER NOT COMING ON- AFFECTING THE ENTIRE BLDG- PLANT MGR JEFFERSON 416- 7360 KLR	10/3/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	Monthly - Filter-Riverview Elementary - Refer to PM schedule details.	10/29/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	HEAT PRIN'S OFC & MAIN OFC AREA-NOT HEATING-PLANT MGR IRVING 416-7360 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	HEAT RMS A11, A112, A108, C123, C124, & 142-ALL NOT HEATING-PLANT MGR JEFFERSON 416-7430 KLR	1/7/14			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	kill power to three cond. units	7/11/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	chiller down	7/22/13			Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	install 2 cond. units and 1 set of service valves	7/26/13			Heating/Ventilation /Air Conditioning

Riverview EI (2620) 1A	RTU NOT COOLING IN CAFE. PLANT MGR- JEFFERSON/416.7620	8/8/13				Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	need 3 foot of harden steel chain and lock for new fence in front of school	8/20/13				Heating/Ventilation /Air Conditioning
Riverview EI (2620) 1A	repair cleanout	9/10/13				Plumbing
Riverview EI (2620) 1A	commode not flushing properly in 2nd stall of boys restroom in " A "Building	1/21/14	Restroom (Boys)	a building		Plumbing
Riverview EI (2620) 1A	commode in girls restroom not working properly in the "E" building.	1/21/14	Restroom (Girls)	E building		Plumbing
Riverview EI (2620) 1A	commode seat has fallen off in the handicap stall in the girls restroom of the kindergarden building (D building) need new seat installed	2/21/14	Restroom (Girls)	D building		Plumbing
Riverview EI (2620) 1A	3-COM SINK IS STOPPED UP IN KITCHEN. PLANT MGR- JEFFERSON/649.6525	2/26/14				Plumbing
Riverview EI (2620) 1A	Disconnect all kitchen equipment still in kitchen area (per Jim Cruthirds).	6/18/14				Plumbing

Riverview EI (2620) 1A	sink stopped up	10/24/13	Cafeteria		Plumbing
Riverview EI (2620) 1A	water leaking off pipe	10/24/13	Restroom (Girls)		Plumbing
Riverview EI (2620) 1A	commode stopped up	11/5/13	1st Floor	teacher lounge	Plumbing
Riverview EI (2620) 1A	PIPE IN KITCHEN CEILING-HAS BURST PER SBE-PLANT MGR JEFFERSON 416-7640 KLR	1/7/14			Plumbing
Riverview EI (2620) 1A	HOT WATER TANK IS LEAKING WATER (083). SBE-MCFARLANE/6500389	7/18/13			Plumbing
Riverview EI (2620) 1A	no hot water in kitchen per Jefferson 416-7360	7/31/13			Plumbing
Riverview EI (2620) 1A	RTU IS LEAKING WATER IN PRIN OFFICE. PLANT MGR- JEFFERSON/649.6525	8/8/13			Plumbing
Riverview EI (2620) 1A	Toilet in boys restroom near plant manager's office won't stop running.	8/23/13	Restroom (Boys)		Plumbing

Riverview EI (2620) 1A	water leaking from the roof in main hallway (westend)	1/14/14	Hallway/Corridor	west end main hall	Roof
Riverview EI (2620) 1A	roof leak in classroom (107) water coming through ceiling tile	1/14/14	Classroom	107	Roof
Riverview EI (2620) 1A	roof leaking in conference room (next to principals office)	1/14/14	Administration Area	conference room	Roof
Riverview EI (2620) 1A	roof in the main hallway of the A building is leaking on the far west side	2/4/14	Hallway/Corridor	main hallway	Roof
Riverview EI (2620) 1A	roof leaking into the conference room next to principal's office.	2/5/14	Administration Area	conference room	Roof
Riverview EI (2620) 1A	roof leaking in conference room next to principals office	4/8/14	Administration Area	conference room	Roof
Riverview EI (2620) 1A	roof leaking in hallway of A building near entrance from parking lot	4/8/14	Hallway/Corridor	southwest end building A	Roof
Riverview EI (2620) 1A	water coming from roof leak in stairway behind auditorum(#421304) sent 3/7/14	4/8/14	Hallway/Corridor	behind auditorum	Roof

Riverview EI (2620) 1A	severe roof leak in classroom(water raining down into classroom)	9/20/13	Classroom	133	Roof
Riverview EI (2620) 1A	roof leaking into classroom 107, 133 and conference room	9/23/13	Classroom	107	Roof
Riverview EI (2620) 1A	room 103 has a leak from roof in the center of the room and over by the window	10/2/13	Classroom	103	Roof
Riverview EI (2620) 1A	roof leaking	10/16/13	1st Floor	rm 402	Roof
Riverview EI (2620) 1A	ceiling water leaking	10/17/13	1st Floor	rm 103	Roof
Riverview EI (2620) 1A	roof leaking water into front office area of library	1/10/14	Library	front room	Roof
Riverview EI (2620) 1A	there is a roof leak in classroom E136 above the drop ceiling	8/1/13	Classroom	E136	Roof
Riverview EI (2620) 1A	Remove in replace duct work	1/17/14			Sheet Metal

Riverview EI (2620) 1A	1" strips -- 9 of them	7/26/13			Sheet Metal
Riverview EI (2620) 1A	locker door in classroom has fallen off	8/1/13	Classroom	e136	Sheet Metal
Riverview EI (2620) 1A	Clean gutters	8/13/13			Sheet Metal

Count of Craft	Craft									
	Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Riverview Middle (2625) 1A		3	44	66	75	5	49	13	3	258
Grand Total		3	44	66	75	5	49	13	3	258

Location	Request Description	Submittal Date	Area Descript	Area Number	Craft
Riverview Middle (2625) 1A	replace floor tile in library	6/10/14	Library		Asbestos
Riverview Middle (2625) 1A	refinish gym floor	10/2/13			Asbestos
Riverview Middle (2625) 1A	Auditorium AHU (above) insulate exposed pipe. Possible ACM.	11/6/13			Asbestos
Riverview Middle (2625) 1A	Install a new metal stud/vinyl sheet rock wall in classroom 117 and 119.	6/10/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and install vinyl sheetrock in room 117.	6/12/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and install vinyl sheetrock in room 119.	6/12/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Remove floor tile in room 117 for new wall.	6/12/14	1st Floor		Carpentry

Riverview Middle (2625) 1A	Remove floor tile in room 119 for new wall.	6/12/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and install cove base in room 117.	6/12/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and install cove base in room 119.	6/12/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Repair/patch existing floor tile in room 119.	6/13/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and install new marker board and cork in room 117.	6/13/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and install new marker board and cork in room 119.	6/13/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and replace damaged ceiling tile in room 117.	6/13/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Provide and replace damaged ceiling tile in room 119.	6/13/14	1st Floor		Carpentry

Riverview Middle (2625) 1A	Repair/patch floor in main office.	6/17/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Repair/patch floor in room 117.	6/17/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Build steps for access to water foun. between boys/girls restroom.	6/17/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	Build steps to access water foun. in hallway near science lab.	6/17/14	1st Floor		Carpentry
Riverview Middle (2625) 1A	WINDOW - WEST SIDE OF BLDG BASEMENT DR - GLASS BROKEN OUT CAN'T SECURE - PM/JEFFERSON 416-7430	6/30/14			Carpentry
Riverview Middle (2625) 1A	black board in front of classroom needs replacing, board is falling off the wall creating safety hazard.	7/30/13	Classroom	202	Carpentry
Riverview Middle (2625) 1A	Check doors on handicap switch for gym. Door on left does not lock and needs to be adjusted. Door on right is stuck and will not unlock.(Electrical is OK)	2/7/14			Carpentry
Riverview Middle (2625) 1A	floor tile needs replacing, two pieces are missing and others are loose in area near stairway.	2/18/14	Hallway/Corridor	southwest hallway on 2nd floor	Carpentry

Riverview Middle (2625) 1A	stall door has fallen off in girls restroom on 1st floor near elevator	3/6/14	Restroom (Girls)	1st floor West end	Carpentry
Riverview Middle (2625) 1A	FRONT ENTRY DOOR BY PARKING LOT CANT SECURE PLANT MGR- JEFFERSON/649.6525	4/14/14			Carpentry
Riverview Middle (2625) 1A	Move portable wall partitions in cafeteria to each side of cafe. Fasten to wall with metal fastener.	7/17/13			Carpentry
Riverview Middle (2625) 1A	Lock on door need service hard to get into the room.	7/17/13	Classroom	2nd flr. 218	Carpentry
Riverview Middle (2625) 1A	Electrical Closet door will not lock need service.	7/17/13	Hallway/Corridor	1st. flr. Elect. Clst.	Carpentry
Riverview Middle (2625) 1A	Remove in science lab 3 kitchen cabinets.	7/19/13	1st Floor		Carpentry
Riverview Middle (2625) 1A	Remove three sink/base units.	7/22/13	1st Floor		Carpentry
Riverview Middle (2625) 1A	In Assistance Principal Office it's leaking in her office down on the floor.	7/23/13	Administration Area	2nd Flr. 218	Carpentry

Riverview Middle (2625) 1A	Frame up around pipe in floor, science lab.	7/24/13	1st Floor		Carpentry
Riverview Middle (2625) 1A	Repair floor tile and install new covebase in science lab 1.	7/24/13	1st Floor		Carpentry
Riverview Middle (2625) 1A	Repair floor tile and install new covebase in science lab 2.	7/24/13	1st Floor		Carpentry
Riverview Middle (2625) 1A	Repair floor tile and install new covebase in science lab 3.	7/24/13	1st Floor		Carpentry
Riverview Middle (2625) 1A	Ceiling Tiles are need in all Hallways and all Rooms and Offices.	7/25/13	Hallway/Corridor	1st. Flr. & 2ndFlr& 3rd	Carpentry
Riverview Middle (2625) 1A	Remove all wall mounted televisions and move to a location for pick-up by warehouse personnel. Televisions are to be removed from all classrooms.	5/27/14			Carpentry
Riverview Middle (2625) 1A	Remove cabinet and vent-a-hood in Home Economics room.	5/30/14	Classroom		Carpentry
Riverview Middle (2625) 1A	Remove from wall, cabinet with Vent-a-Hood in old Home Economics.	6/2/14	Classroom		Carpentry

Riverview Middle (2625) 1A	Provide and install new stained plywood tops on 3 science lab cabinet base units.	6/6/14	Classroom		Carpentry
Riverview Middle (2625) 1A	need 2 packs of fiberglass ceiling tile and 2 packs of carboard ceiling tile for the classrooms and hallways	9/5/13	Custodial	1st floor	Carpentry
Riverview Middle (2625) 1A	ceiling brackets and tile need to be installed in front lobby area and hallway on 1st floor. To fill space on both sides of new walls.	9/11/13	Hallway/Corridor	1st floor lobby area	Carpentry
Riverview Middle (2625) 1A	cafeteria door jammed	10/15/13	Cafeteria	1st floor	Carpentry
Riverview Middle (2625) 1A	security door in hallway won't close	10/21/13	2nd Floor	main hall	Carpentry
Riverview Middle (2625) 1A	1ST FLR REAR ENTRANCE DOOR-GLASS BROKE OUT OF DOOR-WON'T BE ABLE TO SECURE-PLANT MGR IRVING 416-7360 KLR	10/29/13			Carpentry
Riverview Middle (2625) 1A	classrooms on the second floor 206,212, 213, and 217 need windows rechalked(draft in classroom)	12/13/13	Classroom	2nd floor	Carpentry
Riverview Middle (2625) 1A	door closer (hydraulic) on door to boys restroom is broken	5/7/14	Restroom (Boys)	2nd floor	Carpentry

Riverview Middle (2625) 1A	Remove/relocate existing lights in room 119 for new wall. Support Jason	6/11/14	1st Floor		Electrical
Riverview Middle (2625) 1A	Remove/relocate existing lights in room 117 for new wall. Support Jason.	6/11/14	1st Floor		Electrical
Riverview Middle (2625) 1A	Re switch lights in room 117.	6/11/14	1st Floor		Electrical
Riverview Middle (2625) 1A	RE switch lights in room 119.	6/11/14	1st Floor		Electrical
Riverview Middle (2625) 1A	Change ballast in room 117.	6/13/14	1st Floor		Electrical
Riverview Middle (2625) 1A	Change ballast in room 119.	6/13/14			Electrical
Riverview Middle (2625) 1A	BREAKER TO MAIN OFC LIGHTS IS BROKEN - PM/JEFFERSON 416-7430	6/30/14			Electrical
Riverview Middle (2625) 1A	need 75 lamps (#46807) to replace blown lamps throughout facility	8/7/13	Classroom		Electrical

Riverview Middle (2625) 1A	handicap button does not work work doors will not open when outside button is pushed coming from parking lot	8/8/13	Grounds	back entrance	Electrical
Riverview Middle (2625) 1A	Repair lights in AHU room lower area north end.	2/11/14			Electrical
Riverview Middle (2625) 1A	ballast need replacing in light in girls restroom on 1st floor of main lobby	2/26/14	Restroom (Girls)	main lobby	Electrical
Riverview Middle (2625) 1A	HEAT RM 113-NOT COMING ON & HAS A BURNING SMELL- PLANT MGR JEFFERSON 416-7340 KLR	3/6/14			Electrical
Riverview Middle (2625) 1A	outside lights around the building need bulbs on the parking lot and front of building	3/11/14	Parking Lot	outside of building	Electrical
Riverview Middle (2625) 1A	master clock needs resetting due to time change	3/11/14	Administration Area	main office	Electrical
Riverview Middle (2625) 1A	ballast need replacing in stairway, replace globe cover	4/8/14	Stairway	southeast stairway	Electrical
Riverview Middle (2625) 1A	timer on outside lights need to be reset, staying on during the day off at night	4/8/14	Grounds	parking lot	Electrical

Riverview Middle (2625) 1A	ballast needs replacing in light fixture of assistant principal office(#218)	4/14/14	Administration Area	218	Electrical
Riverview Middle (2625) 1A	need 2 box(48) light bulbs to replace lights in classrooms,hallways, and cafeteria	4/17/14	1st Floor	SBE office	Electrical
Riverview Middle (2625) 1A	lights in the auditorum need replacing over seating area	4/21/14	Auditorium		Electrical
Riverview Middle (2625) 1A	ballast need replacing in boys dressing room on stage	4/21/14	Auditorium	dressing room	Electrical
Riverview Middle (2625) 1A	switch needs repairing in girls dressing room on stage	4/21/14	Auditorium	girls dressing room	Electrical
Riverview Middle (2625) 1A	wall outlets not working in room 219(computer lab)	4/21/14	2nd Floor	219	Electrical
Riverview Middle (2625) 1A	ballast need replacing in lights (#219) computer lab	4/21/14	2nd Floor	219	Electrical
Riverview Middle (2625) 1A	ballast need replacing in light fixture	4/21/14	Classroom	224	Electrical

Riverview Middle (2625) 1A	ballast need replacing in light fixture	4/21/14	Classroom	125	Electrical
Riverview Middle (2625) 1A	ballast need replacing in light fixture	4/21/14	Classroom	128	Electrical
Riverview Middle (2625) 1A	Electric outlet in classroom on west wall is making loud noise, needs repairing before TCAP testing in classroom	4/25/14	Classroom	119	Electrical
Riverview Middle (2625) 1A	due to power outage main clock in office needs to be reset	4/29/14	Administration Area	main office	Electrical
Riverview Middle (2625) 1A	UV RM 125-NOT COMING ON- PLEASE COME AFTER 11 AM- PLANT MGR JEFFERSON 416-7340 KLR	4/30/14			Electrical
Riverview Middle (2625) 1A	KITCHEN VENT HOOD is NOT COMING ON per Mr. Jefferson, Plant Mgr. 416.7340	5/1/14			Electrical
Riverview Middle (2625) 1A	ballast needs replacing in light fixture of 2nd floor west end boys restroom entrance way	5/7/14	Restroom (Boys)	2nd floor	Electrical
Riverview Middle (2625) 1A	Program master clock and bells.	7/16/13	Administration Area		Electrical

Riverview Middle (2625) 1A	Replace ballast in hall near band room.	7/16/13	Hallway/Corridor		Electrical
Riverview Middle (2625) 1A	Large amounts of lights out.	7/18/13	Hallway/Corridor	1st. Floor	Electrical
Riverview Middle (2625) 1A	Back and Front Porch all lights are out.	7/18/13	1st Floor	Porch	Electrical
Riverview Middle (2625) 1A	Large amount of lights are out.	7/18/13	Library	223 Media Center	Electrical
Riverview Middle (2625) 1A	Repair large amounts of lights.	7/18/13	Cafeteria	First Floor	Electrical
Riverview Middle (2625) 1A	Types of Fluorescent Bulbs 46823/ 25watt, Quantity for both Schools Middle and Elementary 4 cases.	7/19/13	Cafeteria	First Floor	Electrical
Riverview Middle (2625) 1A	29 Lights with Bad Ballasts.	7/23/13	Library	2nd Flr. 223	Electrical
Riverview Middle (2625) 1A	A/C RM 206-NOT COMING ON-PLANT MGR JEFFERSON 416-7430 KLR	5/12/14			Electrical

Riverview Middle (2625) 1A	AHU-7 CAFE & AHU-10 AUDITORIUM-BOTH NOT COOLING-PLANT MGR JEFFERSON 416-7360 KLR	5/14/14			Electrical
Riverview Middle (2625) 1A	Re set Chiller.	5/19/14			Electrical
Riverview Middle (2625) 1A	faulty smoke detector in gym office area continues to give a false alarm	5/23/14	Gym	Gym office	Electrical
Riverview Middle (2625) 1A	Home economics room remove floor Quad recep. on floor. Just past the office on your left.	5/23/14	Classroom		Electrical
Riverview Middle (2625) 1A	CHILLER TO MAIN OFC-NOT COMING ON-PLANT MGR JEFFERSON 416-7430 KLR	5/28/14			Electrical
Riverview Middle (2625) 1A	Remove/disconnect ELEC. power to Teacher Lab Tables. Room 125, 128, and 129.	5/28/14	Classroom		Electrical
Riverview Middle (2625) 1A	CHILL WATER PUMP-2 BOILER RM-NOT WORKING PROPERLY PER SBE-SBE JEFFERSON 416-7340 KLR	8/12/13			Electrical
Riverview Middle (2625) 1A	room 219 fan motor not blowing per jefferson 416-7340	9/4/13			Electrical

Riverview Middle (2625) 1A	CHILL WATER PUMPS#1,2 NOT COMING ON. PLANT MGR- PARKER/416.8134	9/5/13			Electrical
Riverview Middle (2625) 1A	light flickers continuously(ballast needs replacing)	9/13/13	Classroom	205	Electrical
Riverview Middle (2625) 1A	ten lights are out in gym (need bulbs installed)	9/13/13	Basketball Court	Gym	Electrical
Riverview Middle (2625) 1A	electrical switch to lower and raise basketball goals not working (need replacing)	9/13/13	Basketball Court	Gym	Electrical
Riverview Middle (2625) 1A	ceiling lights3 boxes ts 38	10/16/13	1st Floor	main office	Electrical
Riverview Middle (2625) 1A	score board clock not working	10/24/13	Gym		Electrical
Riverview Middle (2625) 1A	FIRE ALARM SYSTEM CONSTANTLY BEEPING- PLANT MGR IRVING 416-7340 KLR	10/25/13			Electrical
Riverview Middle (2625) 1A	bad ballast	10/25/13	Cafeteria	locker rm	Electrical

Riverview Middle (2625) 1A	INSTALL NEW MOTOR ON BASKETBALL BACK BOARD.	11/6/13			Electrical
Riverview Middle (2625) 1A	FIRE ALARM SHOWING TROUBLE-PLANT MGR JEFFERSON 416-7430 KLR	1/7/14			Electrical
Riverview Middle (2625) 1A	HEAT RMS 203, 205, & 217- ALL NOT COMING ON-PLANT MGR JEFFERSON 416-7430 KLR	1/7/14			Electrical
Riverview Middle (2625) 1A	per Mr. Jefferson 416-7430 room 119 not coming on	1/7/14			Electrical
Riverview Middle (2625) 1A	Install key operated switch in circuit for handicapp push-buttons for cafeteria and gymnasium. This is to prevent unauthorized entrance to these areas.	1/22/14			Electrical
Riverview Middle (2625) 1A	Units are NOT COMING ON in ROOMS 210 and 215 per Mr. Jeffries, Plant Mgr. 416.7340	1/24/14			Electrical
Riverview Middle (2625) 1A	ballast needs replacing in light fixture in conference room of main office	1/30/14	Administration Area	conference room	Electrical
Riverview Middle (2625) 1A	HEAT RM 203, 210, & 215-ALL NOT COMING ON-PLANT MGR JEFFERSON 416-7430 KLR	2/3/14			Electrical

Riverview Middle (2625) 1A	All Rooms, All Hallways, & All Offices Fluorescent Bulb Lights needed to be repair #46823/ 28 watts.	7/25/13		All Floors & Offices	Electrical
Riverview Middle (2625) 1A	need rapid start florescent lamps (75) for classrooms throughtout building	8/1/13	Classroom	1st and 2nd floor	Electrical
Riverview Middle (2625) 1A	AHU #5 --- fix busted coil	2/7/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	6/22/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	A/C RM 212-NOT COOLING-PLANT MGR JEFFERSON 416-7430 KLR	6/24/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - Filter-Riverview Middle - Refer to PM schedule details.	6/27/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	AHU-13 3RD FLR LIBRARY STORERM-BLOWING TOO COLD, TEMP IS 68 & AHU-14 3RD FLR STORERM WEST-BLOWING TOO COLD, TEMP IS 67 PER SBE-SBE JEFFERSON 416-7340 KLR	8/1/13			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	chiller down	8/6/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - Filter-Riverview Middle - Refer to PM schedule details.	2/21/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - RIVERVIEW MID LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Yearly - Water-Cool Chiller Filter-Riverview Mid - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Yearly - Rod Chiller - Riverview Middle - Refer to PM schedule details.	3/21/14			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	C/O to A/C --- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Yearly - Cooling Tower-STRAINERS-Riverview Middle - Refer to PM schedule details.	3/25/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	check chillers	3/31/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	check office chiller	4/2/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - RIVERVIEW MID LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Yearly - Air Cool Chillers- Riverview Middle - Refer to PM schedule details.	4/5/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	office chiller	4/14/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	ofc chiller	4/17/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	AHU - LIBRARY - NOT COOLING - SHOWING 81 DEGREES - PM/JEFFERSON 416-7430	4/23/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	4/27/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	ofc chiller	4/29/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	CHILLER MECH RM-NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR JEFFERSON 416-7340 KLR	4/29/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - RIVERVIEW MID LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	rm 128 needs bearing replaced	7/15/13			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	AHU NOT COOLING IN RM-212(083) RM-215(079) RM-207(089) RM-206B(090) TEACHERS' LOUNGE(126) RM-219. SBE-LINDA/650-0389	7/24/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	UNITS NOT COMING ON MAIN BAND RM(139), PRACTICE RM, AUDIT(018), RM-113, RM-110. SBE-LINDA/650-0389	7/24/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	5/9/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - Oil Lube & Belt- Riverview Middle - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	per jefferson 416-7460 chiller down	5/12/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	A/C RM 215-NOT COOLING- PLANT MGR JEFFERSON 416-7430 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	CHILLER MECH RM-NOT COOLING-AFFECTS THE BLDG-PLANT MGR JEFFERSON 416-7360 KLR	5/13/14			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	5/25/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	main office chiller --- bad fan motor and check other compressor	5/28/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - RIVERVIEW MID LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	CHILL WATER PUMP MECH RM-NOT COOLING & MAKING NOISES, CAUSING THE CHILLER NOT TO KICK ON- PLANT MGR JEFFERSON 416-7360 KLR	6/3/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	AHU NOT COOLING IN MAIN OFFICE. PLANT MGR- JEFFERSON/416.7340	8/12/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	A/C IN LIBRARY-BLOWING TOO COLD-REQUESTED BY B SHIPP KLR	8/20/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	rm 111 over cooling	8/21/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	8/26/13			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	UV NOT COOLING IN RM-219 PLANT MGR- JEFFERSON/416.7340	8/28/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	9/4/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Yearly - Oil Samples-Riverview Middle - Refer to PM schedule details.	9/14/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	A/C unit in ROOM 208 is NOT COOLING per Mr. Jefferson, Plant Mgr. 416.7360	9/18/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	9/23/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	9/26/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	9/30/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	chiller down	10/3/13			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	Monthly - Oil Lube & Belt- Riverview Middle - Refer to PM schedule details.	10/6/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Chiller is NOT COOLING per Mr. Ervin, Plant Mgr. 416.7340	10/14/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	A/C unit in ROOM 208 has a BURNING SMELL per Mr. Ervin, Plant Mgr. 315.6847	10/15/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	check 4 pipe	10/17/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Monthly - Filter-Riverview Middle - Refer to PM schedule details.	10/25/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	financial office hot	11/8/13	1st Floor	main office	Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	check leak for plumber	11/8/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	boiler down	11/13/13			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	HEAT IN MAIN OFC - NOT HEATING - PM/ERVIN 416-7360	11/21/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Unit Ventilators are NOT HEATING in ROOMS 201 THRU 219 per Mr. Ervin, Plant Mgr. 416.7360	11/26/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	rm 201 overheating	12/2/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	UV IS OVERHEATING (90) IN RM-205 PLANT MGR-JEFFERSON/649.6525	12/18/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	UNIT ARE OVERHEATING IN MAIN OFFICE, RM-117 PLANT MGR-JEFFERSON/416.7630	12/18/13			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	boiler down	1/2/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	BOILER-1 & BOILER-2-BOTH NOT HEATING BLDG-PLANT MGR JEFFERSON 416-7340 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	HEAT LIBRARY, RMS 210 & 214-ALL NOT HEATING-PLANT MGR JEFFERSON 416-7430 KLR	1/7/14			Heating/Ventilation /Air Conditioning

Riverview Middle (2625) 1A	bleed air off heating system	1/9/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	HEAT RM 202-NOT HEATING-PLANT MGR JEFFERSON 416-7430 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Units are NOT HEATING in ROOMS 202, 206, and 211 per Mr. Jeffries, Plant Mgr. 416.7340	1/24/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	boiler down	1/31/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Daily - RIVERVIEW MID LVL 1 WATER TREATMENT - Refer to PM schedule details.	2/2/14			Heating/Ventilation /Air Conditioning
Riverview Middle (2625) 1A	Paint and patch all classrooms that TV'S were taken down. Thank you	6/6/14	Classroom		Painting
Riverview Middle (2625) 1A	paint all outside doors	7/9/13			Painting
Riverview Middle (2625) 1A	paint fin sec. office	7/16/13			Painting

Riverview Middle (2625) 1A	Paint new concrete work (repair) in science lab to match existing.	7/19/13	1st Floor		Painting
Riverview Middle (2625) 1A	Paint/stain plywood for for existing 3 lab table/desks. Support Jason Zone 1b. Thanks	6/6/14	Classroom		Painting
Riverview Middle (2625) 1A	Remove toilets from girls restroom.	6/17/14	1st Floor		Plumbing
Riverview Middle (2625) 1A	Remove toilets from boys restroom 2 each.	6/17/14	1st Floor		Plumbing
Riverview Middle (2625) 1A	Provide and install 4 new child toilets in girls restroom.	6/17/14	1st Floor		Plumbing
Riverview Middle (2625) 1A	Provide and install 2 new child toilets in boys restroom.	6/17/14	1st Floor		Plumbing
Riverview Middle (2625) 1A	UNIT IS LEAKING WATER IN RM-218 PLANT MGR- JEFFERSON/649.6525	6/20/14			Plumbing
Riverview Middle (2625) 1A	Repair sink faucet.	6/23/14	Restroom (Girls)		Plumbing

Riverview Middle (2625) 1A	A/C RM 218-LEAKING-PLANT MGR JEFFERSON 416-7430 KLR	6/24/14			Plumbing
Riverview Middle (2625) 1A	UV 2ND FLR SW END BY STAIRWELL-LEAKING-PLANT MGR JEFFERSON 461-7430 KLR	6/24/14			Plumbing
Riverview Middle (2625) 1A	PIPE is LEAKING in the CEILING in ROOM 128 per Mr. Jefferson, Plant Mgr. 416.7430	6/26/14			Plumbing
Riverview Middle (2625) 1A	A/C UNIT PIPE is LEAKING in the Ceiling in ROOM 129 per Mr. Jefferson, Plant Mgr. 416.7430	6/26/14			Plumbing
Riverview Middle (2625) 1A	UNIT VENTILATOR is LEAKING in ROOM 218 per Mr. Jefferson, Plant Mgr. 416.7430	6/30/14			Plumbing
Riverview Middle (2625) 1A	Science lab, cut pipe even with floor.	7/31/13	1st Floor		Plumbing
Riverview Middle (2625) 1A	sink in the principals office restroom has a hole in it (broken) needs to be replaced.	8/8/13	Administration Area	principals office	Plumbing
Riverview Middle (2625) 1A	rm 128 needs drain blown out and clamps on drain tightened.	7/15/13			Plumbing

Riverview Middle (2625) 1A	rm 129 needs drain blown out and clamps on drain tightened	7/15/13			Plumbing
Riverview Middle (2625) 1A	Remove sinks in each of three science labs. Remove only stainless steel sinks mounted to wall.	7/17/13			Plumbing
Riverview Middle (2625) 1A	Locate water cut off for SBE. Home ec. room.	5/19/14			Plumbing
Riverview Middle (2625) 1A	Cut water off and cap Teachers lab table in room 125, 128 and 129. Remove fixtures and gas.	5/28/14	Classroom		Plumbing
Riverview Middle (2625) 1A	Repair/Replace 3" water flange valve. Located next to gym lower level hallway.	5/29/14			Plumbing
Riverview Middle (2625) 1A	Remove and cap all water pipes that penetrate wall in Home Economics.	5/29/14	Classroom		Plumbing
Riverview Middle (2625) 1A	Remove and cap all water pipes that penetrate floor in Home Economics.	5/29/14	Classroom		Plumbing
Riverview Middle (2625) 1A	Flush vales need repairing in boys locker room	6/4/14	1st Floor	119	Plumbing

Riverview Middle (2625) 1A	REPLACE HAND SINK IN OFFICE RESTROOM. CHINA SINK HAS CRACKED AND WILL NOT HOLD WATER.	8/8/13			Plumbing
Riverview Middle (2625) 1A	unstop sewer from kitchen	8/12/13			Plumbing
Riverview Middle (2625) 1A	AHU IS LEAKING WATER IN GUIDANCE OFFICE PLANT MGR- JEFFERSON/416.5730	8/14/13			Plumbing
Riverview Middle (2625) 1A	KITCHEN EQUIPMENT NEED PILOT LIT-WILL NEED FOR LUNCH-SBE JEFFERSON 416-7430 KLR	8/14/13			Plumbing
Riverview Middle (2625) 1A	Floor drains backing up.	8/19/13	Kitchen		Plumbing
Riverview Middle (2625) 1A	KITCHEN SINK IS LEAKING PLANT MGR- JEFFERSON/416.7340	8/28/13			Plumbing
Riverview Middle (2625) 1A	flush valve on urinal not working properly, (continuous flush) water overflowing to the floor, and hallways.	9/3/13	Restroom (Boys)	behind gym	Plumbing
Riverview Middle (2625) 1A	middle sink in girls restroom of 1st floor lobby area will not cut off with valve or cut-off under sink(water runs continuously)	9/24/13	Restroom (Girls)	1st floor	Plumbing

Riverview Middle (2625) 1A	commode in 3rd stall of girls restroom outside of room 210 will not stop flushing (unable to turn water off)	9/25/13	Restroom (Girls)	2nd floor	Plumbing
Riverview Middle (2625) 1A	sink near kitchen office, water runs continuously, will not shut off	10/3/13	Kitchen		Plumbing
Riverview Middle (2625) 1A	Repair faucets in boys RR basement.	10/10/13			Plumbing
Riverview Middle (2625) 1A	Floor drain stopped up in basement.	10/10/13			Plumbing
Riverview Middle (2625) 1A	boys restrm sink is leaking	10/16/13	2nd Floor	boy s res t rm	Plumbing
Riverview Middle (2625) 1A	Water leak from ceiling.	10/17/13			Plumbing
Riverview Middle (2625) 1A	floor drain stopped up	10/21/13	1st Floor	boy's locker rm	Plumbing
Riverview Middle (2625) 1A	water leaking in hallway	10/25/13	1st Floor	hallway next to auditorium	Plumbing

Riverview Middle (2625) 1A	urinal water running won't stop	11/1/13	2nd Floor	boy's restrm	Plumbing
Riverview Middle (2625) 1A	water leaking from air handle unit	11/6/13	2nd Floor	auditorium	Plumbing
Riverview Middle (2625) 1A	Repair/unstop floor drain in basement area.	12/5/13			Plumbing
Riverview Middle (2625) 1A	Repair sink b rr on 2nd floor.	12/23/13			Plumbing
Riverview Middle (2625) 1A	bleed off air in heating system	1/8/14			Plumbing
Riverview Middle (2625) 1A	Test and report on backflow prevention devices.	1/9/14			Plumbing
Riverview Middle (2625) 1A	URINAL B RR 2ND FLR BY RM 211-CONSTANTLY RUNNING AND OVERFLOWING ONTO FLR-PLANT MGR JEFFERSON 416-7340 KLR	1/30/14			Plumbing
Riverview Middle (2625) 1A	URINAL IS OVERFLOWING IN B/RR 2ND FLR WEST-END PLANT MGR- JEFFERSON/649.6525	2/6/14			Plumbing

Riverview Middle (2625) 1A	floor drain in boys restroom (2nd floor west end) outside 210 is not draining.	2/6/14	Restroom (Boys)	2nd floor	Plumbing
Riverview Middle (2625) 1A	floor drains in 2nd floor custodial closets are not draining	2/6/14	Custodial Closet	2nd floor	Plumbing
Riverview Middle (2625) 1A	Replace sink in principal's office ASAP per Brian Shipp	8/8/13			Plumbing
Riverview Middle (2625) 1A	water coming into room from under the wall where 1st floor roof connects to building (roof leak)	6/30/14	Administration Area	218	Roof
Riverview Middle (2625) 1A	roof leaking in classroom 108, water coming down from above window in the corner facing north	3/7/14	Classroom	108	Roof
Riverview Middle (2625) 1A	roof leaking in conference room next to principal's office	4/8/14	Administration Area	conference room	Roof
Riverview Middle (2625) 1A	roof leaking in classroom 208 near north west window in classroom (421304)	4/8/14	Classroom	208	Roof
Riverview Middle (2625) 1A	water leaking in stairway behind auditorum from roof, (#414709) sent 2/5/14	4/8/14	Hallway/Corridor	behind auditorum	Roof

Riverview Middle (2625) 1A	water leaking into room from under exterior wall (seal against building connection to roof)	9/23/13	Classroom	218	Roof
Riverview Middle (2625) 1A	roof leaking on stairwell	10/16/13	1st Floor	stairwell ceiling leaking	Roof
Riverview Middle (2625) 1A	roof leak in gym	12/10/13	Gym	main gym	Roof
Riverview Middle (2625) 1A	ceiling in classroom #203	12/10/13	Classroom	203	Roof
Riverview Middle (2625) 1A	water leaking into classroom in front of the window from roof.	12/13/13	Classroom	209	Roof
Riverview Middle (2625) 1A	water leaking from the roof onto the east end of basketball court in front of the goal.	1/9/14	Basketball Court	gym	Roof
Riverview Middle (2625) 1A	water from the connecting roof running into rooms 218 and 219 when it rains.	2/3/14	Classroom	218	Roof
Riverview Middle (2625) 1A	roof leak in the stairway behind the auditorium(southeast end of building) near room 113.	2/5/14	Stairway	back of auditorium	Roof

Riverview Middle (2625) 1A	Fabricate and cover with sheet metal all holes in old home economics classroom.	6/27/14	1st Floor		Sheet Metal
Riverview Middle (2625) 1A	Provide two sheets of 0125 Al, 30" by 40" for Jason M.	7/31/13	1st Floor		Sheet Metal
Riverview Middle (2625) 1A	locker jammed	10/16/13	2nd Floor	locker 473	Sheet Metal

Count of Craft	Craft									
Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
zelle ES (2630)	1	1	21	44	61	2	22	1	3	156
Grand Total	1	1	21	44	61	2	22	1	3	156

Location	Request Description	Submittal Dat	Area Descript	Area Number	Craft
Rozelle ES (2630) 1A	these rooms have some broken floor tiles in them and it poses a tripping hazard and need to be replaced.	6/13/14	3rd Floor	rms,22,24,30.	Asbestos
Rozelle ES (2630) 1A	Brian Shipp requests NCE staff to give support for installation of projector screen and possibly a projector at Rozelle - Contact the principal Carl Johnson, Principal at Rozelle, at 416-8785 (office) or 338-0393 (cell). for the screen etc. give report to Mr. Eddie Miller -- budget 2922-	3/19/14			Cabling
Rozelle ES (2630) 1A	CAFE FRONT DOOR, CANT SECURE PLANT MR-HAYES/378.2478	3/21/14			Carpentry
Rozelle ES (2630) 1A	we are requesting a dry erase board be put in this office,per principal johnson.	5/29/14	2nd Floor	financial secretaries office	Carpentry
Rozelle ES (2630) 1A	the cafeteria doors wont close properly. they get hung on each other and wont close.	9/9/13	Cafeteria	1st floor	Carpentry
Rozelle ES (2630) 1A	the door/stall door wont close properly.	9/26/13	2nd Floor	girls r/r	Carpentry
Rozelle ES (2630) 1A	floor tiles have crumbled and broken in the back of this classroom and students are picking with it.	9/26/13	3rd Floor	rm26	Carpentry

Rozelle ES (2630) 1A	there is a stall door at the very end of r/r that needs a new door handle a child cut her hand on that handle.	9/26/13	1st Floor	girls/r	Carpentry
Rozelle ES (2630) 1A	BROKEN WINDOW IN CAFE (TECH IS ALREADY ON SITE) PLANT MGR-HAYES/416.4612	10/1/13			Carpentry
Rozelle ES (2630) 1A	Replace window	10/11/13			Carpentry
Rozelle ES (2630) 1A	wood buckled on stairwell 3rd floor northeast and northwest per Mr. Hayes 416-8775	10/14/13			Carpentry
Rozelle ES (2630) 1A	on the northwest stairwell there is a hatch in the ceiling leading to the roof. the lock is not working properly and will just pop open exposing the building to rain ect.	10/14/13	3rd Floor	hatch to roof/ceiling	Carpentry
Rozelle ES (2630) 1A	the main entry door from the hallway wont close.	10/15/13	1st Floor	cafe.	Carpentry
Rozelle ES (2630) 1A	rozelle is welcoming sup.hopson on 10-31 and per principal johnson he is requesting missing baseboards on 1st floor and cafeteria be fixed.	10/28/13	1st Floor	hallway/cafe- ria	Carpentry
Rozelle ES (2630) 1A	Replace cove base where needed	10/29/13			Carpentry

Rozelle ES (2630) 1A	the handicap rail has come off of the wall on the handicap ramp.	12/2/13	1st Floor	rm5	Carpentry
Rozelle ES (2630) 1A	there is sheet rock that needs to be repaired.	12/4/13	1st Floor	rm.5	Carpentry
Rozelle ES (2630) 1A	this door cant be secured and is in need of repair.	2/3/14	1st Floor	cafe entrance	Carpentry
Rozelle ES (2630) 1A	there are two doors that wont close properly, principal johnson needs those doors to close properly as it poses a security problem.	3/24/14	Cafeteria	back of cafe	Carpentry
Rozelle ES (2630) 1A	there is a large hole in the wall north west wall up bu the serving line. the children are picking at it. we feel that this is a hazard to the children.	3/31/14	1st Floor	cafeteria	Carpentry
Rozelle ES (2630) 1A	there is another large hole in the wall of the girls restroom.	5/7/14	2nd Floor	girls/r	Carpentry
Rozelle ES (2630) 1A	principal johnson has already purchased a 12ft projection screen and now needs it to be installed in the auditorium. the projection screen is in room 7 on the first floor.	3/24/14	2nd Floor	auditorium	Carpentry
Rozelle ES (2630) 1A	principal johnson is requesting a 12feet projection screen to be put in the auditorium.	3/17/14	2nd Floor	auditorium	Carpentry

Rozelle ES (2630) 1A	it is believed to be the light ballast.	3/17/14	3rd Floor	rm31	Electrical
Rozelle ES (2630) 1A	there is a spot light out in the front of the building on a pole. the city light is on the front of the pole and the spotlight is on the back of the pole facing the building. it is dangerously dark out front.	5/13/14	Grounds	south main entrance	Electrical
Rozelle ES (2630) 1A	COOLING TOWER NOT COMING ON- AFFECTS THE AIR IN THE ENTIRE BLDG-PLANT MGR HAYES 416-8775 KLR	5/14/14			Electrical
Rozelle ES (2630) 1A	please disregard work order #436450, it was meant for peabody ele. thank you.	5/14/14	Grounds	south main entrance	Electrical
Rozelle ES (2630) 1A	there are 3 lights in a row thats out in this room. this room is where the state testing is done and where the principal conducts his meetings. it is very dark area.	3/17/14	3rd Floor	rm 31	Electrical
Rozelle ES (2630) 1A	NO POWER TO EMS BOARD-PLANT MGR HAYES KLR	6/6/14			Electrical
Rozelle ES (2630) 1A	PUMP-4 MECH RM-SMOKING REAL BAD-PLANT MGR HAYES 416-8775 KLR	6/10/14			Electrical
Rozelle ES (2630) 1A	lights bulb has been changed and light wont come on.	9/9/13	1st Floor	northeast stairwell	Electrical

Rozelle ES (2630) 1A	the light in the arch has been changed but still wont come on.	9/9/13	2nd Floor	2nd fl.	Electrical
Rozelle ES (2630) 1A	there are lights that are out in the arch that wont come on.	9/9/13	3rd Floor	hallway arch	Electrical
Rozelle ES (2630) 1A	there are lights in the cloak room that are flickering sometimes on sometimes off. i think its the ballast.	9/10/13	3rd Floor	rm19	Electrical
Rozelle ES (2630) 1A	there are a few lights that need ballast in cafe.	9/10/13	Cafeteria	1st fl.	Electrical
Rozelle ES (2630) 1A	there is a broke receptacle at the entrance of this room.	9/26/13	1st Floor	rm8	Electrical
Rozelle ES (2630) 1A	there are blinking lights in this room cloak rm. the parent said light is affecting childs vision.	10/8/13	3rd Floor	rm19	Electrical
Rozelle ES (2630) 1A	the dusk to dawn lights have gone out and it is very dark and we have had 3 break-ins, in that area.	10/25/13	Parking Lot	WEST parking lot	Electrical
Rozelle ES (2630) 1A	I can not get the fixture off of this light and this light is outside of the room supt.d hopson will have a reception 10-31-13 this thursday.	10/29/13	Stairway	southeast side	Electrical

Rozelle ES (2630) 1A	there is a light fixture where the bulbs have already been changed but wont come on.	10/29/13	1st Floor	rm5	Electrical
Rozelle ES (2630) 1A	there is a light in the kitchen where the bulbs have been changed but it still wont come on.	10/29/13	Kitchen	1stfl.	Electrical
Rozelle ES (2630) 1A	Repair lights	10/29/13			Electrical
Rozelle ES (2630) 1A	the main clock needs to be set to new time.	11/4/13	2nd Floor	main office	Electrical
Rozelle ES (2630) 1A	the christmas production is dec.18 and 19th and only 1(one) light works on the stage and there are 7 that dont work. there will be 3 members from the board in attendance on those evenings and we really need those lights to work. per principal johnson.	12/2/13	2nd Floor	auditorium	Electrical
Rozelle ES (2630) 1A	there is a light fixture thats in the ceiling that appears not to be stable in the ceiling. Its partially hanging we believe it is a very, very hazardous situation.	12/2/13	2nd Floor	auditorium	Electrical
Rozelle ES (2630) 1A	set clocks for new times for bells to ring. Monday, Wednesday and Friday: 7:30, 7:45, 8:00, 9:30, 9:35, 10:25, 10:30, 11:45, 11:50, 12:20, 12:25, 1:35, 1:40,2:50 3:00, 3:15	1/7/14			Electrical
Rozelle ES (2630) 1A	there are 4 lights that need ballast	1/13/14	3rd Floor	ROOM26	Electrical

Rozelle ES (2630) 1A	lights out need ballast.	1/13/14	2nd Floor	north wing hallway	Electrical
Rozelle ES (2630) 1A	there is one light out and it needs a ballast.	1/13/14	1st Floor	by south stairwell	Electrical
Rozelle ES (2630) 1A	there are 4 light fixtures that wont come on. the lights have been changed but they still wont come on.	8/5/13	Kitchen	1st fl	Electrical
Rozelle ES (2630) 1A	music rm --- run electrical for a/c unit	8/16/13			Electrical
Rozelle ES (2630) 1A	HEAT LIBRARY AREA-NOT COMING ON-PLANT MGR HAYES 416-8775 KLR	2/3/14			Electrical
Rozelle ES (2630) 1A	the lights in this cloak room have been changed but still wont come on	2/3/14	3rd Floor	rm22	Electrical
Rozelle ES (2630) 1A	the master clock needs to be set for daylight savings by march 9,2014.	2/27/14		main office	Electrical
Rozelle ES (2630) 1A	LIGHTS RM 18-HALF JUST WENT OUT PER SBE-HALF OF RM IS DARK-PLANT MGR HAYES 416-8775 KLR	3/25/14			Electrical

Rozelle ES (2630) 1A	A/C AUDITORIUM ONE SIDE-NOT COMING ON-PLANT MGR HAYES 416-4612 KLR	4/3/14			Electrical
Rozelle ES (2630) 1A	after changing the lights there are two fixtures that wont come on.	4/8/14	1st Floor	library	Electrical
Rozelle ES (2630) 1A	after changing two lights they still wont come on.	4/8/14	1st Floor	rm6	Electrical
Rozelle ES (2630) 1A	after changing the lights out in this r/r the lights still wont come on/flickering.	4/9/14	1st Floor	girls restroom	Electrical
Rozelle ES (2630) 1A	after changing the lights out one light fixture still would not come on.	4/11/14	1st Floor	rm3	Electrical
Rozelle ES (2630) 1A	UNIT NOT COMING ON IN RM-1,2,3,4,5,8,9 PLANT MGR-HAYES/416.4612	4/14/14			Electrical
Rozelle ES (2630) 1A	the dusk till dawn lights outside of the library and both main entrances are not working properly or are out and we need these areas to be well lighted.per principal johnson.	4/22/14	Grounds	the front of building	Electrical
Rozelle ES (2630) 1A	the bella are about 7minutes off at rozelle and they need to be put on the right time.	4/22/14			Electrical

Rozelle ES (2630) 1A	there is a light thats out in the hallway high up in the ceiling and it is very dark, its right by the stairwell.	4/25/14	2nd Floor	west hallway	Electrical
Rozelle ES (2630) 1A	please disregard new request #432084.	4/25/14	2nd Floor	west hallway	Electrical
Rozelle ES (2630) 1A	the washing machine keeps blowing fuse no.33 everytime the cafe manager turns it on.	8/22/13			Electrical
Rozelle ES (2630) 1A	WE DONT HAVE ANY LIGHTS ON SITE.WE NEED 3 CASES,T-8 LIGHTS AS SOON AS POSSIBLE,THANK YOU.	1/15/14			Electrical
Rozelle ES (2630) 1A	Monthly - ROZELLE ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	6/24/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Provide and install two chemical feed pumps for HVAC system.	8/20/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT PRIN'S OFC-MAKING NOISES-PLANT MGR HAYES 416-8775 KLR	1/16/14			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	1/21/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Yearly - Cooling Towers(STRAINERS)- Rozelle Elem - Refer to PM schedule details.	3/21/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	A/C EXECUTIVE SUITE, RM 12, 10, & 4- ALL NOT COOLING-PLANT MGR HAYES 416-4612 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	water temp. too high --- reading 104 deg. needs to be about 76 deg.	4/28/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	princ. ofc	4/28/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	4/29/14			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	Monthly - ROZELLE ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	per hayes 416-8775 room 26 blowing hot	5/7/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	A/C AUDITORIUM-NOT COOLING-PLANT MGR HAYES 416-8775 KLR	5/8/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	recharge system on auditorium	5/12/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	5/13/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	UNIT is NOT COOLING in ROOM 5 per Mr. Hayes, Plant Mgr. 416.8775	5/14/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	water temp too high -- units not cooling throughout building	5/15/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	keystone actuator not sending water to tower --- repair linkage and replace actuator if needed.	5/22/14			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	5/27/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	rebuild keystone actuator for cooling tower	5/29/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	6/10/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	install t-stat on music rm	9/10/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT PUMP NOT COOLING IN MAIN OFFICE PLANT MGR-HAYES/416.8775	9/16/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - Oil Lube & Belt-Rozelle Elem - Refer to PM schedule details.	9/24/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	room 2 a/c not cooling per Mr. Hayes 416-8775	9/30/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	c/o to heat	11/4/13			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	check boiler	11/12/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	2-BOILERS NOT COMING ON. PLANT MGR-HAYES/378.2478	11/12/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT MAIN OFC AREA, RMS 20 & 23- ALL NOT HEATING-PLANT MGR HAYES 416-4606 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT RMS 16, 17, & 20-ALL NOT HEATING-PLANT MGR HAYES 416-8775 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	various locations --- chemical treatment with Brian Wells	12/3/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT RMS 17, 16, 20, 31, & MAIN OFC- ALL NOT HEATING-PLANT MGR HAYES 416-8775 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	per Ms. Harris (custodial worker) the red light is on and indicates low water temp and it is cold in building 416-8771	12/10/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - Filter-Rozelle Elementary - Refer to PM schedule details.	12/17/13			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	need power to blow down solenoid on chemical treatment	1/13/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	reolace unit in music rm	7/26/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	install portable in music rm	7/29/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	RTU AUD ROOF SE-NOT COOLING-CALLED IN BY PRIN JOHNSON 416-4612 KLR	8/9/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	AHU NOT COOLING IN RM-3,4, PLANT MGR OFFICE. PLANT MGR-HAYES/378.2478	8/12/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - Filter-Rozelle Elementary - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT AUDITORIUM & RM 14-BOTH NOT HEATING-PLANT MGR HAYES 416-8775 KLR	1/29/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	2/4/14			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	UNIT is NOT HEATING in ROOM 17 per Mr. Hayes, Plant Mgr. 416.8775	2/11/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	HEAT AUDITORIUM-NOT HEATING-PLANT MGR HAYES 416-8775 KLR	2/11/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	2/18/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	rm 17 not heating	2/18/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	UNIT is NOT HEATING in ROOM 26 per Mr. Hayes, Plant Mgr. 416.8775	2/19/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	flush units in rms 17 and 26	2/20/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - ROZELLE ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	3/4/14			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	4/1/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	check pump 2 and 4	4/2/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - ROZELLE ELEM LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	UNIT NOT COOLING IN RM-4 PLANT MGR-HAYES/378.2478	4/14/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	per mr hays 416-8775 1st and 2nd floors blowing hot air	4/14/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - Filter-Rozelle Elementary - Refer to PM schedule details.	4/15/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Daily - Rozelle Elem Level 1 Water Treatment - Refer to PM schedule details.	4/15/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	Monthly - Oil Lube & Belt-Rozelle Elem - Refer to PM schedule details.	4/22/14			Heating/Ventilation /Air Conditioning

Rozelle ES (2630) 1A	Yearly - W.C.C Filter - Rozelle Elementary Refer to PM schedule details.	3/7/14			Heating/Ventilation /Air Conditioning
Rozelle ES (2630) 1A	the rails at the front entrance steps need to be painted.	4/23/14	Grounds	the front steps	Painting
Rozelle ES (2630) 1A	rozelle is welcoming sup.hopson, per principal johnson he is asking for paint touch ups in hallways.	10/28/13		1st2nd3rd floors	Painting
Rozelle ES (2630) 1A	urinal stopped up and sink leaking	5/9/14	1st Floor	boys r/r	Plumbing
Rozelle ES (2630) 1A	sinks leaking, 2 toilets loose. 1 toilet not flushing	5/9/14	1st Floor	girls/r	Plumbing
Rozelle ES (2630) 1A	toilet leaking and sink not working.	5/9/14	2nd Floor	boysr/r	Plumbing
Rozelle ES (2630) 1A	toilet and urinal leaking.	5/9/14	3rd Floor	boysr/r	Plumbing
Rozelle ES (2630) 1A	toilet leaking.	5/9/14	3rd Floor	girls/r	Plumbing

Rozelle ES (2630) 1A	the toilet stopped up.	5/12/14	2nd Floor	boysr/r	Plumbing
Rozelle ES (2630) 1A	the toilet loose.	5/12/14	2nd Floor	teachers lounge	Plumbing
Rozelle ES (2630) 1A	the toilet stopped up.	5/12/14	3rd Floor	boysr/r	Plumbing
Rozelle ES (2630) 1A	Check hot water in kitchen	5/22/14			Plumbing
Rozelle ES (2630) 1A	the mop sink is clogged, we tried to plunge it but its still clogged.	6/18/14	2nd Floor	custodial closet	Plumbing
Rozelle ES (2630) 1A	The water cooler on the 1st floor hall south end has a low water flow, to low for drinking. The equipment ID# is 052-017.	9/3/13	Hallway/Corridor	1st floor	Plumbing
Rozelle ES (2630) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	10/31/13			Plumbing
Rozelle ES (2630) 1A	there is a sink thats coming away from the wall and it looks dangerous.	12/10/13	3rd Floor	girls/r	Plumbing

Rozelle ES (2630) 1A	there is a toilet thats stopped up in the boys r/r on the 2nd floor.	12/17/13	2nd Floor	boysr/r	Plumbing
Rozelle ES (2630) 1A	there is toilet leaking in the girls r/r.	7/31/13	1st Floor	girls r/r	Plumbing
Rozelle ES (2630) 1A	there is a toilet leaking.	8/5/13	1st Floor	girls r/r	Plumbing
Rozelle ES (2630) 1A	music rm --- reroute water lines to a/c unit --- reuse flex hoses and circuit setter	8/16/13			Plumbing
Rozelle ES (2630) 1A	music rm --- reroute drain for a/c unit	8/16/13			Plumbing
Rozelle ES (2630) 1A	when the drain in this closet becomes dry it gives off a fecies odor. i dont mind putting something in the hole/drain however i cant get to that drain. we are asking that some thing could be done so that l/we can get to the drain/hole without incidents to put something in it.	4/14/14	1st Floor	rm1	Plumbing
Rozelle ES (2630) 1A	we have tried to plunge this toilet and still cant get it unclogged.	4/15/14	Kitchen	restroom	Plumbing
Rozelle ES (2630) 1A	there is a sink leaking in the girls r/r on the first floor.	4/22/14	1st Floor	girls/r	Plumbing

Rozelle ES (2630) 1A	BROWN WATER THRU ENTIRE BLDG. PLANT MGR-HAYES/378.2478	1/23/14			Plumbing
Rozelle ES (2630) 1A	there is a roof leak in that stairwell.	5/14/14	3rd Floor	northwest/stairwell	Roof
Rozelle ES (2630) 1A	remove duct work from unit in boiler rm	7/29/13			Sheet Metal
Rozelle ES (2630) 1A	music rm --- duct work for a/c unit	8/16/13			Sheet Metal
Rozelle ES (2630) 1A	the metal drain needs to be rerouted under these stairs just like it was done on the northwest side so that the water will drain properly and not puddle. per principal johnson.	4/22/14	Grounds	southwest fire escape	Sheet Metal

Count of Craft	Craft							
Location	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
enic Hills El (2633)	36	52	39	5	31	1	3	167
Grand Total	36	52	39	5	31	1	3	167

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Scenic Hills El (2633) 1B	Metal plate on walkway from main building to annex building is bend need repairing.	8/29/13			Carpentry
Scenic Hills El (2633) 1B	Handrails on portable 333.	9/3/13	Portables		Carpentry
Scenic Hills El (2633) 1B	The office swing door near counter is broken	9/10/13			Carpentry
Scenic Hills El (2633) 1B	REAR KITCHEN DOOR-NOT CLOSING- WON'T BE ABLE TO SECURE-PLANT MGR LADD 416-4342 KLR	10/2/13			Carpentry
Scenic Hills El (2633) 1B	Classroom 202 door need repairing	7/18/13			Carpentry
Scenic Hills El (2633) 1B	Vent grids broken in classroom 209, due to a previous Ac unit repair.	7/18/13			Carpentry
Scenic Hills El (2633) 1B	Reinstall ceiling gride and tile under unit vent.	7/25/13	2nd Floor	Rm 209	Carpentry
Scenic Hills El (2633) 1B	Back kitchen employee RR door is stuck per Ms. Ladd, Plant Mgr. at 901.416.4342. (There's someone stuck in the RR)	8/16/13			Carpentry
Scenic Hills El (2633) 1B	Gutter fell and hanging from portable	8/23/13			Carpentry
Scenic Hills El (2633) 1B	Classroom 210 in annex area door knob is broken	8/23/13			Carpentry

Scenic Hills El (2633) 1B	BROKEN WINDOW IN RM-212. PLANT MGR-LADD/321.1000	10/25/13			Carpentry
Scenic Hills El (2633) 1B	room 202 lockers fell off wall per Ms. Ladd 416-4342	11/20/13			Carpentry
Scenic Hills El (2633) 1B	Classroom 103 door knob need repairing	12/20/13			Carpentry
Scenic Hills El (2633) 1B	Library door knob need repairing	1/6/14			Carpentry
Scenic Hills El (2633) 1B	BROKEN WINDOW IN CAFE PLANT MGR-LADD/416.4342	1/15/14			Carpentry
Scenic Hills El (2633) 1B	Exit door need repairing in kitchen area	1/21/14			Carpentry
Scenic Hills El (2633) 1B	Classroom 209 window need repairing	1/23/14			Carpentry
Scenic Hills El (2633) 1B	per ms ladd 416-4342 rooms 206 door knob fell off and can't open room	2/7/14			Carpentry
Scenic Hills El (2633) 1B	Cafeteria exit door knob broken	3/7/14			Carpentry
Scenic Hills El (2633) 1B	4 stall doors need replacing in boys restroom on 2nd floor in main building	7/9/13			Carpentry
Scenic Hills El (2633) 1B	1 stall door need replacing in girls restroom on 2nd floor in main building	7/9/13			Carpentry

Scenic Hills EI (2633) 1B	1 stall door need replacing in boys restroom on main hall	7/9/13			Carpentry
Scenic Hills EI (2633) 1B	Plant manager office wood on portable porch need replacing, very hazardous	7/10/13			Carpentry
Scenic Hills EI (2633) 1B	4 stall doors need replacing in boys restroom on 1st floor in annex building	7/10/13			Carpentry
Scenic Hills EI (2633) 1B	4 stall doors need replacing in boys restroom on 2nd floor in annex building	7/10/13			Carpentry
Scenic Hills EI (2633) 1B	Stall door need repairing in girls restroom on west end hall in main building	7/17/13			Carpentry
Scenic Hills EI (2633) 1B	Exit doors beside boys restroom near cafeteria need weather strips.	4/14/14			Carpentry
Scenic Hills EI (2633) 1B	Petition in main office need repairing	4/22/14			Carpentry
Scenic Hills EI (2633) 1B	WINDOW CAFE AREA-BLOWN OUT BY HIGH WINDS-WON'T BE ABLE TO SECURE-PLANT MGR LADD 416-4342 KLR	4/28/14			Carpentry
Scenic Hills EI (2633) 1B	WINDOW HAS CAME COMPLETELY OUT IN RM-204 PLANT MGR-LADD/416.4342	4/28/14			Carpentry
Scenic Hills EI (2633) 1B	Replcce double set of door, already on location.	5/6/14	Stairway	North East Main fr.	Carpentry
Scenic Hills EI (2633) 1B	Classroom 210 door knob need repairing	5/9/14			Carpentry

Scenic Hills EI (2633) 1B	WINDOW 2ND FLR RM 204-BROKEN OUT-PLANT MGR LADD 416-4346 KLR	5/9/14			Carpentry
Scenic Hills EI (2633) 1B	Window broken.	5/16/14	Classroom	1st Floor main bldg.	Carpentry
Scenic Hills EI (2633) 1B	Classroom 206 door knob is broken	7/2/13			Carpentry
Scenic Hills EI (2633) 1B	Portable 330 door need repairing	2/21/14			Carpentry
Scenic Hills EI (2633) 1B	Install Lutron lighting controls in common areas.	2/27/14			Electrical
Scenic Hills EI (2633) 1B	light not working on west end staircase in main building	8/30/13			Electrical
Scenic Hills EI (2633) 1B	ELECTRICAL POLE OUTSIDE NEXT TO BLDG-LEAKING A SUBSTANCE OUT PER SBE-PLANT MGR LADD 416-4342 KLR	9/13/13			Electrical
Scenic Hills EI (2633) 1B	2 ballants out in boiler room	9/13/13			Electrical
Scenic Hills EI (2633) 1B	Ballant need replacing in classroom 101	9/26/13			Electrical
Scenic Hills EI (2633) 1B	Classroom 107 and 108 need bulb changing in restroom, high reach area	9/26/13			Electrical
Scenic Hills EI (2633) 1B	Classroom 112A in annex area need 2 ballants	10/4/13			Electrical

Scenic Hills EI (2633) 1B	I need 3 cases of T8 light bulbs	10/4/13			Electrical
Scenic Hills EI (2633) 1B	LIGHT FIXTURE RM 106-MADE A LOUD POPPING NOISE & WENT OUT PER SBE- PLANT MGR LADD 416-4342 KLR	10/23/13			Electrical
Scenic Hills EI (2633) 1B	2 Ballants need replacing in classroom 106	10/23/13			Electrical
Scenic Hills EI (2633) 1B	Ballant need replacing on west end hall in main building	7/18/13			Electrical
Scenic Hills EI (2633) 1B	I need 2 cases of T8 light bulbs (See Jim D. before proceeding).	7/22/13			Electrical
Scenic Hills EI (2633) 1B	Set bells on new time	7/29/13			Electrical
Scenic Hills EI (2633) 1B	2 ballants need replacing in cafeteria near entrance doors	8/5/13			Electrical
Scenic Hills EI (2633) 1B	Cafeteria need 2 ballants replace	8/5/13			Electrical
Scenic Hills EI (2633) 1B	Classroom 101 ballant need replacing	8/26/13			Electrical
Scenic Hills EI (2633) 1B	2 ballants need replacing in cafeteria area	8/26/13			Electrical
Scenic Hills EI (2633) 1B	POWER OUTAGE IN PORT-305A. PLANT MGR-LADD/921.1000	10/31/13			Electrical

Scenic Hills EI (2633) 1B	RECEPTACLE RM 200-MAKING A LOUD NOISE PER SBE-PLANT MGR LADD 416-4342 KLR	11/4/13			Electrical
Scenic Hills EI (2633) 1B	Clocks need reset	11/4/13			Electrical
Scenic Hills EI (2633) 1B	Ballant need replacing on main hall	11/11/13			Electrical
Scenic Hills EI (2633) 1B	6 ballants need replacing in SBE office	11/14/13			Electrical
Scenic Hills EI (2633) 1B	Install proper electrical outlet for new popcorn popper.	12/5/13			Electrical
Scenic Hills EI (2633) 1B	RTU NOT COMING ON IN CAFE PLANT MGR-LADD/416.4342	12/9/13			Electrical
Scenic Hills EI (2633) 1B	Classroom 104 need a ballant replacing	12/9/13			Electrical
Scenic Hills EI (2633) 1B	Classroom 106 light bulb need replaced in restroom (high reach area)	12/13/13			Electrical
Scenic Hills EI (2633) 1B	Bulb need replacing on outside light pole on parking lot	12/20/13			Electrical
Scenic Hills EI (2633) 1B	3 light bulbs need replacing in high areas located in kitchen area	1/13/14			Electrical
Scenic Hills EI (2633) 1B	1 light cover need repairing in storage room located in kitchen area	1/13/14			Electrical

Scenic Hills EI (2633) 1B	1 light need replacing in storage room located in kitchen area	1/13/14			Electrical
Scenic Hills EI (2633) 1B	light bulb in high area need replacing in custodian closet	1/13/14			Electrical
Scenic Hills EI (2633) 1B	Fire pull station in kitchen area needs a protective cover	1/15/14			Electrical
Scenic Hills EI (2633) 1B	power outlet on serving line is not working	1/21/14			Electrical
Scenic Hills EI (2633) 1B	CEILING UNIT MAKING NOISE IN LIBRARY PLANT MGR-LADD/416.4342	1/28/14			Electrical
Scenic Hills EI (2633) 1B	Classroom 112A smoke detector in trouble.	2/13/14			Electrical
Scenic Hills EI (2633) 1B	2 light cover need replacing in cafeteria pantry	3/7/14			Electrical
Scenic Hills EI (2633) 1B	Receptacle need replacing on serving line located in kitchen area	3/7/14			Electrical
Scenic Hills EI (2633) 1B	i need 2 cases of T12 light bulbs	3/17/14			Electrical
Scenic Hills EI (2633) 1B	3 light bulbs need replacing in high area located in kitchen	3/17/14			Electrical
Scenic Hills EI (2633) 1B	I need 3 cases of T8 light bulbs	3/18/14			Electrical

Scenic Hills EI (2633) 1B	Disconnect electrical from boiler, so contractor can install replacement.	3/19/14	Mechanical Room	Boiler Room	Electrical
Scenic Hills EI (2633) 1B	Clock making noise on 1st floor annex building	7/10/13			Electrical
Scenic Hills EI (2633) 1B	Clock not working on 2nd floor annex building	7/10/13			Electrical
Scenic Hills EI (2633) 1B	Classroom 106 plug not working on ceiling area	4/22/14			Electrical
Scenic Hills EI (2633) 1B	Disconnect and remove power that feed temp. boiler.	4/29/14	Mechanical Room		Electrical
Scenic Hills EI (2633) 1B	Light ballant need replacing in main hall	5/16/14			Electrical
Scenic Hills EI (2633) 1B	Clocks need changing, due to daylight saving	2/25/14			Electrical
Scenic Hills EI (2633) 1B	Ballant need replacing in main hall	3/20/14			Electrical
Scenic Hills EI (2633) 1B	Wire new boilers	4/2/14	Mechanical Room		Electrical
Scenic Hills EI (2633) 1B	Clocks need resetting, bells not ringing	4/7/14			Electrical
Scenic Hills EI (2633) 1B	I need a case of 75 watt light bulbs for restrooms	4/11/14			Electrical

Scenic Hills EI (2633) 1B	Classroom 105 restroom light need replacing in high reach area.	4/11/14			Electrical
Scenic Hills EI (2633) 1B	RTU NOT COOLING IN RM-206 PLANT MGR-LADD/416.4342	9/16/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	2nd floor 1/2 of the floor is not cooling on one side per Ms. ladd 416-4342	9/25/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	A/C ENTIRE 1ST FLR RMS 109, 110, 111, 112, 113, 114, & 115-ALL NOT COOLING- PLANT MGR LADD 416-4342 KLR	10/2/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	a/c over cooling (valve stuck) in following rooms 213A, 210A, 109A, 110A, 105, 200, 206 per Ms. Ladd 416-4342	10/17/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Room 109A (annex) id# 233076 a/c not working Room 204 id#233068 a/c not cooling per Ms. ladd 416-4342 see journal notes.	8/1/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Monthly - Oil Lube & Belt-Scenic Hills Elementary - Refer to PM schedule details.	8/20/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	per Ms. Ladd 416-4342 room 200 and 201 unit is overheating	10/30/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	HEAT RMS 206, 207, 208, & 209-ALL ARE OVERHEATING-TEMP IS 95 PER SBE- PLANT MGR LADD 416-4342 KLR	11/22/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	HEAT RM 205-NOT HEATING-PLANT MGR LADD 416-4342 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	room 215A (annex bldg) blowing cold air per ms. ladd 416-4342	11/26/13			Heating/Ventilation /Air Conditioning

Scenic Hills El (2633) 1B	BOILER is NOT HEATING. No heat in the entire building per Ms. Ladd, Plant Mgr. 416.4342	12/2/13			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	HEAT ANNEX BLDG-NOT HEATING-PLANT MGR LADD 416-4346 KLR	12/5/13			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	BOILER IS IN ALARM PLANT MGR-LADD/416.4342	12/10/13			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	Unit is NOT HEATING in CLASSROOM 212A per Ms. Ladd, Plant Mgr. 416.4342	12/13/13			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	Units are NOT HEATING in ROOMS 205 & 206 per Ms. Ladd, Plant Mgr. 416.4342	1/6/14			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	HEAT RM 209-NOT HEATING-PLANT MGR LADD 41604342 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	per ms ladd 416-4342 the boiler is down	1/7/14			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	HEATING UNIT RM 105-MAKING NOISES- PLANT MGR LADD 416-4342 KLR	1/13/14			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	Unit is NOT HEATING in ROOM 212 per Ms. Ladd, Plant Mgr. 416.4342	1/16/14			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	HEAT RM 204-MAKING NOISES & OVERHEATING-TEMP IS 80-PLANT MGR LADD 416-4342 KLR	1/17/14			Heating/Ventilation /Air Conditioning
Scenic Hills El (2633) 1B	BOILER IS IN ALARM. PLANT MGR-LADD/416.4342	1/21/14			Heating/Ventilation /Air Conditioning

Scenic Hills EI (2633) 1B	2-CEILING UNITS NOT HEATING IN RM-215A,106 PLANT MGR-LADD/416.4342	1/28/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	HEAT RM 110A-NOT HEATING-PLANT MGR LADD 416-4342 KLR	1/28/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	room 212 blowing cold air per Ladd 416-4342	1/31/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	BOILER is NOT HEATING the BUILDING per Ms. Ladd, Plant Mgr. 416.4342	2/6/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Install temp boiler	2/10/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	purchase two new boilers-os	2/12/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	HEAT RM 128-NOT HEATING-PLANT MGR LADD 416-4346 KLR	2/12/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	per ms ladd 416-4342 room 106 not cooling and room 101 too cold	4/29/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	A/C RM 106-NOT COOLING-PLANT MGR LADD 416-4342 KLR	5/6/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	UNIT NOT COOLING IN COMPUTER TOWER RM MAIN OFFICE PLANT MGR-LADD/416.4342	5/9/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	A/C UNIT is NOT COOLING in the MAIN OFFICE per Ms. Ladd, Plant Mgr. 416.4342	5/27/14			Heating/Ventilation /Air Conditioning

Scenic Hills EI (2633) 1B	RTU - ENTIRE BLDG - BLOWING NOT COOLING - PM/LADD 416-4342	6/23/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Install new boilers	3/21/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Monthly - Oil Lube & Belt-Scenic Hills Elementary - Refer to PM schedule details.	3/25/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Monthly - Filter-Scenic Hills Elementary - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Monthly - Filter-Scenic Hills Elementary - Refer to PM schedule details.	2/21/14			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Monthly - Filter-Scenic Hills Elementary - Refer to PM schedule details.	10/25/13			Heating/Ventilation /Air Conditioning
Scenic Hills EI (2633) 1B	Girls restroom need painting on west end hall in main building	7/17/13			Painting
Scenic Hills EI (2633) 1B	Classroom 211 and 212 need painting	7/2/13			Painting
Scenic Hills EI (2633) 1B	2nd floor in main building all classroom doors need painting	7/2/13			Painting
Scenic Hills EI (2633) 1B	2nd floor hall need painting	7/2/13			Painting

Scenic Hills El (2633) 1B	:GRAFFITI ON OUTSIDE OF ANNEX BLDG . PLANT MGR-LADD/416.4342	10/21/13			Painting
Scenic Hills El (2633) 1B	Pipe leaking behind ice machine	9/6/13			Plumbing
Scenic Hills El (2633) 1B	Outside faucet located in front of school need a leak repair	10/3/13			Plumbing
Scenic Hills El (2633) 1B	Test and repair RP Devices per MLG&W.	10/10/13	Mechanical Room		Plumbing
Scenic Hills El (2633) 1B	A/C UNIT IS LEAKING WATER IN RM-200. SBE-JEFFERSON/416-1319	7/24/13			Plumbing
Scenic Hills El (2633) 1B	PORT 330A-HAS NO WATER ALL TO IT- CAN'T FLUSH COMMODES OR NOTHING PER SBE-SBE LADD 416-4342 KLR	8/7/13			Plumbing
Scenic Hills El (2633) 1B	WATER FOUNTAIN MAIN FLR BY G RR- HAS COME COMPLETELY OFF THE WALL- SBE LADD 416-4342 KLR	8/8/13			Plumbing
Scenic Hills El (2633) 1B	:GAS SMELL IN KITCHEN AREA-PLANT MGR LADD 416-4342 KLR	8/13/13			Plumbing
Scenic Hills El (2633) 1B	UV-6 BLDG 1 RM 204-LEAKING-SBE LADD 416-4342 KLR	8/19/13			Plumbing
Scenic Hills El (2633) 1B	SINK WATER CONTINUES TO RUN, CANT CONTROL IN B/RR 2ND FLR ANNEX PLANT MGR-LADD/416.4342	8/22/13			Plumbing
Scenic Hills El (2633) 1B	Water leak in courtyard on South side of kitchen	8/26/13			Plumbing

Scenic Hills EI (2633) 1B	Sink need repairing in boys restroom on 2nd floor in annex building	8/29/13			Plumbing
Scenic Hills EI (2633) 1B	Sink leaks in boys restroom on 1st floor in main building	11/22/13			Plumbing
Scenic Hills EI (2633) 1B	Push button broken on water fountain in cafeteria	11/22/13			Plumbing
Scenic Hills EI (2633) 1B	GAS SMELL ON EAST-SIDE BY ANNEX PLANT MGR-LADD/416-4342	12/17/13			Plumbing
Scenic Hills EI (2633) 1B	PILOT needs to be LIT in KITCHEN AREA per Ms. Ladd, Plant Mgr. 416.4342	2/11/14			Plumbing
Scenic Hills EI (2633) 1B	Check out low water level on temporary boiler, boiler keeps dropping out.	3/4/14			Plumbing
Scenic Hills EI (2633) 1B	Handle leaking on faucet in girls restroom on 2nd floor in main building	7/9/13			Plumbing
Scenic Hills EI (2633) 1B	Fountain not working on west end 1st floor in annex building	7/10/13			Plumbing
Scenic Hills EI (2633) 1B	Assist wash truck with cleaning area drains on backside of school. Wed. morning, 04/16/14	4/15/14			Plumbing
Scenic Hills EI (2633) 1B	Clean area drains on backside of school. Wed. morning, 04/16/14	4/15/14			Plumbing
Scenic Hills EI (2633) 1B	TOILET IS LEAKING WATER & RUNNING WATER CONTINUOUSLY IN G/RR ANNEX PLANT MGR-LADD/416.4342	4/22/14			Plumbing

Scenic Hills El (2633) 1B	PIPE B RR MAIN FLR-COMING FROM WALL LEAKING, CAN'T CONTAIN-PLANT MGR LADD 416-4342 KLR	4/25/14			Plumbing
Scenic Hills El (2633) 1B	COMMODE G RR 2ND FLR-PIPE LEAKING & WATER GOING DOWN INTO G RR 1ST FLR PER SBE-PLANT MGR LADD 416-4342 KLR	5/6/14			Plumbing
Scenic Hills El (2633) 1B	Push bar broken on water fountain near girls restroom on 2nd floor.	5/6/14			Plumbing
Scenic Hills El (2633) 1B	PIPE IS LEAKING WATER IN G/RR MAIN HALL PLANT MGR-LADD/416.4342	5/12/14			Plumbing
Scenic Hills El (2633) 1B	PIPE in WALL is LEAKING in BOY'S RR on MAIN HALL per Ms. Ladd, Plant Mgr. 416.4342	5/20/14			Plumbing
Scenic Hills El (2633) 1B	Mop sink stopped up in custodial closet located in boys restroom on main hall	6/25/14			Plumbing
Scenic Hills El (2633) 1B	test back flow device-os	7/2/13			Plumbing
Scenic Hills El (2633) 1B	STEAMTABLE SERVING LINE AREA-PILOT HAS GONE OUT-THEY ARE SERVING LUNCH NOW-PLANT MGR LADD 416-4342 KLR	3/27/14			Plumbing
Scenic Hills El (2633) 1B	Toilet not flushing properly in girls restroom on 1st floor in annex building	4/8/14			Plumbing
Scenic Hills El (2633) 1B	GAS SMELL IN BOILER RM PLANT MGR-LADD/321.1000	3/20/14			Plumbing
Scenic Hills El (2633) 1B	Roof leak in classroom last room west end of bldg per Robert Reed Zone Manager	7/23/13			Roof

Scenic Hills EI (2633) 1B	Make and install thresholds.	9/11/13	Portables		Sheet Metal
Scenic Hills EI (2633) 1B	LOCKER RM 201-COMING LOOSE FROM WALL-COULD FALL ON SOMEONE-PLANT MGR LADD 416-3234 KLR	3/25/14			Sheet Metal
Scenic Hills EI (2633) 1B	Fab and install vent pipe for the new boilers	4/2/14			Sheet Metal

Count of Craft	Craft									
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal
Snowden K8 (2690) 1A	4	1	133	178	61	19	148	24	20	588
Grand Total	4	1	133	178	61	19	148	24	20	588

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Snowden K8 (2690) 1A	Please repair the pipe from Fan Coil unit it was leaking	5/12/14	2nd Floor	226	Asbestos
Snowden K8 (2690) 1A	Reinsulate pipes at fan core units, where plumbers made repairs.	4/28/14	2nd Floor	206,320,	Asbestos
Snowden K8 (2690) 1A	insulate new pipe that was installed in band room-os	4/7/14			Asbestos
Snowden K8 (2690) 1A	Please Refinished Gym Floor and the Auditorrium	11/14/13	Gym	GymFloor	Asbestos
Snowden K8 (2690) 1A	Need to add computer outlets in the computer labs Can we have a pole add	9/9/13	1st Floor	124	Cabling
Snowden K8 (2690) 1A	The main Door, and 6grade Door need to add Door sweep	2/6/14	1st Floor	main office	Carpentry
Snowden K8 (2690) 1A	Need concert nail to hang fire extinguishers in hallway	1/29/14	1st Floor	All Floor	Carpentry

Snowden K8 (2690) 1A	NORTHEAST OUTSIDE DOOR cannot be SECURED per Ms. Longmire, Plant Mgr. 416.1625	1/30/14			Carpentry
Snowden K8 (2690) 1A	Please replace the ceiling tiles in the cafeteria need a lift.	1/31/14	Cafeteria	cafeteria	Carpentry
Snowden K8 (2690) 1A	Replace the ceiling tiles in the Band Room.It have mold on the ceiling tiles serious health concern	9/11/13	1st Floor	Band Room	Carpentry
Snowden K8 (2690) 1A	Reattach barrier cable to post and remove any post no longer in use. Post and cable were remove during temporary chiller installation.	2/11/14	Grounds		Carpentry
Snowden K8 (2690) 1A	need to replace the ceiling tiles special cuts	2/3/14	1st Floor	111	Carpentry
Snowden K8 (2690) 1A	Replace the ceiling tiles	2/3/14	Custodial Closet	1st floor east side	Carpentry
Snowden K8 (2690) 1A	Replace ceiling tiles in the classroom	2/4/14	1st Floor	111	Carpentry
Snowden K8 (2690) 1A	Need the handle replace on the cabinet.See Mrs. Longmire	2/5/14	1st Floor	nurse station	Carpentry

Snowden K8 (2690) 1A	Replace ceiling tiles in the classroom	2/5/14	1st Floor	113	Carpentry
Snowden K8 (2690) 1A	The door to the East stairwell East of the stage is getting harder and harder to open	2/5/14	Auditorium	2nd Floor	Carpentry
Snowden K8 (2690) 1A	Need to repair some seat in the auditorium	2/20/14	Auditorium	2nd floor	Carpentry
Snowden K8 (2690) 1A	Replace the base board in the hallway	2/20/14	Hallway/Corridor	Front 316	Carpentry
Snowden K8 (2690) 1A	The 6 grade and the kk wing door need to add door swept See Longmire for location	2/20/14	1st Floor	Exit door	Carpentry
Snowden K8 (2690) 1A	The back door need to be repair	2/20/14	1st Floor	133	Carpentry
Snowden K8 (2690) 1A	The Floor tiles is damaged and missing from the floor	2/24/14	Portables	335B	Carpentry
Snowden K8 (2690) 1A	Please remove a fence pole from ground next to the incinerator See Longmire for location	2/26/14	Grounds		Carpentry

Snowden K8 (2690) 1A	The Auditorium seat need to replace they are broken	2/27/14	Auditorium	2nd Floor	Carpentry
Snowden K8 (2690) 1A	Snowden is having aCity Council meeting on March 15, need the ceiling tiles replace Need a LIFT	2/28/14	Cafeteria	cafeteria	Carpentry
Snowden K8 (2690) 1A	Need to replace the ceiling tile in these classroom	3/6/14	3rd Floor	310,312,314	Carpentry
Snowden K8 (2690) 1A	Replace the ceiling tiles special cuts	5/1/14	3rd Floor	313	Carpentry
Snowden K8 (2690) 1A	These locker are coming off the wall	5/2/14	1st Floor	locker #1197,1199,1198,1200	Carpentry
Snowden K8 (2690) 1A	The stall door is broken	4/8/14	2nd Floor	Girls restroom middle	Carpentry
Snowden K8 (2690) 1A	Need to add door graud on the bottom of exit door snake coming in the building	4/14/14	1st Floor	All Exit door	Carpentry
Snowden K8 (2690) 1A	The ceiling tiles are stain and need to be replace special CUTs ToTal 8	4/16/14	2nd Floor	2nd floor landing next rm.123	Carpentry

Snowden K8 (2690) 1A	Need ceiling tiles replace special cuts	4/16/14	2nd Floor	228	Carpentry
Snowden K8 (2690) 1A	The 2nd stall door is broken and will not lock	4/16/14	1st Floor	8grade Girls restroom	Carpentry
Snowden K8 (2690) 1A	SCANNER FRONT OF BLDG HAS CAME DETACHED FROM WALL PLANT MGR-LONGMIRE/416.4621	4/1/14			Carpentry
Snowden K8 (2690) 1A	Replace the door closure	4/1/14	1st Floor	121	Carpentry
Snowden K8 (2690) 1A	The Stall Door is broken	3/19/14	2nd Floor	2nd next elevator	Carpentry
Snowden K8 (2690) 1A	The Bathroom door lock doest work	3/19/14	3rd Floor	313	Carpentry
Snowden K8 (2690) 1A	Need ceiling tiles replace before Town Hall Meeting on today.See Longmire Special Cuts	3/20/14	1st Floor	Mall area	Carpentry
Snowden K8 (2690) 1A	Please set the tenison on the door clousre	3/25/14	Hallway/Corridor	main hallway,Exit door	Carpentry

Snowden K8 (2690) 1A	Door closure is broken	3/26/14	1st Floor	121	Carpentry
Snowden K8 (2690) 1A	Repair closet door See Longmire for location	3/27/14	Administration Area	Princpal office	Carpentry
Snowden K8 (2690) 1A	Door in classroom has been damage,please repair or replace	3/28/14	3rd Floor	313	Carpentry
Snowden K8 (2690) 1A	The window in the classroom is falling from the wall.	4/2/14	1st Floor	124	Carpentry
Snowden K8 (2690) 1A	The Handicap stall Door is broken	6/24/14	2nd Floor	Boys restroom across library	Carpentry
Snowden K8 (2690) 1A	Need a 4x6 bulletin board	6/25/14	Administration Area	New AP office	Carpentry
Snowden K8 (2690) 1A	Remove the ceiling tiles has mold . 3pcs special	7/30/13	1st Floor	Band Room	Carpentry
Snowden K8 (2690) 1A	Locker #3076 is jammed. Please work on it for next years	5/15/14	3rd Floor	3076	Carpentry

Snowden K8 (2690) 1A	Need a 4x6 Dry Erase	5/15/14	1st Floor	110	Carpentry
Snowden K8 (2690) 1A	The ceiling tiles are missing special Cut 4pcs	5/21/14	1st Floor	109	Carpentry
Snowden K8 (2690) 1A	The window in the classroom need to be repair	5/28/14	2nd Floor	222	Carpentry
Snowden K8 (2690) 1A	The White board on the West wall is broken not attached properly	5/28/14	2nd Floor	222	Carpentry
Snowden K8 (2690) 1A	The window sill need repair	6/5/14	3rd Floor	307	Carpentry
Snowden K8 (2690) 1A	Replace the ceiling tiles in the classroom special cuts	1/7/14	1st Floor	124	Carpentry
Snowden K8 (2690) 1A	Need to put up the name sign above the classroom door Can Snowden have concrete nail	1/7/14	1st Floor	113	Carpentry
Snowden K8 (2690) 1A	The Room 103 has a new metal door remove from the classroom.It next to the File Cabinet.It was left by the carpenter	1/9/14	1st Floor	103	Carpentry

Snowden K8 (2690) 1A	Replace the ceiling tiles. specail cut in the classroom	1/13/14	1st Floor	124,125,126	Carpentry
Snowden K8 (2690) 1A	Need the tenison set the door close slow	1/14/14	Hallway/Corridor	Exit Door next 101	Carpentry
Snowden K8 (2690) 1A	Need a picture put above the locker	1/14/14	Hallway/Corridor	See Longmire	Carpentry
Snowden K8 (2690) 1A	Need changes the ceiling tiles special cut	1/16/14	Restroom (Girls)	kk wing front 108	Carpentry
Snowden K8 (2690) 1A	Termites damage base board need to be replace	1/16/14	1st Floor	Front main office	Carpentry
Snowden K8 (2690) 1A	Need ceiling tiles replace in in the boys restroom special Cuts	1/21/14	1st Floor	boys 8grade	Carpentry
Snowden K8 (2690) 1A	The caferia lobby has damages ceiling tiles	1/21/14	1st Floor	cafeteria lobby	Carpentry
Snowden K8 (2690) 1A	Repair fire door in the stairwell by room 309 won't latch	1/22/14	Hallway/Corridor	3floor	Carpentry

Snowden K8 (2690) 1A	Replace ceiling tiles	1/23/14	1st Floor	128	Carpentry
Snowden K8 (2690) 1A	The stall Door is broken	1/24/14	2nd Floor	7grade boys restroom	Carpentry
Snowden K8 (2690) 1A	Special Cuts ceiling tiles is damages around the Fan Coil unit	1/28/14	1st Floor	Girls restroom	Carpentry
Snowden K8 (2690) 1A	Ceiling tiles missing special cuts	1/28/14	1st Floor	main lobby	Carpentry
Snowden K8 (2690) 1A	The Portables is sinking It is on the Northwest corner that it leaning Also has tiles that are missing need 10pcs replaced	9/5/13	Portables	p124	Carpentry
Snowden K8 (2690) 1A	The storage or closet door need to replace it is in bad sharpe	9/5/13	1st Floor	103	Carpentry
Snowden K8 (2690) 1A	The stall door is coming off	9/6/13	2nd Floor	Elem.Girls next elevator	Carpentry
Snowden K8 (2690) 1A	Need the window in the Boys Locker Room no handle will not lock. Please See SBE	11/25/13	1st Floor	Gym	Carpentry

Snowden K8 (2690) 1A	COMPLETE WINDOW HAS FALLEN OUT IN RM-222 PLANT MGR-LONGMIRE/416.4621	11/25/13			Carpentry
Snowden K8 (2690) 1A	SIDE ENTRY DOOR, CANT SECURE BY SBE OFFICE PLANT MGR-LONGMIRE/416.4621	12/2/13			Carpentry
Snowden K8 (2690) 1A	We have 6pcs of stain ceiling tiles in the classroom special cuts	12/2/13	2nd Floor	208	Carpentry
Snowden K8 (2690) 1A	The ceiling tiles are missing around the Fan Coil unit and pipes.SPECIAL CUTS	12/3/13	1st Floor	132	Carpentry
Snowden K8 (2690) 1A	The DOOR Clouser need the cover. See SBE for the cover	12/9/13	2nd Floor	220	Carpentry
Snowden K8 (2690) 1A	Need to replace the wood on the floor. Before we get the floor refinish on January2,2013	12/9/13	Gym	Gym floor	Carpentry
Snowden K8 (2690) 1A	The stall door is missing screws will fall down soon	12/10/13	1st Floor	8grade Girls restroom	Carpentry
Snowden K8 (2690) 1A	The main door close slow	12/12/13	1st Floor	Main door	Carpentry

Snowden K8 (2690) 1A	Please secure the projector screen it fell yesterday.	12/12/13	3rd Floor	303	Carpentry
Snowden K8 (2690) 1A	Rotten wood on the ramp Ramp feel very spongy plus there a hole in it. Some kids is going to step though to the ground	11/3/13	Portables	p122	Carpentry
Snowden K8 (2690) 1A	Replace the stall door. Door is on location	11/3/13	1st Floor	8grade restroom Girl	Carpentry
Snowden K8 (2690) 1A	Need to replace the soap Dispenser	11/5/13	2nd Floor	Girls restroom	Carpentry
Snowden K8 (2690) 1A	The classroom door need to be repair	11/5/13	3rd Floor	301	Carpentry
Snowden K8 (2690) 1A	The ceiling tiles are missing special Cuts 4pcs	11/6/13	Kitchen	cafe	Carpentry
Snowden K8 (2690) 1A	Ar store door will not lock teacher coat and Book money is missing	11/6/13	1st Floor	Ar store	Carpentry
Snowden K8 (2690) 1A	Boys ceiling tiles is missing 4pcs specail cuts	11/8/13	1st Floor	Boys restroom 8grade	Carpentry

Snowden K8 (2690) 1A	Replace the ceiling tiles	11/10/13	1st Floor	8 grade Boy restroom	Carpentry
Snowden K8 (2690) 1A	Move the keys box from the Fin.office to the SBE office	11/13/13	Administration Area	Berry office	Carpentry
Snowden K8 (2690) 1A	Replace the ceiling tiles 5 pcs	11/14/13	Cafeteria	over the seving line	Carpentry
Snowden K8 (2690) 1A	Need to replace the base board	11/14/13	Hallway/Corridor	Front 316	Carpentry
Snowden K8 (2690) 1A	Need a door clouse replace	11/18/13	3rd Floor	313	Carpentry
Snowden K8 (2690) 1A	Need a bull. board next to pencil sharpener	11/18/13	2nd Floor	216	Carpentry
Snowden K8 (2690) 1A	The door lock stick	11/18/13	1st Floor	P123, P335	Carpentry
Snowden K8 (2690) 1A	All 4 Door need a Door sweep on them. Mice coming in the building under the door this morning	11/20/13	Cafeteria	cafe.Door	Carpentry

Snowden K8 (2690) 1A	Need 2 Dry Erase boards to replace shower boards that is falling off 4x8	11/21/13			Carpentry
Snowden K8 (2690) 1A	The Floor in front of main office it has a incline and the floor is wet, and slippery when it rain.	11/22/13	Administration Area	Front hallway	Carpentry
Snowden K8 (2690) 1A	The window in the Gym will not lock.All of them	11/24/13	Gym	Gym window	Carpentry
Snowden K8 (2690) 1A	Need the pole on the fence place back so Snowden can lock the gate	11/24/13	Grounds	pole on the fence	Carpentry
Snowden K8 (2690) 1A	The library door the handle is broken	11/25/13	1st Floor	Elem. library	Carpentry
Snowden K8 (2690) 1A	Replace ceiling tiles in the hallways front 123 special cuts	7/30/13	1st Floor	123	Carpentry
Snowden K8 (2690) 1A	The floor tiles the carpertry didnt finish the floor tiles	7/30/13	1st Floor	cafe lobby	Carpentry
Snowden K8 (2690) 1A	#368911 This is Floor Tiles that need adhesive and special cuts This is for os	7/30/13	1st Floor	cafe lobby	Carpentry

Snowden K8 (2690) 1A	The clothes closet need to add a roob for hanging coats	7/18/13	1st Floor	103	Carpentry
Snowden K8 (2690) 1A	Front of the main office tiles are missing	7/22/13	1st Floor	Front main office	Carpentry
Snowden K8 (2690) 1A	Missing 2floor tiles near window	7/29/13	2nd Floor	313	Carpentry
Snowden K8 (2690) 1A	Replace ceiling tiles in the portable	7/29/13	Portables	p310	Carpentry
Snowden K8 (2690) 1A	Remove Bulletin Board has mold on it	7/29/13	1st Floor	103	Carpentry
Snowden K8 (2690) 1A	Hoping to get the bulletin board drilled into the wall.Bulletinboard on location	7/29/13	2nd Floor	304	Carpentry
Snowden K8 (2690) 1A	Need to replace ceiling tiles in the hallways special cuts around pipes	8/5/13	Hallway/Corridor	front 114	Carpentry
Snowden K8 (2690) 1A	Need a New projector screen mount on the wall Have projector screen on location	8/6/13	1st Floor	126	Carpentry

Snowden K8 (2690) 1A	This door is very hard to open and we would like to use that side this year for entrance for class	8/7/13	Portables	p123	Carpentry
Snowden K8 (2690) 1A	Need the ceiling replace special cuts. The leaks are repaired	8/8/13	2nd Floor	middle library	Carpentry
Snowden K8 (2690) 1A	Need Projector screen hung has screen on location	8/8/13	1st Floor	108	Carpentry
Snowden K8 (2690) 1A	Need to move projector screen to a bricks wall.	8/8/13	2nd Floor	218	Carpentry
Snowden K8 (2690) 1A	The Back door in the main office with not lock	8/9/13	Administration Area	Backdoor main office	Carpentry
Snowden K8 (2690) 1A	Please hang screen in front of room Brick wall	8/9/13	2nd Floor	232	Carpentry
Snowden K8 (2690) 1A	Reinstall mailboxes removed for wall modification.	8/13/13	Administration Area		Carpentry
Snowden K8 (2690) 1A	Need to replace paper towel holders	8/13/13	1st Floor	Girls 1st floor Girls 2nd floor	Carpentry

Snowden K8 (2690) 1A	Need to replace the ceiling tiles special cuts	8/16/13	Kitchen	servicing line	Carpentry
Snowden K8 (2690) 1A	Please hang projector screen don't have screw	8/2/13	1st Floor	112	Carpentry
Snowden K8 (2690) 1A	Need the ceiling tiles replace special cut next to the fan coil unit	8/2/13	1st Floor	Band room	Carpentry
Snowden K8 (2690) 1A	A Hole in the wood floor on the basketball court. The West end of the court	8/20/13	Gym	Gym floor	Carpentry
Snowden K8 (2690) 1A	Please hang screen on the right side of front board. I have the screen but not the hooks	8/21/13	2nd Floor	232	Carpentry
Snowden K8 (2690) 1A	The ceiling tiles across from rm. 114 need to be replaced special cuts	8/30/13	Hallway/Corridor	Across from rm 114	Carpentry
Snowden K8 (2690) 1A	The rotten wood on ramp	9/23/13	Portables	p1222	Carpentry
Snowden K8 (2690) 1A	Need to add 4x6 Bulletin board in the main office	9/24/13	Administration Area	118H	Carpentry

Snowden K8 (2690) 1A	Need a bulletin board in the Att.office	9/27/13	1st Floor	Beamon office	Carpentry
Snowden K8 (2690) 1A	Need a 4x6 bulletin board	9/27/13	Administration Area	main office police office	Carpentry
Snowden K8 (2690) 1A	Replace water damaged and broken ceiling tile in various locaton in hallways.	10/2/13			Carpentry
Snowden K8 (2690) 1A	Please install projector screen on the south window.See SBE for location	10/4/13	3rd Floor	303	Carpentry
Snowden K8 (2690) 1A	Please install projector screen on the east wall above white board SEE SBE for location	10/4/13	1st Floor	102	Carpentry
Snowden K8 (2690) 1A	Replace the ceiling tiles special cuts	11/25/13	1st Floor	Band room	Carpentry
Snowden K8 (2690) 1A	Need gates adjusted on McLain side by double wide gates won't close and lock.Check all the gates because outside guest will use the feild on the weekend	3/12/14	Grounds	Football feild	Carpentry
Snowden K8 (2690) 1A	Need a carpentry Welder to weld the 1grade table back together	5/12/14	1st Floor	106	Carpentry

Snowden K8 (2690) 1A	Place Bulletin board on the wall outside of door	6/26/14	1st Floor	111	Carpentry
Snowden K8 (2690) 1A	The closet is missing a door	8/5/13	Portables	p310	Carpentry
Snowden K8 (2690) 1A	Work order request # 414580 is for the carpenter not the plumber	2/6/14	Auditorium	2nd floor	Carpentry
Snowden K8 (2690) 1A	Ballast out in the closet	2/6/14	3rd Floor	315	Electrical
Snowden K8 (2690) 1A	Need a light cover in the cafeteria lobby expose wires	2/6/14	Cafeteria	cafeteria lobby	Electrical
Snowden K8 (2690) 1A	Ballast out under the pavillion	2/4/14	Grounds	pavillion	Electrical
Snowden K8 (2690) 1A	Ballast out in the hallway	2/4/14	Hallway/Corridor	Front room 211	Electrical
Snowden K8 (2690) 1A	NO POWER IN B/RR GYM. PLANT MGR-LONGMIRE/416.4621	2/4/14			Electrical

Snowden K8 (2690) 1A	Need lid cover over the fluorescent lamps in the classroom and hallway	2/11/14	Hallway/Corridor	2nd floor and rm.234 228, 232	Electrical
Snowden K8 (2690) 1A	Ballast out in the 1st grade classroom	2/12/14	1st Floor	104	Electrical
Snowden K8 (2690) 1A	Ballast out under the pavillion	2/17/14	Grounds	pavillion	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	2/17/14	1st Floor	104	Electrical
Snowden K8 (2690) 1A	Ballast out in the restroom	2/21/14	Gym	Girls restroom	Electrical
Snowden K8 (2690) 1A	Please set the clock for day light saving on Friday March 7,2014	2/24/14	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	Ballast out in the portable	2/24/14	Portables	335A	Electrical
Snowden K8 (2690) 1A	Ballast out in the mall	2/25/14	1st Floor	mall	Electrical

Snowden K8 (2690) 1A	A/C WINDOW UNIT GYM AREA- NOT HEATING-PLANT MGR LONGMIRE 416-6125 KLR	2/25/14			Electrical
Snowden K8 (2690) 1A	WE have Counsel meeting at Snowden on March 15, need all the ballast and lights in for the meeting Need a lift	2/28/14	Cafeteria	cafeteira Kitchen	Electrical
Snowden K8 (2690) 1A	Need the Ballast repair	2/28/14	1st Floor	elevator Rm. buff room	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	3/6/14	1st Floor	120	Electrical
Snowden K8 (2690) 1A	The A/Cunit is popping off.Longmire have to go back to the circuit breaker for power	5/5/14	1st Floor	copy room	Electrical
Snowden K8 (2690) 1A	per ms longmeier 416-6125 room 112 a/c not coming on at all	5/7/14			Electrical
Snowden K8 (2690) 1A	Need to add 110 outlet in back office	5/7/14	1st Floor	Plant Mrg. office	Electrical
Snowden K8 (2690) 1A	Install exhaust fan inside closed in outside entrance off North Parkway side or backside of room 103. Moisture and humidity inside the area causing problems inside room 103. Please contact Eric Thomas for further details.	5/7/14			Electrical

Snowden K8 (2690) 1A	Ballast out in the closet next to Auditorium	5/12/14	2nd Floor	closet net Auditorium	Electrical
Snowden K8 (2690) 1A	The 3rd Floor classroom need to finish the Thermostat on the Fan Coil Unit	4/22/14	3rd Floor	317,318,309,320,324,315	Electrical
Snowden K8 (2690) 1A	The Window Unit in the Gym has not been repair.No window to open	4/22/14	Gym	Gym classroom	Electrical
Snowden K8 (2690) 1A	UNIT NOT COOLING IN RM-125,113,212,317,318,309,320,324 PLANT MGR-LONGMIRE/6125	4/22/14			Electrical
Snowden K8 (2690) 1A	Light Ballast is out	4/4/14	Portables	p335B	Electrical
Snowden K8 (2690) 1A	Ballast out over the secretary desk	4/7/14	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	The Fire Alarm is turned up can it be turn down	4/7/14	Portables	P125	Electrical
Snowden K8 (2690) 1A	Ballast out in the Bell Tower	4/14/14	3rd Floor	Bell Tower	Electrical

Snowden K8 (2690) 1A	per ms longmeier 416-6125 the heating unit in front of room 216 is sparking fire out of the pipe	4/14/14			Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	4/16/14	3rd Floor	313	Electrical
Snowden K8 (2690) 1A	The Exhaust Fan not working	4/17/14	1st Floor	Electrician closet	Electrical
Snowden K8 (2690) 1A	ALL three (3) UNITS are NOT COMING ON per Ms. Longmire, Plant Mgr. 416.6125	4/21/14			Electrical
Snowden K8 (2690) 1A	The Mall lights Snowden have Total 30 lights out. 9 Watts max Type P.I 9watt Need these before March 14 2014 Town Hall Meeting	3/11/14	1st Floor	Mall	Electrical
Snowden K8 (2690) 1A	Ballast out in the restroom	3/11/14	3rd Floor	Boys restroom next elevator	Electrical
Snowden K8 (2690) 1A	Need the spot light replace in the Auditorum	3/31/14	Auditorium	2nd floor	Electrical
Snowden K8 (2690) 1A	Master clock needs to set.	3/18/14	Administration Area	See Plant MGR.	Electrical

Snowden K8 (2690) 1A	The Master Clock is 7min behind need help	3/19/14	Administration Area	Master Clock	Electrical
Snowden K8 (2690) 1A	No power on the West wall outlet is out T.V. will not come on	3/19/14	3rd Floor	309	Electrical
Snowden K8 (2690) 1A	Need Track lights out in the Mall Area. Need to be repair on today for the meeting on Friday. Town Hall Meeting	3/20/14	1st Floor	mall area	Electrical
Snowden K8 (2690) 1A	Ballast out	3/20/14	1st Floor	spot light board	Electrical
Snowden K8 (2690) 1A	Need to replace the spot lights on stage	3/21/14	Auditorium	spot lights	Electrical
Snowden K8 (2690) 1A	The Master clock the bell rang on Sunday but Monday and Tuesday it didn't ring at all	3/25/14	Administration Area	masterClock	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	3/25/14	2nd Floor	228	Electrical
Snowden K8 (2690) 1A	Ballast out	3/27/14	1st Floor	110	Electrical

Snowden K8 (2690) 1A	Ballast out in the classroom	3/31/14	1st Floor	110	Electrical
Snowden K8 (2690) 1A	The lights out on the step	4/2/14	Auditorium	Right step side	Electrical
Snowden K8 (2690) 1A	Please changes the time for the new school year on the master clock	6/26/14	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	The Air Unit is making a loud noise	5/15/14	Portables	335A	Electrical
Snowden K8 (2690) 1A	The Air Unit is making a loud noise	5/15/14	Portables	335A	Electrical
Snowden K8 (2690) 1A	CHILLER = (2) WEST END OF BLDG = NOT COMING ON - PM/LONGMEIR 416-6125	5/27/14			Electrical
Snowden K8 (2690) 1A	A/C UNIT is NOT COMING ON per Ms. Longmire, Plant Mgr. 416.6125	5/27/14			Electrical
Snowden K8 (2690) 1A	The Heat unit no power	1/7/14	1st Floor	elem library	Electrical

Snowden K8 (2690) 1A	The power on the South east wall has no power	1/8/14	Administration Area	Nurse Station	Electrical
Snowden K8 (2690) 1A	BREAKER BOX#27 IS TRIPPING, NO POWER FOR NURSING STATION PLANT MGR-LONMIRE/416.4621	1/8/14			Electrical
Snowden K8 (2690) 1A	Ballast out	1/8/14	Hallway/Corridor	Front 208	Electrical
Snowden K8 (2690) 1A	Ballast out	1/8/14	Stairway	Next room 125	Electrical
Snowden K8 (2690) 1A	HEAT GYM AREA-NOT COMING ON-PLANT MGR LONGMIRE 416-6125 KLR	1/9/14			Electrical
Snowden K8 (2690) 1A	Need new time add to the master clock	1/9/14	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	1/13/14	2nd Floor	206	Electrical
Snowden K8 (2690) 1A	Ballast out in the teacher restroom	1/15/14	2nd Floor	women restroom teacher only	Electrical

Snowden K8 (2690) 1A	Need light bulb for the lamps in the main office 25 volt Incandescent lamp Total 6	1/15/14	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	Need to have the lights around the building on totals 6 Need the lift	1/16/14	1st Floor	Outside building	Electrical
Snowden K8 (2690) 1A	Need the lights replace under the pavillion. Front Gym and the back	1/16/14	Grounds	Under the pavillion	Electrical
Snowden K8 (2690) 1A	The cafeteria lights out need a lift	1/16/14	Cafeteria	cafeteria	Electrical
Snowden K8 (2690) 1A	Ballast out in two portable	1/16/14	Portables	p335A and B	Electrical
Snowden K8 (2690) 1A	Need Phillips Lamps 6boxes F32T8 28 Watts	1/17/14	1st Floor	For all Floor	Electrical
Snowden K8 (2690) 1A	Need lamps #46820	1/21/14	1st Floor	See longmire	Electrical
Snowden K8 (2690) 1A	Need light Damar self ballasted lamp Hm155L/ 41k 120 vac 15w 4100k UI File no 170072 6G081009	1/21/14	1st Floor	see Mrs longmire	Electrical

Snowden K8 (2690) 1A	HEAT RM 217-NOT COMING ON- PLANT MGR LONGMIRE 416-6125 KLR	1/21/14			Electrical
Snowden K8 (2690) 1A	Need a Ballast in the portable	1/22/14	Portables	p123	Electrical
Snowden K8 (2690) 1A	Ballast out in the halway	1/23/14	Hallway/Corridor	Front room 309	Electrical
Snowden K8 (2690) 1A	The clock in the gym need to set Need alift	1/24/14	Gym	Clocks	Electrical
Snowden K8 (2690) 1A	Check the window unit outlet this classroom has a window unit	9/3/13	1st Floor	130	Electrical
Snowden K8 (2690) 1A	Ballast out in the portable Lights blinking	9/3/13	Portables	310A	Electrical
Snowden K8 (2690) 1A	Ballast out in the closet in the middle library	9/4/13	Library	2nd floor	Electrical
Snowden K8 (2690) 1A	The Circuit Breaker for the copying machine	9/5/13	1st Floor	copy Room	Electrical

Snowden K8 (2690) 1A	A/C ENTIRE 3RD FLR ABOUT (19) RMS-ALL NOT COMING ON-PLANT MGR LONGMIRE 416-4625 KLR	9/9/13			Electrical
Snowden K8 (2690) 1A	This is a window Unit very hot in this room. I think need the filter change and Freon	9/10/13	Library	Copy room	Electrical
Snowden K8 (2690) 1A	HALF OF LIGHTS NOT COMING ON IN MIDDLE SCHOOL LIBRARY-PLANT MGR LONGMIRE 416-6125 KLR	9/11/13			Electrical
Snowden K8 (2690) 1A	FCU'S IN ALL HALLWAYS-NOT COMING ON-PLANT MGR LONGMIRE 416-6125 KLR	11/25/13			Electrical
Snowden K8 (2690) 1A	Ballast out	11/26/13	3rd Floor	305	Electrical
Snowden K8 (2690) 1A	The Fire door the magnet will not stick 1st and 2nd floor.	12/2/13	1st Floor	Fire Door	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	12/9/13	1st Floor	126	Electrical
Snowden K8 (2690) 1A	The wall front of N Parkway none of the outlet are working	12/9/13	2nd Floor	Middle Library	Electrical

Snowden K8 (2690) 1A	Ballast out in the classroom	12/9/13	2nd Floor	216	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	12/9/13	3rd Floor	305	Electrical
Snowden K8 (2690) 1A	HEAT GYM-NOT HEATING-PLANT MGR LONGMIRE 416-6125 KLR	12/9/13			Electrical
Snowden K8 (2690) 1A	Make necessary changes to electric inorder to hookup new rooftop package units.	12/12/13	Administration Area		Electrical
Snowden K8 (2690) 1A	Snowden has several lights out on the campus and the parklot. See the SBE for location	12/13/13	Parking Lot	McLean	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	12/13/13	2nd Floor	216	Electrical
Snowden K8 (2690) 1A	Ballast out inthe restroom.It dark in the restroom	12/16/13	2nd Floor	5 grade restroom boys next elevator	Electrical
Snowden K8 (2690) 1A	BOILER-1 & BOILER-2-BOTH NOT HEATING-PLANT MGR LONGMIRE 416-6125 KLR	1/7/14			Electrical

Snowden K8 (2690) 1A	Need Electrical 110 outlet to place along wall under large 4x8 white boards under the heat unit	1/7/14	1st Floor	103	Electrical
Snowden K8 (2690) 1A	Ballast out in the portable for 3 week please help	11/3/13	Portables	P122	Electrical
Snowden K8 (2690) 1A	Changes the master clock for the new time	11/3/13	Administration Area	Main office	Electrical
Snowden K8 (2690) 1A	Ballast out	11/4/13	Hallway/Corridor	front 140	Electrical
Snowden K8 (2690) 1A	BELL 1ST GR HALL-CONSTANTLY RINGING, CAN'T CUT OFF-PLANT MGR LONGMIRE 416-6125 KLR	11/4/13			Electrical
Snowden K8 (2690) 1A	Ballast out	11/4/13	Hallway/Corridor	front rm. 120	Electrical
Snowden K8 (2690) 1A	Ballast out	11/4/13	Hallway/Corridor	Landing	Electrical
Snowden K8 (2690) 1A	Need Florescent lamp,Galux energy saver lamps 13wGD, 13wGs,and lamps 60 watts	11/4/13	1st Floor	All floor ,restroom	Electrical

Snowden K8 (2690) 1A	Need lamps 46820 at least 20	11/4/13	1st Floor	All floor	Electrical
Snowden K8 (2690) 1A	Repair lights on the serving line and cord falling from ceiling in kitchen.	11/5/13	Kitchen		Electrical
Snowden K8 (2690) 1A	Ballast out in the hallway	11/7/13	3rd Floor	Hallway	Electrical
Snowden K8 (2690) 1A	Ballast out in the hallway	11/7/13	3rd Floor	Hallway	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	11/10/13	2nd Floor	228	Electrical
Snowden K8 (2690) 1A	Multiple outlet not working in the Science Lab	11/13/13	2nd Floor	228	Electrical
Snowden K8 (2690) 1A	Ballast out	11/13/13	2nd Floor	228	Electrical
Snowden K8 (2690) 1A	Ballast out	11/13/13	2nd Floor	Girls restroom Elem	Electrical

Snowden K8 (2690) 1A	The lamps did not help. The Ballast out	11/13/13	2nd Floor	205	Electrical
Snowden K8 (2690) 1A	Ballast out in the hallway	11/14/13	Hallway/Corridor	3rd front 309	Electrical
Snowden K8 (2690) 1A	Two set of lights are out in the hallway. See SBE for location	11/14/13	3rd Floor	hallway	Electrical
Snowden K8 (2690) 1A	The light switch need a cover	11/15/13	Cafeteria	Dish room window	Electrical
Snowden K8 (2690) 1A	Ballast out in the Emergency light out	11/18/13	1st Floor	132	Electrical
Snowden K8 (2690) 1A	The outlet hanging out near the window wall	11/18/13	2nd Floor	216	Electrical
Snowden K8 (2690) 1A	The circuit Breaker feel HOt to the touch	11/18/13	Auditorium	2nd floor	Electrical
Snowden K8 (2690) 1A	Ballast out	11/19/13	1st Floor	Lost Found rm.	Electrical

Snowden K8 (2690) 1A	Ballast out by practic Room	11/20/13	1st Floor	128	Electrical
Snowden K8 (2690) 1A	Electrcail outlet not working	11/21/13	2nd Floor	233	Electrical
Snowden K8 (2690) 1A	Ballast out	11/21/13	2nd Floor	233	Electrical
Snowden K8 (2690) 1A	The stage is use for a music room.Lighting onstage is not suitable for reading music, especially near the edges Can we please have flonrescent.They	11/21/13	Auditorium	2nd floor	Electrical
Snowden K8 (2690) 1A	Ballast out in front rm.116	11/22/13	Hallway/Corridor	Front 116	Electrical
Snowden K8 (2690) 1A	The circuit breaker it trips over and over.See Plant Mrg.	11/22/13	Auditorium	circuit breaker	Electrical
Snowden K8 (2690) 1A	Need a key chart for the circuit breaker in the Aud	11/22/13	Auditorium	2nd floor	Electrical
Snowden K8 (2690) 1A	Replace the 110 outlet in the main office	7/30/13	Administration Area	Main office	Electrical

Snowden K8 (2690) 1A	Please changes the bell s schedule. See Mrs Longmire	7/30/13	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	7/30/13	1st Floor	103	Electrical
Snowden K8 (2690) 1A	The light switch has a shortage	7/30/13	Portables	335B	Electrical
Snowden K8 (2690) 1A	5-UV NOT COMING ON IN RM- 301,310,320,123,102(093,015,110,1 63,177) PLANT MGR-LONGMIRE/416-4621	7/30/13			Electrical
Snowden K8 (2690) 1A	Ballast out in the locker room	7/22/13	Gym	Boys locker room	Electrical
Snowden K8 (2690) 1A	Ballast is out in front dish room	7/22/13	Cafetorium	Outside dish room window	Electrical
Snowden K8 (2690) 1A	ovens will not come on , please repair	7/25/13	Cafeteria	cooking area	Electrical
Snowden K8 (2690) 1A	Ballast out in room 116	7/29/13	1st Floor	116	Electrical

Snowden K8 (2690) 1A	Ballast out in the classroom	7/29/13	1st Floor	136	Electrical
Snowden K8 (2690) 1A	Ballast out in the hallway	8/6/13	Hallway/Corridor	1st grade fl	Electrical
Snowden K8 (2690) 1A	Ballast out in the library closet	8/7/13	2nd Floor	middle library	Electrical
Snowden K8 (2690) 1A	The pump west p1-2 is making loud noise	8/9/13	Mechanical Room	Mcclean side	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	8/9/13	2nd Floor	232	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	8/9/13	2nd Floor	233	Electrical
Snowden K8 (2690) 1A	Need Fluorescent lamps #F32T8/TL41 32Watt	8/12/13	1st Floor	all floor	Electrical
Snowden K8 (2690) 1A	Need to add a time to the clock 1:55 bell need to ring daily	8/13/13	Administration Area	main office	Electrical

Snowden K8 (2690) 1A	Ballast out in the classroom	8/13/13	Hallway/Corridor	KK wing	Electrical
Snowden K8 (2690) 1A	Need a electrical the ballast out in the classroom	8/1/13	1st Floor	Mall, cafe	Electrical
Snowden K8 (2690) 1A	Need clock for hallway	8/1/13	1st Floor	hallway	Electrical
Snowden K8 (2690) 1A	The wall outlet has no power	8/2/13	1st Floor	108	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	8/2/13	1st Floor	138	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	8/5/13	1st Floor	103	Electrical
Snowden K8 (2690) 1A	Need the ballast replace	8/5/13	2nd Floor	202	Electrical
Snowden K8 (2690) 1A	Ballast out in the restroom	8/22/13	Gym	Boys restroom	Electrical

Snowden K8 (2690) 1A	Ballast out in the hallway next to stage	8/23/13	Auditorium	hallway beside stage	Electrical
Snowden K8 (2690) 1A	Expose wire under the clock need a cover	8/23/13	1st Floor	mall area	Electrical
Snowden K8 (2690) 1A	The Window Units in the portable has no power	8/23/13	Portables	p123	Electrical
Snowden K8 (2690) 1A	Ballast out in the restroom	8/30/13	3rd Floor	3floor Boy next elevator	Electrical
Snowden K8 (2690) 1A	The computer outlet is making a noise	8/30/13	1st Floor	119	Electrical
Snowden K8 (2690) 1A	Need to add Need new times to bells 7:55 1:55,2:00 3:00	8/30/13	Administration Area	Master Clock	Electrical
Snowden K8 (2690) 1A	The Refigerator outlet is out the one next to window in the Teacher Lounge	9/3/13	1st Floor	Teacher Lounge	Electrical
Snowden K8 (2690) 1A	Ballast out in the restroom	9/3/13	2nd Floor	Girls restroom across library	Electrical

Snowden K8 (2690) 1A	Ballast out in the Boys restroom	9/3/13	3rd Floor	Boys restroom next elevator	Electrical
Snowden K8 (2690) 1A	A buzzing from the computer outlet behind the teacher desk	9/3/13	1st Floor	119	Electrical
Snowden K8 (2690) 1A	The Room need cover over the Flr. lamps 2SETS dangerous.And Ballast out	9/12/13	2nd Floor	232	Electrical
Snowden K8 (2690) 1A	This potable has two window Unit not cooling	9/13/13	Portables	P125	Electrical
Snowden K8 (2690) 1A	Ballast out in the portable	9/23/13	Portables	p122	Electrical
Snowden K8 (2690) 1A	New the master clock set will a new time	9/25/13	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	WINDOW UNIT NOT COMING ON IN GYM CLASS PLANT MGR-LONGMIRE/416.4621	9/25/13			Electrical
Snowden K8 (2690) 1A	The lights on the wet,east wall are out	9/25/13	Auditorium	2nd floor	Electrical

Snowden K8 (2690) 1A	Ballast out in the mall See SBE	9/30/13	1st Floor	mall area	Electrical
Snowden K8 (2690) 1A	Ballast out in the hallway front room 230	9/30/13	2nd Floor	hallway	Electrical
Snowden K8 (2690) 1A	A/C ENTIRE 3RD FLR-NOT COMING ON-PLANT MGR LONGMIRE 416-6125 KLR	10/4/13			Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	10/4/13	1st Floor	113	Electrical
Snowden K8 (2690) 1A	Ballast out in the Mr. T office	10/8/13	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	Ballast out in the classroom	10/8/13	2nd Floor	230	Electrical
Snowden K8 (2690) 1A	The conduit pipe is loose and coming from the wall	10/14/13	Hallway/Corridor	Front rm 303 and 304	Electrical
Snowden K8 (2690) 1A	The Score board need power add and a 110 outlet repair	3/31/14	Grounds	Foot ball feild	Electrical

Snowden K8 (2690) 1A	The Court Yard and the side of the Gym building the lights are out Need a LIFT to reach the lights,	4/4/14	Grounds	Southwest Gym, court yard	Electrical
Snowden K8 (2690) 1A	Need to add a 110 or computer outlet in front of the smart board	7/30/13	1st Floor	131	Electrical
Snowden K8 (2690) 1A	Air Conditioner put off burning smell when turned on this is a window Unit	9/3/13	1st Floor	130	Electrical
Snowden K8 (2690) 1A	need main office clock set up for new time change	11/1/13	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	Need replace the 110 outlet	7/30/13	Administration Area	main office	Electrical
Snowden K8 (2690) 1A	HEAT ENTIRE 3RD FLR (18) RMS- ALL NOT HEATING-PLANT MGR LONGMIRE 416-6125 KLR	2/6/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	8-UV NOT HEATING IN RM- 305,304,306,316,317,318,302,307 PLANT MGR-LONGMIRE/416.4621	2/10/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Monthly - Oil Lube & Belt-Snowden Middle - Refer to PM schedule details.	2/22/14			Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	Monthly - Air Comp-1st Fir Mech Rm113-Snowden #090 - Refer to PM schedule details.	2/24/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	A Leaking in the corner of the closet See Longmire for location	2/25/14	Custodial Closet	1st. east 8grade	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	per ms longmeier 416-6125 the entire 3rd floor all rooms no heat blowing cold	3/6/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	per ms longmeier 416-6125 gym, cafeteria and room 212 are not cooling	5/5/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	A/C MAIN OFC, RM 302 & PORT 310A-ALL NOT COOLING-PLANT MGR LONGMIRE 416-6125 KLR	5/8/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	per ms longmeier 416-6125 rooms 302 and 305 not cooling	5/12/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	A/C UNIT PIPE IN CEILING OF RM 226-HAS BURST AND WATER GOING EVERYWHERE-PLANT MGR LONGMIRE 416-6125 KLR	4/8/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	The Band is leaking again the teacher has barrel under the leak please HELP	4/3/14	1st Floor	Band Room	Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Need a window unit replace .The copy machine will not come on when get hot in the classroom	6/27/14	1st Floor	Copy Room	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Check ceiling in computer room (rm 124). Ceiling is coming down over window.Remove ceiling tile and check on damage.	6/30/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Check A/C in room 124 (computer room). Door is open on ceiling unit.	6/30/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	UNIT NOT COOLING THRU ENTIRE 3RD FLR. PLANT MGR-LONGMIRE/416.4621	5/12/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	A/C RM 128 & 301-BOTH NOT COOLING-PLANT MGR LONGMIRE 416-6125 KLR	5/13/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	UNIT VENTS - RMS126, 128, 134, 119, 118, 123, 211, 228, 220, 230 - ALL ARE BLOWING BUT NOT COOLING - PM/LONGMEIR	6/4/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	2-UNITS NOT COOLING IN EAST- END BLDG 1ST & 2ND FLRS 25- RMS PLANT MGR-LONGMIRE/416.4621	6/6/14			Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	Units are NOT HEATING in Rooms 101, 102, 105, 112, 126, 134, Elementary Library, Kitchen area, 203, 216, 217, 220, 228, 230, 232, 301, 302, 304, 305, 306, 308, 309, 316, 317, and 320 per Ms. Longmire, Plant Mgr. 416.1625	1/8/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Unit in the GYM is NOT COMING ON per Ms. Longmire, Plant Mgr. 416.6125	1/16/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	HEAT 1ST FLR RM 124, 123, 125, 130, 118, 119, 121, & BANRM & 2ND FLR RMS 232, 217, 213, 224, 228, 226, & 230-ALL NOT HEATING-PLANT MGR LONGMIRE 416-6125 KLR	1/21/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	17-UV NOT HEATING THRU ENTIRE 3RD FLR & RM-217. PLANT MGR-LONGMIRE/416.4621	1/24/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	HEAT KITCHEN AREA-NOT COMING ON-PLANT MGR LONGMIRE 416-6125 KLR	1/24/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	HVAC leaking in ceiling of band room, carpenter waiting to repair ceiling.	9/11/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	per ms longmeir 416-6125 rooms 317, 102, attendance office and plant manager's office blowing cold air and 3rd floor hallway blowing cold air	12/9/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	HEAT RMS 314, 320, 324, 308, 301, & 305-ALL NOT HEATING-PLANT MGR LONGMIRE 416-6125 KLR	12/9/13			Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	5-UV NOT HEATING IN RM- 302,307,311,318,211 PLANT MGR-LONGMIRE/416.4621	12/10/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	replace roof top for office	12/12/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	BOILER EAST END OF BLDG-NOT COMING ON-PLANT MGR LONGMIRE 416-6125 KLR	12/12/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Snowden need the Air changes to heat this week. 11/8/13	11/4/13	2nd Floor	All floor	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	The AIR FILTER needs changing	11/5/13	Portables	310A	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	3-BOILERS NOT COMING ON. PLANT MGR-LONGMIRE/416-4621	11/12/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	RADIATORS ON ALL FLRS-NOT COMING ON-PLANT MGR 416- 6125 KLR	11/14/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	3-UV NOT HEATING IN RM- 112,103,317 PLANT MGR-LONGMIRE/416.4621	11/18/13			Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	Rooms 101, 103, 104, 113, 114, 218, 301, 303 running but not cooling Ms. Longmyer 416-6125	7/18/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Monthly - Oil Lube & Belt-Snowden Middle - Refer to PM schedule details.	7/20/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Room 310 a/c unit leaking per Mr. Longmire 416-4621	7/25/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	CHILLER#1 IS NOT COMING ON. SBE LONGIMERE 416-6125	7/30/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Ventilating units rm 126, 128 and 103 are not cooling and room 103 feels like moisture in the air per Ms. Longmeier 416-6125	8/6/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	FCU 3RD FLR RM 302-NOT COOLING-SBE LONGMIRE 416-6125 KLR	8/15/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Monthly - Air Comp-1st Fir Mech Rm113-Snowden #090 - Refer to PM schedule details.	8/19/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	20-UV NOT COOLING EAST-END OF BLDG, & RM-324,318,212,213,324,318,212,213,104. PLANT MGR-LONGMIRE/416-4621	7/31/13			Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	AIR COOLED CHILLER-3 OUTSIDE NE-NOT COMING ON-SBE LONGMIRE 416-6126 KLR	7/31/13				Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Need the filter changes and the properly	8/5/13	Portables	p310B		Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Filter in not correct size need to changes	8/5/13	Portables	p310A		Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	This room is very damp and it is not cooling. The Work#365737This has been a problem since school start	8/20/13	1st Floor	103		Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	CHILLER NOT COMING ON THRU ENTIRE WEST-END OF BLDG. PLANT MGR-LONGMIRE/416.4621	8/30/13				Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	A/C WINDOW UNIT TEACHER'S LOUNGE COPIER RM & RM 130-BOTH NOT COMING ON-PLANT MGR LONGMIRE 416-6125 KLR	9/19/13				Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	HAD A POWER OUTAGE FRIDAY EVENING & THE AIR DID NOT COME BACK ON IN THE ENTIRE BLDG PER SBE-PLANT MGR LONGMIRE 416-6125 KLR	9/23/13				Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	RTU's in the AUTODI and ROOM 310 is NOT COMING ON per Ms. Longmire, Plant Mgr. 416.6125	10/2/13				Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	Need clean air filter in all the portable	10/2/13	Portables	All Portable	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Need to change filters	10/2/13	1st Floor	All Floor	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Air has been out for 2 weeks it not electrical	10/4/13	Gym	Gym classroom	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Monthly - Filter-Snowden Middle - Refer to PM schedule details.	10/5/13			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Fan Coil or roof top unit not cooling	10/15/13		cafeteria	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Room 124 is not cooling	10/18/13	1st Floor	124	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Need to add a thermostat in the kitchen	1/31/14	1st Floor	cafeteria	Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	This is a window Unit in the classroom and the motor is out NO AIR	9/12/13	1st Floor	copyRoom, 130	Heating/Ventilation /Air Conditioning

Snowden K8 (2690) 1A	Monthly - Filter-Snowden Middle - Refer to PM schedule details.	2/8/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Monthly - Filter-Snowden Middle - Refer to PM schedule details.	6/7/14			Heating/Ventilation /Air Conditioning
Snowden K8 (2690) 1A	Plaster two classroom 202, 126	7/30/13	2nd Floor	202,126	Painting
Snowden K8 (2690) 1A	Need to be paint with Green paint. Paint is on location All the STAIRWELL	1/7/14	2nd Floor	6 west stairwell	Painting
Snowden K8 (2690) 1A	Please paint classroom the plaster is finish. Before March 14, 2014	3/11/14	3rd Floor	309	Painting
Snowden K8 (2690) 1A	The corner beam need to be reair	4/3/14	Hallway/Corridor	next rm.306	Painting
Snowden K8 (2690) 1A	Need to paint hallway outside rm306	4/3/14	Hallway/Corridor	next rm 306	Painting
Snowden K8 (2690) 1A	The classroom need to be paint	4/4/14	1st Floor	109	Painting

Snowden K8 (2690) 1A	Need to paint room 313 and 309	5/1/14	3rd Floor	313	Painting
Snowden K8 (2690) 1A	Need all the restroom in the main building paint	4/2/14	Restroom (Boys)	Girls restroom	Painting
Snowden K8 (2690) 1A	The classroom need sheet rock and corner beam replace next to the entrance door	2/5/14	1st Floor	126	Painting
Snowden K8 (2690) 1A	please remove the graffiti from the pole and power wash them at the Top of the pavillion	2/17/14	Grounds	2 pavillion	Painting
Snowden K8 (2690) 1A	Need the exit Door for the cafeteria painted Snowden is having atown Hall Meeting in the cafeteria.	3/11/14	Cafeteria	Exit door	Painting
Snowden K8 (2690) 1A	Cafeteria need touch up paint for the Town Hall Meeting. March 14,2014	3/11/14	Cafeteria	Lobby cafeteria	Painting
Snowden K8 (2690) 1A	Please remove the Graffiti before the Town House meeting March 14	3/11/14	Grounds	Pavillion pole	Painting
Snowden K8 (2690) 1A	Please paint the lines on the park lot before the Town Hall meeting on March 15,2014	3/12/14	Parking Lot	Entire parking lot	Painting

Snowden K8 (2690) 1A	The Exit door in the cafeteria and top part of mall need to be paint before Town Hall Meeting on Friday Mar. 21 14	3/20/14	1st Floor	mall	Painting
Snowden K8 (2690) 1A	The restroom wall look bad with Graffiti	3/31/14	3rd Floor	Girls restroom 6grade	Painting
Snowden K8 (2690) 1A	Paint baseboard. See Mike Carmony	1/28/14			Painting
Snowden K8 (2690) 1A	Graffiti on the Gym See Plant Mrg.	9/3/13	Gym	outside	Painting
Snowden K8 (2690) 1A	Ms. Longmire requesting that my outer door be sanded and reshellaced because profanity has been etched into it	1/29/14	1st Floor	SBE office	Painting
Snowden K8 (2690) 1A	Please repair these restrooms soon .Theses are 1grade and kindgarten See Longmire	1/30/14	1st Floor	1st floor, Girls, 2nd restroom	Plumbing
Snowden K8 (2690) 1A	Missing a commode seat	2/7/14	2nd Floor	Boys elem.	Plumbing
Snowden K8 (2690) 1A	The 2nd urnial is stop up	2/10/14	3rd Floor	Boys Elem. next elevator	Plumbing

Snowden K8 (2690) 1A	The commode is stop up	2/10/14	Administration Area	Nurse station	Plumbing
Snowden K8 (2690) 1A	The Hand sink is stop up the girls restroom cant wash they hand	2/3/14	1st Floor	kk restroom Girls	Plumbing
Snowden K8 (2690) 1A	TOILET in the GIRL'S RR on the 1ST FLOOR is STOPPED UP per Ms. Longmire, Plant Mgr. 416.6125	2/3/14			Plumbing
Snowden K8 (2690) 1A	Hand Wash Sink is the handle is broken	2/4/14	1st Floor	Girls restroom	Plumbing
Snowden K8 (2690) 1A	The Floor drain is stop up. See Mrs Longmire for location	2/5/14	1st Floor	Next to rm 102	Plumbing
Snowden K8 (2690) 1A	The HAndcaip restroom the commode seat is broken.Please replace soon because we have a handicap students	2/18/14	3rd Floor	Girls restoom middle side	Plumbing
Snowden K8 (2690) 1A	Sink is leaking in the girls restoom Gym	2/21/14	Gym	Girls restroom	Plumbing
Snowden K8 (2690) 1A	RR TOILET shoots WATER from the BACK in the KINDERGARTEN WING per Ms. Longmire, Plant Mgr. 416.6125	2/21/14			Plumbing

Snowden K8 (2690) 1A	The sink is leaking it has hole in it	2/21/14	Cafeteria	kitchen	Plumbing
Snowden K8 (2690) 1A	GARBAGE DISPOSAL IS STOPPED UP PLANT MGR-LONGMIRE/416.4621	2/24/14			Plumbing
Snowden K8 (2690) 1A	NO HOT WATER IN CAFE PLANT MGR-LONGMIRE/416.4621	2/27/14			Plumbing
Snowden K8 (2690) 1A	Fan Coil unit leaking	5/5/14	1st Floor	105	Plumbing
Snowden K8 (2690) 1A	Drain is stop up	5/6/14	1st Floor	103	Plumbing
Snowden K8 (2690) 1A	These classroom is leaking From Fan Coil unit on the student desk.Need to be repair before TCap	4/22/14	2nd Floor	206,320,	Plumbing
Snowden K8 (2690) 1A	The Hand Sink is leaking from the bottom	4/28/14	1st Floor	8grade boys	Plumbing
Snowden K8 (2690) 1A	Boys Handicap restroom is stop up	4/28/14	3rd Floor	boys middle side	Plumbing

Snowden K8 (2690) 1A	Assist zone with backflow device	4/4/14			Plumbing
Snowden K8 (2690) 1A	The pipe in the ceiling is leaking	4/7/14	2nd Floor	226	Plumbing
Snowden K8 (2690) 1A	The pipe is leaking in the classroom over the student desk	4/7/14	2nd Floor	211	Plumbing
Snowden K8 (2690) 1A	The urinal is broken	4/8/14	3rd Floor	Boys restroom front 309	Plumbing
Snowden K8 (2690) 1A	In the Hallway the Fain Coil Unit Are leaking water. See Mrs Longmire for location	4/15/14	2nd Floor	3rd Floor	Plumbing
Snowden K8 (2690) 1A	The outside drain is stop up	4/15/14	1st Floor	outside drain	Plumbing
Snowden K8 (2690) 1A	FAN COIL UNIT is LEAKING in ROOM 212 per Ms. Longmire, Plant Mgr. 416.6125	4/21/14			Plumbing
Snowden K8 (2690) 1A	The 7th grade boys restroom the toilet stopped up. And has abroken toilet seat	4/3/14	2nd Floor	Boys 7grade next elevator	Plumbing

Snowden K8 (2690) 1A	Girls kk. by elevator has started leaking the handicap	4/3/14	1st Floor	Girls kk	Plumbing
Snowden K8 (2690) 1A	Urinal leaking from the bottom	4/3/14	1st Floor	1st grade boys	Plumbing
Snowden K8 (2690) 1A	The pipe in the ceiling is leaking on a student head in the classroom	4/3/14	2nd Floor	206	Plumbing
Snowden K8 (2690) 1A	Urinal stopped up	3/19/14	2nd Floor	boys next elevtor	Plumbing
Snowden K8 (2690) 1A	The Urinal stopped and leaking on the floor	3/19/14	1st Floor	1Grade Boys	Plumbing
Snowden K8 (2690) 1A	Leaking from the Air unit in the classroom	7/30/13	3rd Floor	310	Plumbing
Snowden K8 (2690) 1A	Need Plummer before town Hall Meeting The commode stop up	3/20/14	1st Floor	8grade Boys	Plumbing
Snowden K8 (2690) 1A	The cus.closet the mop sink is stop up	3/20/14	Custodial Closet	8grade	Plumbing

Snowden K8 (2690) 1A	The Hand Sink is broken	4/2/14	Cafeteria	kitchen	Plumbing
Snowden K8 (2690) 1A	Test and/or repair RP device for MLGW certify.	4/30/14			Plumbing
Snowden K8 (2690) 1A	Fan Coil unit is leaking over student desk	5/13/14	1st Floor	126	Plumbing
Snowden K8 (2690) 1A	Rust water leaking from the rear Air Conditioner	5/15/14	1st Floor	104	Plumbing
Snowden K8 (2690) 1A	The commode seat is broken	5/19/14	1st Floor	8grade boy restroom	Plumbing
Snowden K8 (2690) 1A	Please repair leaking Fan Coil unit	5/23/14	1st Floor	Band room closet	Plumbing
Snowden K8 (2690) 1A	Please up stop the mop sink it be 4week	7/30/13	1st Floor	mop room	Plumbing
Snowden K8 (2690) 1A	Commode in the Counselor office will not Flush and the tank either doesn't fill up or takes manys hours to fill back up with water.Please Help	1/8/14	3rd Floor	304	Plumbing

Snowden K8 (2690) 1A	The commode seat need to be replace.	1/8/14	Administration Area	men restroom	Plumbing
Snowden K8 (2690) 1A	Teacher restroom is stop up	1/15/14	3rd Floor	304	Plumbing
Snowden K8 (2690) 1A	The commode is loose at the bottom water is on the floor.This is dangerous for the 1st grade	1/21/14	1st Floor	1st grade restroom	Plumbing
Snowden K8 (2690) 1A	The commode is stop up	1/22/14	1st Floor	1st grade girls restroom	Plumbing
Snowden K8 (2690) 1A	The sink in the cafeteria kitchen is leaking	1/22/14	Kitchen	kitchen	Plumbing
Snowden K8 (2690) 1A	Broken commode seat	1/23/14	3rd Floor	Boys restroom middle school	Plumbing
Snowden K8 (2690) 1A	Broken commode seat	1/23/14	2nd Floor	2nd floor Elem. side	Plumbing
Snowden K8 (2690) 1A	This is teacher restroom it broken. Please help soon	1/23/14	3rd Floor	304	Plumbing

Snowden K8 (2690) 1A	Water cooler is stop up. Student need water	1/23/14	Cafeteria	Cafeteria	Plumbing
Snowden K8 (2690) 1A	The pipe is leaking in the closet	1/24/14	1st Floor	Cus. closet	Plumbing
Snowden K8 (2690) 1A	GAS SMELL IN G/LOCKER RM PLANT MGR-LONGMIRE/416.4621	1/27/14			Plumbing
Snowden K8 (2690) 1A	Two broken toilet seats inside stall	1/28/14	2nd Floor	2nd floor elem	Plumbing
Snowden K8 (2690) 1A	The Mop sink the handle is broken	1/29/14	Hallway/Corridor	3rd floor mop	Plumbing
Snowden K8 (2690) 1A	Girls restroom the 1 stall is stop up	1/29/14	1st Floor	1st grade wing	Plumbing
Snowden K8 (2690) 1A	Need two commode seats for the restroom	9/4/13	1st Floor	kk restroom Boys Girls	Plumbing
Snowden K8 (2690) 1A	The Girls restroom 1stall is stop up	9/5/13	1st Floor	8grade girls	Plumbing

Snowden K8 (2690) 1A	Snowden need a plumbing soon on all the floor. Ms Longmire send work order for 4 commode,	11/25/13	1st Floor	ALL the restrooms	Plumbing
Snowden K8 (2690) 1A	The sink in the classroom is leaking under the cabinet	11/26/13	2nd Floor	232	Plumbing
Snowden K8 (2690) 1A	Water Fountain need fixed outside of the prin. office	12/4/13	Administration Area	Front of Prin. office	Plumbing
Snowden K8 (2690) 1A	Sink stopped up.	12/4/13	Classroom	Rm 132	Plumbing
Snowden K8 (2690) 1A	GAS SMELL 1ST FLR FROM RM 125 TO MAIN OFC-PLANT MGR LONGMIRE 416-6125 KLR	12/11/13			Plumbing
Snowden K8 (2690) 1A	The Floor drain in the kitchen is stop up	12/12/13	Cafeteria	kitchen	Plumbing
Snowden K8 (2690) 1A	Leaking over 3rd and 4th computer	11/3/13	1st Floor	113	Plumbing
Snowden K8 (2690) 1A	The sink is leaking again	11/6/13	Cafeteria	kitchen	Plumbing

Snowden K8 (2690) 1A	The mop sink is stop up	11/10/13	Custodial Closet	2nd floor front library	Plumbing
Snowden K8 (2690) 1A	The Boys and Girls restroom both have problems has bags over the commode	11/14/13	1st Floor	1st grade	Plumbing
Snowden K8 (2690) 1A	Commode is stop up the 2nd stall	11/14/13	1st Floor	Girls restroom 8 grade	Plumbing
Snowden K8 (2690) 1A	The water cooler is stop up again. The pumber has repaired this water cooler at least 4times But the princpal want it repair soon	11/19/13	Administration Area	main office	Plumbing
Snowden K8 (2690) 1A	The Mop sink is stop up	11/19/13	Hallway/Corridor	3rd floor elem side	Plumbing
Snowden K8 (2690) 1A	Toilet in small stall runs and runs for 10min when flushed.	11/20/13	Gym	Girls Bathroom	Plumbing
Snowden K8 (2690) 1A	RTU IN THE CAFE IS LEAKING. SBE LONGIMERE 416- 6125	7/5/13			Plumbing
Snowden K8 (2690) 1A	RTU IS LEAKING WATER IN PRIN OFFICE (006). SBE-LONGMIRE/416-4621	7/15/13			Plumbing

Snowden K8 (2690) 1A	Replace the broken toilet seat	7/30/13	1st Floor	men restroom	Plumbing
Snowden K8 (2690) 1A	The mop Sink is stop up	7/18/13	1st Floor	8grade hallway	Plumbing
Snowden K8 (2690) 1A	The Roof Top unit is leaking on the seving line over the cash register	7/18/13	Kitchen	seving line	Plumbing
Snowden K8 (2690) 1A	The sinks in the classroom the water is moving slow to empty	7/22/13	1st Floor	113	Plumbing
Snowden K8 (2690) 1A	rm 101 a/c leaking per Mr. Longmeier 416-6125	7/24/13			Plumbing
Snowden K8 (2690) 1A	most times this commode is flushed it sticks and water just runs, need to be repaired	7/25/13	Administration Area	mens restroom in main office	Plumbing
Snowden K8 (2690) 1A	Air condition leaking water on the floor	7/29/13	1st Floor	101	Plumbing
Snowden K8 (2690) 1A	Air units leaking in the classroom	7/30/13	3rd Floor	310	Plumbing

Snowden K8 (2690) 1A	Water is moving slow in the sink in the classroom	7/29/13	1st Floor	113	Plumbing
Snowden K8 (2690) 1A	Boys restroom next to elevator is stop up	8/5/13	3rd Floor		Plumbing
Snowden K8 (2690) 1A	MOP SINK 1ST FLR 8TH GR HALL- STOPPED UP AND WATER RUNNING ON FLR PER SBE-SBE LONGMIRE 416-6125 KLR	8/5/13			Plumbing
Snowden K8 (2690) 1A	The kitchen has no Hot Water for cooking and wash dishes	8/6/13	Kitchen	kitchen	Plumbing
Snowden K8 (2690) 1A	Air Unit is leaking in the classroom	8/6/13	1st Floor	128	Plumbing
Snowden K8 (2690) 1A	The water cooler handle is broken	8/7/13	2nd Floor	Front middle library	Plumbing
Snowden K8 (2690) 1A	Boys commode is stop up	8/7/13	Restroom (Boys)	2nd floor next to elevator	Plumbing
Snowden K8 (2690) 1A	A/C UNIT MAIN OFC ROOF EAST- LEAKING DOWN WALL PER SBE-SBE LONGMIRE 416-6125 KLR	8/8/13			Plumbing

Snowden K8 (2690) 1A	The sink in the kitchen is leaking	8/8/13	Kitchen	kitchen	Plumbing
Snowden K8 (2690) 1A	Water leaks from faucet when you turn it on	8/9/13	2nd Floor	232	Plumbing
Snowden K8 (2690) 1A	No Hot WATER in the kitchen on 8/13/13	8/13/13	Kitchen	kitchen	Plumbing
Snowden K8 (2690) 1A	The Water cooling is running on the Kindergarten hall	8/13/13	Hallway/Corridor	kk wing	Plumbing
Snowden K8 (2690) 1A	Fan Coil unit is leaking in the hallway	8/13/13	Hallway/Corridor	Bell tower steps	Plumbing
Snowden K8 (2690) 1A	WATER FOUNTAIN KINDERGARTEN HALL-HAS BEEN KNOCKED DOWN FROM WALL & WATER SHOOTING OUT EVERYWHERE PER SBE-SBE LONGMIRE 416-6125 KLR	8/13/13			Plumbing
Snowden K8 (2690) 1A	Water cooler is broken	8/13/13	Hallway/Corridor	Front rm112	Plumbing
Snowden K8 (2690) 1A	Assist Marvin Crutchfield with locating sewer cleanout, will need generator for power	8/14/13			Plumbing

Snowden K8 (2690) 1A	The Faucet at table #3is constantly dripping the sink is not draining properly so water is backing up in the sink	8/19/13	2nd Floor	228	Plumbing
Snowden K8 (2690) 1A	The Air conditioner leaking in the classroom	8/1/13	1st Floor	104	Plumbing
Snowden K8 (2690) 1A	A/c unit is leaking	8/1/13	2nd Floor	205	Plumbing
Snowden K8 (2690) 1A	The sink in the restroom is leaking	8/2/13	Kitchen	restroom	Plumbing
Snowden K8 (2690) 1A	Air unit is leaking	8/2/13	1st Floor	104	Plumbing
Snowden K8 (2690) 1A	Fan Coil unit leaking in the classroom over the teacher computer	8/5/13	3rd Floor	324	Plumbing
Snowden K8 (2690) 1A	Air condition leaking in the classroom	8/5/13	2nd Floor	210	Plumbing
Snowden K8 (2690) 1A	LAB SINK RM 222 SCIENCE LAB-LEAKING, CAN'T CONTAIN PER PLANT MGR-PLANT MGR LONGMIRE 416-6125 KLR	8/20/13			Plumbing

Snowden K8 (2690) 1A	The Fan Coil unit is leaking	8/20/13	2nd Floor	228	Plumbing
Snowden K8 (2690) 1A	Thr faucet is leaking in the classroom	8/20/13	1st Floor	132	Plumbing
Snowden K8 (2690) 1A	The Fan Coil Unit is leaking in the hallway.Dangerous when the 6 grade pass classes	8/21/13	2nd Floor	2nd floor 6grade landing	Plumbing
Snowden K8 (2690) 1A	Test and/or repair RP devices per MLGW.	8/21/13			Plumbing
Snowden K8 (2690) 1A	Need commode seat	8/21/13	3rd Floor	Boys and Girls 6grade	Plumbing
Snowden K8 (2690) 1A	The two Units inthe classroom is leaking. Teacher don't have Air.The plumber repair but it is doing it again	8/23/13	2nd Floor	228	Plumbing
Snowden K8 (2690) 1A	Locate sewer cleanout in ball field	8/26/13			Plumbing
Snowden K8 (2690) 1A	The middle urinal is stop up	8/26/13	3rd Floor	Elem.sidenext elevator	Plumbing

Snowden K8 (2690) 1A	Base of the commode is very loose,replace screws	8/27/13	1st Floor	8Grade boys restroom	Plumbing
Snowden K8 (2690) 1A	The ACnit is dripping water contantly 3 Times	8/29/13	2nd Floor	228	Plumbing
Snowden K8 (2690) 1A	The commode is missing the seat	8/30/13	Gym	Boys restroom	Plumbing
Snowden K8 (2690) 1A	These Air Units STILL leaking WATER on the teacher book	8/30/13	1st Floor	104,228	Plumbing
Snowden K8 (2690) 1A	The 2nd floor Custodian closet backing up water ging down real slow	9/12/13	2nd Floor	7th grade hall across library	Plumbing
Snowden K8 (2690) 1A	1st stall stop up	9/12/13	2nd Floor	Girls 2nd floor east	Plumbing
Snowden K8 (2690) 1A	Commode the 1 stall is stop up	9/12/13	1st Floor	1st floor 8grade	Plumbing
Snowden K8 (2690) 1A	The 8 grade,KKwing,The commode is stop up and the boys kkwing is stop up	9/18/13	1st Floor	Girls restroom	Plumbing

Snowden K8 (2690) 1A	The commode are stop up	9/18/13	2nd Floor	Boys next elevtor	Plumbing
Snowden K8 (2690) 1A	Commode are stop	9/18/13	3rd Floor	3 rd next elevtor	Plumbing
Snowden K8 (2690) 1A	The sink is stop up agains	9/18/13	Kitchen	kitchen	Plumbing
Snowden K8 (2690) 1A	The commode is stop up	9/19/13	3rd Floor	Girls restroom across rm 309	Plumbing
Snowden K8 (2690) 1A	Air unit leaking in the classroom	9/24/13	1st Floor	128	Plumbing
Snowden K8 (2690) 1A	The sink in rhe ARt Room is leaking please help	10/1/13	1st Floor	132	Plumbing
Snowden K8 (2690) 1A	When enter the cafeteria water is leaking on the student head from the ceiling	10/4/13	Cafetorium	cafe lobby	Plumbing
Snowden K8 (2690) 1A	Test and repair RP Devices per MLG&W.	10/10/13	Mechanical Room		Plumbing

Snowden K8 (2690) 1A	Snowden need a plumbing soon on all the floor. Ms Longmire send work order for 4 commode,	10/14/13	1st Floor	ALL the restrooms	Plumbing
Snowden K8 (2690) 1A	Fan Coil Unit leaking over The cashier	10/14/13	Cafeteria	cafeteria seving line	Plumbing
Snowden K8 (2690) 1A	RTU SERVING LINE AREA OVER CASH REGISTER-LEAKING-PLANT MGR LONGMIRE 416-6125 KLR	10/14/13			Plumbing
Snowden K8 (2690) 1A	URINAL IS HANGING OFF WALL IN B/RR 1ST GRADE . PLANT MGR-LONGMIRE/416.4621	10/16/13			Plumbing
Snowden K8 (2690) 1A	The 8grade Girls restroom the 1 stall is stop up	10/16/13	1st Floor	boys restroom 1st floor	Plumbing
Snowden K8 (2690) 1A	The urinal is leaking	10/16/13	1st Floor	Boys kk wings	Plumbing
Snowden K8 (2690) 1A	The Mop sink is stop up	10/16/13	Custodial Closet	1st and 2nd Floor	Plumbing
Snowden K8 (2690) 1A	Commode is stop up	10/16/13	3rd Floor	Girls middle side	Plumbing

Snowden K8 (2690) 1A	commode is stop up	10/16/13	1st Floor	1st grade girls	Plumbing
Snowden K8 (2690) 1A	Boys urinal stop up	10/16/13	2nd Floor	Boys restroom next elevator	Plumbing
Snowden K8 (2690) 1A	need leaking faucet repair on south west coner or gym it is a mud hole there.	10/24/13	Gym	southwest gym	Plumbing
Snowden K8 (2690) 1A	RTU IS LEAKING WATER IN KITCHEN. PLANT MGR-LONGMIRE/416.4621	10/28/13			Plumbing
Snowden K8 (2690) 1A	The commode tank won't refill this commode is for the teacher only	1/7/14	3rd Floor	304	Plumbing
Snowden K8 (2690) 1A	The sink in the Art Room is stop up	12/4/13	1st Floor	132	Plumbing
Snowden K8 (2690) 1A	Fan Coil Unit is leaking	9/11/13	1st Floor	Band Room	Plumbing
Snowden K8 (2690) 1A	Work order #43865 and 412262 is in the 1grade wing .Parent are ask question about the problems Please HELP SOON	2/11/14	1st Floor	1grade Girls restroom	Plumbing

Snowden K8 (2690) 1A	Fan Coil Unit is leaking and need to be repair before TCAP start Monday April 28 14	4/22/14	2nd Floor	212	Plumbing
Snowden K8 (2690) 1A	There is a leak in the gym the single girls restroom.And Boys locker Room by the commode	2/5/14	1st Floor	gym	Roof
Snowden K8 (2690) 1A	The Classroom and Elem. Library are leaking	2/3/14	Library	Elem library, 104	Roof
Snowden K8 (2690) 1A	Leaking in the girls locker Room.Glutter is stop up	2/4/14	Gym	Locker room	Roof
Snowden K8 (2690) 1A	The roof is leaking Glutter stop up	2/4/14	Gym	Boys locker	Roof
Snowden K8 (2690) 1A	I can hear a drip astrong one in the hallway at the top of the East stairwell	2/5/14	2nd Floor	East stairwell	Roof
Snowden K8 (2690) 1A	The Glutter next to main office is broken from the ice It is leaking See Mrs Longmire	3/5/14	1st Floor	outside main door	Roof
Snowden K8 (2690) 1A	The Glutter was broken leaking in these two CLASSRom when the ice melt	3/6/14	3rd Floor	310 ,312	Roof

Snowden K8 (2690) 1A	This Room leaking every time it rain.It is very bad we have to use dust mop on the floor because we can't mop fast enough.We put the children in the library.Teacher computer has to be move. HELP	4/24/14	1st Floor	107	Roof
Snowden K8 (2690) 1A	Leaking in the classroom	4/28/14	1st Floor	109	Roof
Snowden K8 (2690) 1A	The roof is leaking over the computer	4/7/14	2nd Floor	226	Roof
Snowden K8 (2690) 1A	Roof leaking in the classroom over student head	4/7/14	2nd Floor	211	Roof
Snowden K8 (2690) 1A	leaking in the kitchen over the cooking table	4/7/14	Cafeteria	kitchen	Roof
Snowden K8 (2690) 1A	The roof is leaking in the classroom	4/9/14	2nd Floor	212	Roof
Snowden K8 (2690) 1A	When it Rain This classroom leaking is Bad. You will think that the room has no Roof	4/15/14	1st Floor	109	Roof
Snowden K8 (2690) 1A	The roof is leaking over the principal desk	6/24/14	Administration Area	Main office	Roof

Snowden K8 (2690) 1A	Rain in the prin. office again	6/26/14	Administration Area	prin. office	Roof
Snowden K8 (2690) 1A	Today is Sunday and it is raining again on the carpet. Wall is coming from wall and ceiling.Please HELP	6/29/14	Administration Area	Prin. office	Roof
Snowden K8 (2690) 1A	Rain is coming in the Financial office, See Longmire	6/29/14	Administration Area	Financial secretary	Roof
Snowden K8 (2690) 1A	Leaking in the classroom	4/4/14	1st Floor	109	Roof
Snowden K8 (2690) 1A	Leaking on the teacher desk and computer	1/9/14	2nd Floor	228	Roof
Snowden K8 (2690) 1A	Leaking in the Elem library and 104	1/9/14	Library	104,	Roof
Snowden K8 (2690) 1A	The Glutter are stop up is leaking in the classroom	11/25/13	1st Floor	104,elem. library	Roof
Snowden K8 (2690) 1A	Portable 310B has a roof leak	7/29/13	Portables		Roof

Snowden K8 (2690) 1A	The roof is leaking again over the seving line.For at least2years .Please help	8/5/13	Kitchen	over the seving line	Roof
Snowden K8 (2690) 1A	The Fan Coil Unit have came from the wall. Need it place back in place	1/30/14	Hallway/Corridor	3rd 2nd Floor	Sheet Metal
Snowden K8 (2690) 1A	The Locker # 2064 won't close at top or middle	2/14/14	2nd Floor	locker # 2064	Sheet Metal
Snowden K8 (2690) 1A	The Two locker is coming off the wall	2/20/14	2nd Floor	Locker 1199 ,1200	Sheet Metal
Snowden K8 (2690) 1A	Need the air vent replace back in place before they fell on the student heads louvers Student Cou. will be in the cafeteria March 15,14	3/10/14	Cafeteria	cafeteria above table	Sheet Metal
Snowden K8 (2690) 1A	The locker bent hard to open#1071	3/21/14	1st Floor	Locker# 1071	Sheet Metal
Snowden K8 (2690) 1A	Need vent cover made for ductwork in the boys restroom	1/22/14	1st Floor	8grade boys	Sheet Metal
Snowden K8 (2690) 1A	Room 126,220 need a door on the heater unit.Teacher said it is dangerous for the kids	12/9/13	2nd Floor	220	Sheet Metal

Snowden K8 (2690) 1A	Need to remove a large sheet metal pcs. that came off a root top unit. This is very dangerous for the KIDS	12/17/13	Grounds	Grave yard	Sheet Metal
Snowden K8 (2690) 1A	The locker will not lock	12/17/13	1st Floor	locker 1026	Sheet Metal
Snowden K8 (2690) 1A	Locker is broken	11/3/13	1st Floor	1074, 1089 Locker	Sheet Metal
Snowden K8 (2690) 1A	Locker are won't open	11/3/13	2nd Floor	locker 225 and 227 Elem side	Sheet Metal
Snowden K8 (2690) 1A	Water pours in right at door when it rains	11/5/13	Portables	310A	Sheet Metal
Snowden K8 (2690) 1A	Install new locker on 2nd & 3rd flrs.	7/8/13	Hallway/Corridor		Sheet Metal
Snowden K8 (2690) 1A	Need the keys for the new locker on the 2nd and 3rd floor	7/30/13	2nd Floor	5grade hallway 4grade hallway	Sheet Metal
Snowden K8 (2690) 1A	The locker#1121 with the open with the Master keys	8/9/13	1st Floor	1121 locker	Sheet Metal

Snowden K8 (2690) 1A	The lockers is stuck	8/16/13	3rd Floor	locker#3178 and 3030	Sheet Metal
Snowden K8 (2690) 1A	Locker is jammed and will not open	8/2/13	2nd Floor	2369	Sheet Metal
Snowden K8 (2690) 1A	Can not open because it is stuck	8/20/13	3rd Floor	Locker#3076	Sheet Metal
Snowden K8 (2690) 1A	The locker will open with out the combination	4/30/14	1st Floor	Locker 1199	Sheet Metal
Snowden K8 (2690) 1A	We have two new student desk need the legs sodered on	7/18/13	1st Floor	103	Sheet Metal

Count of Craft	Craft							Grand Total
	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	
Location								
South Side Middle (2696) 1A	2	2	46	135	46	1	73	305
Grand Total	2	2	46	135	46	1	73	305

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
South Side Middle (2696) 1A	gym floor needs to be refinished	10/2/13	Gym	1st fl.	Asbestos
South Side Middle (2696) 1A	Cove base falling off wall in mian office.	11/4/13	Administration Area		Asbestos
South Side Middle (2696) 1A	Split light control in renovated commons area and staff bathroom.	8/30/13	Annex		Cabling
South Side Middle (2696) 1A	bad network jack port # mdf 113-18	9/27/13	Classroom	113	Cabling
South Side Middle (2696) 1A	cove base missing	6/19/14	Cafeteria	serving line	Carpentry
South Side Middle (2696) 1A	missing cove base	6/19/14	Classroom	209	Carpentry
South Side Middle (2696) 1A	missing cove base	6/27/14	1st Floor	123	Carpentry

South Side Middle (2696) 1A	studnet stuck a hair pin in lock	3/24/14	Classroom	223 b-building	Carpentry
South Side Middle (2696) 1A	counter top needs to be repaired	4/8/14	Administration Area	main office	Carpentry
South Side Middle (2696) 1A	need dry erase board installed board is at location already	4/16/14	Custodial Closet	1st fl	Carpentry
South Side Middle (2696) 1A	floor tile missing	4/21/14	Hallway/Corridor	b-building 3rd fl.	Carpentry
South Side Middle (2696) 1A	can not lower flag	4/21/14	1st Floor	front entrance	Carpentry
South Side Middle (2696) 1A	BROKEN DOOR HANDLE	4/30/14	Administration Area	MAIN ENTRANCE	Carpentry
South Side Middle (2696) 1A	THRESHHOLD PLATE IS BROKEN	4/30/14	Administration Area	MAIN ENTRANCE	Carpentry
South Side Middle (2696) 1A	door closer needs repaired	5/19/14	Auditorium		Carpentry

South Side Middle (2696) 1A	BLEACHERS ARE JAMMED UP WILL NOT ROLL OUT ALL THE WAY	7/9/13	Gym		Carpentry
South Side Middle (2696) 1A	Broken window pane in the BAND ROOM on the E. side of school per Mr. Strickland, Plant Mgr. at 416.7420.	7/10/13			Carpentry
South Side Middle (2696) 1A	Break in Repair window front door	8/5/13			Carpentry
South Side Middle (2696) 1A	broken chair in this area	9/9/13	Auditorium		Carpentry
South Side Middle (2696) 1A	door needs to be repaired	9/23/13	Administration Area	main office	Carpentry
South Side Middle (2696) 1A	back gym exterior won't latch and can't secure per Mr. Strickland 416- 7430	10/3/13			Carpentry
South Side Middle (2696) 1A	door sticks very hard to open	10/22/13	Classroom	307	Carpentry
South Side Middle (2696) 1A	door closer broken	10/24/13	Gym		Carpentry

South Side Middle (2696) 1A	broken door closer	8/7/13	Gym		Carpentry
South Side Middle (2696) 1A	can not secure this area door will not close to lock	8/8/13	Library		Carpentry
South Side Middle (2696) 1A	door stricks very hard to open	8/9/13	2nd Floor	219	Carpentry
South Side Middle (2696) 1A	broken door closer	8/13/13	Gym		Carpentry
South Side Middle (2696) 1A	Hinge is hanging down can't be closed need repair.	12/9/13	Restroom (Boys)	1st. Flr. by Auditorium	Carpentry
South Side Middle (2696) 1A	Door is hanging can't be closed need repair.	12/9/13	Restroom (Girls)	1st. Flr. by Gym	Carpentry
South Side Middle (2696) 1A	Last stall door is completely off need repair.	12/9/13	Restroom (Boys)	3rd. Flr. Midle. Hallway	Carpentry
South Side Middle (2696) 1A	CAN NOT LOCK THIS DOOR	1/27/14	Auditorium		Carpentry

South Side Middle (2696) 1A	door still will not close and secure properly	1/29/14	Auditorium	door	Carpentry
South Side Middle (2696) 1A	floor tile needs to be replaced in some areas	2/5/14	Cafeteria		Carpentry
South Side Middle (2696) 1A	floor tile needs to be replaced	2/5/14	Hallway/Corridor	3rd fl. b-building	Carpentry
South Side Middle (2696) 1A	back door will not close properly	2/24/14	Gym		Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Boys)	MAIN HALLWAY	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	MAIN HALLWAY	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROPS	5/1/14	Cafeteria	ENTRANCE DOORS	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROPS	5/1/14	Administration Area	ENTRANCE DOORS	Carpentry

South Side Middle (2696) 1A	INSTALL DOOR PROPS	5/1/14	Restroom (Boys)	1ST FL B-BUILDING	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	1ST FL B-BUILDING	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	2ND FL B-BUILDING	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Boys)	2ND FL B-BUILDING	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Boys)	3RD FL B-BUILDING	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Restroom (Girls)	3RD FL B-BUILDING	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Gym	1ST FL	Carpentry
South Side Middle (2696) 1A	INSTALL DOOR PROP	5/1/14	Hallway/Corridor	1ST FL B-BUILDING	Carpentry

South Side Middle (2696) 1A	broken chair	8/7/13	Auditorium		Carpentry
South Side Middle (2696) 1A	missing cove base	6/19/14	Classroom	211	Carpentry
South Side Middle (2696) 1A	missing cove base	6/19/14	Classroom	215	Carpentry
South Side Middle (2696) 1A	large light fixture bulb in main hallway needs replaced light is flashing all day	6/10/14	Hallway/Corridor	1st fl	Electrical
South Side Middle (2696) 1A	The fire alarm panel is in trouble. Unable to reach SBE	6/17/14			Electrical
South Side Middle (2696) 1A	Oil bearing check belts on air handler	6/18/14		first floor a building	Electrical
South Side Middle (2696) 1A	Oil bearing check belts on air handler	6/18/14		second floor a building	Electrical
South Side Middle (2696) 1A	Oil bearing check belts on air handler	6/18/14		thrid floor a building	Electrical

South Side Middle (2696) 1A	Oil bearing check belts on air handler	6/18/14		thrid floor b building	Electrical
South Side Middle (2696) 1A	Oil bearing check belts on air handler	6/18/14		second floor b building	Electrical
South Side Middle (2696) 1A	Oil bearing check belts on air handler	6/18/14		first floor b building	Electrical
South Side Middle (2696) 1A	Oil & check belt on air handler cefeteria	6/19/14			Electrical
South Side Middle (2696) 1A	Oil & check belt on air handler auditorium	6/19/14			Electrical
South Side Middle (2696) 1A	Oil & check belt on air handler basemnt	6/19/14			Electrical
South Side Middle (2696) 1A	four ballast out	6/19/14	Cafeteria		Electrical
South Side Middle (2696) 1A	ballast out	6/19/14	Restroom (Girls)	3rd fl northend	Electrical

South Side Middle (2696) 1A	four ballast out	6/19/14	Classroom	223	Electrical
South Side Middle (2696) 1A	three ballast out	6/19/14	Classroom	213	Electrical
South Side Middle (2696) 1A	three ballast out	6/24/14	1st Floor	west hallway	Electrical
South Side Middle (2696) 1A	A/C RM 318, 317, 315, & 314-ALL NOT COMING ON, HAVE NO POWER-PLANT MGR STRICKLAND 416-7420 KLR	6/24/14			Electrical
South Side Middle (2696) 1A	outlet needs to be replaced	6/27/14	1st Floor	main hall	Electrical
South Side Middle (2696) 1A	four ballast out	6/27/14	1st Floor	110	Electrical
South Side Middle (2696) 1A	three ballast out	6/27/14	2nd Floor	210	Electrical
South Side Middle (2696) 1A	Replace lights in lobby	6/30/14			Electrical

South Side Middle (2696) 1A	need side basketball goals let down for tournament no keys to control panel	6/30/14	Gym	1ST FL	Electrical
South Side Middle (2696) 1A	9 lights out.	12/19/13	Classroom	3rd.Flr 318	Electrical
South Side Middle (2696) 1A	All Stairway lights out.	12/19/13	Stairway	1st.Flr. 2nd. & 3rd. Flr.	Electrical
South Side Middle (2696) 1A	breaker will not reset	4/10/14	Custodial Closet	1st fl b-building	Electrical
South Side Middle (2696) 1A	missing outlet cover	4/10/14	1st Floor	teacher lounge	Electrical
South Side Middle (2696) 1A	need three cases of bulbs # 46807	4/14/14			Electrical
South Side Middle (2696) 1A	need 20 house screw in bulbs	4/14/14			Electrical
South Side Middle (2696) 1A	five ballast out in this are needed for TCAP TESTING	4/15/14	Classroom	1st fl b-building rm 111four ba	Electrical

South Side Middle (2696) 1A	ballast outside room 114 needs replaced	4/21/14	Hallway/Corridor	1fl b-building	Electrical
South Side Middle (2696) 1A	three ballast out	4/21/14	Classroom	213 b-building	Electrical
South Side Middle (2696) 1A	ballast out	4/23/14	Hallway/Corridor	1st fl b-building	Electrical
South Side Middle (2696) 1A	NO POWER IN GUIDANCE OFFICE & TEACHERS' LOUNGE 2ND FLR PLANT MGR-COLEMAN/416.2257	4/23/14			Electrical
South Side Middle (2696) 1A	two ballast out from power outage	4/28/14	Classroom	b-312	Electrical
South Side Middle (2696) 1A	two ballast out from power outage	4/28/14	Classroom	3rd fl.b-317	Electrical
South Side Middle (2696) 1A	two ballast out from power outage	4/28/14	Classroom	2nd fl.b-211	Electrical
South Side Middle (2696) 1A	three ballast out from power outage	4/28/14	Administration Area	2nd fl.b-219	Electrical

South Side Middle (2696) 1A	three ballast out from power outage	4/28/14	Classroom	1st fl b-121	Electrical
South Side Middle (2696) 1A	no power in area	4/28/14	Custodial Closet	1st fl b-building	Electrical
South Side Middle (2696) 1A	water running in sink will not stop	4/28/14	Custodial Closet	3rd fl b-building	Electrical
South Side Middle (2696) 1A	TWO BALLAST OUT	4/29/14	Classroom	303	Electrical
South Side Middle (2696) 1A	TWO BALLAST OUT	4/29/14	Classroom	314	Electrical
South Side Middle (2696) 1A	exhaust fan no power	3/5/14	Restroom (Boys)	1st fl b-building	Electrical
South Side Middle (2696) 1A	under carport light is out	3/5/14	Parking Lot	northend	Electrical
South Side Middle (2696) 1A	outside front of school four lights are out	3/5/14	1st Floor	main entrance	Electrical

South Side Middle (2696) 1A	reset master clock for new time	3/5/14	Administration Area		Electrical
South Side Middle (2696) 1A	Pump #1 wire burnt on starter	3/6/14			Electrical
South Side Middle (2696) 1A	AHU -B BLDG 2ND FLR COVERS RM 208, 209, 210 & 211 - NOT COMING ON - PM/ STRICKLAND 416-7430	3/7/14			Electrical
South Side Middle (2696) 1A	broken outlet on bleacher	3/18/14	Gym		Electrical
South Side Middle (2696) 1A	14 Lights out.	12/19/13	Classroom	2nd.Flr. 221	Electrical
South Side Middle (2696) 1A	3 lights out.	12/19/13	Restroom (Girls)	2nd.Flr.	Electrical
South Side Middle (2696) 1A	3 lights out.	12/19/13	Restroom (Girls)	3rd.Flr.	Electrical
South Side Middle (2696) 1A	1 light out.	12/19/13	Classroom	3rd.Flr. 301	Electrical

South Side Middle (2696) 1A	3 lights out.	12/19/13	Restroom (Boys)	3rd.Flr.	Electrical
South Side Middle (2696) 1A	3 lights out.	12/19/13	Classroom	3rd.Flr. 303	Electrical
South Side Middle (2696) 1A	2 lights out.	12/19/13	Classroom	3rd.Flr. 302	Electrical
South Side Middle (2696) 1A	4 lights out.	12/19/13	Classroom	3rd.Flr. 306	Electrical
South Side Middle (2696) 1A	4 lights out.	12/19/13	Classroom	3rd.Flr. 307	Electrical
South Side Middle (2696) 1A	outside light is out in this area	5/16/14	1st Floor	notheast exit	Electrical
South Side Middle (2696) 1A	five ballast in this area	7/3/13	Hallway/Corridor	3rd fl b- building	Electrical
South Side Middle (2696) 1A	six ballast out in this area,bulbs are in fixture	7/3/13	Hallway/Corridor	1st fl b- building	Electrical

South Side Middle (2696) 1A	EXIT DOOR HAS NO POWER. A.S.D PROJECT GRAD SCHOOL	7/9/13	Athletic Field	hallway	Electrical
South Side Middle (2696) 1A	EXIT DOOR HAS NO POWER CAN NOT SECURE	7/9/13	Annex	ROOM 5	Electrical
South Side Middle (2696) 1A	NO LIGHTS TWO BALLAST OUT	7/12/13	Restroom (Boys)	MAIN HALL	Electrical
South Side Middle (2696) 1A	FOUR BALLAST OUT NO LIGHTS	7/12/13	Cafeteria	SERVING LINE	Electrical
South Side Middle (2696) 1A	RECEPTACLES IN THE PRINC OFFICE KEEP TRIPPING. SBE STRICKLAND 416-7420	7/30/13	Cafetorium		Electrical
South Side Middle (2696) 1A	Check motor on air handler 2nd floor	8/2/13			Electrical
South Side Middle (2696) 1A	In the Grad Academy side there is no power to receptacles in the kitchen, breaker keeps tripping and cannot reset per Strickland 416- 7420	8/6/13			Electrical
South Side Middle (2696) 1A	AHU SERVES RMS 309, 308, & 307-MAKING NOISE-PLANT MGR STRICKLAND 416-7430 KLR	8/29/13			Electrical

South Side Middle (2696) 1A	bells do not ring for school start time or dismissal	9/9/13	Administration Area		Electrical
South Side Middle (2696) 1A	Simplex performed the annual inspection of the fire alarm at SouthSide High on 8/28/13 and the following devices failed: Bldg B in Boys restroom by B309 – strobe (visual) failed Bldg B in Boys restroom 2nd floor	9/26/13			Electrical
South Side Middle (2696) 1A	Nine lights are out in this area	10/15/13	Gym	1st fl.	Electrical
South Side Middle (2696) 1A	two ballast out	10/15/13	Classroom	210	Electrical
South Side Middle (2696) 1A	six ballast out	10/15/13	Classroom	305	Electrical
South Side Middle (2696) 1A	two ballast out	10/15/13	Classroom	303	Electrical
South Side Middle (2696) 1A	ballast out bulbs are in	10/15/13	Classroom	301	Electrical
South Side Middle (2696) 1A	ballast out lights are flashing.bulbs are in	10/15/13	Hallway/Corridor	3rd fl	Electrical

South Side Middle (2696) 1A	ballast are out	10/15/13	Stairway	3rd fl	Electrical
South Side Middle (2696) 1A	ballast out. bulbs are in. by middle fan room	10/16/13	Hallway/Corridor	3rd fl	Electrical
South Side Middle (2696) 1A	north stairwell ballast out	10/16/13	Hallway/Corridor	3rd fl	Electrical
South Side Middle (2696) 1A	nine bulbs are out in this area	10/16/13	Gym		Electrical
South Side Middle (2696) 1A	need three cases of 46807 bulbs	10/16/13	1st Floor		Electrical
South Side Middle (2696) 1A	Pull bleacher motor for repairs	10/29/13			Electrical
South Side Middle (2696) 1A	four ballast are out	10/29/13	Administration Area	1ST FL 109	Electrical
South Side Middle (2696) 1A	7 lights out need repair.	11/8/13	Classroom	Teacher Work Area	Electrical

South Side Middle (2696) 1A	2 lights with Bad Ballast need repair.	11/8/13	Classroom	210 2nd Floor	Electrical
South Side Middle (2696) 1A	exhaust fan no power	8/7/13	Restroom (Boys)	2nd fl.	Electrical
South Side Middle (2696) 1A	exhaust fan no power	8/13/13	Restroom (Boys)	2nd fl b- building	Electrical
South Side Middle (2696) 1A	four lights out in this area	8/20/13	Grounds	front entrance	Electrical
South Side Middle (2696) 1A	Security lights need repairing 5 out front of building, 1 side of cafeteria, 1 corner of building by long driveway, 1 in court yard by carport area.	12/13/13	Grounds	Outside Building	Electrical
South Side Middle (2696) 1A	Grad Academy side security lights out need repairing, 2 at back door entrance, and 1 flood light 2 front door entrance, 2 at B building.	12/13/13	Grounds	Outside Building	Electrical
South Side Middle (2696) 1A	Flood light out.	11/19/13	Kitchen	Outside by Dumpster	Electrical
South Side Middle (2696) 1A	8 lights out.	12/19/13	Classroom	1st. Flr. 122	Electrical

South Side Middle (2696) 1A	1 light out.	12/19/13	Restroom (Boys)	1st. Flr.	Electrical
South Side Middle (2696) 1A	2 lights out.	12/19/13	Cafeteria	1st. Flr.	Electrical
South Side Middle (2696) 1A	5 lights out.	12/19/13	Kitchen	1st. Flr.	Electrical
South Side Middle (2696) 1A	Multiple lights are out.	12/19/13	Auditorium	1st. Flr.	Electrical
South Side Middle (2696) 1A	Fire alarm panel is in trouble. According to the panel smoke detector in room 208 is dirty.	12/20/13			Electrical
South Side Middle (2696) 1A	1st. Flr. Alt. Schl. classroom 208 Smoke Detector Dirty this need repairing.	12/20/13	Administration Area	1st. Flr.	Electrical
South Side Middle (2696) 1A	Light with Bad Ballast.	1/3/14	Hallway/Corridor	1st.Flr.By Cafe.	Electrical
South Side Middle (2696) 1A	Light with Bad Ballast.	1/3/14	Hallway/Corridor	1st.Flr.By Main Office	Electrical

South Side Middle (2696) 1A	Light with Bad Ballast.	1/3/14	Hallway/Corridor	1st.Flr.By Guidance	Electrical
South Side Middle (2696) 1A	6 lights with Bad Ballast.	1/3/14	Classroom	3rd. Flr. 310	Electrical
South Side Middle (2696) 1A	2 lights with Bad Ballast.	1/3/14	Classroom	3rd. Flr. 312	Electrical
South Side Middle (2696) 1A	3 lights with Bad Ballast.	1/3/14	Classroom	3rd. Flr. 314	Electrical
South Side Middle (2696) 1A	HEAT KITCHEN AREA-NOT COMING ON-PLANT MGR STRICKLAND 416-7420 KLR	1/8/14			Electrical
South Side Middle (2696) 1A	six ballast out in this area	1/17/14	Classroom	312	Electrical
South Side Middle (2696) 1A	bells will not ring for school start time or dismissal time	1/17/14	Administration Area		Electrical
South Side Middle (2696) 1A	three ballast out	1/17/14	Hallway/Corridor	main hall	Electrical

South Side Middle (2696) 1A	three ballast out	1/17/14	1st Floor	b-building	Electrical
South Side Middle (2696) 1A	four ballast out	1/17/14	Restroom (Boys)	lockerroom	Electrical
South Side Middle (2696) 1A	three ballast out in this area	1/17/14	Restroom (Girls)	lockerroom	Electrical
South Side Middle (2696) 1A	four ballast out	1/23/14	3rd Floor	314	Electrical
South Side Middle (2696) 1A	two ballast out in stairway	2/5/14	Hallway/Corridor	3rd fl b-building	Electrical
South Side Middle (2696) 1A	ballast out north stairway	2/5/14	Hallway/Corridor	3rd fl b-building	Electrical
South Side Middle (2696) 1A	light out very dark for cafeteria manager when she arrives	2/5/14	Grounds	behind cafeteria	Electrical
South Side Middle (2696) 1A	two ballast out	2/5/14	1st Floor	main hall	Electrical

South Side Middle (2696) 1A	three ballast out	2/24/14	Classroom	121	Electrical
South Side Middle (2696) 1A	6 Lights out on the outside, front of the Administration area.	11/19/13	Annex	Grad Academy/ Area	Electrical
South Side Middle (2696) 1A	Multiple lights out in Hallways on every Floor.	12/19/13	Hallway/Corridor	1st. Flr.	Electrical
South Side Middle (2696) 1A	11 lights out.	12/19/13	Classroom	1st. Flr. 113	Electrical
South Side Middle (2696) 1A	1 light out	12/19/13	Classroom	1st. Flr. 112	Electrical
South Side Middle (2696) 1A	6 lights out. Where is this located	12/19/13	Classroom	1st. Flr. 108	Electrical
South Side Middle (2696) 1A	Lights for rooms 100 -110 and hallways.	12/12/13	Classroom		Electrical
South Side Middle (2696) 1A	Boiler Room	12/19/13	Mechanical Room	1st. Flr. Annex side	Electrical

South Side Middle (2696) 1A	need four case's of bulbs 46807	8/26/13	Classroom		Electrical
South Side Middle (2696) 1A	3 lights out.	12/19/13	Classroom	1st. Flr. 124	Electrical
South Side Middle (2696) 1A	6 lights out.	12/19/13	Classroom	1st. Flr. 121	Electrical
South Side Middle (2696) 1A	Multiple lights out.	12/19/13	Portables	312	Electrical
South Side Middle (2696) 1A	Mr. White, Fluorescent Bulbs 46823 / 25 watt, Quantity 4 Boxes. These are needed at Southside Middle School, the name of the school has changed.	11/11/13			Electrical
South Side Middle (2696) 1A	near middle stairwell	10/15/13	Stairway	3rd fl	Electrical
South Side Middle (2696) 1A	3 lights out.	12/19/13	Classroom	3rd.Flir. 309	Electrical
South Side Middle (2696) 1A	5 lights out.	12/19/13	Classroom	3rd.Flir 310	Electrical

South Side Middle (2696) 1A	6 lights out.	12/19/13	Classroom	3rd.Flr 312	Electrical
South Side Middle (2696) 1A	2 lights out.	12/19/13	Classroom	3rd.Flr 314	Electrical
South Side Middle (2696) 1A	Monthly - Filter-Southside Middle - Refer to PM schedule details.	6/2/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	6/10/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	6/24/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	4/1/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - SOUTHSIDE/LONGVIEW LVL 2 WATER TREATMEN - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	clean top basins of cooling tower	4/7/14			Heating/Ventilation /Air Conditioning

South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	4/15/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - AirCompress#171 Southside/Longview Mid - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - Oil Lube & Belt-Southside Middle - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	check cooling tower	9/23/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	4/29/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	3/4/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	per mr strickland 416-7430 there is no heat entire building	3/6/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Water-Cool Chiller Filter-Southside Mid - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning

South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Cooling TowersSTRAINERS Southside Middle - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Rod Chiller - Southside Middle - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	clean top of tower	5/1/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - SOUTHSIDE/LONGVIEW LVL 2 WATER TREATMEN - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	5/13/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	5/27/14			Heating/Ventilation /Air Conditioning

South Side Middle (2696) 1A	cooling tower overflowing	7/25/13	Parking Lot		Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - Oil Lube & Belt-Southside Middle - Refer to PM schedule details.	9/20/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Oil Samples-Southside Middle - Refer to PM schedule details.	9/22/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - Filter-Southside Middle - Refer to PM schedule details.	9/30/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - AirCompress#171 Southside/Longview Mid - Refer to PM schedule details.	10/25/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	2-WALL UNITS NOT HEATING IN MAIN OFFICE. PLANT MGR- MCFARLAND/416.7420/416.8880	11/20/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	P-1 in boiler rm ---no fuses --- insert proper fuses, check motor and get running.	11/20/13			Heating/Ventilation /Air Conditioning

South Side Middle (2696) 1A	replace safety valves	11/25/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	P-1 in boiler room ---- 1/2 amp control fuse blown	12/3/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	3rd floor AHU's --- open water valves 50%	12/5/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	BOILER NOT HEATING. PLANT MGR- MCFARLAND/650.0389	11/12/13			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	boiler down	1/10/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	1/21/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - Filter-Southside Middle - Refer to PM schedule details.	2/3/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	UNIT NOT HEATING IN CAFE, & RM-305,304 PLANT MGR- STRICKLAND/237.5329	2/3/14			Heating/Ventilation /Air Conditioning

South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	2/4/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Daily - Southside/Longview Level 1 Water Treatme - Refer to PM schedule details.	2/18/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	BOILER - DOWN SHOWING LOW WTR - PM/STRICKLAND 416-7420	2/26/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	No wried connected to these units 135-148 & 135-147 Left Unit Isolated flow out south of this unit 135-146.	11/12/13	Mechanical Room	Grad Academy	Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Boiler 076 -Southside Alt-Boiler Rm N - Refer to PM schedule details.	3/25/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Boiler 074 -Southside Alt-Boiler Rm S - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Yearly - Boiler 075 -Southside Alt-Boiler Rm Ctr - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
South Side Middle (2696) 1A	Monthly - SOUTHSIDE/LONGVIEW LVL 2 WATER TREATMEN - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning

South Side Middle (2696) 1A	GRAFFITI IN B/RR-G/RR 1ST, 2ND, & 3RD FLRS PLANT MGR- STRICKLAND/416.7430	2/18/14			Painting
South Side Middle (2696) 1A	can not get sink unstopped in this room	4/2/14	Classroom	b-building 124	Plumbing
South Side Middle (2696) 1A	can not get sink unstopped in this room	4/2/14	Classroom	b-building 124	Plumbing
South Side Middle (2696) 1A	storm drain needs to be cleaned	4/8/14	Parking Lot		Plumbing
South Side Middle (2696) 1A	stopm drain needs to be cleaned out	4/8/14	Grounds	between a-b building	Plumbing
South Side Middle (2696) 1A	Cut water off to heat line	4/9/14			Plumbing
South Side Middle (2696) 1A	can not turn hot water off in kitchen sink	4/10/14	Kitchen		Plumbing
South Side Middle (2696) 1A	water in sink will not turn off	4/11/14	Administration Area	main office	Plumbing

South Side Middle (2696) 1A	water in sink will not turn off	4/11/14	Custodial Closet	northend	Plumbing
South Side Middle (2696) 1A	toilet will not flush	4/14/14	Restroom (Girls)	1st fl b- building northend	Plumbing
South Side Middle (2696) 1A	three compartment sink has water leak	4/17/14	Kitchen		Plumbing
South Side Middle (2696) 1A	two toilets are will not flush	4/24/14	Restroom (Girls)	2nd fl b- building	Plumbing
South Side Middle (2696) 1A	roof drain stooped up	4/29/14		roof	Plumbing
South Side Middle (2696) 1A	SINK WIIL NOT DRAIN	4/29/14	Custodial Closet	1ST FL	Plumbing
South Side Middle (2696) 1A	sink will not stop running	3/5/14	Custodial Closet	3rd fl b- building	Plumbing
South Side Middle (2696) 1A	TOILET STOPPED UP	3/10/14	Restroom (Boys)	2nd fl B- BUILDING	Plumbing

South Side Middle (2696) 1A	toilet will not stop running water	3/18/14	Restroom (Girls)	2nd fl b-building	Plumbing
South Side Middle (2696) 1A	toilet will not flush	3/18/14	Restroom (Boys)	3rd fl b-building	Plumbing
South Side Middle (2696) 1A	roof drain needs to be cleaned out	5/5/14	Administration Area	roof	Plumbing
South Side Middle (2696) 1A	Flush area drains at cooling tower	5/5/14			Plumbing
South Side Middle (2696) 1A	drinking fountain has water leak	5/16/14	Hallway/Corridor	3rd fl b-building	Plumbing
South Side Middle (2696) 1A	toilet valve leaking	7/5/13	Restroom (Boys)	3rd fl	Plumbing
South Side Middle (2696) 1A	mop sink will not drain	7/5/13	Custodial Closet	3rd fl	Plumbing
South Side Middle (2696) 1A	toilet vavle leaking	7/5/13	Restroom (Girls)	3rd fl	Plumbing

South Side Middle (2696) 1A	water fountain low pressure	7/5/13	Hallway/Corridor	3rd fl	Plumbing
South Side Middle (2696) 1A	stall vavle leaking	7/5/13	Restroom (Boys)	3rd fl	Plumbing
South Side Middle (2696) 1A	sink faucet leaking	7/5/13	Restroom (Boys)	3rd fl	Plumbing
South Side Middle (2696) 1A	urinal stoppef up	7/5/13	Restroom (Boys)	3rd fl	Plumbing
South Side Middle (2696) 1A	mop sink faucet leaking	7/5/13	Custodial Closet	3rd fl	Plumbing
South Side Middle (2696) 1A	crack in 1st toilet stall	7/5/13	Restroom (Girls)	3rd fl	Plumbing
South Side Middle (2696) 1A	toilet leaking in 1st stall	7/5/13	2nd Floor	Boys RR	Plumbing
South Side Middle (2696) 1A	mop sink draining slow	7/5/13	Custodial Closet		Plumbing

South Side Middle (2696) 1A	3rd toilet valve leaking	7/5/13	Restroom (Boys)	2nd floor	Plumbing
South Side Middle (2696) 1A	drinking fountain stopped up	7/5/13	Hallway/Corridor	2nd floor	Plumbing
South Side Middle (2696) 1A	flush valve leaking in 1st @ 2nd stalls	7/5/13	Restroom (Boys)	A-wing	Plumbing
South Side Middle (2696) 1A	1st, 2nd, @ 3rd flush valves leaking	7/5/13	Restroom (Girls)	A-wing	Plumbing
South Side Middle (2696) 1A	replace toilet seat	7/5/13	Restroom (Girls)	A-wing 1st floor	Plumbing
South Side Middle (2696) 1A	repair 2nd toilet	7/5/13	Restroom (Girls)	A-wing 1st floor	Plumbing
South Side Middle (2696) 1A	replace toilet seat	7/5/13	Gym	Boys restroom	Plumbing
South Side Middle (2696) 1A	drinking fountain not working	7/5/13	Auditorium	behind stage	Plumbing

South Side Middle (2696) 1A	TOILET STOPPED UP IN THIS AREA. A.S.D PROJECT GRAD SCHOOL	7/11/13	Restroom (Girls)	2ND FL	Plumbing
South Side Middle (2696) 1A	A.H.U #135-065 FLOODING	7/24/13	Auditorium		Plumbing
South Side Middle (2696) 1A	UNIT LEAKING IN RM 5. SB STRICKLAND 416-7420	7/24/13			Plumbing
South Side Middle (2696) 1A	No HOT WATER in the kitchen per Mr. Strickland, Plant Mgr at 901.416.7420.	7/30/13			Plumbing
South Side Middle (2696) 1A	No hot water in kitchen per Mr. Strickland 416-7420	8/5/13			Plumbing
South Side Middle (2696) 1A	leaking pipie from ceiling	9/9/13	Restroom (Boys)	2nd fl b-building	Plumbing
South Side Middle (2696) 1A	3rd floor water fountains running constantly and cannot shut off per Mr. Strickland 416-7430	9/23/13			Plumbing
South Side Middle (2696) 1A	Repair drain	10/10/13			Plumbing

South Side Middle (2696) 1A	Replace cut off at sink	10/18/13			Plumbing
South Side Middle (2696) 1A	SINK - CUSTODIAL CLOSET - REPAIR FAUCET - CAN'T TURN OFF - WTR CONTINUES TO RUN - PM/STRICKLAND 416-7430	10/21/13			Plumbing
South Side Middle (2696) 1A	sink stopped up will not drain	10/22/13	Classroom	124	Plumbing
South Side Middle (2696) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	10/31/13			Plumbing
South Side Middle (2696) 1A	Floor drain near kettle pot clogged up.	11/5/13	Cafeteria	kitchen	Plumbing
South Side Middle (2696) 1A	sink will not drain	8/21/13	Classroom	124	Plumbing
South Side Middle (2696) 1A	sink will not drain	8/21/13	Hallway/Corridor	1st.fl. by cafeteria	Plumbing
South Side Middle (2696) 1A	three compartment sink has leak	8/26/13	Kitchen		Plumbing

South Side Middle (2696) 1A	two compartment sink has leak	8/26/13	Kitchen		Plumbing
South Side Middle (2696) 1A	Water is leaking from under the sink.	11/25/13	Classroom	1st. Flr. 111	Plumbing
South Side Middle (2696) 1A	1st. Fauset constantly running will not cut off.	12/4/13	Gym	1st. Flr. Locker room	Plumbing
South Side Middle (2696) 1A	3rd stall water is coming from handle.	12/5/13	Restroom (Boys)	1st. Flr.by Comp. Lab	Plumbing
South Side Middle (2696) 1A	Sink is stopped up.	12/11/13	Classroom	1st. Flr.	Plumbing
South Side Middle (2696) 1A	Restroom drain is stopped up.	12/19/13	Restroom (Boys)	2nd. Flr.	Plumbing
South Side Middle (2696) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13			Plumbing
South Side Middle (2696) 1A	Behind portable there is large amount of water that's coming from a pipe.	12/19/13	Portables	312	Plumbing

South Side Middle (2696) 1A	Sink stopped up.	1/3/14	Custodial Closet	2nd. Flr.	Plumbing
South Side Middle (2696) 1A	hot water in sink will not shut off	1/13/14	Restroom (Boys)	lockeroom	Plumbing
South Side Middle (2696) 1A	floor drain stopped up	1/15/14	Restroom (Boys)	1st fl b-building	Plumbing
South Side Middle (2696) 1A	toilet will not flush	1/17/14	Restroom (Boys)	b-building	Plumbing
South Side Middle (2696) 1A	broken toilet seat	1/17/14	Restroom (Girls)	locker room	Plumbing
South Side Middle (2696) 1A	toilet will not flush	1/17/14	Restroom (Girls)	lockeroom	Plumbing
South Side Middle (2696) 1A	replace faucet in this area	1/17/14	Restroom (Boys)	lockeroom	Plumbing
South Side Middle (2696) 1A	toilet will not flush	1/23/14	Restroom (Boys)	1st a-building fl	Plumbing

South Side Middle (2696) 1A	sink stopped up in this area, please remove sink	1/29/14	Classroom	124	Plumbing
South Side Middle (2696) 1A	PIPE B RR 1ST FLR B BLDG HAS BURST & FLOOR DRAIN IN SAME RR-STOPPED UP-PLANT MGR STRICKLAND 416-7430 KLR	2/25/14			Plumbing

Count of Craft	Craft							Grand Total
	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	
Southwest Prep Academy (2828) 1A	1	10	43	28	5	48	6	141
Grand Total	1	10	43	28	5	48	6	141

Location	Request Description	Submittal Dat	Area Description	Area Number	Craft
Southwest Prep Academy (2828) 1A	Remove carpet and replace it with floor tile. carpet is a trip hazard.	9/12/13	Administration Area	2nd floor	Asbestos
Southwest Prep Academy (2828) 1A	RM A204-KNOB ON DOOR HARD TO TURN AND CLASS IS STUCK INSIDE PER SBE-PLANT MGR FANE 416-7884 KLR	8/29/13			Carpentry
Southwest Prep Academy (2828) 1A	Door knob handle is loose from cylinder	10/15/13	2nd Floor	B 205	Carpentry
Southwest Prep Academy (2828) 1A	Door knob handle is loose from cylinder.	10/15/13	Library	A-Building	Carpentry
Southwest Prep Academy (2828) 1A	Replace flag pole cable.	7/3/13	Grounds	Front of building	Carpentry
Southwest Prep Academy (2828) 1A	Door knob is broke in half.	7/10/13	2nd Floor	201A	Carpentry
Southwest Prep Academy (2828) 1A	Door closure is bad.	11/25/13	2nd Floor	Front enter door	Carpentry

Southwest Prep Academy (2828) 1A	Enter door will not open.	6/3/14	Cafeteria	1st floor	Carpentry
Southwest Prep Academy (2828) 1A	The screws on the counter top gate will not tight.	4/28/14	Administration Area	1st floor	Carpentry
Southwest Prep Academy (2828) 1A	DOOR TO RM A101- JAMED CAN'T OPEN AND THERE ARE STUDENTS INSIDE-PLANT MGR FANE 416-7884 KLR	4/30/14			Carpentry
Southwest Prep Academy (2828) 1A	per mr fane 416-7884 room A103 door is jammed and people can't get out and there are people in room	5/5/14			Carpentry
Southwest Prep Academy (2828) 1A	A106 unit ventilator not coming on per Fane 416- 7884	8/12/13			Electrical
Southwest Prep Academy (2828) 1A	CR A206 unit ventilator not working, B103 not working per Fane 416-7884	8/13/13			Electrical
Southwest Prep Academy (2828) 1A	Need twenty five fluorescent lamp.	8/28/13	2nd Floor	Plant manager office	Electrical
Southwest Prep Academy (2828) 1A	Light ballasts is burn out.	9/10/13	Library	2nd floor	Electrical

Southwest Prep Academy (2828) 1A	B203 uv not coming on per Mr. Fane 416-7884	9/12/13			Electrical
Southwest Prep Academy (2828) 1A	per Fane 416-7884 A105 unit ventilator is not coming on	9/16/13			Electrical
Southwest Prep Academy (2828) 1A	uv in room B103 not coming on per Mr. Fane 416-7884	10/2/13			Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	10/2/13	1st Floor	B 103	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	10/22/13	Kitchen	1st floor	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	10/23/13	Hallway/Corridor	2nd floor hall	Electrical
Southwest Prep Academy (2828) 1A	Set Master Clock for school new start time. And bell schedule.	8/1/13	Administration Area	2nd floor	Electrical
Southwest Prep Academy (2828) 1A	Room A206 a/c not working at all ID011041 per Mr. Fane 416-7874	8/7/13			Electrical

Southwest Prep Academy (2828) 1A	Unit Ventilator NOT COMING ON in Rm 105! Per Mr. Fane at 901.416.4258.	7/8/13			Electrical
Southwest Prep Academy (2828) 1A	Set Master Clock for daylight save time.	11/4/13	Administration Area	2nd floor	Electrical
Southwest Prep Academy (2828) 1A	B206 uv not coming on per Fane 416-7884	11/7/13			Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	11/8/13	Administration Area	A-209	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	11/15/13	2nd Floor	B-203	Electrical
Southwest Prep Academy (2828) 1A	I forget to say set Master Clock for daylight saving time. On the first work order.	3/4/14	Administration Area	2ndFloor	Electrical
Southwest Prep Academy (2828) 1A	UNIT VENT - RMB205 - NOT COMING ON - PM/FANE 416-7884	12/19/13			Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out	1/10/14	2nd Floor	A209	Electrical

Southwest Prep Academy (2828) 1A	UV NOT COMING ON IN RM-B205 PLANT MGR- FANE/416.7884	1/22/14			Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	2/17/14	2nd Floor	A207	Electrical
Southwest Prep Academy (2828) 1A	A104 UV not coming on per Mr. Fane 416-7884	2/26/14			Electrical
Southwest Prep Academy (2828) 1A	oil a/c unit east end first floor	6/12/14			Electrical
Southwest Prep Academy (2828) 1A	oil a/c uniteast end second floor	6/12/14			Electrical
Southwest Prep Academy (2828) 1A	oil a/c unit west end first floor	6/12/14			Electrical
Southwest Prep Academy (2828) 1A	oil a/c unit west end second floor	6/12/14			Electrical
Southwest Prep Academy (2828) 1A	replace disconnect	6/18/14		boy restroom	Electrical

Southwest Prep Academy (2828) 1A	peplace bearing on unit vent	6/18/14		B203	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	5/30/14	1st Floor	B bldg. hall	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	5/28/14	2nd Floor	A206	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	5/28/14	2nd Floor	A208	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	4/4/14	Restroom (Girls)	B Bldg.2nd floor	Electrical
Southwest Prep Academy (2828) 1A	UNIT VENT - RM B103 & B206 - NOT COMING ON - PM/FANE 416-7884	4/14/14			Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	4/14/14	1st Floor	B103	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	4/22/14	Hallway/Corridor	1st floor A Bldg.	Electrical

Southwest Prep Academy (2828) 1A	Light ballast is burn out.	4/22/14	Hallway/Corridor	1st floor B Bldg.	Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	4/23/14	Cafeteria	1st floor	Electrical
Southwest Prep Academy (2828) 1A	per fane 416-7884 room B103 UV not coming on	5/7/14			Electrical
Southwest Prep Academy (2828) 1A	Light ballast is burn out.	5/7/14	1st Floor	B103	Electrical
Southwest Prep Academy (2828) 1A	Set Master for daylight saving time.	3/4/14	Administration Area	2nd Floor	Electrical
Southwest Prep Academy (2828) 1A	I need seventy five fluorescent lamps . 4 Ft	11/20/13	Custodial Closet	2nd floor	Electrical
Southwest Prep Academy (2828) 1A	I don't know how many bulbs come in a box.The number on the bulb is FB32T8/TL741/6.	9/10/13	Library	2nd floor	Electrical
Southwest Prep Academy (2828) 1A	Check chiller. Will not start.	5/27/14			Heating/Ventil ation /Air Conditioning

Southwest Prep Academy (2828) 1A	Install sequence timer board in chiller and check compressor.	6/10/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	CHECK CHILLER WILL NOT RUN.	7/31/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	REPAIR CHILLER #2	8/8/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Monthly - Oil Lube & Belt- Stafford Alt High - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	clean chiller coil	8/13/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	chiller 1 b not cooling	8/13/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	B Building no a/c entire building per Fane 416-7884	8/13/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	UV RM A206-MAKING LOUD NOISES-SBE FANE 416-7884 KLR	8/20/13			Heating/Ventilation /Air Conditioning

Southwest Prep Academy (2828) 1A	UNIT VENT RM A206 - BLOWING NOT COOLING - PM/FANE 416-7884	8/26/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Room A206 UV not cooling per Mr. Fane 416-7884	9/12/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Ready for winter change over.	10/22/13	1st Floor	Boiler Room	Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	oil sample	10/23/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	supply sibley with 3 jugs of R22	8/1/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Monthly - Filter-Southwest Prep Academy - Refer to PM schedule details.	7/14/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Building B not cooling entire bldg, but unit B103 is not coming on at all per Fane 416-4258	7/30/13			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Monthly - Filter-Southwest Prep Academy - Refer to PM schedule details.	11/17/13			Heating/Ventilation /Air Conditioning

Southwest Prep Academy (2828) 1A	Monthly - Filter-Southwest Prep Academy - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Monthly - Oil Lube & Belt-Stafford Alt High - Refer to PM schedule details.	3/17/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	per fane 416-7884 there is no heat in A building	2/27/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	(2) BOILERS BOTH ARE NOT COMING ON - PM/FANE 416-7884	2/28/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	supply contractor 120lbs of R-22	6/18/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	A/C B BLDG-NOT COMING ON AT ALL-PLANT MGR FANE 416-7884 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	b bldg chiller down	4/29/14			Heating/Ventilation /Air Conditioning

Southwest Prep Academy (2828) 1A	RTU - COVERS B BLDG - NOT COMING ON - PM/FANE 416-7884	5/23/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Yearly - Boiler002- SouthwestPrep-Alt-1st FIMechRm - Refer to PM schedule details.	3/21/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Yearly - Boiler003- Southwest Prep- 1stFIMechRmS - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Southwest Prep Academy (2828) 1A	Parking Lot need to be stripe.	10/28/13	Grounds	Parking Lot	Painting
Southwest Prep Academy (2828) 1A	remove graffiti off the wall and ceiling.	5/29/14	Restroom (Boys)	2nd floor	Painting
Southwest Prep Academy (2828) 1A	remove graffiti off wall and ceiling.	5/29/14	Restroom (Girls)	2nd floor A bldg.	Painting
Southwest Prep Academy (2828) 1A	remove graffiti off wall and ceiling.	5/29/14	Restroom (Boys)	1st floor B bldg.	Painting
Southwest Prep Academy (2828) 1A	The room need painting.	5/23/14	2nd Floor	A205	Painting

Southwest Prep Academy (2828) 1A	Faucet is leaking	8/9/13	Administration Area	1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Pipe is broke loose from urinal and toilet.	8/16/13	Restroom (Boys)	1st floor A Building	Plumbing
Southwest Prep Academy (2828) 1A	UNIT VENT - RM A108 - LEAKING PM/FANE 416- 7884	8/22/13			Plumbing
Southwest Prep Academy (2828) 1A	urinal is leaking from flush valve.	8/29/13	1st Floor	B - Building	Plumbing
Southwest Prep Academy (2828) 1A	A/C RM A101-LEAKING- PLANT MGR FANE 416- 7884 KLR	9/3/13			Plumbing
Southwest Prep Academy (2828) 1A	B hallway Fan Coil Unit is leaking per fane 416-7884	9/12/13			Plumbing
Southwest Prep Academy (2828) 1A	Commode is stop up	9/24/13	Restroom (Girls)	1st floor A hall	Plumbing
Southwest Prep Academy (2828) 1A	Flush sewer lines	9/26/13			Plumbing

Southwest Prep Academy (2828) 1A	Water on urinal will not stop running.	9/27/13	Restroom (Boys)	B-Building 1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet is stop up.	8/6/13	Restroom (Girls)	1st floor A building	Plumbing
Southwest Prep Academy (2828) 1A	Urinal will not flush.	8/6/13	Restroom (Boys)	2nd floor A building	Plumbing
Southwest Prep Academy (2828) 1A	water cooler is stop up.	7/2/13	Cafeteria	1st floor	Plumbing
Southwest Prep Academy (2828) 1A	PILOT NEEDS TO BE FOR THE OVEN PLANT MGR-FANE/416.7826	3/7/14			Plumbing
Southwest Prep Academy (2828) 1A	Toilet is stop up.	12/10/13	Restroom (Girls)	1st floor A building	Plumbing
Southwest Prep Academy (2828) 1A	Test and report on backflow prevention devices.	12/19/13			Plumbing
Southwest Prep Academy (2828) 1A	PILOT HAS GONE ON STOVE KITCHEN AREA-PLANT MGR FANE 416-7884 KLR	1/6/14			Plumbing

Southwest Prep Academy (2828) 1A	Sink is stop up.	1/15/14	Custodial Closet	2nd floor A building	Plumbing
Southwest Prep Academy (2828) 1A	Test and report on backflow prevention devices.	1/21/14			Plumbing
Southwest Prep Academy (2828) 1A	Commode is stop up.	1/23/14	Restroom (Girls)	1st floor A building	Plumbing
Southwest Prep Academy (2828) 1A	Floor drain is stop up.	2/6/14	Restroom (Boys)	1st floor A building	Plumbing
Southwest Prep Academy (2828) 1A	Unstop sewer & wash down drive	2/21/14			Plumbing
Southwest Prep Academy (2828) 1A	Toilet leaks	6/5/14		3 rd floor	Plumbing
Southwest Prep Academy (2828) 1A	Repair toilet girls restroom	6/5/14		B103	Plumbing
Southwest Prep Academy (2828) 1A	Water fountain need handle	6/5/14			Plumbing

Southwest Prep Academy (2828) 1A	Faucet leaks	6/5/14		B201	Plumbing
Southwest Prep Academy (2828) 1A	UNIT VENT - RM A106 - LEAKING - PM/FANE 416- 7884	6/6/14			Plumbing
Southwest Prep Academy (2828) 1A	Toilet will not flush.	4/1/14	Restroom (Girls)	B Bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet is stop up.	4/9/14	Restroom (Girls)	A Building	Plumbing
Southwest Prep Academy (2828) 1A	Drinking fountain draining slow.	4/10/14	Restroom (Girls)	A bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Girls RR toilet is leaking.	4/10/14	Restroom (Girls)	A Bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Spud is leaking.	4/10/14	Restroom (Girls)	A Bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Urinal is leaking.	4/10/14	Restroom (Boys)	A Bldg. 2nd floor	Plumbing

Southwest Prep Academy (2828) 1A	Sink handle stripped.	4/10/14	Restroom (Boys)	A Bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Mop sink faucet is leaking.	4/10/14	Custodial Closet	A Bldg. 2n floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet seat is loose	4/10/14	1st Floor	Bldg.	Plumbing
Southwest Prep Academy (2828) 1A	Toilet seat is loose.	4/10/14	Restroom (Girls)	B bldg. 1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet seat is broken.	4/10/14	Restroom (Girls)	B Bldg. 1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Replace mop sink faucet - single .	4/10/14	Custodial Closet	B bidg. 1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Urinal not flushing.	4/10/14	Restroom (Boys)	B bldg. 1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Girls R.R. by the cafeteria toilet is leaking.	4/10/14	Restroom (Girls)	A bldg. 1st floor	Plumbing

Southwest Prep Academy (2828) 1A	Toilet not flushing.	4/10/14	Restroom (Girls)	B Bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Faucet is leaking.	4/10/14	Restroom (Girls)	B bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Drinking fountain by the boys r.r. not working.	4/10/14	2nd Floor	B bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet seat is loose.	4/10/14	Restroom (Boys)	B bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	urinal is stopped up.	4/10/14	Restroom (Boys)	B bldg. 2nd floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet is leaking.	4/10/14	Restroom (Girls)	A bldg. 1st floor	Plumbing
Southwest Prep Academy (2828) 1A	Toilet seat is broken.	4/10/14	Restroom (Girls)	3rd floor west end	Plumbing
Southwest Prep Academy (2828) 1A	Toilet is stopped up.	4/29/14	Restroom (Girls)	1st floor	Plumbing

Southwest Prep Academy (2828) 1A	Roof is leaking over serving area.	7/31/13	Grounds	roof over cafeteria	Roof
Southwest Prep Academy (2828) 1A	Roof is leaking from balcony over front enter door.	6/2/14	Grounds	Roof front of bldg.	Roof
Southwest Prep Academy (2828) 1A	Roof is leaking in the library area.	6/6/14	Library	Roof	Roof
Southwest Prep Academy (2828) 1A	Roof is leaking in the classroom.	6/6/14	2nd Floor	A208	Roof
Southwest Prep Academy (2828) 1A	Roof is leaking in the serving area.	6/10/14	Cafeteria	1st floor	Roof
Southwest Prep Academy (2828) 1A	Roof is leaking in the library.	4/2/14		Roof	Roof

Count of Craft	Craft								
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
ring Hill El (2707)	1	19	34	32	1	39	5	1	132
Grand Total	1	19	34	32	1	39	5	1	132

Location	Request Description	Submittal Date	Area Description	Area Number	Craft	Custom
Spring Hill EI (2707) 1B	Pipe need rewrapping on west end of building near boys restroom on 2nd grade hall	8/20/13			Asbestos	
Spring Hill EI (2707) 1B	Chain fence around playground located in back of school need repairing	2/28/14			Carpentry	
Spring Hill EI (2707) 1B	Railing located in back of building near ramp need repairing, damage by SCS delivery driver truck	11/22/13			Carpentry	
Spring Hill EI (2707) 1B	Adult restroom door on west end of main hall located near library need repairing	7/8/13			Carpentry	
Spring Hill EI (2707) 1B	Classroom 131 door knob need repairing	7/9/13			Carpentry	
Spring Hill EI (2707) 1B	Exit door need repair on west end of hall near cafeteria	7/19/13			Carpentry	
Spring Hill EI (2707) 1B	Door need repair on west end of hall to prevent rain from entering the building and flooding hall	7/19/13			Carpentry	
Spring Hill EI (2707) 1B	Classroom 110 door need repairing	2/11/14			Carpentry	
Spring Hill EI (2707) 1B	Boys restroom near cafeteria ceiling need repairing	2/12/14			Carpentry	

Spring Hill EI (2707) 1B	DOOR KNOB HAS COME COMPLETELY OFF IN RM-136. CANT GET IN RM PLANT MGR- LADD/921.1000	2/18/14			Carpentry	
Spring Hill EI (2707) 1B	Floor tiles need replacing in boys restroom located in the annex areal	2/21/14			Carpentry	
Spring Hill EI (2707) 1B	Hole need repairing on wall in boys restroom located near classroom 109	2/21/14			Carpentry	
Spring Hill EI (2707) 1B	Special cut tiles need replacing on east hall near classroom 102	8/20/13			Carpentry	
Spring Hill EI (2707) 1B	Classroom 108 door handle broke	8/29/13			Carpentry	
Spring Hill EI (2707) 1B	stall door broken in girls restroom near cafeteria	9/4/13			Carpentry	
Spring Hill EI (2707) 1B	Classroom 136 door knob is broken	9/5/13			Carpentry	
Spring Hill EI (2707) 1B	Exit screen door need replacing in kitchen area	9/12/13			Carpentry	
Spring Hill EI (2707) 1B	Repair and/or replace upper hinge on swinging gate.	10/1/13	Administration Area		Carpentry	
Spring Hill EI (2707) 1B	Vent cover locks need replacing on vent near restroom on wast hallway	10/3/13			Carpentry	

Spring Hill EI (2707) 1B	DOOR TO RM 123- HARDWARE DAMAGED, CAN'T UNLOCK-CLASS NEEDS TO GET IN PER SBE- PLANT MGR LADD 416-4346 KLR	10/4/13			Carpentry	
Spring Hill EI (2707) 1B	I would like to request 2 cases of T8 light bulbs	3/6/14			Electrical	
Spring Hill EI (2707) 1B	Clocks need set	11/4/13			Electrical	
Spring Hill EI (2707) 1B	electrician to look at the starter for boiler loop pump 4.	11/14/13			Electrical	
Spring Hill EI (2707) 1B	Ballant need replacing in custodial closet on annex hall	11/19/13			Electrical	
Spring Hill EI (2707) 1B	FIRE ALARM IS SHOWING TROUBLE PLANT MGR-LADD/416.4342	3/31/14			Electrical	
Spring Hill EI (2707) 1B	2 ballants need replacing in teacher lounge.	4/11/14			Electrical	
Spring Hill EI (2707) 1B	Classroom 126 need 3 ballants replace	4/23/14			Electrical	
Spring Hill EI (2707) 1B	2 light ballants in main office need replacing	5/19/14			Electrical	
Spring Hill EI (2707) 1B	CHILLER IS IN ALARM. SBE LADD 416-4342	6/23/14			Electrical	

Spring Hill EI (2707) 1B	HAS A COMPLETE POWER OUTAGE-PLANT MGR LADD 416-4342 KLR	6/24/14			Electrical	
Spring Hill EI (2707) 1B	Clock need replacing on wall in classroom123	8/9/13			Electrical	
Spring Hill EI (2707) 1B	I need 2 cases of T8 light bulbs (See Jim D. before proceeding).	7/22/13			Electrical	
Spring Hill EI (2707) 1B	Set bells to new time	7/29/13			Electrical	
Spring Hill EI (2707) 1B	HEAT RM 138-MAKING NOISES-PLANT MGR LADD 416-4346 KLR	12/9/13			Electrical	
Spring Hill EI (2707) 1B	BREAKER BY TEACHER'S LOUNGE-KEEPS TRIPPING KNOCKING POWER OUT TO TEACHER'S LOUNGE & LIBRARY-PLANT MGR LADD 416-4342 KLR	1/21/14			Electrical	
Spring Hill EI (2707) 1B	Light fixture cover need replacing in annex	2/3/14			Electrical	
Spring Hill EI (2707) 1B	HEAT RM 131-HAS A BURNING SMELL-PLANT MGR LADD 416-4346 KLR	2/12/14			Electrical	
Spring Hill EI (2707) 1B	Clocks need changing , due to daylight saving	2/25/14			Electrical	
Spring Hill EI (2707) 1B	4 outside lights on back of building in high area need replacing	8/12/13			Electrical	

Spring Hill EI (2707) 1B	VENT-A-HOOD KITCHEN- NOT COMING ON-WILL NEED-PLANT MGR LADD 416-4346 KLR	8/22/13			Electrical	
Spring Hill EI (2707) 1B	Classroom 114 Ballant need replacing	8/26/13			Electrical	
Spring Hill EI (2707) 1B	A/C GUIDANCE OFC-NOT COMING ON-LEAD CUST GALLOWAY 416-3796 KLR	8/29/13			Electrical	
Spring Hill EI (2707) 1B	I need 2 boxes of energy bulbs- 23 w.120v. for walk in freezer in kitchen area	9/10/13			Electrical	
Spring Hill EI (2707) 1B	Front porch light not working in high area	9/13/13			Electrical	
Spring Hill EI (2707) 1B	POWER OUTAGE THRU ENTIRE BLDG . PLANT MGR-LADD/921.1000	9/24/13			Electrical	
Spring Hill EI (2707) 1B	FIRE ALARM IS SHOWING TROUBLE . PLANT MGR-LADD/921.1000	9/24/13			Electrical	
Spring Hill EI (2707) 1B	Bells not ringing due to clocks need resetting	9/25/13			Electrical	
Spring Hill EI (2707) 1B	2 ballants need replacing on hallway beside boys restroom near cafeteria	9/25/13			Electrical	
Spring Hill EI (2707) 1B	I need 3 cases of T8 lights bulbs	10/3/13			Electrical	

Spring Hill EI (2707) 1B	light bulb broken in socket located on vent hood in kitchen area	10/15/13			Electrical	
Spring Hill EI (2707) 1B	I need 3 cases of T8 w/starcoat light bulbs (U Shape)	10/29/13			Electrical	
Spring Hill EI (2707) 1B	2 ballants need replacing in main office	10/30/13			Electrical	
Spring Hill EI (2707) 1B	2 Ballants out in kitchen area	10/30/13			Electrical	
Spring Hill EI (2707) 1B	Clocjk need replacing on wall in classroom123	8/9/13			Electrical	
Spring Hill EI (2707) 1B	per ms ladd 416-4342 hvac unit in ceiling leaking	3/7/14			Heating/Ventilation /Air Conditioning	
Spring Hill EI (2707) 1B	2-BOILERS NOT COMING ON. PLANT MGR-LADD/	11/7/13			Heating/Ventilation /Air Conditioning	
Spring Hill EI (2707) 1B	Monthly - Oil Lube & Belt-Spring Hill EI - Refer to PM schedule details.	11/10/13			Heating/Ventilation /Air Conditioning	
Spring Hill EI (2707) 1B	CHANGE FROM HEAT TO A/C-REQUESTED BY O SCHLAFER KLR	4/1/14			Heating/Ventilation /Air Conditioning	
Spring Hill EI (2707) 1B	per ms ladd 416-4342 rooms 122, 123, 125, 126 a/c not coming on	5/8/14			Heating/Ventilation /Air Conditioning	

Spring Hill EI (2707) 1B	CHILLER MECH RM-NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR LADD 416-4346 KLR	5/9/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	CHILLER NOT COMING ON PLANT MGR-LADD/921.1000	5/13/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	Monthly - Oil Lube & Belt-Spring Hill EI - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	chiller down	6/23/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	replace vfd's in boiler room	8/6/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	UNITS ARE NOT COOLING 134 & 104. SBE LADD 416-	8/7/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	Monthly - Filter-Spring Hill Elementary - Refer to PM schedule details.	7/20/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	2-UNITS NOT COOLING IN RM-118(205) RM-134 ANNEX (021).	7/22/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	2-UNITS NOT COOLING IN RM-118(205) RM-134 ANNEX (021). SBE-LADD/	7/22/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	UNIT NOT COMING ON IN PRIN CONFER RM. LEAD PERSON- GALLOWAY/643.5037	7/25/13			Heating/Ventilation /Air Conditioning

Spring Hill EI (2707) 1B	3-AHU NOT COOLING IN CAFE(111,112,113) . PLANT MGR- JEFFERSON/416.4346	7/25/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	BOILER MECH RM-IN ALARM-PLANT MGR LADD 416-4346 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	HEAT MAIN OFC & CONFERENCE RM-BOTH NOT HEATING-PLANT MGR LADD 416-4346 KLR	1/22/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	UNITS are NOT HEATING in ROOMS 112 and 128 per Ms. Ladd, Plant Mgr. 416.4346	2/3/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	UNIT NOT COMING ON IN LIBRARY OFFICE. PLANT MGR-LADD/416.4346	2/4/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	UNIT NOT HEATING IN PRIN OFFICE & CONFER RM PLANT MGR-LADD/921.1000	2/6/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	UNIT is LEAKING in CLASSROOM 110 per Ms. Ladd, 416.4346	2/14/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	A/C IN RM 134-NOT COOLING-PLANT MGR LADD 416-4346 KLR	8/20/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	RTU EAST HALL-LEAKING- PLANT MGR LADD 416-4342 KLR	8/26/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	CHILLER IN ALARM-PLANT MGR LADD 416-4342 KLR	8/29/13			Heating/Ventilation /Air Conditioning

Spring Hill EI (2707) 1B	A/C MAIN OFC-LEAKING-PLANT MGR LADD 416-4346 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	A/C RM 114-NOT COOLING-PLANT MGR LADD 416-4346 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	A/C SBE'S OFC-LEAKING-PLANT MGR LADD 416-4346 KLR	9/11/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	A/C RM 126, 124, & KITCHEN-ALL NOT COOLING-PLANT MGR LADD 416-4346 KLR	9/12/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	RTU NOT COOLING IN CAFE. PLANT MGR-LADD/416.4346	9/27/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	Monthly - Filter-Spring Hill Elementary - Refer to PM schedule details.	11/23/13			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	Monthly - Filter-Spring Hill Elementary - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Spring Hill EI (2707) 1B	Ceilling falling in boys restroom located beside stage in cafeteria (See journal notes).jd	8/1/13			Painting
Spring Hill EI (2707) 1B	Handle broken on toilet in girls restroom located on west end of building beside computer lab.	3/18/14			Plumbing
Spring Hill EI (2707) 1B	Toilet in boys restroom located in annex not flushing properly	3/20/14			Plumbing

Spring Hill EI (2707) 1B	SINK HAS FALLEN OFF WALL IN B/RR BY RM-109 PLANT MGR-LADD/416.4342	3/31/14			Plumbing	
Spring Hill EI (2707) 1B	Boys restroom toilet located beside classroom 109 not flushing properly	4/1/14			Plumbing	
Spring Hill EI (2707) 1B	Teacher restroom on east end of building not flushing properly	4/1/14			Plumbing	
Spring Hill EI (2707) 1B	Toilet handle broken in girls restroom located in annex area	5/6/14			Plumbing	
Spring Hill EI (2707) 1B	UNIT IS LEAKING WATER IN MAIN OFFICE PLANT MGR-LADD/416.4346	5/8/14			Plumbing	
Spring Hill EI (2707) 1B	FACILITATOR'S OFC HAS A LEAK BUT SBE DOESN'T KNOW WHERE IT COMING FROM-A PUDDLE IS IN THE MIDDLE OF THE FLR, EVEN AFTER MOPPING PER SBE- PLANT MGR LADD 416-4342	5/12/14			Plumbing	
Spring Hill EI (2707) 1B	UNIT IS LEAKING WATER IN MAIN OFFICE PLANT MGR-LADD/416.4346	6/5/14			Plumbing	
Spring Hill EI (2707) 1B	CEILING PIPE IS LEAKING WATER IN FRONT ENTRY PLANT MGR-LADD/921.1000	6/12/14			Plumbing	
Spring Hill EI (2707) 1B	UNIT IS LEAKING WATER IN MAIN OFFICE PLANT MGR-LADD/921.1000	6/16/14			Plumbing	
Spring Hill EI (2707) 1B	A/C UNITS is LEAKING in MAIN OFFICE per Ms. Ladd, Plant Mgr. 416.4342	6/25/14			Plumbing	

Spring Hill EI (2707) 1B	AHU - IN MAIN OFC LEAKING - PM/LAD 416- 4342	6/30/14			Plumbing	
Spring Hill EI (2707) 1B	NO HOT WATER IN THE KITCHEN. SBE LADD 416- 4648	8/2/13			Plumbing	
Spring Hill EI (2707) 1B	Toilet leaking in boys restroom near annex	8/2/13			Plumbing	
Spring Hill EI (2707) 1B	Urinal not working on west end hall near annex	8/5/13			Plumbing	
Spring Hill EI (2707) 1B	Replace relief and prv valve on chillwater system.	7/15/13			Plumbing	
Spring Hill EI (2707) 1B	RTU IS LEAKING WATER IN MAIN OFFICE (196). SBE-LADD/416-4346	7/16/13			Plumbing	
Spring Hill EI (2707) 1B	Toilet leaking in boys restroom in annex area	7/18/13			Plumbing	
Spring Hill EI (2707) 1B	WATER FOUNTAIN CAFE AREA-WATER CONSTANTLY RUNNING FROM SPOUT- SBE HAS IT UNPLUGGED, STILL RUNNING-PLANT MGR LADD 416-4643 KLR	11/27/13			Plumbing	
Spring Hill EI (2707) 1B	FLOOR DRAIN KITCHEN AREA-BACKING UP SEWAGE-PLANT MGR LADD 416-4346 KLR	2/14/14			Plumbing	
Spring Hill EI (2707) 1B	Water fountain making loud noise located beside boys restroom in cafeteria	8/9/13			Plumbing	

Spring Hill EI (2707) 1B	UNIT IS LEAKING IN MAIN OFFICE PLANT MGR-LADD/416.4346	8/21/13			Plumbing	
Spring Hill EI (2707) 1B	ALL THE WATER IN THE KITCHEN AREA IS RUNNING HOT-PLANT MGR LADD 416-4346 KLR	8/22/13			Plumbing	
Spring Hill EI (2707) 1B	RTU IS LEAKING WATER IN RM-109(182) PLANT MGR-LADD/416.4346	8/23/13			Plumbing	
Spring Hill EI (2707) 1B	Toilet seat broken in girls restroom near cafeteria	9/4/13			Plumbing	
Spring Hill EI (2707) 1B	faucet makes loud noise when turning water on in boys restroom near cafeteria	9/4/13			Plumbing	
Spring Hill EI (2707) 1B	NO WATER AT ALL TO KITCHEN PER SBE-PLANT MGR LADD 416-4346 KLR	9/18/13			Plumbing	
Spring Hill EI (2707) 1B	Water fountain leaking in classroom 132	9/19/13			Plumbing	
Spring Hill EI (2707) 1B	Broken toilet seat need replacing in girls restroom near cafeteria	9/19/13			Plumbing	
Spring Hill EI (2707) 1B	Water fountain making loud noise on east end hall	9/19/13			Plumbing	
Spring Hill EI (2707) 1B	a/c leaking in room 131 per Ms. Ladd 416-4346	9/20/13			Plumbing	

Spring Hill EI (2707) 1B	WATER FOUNTAIN RM 32- CONSTANTLY LEAKING- PLANT MGR LADD 416-4346 KLR	9/26/13			Plumbing	
Spring Hill EI (2707) 1B	Faucet need reparing in girls restroom near cafeteria area	10/16/13			Plumbing	
Spring Hill EI (2707) 1B	Sink leaking in kitchen area near dishwasher.	10/28/13			Plumbing	
Spring Hill EI (2707) 1B	Garbage disposal not working in kitchen area	10/28/13			Plumbing	
Spring Hill EI (2707) 1B	FLOOR DRAIN KITCHEN AREA-BACKING UP SEWAGE-PLANT MGR LADD 416-4346 KLR	10/31/13			Plumbing	
Spring Hill EI (2707) 1B	Main office restroom faucet leaking	10/31/13			Plumbing	
Spring Hill EI (2707) 1B	Main office restroom faucet leaking	10/31/13			Plumbing	
Spring Hill EI (2707) 1B	Roof leaks on east hall located near double exit doors beside restrooms	11/22/13			Roof	
Spring Hill EI (2707) 1B	Roof leaks in cafeteria manager office	11/22/13			Roof	
Spring Hill EI (2707) 1B	Roof leaking on main hall located near conference room	3/31/14			Roof	

Spring Hill El (2707) 1B	HEAT RM 107-LEAKING THRU AIR VENT PER SBE- PLANT MGR LADD 416-4346 KLR	12/16/13			Roof	
Spring Hill El (2707) 1B	Classroom 110 roof leaking	2/11/14			Roof	
Spring Hill El (2707) 1B	Gutter need repairing near outside boiler room door	7/2/13			Sheet Metal	

Count of Craft	Craft							Grand Total
	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	
Location								
Springdale El (2707) 1B	1	22	40	35	1	22	3	124
Grand Total	1	22	40	35	1	22	3	124

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Springdale El (2707) 1B	Pipes in the ceiling near Plant Mgr. Office needs some pipe covers	2/13/14	Hallway/Corridor	See Mgr.	Asbestos
Springdale El (2707) 1B	per ms brunson 416-4880 in the boiler room the window is broken out	4/14/14			Carpentry
Springdale El (2707) 1B	BACK DOOR BY PARK, CAN'T SECURE PLANT MGR- BRUNSON/277.8353	4/17/14			Carpentry
Springdale El (2707) 1B	MAIN ENTRY DOOR CANT SECURE PLANT MGR- BRUNSON/277.8353	5/2/14			Carpentry
Springdale El (2707) 1B	Fix cabinet	7/22/13	Classroom	Room 204	Carpentry
Springdale El (2707) 1B	Markee board needs to be repair hard to open	8/22/13	Administration Area	See Plant Manager	Carpentry
Springdale El (2707) 1B	REAR KITCHEN DOOR-NOT LOCKING-WON'T BE ABLE TO SECURE BLDG-PLANT MGR BRUNSON 416-4883 KLR	9/26/13			Carpentry
Springdale El (2707) 1B	Replace damage tile (around sprinkle system)	10/1/13	Library	See Mgr.	Carpentry

Springdale El (2707) 1B	Request for a bulletin board	10/4/13	Administration Area	See Prin.	Carpentry
Springdale El (2707) 1B	Fix stall door	10/4/13	Restroom (Girls)	Pre K Hall	Carpentry
Springdale El (2707) 1B	fix door	10/4/13	Administration Area	book store	Carpentry
Springdale El (2707) 1B	Request cabinet be removed to allow plumber to replace pipes.	12/10/13			Carpentry
Springdale El (2707) 1B	stall door need to be replaced (broken)	12/18/13	Restroom (Girls)	near room 301	Carpentry
Springdale El (2707) 1B	Replace ceiling tiles in room 408.	1/16/14			Carpentry
Springdale El (2707) 1B	Replace ceiling tiles in room 408.	1/16/14			Carpentry
Springdale El (2707) 1B	Replace damage ceiling tiles.	1/22/14	Classroom	Room 408, 405, 407	Carpentry
Springdale El (2707) 1B	Replace missing ceiling tiles	1/22/14	Cafeteria	Kitchen	Carpentry

Springdale EI (2707) 1B	Replace missing floor tile	1/22/14	Classroom	Rm. 106	Carpentry
Springdale EI (2707) 1B	Replace Damage ceiling tiles. (pipe Leaks)	1/24/14	Hallway/Corridor	See Plant Mgr.	Carpentry
Springdale EI (2707) 1B	Cabinet door needs repair	1/24/14	Administration Area	Main Office	Carpentry
Springdale EI (2707) 1B	Fix cabinet door	1/31/14	Classroom	rm 208	Carpentry
Springdale EI (2707) 1B	Repair bookcase	1/31/14	Classroom	Rm 408,106,107,303, 304	Carpentry
Springdale EI (2707) 1B	Request panels be stained.	2/12/14			Carpentry
Springdale EI (2707) 1B	please set our bell schedule for the upcoming school year	7/10/13	Administration Area	main office	Electrical
Springdale EI (2707) 1B	per ms brunson 416-4883 room 206 a/c won't come on at all	5/5/14			Electrical
Springdale EI (2707) 1B	A/C MAIN OFC-NOT COMING ON-PLANT MGR BRUNSON 416- 4583 KLR	5/21/14			Electrical

Springdale EI (2707) 1B	UNIT IN THE LIBRARY AND RM 310 IS NOT COMING. SBE BRUNSON 416-883	7/22/13			Electrical
Springdale EI (2707) 1B	Request from Prin. to reset bells schedule.	7/22/13	Administration Area		Electrical
Springdale EI (2707) 1B	Light out very dark (urgent)	7/22/13	Hallway/Corridor	SPED Hall	Electrical
Springdale EI (2707) 1B	UV-2 RM 207-NOT COMING ON-SBE BRONSON 416-4883 KLR	8/2/13			Electrical
Springdale EI (2707) 1B	UV-2 RM RM 105-OVERHEATING PER SBE AND HAS A BURNING SMELL-SBE BRONSON 416-4883 KLR	8/8/13			Electrical
Springdale EI (2707) 1B	Set Master clock back to reg. standard time.	8/9/13	Administration Area	Main Office	Electrical
Springdale EI (2707) 1B	needs 3 boxes of bulb	10/29/13	Custodial	See Plant Manager	Electrical
Springdale EI (2707) 1B	light out (Dark in room)	10/29/13	Library	Library office	Electrical
Springdale EI (2707) 1B	light out X 5 (URGENT) very very dark	10/31/13	Hallway/Corridor	Pre K hall	Electrical

Springdale EI (2707) 1B	light out Main Hall	11/19/13	Hallway/Corridor	See Mgr.	Electrical
Springdale EI (2707) 1B	UV KEEPS SHUTTING OFF IN RM-202 PLANT MGR- BRUNSON/416.4883	8/14/13			Electrical
Springdale EI (2707) 1B	Cable wire on flag pole needs to be repair can't remove flag	8/22/13	Administration Area	See Plant Manager	Electrical
Springdale EI (2707) 1B	2-UV NOT COMING ON IN IN RM-207(071), RM-202 PLANT MGR- BRUNSON/416.7150	8/26/13			Electrical
Springdale EI (2707) 1B	Prin. request to have bell schedule reset	8/26/13	Administration Area	See Prin.	Electrical
Springdale EI (2707) 1B	A/C-1 MAIN OFC-NOT COMING ON-PLANT MGR BRONSON 416-4883 KLR	8/28/13			Electrical
Springdale EI (2707) 1B	A/C MAIN OFC-NOT COMING ON-PLANT MGR BRONSON 416-4883 KLR	8/29/13			Electrical
Springdale EI (2707) 1B	Set master clock (ringing pm time not am time (URGENT)	9/9/13	Administration Area	See Plant Manager	Electrical
Springdale EI (2707) 1B	light out (URGENT)	9/10/13	Restroom (Girls)	near room 301	Electrical

Springdale EI (2707) 1B	light out	9/10/13	Hallway/Corridor	near room 405	Electrical
Springdale EI (2707) 1B	Unit Ventilator in ROOM 202 is NOT COMING ON per Ms. Brunson, Plant Mgr. 416.4883	9/20/13			Electrical
Springdale EI (2707) 1B	UV RM 202-NOT COMING ON-PLANT MGR BRUNSON 416-4883 KLR	9/26/13			Electrical
Springdale EI (2707) 1B	CONDENSER UNIT NOT COMING ON IN MAIN OFFICE PLANT MGR-BRUNSON/277.8353	9/26/13			Electrical
Springdale EI (2707) 1B	light out	10/1/13	Hallway/Corridor	5th Grade Hall	Electrical
Springdale EI (2707) 1B	UV RM 202-NOT COMING ON-PLANT MGR BRUNSON 416-4883 KLR	10/1/13			Electrical
Springdale EI (2707) 1B	light out	12/9/13	Kitchen	Serving Line	Electrical
Springdale EI (2707) 1B	Round light fixture falling again	12/10/13	Hallway/Corridor	Main entrance	Electrical
Springdale EI (2707) 1B	UNIT NOT COMING ON IN KITCHEN PLANT MGR-BRUNSON/416.4883	1/16/14			Electrical

Springdale EI (2707) 1B	lights bulb t-8, and case of small lamp.	2/27/14			Electrical
Springdale EI (2707) 1B	light out	2/28/14	Hallway/Corridor	Main Entrance	Electrical
Springdale EI (2707) 1B	Light out X5	3/4/14	Hallway/Corridor	Pre K Hall	Electrical
Springdale EI (2707) 1B	Boiler not coming on.	3/4/14			Electrical
Springdale EI (2707) 1B	Light out in classrooms (URGENT)	3/5/14	Classroom	Rm. 401, 402, 403, 404, 100, 106, 105	Electrical
Springdale EI (2707) 1B	Light out in classrooms.	3/5/14	Classroom	Rm. 302,303, 304	Electrical
Springdale EI (2707) 1B	Request for 3 boxes of bulbs for classroom. Attn: Mr. Means	3/5/14	Custodial	See Plant Mgr.	Electrical
Springdale EI (2707) 1B	light out X3	3/6/14	Kitchen	servicing line	Electrical
Springdale EI (2707) 1B	light out	3/18/14	Hallway/Corridor	Main entrance	Electrical

Springdale EI (2707) 1B	COOLING TOWER IS NOT COMING ON. SBE MITCHELL 416-	7/15/13			Electrical
Springdale EI (2707) 1B	Monthly - Oil Lube & Belt-Springdale Elementary - Refer to PM schedule details.	6/7/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	CHILLER NOT COMING ON (001). SBE-MITCHELL/416-4883	7/15/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	A/C unit, ID#059-099 NOT COOLING in the kitchen per Ms. Brunson, Plant Mgr. at 901.416.4883.	7/29/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	UV NOT COOLING IN RM-402(083) PLANT MGR-BRUNSON/416.4883	8/12/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Repair leaking pump	10/31/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	BOILER NOT COMING ON. PLANT MGR-BRUNSON/416.7150	11/7/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	UV NOT HEATING IN RM-402. PLANT MGR-BRUNSON/277.8353	11/8/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	UV RM 405-OVERHEATING-TEMP IS 81-PLANT MGR BRONSON 416-4883 KLR	11/8/13			Heating/Ventilation /Air Conditioning

Springdale El (2707) 1B	THERMOSTATS RMS 207 & 303- BOTH NOT WORKING PROPERLY-PLANT MGR BRONSON 416-4883 KLR	11/8/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	Monthly - Oil Lube & Belt- Springdale Elementary - Refer to PM schedule details.	11/9/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	UV NOT HEATING IN RM-402 PLANT MGR- BRUNSON/416.4883	11/12/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	HEAT RM 402-NOT HEATING- PLANT MGR BRONSON 416- 7150 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	per Ms. Brunson 416-4883 rooms 401, 403, 404 the freeze stat tripped blowing cold air	11/14/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	HEAT RMS 202 & 204-BOTH NOT HEATING-PLANT MGR BRONSON 416-4883 KLR	11/14/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	3-UV NOT HEATING IN RM- 401,402,403 PLANT MGR- BRUNSON/277.8353	11/25/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	5-UV NOT HEATING IN IN RM- 404,405,202,204,208 PLANT MGR- BRUNSON/277.8353	11/25/13			Heating/Ventilation /Air Conditioning
Springdale El (2707) 1B	Unit Ventilators are NOT HEATING in ROOMS 202, 204, 208, 401, 402, 403, and 404 per Ms. Brunson, Plant Mgr. 416.4883	12/2/13			Heating/Ventilation /Air Conditioning

Springdale EI (2707) 1B	A/C UNIT MAIN OFC-NOT COOLING-PLANT MGR BRUNSON 416-4883 KLR	8/26/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	A/C MAIN OFC-NOT COOLING-PLANT MGR BRUNSON 416-4883 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Library a/c not cooling per Ms. Brunson 416-4883	9/17/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	library a/c is not cooling and there is a meeting in there today per Ms. Brunson 416-4883	9/20/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	UNIT VENT - RM 202 - NOT COOLING - PM/BRUNSON 416-4883	10/4/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Unit Ventilators are NOT HEATING in ROOMS 201, 202, 208, 401, 402, 403, AND 404 per Ms. Brunson, Plant Mgr. 416.4883	12/9/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	HEAT CAFE AREA, RMS 202, 404, 104, 107, 106, 30, & 304- ALL NOT HEATING-PLANT MGR BRUNSON 416-4883 KLR	12/16/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	HEAT RMS 303, 402, 207, & 208- OVERHEATING PER SBE-TEMP IS 90-PLANT MGR BRUNSON 416-4883 KLR	1/3/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	HEAT RMS 204 & 404-BOTH NOT HEATING-PLANT MGR BRUNSON 416-4883 KLR	1/3/14			Heating/Ventilation /Air Conditioning

Springdale EI (2707) 1B	replace controllers damaged by busted coils	1/8/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	per Ms. Brunson 416-4883 kitchen has no heat blowing cold air	1/8/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Repair or replace all busted coils	1/17/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	UNIT NOT HEATING IN RM-402. PLANT MGR- BRUNSON/416.4883	1/21/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	repair busted coil rm 107	2/1/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	CHANGE FROM HEAT TO A/C- REQUESTED BY O SCHLAFFER KLR	4/1/14			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Monthly - Filter-Springdale Elementary - Refer to PM schedule details.	8/13/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Monthly - Filter-Springdale Elementary - Refer to PM schedule details.	12/7/13			Heating/Ventilation /Air Conditioning
Springdale EI (2707) 1B	Monthly - Filter-Springdale Elementary - Refer to PM schedule details.	4/5/14			Heating/Ventilation /Air Conditioning

Springdale El (2707) 1B	Request to have outside entrance pole painted.	10/18/13	Administration Area	See Prin	Painting
Springdale El (2707) 1B	FLR DRAIN IS STOPPED UP IN BOILER CAUSING A FLOOD. PLANT MGR-BRUNSON/416.4883	8/1/13			Plumbing
Springdale El (2707) 1B	sink leaking	10/22/13	Administration Area	Teacher Lounge	Plumbing
Springdale El (2707) 1B	kitchen sink leaking	10/23/13	Kitchen	See Mrg.	Plumbing
Springdale El (2707) 1B	toilet leaking	11/5/13	Restroom (Girls)	Pre K Hall	Plumbing
Springdale El (2707) 1B	toilet leaking from bottom	11/19/13	Restroom (Girls)	Pre K Hall	Plumbing
Springdale El (2707) 1B	pipe leaking	12/3/13	Restroom (Boys)	near room 401	Plumbing
Springdale El (2707) 1B	Request back flow test.	9/5/13			Plumbing
Springdale El (2707) 1B	not working	9/11/13	Restroom (Girls)	Pre K Hall	Plumbing

Springdale El (2707) 1B	Pump is leaking in the BOILER ROOM per Ms. Brunson, Plant Mgr. 416.4883	9/20/13			Plumbing
Springdale El (2707) 1B	toilet won't flush	10/1/13	Restroom (Boys)	Pre K Hall	Plumbing
Springdale El (2707) 1B	UNIT VENT - RM 207 - LEAKING - PM/BRUNSON 416-4883	10/4/13			Plumbing
Springdale El (2707) 1B	toilet won't stop running	10/4/13	Restroom (Girls)	Pre K Hall	Plumbing
Springdale El (2707) 1B	COMMODE B RR KINDERGARTEN HALL-PIPE HAS BURST TO IT AND WATER RUNNING EVYERWHERE PER SBE, CAN'T CONTAIN OR CUT OFF-PLANT MGR BRUNSON 416-4883 KLR	10/4/13			Plumbing
Springdale El (2707) 1B	Pump not working in the boiler room	12/18/13			Plumbing
Springdale El (2707) 1B	PIPES HAVE BURST IN RMS 202, 207, 208, & 303-WATER RUNNING EVERYWHERE, CAN'T CONTAIN-PLANT MGR BRONSON 416-4883 KLR	1/6/14			Plumbing
Springdale El (2707) 1B	urnial stop up	1/9/14	Restroom (Boys)	near room 301	Plumbing
Springdale El (2707) 1B	urnial pipe leaking	1/24/14	Restroom (Boys)	near rm. 301	Plumbing

Springdale El (2707) 1B	toilet broken	1/24/14	Restroom (Girls)	near rm 301	Plumbing
Springdale El (2707) 1B	COMMODE G RR KINDERGARTEN AREA- CONSTANTLY OVERFLOWING, CAN'T CUT OFF OR CONTAIN- PLANT MGR BRONSON 416- 4348 KLR	1/24/14			Plumbing
Springdale El (2707) 1B	umial broken	2/19/14	Restroom (Boys)	5th grade hall	Plumbing
Springdale El (2707) 1B	toilet crack and seat needs to be replaced.	2/21/14	Restroom (Girls)	Pre K Hall	Plumbing
Springdale El (2707) 1B	BOILER RM FLOODED OUT- SBE DOES NOT KNOW WHERE WATER COMING FROM-PLANT MGR BRONSON 416-4883 KLR	4/2/14			Plumbing
Springdale El (2707) 1B	ceiling leaking	9/24/13	Classroom	rm 403	Roof
Springdale El (2707) 1B	CEILING PIPE IS LEAKING WATER IN RM-405 PLANT MGR- BRUNSON/416.4883	1/10/14			Roof
Springdale El (2707) 1B	CEILING IS LEAKING WATER IN RM-405,407 PLANT MGR- BRUNSON/416.4883	1/17/14			Roof

Count of Craft	Craft							
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Trezevant CTC (2727) 1B	1	39	67	34	7	12	2	162
Grand Total	1	39	67	34	7	12	2	162

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Trezevant CTC (2727) 1B	please install new line for fax machine move fax machine from principal office to the main office. (SCS Network Cabling and Electronics dept.-- "Please See Journal Notes")	1/23/14	1st Floor	main office	Cabling
Trezevant CTC (2727) 1B	please deliver 50 screws to repair students desk and chairs in rooms #125.123.	5/6/14	1st Floor	rooms 125,123	Carpentry
Trezevant CTC (2727) 1B	please repair the chain on the door that raise the door up and down.the chain come off the wheel sometime in the diesel mechanic#118.	5/21/14	1st Floor	diesel mechanic#118	Carpentry
Trezevant CTC (2727) 1B	please install a 4"x 4" bulletin board in room#125.	3/31/14	1st Floor	break room near rm125	Carpentry
Trezevant CTC (2727) 1B	please install a 4"x 4" bulletin board on the wall near room#125.	3/31/14	1st Floor	break rm near rm 125	Carpentry
Trezevant CTC (2727) 1B	please install a 3 x 4 bulletin board in room#125.	3/31/14	1st Floor	room#125	Carpentry
Trezevant CTC (2727) 1B	The Inspector says install a door closer on the back door on the east side of the kitchen so the door can closed tight.	10/29/13	Kitchen	kitchen	Carpentry
Trezevant CTC (2727) 1B	please open stroage room door for the secretary.the door are not stuck. the lock cylinder will not turn.files in the room for the secretary.(urgent)	11/13/13	Administration Area	secretary storage Room	Carpentry
Trezevant CTC (2727) 1B	please install weather strips on the west front entrance doors.to keep the cool air out of the building.	11/14/13	1st Floor	west front doors	Carpentry

Trezevant CTC (2727) 1B	please replace the door lock on the closet door inside adult business room#111.for storage computer for night class.	2/25/14	1st Floor	closet inside rm#111	Carpentry
Trezevant CTC (2727) 1B	please repair the door closer in the hallway near the boys restroom.the door hang up at the top of the door closer.	3/7/14	1st Floor	hallway near boys R.R	Carpentry
Trezevant CTC (2727) 1B	please move (2) bulletin boards in the break area and install the same (2) bulletin boards on the wall in the break area in a different location see the plant manager(urgent)	3/20/14	1st Floor	break room area	Carpentry
Trezevant CTC (2727) 1B	Principal request the fade plexiglass be replace with new plexiglass in front of the school building on the west side.attn.(Brian Shipp)	9/9/13	1st Floor	west front of sch.bldg	Carpentry
Trezevant CTC (2727) 1B	please repair the door lock.the door handle hang up and some time the door hard to open from in side the lady restroom in the main office.	9/7/13	Administration Area	Lady R.R main office	Carpentry
Trezevant CTC (2727) 1B	please install a cock strips on the dry erase boards in the cosmetology #123.	8/26/13	1st Floor	cosmetology#123.	Carpentry
Trezevant CTC (2727) 1B	please deliver one bundle of 2"x 2"ceiling tiles for the hallways.	8/27/13	1st Floor	plant manager office	Carpentry
Trezevant CTC (2727) 1B	the principal say please repair or install a lock on the boys and girls restroom doors.	8/27/13	1st Floor	boys and girl restroom	Carpentry
Trezevant CTC (2727) 1B	please repair the door closer.the west front doors will not close and latch.	8/13/13	Hallway/Corridor	west front doors	Carpentry
Trezevant CTC (2727) 1B	please repair broken door fram in classroom#128.	8/19/13	Classroom	classroom#128	Carpentry

Trezevant CTC (2727) 1B	please replace 30 peices of water damage 2"x2"ceiling tiles in the culinary arts dinning room#128.	8/22/13	1st Floor	culinary art rm.128	Carpentry
Trezevant CTC (2727) 1B	please install a 4"x 4" bulletin board in cosmetology #123.	9/16/13	1st Floor	cosmetology #123	Carpentry
Trezevant CTC (2727) 1B	please install diagnostic station on the wall in the helth science lab #117.	9/18/13	1st Floor	health science#117	Carpentry
Trezevant CTC (2727) 1B	Door knob keeps coming off in the Ladies RR in the MAIN OFFICE per Mgr. Willie Golden, Plant Mgr. 416.0189	9/24/13			Carpentry
Trezevant CTC (2727) 1B	please replace (7) pieces of water damage ceiling tiles in the hallway near the plant manage office.	12/12/13	1st Floor	hallway by SBE office	Carpentry
Trezevant CTC (2727) 1B	please replace (8) pieces of water damage ceiling tiles in the hallway near room#128.	12/12/13	1st Floor	hallway near rm.128	Carpentry
Trezevant CTC (2727) 1B	please replace (3) pieces of water damage ceiling tiles in the hallway near room#126.	12/12/13	1st Floor	hallway near room 126	Carpentry
Trezevant CTC (2727) 1B	please replace (3) pieces of water damage ceiling tiles in the hallway near the girls restroom.	12/12/13	1st Floor	hallway near girls R.R.	Carpentry
Trezevant CTC (2727) 1B	please replace(4) pieces of water damage ceiling tiles in the hallway near room#119.	12/12/13	1st Floor	hallway near room119	Carpentry
Trezevant CTC (2727) 1B	please replace (4) pieces of water damage ceiling tiles in the hallway near room#113.	12/12/13	1st Floor	hallway near rm#113	Carpentry

Trezevant CTC (2727) 1B	please replace (3) pieces of water damage ceiling tiles in the hallway near the teacher lounge.	12/12/13	1st Floor	halls near tech.lounge	Carpentry
Trezevant CTC (2727) 1B	please repair the broken door closer in the hallway by the girls restroom the door closer hanging up.(urgent)	1/15/14	Hallway/Corridor	hallway by girls R.Room	Carpentry
Trezevant CTC (2727) 1B	DOOR FRAME IS JAMMED IN RM-114, CANT OPEN PLANT MGR- GOLDEN/416.3800	1/28/14			Carpentry
Trezevant CTC (2727) 1B	please repair the door to the storage room next to the entrance to diesel mechanic room#118.the door hang at the top of the door and the door hard to close.(see plant manage if you can not find it)	2/6/14	1st Floor	entrance to shop118	Carpentry
Trezevant CTC (2727) 1B	need a new lock on the closet door in the shop #114.	2/10/14	2nd Floor	closet door	Carpentry
Trezevant CTC (2727) 1B	please repair hanging door in the shop #118.	2/10/14	1st Floor	shop#118	Carpentry
Trezevant CTC (2727) 1B	please install locks on four wooden cabinet in cosmetology room#121.	8/28/13	2nd Floor	comsetology rm#121	Carpentry
Trezevant CTC (2727) 1B	Put new equipment on wall,for classroom instructions.	9/9/13	Classroom	Medical Lab #117	Carpentry
Trezevant CTC (2727) 1B	please install a slide latch on boys and girls restroom doors so I can lock the door with a pad lock.also deliver (2) pad lock.	8/26/13	1st Floor	boys and girl restroom	Carpentry
Trezevant CTC (2727) 1B	please repair chair	9/18/13	1st Floor	cosmetology#121	Carpentry

Trezevant CTC (2727) 1B	please make a 4ft.x4ft.bulletin board and install the bulletin board on the west wall in the hallway near room#105.	12/3/13	1st Floor	hallway wall by rm 105	Carpentry
Trezevant CTC (2727) 1B	UNIT NOT COMING ON IN MAIN OFFICE PLANT MGR- GOLDEN/416.3800	4/22/14			Electrical
Trezevant CTC (2727) 1B	UNIT NOT COMING ON IN MAIN OFFICE PLANT MGR- GOLDEN/416.0189	5/5/14			Electrical
Trezevant CTC (2727) 1B	Trezevant- CTC- WO379045 -please repair school bells and intercom system can not hear the bell on the south east hallway ID# 249-039 (urgent) (SCHOOL BELLS ONLY) (OCC Network Call# 3800)	8/28/13	1st Floor	hallway by rm.121	Electrical
Trezevant CTC (2727) 1B	Change ballast in hall. Light flickering.	9/3/13	1st Floor	In front of room #123	Electrical
Trezevant CTC (2727) 1B	RM 114 AUTO BODY-HEATING UNIT FOR PAINT BOTTH-HAS NO POWER- WILL NEED FOR CLASS- PLANT MGR GOLDEN 416-3800 KLR	5/16/14			Electrical
Trezevant CTC (2727) 1B	ELECTRICAL PANEL AUTOMOTIVE LAB-ON THE WALL FOR AIR COMPRESSOR HAS KICKED OFF AND CANNOT BE RESET-CHECK THIS PANEL-REQUESTED BY B SUPERVISOR	5/21/14			Electrical
Trezevant CTC (2727) 1B	please replace (2) missing receptacle plate on the receptacle in the dining room#127	5/29/14	1st Floor	dining room#127	Electrical
Trezevant CTC (2727) 1B	please replace the blown ballast (1) set of light not working in room #121.	5/29/14	1st Floor	cosmetology#121	Electrical
Trezevant CTC (2727) 1B	please replace GFCI receptacles in the kitchen	6/5/14		kitchen	Electrical

Trezevant CTC (2727) 1B	please replace GFCI receptacles and cove out side.	6/5/14		north side	Electrical
Trezevant CTC (2727) 1B	please replaced ballast in the kitchen.	6/5/14		kitchen	Electrical
Trezevant CTC (2727) 1B	please replace bad ballast in the break room.	6/5/14	1st Floor	breakroom	Electrical
Trezevant CTC (2727) 1B	please replace bad ballast in the storage room in room#111	6/5/14	1st Floor	room#111	Electrical
Trezevant CTC (2727) 1B	UNIT NOT COMING ON IN RM-121,123,125 PLANT MGR- GOLDEN/416.3800	6/11/14			Electrical
Trezevant CTC (2727) 1B	please repair three lights not working in room#111	6/16/14	1st Floor	room 111	Electrical
Trezevant CTC (2727) 1B	please replace missing receptacle in room#121.	6/16/14	1st Floor	room#121	Electrical
Trezevant CTC (2727) 1B	please replace the blown ballast one set of light not working in the main office	6/26/14	1st Floor	main office	Electrical
Trezevant CTC (2727) 1B	please repair security lights (3) poles security lights not working on the north parking lot.	4/3/14	Grounds	north parking lot	Electrical
Trezevant CTC (2727) 1B	Install 3 new elec. hanging heaters in Auto-Shop.	4/9/14			Electrical

Trezevant CTC (2727) 1B	please replace the blown ballast one set of light not working in the break room.	11/26/13	2nd Floor	break room	Electrical
Trezevant CTC (2727) 1B	please repair the compressor. the compressor have no power.	11/1/13	1st Floor	auto mech.#132	Electrical
Trezevant CTC (2727) 1B	PLEASE REPLACE THE BLOWN BALLAST.(4) SET OF LIGHTS NOT WORKING IN HEALTH SCIENCE ROOM#106.	11/4/13	1st Floor	health science#106	Electrical
Trezevant CTC (2727) 1B	please replace the blown ballast one set of light not working in the hallway near cosmetology room#123.	11/4/13	1st Floor	hallway near rm#123.	Electrical
Trezevant CTC (2727) 1B	please replace the missing light cover on the light fixture in the entrance hallway to business technology room#107.	11/4/13	1st Floor	break rm.by room#107	Electrical
Trezevant CTC (2727) 1B	RECEPTACLES AUTO SHOP AREA-HAVE NO POWER-WILL NEED FOR COMPUTERS-PLANT MGR GOLDEN 416-3800 KLR	11/15/13			Electrical
Trezevant CTC (2727) 1B	please set the clocks to day light saving time near room#126 and 104.	2/11/14	1st Floor	hallway near 126,104	Electrical
Trezevant CTC (2727) 1B	please set the clocks for day light saving time.	2/24/14	1st Floor	main office	Electrical
Trezevant CTC (2727) 1B	HEAT RM 115 & 112-BOTH NOT COMING ON-PLANT MGR GOLDEN 416-3800 KLR	3/6/14			Electrical
Trezevant CTC (2727) 1B	please repair the bells will not work.(urgent)	3/6/14	1st Floor	main office	Electrical

Trezevant CTC (2727) 1B	Repair/replace breaker in mechanical room.	7/10/13	Mechanical Room	S.B.E. Office #131	Electrical
Trezevant CTC (2727) 1B	Repair light in storage room.	7/23/13	Administration Area	Storage closet	Electrical
Trezevant CTC (2727) 1B	Set new bell times for new school year's operations.	7/26/13	Administration Area	Main Office	Electrical
Trezevant CTC (2727) 1B	please repair or replace the burned out security light on the pole that on the north east sign.	8/27/13	Grounds	north east side	Electrical
Trezevant CTC (2727) 1B	NO LIGHTS IN MAIN OFFICE RR. PLANT MGR- GOLDEN/416.3760	8/6/13			Electrical
Trezevant CTC (2727) 1B	Paint booth lights are out.	8/8/13	Machine Shop	Collision Repair	Electrical
Trezevant CTC (2727) 1B	please repair the lights.the lights will not work in the paint booth room#110 (un-safty urgent)can not see how to paint.	8/12/13	1st Floor	auto body shop 110	Electrical
Trezevant CTC (2727) 1B	please repair the clock. the clock do not keep the right time.in the hallway by the teacher working room#126.	8/12/13	1st Floor	hallway by room#126	Electrical
Trezevant CTC (2727) 1B	please repair the clock. the clock do not keep the right time on the wall in the hallway by room#105	8/12/13	1st Floor	hallway by room#105	Electrical
Trezevant CTC (2727) 1B	please repair light fixture. can not replace blown out light in the principal office.	8/13/13	Administration Area	prinicipal office	Electrical

Trezevant CTC (2727) 1B	please replace (3) sets of blown out security lights on the west side of the main building.needs a bucket truck.	8/13/13	Administration Area	west side of building	Electrical
Trezevant CTC (2727) 1B	please repair light fixture.the lights will not work on the porch of the west front entrance.	8/13/13		west porch	Electrical
Trezevant CTC (2727) 1B	please replace the blown ballast no light working in the men restroom in the main office.(urgent)	8/16/13	Administration Area	men restroom	Electrical
Trezevant CTC (2727) 1B	please replace (2) sets of blown out security light on the east side of the main building.needs a bucket truck.	8/19/13	Grounds	east side of main bldg.	Electrical
Trezevant CTC (2727) 1B	please replace (2) blown out security lights in the west drive way entrance to the main building.needs a bucket truck.	8/19/13	Grounds	west drive way entrance	Electrical
Trezevant CTC (2727) 1B	please replace (8) sets of blown out lights in the auto mech.room#132.needs a lift.	8/19/13	Machine Shop	rm#132 auto mech.rm.	Electrical
Trezevant CTC (2727) 1B	please repair or replace (11) blown out lights in the welding shop#133.needs a lift.	8/21/13	1st Floor	welding shop#133	Electrical
Trezevant CTC (2727) 1B	Please repair or replace (9) sets of blown out lights in the HVAC classroom114.needs a lift.	8/21/13	1st Floor	HVAC#114	Electrical
Trezevant CTC (2727) 1B	please repair or replace (14) sets of blown out lights in collision repair shop#114	8/21/13	2nd Floor	collision repair shop	Electrical
Trezevant CTC (2727) 1B	PLEASE PROVIDE 3 CASE OF ITEM# 46807 T8 LAMPS please repair or replace (5) sets of blown out lights in collision classroom #114A needs a lift.	8/21/13	1st Floor	collision room#114a	Electrical

Trezevant CTC (2727) 1B	please replace the blown ballast one set of light not working in the closet inside room cep#103.	8/21/13	1st Floor	CEP Room#103	Electrical
Trezevant CTC (2727) 1B	please repair the security lights on the west parking lot and west drive way no lights are working we have night school very dark at night. also please repair the light on the marquee light not	9/11/13	Parking Lot	parking lot	Electrical
Trezevant CTC (2727) 1B	please repair security lights. three security lights on the west side of the building not working.very dark on parking lot at night .we have night school.(urgent)needs a bucket truck.	9/25/13	Grounds	west side of main bldg.	Electrical
Trezevant CTC (2727) 1B	please replace bad breaker in breaker box EP4.	10/11/13	1st Floor	plant manage office	Electrical
Trezevant CTC (2727) 1B	Disconnect electric for equipment in auto shop.	10/8/13			Electrical
Trezevant CTC (2727) 1B	please repair the exhaust fan. the exhaust fan will not pull the air out of the paint booth.in the collision repair shop#114	10/15/13	1st Floor	collision repair shop	Electrical
Trezevant CTC (2727) 1B	please remove all conduit cables in the welding room#133.	10/23/13	2nd Floor	welding room#133	Electrical
Trezevant CTC (2727) 1B	please replace the burned out u shape flourescent light in the room by the laundry in side kitchen	12/10/13	1st Floor	kitchen	Electrical
Trezevant CTC (2727) 1B	HEAT RMS 119 & 120-BOTH NOT COMING ON-PLANT MGR GOLDEN 416-3800 KLR	12/11/13			Electrical
Trezevant CTC (2727) 1B	please replace the blown ballast (4) sets of not working in room#132.auto mechanics.	12/17/13	1st Floor	auto mechanice 132	Electrical

Trezevant CTC (2727) 1B	Three (3) units in the Auto Mechanical Room are NOT COMING ON per Willie Golden, Plant Mgr. 416.0189	1/6/14				Electrical
Trezevant CTC (2727) 1B	HEAT FOR PAINTING BOOTH IN COLLISION RM 114-NOT HEATING-PLANT MGR GOLDEN 416-3800 KLR	1/15/14				Electrical
Trezevant CTC (2727) 1B	FIRE ALARM - SHOWING SMOKE DETECTIVE BEEPING -PM/GOLDEN 416-0189	1/29/14				Electrical
Trezevant CTC (2727) 1B	please repair heater the three lagging heaters will not work in the auto mechanice shop#132	1/31/14	1st Floor	auto mech.#132		Electrical
Trezevant CTC (2727) 1B	Need 2 boxes of bulbs (Rapid start #46807) & four-60 watt bulbs.	7/26/13	1st Floor	Classrooms		Electrical
Trezevant CTC (2727) 1B	please deliver (100) floucent lights these lights are for the welding shop and HVAC room and collision repair shop and collison classroom and auto mech. shop.	8/28/13	2nd Floor	plant manage office		Electrical
Trezevant CTC (2727) 1B	please deliver 50 flourescent lamps to replace the burned out lights in classrooms.	10/27/13	Administration Area	plant manage office		Electrical
Trezevant CTC (2727) 1B	please deliver (50) flourescent lamps to replaced the burned out lights the hallways and classrooms.	11/22/13	1st Floor	classrooms,hallways		Electrical
Trezevant CTC (2727) 1B	RTU # 6 --- purchase 2 compressors	4/22/14				Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	purchase comp. for main ofc	5/1/14				Heating/Ventilation /Air Conditioning

Trezevant CTC (2727) 1B	UNIT NOT COMING ON IN MAIN OFFICE PLANT MGR- GOLDEN/416.3800	4/21/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	install comp. in RTU main ofc	5/7/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	hall unit not cooling	6/12/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	clean coils on rtu's	6/18/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Filter-Trezevant VoTech - Refer to PM schedule details.	11/25/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	HEAT MAIN OFC & DINING RM-BOTH NOT HEATING- PLANT MGR GOLDEN 416- 3800 KLR	11/25/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	RTU NOT COOLING IN KITCHEN. PLANT MGR- GOLDEN/416.3800	10/28/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	kitchen has no heat per Willie Golden 416-0189	11/8/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	HEAT HEALTH SCIENCES RM-CONSTANTLY RUN, NOT CYCLING OFF-PLANT MGR GOLDEN 416-3800 KLR	2/21/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	RTU #8 not heating	2/26/14			Heating/Ventilation /Air Conditioning

Trezevant CTC (2727) 1B	check heat	3/6/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	per willie golden 416-0189 no heat in rooms 118 and 110	3/7/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Trezevant CTC AirCompressor #084 - Refer to PM schedule details.	3/10/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Trezevant CTC Air Compressor #085 - Refer to PM schedule details.	3/10/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Oil Lube & Belt-Trezevant VoTech - Refer to PM schedule details.	3/11/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	3-UNITS NOT HEATING IN RM-106,114,118 PLANT MGR-GOLDEN/416.3800	3/17/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Filter-Trezevant VoTech - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Trezevant CTC AirCompressor #084 - Refer to PM schedule details.	9/9/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Trezevant CTC Air Compressor #085 - Refer to PM schedule details.	9/9/13			Heating/Ventilation /Air Conditioning

Trezevant CTC (2727) 1B	Clean coils on RTU 6,dogwood trees.	7/2/13		Roof	Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Filter-Trezevant VoTech - Refer to PM schedule details.	7/22/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Check thermostat on a/c, it is running too long.	7/26/13	Administration Area	Main Office	Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Oil Filter Change - Trezevant CTC - Refer to PM schedule details.	8/6/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Monthly - Oil Lube & Belt- Trezevant VoTech - Refer to PM schedule details.	8/6/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	A/C MAIN OFC-NOT COOLING-PLANT MGR GOLDEN 416-3800 KLR	9/11/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	A/C MAIN OFC-NOT COOLING AGAIN-PLANT MGR GOLDEN 416-3361 KLR	9/12/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	RTU NOT COOLING IN KITCHEN. PLANT MGR- GOLDEN/416.3760	9/26/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	RTU NOT COOLING IN MAIN OFFICE. PLANT MGR- GOLDEN/416.3800	10/15/13			Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	3-RTU NOT HEATING IN RM- 125,123,121 PLANT MGR- GOLDEN/416.3800	1/29/14			Heating/Ventilation /Air Conditioning

Trezevant CTC (2727) 1B	Monthly - Oil Filter Change - Trezevant CTC - Refer to PM schedule details.	2/11/14				Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	Yearly - Air Cool Chillers- Trezevant CTC - Refer to PM schedule details.	4/19/14				Heating/Ventilation /Air Conditioning
Trezevant CTC (2727) 1B	The Principal Eleanor Thomas request the wall paper and border be remove from the wall in her office Brian Shipp.	9/7/13	Administration Area	principal office		Painting
Trezevant CTC (2727) 1B	please repair top border falling of the wall in the conference room.	9/9/13	Administration Area	conference room		Painting
Trezevant CTC (2727) 1B	Principal request the fade school sign on front of the building be painted attn.(Brain Shipp)	9/9/13	1st Floor	west front of building		Painting
Trezevant CTC (2727) 1B	A new door been install on the new gym please paint door.	3/28/14	1st Floor	new gym		Painting
Trezevant CTC (2727) 1B	We do not have welding any more the old welding shop have been change to logistic shop the shop needs to be painted.	5/6/14	1st Floor	welding room#133		Painting
Trezevant CTC (2727) 1B	please paint the walls in the restroom in the auto mech.shop#132 graffiti cut in walls.	3/20/14	1st Floor	auto mach.shop		Painting
Trezevant CTC (2727) 1B	Paint door brackets, beige.	9/9/13				Painting
Trezevant CTC (2727) 1B	Unstop sink in kitchen,it has standing water in it. (Health Issue)	9/3/13	Kitchen	Culinary Arts #129		Plumbing

Trezevant CTC (2727) 1B	SINK - IN THE BARBER STOPPED UP & BACKING UP THRU THE DRINKING FOUNTAIN --PM/GOLDEN 416-0189	5/6/14				Plumbing
Trezevant CTC (2727) 1B	please replace the broken spray holes on the first and second sinks in the cosmetology #123.	10/31/13	1st Floor	cosmetology#123		Plumbing
Trezevant CTC (2727) 1B	please install (5) missing strainer for the sinks in cosmetology#123.	9/11/13	1st Floor	cosmetology#123		Plumbing
Trezevant CTC (2727) 1B	please repair or replace the borken hair rinse holes on the sinks in the cosmetology#123	9/11/13	1st Floor	cosmetology#123		Plumbing
Trezevant CTC (2727) 1B	please repair the hole in the faucet line on the third sinks in the cosmetology#123.	9/11/13	1st Floor	cosmetology#123		Plumbing
Trezevant CTC (2727) 1B	please unstopped the shampoo sink.	9/18/13	1st Floor	cosmetology#121		Plumbing
Trezevant CTC (2727) 1B	please repair the second commode.the commode are short flushing in the boys restroom	10/7/13	Restroom (Boys)	boys restroom		Plumbing
Trezevant CTC (2727) 1B	please disconnect all air lines in the leisure craft #120.	10/23/13	1st Floor	leisure craft#120		Plumbing
Trezevant CTC (2727) 1B	AIR COMPRESSOR AUTO SHOP-NOT WORKING-WILL NEED FOR CLASS-PLANT MGR GOLDEN 416-3800 KLR	10/24/13				Plumbing
Trezevant CTC (2727) 1B	please replace broken commode seat in the ladies restroom in the main office.	12/16/13	1st Floor	ladies RR main lobby		Plumbing

Trezevant CTC (2727) 1B	please repair or replace the strip cold water faucet on the last sink on the north wall in the kitchen.	1/29/14	2nd Floor	kitchen	Plumbing
Trezevant CTC (2727) 1B	please repair roof the roof is leaking water near room123 in the hallway.	11/22/13	Administration Area	roof on top of rm#123	Roof
Trezevant CTC (2727) 1B	please repair the roof leaks in the hallway near cosmetology room#121.the ceiling tile where the leak is have a yellow round circle on the ceiling tile.	2/6/14	1st Floor	hallway near rm.121	Roof

Count of Craft	Craft								
Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Trezevant Sr (2725) 1B	12	139	125	116	29	116	4	8	549
Grand Total	12	139	125	116	29	116	4	8	549

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Trezevant Sr (2725) 1B	please refinished the floor in the new gym.	1/1/14	Gym	new gym	Asbestos
Trezevant Sr (2725) 1B	Replace (acm) floor tiles, water damage. Tripping hazard. Room 257.	8/27/13	Classroom		Asbestos
Trezevant Sr (2725) 1B	please replace (20) missing and broken floor tiles.someone may trip on the loose floor tiles in classroom#258.	9/24/13	3rd Floor	classroom#258.	Asbestos
Trezevant Sr (2725) 1B	PLEASE REFINISHED THE GYM FLOOR.	10/1/13	Gym	GYM FLOOR	Asbestos
Trezevant Sr (2725) 1B	please install new floor tiles over the entire floor in classroom#258.the floor tiles are broken and missing and silding over the floor the students can trip on the floor tiles and injury then self.	10/24/13	2nd Floor	classroom#258	Asbestos
Trezevant Sr (2725) 1B	please refinished the rubber basketball playing floor in the 2nd gym. the new gym behind the Jrotc building.	1/2/14	Gym	new gym	Asbestos
Trezevant Sr (2725) 1B	please replace (4) piece of missing floor tiles in the hallway by the south end of the library.	11/18/13	1st Floor	hallway floor by library	Asbestos
Trezevant Sr (2725) 1B	please replace (8) missing pieces of floor tiles in classroom#142.	12/12/13	1st Floor	classroom#142	Asbestos

Trezevant Sr (2725) 1B	Insulate pipes on New Chiller. Target date for this work is 5-22-2014.	5/15/14	Grounds		Asbestos
Trezevant Sr (2725) 1B	please replace a section of wore down and missing floor tiles on the first floor in the stairwell near girls restrooms#147.	3/19/14	1st Floor	floor by girls RR 147	Asbestos
Trezevant Sr (2725) 1B	please Peplace missing and cracking floor tiles in the hallway near room#126.	3/19/14		hallway near RM.126	Asbestos
Trezevant Sr (2725) 1B	please replace the missing floor tiles in the hallway near room#150 and around the corner from room#151.see plant manger.	3/19/14	1st Floor	hallway near rm.150	Asbestos
Trezevant Sr (2725) 1B	Replace floor tiles,they have water damage.(trip hazzard)	8/15/13	Classroom	#257	Carpentry
Trezevant Sr (2725) 1B	please repair the broken door to the girls locker room in the old gym can not lock the door.	8/15/13	Gym	old gym	Carpentry
Trezevant Sr (2725) 1B	Repair/replace door knob,will not stay on door.	9/4/13	Classroom	Math #142	Carpentry
Trezevant Sr (2725) 1B	please repair or replace the hanging plexiglass top right window in the old gym lobby.	9/5/13	Gym	old gym lobby	Carpentry
Trezevant Sr (2725) 1B	please install missing toilet tissue holden in boys restroom#171.	9/5/13	1st Floor	boys restroom#171	Carpentry

Trezevant Sr (2725) 1B	please install broken toilet tissue holden in the boys restroom#272.	9/5/13	2nd Floor	boys restroom#272	Carpentry
Trezevant Sr (2725) 1B	please install (4) missing toilet tissue holden in the girls restroom#256.	9/5/13	2nd Floor	girls restroom#256	Carpentry
Trezevant Sr (2725) 1B	Remove petition so floor machine can get to floor.	9/9/13	1st Floor	Hall	Carpentry
Trezevant Sr (2725) 1B	please repair or remove the flag from the flag pole the flag is hung and I can not remove the flag need a lift.(urgent)	9/11/13	Grounds	flag lot	Carpentry
Trezevant Sr (2725) 1B	please replace (13) pieces missing cove base on the west side of the new gym.	7/1/13	Gym	new gym	Carpentry
Trezevant Sr (2725) 1B	please replace(24) piece missing cove base on the south side of the new gym.	7/1/13	Gym	new gym	Carpentry
Trezevant Sr (2725) 1B	please replace(16) piece of cove base on the east side of the new gym.	7/1/13	Gym	new gym.	Carpentry
Trezevant Sr (2725) 1B	please repair the damage wall vent in the hall way and rifle range classroom in the jrotc building.	7/2/13	Annex	JROTC.Building	Carpentry
Trezevant Sr (2725) 1B	Repair/replace fence near street.	7/8/13	Grounds	Football Field	Carpentry

Trezevant Sr (2725) 1B	MAIN ENTRANCE DOOR PANIC BAR IS BROKEN AND THE BLDG CANNOT BE SECURED. SBE GRANDERSON 416-3936	7/12/13			Carpentry
Trezevant Sr (2725) 1B	please repair the door. the door are sticking at the botton of the door.the door are hard to open on the south side of the cafeteria.	7/23/13	Cafeteria	south door of cafeteria	Carpentry
Trezevant Sr (2725) 1B	please install a bracket on the class room wall for projector screen in the jroct building.the projector screen are at the school.	8/23/13	Annex	JROTC Building	Carpentry
Trezevant Sr (2725) 1B	please repair the library door. sometime the north west door will not close tight	9/23/13	1st Floor	library	Carpentry
Trezevant Sr (2725) 1B	please remove the flag the flag are hung at the top of the pole and I can not the flag down.on the west side of the main building.(urgent)	9/23/13	Grounds	flag pole	Carpentry
Trezevant Sr (2725) 1B	please repair the broken door handle on the boys locker room on the north side in the old gym.	9/25/13	Gym	north boys locker rm.	Carpentry
Trezevant Sr (2725) 1B	the flag are hung up and tange up at the top of the flag pole I can not get the flag down the wire rope needs to be replace please get the flag down (urgent)needs a bucket truck.	9/25/13	Grounds	west of main building	Carpentry
Trezevant Sr (2725) 1B	Please install a dry erase board in classroom#186 A	9/27/13	2nd Floor	classroom#186A	Carpentry
Trezevant Sr (2725) 1B	exterior gym door can't secure panic bar broken per willie golden 416-3361	9/30/13			Carpentry

Trezevant Sr (2725) 1B	Put door handle back on door.	10/3/13	Gym	Boys Locker Room	Carpentry
Trezevant Sr (2725) 1B	please remove the (2)bolts on the door to the boys locker room in the old gym.a new handle was replace and they left the bolt sticking out students can cut their hand on the bolts.	10/15/13	Gym	old gym locker room	Carpentry
Trezevant Sr (2725) 1B	Replace allen screws in sign cover,they are rusted out.Allen key will not fit hole.	10/16/13		Outside Activity Sign	Carpentry
Trezevant Sr (2725) 1B	Repair door it is sticking in open position.(Not Securing) Front door, left side.	10/16/13	1st Floor	Main Entrance Door	Carpentry
Trezevant Sr (2725) 1B	please removed the bulletin board and install a new dry erase board in the guildance office on the west wall.	6/16/14			Carpentry
Trezevant Sr (2725) 1B	the new principal request to install a small cable wires throw the locks on the students lockers by the cafeteria and from rooms 130 thru 153.do not want the student to used lockers in the hallway.or bolt the lock.	6/16/14	1st Floor	hallway student locker	Carpentry
Trezevant Sr (2725) 1B	Install metal studs and sheetrock.	6/23/14	1st Floor		Carpentry
Trezevant Sr (2725) 1B	Install metal studs and sheetrock.	6/23/14	2nd Floor		Carpentry
Trezevant Sr (2725) 1B	Apply sheet rock to new metal studs in hallway.	6/26/14	1st Floor		Carpentry

Trezevant Sr (2725) 1B	Apply sheet rock to new metal studs in hallway.	6/26/14	2nd Floor		Carpentry
Trezevant Sr (2725) 1B	please replace (2) cloudy plexiglass windows in the breezeway on the south side near the teachers lounge.	4/21/14	1st Floor	breezeway by teach lounge	Carpentry
Trezevant Sr (2725) 1B	please replace (2) cloudy plexiglass window on the hallway.	4/23/14	1st Floor	north hallway	Carpentry
Trezevant Sr (2725) 1B	please replace (2) cloudy plexiglass windows in the south hallway.	4/23/14	1st Floor	south hallway	Carpentry
Trezevant Sr (2725) 1B	please replace (2) damage plexiglass windows on the west side in the main lobby.	4/23/14	1st Floor	west main lobby	Carpentry
Trezevant Sr (2725) 1B	Install protective plywood/metal skirting to protect the new Chiller unit under carriage.	4/24/14	Grounds		Carpentry
Trezevant Sr (2725) 1B	Procure and install New 10' chain link fence fabric, posts, concrete and 2, 3' leaf gates at CL of New Chiller concrete slab.	4/24/14	Grounds		Carpentry
Trezevant Sr (2725) 1B	please replace (2) cloudy plexiglass on the door in the stairwell near room#181.	4/25/14	1st Floor	stairwell door by rm 181	Carpentry
Trezevant Sr (2725) 1B	please repair or replace the broken doors hinger on the cabinets in the kitchen.	3/26/14	1st Floor	kitchen	Carpentry

Trezevant Sr (2725) 1B	please install a plate over the holes in the wall in the boys and girls locker room in the new gym pipe buster in the wall (urgent) so GCA workers can cleaned the area.	3/26/14	1st Floor	new gym locker room	Carpentry
Trezevant Sr (2725) 1B	please repair the haggging cover on the radiator in the hallway near room#142.	3/26/14	1st Floor	hallway near rm 142	Carpentry
Trezevant Sr (2725) 1B	please repair the door.the door are haggging up next to the ID Badger door in the main lobby.	5/20/14	1st Floor	west main lobby door	Carpentry
Trezevant Sr (2725) 1B	Seal existing window next to New Chiller.	5/21/14	Mechanical Room		Carpentry
Trezevant Sr (2725) 1B	bulletin board fell off the wall please install the bulletin board back on the wall in classroom#252.	5/23/14	2nd Floor	classroom#252	Carpentry
Trezevant Sr (2725) 1B	Apply new cove base to new wall in hallway.	6/27/14	1st Floor		Carpentry
Trezevant Sr (2725) 1B	Apply new cove base to new wall in hallway.	6/27/14	2nd Floor		Carpentry
Trezevant Sr (2725) 1B	Install new hardware to new pair of doors in hallway.	6/27/14	1st Floor		Carpentry
Trezevant Sr (2725) 1B	Install new hardware to new pair of doors in hallway.	6/27/14	2nd Floor		Carpentry

Trezevant Sr (2725) 1B	please replace the (2) cloudy windows in the doors in the short hallway near room#114.	4/9/14	1st Floor	doors by room#114	Carpentry
Trezevant Sr (2725) 1B	Replace water damaged tiles on stage,they have buckled.	6/27/14	Auditorium	Stage Floor	Carpentry
Trezevant Sr (2725) 1B	The new principal request for the divided partition be dis-assemble and removed from classroom#231.	4/9/14	2nd Floor	classroom#231	Carpentry
Trezevant Sr (2725) 1B	The new principal request for the divided partition be dis-assemble and moved from classroom#235	4/9/14	2nd Floor	classroom#235.	Carpentry
Trezevant Sr (2725) 1B	The new principal request for the divided partition to be dis-assemble and moved from classroom#237.	4/9/14	2nd Floor	classroom#237	Carpentry
Trezevant Sr (2725) 1B	please repair or replace the damage wall in the (3)practice rooms in the band room.	6/26/14	1st Floor	band room	Carpentry
Trezevant Sr (2725) 1B	the new principal request to install a small cable wire throw the locks on the student lockers in the hallway by rooms 230 thru 258.do not want the student to used the lockers.	6/16/14	2nd Floor	room 230--258	Carpentry
Trezevant Sr (2725) 1B	please deliver (2) roll paper towels dispensers and install the dispensers in the boys locker rooms in the new gym.	8/1/13	Restroom (Boys)	boys loc.rm.new gym	Carpentry
Trezevant Sr (2725) 1B	please clean and finished the gym basket ball floor (urgent)	9/16/13	Gym	gym floor	Carpentry

Trezevant Sr (2725) 1B	please replace (8) cloud plexiglass windows in the old gym lobby	2/18/14	Gym	old gym lobby	Carpentry
Trezevant Sr (2725) 1B	please deliver and install (6) paper towels dispenser in girls restroom#256 and girls locker room in the old gym and boys lockers rooms in the old and new gym.	1/13/14	1st Floor	plant manage office	Carpentry
Trezevant Sr (2725) 1B	The new principal request for the divided partition be dis-assemble and remove from classroom#230.	4/9/14	2nd Floor	classroom#230	Carpentry
Trezevant Sr (2725) 1B	please install a 4x8 feet bulletin board on the hallway wall near boys restroom#171.	5/20/14	1st Floor	halls wall near boy RR 171	Carpentry
Trezevant Sr (2725) 1B	please install a 4x8 ft.bulletin board on the hallway wall near room#182 see plant manage.	5/20/14	1st Floor	hallway near room#181	Carpentry
Trezevant Sr (2725) 1B	please install a 4x8 ft.bulletin board on the hallway wall near room#151.see plant manager.	5/20/14	1st Floor	hallway near RM#150	Carpentry
Trezevant Sr (2725) 1B	please install a 4x8 bulletin board on the hallway wall near room#141.see plant manger.	5/20/14	1st Floor	hallway near room#141	Carpentry
Trezevant Sr (2725) 1B	WINDOW HAS CAME COMPLETELY OUT IN CAFE. PLANT MGR-GOLDEN/416.3760	10/31/13			Carpentry
Trezevant Sr (2725) 1B	DOOR FRAME ID HANGING, CANT OPEN DOOR IN RM-163. PLANT MGR-GOLDEN/416.3760	11/5/13			Carpentry

Trezevant Sr (2725) 1B	Repaair inside doorknob,it came off. Hard to exit room.	11/5/13	Mechanical Room	Vocational Building	Carpentry
Trezevant Sr (2725) 1B	please repair broke door to classroom#165.	11/6/13	1st Floor	classroom#165	Carpentry
Trezevant Sr (2725) 1B	please install the sign on the wall we have sign at the school please see (willie golden)	11/14/13	1st Floor	main hallway	Carpentry
Trezevant Sr (2725) 1B	please repair the back door so the door can open the latch stuck and the door can not open in the boys locker room by the coaches office in the old gym.	11/21/13	Gym	boys locker room	Carpentry
Trezevant Sr (2725) 1B	WINDOW BROKEN OUT IN RM 145-WON'T BE ABLE TO SECURE-REQUESTED BY T PALMERTREE KLR	1/2/14			Carpentry
Trezevant Sr (2725) 1B	per Mr. Golden 416-3361 room 145 the window was blown out (it has already been repaired)	1/2/14			Carpentry
Trezevant Sr (2725) 1B	the door to boys locker room in big gym won't open per Mr. Granderson 416-3760	10/18/13			Carpentry
Trezevant Sr (2725) 1B	please replace the broken missing door closer on the boys restroom#171.	10/22/13	1st Floor	boys restroom#171	Carpentry
Trezevant Sr (2725) 1B	BLEACHERS will not COMING OUT COMPLETE per Mr. Willie Golden, Plant Mgr. 416.3369	11/26/13			Carpentry

Trezevant Sr (2725) 1B	please replace the missing broken out plexiglass window in classroom#278.	12/3/13	2nd Floor	classroom#278	Carpentry
Trezevant Sr (2725) 1B	please replace (2) broken out plexiglass windows in boys restroom #254.	1/2/14	2nd Floor	boys restroom #254	Carpentry
Trezevant Sr (2725) 1B	please replace (2) broken out plexiglass windows in the boys restroom#254.	1/3/14	2nd Floor	boys restroom#254	Carpentry
Trezevant Sr (2725) 1B	please replace the broken out plexiglass window in classroom#273.	1/3/14	2nd Floor	classroom#273	Carpentry
Trezevant Sr (2725) 1B	WINDOW GYM LOBBY AREA- HAS BEEN PUSHED OUT OF FRAME-WON'T BE ABLE TO SECURE-PLANT MGR GOLDEN 416-3361 KLR	12/19/13			Carpentry
Trezevant Sr (2725) 1B	in the gym lobby a window has been kicked out per Mr. Branderson 416-3760 or cell 562-5611	12/23/13			Carpentry
Trezevant Sr (2725) 1B	please replace the large broke out window in classroom#142.(urgent)	2/3/14	1st Floor	classroom#142	Carpentry
Trezevant Sr (2725) 1B	please replace screws in the door lock in classrooms#258.	2/3/14	2nd Floor	classroom#258	Carpentry
Trezevant Sr (2725) 1B	Replace soap dish, screws are not removable.	2/6/14	Restroom (Girls)	#147	Carpentry

Trezevant Sr (2725) 1B	please remove the broken key out of the lock cylinder in the boys restroom#155	2/10/14	1st Floor	boys restroom#155	Carpentry
Trezevant Sr (2725) 1B	please repair broken window in room#142	2/13/14	1st Floor	classroom#142	Carpentry
Trezevant Sr (2725) 1B	please replace crack pleiglass window in classroom#143	2/13/14	1st Floor	classroom#143	Carpentry
Trezevant Sr (2725) 1B	please replace broken window in classroom#146	2/13/14	1st Floor	classroom#146	Carpentry
Trezevant Sr (2725) 1B	please replace broken door glass in the door in the breezeway around the corner from room#150.	2/13/14	1st Floor	breezeway near rm 150	Carpentry
Trezevant Sr (2725) 1B	please replace cove base in the hallway near room#143.	2/13/14	2nd Floor	hallway near rm 243	Carpentry
Trezevant Sr (2725) 1B	Replace broken glass on door.	2/17/14	Hallway/Corridor	Vocational Area (Door)	Carpentry
Trezevant Sr (2725) 1B	Replace broken glass on door.	2/17/14	1st Floor	Band Room	Carpentry
Trezevant Sr (2725) 1B	please replace the broken out window glass and seal one plexiglass window in classroom#142	1/16/14	1st Floor	classroom#142	Carpentry

Trezevant Sr (2725) 1B	please repair or replace the (15) broken latch on the windows in the boys and girls locker room in the new gym. please do not bolt the window.	1/16/14	2nd Floor	new gym	Carpentry
Trezevant Sr (2725) 1B	please replace the broken lock on the coaches office door in the old gym.on the south west end.	1/31/14	1st Floor	old gym in side gym	Carpentry
Trezevant Sr (2725) 1B	please replace(3) cloud plexiglass windows in the breezeway near room#138 and the voe building on the north side.	2/18/14	1st Floor	breezeway near rm 138	Carpentry
Trezevant Sr (2725) 1B	please repair the second entrance door in the girls restroom#179.the door will not closed tight.	2/18/14	2nd Floor	girls restroom#179	Carpentry
Trezevant Sr (2725) 1B	please cut and install three piece of missing ceiling tile in the stairwell near room#245.	2/18/14	2nd Floor	stairwell near rm 245	Carpentry
Trezevant Sr (2725) 1B	please cut and replace missing ceiling tile in the hallway near room#172 and the voe building.	2/18/14	1st Floor	hallway near RR#171	Carpentry
Trezevant Sr (2725) 1B	please replace 10 piece of damage ceiling tiles on the north side in the cafeteria.	2/18/14	1st Floor	cafeteria	Carpentry
Trezevant Sr (2725) 1B	please replace (12) pieces of damage ceiling tiles on the south side in the cafeteria.	2/18/14	1st Floor	cafeteria	Carpentry
Trezevant Sr (2725) 1B	please replace (8) piece of damage ceiling tiles on the west side in the cafeteria.	2/18/14	1st Floor	cafeteria	Carpentry

Trezevant Sr (2725) 1B	please repair or replace the broke door lock. the door will not lock in classroom#250 (urgent)	2/20/14	2nd Floor	classroom#250	Carpentry
Trezevant Sr (2725) 1B	please replace the missing plexiglass window.the wind blow the plexiglass window out in classroom#288.(very urgent please replace the plexiglass window today)	2/21/14	2nd Floor	classroom#288	Carpentry
Trezevant Sr (2725) 1B	please repair door lock door wont unlock from the inside.	2/21/14	1st Floor	boys restroom#155	Carpentry
Trezevant Sr (2725) 1B	please replace missing cove base in hallway near classroom#288.	2/25/14	2nd Floor	hallway near rm.#288	Carpentry
Trezevant Sr (2725) 1B	please replace the broken lock on the door in classroom#244.	2/26/14	2nd Floor	classroom#244	Carpentry
Trezevant Sr (2725) 1B	please repair or replace the damage plate on back of the door inside boys restroom#254.	2/26/14	2nd Floor	boys restroom#254	Carpentry
Trezevant Sr (2725) 1B	please repair the damage door and door frame on the closet door inside computer room#164.someone tried to break in to the closet (urgent)	2/28/14	1st Floor	computer room#164	Carpentry
Trezevant Sr (2725) 1B	Provide harden steel chain/lock for new fence around new chiller.	4/30/14			Carpentry
Trezevant Sr (2725) 1B	Change broken window.(It is glass)	5/2/14	2nd Floor	North Hall	Carpentry

Trezevant Sr (2725) 1B	please replace all the damage ceiling tiles on the upper walls and ceiling in the band room.	5/6/14	1st Floor	band room	Carpentry
Trezevant Sr (2725) 1B	Replace broken window.(Glass)	5/9/14	Classroom	#253	Carpentry
Trezevant Sr (2725) 1B	BROKEN WINDOW IN RM-253 PLANT MGR-DONALD/416.3760	5/9/14			Carpentry
Trezevant Sr (2725) 1B	FRONT ENTRY DOOR, CANT SECURE PLANT MGR- GRANDERSON/5255611	5/13/14			Carpentry
Trezevant Sr (2725) 1B	please scrap the partition to the wall in classroom#231.	5/14/14	2nd Floor	classroom#231	Carpentry
Trezevant Sr (2725) 1B	please scrap the partitons to the wall in classroom#230.	5/14/14	2nd Floor	classroom#230	Carpentry
Trezevant Sr (2725) 1B	please scrap the partition to the wall in classroom #235.	5/14/14	2nd Floor	classroom#235	Carpentry
Trezevant Sr (2725) 1B	please scrap the partition to the wall in classroom#237.	5/14/14	2nd Floor	classroom#237	Carpentry
Trezevant Sr (2725) 1B	Fabricate and install expand metal on the New Chiller. Paint color black. Install after Chiller pipes has been insulated.	5/15/14	Grounds		Carpentry

Trezevant Sr (2725) 1B	please repair the windows (2) windows will not closed in classroom#278.	5/20/14	1st Floor	classroom#278	Carpentry
Trezevant Sr (2725) 1B	please replace (2) cloudy plexiglass windows in the breezeway on the north hallway.	3/19/14	1st Floor	north hallway breezeway	Carpentry
Trezevant Sr (2725) 1B	please replace (2) cloudy plexiglass windows in the breezeway on the south hallway	3/19/14		south hallway	Carpentry
Trezevant Sr (2725) 1B	please cut and replace the missing ceiling tiles in the Jrotc Building.see plant manger ceiling are at the school.	3/19/14	1st Floor	JROCT Building	Carpentry
Trezevant Sr (2725) 1B	please repair the door lock on the classroom door#181.	3/20/14	1st Floor	classroom#181	Carpentry
Trezevant Sr (2725) 1B	please repair or replace the damage door lock on the door to the stroage room#125G in the lobby in the old gym.	3/20/14	1st Floor	old gym lobby rm#125G	Carpentry
Trezevant Sr (2725) 1B	please repair or replace the damage door lock to the A.V Division room.	3/20/14	1st Floor	AV division room	Carpentry
Trezevant Sr (2725) 1B	please install a dry erase board on the wall in classroom# see plant manager.	3/6/14	1st Floor	classroom#141	Carpentry
Trezevant Sr (2725) 1B	please repair the broken door.the door will not close tight in the hallway in the jrotc building	3/7/14	1st Floor	JROCT Building	Carpentry

Trezevant Sr (2725) 1B	please replace the large crack window glass in classroom#252.	4/2/14	2nd Floor	classroom#252	Carpentry
Trezevant Sr (2725) 1B	please replace the crack door glass on the door to classroom#253.	4/3/14	2nd Floor	classroom#253	Carpentry
Trezevant Sr (2725) 1B	please replace the missing cove base on the east wall in classroom#231.	4/9/14	2nd Floor	classroom#231	Carpentry
Trezevant Sr (2725) 1B	please replace the damage ceiling tile in the hallway near boys restroom#171.	4/9/14	1st Floor	hallway by boy rm 171	Carpentry
Trezevant Sr (2725) 1B	please replace the damage ceiling tile in the corridor near classroom#230.	4/9/14	2nd Floor	Corridor near room#230	Carpentry
Trezevant Sr (2725) 1B	please replace the damage ceiling tile in the hallway near classroom#181.	4/9/14	1st Floor	hallway near room#181.	Carpentry
Trezevant Sr (2725) 1B	NEED NEW DOORS & FRAMES- REQUESTED BY BRIAN SHIPP KLR	6/10/14			Carpentry
Trezevant Sr (2725) 1B	Fabricate and install 4 gate locations (pair 25' + or -) at entrance across front of School.	6/10/14	Grounds		Carpentry
Trezevant Sr (2725) 1B	please repair the lights on the west front porch the lights will not work.the breaker need to be replace the breaker are in the closet in side the main.(very dark at night (urgent)	8/6/13	Administration Area	west front porch	Electrical

Trezevant Sr (2725) 1B	please repair the light.the light not working on the porch on the south side of the old gym.	8/8/13	Gym	porch on the gym	Electrical
Trezevant Sr (2725) 1B	please repair the security light.the security blown out light need	8/8/13	Auditorium	west side of auditorium	Electrical
Trezevant Sr (2725) 1B	please replace the blown out security light on the north east end of the auditorium.very dark at night.needs a bucket truck (urgent)	8/9/13	Auditorium	east of the auditorium	Electrical
Trezevant Sr (2725) 1B	please replace the blown out security light on top of room 235.very dark at night worker need lights to empty trash. needs a bucket truck.	8/9/13	Classroom	top of room 235	Electrical
Trezevant Sr (2725) 1B	please repair porch light.the light want work on the south porch of the old gym.	8/9/13	Gym	old gym porch	Electrical
Trezevant Sr (2725) 1B	please repair the exhaust fan the second exhaust fan will not work in the old gym.	8/19/13	Gym	old gym	Electrical
Trezevant Sr (2725) 1B	please replace the burned out spot light in the rifle range in the Jroct building.(urgent)	8/28/13	Annex	JROTC Building	Electrical
Trezevant Sr (2725) 1B	please repair the water fountain. the water fountain will not work in the old gym lobby.	9/9/13	Gym	old gym lobby	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast. (2) set of light not working in classroom#181.	9/16/13	1st Floor	classroom#181	Electrical

Trezevant Sr (2725) 1B	please replace the broken receptacle on the west wall in the new gym	7/1/13	Gym	new gym	Electrical
Trezevant Sr (2725) 1B	please replace the broken receptacle on the west wall in the out side gym.	7/2/13	Annex	out side gym	Electrical
Trezevant Sr (2725) 1B	please repair the second exhaust fan.the exhaust fan will not run.	7/24/13	Gym	old gym	Electrical
Trezevant Sr (2725) 1B	please deliver (50) fluorsecent light bulbs #46807 and twenty 60 watts light bulbs#46820 and twenty 300 watts light bulbs for the auditorium.	7/25/13	Administration Area	plant manage office	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast the only set of light not working in the custodial closet in the new gym (urgent)	7/25/13	Gym	new gym	Electrical
Trezevant Sr (2725) 1B	LIGHTS NOT COMING ON IN THE MIDDLE HALL-VERY DARK IN AREA-PLANT MGR GOLDEN 416-3361 KLR	8/23/13			Electrical
Trezevant Sr (2725) 1B	please repair the light fixture.the only lights will not working in the custodial closet in the new gym.very dark (urgent)	8/23/13	Gym	new gym	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (4) set of lights not working in the band room.	9/16/13	2nd Floor	band room	Electrical
Trezevant Sr (2725) 1B	please repair the vent hood. the vent hood do not work in the kitchen.	9/17/13	1st Floor	kitchen	Electrical

Trezevant Sr (2725) 1B	Three (3) Smoke Detectors are NOT WORKING located on C-hall on South End. And Fire Alarm System cannot be re-set per Mr. Golden, Plant Mgr. 416.3361	9/24/13			Electrical
Trezevant Sr (2725) 1B	PLEASE REPLACE THE MISSING LIGHT FIXTURE FRAME IN THE VOE. BUILDING BY ASST.PRINCIPAL OFFICE#162.	10/1/13	1st Floor	VOE.BUILDING	Electrical
Trezevant Sr (2725) 1B	PLEASE REPLACE THE MISSING LIGHT FIXTURE FRAME IN THE CAFETERIA.	10/1/13	Cafeteria	CAFETERIA	Electrical
Trezevant Sr (2725) 1B	please repair the blown ballast one set of light flicking and not working in the hallway by room#117.	10/14/13	Hallway/Corridor	hallway by room#117.	Electrical
Trezevant Sr (2725) 1B	please repair the exhaust fan in the paint booth. the exhaust fan not working will not pull the air out of the paint booth in the collision repair shop#114	10/15/13	1st Floor	collision repair shop	Electrical
Trezevant Sr (2725) 1B	please replace or repair the bad light switch. one row of lights not working in classroom#278.	10/23/13	2nd Floor	classroom#278	Electrical
Trezevant Sr (2725) 1B	please repair burned out security light. the security light will not work in the north court yard over room #135 needs a bucket truck.	10/24/13	Grounds	light over room#135	Electrical
Trezevant Sr (2725) 1B	please repair the security light.the security light will not work on the east side of the voe building.need a bucket truck.	10/25/13	Grounds	west of voc.bldg	Electrical
Trezevant Sr (2725) 1B	UNIT IS MAKING NOISE IN MAIN OFFICE plant mgr-GOLDEN/416.3760	6/19/14			Electrical

Trezevant Sr (2725) 1B	Relocate hold open device on wall to floor. This will be very close to new wall/doors being installed. Support Phillip.	6/20/14	2nd Floor		Electrical
Trezevant Sr (2725) 1B	please replace (3) burned out lights in the ceiling over the basket ball floor in the old gym.	4/11/14	Gym	old gym	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (3) sets of lights not working in classroom#231.	4/11/14	2nd Floor	classroom#231	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (3) set of lights not working in classroom#230.	4/11/14	2nd Floor	classroom#231	Electrical
Trezevant Sr (2725) 1B	Install new 200 amp Nema 3R switch, 600 volt. See attached Drawing of 4/14/14 from Kevin.	4/14/14	1st Floor		Electrical
Trezevant Sr (2725) 1B	Replace ballast bad.	4/21/14	Basketball Court		Electrical
Trezevant Sr (2725) 1B	UNIT IS MAKING NOISE IN MAIN OFFICE PLANT MGR-GOLDEN/416.3800	4/22/14			Electrical
Trezevant Sr (2725) 1B	Repair HVAC unit in room 164. Single phasing.	4/25/14	1st Floor		Electrical
Trezevant Sr (2725) 1B	A/C CAFE DINING AREA, SERVING LINE AREA, & RM 110. ALL NOT COMING ON-PLANT MGR GOLDEN 416-3361 KLR	4/29/14			Electrical

Trezevant Sr (2725) 1B	A/C RM 237 & 238-BOTH ALL NOT COMING ON-PLANT MGR GOLDEN 416-3361 KLR	4/29/14			Electrical
Trezevant Sr (2725) 1B	please replace blown ballast (2) set of lights not working in the kitchen.	3/25/14	1st Floor	kitchen	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast.(4) set of lights not working in classroom#183.	3/26/14	1st Floor	classroom#183	Electrical
Trezevant Sr (2725) 1B	please install a battery clock the clock are broken on the hallway near teacher work room#126.	3/27/14	1st Floor	hallway near rm#126	Electrical
Trezevant Sr (2725) 1B	Disconnect existing chiller in Mech room 176.	3/28/14	1st Floor		Electrical
Trezevant Sr (2725) 1B	Repair light in parking lot for entrance.(Very Dark Unsafe)	5/20/14	Parking Lot	Teacher's Entrance	Electrical
Trezevant Sr (2725) 1B	RECEPTACLE HAS NO POWER IN RM-180 MECH RM(FOR ALARM SYS) PLANT MGR-GOLDEN/416.3760	5/22/14			Electrical
Trezevant Sr (2725) 1B	assist hvac --- lift comp. on roof	5/30/14			Electrical
Trezevant Sr (2725) 1B	FCU MAIN BLDG HALL BY RM 111, FCU SHOP RM 114 WEST END, A/C IN RM 118, A/C IN RM 119 & AHU-3 AUD NE MECH RM. ALL NOT COMING ON-SBE GOLDEN 416-3361 KLR	8/1/13			Electrical

Trezevant Sr (2725) 1B	please repair or replace the receptacle.the receptacle are making a buzzing sound in room#289.	9/24/13	2nd Floor	room#289	Electrical
Trezevant Sr (2725) 1B	please replace the broken light switch one row of light can not be turn off in classroom#278.	9/24/13	2nd Floor	classroom#278	Electrical
Trezevant Sr (2725) 1B	Light switch is not working,it is locked in on position and will not go out.	8/24/13	2nd Floor	Northwest upstairs hall	Electrical
Trezevant Sr (2725) 1B	please deliver (75) flourescent lamps to replace the burned out lights in classrooms.hallways,offices and cafeteria.	11/22/13	1st Floor	classrooms.hallways.	Electrical
Trezevant Sr (2725) 1B	please repair the (2) broken portable fans in the boys locker room in the old gym.	8/19/13	Gym	boys locker rm.old gym	Electrical
Trezevant Sr (2725) 1B	I needs ten 60 watts light bulbs for restrooms and closets.at trezevant high.	2/28/14	1st Floor	plant mamage office	Electrical
Trezevant Sr (2725) 1B	please deliver ten 60 watts light bulbs to replaced the buned out lights in restrooms and closet at trezevant high.	2/7/14	2nd Floor	plant manage office	Electrical
Trezevant Sr (2725) 1B	please deliver (20) 60 watt bulbs and (20) 25 watt bulbs to replaced the burned out bulbs in the boys and girls restrooms and the closets.	1/13/14	1st Floor	plant manager office	Electrical
Trezevant Sr (2725) 1B	please deliver 50 flourescent lamps for the blown out light in classrooms and hallways.	10/22/13	Administration Area	plant manager office	Electrical

Trezevant Sr (2725) 1B	FIRE ALARM SYSTEM SHOWING TROUBLE-PLANT MGR GOLDEN 416-3361 KLR	10/28/13			Electrical
Trezevant Sr (2725) 1B	please replace the burned out security light on the north side of the voe.building.	10/29/13	Administration Area	voe.building	Electrical
Trezevant Sr (2725) 1B	please replace blown ballast in the emergency lights in the breezeway near room#150.(urgent)	10/30/13	1st Floor	south breezeway	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast.(4) set of lights not working in the library.	10/30/13	Library	library	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast.(4) set of lights not working in the library	11/6/13	1st Floor	library	Electrical
Trezevant Sr (2725) 1B	please replace the bad ballast (4) set of lights not working in classroom#252.	11/21/13	2nd Floor	classroom#252	Electrical
Trezevant Sr (2725) 1B	please replace three blown out light bulbs in the ceiling over the basket ball court very dark when playing a basket game in the old gym needs a lift.	11/26/13	Gym	old gym	Electrical
Trezevant Sr (2725) 1B	Light switch is not working,it is locked in on position and will not go out.	11/27/13	2nd Floor	Northwest upstairs hall	Electrical
Trezevant Sr (2725) 1B	please repair or replace the receptacle.the receptacle are making a buzzing sound in room#289.	11/27/13	2nd Floor	room#289	Electrical

Trezevant Sr (2725) 1B	please replace the broken light switch one row of light can not be turn off in classroom#278.	11/27/13	2nd Floor	classroom#278	Electrical
Trezevant Sr (2725) 1B	Repair exhaust fan in bathroom.	11/27/13	1st Floor	Bathroom by Plant Mgr.	Electrical
Trezevant Sr (2725) 1B	Repair exit sign,it is broken.	11/27/13	2nd Floor	Hall	Electrical
Trezevant Sr (2725) 1B	please replace (2) missing light fixtures cover in classroom#284	1/3/14	2nd Floor	classroom#284	Electrical
Trezevant Sr (2725) 1B	please replace (4) missing lights fixture cover in classroom#290.	1/3/14	2nd Floor	classroom#290	Electrical
Trezevant Sr (2725) 1B	please repair or replace lights.one row or lights not working.in classroom#173.	1/3/14	1st Floor	classroom#173	Electrical
Trezevant Sr (2725) 1B	per willie golden 416-3361 teachers lounge upstairs unit won't come on	1/8/14			Electrical
Trezevant Sr (2725) 1B	Repair heater,before pipes bust. (it is very cold!!!!)	1/10/14	Gym	Girls Locker Room	Electrical
Trezevant Sr (2725) 1B	no heat in principal's office not coming on per Mr. Golden 416-3361	12/9/13			Electrical

Trezevant Sr (2725) 1B	need lift	12/10/13			Electrical
Trezevant Sr (2725) 1B	please repair light fixture I can not replace the burned out light. in the band room.	12/11/13	1st Floor	band room#118	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast one set of light not working in the hallway near room#181.	12/11/13	Hallway/Corridor	hallway near rm.181	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast one set of lights not working in the hallway near room#282.	12/11/13	2nd Floor	hallway near rm#282	Electrical
Trezevant Sr (2725) 1B	please replace (24)burned out lights bulbs in the auditorium.	12/12/13	1st Floor	auditorium	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (4) sets of lights not working in classroom#152.	12/16/13	2nd Floor	classroom#252	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (4) set of lights not working in classroom#172.	12/18/13	1st Floor	classroom#172	Electrical
Trezevant Sr (2725) 1B	Replace broken light switch rm 278.	12/19/13	2nd Floor		Electrical
Trezevant Sr (2725) 1B	Lights will not go off (too much energy used) In main gym.	2/4/14	Gym		Electrical

Trezevant Sr (2725) 1B	please replace bad ballast (4) set of light not working in classroom#153.	2/10/14	1st Floor	classroom#153	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (2) set of lights not working in classroom#282.	2/10/14	2nd Floor	classroom#282	Electrical
Trezevant Sr (2725) 1B	please repair light fixture (2) set of lights not working on the west front porch.	1/14/14	1st Floor	west front porch	Electrical
Trezevant Sr (2725) 1B	please repair and replace peice for the magnetic on the door in the hallway near room#282.the door will not stay open.(urgent)	1/23/14	1st Floor	hallway near rm 282	Electrical
Trezevant Sr (2725) 1B	please repair light fixture one set of lights not working on the west front porch.	1/30/14	1st Floor	west front porch	Electrical
Trezevant Sr (2725) 1B	please repair the (4)extra basket ball goals in the old gym. the goal will not let up and down for PE class.	1/31/14	1st Floor	old gym	Electrical
Trezevant Sr (2725) 1B	please replace the three blown out lights on the stage in the auditorium. the lamps are at the school see the plant manage.	2/18/14	Auditorium	auditorium	Electrical
Trezevant Sr (2725) 1B	please replace 12 bulbs.	2/20/14	Auditorium		Electrical
Trezevant Sr (2725) 1B	please set the clock for day light saving time.	2/24/14	2nd Floor	attendance office	Electrical

Trezevant Sr (2725) 1B	please replace damage receptacle plate in the stair well nearroom#186.	2/25/14	1st Floor	stairwell near rm.#186	Electrical
Trezevant Sr (2725) 1B	please replace missing receptacle plate on the receptacle behind the hallway door near girls restroom#281.	2/25/14	2nd Floor	near girls restroom 281	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (2) set of lights not working in classroom#290.	2/26/14	2nd Floor	classroom#290	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (2) set of lights not working in classroom#288.	2/26/14	2nd Floor	classroom#288	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (2) set of lights not working in classroom#283	2/26/14	2nd Floor	classroom#283	Electrical
Trezevant Sr (2725) 1B	please replace the bad light switch or the blown ballast (1) set of light not working in the lobby of the old gym.	2/26/14	1st Floor	old gym lobby	Electrical
Trezevant Sr (2725) 1B	please repair the broken light switch receptacle in the girls restroom in the main lobby.	2/27/14	1st Floor	girls RR in main lobby	Electrical
Trezevant Sr (2725) 1B	please replace the missing cover plate on the receptacle on the west wall in the cafeteria.	5/5/14	1st Floor	cafeteria	Electrical
Trezevant Sr (2725) 1B	Install heat trace to new chiller pipes.	5/7/14	Mechanical Room		Electrical

Trezevant Sr (2725) 1B	UNIT NOT COMING ON IN RM-253 PLANT MGR-GOLDEN/416.3760	5/8/14			Electrical
Trezevant Sr (2725) 1B	UNIT NOT COMING ON IN RM-253 PLANT MGR-GOLDEN/416.3800	5/13/14			Electrical
Trezevant Sr (2725) 1B	wire in flow switch on chiller	5/13/14			Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast one set of light not working on the botton stairwell near room#142.	5/14/14	Stairway	stairwell by rm#142	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (4) set of lights not working in classroom#253.	5/14/14	2nd Floor	classroom#253	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (4) set of light not working in classroom#186b.	5/16/14	1st Floor	classroom#186b	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (2) set of lights not working in classroom#153	5/19/14	1st Floor	classroom#153	Electrical
Trezevant Sr (2725) 1B	per Willie Golden 416-3361 roof top unit for 164 not coming on at all and the band room	4/3/14			Electrical
Trezevant Sr (2725) 1B	Change ballast.	4/9/14	Stairway	By Rm. #247	Electrical

Trezevant Sr (2725) 1B	please replace broken receptacle in the breezeway near office#270.	4/9/14	Hallway/Corridor	breezeway near office 270	Electrical
Trezevant Sr (2725) 1B	please replace broken receptacle in the hallway by boys restroom#254.	4/9/14	2nd Floor	hallway by boys RR 254	Electrical
Trezevant Sr (2725) 1B	assist hvac on RTU --- wiring	6/4/14			Electrical
Trezevant Sr (2725) 1B	please replace the broken plate and receptacle on the wall out side of the coach office in the old gym.	4/9/14	1st Floor	old gym coach office	Electrical
Trezevant Sr (2725) 1B	please replace the broken receptacle plate on the receptacle in the hallway by classroom#282.	4/9/14	2nd Floor	hallway by room#281	Electrical
Trezevant Sr (2725) 1B	please replace the blown ballast (4) set of lights not working in the library.	4/9/14	1st Floor	Library	Electrical
Trezevant Sr (2725) 1B	please replace the battery in the exit light in the hallway near the teacher lounge I	4/9/14	1st Floor	hallway by teacher lounge	Electrical
Trezevant Sr (2725) 1B	please replace the battery in the exit lights in the hallway near the attendance office.	4/9/14	1st Floor	hallway by atten. office	Electrical
Trezevant Sr (2725) 1B	please repair the exit light in the hallway by the plant manager office.	4/9/14	1st Floor	hallway by SbE Office	Electrical

Trezevant Sr (2725) 1B	please replace the battery in the exilt light in the short hallway near room#114.	4/9/14	1st Floor	hallway by rm 114	Electrical
Trezevant Sr (2725) 1B	pleace replace (4) set of blown lights in the ceiling over the basket ball playing floor in the new gym.	4/9/14	Gym	new gym	Electrical
Trezevant Sr (2725) 1B	please replace the missing light switch plate in the back of the room on the south wall in classroom#231.	4/9/14	2nd Floor	classroom#231	Electrical
Trezevant Sr (2725) 1B	please replace the missing light switch plate in the book room near classroom#231.	4/9/14	2nd Floor	book room	Electrical
Trezevant Sr (2725) 1B	please repair the damage light fixture in classroom#230.one set of light not working.	4/9/14	2nd Floor	classroom#230	Electrical
Trezevant Sr (2725) 1B	Change out light switch,it has a shortage.	6/3/14	1st Floor	Bookroom by #131	Electrical
Trezevant Sr (2725) 1B	UNIT NOT COMING ON IN RM-282,288 PLANT MGR-- GRANDERSON/416.3760	6/9/14			Electrical
Trezevant Sr (2725) 1B	EVALUATE TRANE CHILLER. PREPARE QUOTE FOR REPAIR.	3/18/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Check chiller. Possible shorted compressor.	10/17/13			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	Chiller will not start.	8/2/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	FCU EAST WING 2ND FLR RM 289, FCU EAST WING 1ST FLR RM 182 NORTH, FCU EAST WING 1ST FLR RM 182, FCU EAST WING 2ND FLR RM 289, FCU EAST WING 2ND FLR RM 290, AHU-3 AUD NE MECH RM, & AHU-3 AUD NE MECH RM,	8/2/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	supply contractor 3 jugs R22	8/2/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	clean aud. units	8/8/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	3-FCU NOT COOLING IN RM-181(130) RM-192(129) RM-183(127). PLANT MGR-GOLDEN/416.3760	8/8/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	RTU VOC ANNEX NE SERVES RM 163-NOT COOLING-SBE GOLDEN 416-3361 KLR	8/13/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	AHU NOT COOLING IN ROTC RM (151), & RM-182 PLANT MGR-GOLDEN/416.3760	8/14/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	CHILLER 136-111 - NOT COMING ON - PM/GOLDEN 416-3361	8/30/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 258 leaking	8/30/13			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	install comp. in serving line unit	9/10/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	FCU NOT COOLING IN RM-284 PLANT MGR-GOLDEN/416.3760	9/10/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	AHU NOT COOLING IN AUDIT (HAVING A SPECIAL MEETING TODAY) PLANT MGR-GOLDEN/416.3760	9/12/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	A/C RM 123-NOT COOLING- PLANT MGR GOLDEN 416-3361 KLR	9/13/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	chiller down	7/8/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Monthly - Filter-Trezevant High - Refer to PM schedule details.	7/9/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	chiller down	7/10/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	serving line not cooling	7/11/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	chiller down	7/12/13			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	chiller down	7/15/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	chiller down	7/23/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	air handler unit main office making loud noise air handler unit JROTC bldg not cooling per Willie Golden 416-3361	7/23/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	CHILLER NOT COMING ON (111) PLANT MGR-GOLDEN/416.3760	8/19/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	FCU NOT COOLING IN RM- 290(121). PLANT MGR-GOLDEN/416.3760	8/20/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	CHILLER NOT COOLING- AFFECTS PART OF BLDG- PLANT MGR GOLDEN 416-3361 KLR	8/22/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	aud. not cooling	9/23/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	chiller not coming on per Willie Golden 416-3361	10/14/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	RTU RM 163 - BLOWING NOT COOLING - PM/GOLDEN 416- 3361	10/15/13			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	rm 110 ready for heat	10/23/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	c/o to heat	10/23/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	FCU NOT HEATING IN RM-141, & LIBRARY. PLANT MGR-GOLDEN/416.3800	10/25/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	A/C LIBRARY-NOT COOLING- PLANT MGR GRANDERSON 416-3361 KLR	6/18/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	A/C UNIT is NOT COOLING in ROOM 118 (Band Room), per Mr. Granderson, Plant Mgr. 416.3760	6/18/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Yearly - Air Cool Chillers- Trezevant High - Refer to PM schedule details.	4/22/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	main ofc making noise	4/22/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	UNIT NOT COOLING IN BAND RM, RM-163. PLANT MGR-GOLDEN/416.3800	4/24/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	install chiller	4/24/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	A/C AUDITORIUM-NOT COOLING-THEY WILL BE HAVING A PROGRAM THIS MORNING AT 8:30-PLANT MGR GOLDEN 416-3361 KLR	4/25/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	set chiller	4/28/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Rm 164 not cooling	4/30/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Cafe Rtu not cooling	4/30/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	install comp. for rm 164	5/30/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Monthly - Oil Lube & Belt- Trazevant High - Refer to PM schedule details.	8/2/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	A/C LIBRARY-NOT COOLING- PLANT MGR GOLDEN 416-3361 KLR	6/26/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Yearly - #1 Boiler 001-Trezevant Hi-Boiler Rm S - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	Yearly - #2 Boiler 002-Trezevant Hi-Boiler Rm N - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	shut down and drain system to repair condensate pumps	10/25/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Monthly - Filter-Trezevant High - Refer to PM schedule details.	11/5/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	please repair the broken control box on the a/c unit in classroom#273.	11/12/13	2nd Floor	classroom#273	Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rooms 276 and 174 are not heating blowing cold per willie golden 416-3361	11/12/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	HEAT RM 277-NOT HEATING-PLANT MGR GOLDEN 416-3361 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	6-FCU NOT HEATING IN RM-272,276,278,243,257,252 PLANT MGR-GOLDEN/416.3760	11/19/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	control valve leaking	11/21/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	pipeing leaking and flow switch leaking	11/25/13			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	Air Handler Unit is LEAKING WATER on the gym floors in the Old Gym per Willie Golden, Plant Mgr. 416.3369	11/26/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	check gym units for leaks	12/2/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	please set thermostat over heating in the auditorium	12/3/13	Auditorium	auditorium	Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	check steam trap on gym units	12/3/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	BOILER #2 is NOT COMING ON per Mr. Golden, Plant Mgr. 416.3361	1/3/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 273 not heating	1/29/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	HEAT RMS 273, 274, 275, 276, 277M & 278-ALL NOT HEATING-PLANT MGR GOLDEN 416-3361 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	HEAT RM 165-NOT HEATING-PLANT MGR GOLDEN 416-3361 KLR	1/7/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per Willie Golden 416-3361 room 185 is blowing cold air	1/8/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	rm 273 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 274 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 275 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 276 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 277 not heating	1/8/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per Willie Golden 416-3361 rooms 132 and 137 blowing cold air	1/9/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per willie golden 416-3361 rooms 130, 135 heat not coming on	1/9/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	domestic water pipe busted in girls gym	1/9/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	boiler down	1/10/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	HEAT GYM-LEAKING ON HARDWOOD FLR PER SBE- PLANT MGR GOLDEN 416-3361 KLR	12/9/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Unit in ROOM 185 is NOT HEATING per Willie Golden, Plant Mgr. 416.3361	12/9/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	main ofc not heating	12/10/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per willie golden 416-3361 the outside gym boys locker room has no heat - not coming on at all	12/11/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Gym --- make pans for both units	12/11/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	HEAT RMS 274, 277, & 282-ALL NOT HEATING-PLANT MGR GOLDEN 416-3361 KLR	12/11/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per Willie Golden 416-3361 room 277 is blowing cold	12/13/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	HEAT RM 257-NOT HEATING- PLANT MGR GOLDEN 416-3361 KLR	12/13/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	boiler out on flame failure	12/18/13			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	blow down boilers	12/20/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Unit in the ceiling is NOT HEATING in Gym per Mr. Granderson, Plant Mgr. 416.3760 or 901.562.5611.	12/23/13			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	change filters in library units	2/4/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	library not heating	2/6/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	UNITS NOT HEATING IN RM- 252.278 PLANT MGR-GOLDEN/416.3760	2/7/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per willie golden 416-3361 boys locker room in the outside gym is blowing cold air	2/7/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	RTU NOT COMING ON IN B/LOCKER RM GYM PLANT MGR-GOLDEN/416.3800	2/10/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per willie golden 416-3361 there is no heat in the boys locker room in the outside gym (again)	2/11/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	boiler down	1/17/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	RTU - IN ASST PRIN - COMING ON BUT NOT HEATING - PM/GOLDEN 416-3361	1/21/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	RTU #4 --- repair or replace disconnect	1/21/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per Mr. Golden 416-3361 rooms 172 and 174 are blowing cold air	1/23/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per Willie Golden 416-3361 in the new gym, boys locker room and rooms 273 & 185 are blowing cold air	1/28/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 185 not heating	1/29/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	RTU NOT HEATING IN RM-164 PLANT MGR-GOLDEN/416.3800	1/29/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	per willie golden 416-3361 there is a busted coil in the heating unit in the library	1/29/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	UNIT NOT HEATING IN AUDIT (TAKING A TEST TODAY) PLANT MGR-GOLDEN/416.3800	1/30/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	boiler down	2/26/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	HEAT AUDITORIUM-NOT HEATING-PLANT MGR GOLDEN 416-3361 KLR	2/27/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Monthly - Oil Lube & Belt- Trazevant High - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	A/C RM 183 & 186-BOTH NOT COOLING-PLANT MGR GRANDERSON 416-3361 KLR	5/12/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rotc froze up	5/13/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	rm 251 -- clean coil and change filter	5/14/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	check options for chiller repair or replacement	3/19/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	HEAT LIBRARY AREA-NOT HEATING-PLANT MGR GOLDEN 416-3361 KLR	3/7/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Monthly - Filter-Trezevant High - Refer to PM schedule details.	3/11/14			Heating/Ventilation /Air Conditioning

Trezevant Sr (2725) 1B	evacuate system for tear out	4/3/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	demo chiller	4/7/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Oldham Crane and Rigging to unload chiller	4/8/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	UNIT VENT - RMS 244, 250, 285, BLOWING NOT COOLING - PM/GRANDERSON 416-3760	6/4/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	UNIT NOT COOLING IN AUDIT PLANT MGR-GOLDEN/416.3800	6/11/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	Rm 235 --- burn smell -- motor running but very hot so plumber cut off unit.	6/11/14			Heating/Ventilation /Air Conditioning
Trezevant Sr (2725) 1B	please paint the colmun and the top part of the hallway wall on the second floor from room 238 thur room 231 paint peeling and graffiti on the wall in the hallway.	1/31/14	2nd Floor	2nd floor hallway	Painting
Trezevant Sr (2725) 1B	please paint the ceiling in girls restroom#287 the paint peeling and the paint falling on the floor.	3/21/14	2nd Floor	girls restroom#287	Painting
Trezevant Sr (2725) 1B	The new principal said please paint the hand rails the paint peeling in the stairwell near room#142.	3/31/14	1st Floor	stairwell near rm 142	Painting

Trezevant Sr (2725) 1B	The new principal said please paint the hand rails the paint peeling in stairwells near rooms#172 and 181.	3/31/14	1st Floor	stairwells by rms 172,181	Painting
Trezevant Sr (2725) 1B	The new principal said please paint the hand rails the paint peeling in the stairwells near rooms#146 and 159.	3/31/14	1st Floor	stairwells by rms 146,159	Painting
Trezevant Sr (2725) 1B	please paint the ceiling.the paint peeling and cracking in the ceiling in the girls restroom#287	4/10/14	2nd Floor	girls restroom#287	Painting
Trezevant Sr (2725) 1B	Need room painted purple. Trezevant Room 117	6/2/14	1st Floor	117	Painting
Trezevant Sr (2725) 1B	please paint over graffiti and gang sign on classroom doors 163.164.	12/5/13	1st Floor	classroom#164,165	Painting
Trezevant Sr (2725) 1B	please paint the side of the lab tables graffiti on the side of the lab tables (the painter are know at the school painting the walls and top of the lab tables)	4/15/14	1st Floor	classroom#175	Painting
Trezevant Sr (2725) 1B	please paint the north walls and the labs tables in classroom#175 some one have painting gang sign word (vicelord) in green paint on the north walls and lab tables.	3/31/14	Stairway	stairwell near rm 142	Painting
Trezevant Sr (2725) 1B	paint window guards	5/28/14			Painting
Trezevant Sr (2725) 1B	please paint (6) column that have graffiti and paint peeling on the column in the hallway by the library on the north and south end.	12/9/13	1st Floor	hallway by library	Painting

Trezevant Sr (2725) 1B	please paint (4) column with graffiti and paint peeling on the column in the hallway near rooms#141 and 138.	12/9/13	2nd Floor	hallway near rm.#141	Painting
Trezevant Sr (2725) 1B	please paint (4) column that have graffiti and paint peeling in the hallway near#173	12/9/13	1st Floor	hallway near rm173	Painting
Trezevant Sr (2725) 1B	please paint (3) column that have graffiti and the paint peeling on the column in the hall by room#181.	12/9/13	1st Floor	hallway by room#181.	Painting
Trezevant Sr (2725) 1B	please paint (4) column that have paint peeling and graffiti on the column in the hallway near room#150.	12/9/13	1st Floor	hallway near rm#150	Painting
Trezevant Sr (2725) 1B	please paint (2) column with graffiti and paint peeling in the hallway by room#158.	12/9/13	1st Floor	hallway by room 158.	Painting
Trezevant Sr (2725) 1B	please paint (2) column that have paint peeling and graffiti in the hallway by room#240.	12/9/13	2nd Floor	hallway by room#240	Painting
Trezevant Sr (2725) 1B	please paint (5) column with paint peeling and graffiti in the hallway by rooms#250 and 257.	12/9/13	2nd Floor	hallway by rm#250 257.	Painting
Trezevant Sr (2725) 1B	please paint (5) column paint peeling and graffiti on column in the hallway near room#282 and 273.	12/9/13	2nd Floor	hall near rm 282,273	Painting
Trezevant Sr (2725) 1B	please paint (5) column the paint peeling and graffiti on the column in the hallway near rooms#273 and 282.	12/9/13	2nd Floor	halls by room#273.281	Painting

Trezevant Sr (2725) 1B	please paint the commode wall and stall doors.the wall and door have graffiti cut into the paint in the boys restroom#254.	12/12/13	2nd Floor	boys restroom#254	Painting
Trezevant Sr (2725) 1B	please paint the top part of the first floor hallway wall and the column from room# 131 thur room #138 the paint peeling and graffiti on the hallway wall.	1/31/14	1st Floor	first floor	Painting
Trezevant Sr (2725) 1B	please paint the commode stall wall and middle door in the girls restroom#281.graffiti on wall and door.	2/18/14	2nd Floor	girls restroom 281	Painting
Trezevant Sr (2725) 1B	please paint the commode stall walls and doors the walls and doors have graffiti on them in the girls restroom#281	2/20/14	2nd Floor	girls restroom#281	Painting
Trezevant Sr (2725) 1B	please paint the commode walls and doors in the girls restroom#256 graffiti on walls and doors.	2/20/14	2nd Floor	girls restroom#256	Painting
Trezevant Sr (2725) 1B	please paint the wall in classroom#117 all the paint are peeling of the wall.	2/25/14	1st Floor	classroom#117	Painting
Trezevant Sr (2725) 1B	please paint the peeling wall in classroom.#282.	2/25/14	2nd Floor	classroom#283	Painting
Trezevant Sr (2725) 1B	Prep/Paint (school purple) posts (8) and gate arms (8). On site touch-up paint will be required when installation is complete. Target date is 6-19-2014. Support Danny Walker. Thank you Zone 1b	6/11/14	Grounds		Painting
Trezevant Sr (2725) 1B	Room 257 and Room 275 a/c units leaking per Willie Golden 416-3361	8/5/13			Plumbing

Trezevant Sr (2725) 1B	2-FCU ARE LEAKING WATER IN RM-275,258(107,096). PLANT MGR-GOLDEN/416.3760	8/6/13			Plumbing
Trezevant Sr (2725) 1B	STOVE NEEDS TO BE LIT. PLANT MGR-GOLDEN/416.3760	8/8/13			Plumbing
Trezevant Sr (2725) 1B	A/C WALL UNIT 2ND FLR MIDDLE S RM 258-LEAKING- SBE GOLDEN 416-3361 KLR	8/9/13			Plumbing
Trezevant Sr (2725) 1B	please repair the last commode will not flush in the girls restroom#147.	8/12/13	Restroom (Girls)	girls restroom#147	Plumbing
Trezevant Sr (2725) 1B	Change water valve,toilet has no pressure	8/15/13	1st Floor	Girls Bathroom#147	Plumbing
Trezevant Sr (2725) 1B	Per Willie Golden 416-3361 the floor drain is stopped up in the kitchen	8/28/13			Plumbing
Trezevant Sr (2725) 1B	FCU RM 258-LEAKING-PLANT MGR GOLDEN 416-3361 KLR	8/29/13			Plumbing
Trezevant Sr (2725) 1B	Room 240 a/c leaking per Willie Golden 416-3361	8/30/13			Plumbing
Trezevant Sr (2725) 1B	please repair or replace commode drain pipes in boys restroom#171.the pipes are leaking from ceiling (URGENT) bad odor.	8/30/13	1st Floor	boys restroom171	Plumbing

Trezevant Sr (2725) 1B	CIRCULATING PUMP-LEAKING-PLANT MGR GRANDERSON 416-3361 KLR	9/3/13			Plumbing
Trezevant Sr (2725) 1B	A/C RM 258-LEAKING-PLANT MGR GRANDERSON 416-3361 KLR	9/3/13			Plumbing
Trezevant Sr (2725) 1B	a/c leaking in room 150 per Donald Granderson 416-3760	9/4/13			Plumbing
Trezevant Sr (2725) 1B	Room 273 and JROTC Bldg a/c leaking per Willie Golden 416-3361	9/5/13			Plumbing
Trezevant Sr (2725) 1B	please repair the commode. the first commode is short flushing in the girls restroom#147.	9/5/13	Restroom (Girls)	girls restroom#147.	Plumbing
Trezevant Sr (2725) 1B	A/C UNIT RM 251-LEAKING-PLANT MGR GOLDEN 416-3362 KLR	9/10/13			Plumbing
Trezevant Sr (2725) 1B	AHU & FCU ARE LEAKING WATER IN RM-258,MAIN OFFICE PLANT MGR-GOLDEN/416.3760	9/10/13			Plumbing
Trezevant Sr (2725) 1B	please repair the broken water fountain in the new gym.	9/11/13	Gym	new gym	Plumbing
Trezevant Sr (2725) 1B	FCU IS LEAKING WATER IN RM-258 PLANT MGR-GOLDEN/416.3760	9/12/13			Plumbing

Trezevant Sr (2725) 1B	please repair the broken flush valve. the commode will not flush in the restroom in the sbe office.	7/1/13	Administration Area	SBE.OFFICE.	Plumbing
Trezevant Sr (2725) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/30/13			Plumbing
Trezevant Sr (2725) 1B	please repair the dripping faucet in the boys restroom in the teacher lounge.	7/17/13	1st Floor	men RR teacher loug.	Plumbing
Trezevant Sr (2725) 1B	please repair the leaking pipe on the second commode in the boys locker room in the old gym.	7/17/13	Gym	boy locker room gym	Plumbing
Trezevant Sr (2725) 1B	please repair faucet the water turn off on the middle sink in the girls locker room in the old gym.	7/17/13	Gym	girls locker room	Plumbing
Trezevant Sr (2725) 1B	please repair the A/C unit leaking water in classroom#273 ID#136-109	7/17/13	2nd Floor	classroom#273	Plumbing
Trezevant Sr (2725) 1B	please repair the a/c unit leaking water in classroom#257.ID#136-095	7/17/13	2nd Floor	classroom#257	Plumbing
Trezevant Sr (2725) 1B	A/C leaking in ROTC Building Willie Golden 416-3361	7/18/13			Plumbing
Trezevant Sr (2725) 1B	please repair the water fountain.the water fountain leaking water on the floor in the new gym.	7/24/13	Gym	new gym	Plumbing

Trezevant Sr (2725) 1B	please un-stopped the second commode in the boys locker room on the south end in the new gym.	7/24/13	Gym	new gym	Plumbing
Trezevant Sr (2725) 1B	A/C Unit rm 257 leaking water per Willie Golden 416-3361	7/30/13			Plumbing
Trezevant Sr (2725) 1B	Repair water leak rm 257.	7/31/13	2nd Floor		Plumbing
Trezevant Sr (2725) 1B	Rooms 273, 253, 172 a/c leaking per Willie Golden 416-3361	8/1/13			Plumbing
Trezevant Sr (2725) 1B	please un-stopped the second commode in the boys locker room in the new gym	8/1/13	Annex	new gym	Plumbing
Trezevant Sr (2725) 1B	FCU IS LEAKIING IN RM-240(085). PLANT MGR-GOLDEN/416.3760	8/20/13			Plumbing
Trezevant Sr (2725) 1B	Repair leak on custodial chemical supply sink.	8/20/13	Custodial	Plant Manager Office	Plumbing
Trezevant Sr (2725) 1B	FCU RM 119 LEAKING-PLANT MGR GOLDEN 416-3361 KLR	8/21/13			Plumbing
Trezevant Sr (2725) 1B	AHU BANDRM-LEAKING-PLANT MGR GOLDEN 416-3361 KLR	8/22/13			Plumbing

Trezevant Sr (2725) 1B	UNIT IS LEAKING WATER IN RM-258(096) PLANT MGR-GOLDEN/416.3760	8/23/13			Plumbing
Trezevant Sr (2725) 1B	per willie golden 416-3361 fan coil unit in room 150 and 251 are leaking	9/17/13			Plumbing
Trezevant Sr (2725) 1B	A/C RM 258-LEAKING-PLANT MGR GOLDEN 416-3361 KLR	9/25/13			Plumbing
Trezevant Sr (2725) 1B	Please repair the sink.the sink falling off the wall in the boys restroom in the Jrotc building.(urgent)	9/25/13	Annex	JROTC BLDG.	Plumbing
Trezevant Sr (2725) 1B	A/C RM 282-LEAKING-PLANT MGR GOLDEN 416-3361 KLR	9/25/13			Plumbing
Trezevant Sr (2725) 1B	A/C RM 142-LEAKING-PLANT MGR GOLDEN 416-3361 KLR	9/30/13			Plumbing
Trezevant Sr (2725) 1B	a/c leaking in room 258 per Willie Golden 416-3361	10/1/13			Plumbing
Trezevant Sr (2725) 1B	Unstop floor drain,it is coming out to floor.	10/3/13	Restroom (Girls)	#147	Plumbing
Trezevant Sr (2725) 1B	Unstop toilet. Used plunger and Closet organ.	10/3/13	Auxiliary Gym	Locker Room (outside)	Plumbing

Trezevant Sr (2725) 1B	Water fountain has no water pressure.	10/3/13	Administration Area	Office	Plumbing
Trezevant Sr (2725) 1B	please repair the hole in the water pipe under the three compartment sink in the kitchen.	10/25/13	1st Floor	kitchen	Plumbing
Trezevant Sr (2725) 1B	replace shut off valve on condensate pipe	10/25/13			Plumbing
Trezevant Sr (2725) 1B	UNIT IS LEAKING WATER IN RM-238,240 PLANT MGR-GOLDEN/416.3760	6/17/14			Plumbing
Trezevant Sr (2725) 1B	Test and report on backflow prevention devices.	6/17/14			Plumbing
Trezevant Sr (2725) 1B	A/C RM 237 & 238-BOTH LEAKING-PLANT MGR GRANDERSON 416-3361 KLR	6/18/14			Plumbing
Trezevant Sr (2725) 1B	A/C UNIT is LEAKING in the GUIDANCE OFFICE per Mr. Granderson, Plant Mgr. 416.3760	6/18/14			Plumbing
Trezevant Sr (2725) 1B	A/C UNIT is LEAKING in ROOM 275 per Willie Golden, Plant Mgr. 416.3361	6/24/14			Plumbing
Trezevant Sr (2725) 1B	URINAL- B RR BY RM 278 - CONSTANTLY RUNNING - PM/GRANDERSON 416-3760	6/24/14			Plumbing

Trezevant Sr (2725) 1B	A/C UNIT is LEAKING ROOM 253 and ROOFTOP UNIT in LEAKING in the CAFETERIA per Willie Golden, Plant Mgr. 416.3361	6/25/14			Plumbing
Trezevant Sr (2725) 1B	please repair the faucet on the sink in the back room of the attendance office.	4/16/14	1st Floor	attendance office	Plumbing
Trezevant Sr (2725) 1B	please repair or replace the broken commode.the commode will not flush in the girls restroom in the JROTC building.	4/22/14	Restroom (Girls)	JROTC Building	Plumbing
Trezevant Sr (2725) 1B	FLOOR DRAIN RM 110 RR AREA-BACKING UP WATER-FLOODING AREA PER SBE-PLANT MGR GOLDEN 416-3361 KLR	3/25/14			Plumbing
Trezevant Sr (2725) 1B	POP-OFF VALVE MECH RM BY RM 142-LEAKING-PLANT MGR GOLDEN 416-3361 KLR	3/28/14			Plumbing
Trezevant Sr (2725) 1B	WATER PIPE - NEW GYM BUSTED INSIDE WALL IN GIRL'S LOCKER RM - PM/GOLDEN 416-3369	5/21/14			Plumbing
Trezevant Sr (2725) 1B	please un-stopped the (2) drinking fountain in the Jrotc building	5/23/14	3rd Floor	Jrotc Building	Plumbing
Trezevant Sr (2725) 1B	A/C UNIT is LEAKING in the CAFETERIA per Donald Granderson, Plant Mgr. 562.5611	6/30/14			Plumbing
Trezevant Sr (2725) 1B	replace pump on condensate tank	10/25/13			Plumbing

Trezevant Sr (2725) 1B	please un-stopped (2) sinks in the kitchen in room#146.	10/31/13	1st Floor	kitchen #room#146	Plumbing
Trezevant Sr (2725) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	10/31/13			Plumbing
Trezevant Sr (2725) 1B	Toilet has lost water pressure. Will not flush!	11/5/13	Gym	Outside Locker Room	Plumbing
Trezevant Sr (2725) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13			Plumbing
Trezevant Sr (2725) 1B	pick up pump for condensate tank	11/18/13			Plumbing
Trezevant Sr (2725) 1B	please repair the commode.the 3rd commode is short flushing in the girls restroom 157.	11/19/13	1st Floor	girls restroom#157	Plumbing
Trezevant Sr (2725) 1B	WATER HEATER PIPE HAS HOLE & LEAKING , POP OFF VALVE IS LEAKING IN OLD GYM MECH RM, POP OFF VALVE LEAKING IN ELEC RM BY 141, & CONNECT VALVE IS LEAKING IN BOILER RM	11/19/13			Plumbing
Trezevant Sr (2725) 1B	water heater leaking	11/20/13			Plumbing
Trezevant Sr (2725) 1B	pop off leaking in old gym	11/20/13			Plumbing

Trezevant Sr (2725) 1B	pop off leaking in elec. rm by 141	11/20/13			Plumbing
Trezevant Sr (2725) 1B	control valve leaking in boiler rm	11/20/13			Plumbing
Trezevant Sr (2725) 1B	WATER PIPE MECH RM OLD GYM-LEAKING FROM CEILING- PLANT MGR GOLDEN 416-3361 KLR	11/26/13			Plumbing
Trezevant Sr (2725) 1B	flush princ. ofc --- no heat	1/6/14			Plumbing
Trezevant Sr (2725) 1B	please repair the drinking fountain. the drinking fountain is leaking water in the main lobby.	1/9/14	1st Floor	main lobby	Plumbing
Trezevant Sr (2725) 1B	NORTH WALL PIPE HAS BUSTED IN GYM PLANT MGR-GOLDEN/416.3760	1/10/14			Plumbing
Trezevant Sr (2725) 1B	Repair toilet, it will not flush. Not enough water pressure to flush.	12/5/13	Gym	Locker Room	Plumbing
Trezevant Sr (2725) 1B	please repair or turn off the drinking fountain so the water want run on the floor.	12/9/13	3rd Floor	hallway by rm#273	Plumbing
Trezevant Sr (2725) 1B	Test and report on backflow prevention devices.	12/18/13			Plumbing

Trezevant Sr (2725) 1B	SHOWER FAUCET GYM B LOCKER RM-BROKEN OFF AND WATER RUNNING OUT OF IT-CAN'T CUT OFF-PLANT MGR GOLDEN 416-3361 KLR	2/3/14			Plumbing
Trezevant Sr (2725) 1B	please repair the commode the first commode is short flushing in the north boys locker room restroom in the old gym.	1/13/14	2nd Floor	boys locker rm old gym	Plumbing
Trezevant Sr (2725) 1B	PIPE IS LEAKING WATER IN MECH RM OLD GYM. PLANT MGR-GOLDEN/416.3160	1/21/14			Plumbing
Trezevant Sr (2725) 1B	NO HOT WATER TO KITCHEN- PLANT MGR GOLDEN 416-3361 KLR	1/22/14			Plumbing
Trezevant Sr (2725) 1B	Insulate pipes in locker room gym outside. Repairs are complete.	1/23/14	Gym		Plumbing
Trezevant Sr (2725) 1B	COILS HAVE BURST IN LIBRARY AREA-PLANT MGR GOLDEN 416-3361 KLR	1/29/14			Plumbing
Trezevant Sr (2725) 1B	please repair the broken faucet on the third commode in the girls restroom#281.	2/26/14	2nd Floor	girls restroom#281	Plumbing
Trezevant Sr (2725) 1B	please repair the faucet handle in the shower boys locker room in the new gym.	2/27/14	1st Floor	new gym	Plumbing
Trezevant Sr (2725) 1B	PIPE KITCHEN AREA-LEAKING ON FREEZER-PLANT MGR GOLDEN 416-3361 KLR	5/6/14			Plumbing

Trezevant Sr (2725) 1B	please repair the broken faucet on the face basin in the boys restroom in the main lobby.	5/6/14	1st Floor	boys RR main lobby	Plumbing
Trezevant Sr (2725) 1B	per mr golden 416-3369 a/c units in rooms 251 and 252 are leaking	5/7/14			Plumbing
Trezevant Sr (2725) 1B	Unstop drain in air conditioner, it is leaking water.	5/9/14	Classroom	#252	Plumbing
Trezevant Sr (2725) 1B	UNIT IS LEAKING WATER IN RM-252 PLANT MGR-DONALD/416.3760	5/9/14			Plumbing
Trezevant Sr (2725) 1B	A/C RM 274-LEAKING-PLANT MGR GRANDERSON 416-3361 KLR	5/12/14			Plumbing
Trezevant Sr (2725) 1B	UNIT IS LEAKING WATER IN RM-251,252,274,231,238 PLANT MGR-GOLDEN/416.3800	5/13/14			Plumbing
Trezevant Sr (2725) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	5/19/14			Plumbing
Trezevant Sr (2725) 1B	please repair the leaking faucet on the sink in the kitchen please see the cafeteria manager.	3/20/14	1st Floor	kitchen	Plumbing
Trezevant Sr (2725) 1B	please repair faucet leaking water on the sink in the men restroom (I turn the right faucet off.)	2/28/14	1st Floor	men RR teacher lounge	Plumbing

Trezevant Sr (2725) 1B	please repair commode commode leaking water in the girls locker in the new gym.	3/17/14	1st Floor	new gym locker room	Plumbing
Trezevant Sr (2725) 1B	please repair the urinal. the urinal leaking water behind the urinal next to the wall in the boys locker room in the new gym.	4/1/14	Gym	new gym	Plumbing
Trezevant Sr (2725) 1B	please repair the second commode the commode leaking water around the flush valve in boys restroom#234.	4/2/14	2nd Floor	boys restroom#234	Plumbing
Trezevant Sr (2725) 1B	2-MOTORS ARE LEAKING WATER IN MECH RM. PLANT MGR-GOLDEN/416.3760	4/4/14			Plumbing
Trezevant Sr (2725) 1B	UNIT IS LEAKING WATER IN RM-252,253 PLANT MGR-GRANDERSON/562.5611	6/3/14			Plumbing
Trezevant Sr (2725) 1B	UNIT VENT - RMS 275 LEAKING - PM/GRANDERSON 416-3760	6/4/14			Plumbing
Trezevant Sr (2725) 1B	2-WALL UNITS ARE LEAKING WATER IN RM-253,258. PLANT MGR-GRANDERSON/562.5611	6/5/14			Plumbing
Trezevant Sr (2725) 1B	UNIT IS LEAKING WATER IN RM-143 PLANT MGR--GRANDERSON/416.3760	6/9/14			Plumbing
Trezevant Sr (2725) 1B	Repair ac unit rm 143.	6/12/14	Classroom		Plumbing

Trezevant Sr (2725) 1B	Repair ac in room 235.	6/12/14			Plumbing
Trezevant Sr (2725) 1B	Repair ac in room 236.	6/12/14			Plumbing
Trezevant Sr (2725) 1B	Repair ac in room 253.	6/12/14			Plumbing
Trezevant Sr (2725) 1B	Repair ac in room 244.	6/12/14			Plumbing
Trezevant Sr (2725) 1B	Repair ac in room 257.	6/12/14			Plumbing
Trezevant Sr (2725) 1B	Repair ac in room 258.	6/12/14			Plumbing
Trezevant Sr (2725) 1B	FLOOR DRAIN AUDITORIUM 3RD FLR-STOPPED UP AND WATER RUNNING DOWN WALL IN AREAS BELOW-PLANT MGR GOLDEN 416-3361 KLR	6/16/14			Plumbing
Trezevant Sr (2725) 1B	Repair roof leak.	5/29/14	Administration Area	Guidance Office	Roof
Trezevant Sr (2725) 1B	Repair roof leak in hall.	6/30/14	Hallway/Corridor	Vocational Area	Roof

Trezevant Sr (2725) 1B	Repair roof leak.	6/30/14	Cafeteria		Roof
Trezevant Sr (2725) 1B	please repair the roof. the roof are leaking water in the cafeteria	3/6/14	1st Floor	cafeteria	Roof
Trezevant Sr (2725) 1B	Remove louvers and fabricate metal to cover opening, next to new chiller. Support Chalk.	4/30/14	Mechanical Room		Sheet Metal
Trezevant Sr (2725) 1B	Grind down metal peice, left of building.	8/22/13	Annex	ROTC	Sheet Metal
Trezevant Sr (2725) 1B	Fabricate side cover plates for water fountain in New boys gym.	9/18/13			Sheet Metal
Trezevant Sr (2725) 1B	repair shell on boiler #2	10/25/13			Sheet Metal
Trezevant Sr (2725) 1B	please repair the haggging cover end on the radiator in the hallway near room#150.	3/26/14	1st Floor	hallway near room 150	Sheet Metal
Trezevant Sr (2725) 1B	need to check insulation on unit	12/10/13			Sheet Metal
Trezevant Sr (2725) 1B	Fabricate sheet metal shims for ac units. Support Joe.	5/14/14			Sheet Metal

Trezevant Sr (2725) 1B	Make shimes for HVAC units. Support Joe	6/11/14			Sheet Metal
------------------------	--	---------	--	--	-------------

Count of Craft	Craft						
Location	Carpentry	Electrical	HVAC	Painting	Plumbing	Sheet Metal	Grand Total
Vance Middle (2728) 1A	13	21	53	1	40	3	131
Grand Total	13	21	53	1	40	3	131

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
Vance Middle (2728) 1A	Pantry doors need repair hard to open and close per cafe. manager URGENT.	11/14/13	Kitchen	pantry		Carpentry
Vance Middle (2728) 1A	WINDOW WONT SHUT IN RM-207 PLANT MGR-SHARPE/416.8400	11/25/13				Carpentry
Vance Middle (2728) 1A	REAR ENTRANCE DOOR KITCHEN AREA-BOLTS COMING OUT OF HINGE-SAFETY AND SECURITY ISSUE-PLANT MGR SHARP 416-5236 KLR	1/22/14				Carpentry
Vance Middle (2728) 1A	Remount pump base	8/14/13				Carpentry
Vance Middle (2728) 1A	Asst. Principal office the wall needs repair it coming apart from the top URGENT.	8/28/13	1st Floor	Asst. Principal		Carpentry
Vance Middle (2728) 1A	Remove big teacher mail box from wall in office per principal.	8/5/13	1st Floor	main office		Carpentry
Vance Middle (2728) 1A	Back entrance door to kitchen needs repair manager is having hard time locking it URGENT.	10/28/13	1st Floor	kitchen		Carpentry

Vance Middle (2728) 1A	Ladies room door not closing properly URGENT.	1/24/14	1st Floor	kitchen	Carpentry
Vance Middle (2728) 1A	Rest room door boys locker room has come off the hinge.	2/24/14	2nd Floor	boys locker room	Carpentry
Vance Middle (2728) 1A	Main entrance library door cylinder hanging it vrey hard to close.	3/18/14	2nd Floor	Library	Carpentry
Vance Middle (2728) 1A	Boys restroom door not closing properly.	3/18/14	2nd Floor	boys restroom	Carpentry
Vance Middle (2728) 1A	Entrance door hanging off hinge.	3/18/14	Gym	boys locker room	Carpentry
Vance Middle (2728) 1A	Install handy cap access to girls restroom per principal have 2 students in wheel chairs.	8/21/13	1st Floor	girls restroom	Carpentry
Vance Middle (2728) 1A	Main office lights need balast.	11/14/13	Administration Area	MAIN OFFICE	Electrical
Vance Middle (2728) 1A	Conference room needs balast in 2 lights.	12/18/13	1st Floor	North area office	Electrical

Vance Middle (2728) 1A	Guidance office restroom light has bad balast,cant see in there at all per staff URGENT.	1/16/14	2nd Floor	main office	Electrical
Vance Middle (2728) 1A	REPL BREAKER FOR COOLING TOWER-REQUESTED BY D HURDLE KLR	8/14/13			Electrical
Vance Middle (2728) 1A	KITCHEN HAS NO POWER AT ALL-VERY DARK IN AREA- PLANT MGR KLR	8/23/13			Electrical
Vance Middle (2728) 1A	pump #3 starter dropping out	7/9/13			Electrical
Vance Middle (2728) 1A	2nd floor and gym the a/c is not working at all per Frank Sharp 416-3256	8/7/13			Electrical
Vance Middle (2728) 1A	Light over teacher station has bad balast URGENT.	9/10/13	2nd Floor	library	Electrical
Vance Middle (2728) 1A	AHU NOT COMING ON ON 1ST FLR WEST-WING. PLANT MGR-SHARPE/416.3256	9/18/13			Electrical
Vance Middle (2728) 1A	Repair exit lights.	9/30/13	1st Floor	building 1&2 floor	Electrical

Vance Middle (2728) 1A	Exhaust fans not working.	10/1/13	1st Floor	2nd grade rest rooms	Electrical
Vance Middle (2728) 1A	Replace pump coupler	10/2/13			Electrical
Vance Middle (2728) 1A	Repair light in cafeteria manager restroom.URGENT	10/15/13	1st Floor	kitcken	Electrical
Vance Middle (2728) 1A	Class room 104,&2nd floor lobby needs balast.	11/5/13	1st Floor	room 104	Electrical
Vance Middle (2728) 1A	Replace burned out bulbs in all custodial closets.	11/7/13	1st Floor	custodial closets	Electrical
Vance Middle (2728) 1A	VENTING HOOD NOT COMING ON IN CAFE PLANT MGR-SHARPE/416.8400	3/17/14			Electrical
Vance Middle (2728) 1A	Please give me 20 of the 100 watt screw in light bulbs I think the number is 46805	4/22/14			Electrical
Vance Middle (2728) 1A	Disconnect electrical from kitchen equipment so equipment may be moved. (per Jim Cruthirds)	6/20/14			Electrical

Vance Middle (2728) 1A	Need 50 rapid start 25 bulbs, philips #pl-s9w/27c, philips PL-S13W/27A, 24 REGULAR 100 WATT.	8/28/13	1st Floor	Plant manager office	Electrical
Vance Middle (2728) 1A	Lamp flr, rapid start 25 #46807 3box	1/23/14	1st Floor	plant manager	Electrical
Vance Middle (2728) 1A	Lamp Flr, rapid start 25 #46807 need 75.	12/16/13	1st Floor	PLANT MANAGER	Electrical
Vance Middle (2728) 1A	boiler down	11/25/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Filter-Vance Middle - Refer to PM schedule details.	12/9/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	UNIT NOT HEATING THRU ENTIRE 1ST & 2ND FLRS PLANT MGR-SHARPE/870.0368	12/11/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	check boilers	12/12/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	AHU SERVES BANDRM & HOME EC RM-NOT HEATING-PLANT MGR SHARP KLR	12/13/13			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	boiler down	12/23/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Air Comp-Boiler Rm W. Wall-Vance Mdl - Refer to PM schedule details.	1/7/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	HEAT 1ST FLR ABOUT (6) RMS-SBE DIDN'T HAVE NUMBERS-NOT HEATING-PLANT MGR SHARP 416-2610 KLR	1/7/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	boiler not coming up to temp	1/8/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	chemical treatment piping leaking -- repair or replace	1/13/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	1/21/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	cooling tower making noise	7/3/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Air Comp-Boiler Rm W. Wall-Vance Mdl - Refer to PM schedule details.	7/9/13			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	chiller down	7/9/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Oil Lube & Belt-Vance Middle - Refer to PM schedule details.	7/16/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	CHILLER IS NOT COOLING. SBE SHARPE 416-3256	7/23/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	UNIT NOT COOLING IN GYM. PLANT MGR-SHARPE/416.3256	8/1/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Filter-Vance Middle - Refer to PM schedule details.	8/5/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	AHU NOT COOLING THRU ENTIRE 2ND FLR. PLANT MGR-SHARP/870.0368	8/5/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	AHU - WATER FLOW PROBLEM AROUND CAFE AREA NOT COOLING - PM/SHARP 870-0368	9/9/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	1st floor near cafeteria a/c not cooling entire area per Mr. Sharp 870-0568	9/10/13			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	flush coils and strainers on AHU's	9/11/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	1st floor classrooms a/c not cooling per Sharp 416-3256	9/17/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	A/C RMS 107, 108, & 109-ALL NOT COOLING-PLANT MGR JEFFERSON 416-2514 KLR	9/18/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Yearly - Oil Samples-Vance Middle - Refer to PM schedule details.	9/23/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - VANCE MIDDLE LVL 2 WATER TREATMENT - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	2/4/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Oil Lube & Belt-Vance Middle - Refer to PM schedule details.	2/18/14			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	2/18/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	boiler down	2/26/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - VANCE MIDDLE LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	3/4/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	3/18/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	C/O to A/C ---- 4 pipe system	3/21/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Yearly - Rod Chiller - Vance Middle - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Yearly - Cooling Towers(STRAINERS)- Vance Middle - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	clean cooling tower	3/24/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Yearly - Water-Cool Chiller Filter-Vance Middle - Refer to PM schedule details.	3/25/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	4/1/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - VANCE MIDDLE LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - Filter-Vance Middle - Refer to PM schedule details.	4/7/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	4/15/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	4/29/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - VANCE MIDDLE LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	per sharp 416-3256 12 and 15 blowing hot	5/7/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	5/13/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	5/27/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Monthly - VANCE MIDDLE LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	6/10/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	CHILLER MECH RM-NOT COMING ON-PLANT MGR SHARP 416-7370 KLR	6/13/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	clean coils	6/19/14			Heating/Ventilation /Air Conditioning
Vance Middle (2728) 1A	Daily - Vance Middle Level 1 Water Treatment - Refer to PM schedule details.	6/24/14			Heating/Ventilation /Air Conditioning

Vance Middle (2728) 1A	Paint in main office and the front of the building per principal.	8/12/13	2nd Floor	mainoffice	Painting
Vance Middle (2728) 1A	Gas leak boiler room	11/12/13			Plumbing
Vance Middle (2728) 1A	Commods leaking around flushing handles.	11/19/13	2nd Floor	girls&mans	Plumbing
Vance Middle (2728) 1A	1st floor boys restroom commode leaking also 3rd floor girls commode leak.	11/25/13	1st Floor	restrooms	Plumbing
Vance Middle (2728) 1A	1ST floor boys restroom commode leaks when it flushed,same for girls& boys on 2and floor near concession stand.	12/5/13	1st Floor	boys restroom	Plumbing
Vance Middle (2728) 1A	Oder from drain smelling all over the building.	12/9/13	1st Floor	entire building	Plumbing
Vance Middle (2728) 1A	1st floor boys restroom commode leaking.	1/10/14	1st Floor	1st&2nd	Plumbing
Vance Middle (2728) 1A	Commode leaking when it is flushed last stall.	1/10/14	2nd Floor	girls restroom	Plumbing

Vance Middle (2728) 1A	NO HOT WATER TO KITCHEN AREA-DON'T KNOW IF HOT WATER TANK NOT COMING ON OR NOT HEATING OR PILOT-PLANT MGR SHARP 416-2610 KLR	1/13/14			Plumbing
Vance Middle (2728) 1A	Air Unit leaking in Rm 4 Per Mr. Billy Williams at 901.416.7383.	7/8/13			Plumbing
Vance Middle (2728) 1A	Boys restroom near cafe.has2 hand washing sinks leaking.	7/24/13	1st Floor	boys restroom	Plumbing
Vance Middle (2728) 1A	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	7/31/13			Plumbing
Vance Middle (2728) 1A	Rpair hand washing sinks all of them are leaking bad URGENT.	8/8/13	1st Floor	boysrestroom	Plumbing
Vance Middle (2728) 1A	SEWAGE IS BACKING UP IN KITCHEN PLANT MGR-SHARPE/870.0368	9/3/13			Plumbing
Vance Middle (2728) 1A	Drain in dishwasher area is stop up,sink on west wall has a leaking drain pipe.	9/4/13	1st Floor	kitchen	Plumbing
Vance Middle (2728) 1A	Cafeteria Manager commode seat broken.	9/24/13	Kitchen	cafeteria office	Plumbing

Vance Middle (2728) 1A	Commode flush valve needs replaceing not working at all.	9/25/13	2nd Floor	girls restroom	Plumbing
Vance Middle (2728) 1A	Sink water cannot be CONTAINED in Kitchen per Mr. Sharp, Plant Mgr. 870.0368	9/27/13			Plumbing
Vance Middle (2728) 1A	MOP sink leaking per plumber.	10/1/13	1st Floor	kitchen	Plumbing
Vance Middle (2728) 1A	Commode stop up boys restroom ist floor,I tried no luck.	10/1/13	1st Floor	BOYS RESTROOM	Plumbing
Vance Middle (2728) 1A	Check building for sewer gas	10/3/13			Plumbing
Vance Middle (2728) 1A	1st floor girls restroom the hand sink has come off the wall per Mr. Sharp 870-0368	10/17/13			Plumbing
Vance Middle (2728) 1A	Boys restroom urinals stop up,one toilet 1st floor,girls commode stop up bad order coming from drains.	10/23/13	2nd Floor	boysrestroom &girls	Plumbing
Vance Middle (2728) 1A	expansion tank needs sight glass valves	10/23/13			Plumbing

Vance Middle (2728) 1A	Replace toilet ,its leaking also unstop urinal drains.	10/28/13	2nd Floor	boys restroom	Plumbing
Vance Middle (2728) 1A	Floor drain backing up.	2/13/14	1st Floor	girls restroom	Plumbing
Vance Middle (2728) 1A	FLOOR DRAIN SERVING LINE AREA-BACKING UP-PLANT MGR SHARP KLR	2/19/14			Plumbing
Vance Middle (2728) 1A	Repair line going to cooling tower	2/20/14			Plumbing
Vance Middle (2728) 1A	1st floor boys restroom commode not flushing properly,3rd stall.	3/19/14	1st Floor	boys restroom	Plumbing
Vance Middle (2728) 1A	Sewer drian needs some treatment,its smelling very bad.	3/19/14	1st Floor	sewer drian	Plumbing
Vance Middle (2728) 1A	SEWAGE SMELL THRU ENTIRE BLDG SEC-COLEMAN/416.3256	4/7/14			Plumbing
Vance Middle (2728) 1A	Test and report on backflow prevention devices.	4/11/14			Plumbing

Vance Middle (2728) 1A	PIPE CEILING IS LEAKING WATER IN STORAGE RM PLANT MGR-SHARPE/416.7370	4/21/14			Plumbing
Vance Middle (2728) 1A	2nd floor boys restroom urinal stop up.	4/30/14			Plumbing
Vance Middle (2728) 1A	commode has come lose causing water to run down to boys 2nd floor restroom URGENT.	5/2/14	3rd Floor	boys restroom	Plumbing
Vance Middle (2728) 1A	Pull & reset toilet	5/5/14			Plumbing
Vance Middle (2728) 1A	Check roof drain for blockage.	5/5/14	Grounds	roof drian	Plumbing
Vance Middle (2728) 1A	Louse toliet seat,flush value leaks around commodes.	5/16/14	3rd Floor	restrooms	Plumbing
Vance Middle (2728) 1A	Louse toliet seat,flush value leaks around commodes.	5/16/14	2nd Floor	restrooms	Plumbing
Vance Middle (2728) 1A	Test and report on backflow prevention devices.	6/17/14			Plumbing

Vance Middle (2728) 1A	Disconnect plumbing from kitchen equipment so equipment may be moved. (per Jim Cruthirds)	6/20/14			Plumbing
Vance Middle (2728) 1A	cut access in duct	9/11/13			Sheet Metal
Vance Middle (2728) 1A	Remove old paper towel holders, in kk girls&rotunda boys.	10/2/13	1st Floor	1st floor restroom	Sheet Metal
Vance Middle (2728) 1A	Patch holes in cooling tower	4/9/14			Sheet Metal

Count of Craft	Craft						
Location	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Volentine ES (2730) 1E	19	19	55	2	28	11	134
Grand Total	19	19	55	2	28	11	134

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Vollentine ES (2730) 1B	CEILING TILE IS FALLEN IN RM-206 PLANT MGR-FOSSETT/416.4632	3/18/14			Carpentry
Vollentine ES (2730) 1B	We have a sliding wall thats off track and need repairing, so that we can keep it shut when kids are having activities in room for safety purposes. Thanks	6/20/14	Auxiliary Gym	Rm 150	Carpentry
Vollentine ES (2730) 1B	Door mull is loose and need repairing not letting door lock close properly most urgent matter, thanks.	4/30/14	Hallway/Corridor	1st Floor northwest entrance door	Carpentry
Vollentine ES (2730) 1B	We had a break in last night here and three classroom view windows were broken out need repairing. Thanks	5/7/14	Classroom	2nd floor Rms. #228, 229,226	Carpentry
Vollentine ES (2730) 1B	Same thing view window broken out due to break-in at school last night, need repairing most urgent.	5/7/14	Administration Area	2nd floor Lounge	Carpentry
Vollentine ES (2730) 1B	Cafeteria door need repairing will not close properly and lock. Thanks	5/7/14	Cafeteria	1st floor Rm 140	Carpentry
Vollentine ES (2730) 1B	We have damaged cieling tiles Due to previous roof leaks, need cieling tiles replaced. Thanks	3/19/14	Hallway/Corridor	2nd Floor Hallway Cieling Tile	Carpentry
Vollentine ES (2730) 1B	Adjust door closer	7/11/13			Carpentry
Vollentine ES (2730) 1B	cieling tiles need putting back in place. To high for plant manager.	8/6/13	Classroom	Multi - purpose Rm 150	Carpentry

Vollentine ES (2730) 1B	We have a room were the cieling tiles got wet and the techs removed them. It left a mildew smell in the room, need someone to investigate this matter.	8/6/13	Classroom	Music Rm 153	Carpentry
Vollentine ES (2730) 1B	Stall door is broken	9/5/13	Restroom (Boys)	2nd Floor	Carpentry
Vollentine ES (2730) 1B	Stall door is broken	9/5/13	Restroom (Girls)	2nd Floor	Carpentry
Vollentine ES (2730) 1B	Handrail is extremely and need repairing for safety issues. Thanks	11/12/13	1st Floor	Stairwell- Handrail	Carpentry
Vollentine ES (2730) 1B	Disreguard that first request its on the second floor handrail.	11/13/13	2nd Floor	Stairwell- 2nd Floor	Carpentry
Vollentine ES (2730) 1B	metal plate on the floor ,under the refridgerator door is coming up - which causes door remain cracked open even when it's lock - employees and I stumble over it each time we enter and exit -it's a hazard	11/19/13	Kitchen		Carpentry
Vollentine ES (2730) 1B	We have floor tile that has been damage by roof leak, and its coming up from floor real bad. Need a technician. Thanks	1/22/14	Gym	Multi- Purpose Rm 145	Carpentry
Vollentine ES (2730) 1B	We have several cieling tiles thats falling due to leaks and have warp from the moisture and need removing and replacing. Also there are no cieling tile on hand at the school thats corrugated kind. Thanks	2/24/14	Auxiliary Gym	Multi- Purpose Rm. 150	Carpentry
Vollentine ES (2730) 1B	We have a banner that were requesting to be hung under the existing banner. Also this request is warranted by, Daniel Hurdle, Thanks	3/11/14	Administration Area	Outside - Bldg Structure	Carpentry
Vollentine ES (2730) 1B	We have a couple of large library book islands that need to be removed and taken to another room which is the multi- purpose room. They need to be unassembled. Thanks	3/17/14	Library	1st Floor - Library	Carpentry

Vollentine ES (2730) 1B	Disconnect power on disposal	4/4/14			Electrical
Vollentine ES (2730) 1B	We have a couple of bad ballast gone bad and its creating a dark work enviroment for teachers and student,need lighting	4/7/14	Classroom	2ND Floor Rm 207	Electrical
Vollentine ES (2730) 1B	We need batteries for clocks,thanks.	5/7/14	Hallway/Corridor	1st&2nd floor	Electrical
Vollentine ES (2730) 1B	We have some ballast out in this room that need repairing. Thanks	3/31/14	Auxiliary Gym	1st Floor Rm 150 A	Electrical
Vollentine ES (2730) 1B	These doors are staying open due to over energize circuit will close when unplugged. Need for access for teachers and public.	4/3/14	1st Floor	West Entry- Handicap Door	Electrical
Vollentine ES (2730) 1B	Install stove & oven	7/15/13			Electrical
Vollentine ES (2730) 1B	UNIT NOT COMING ON IN CAFE, RM-207,208 (NO ID). SBE-LONGMIRE/416-4632	7/17/13			Electrical
Vollentine ES (2730) 1B	Cafeteria Manager need lighting in her area because its dark when she enters the bldg concerns of stragglers hanging around dumpster for sleeping spot. Thanks Bldg Maintenance.	8/7/13	Cafeteria	outside entry	Electrical
Vollentine ES (2730) 1B	UV RM 102-NOT COMING ON- PLANT MGR FOSSETT 416-4632 KLR	8/26/13			Electrical
Vollentine ES (2730) 1B	We have a ballast thats bad in the office area over the sink.	9/6/13	Administration Area	Main -Office	Electrical

Vollentine ES (2730) 1B	We need light bulbs in these areas for better lighting support also in the hallways.	9/13/13	Classroom	All Classroom	Electrical
Vollentine ES (2730) 1B	We have a ballast out in this room, need light for learning purposes.	9/23/13	Classroom	1st floor/102	Electrical
Vollentine ES (2730) 1B	We have two ballast thats burned out in this room.	9/24/13	Classroom	2nd floor/234	Electrical
Vollentine ES (2730) 1B	We have burned out ballast in this room also.	9/24/13	Classroom	2nd floor/235	Electrical
Vollentine ES (2730) 1B	We have a burned out ballast in this area.	9/24/13	Hallway/Corridor	2nd floor 3rd grade	Electrical
Vollentine ES (2730) 1B	Master clock need resetting due to storm.	9/25/13	Administration Area	Main- Office Area	Electrical
Vollentine ES (2730) 1B	Clocks need resetting. Thanks	11/4/13	Hallway/Corridor	Hallway/office area	Electrical
Vollentine ES (2730) 1B	Central clock and hall clocks need resetting, for daylight saving times. Thanks	2/26/14	Administration Area	Central Clock Resetting	Electrical
Vollentine ES (2730) 1B	We have a light out over the general secretary desk, also its making the office have a dim look about this area. Its the ballast, thanks.	2/27/14	Administration Area	Main - Office	Electrical
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning

Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	per mr fossett 416-4632 in the main office the HVAC unit is making a loud roaring noise and burning smell	4/9/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Yearly - Air Cool Chillers-Vollentine Elementary - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - Filter-Vollentine Elementary - Refer to PM schedule details.	4/28/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	per mr fossett 416-2632 library is not cooling	5/5/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	A/C LIBRARY, MAIN OFC AREA, & RM 214-ALL NOT COOLING- PLANT MGR FOSSETT 416-4632 KLR	5/6/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 177 not cooling	5/7/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 214 not cooling	5/7/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	clean library coils	5/7/14			Heating/Ventilation /Air Conditioning

Vollentine ES (2730) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	A/C RM 213 & 214-BOTH NOT COOLING-PLANT MGR FOSSETT 416-4632 KLR	5/30/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UNIT NOT COOLING IN RM-202 PLANT MGR-FOSSETT/416.4632	6/3/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UNIT NOT COOLING IN RM-208,209 PLANT MGR--FOSSETT/463.5448	6/9/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - Oil Lube & Belt-Vollentine Elementary - Refer to PM schedule details.	7/21/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UNITS ARE NOT COOLING IN RMS 106,138,139,107,228,230,231,232, 208,234,235,214. SBE LONGIMERE 416-3412	7/22/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)-Vollentine Elem - Refer to PM schedule details.	8/2/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UNIT IN THE KITCHEN IS NOT COOLING. SBE FOSSETT 416-4632	8/5/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Unit Ventilator in Room 147 Pre-K NOT COOLING per Mr. Fossett, Plant Mgr. at 901.416.4682.	8/6/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)-Vollentine Elem - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning

Vollentine ES (2730) 1B	Monthly - Filter-Vollentine Elementary - Refer to PM schedule details.	9/2/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	A/C RM 103-NOT COOLING-PLANT MGR FOSSETT 416-4632 KLR	9/9/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	RTU NOT COOLING KITCHEN PLANT MGR-FOSSETT/416.0632	9/10/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UV NOT COOLING IN RM-147 PLANT MGR-FOSSETT/416.4572	9/12/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)-Vollentine Elem - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	c/o to heat	10/22/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)-Vollentine Elem - Refer to PM schedule details.	11/1/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	(2) BOILERS-BOTH NOT COMING ON-PLANT MGR FOSSETT 416-4582 KLR	11/12/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	check boiler	11/13/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UNIT VENT - RM 214 - BLOWING NOT HEATING - PM/FOSSETT 416-4632	11/13/13			Heating/Ventilation /Air Conditioning

Vollentine ES (2730) 1B	both boilers are down per Mr. Fossett 416-4632	11/25/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	BOILER NOT COMING ON . PLANT MGR-FOSSETT/416.4582	11/25/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	11/29/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	check boiler	12/5/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	in the multi purpose room it is blowing cold air per Mr. Fossett 416-4582	12/16/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - Filter-Vollentine Elementary - Refer to PM schedule details.	12/30/13			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	1/3/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	per Mr. Fossett 416-4582 the library and room 229 are blowing cold air	1/7/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	HEAT LIBRARY-NOT HEATING- PLANT MGR FOSSETT 416-4632 KLR	1/21/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	boiler down	1/23/14			Heating/Ventilation /Air Conditioning

Vollentine ES (2730) 1B	library not heating	1/23/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 175 not heating	1/23/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 229 not heating	1/23/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 230 not heating	1/23/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	HEAT RM 229-NOT HEATING- PLANT MGR FOSSETT 416-4632 KLR	1/23/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	per mr fossett 416-4632 both boilers are down	2/3/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 139 not heating	2/3/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	rm 175 not heating	2/3/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - Oil Lube & Belt-Vollentine Elementary - Refer to PM schedule details.	2/23/14			Heating/Ventilation /Air Conditioning

Vollentine ES (2730) 1B	HEAT RM 227 & 229-BOTH NOT HEATING-PLANT MGR FOSSETT 41604582 KLR	2/26/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	UNIT NOT HEATING IN RM-214 PLANT MGR-FOSSETT/416.4572	2/27/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	Monthly - 1' Filters (Monthly)- Vollentine Elem - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	5-UNIT NOT HEATING IN RM-229,232,210,214,228,215 PLANT MGR-FOSSETT/416.4582	3/7/14			Heating/Ventilation /Air Conditioning
Vollentine ES (2730) 1B	paint walls in library	4/21/14			Painting
Vollentine ES (2730) 1B	Paint bracket to match window	5/27/14			Painting
Vollentine ES (2730) 1B	per mr fossett 416-4632 in plant manager's office there is a leak coming from ceiling pipes and there is a restroom above his office	4/3/14			Plumbing
Vollentine ES (2730) 1B	Install disposal	4/4/14			Plumbing
Vollentine ES (2730) 1B	Toilet is flooding floor when flushed. Water is coming out of toilet from the surface, need tech thanks.	4/24/14	Restroom (Girls)	2nd Floor Westside Of Bldg	Plumbing
Vollentine ES (2730) 1B	We have a automatic hand wash sink thats leaking water onto the floor, and causing it to be wet, and hazardous. Need tech thanks.	4/3/14	Hallway/Corridor	1st Floor - Pre- K Area	Plumbing

Vollentine ES (2730) 1B	FAN COIL UNIT is LEAKING in ROOM 210, which is leaking in the Principal's office per Mr. Patterson, Plant Mgr. 416.4632	6/9/14			Plumbing
Vollentine ES (2730) 1B	FCU IN RM 153 IS LEAKING. SBE BLAKELY 416-4632	7/9/13			Plumbing
Vollentine ES (2730) 1B	Install stove & oven	7/15/13			Plumbing
Vollentine ES (2730) 1B	toilet is stop up and won't flush. Need a tech to fix problem.	8/6/13	Restroom (Girls)	Girls Pre k 1st floor	Plumbing
Vollentine ES (2730) 1B	Unit ventilator leaking in Room 175 per Mr. Fossett, Plant Mgr. 901.416.4562.	8/7/13			Plumbing
Vollentine ES (2730) 1B	We have a toilet thats costantly running, that was over flowing plant mgr slowed the flow of water to were it will not make a flood need tech to stop constant running. Thanks Bldg Maintenance.	8/8/13	Restroom (Girls)	2nd Floor 3rd grade	Plumbing
Vollentine ES (2730) 1B	toilet wont flush. Thanks	8/8/13	Restroom (Girls)	1st floor west girls restroom	Plumbing
Vollentine ES (2730) 1B	urinal cracked leaking. Thanks	8/8/13	Restroom (Boys)	2nd floor east	Plumbing
Vollentine ES (2730) 1B	urinal leak when flush. Thanks	8/8/13	Restroom (Boys)	2nd floor east	Plumbing
Vollentine ES (2730) 1B	PIPE IN B RR 1ST FLR WEST END LEAKING, CAN'T CONTAIN-SBE FOSSETT 416-4632 KLR	8/9/13			Plumbing

Vollentine ES (2730) 1B	FCU 2ND FLR RM 228-LEAKING-SBE FOSSETT 416-4632 KLR	8/13/13			Plumbing
Vollentine ES (2730) 1B	UV RM 214 2ND FLR-LEAKING-PLANT MGR FOSSETT 416-4582 KLR	9/3/13			Plumbing
Vollentine ES (2730) 1B	We have a urinal that s been running for a very long time and need a tech fix the problem.	10/29/13	Restroom (Boys)	Special Needs Area	Plumbing
Vollentine ES (2730) 1B	We have another urinal thats running and need fixing. Thanks	10/29/13	Restroom (Boys)	Down stair 1st Grade	Plumbing
Vollentine ES (2730) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	10/31/13			Plumbing
Vollentine ES (2730) 1B	TEST AND REPORT ON BACKFLOW PREVENTION DEVICES.	11/15/13			Plumbing
Vollentine ES (2730) 1B	We have a very foul odor coming from a drain and its causing the bldg to stink very badly need some assitance on this matter. Thanks	11/21/13	Restroom (Boys)	1st Floor boys east RR	Plumbing
Vollentine ES (2730) 1B	Toilet is stop up will not flush.	1/9/14	Restroom (Boys)	2nd Floor westside	Plumbing
Vollentine ES (2730) 1B	Will not flush.	1/9/14	Restroom (Girls)	2nd Floor	Plumbing
Vollentine ES (2730) 1B	Will not flush.	1/9/14	Restroom (Girls)	2nd floor east	Plumbing

Vollentine ES (2730) 1B	Will not flush.	1/9/14	Restroom (Girls)	1st Floor northeast	Plumbing
Vollentine ES (2730) 1B	COMMODE G RR 1ST FLR E SIDE CONSTANTLY OVERFLOWING, CAN'T CONTAIN-PLANT MGR FOSSETT 416-4632 KLR	1/28/14			Plumbing
Vollentine ES (2730) 1B	We need a tech check out problem were having with water issues. Faucets not releasing water. 2nd floor boys restroom west 5 th grade hall.	2/19/14	Restroom (Boys)	2nd Floor West side	Plumbing
Vollentine ES (2730) 1B	We have a leak on the garbage disposal, need tech its keeping the floor unsafe to walk on. Thanks	2/26/14	Cafeteria	Kitchen Area Sink	Plumbing
Vollentine ES (2730) 1B	We have a roof leak in this room. Need tech to fix problem.	3/17/14	Auxiliary Gym	Multi- Purpose Rm. 150	Roof
Vollentine ES (2730) 1B	We have a roof leak, need tech to fix problem. THANKS	3/17/14	Classroom	2ND Floor Rm 206	Roof
Vollentine ES (2730) 1B	Roof leaking	6/9/14	2nd Floor	Library	Roof
Vollentine ES (2730) 1B	Roof leak, multipurpose room leak at roof drain	7/15/13			Roof
Vollentine ES (2730) 1B	We have a leak in this area and need attending to. Thanks	10/31/13	Hallway/Corridor	Cafeteria/multi-purpose	Roof
Vollentine ES (2730) 1B	We have a roof leak in this room.	1/9/14	Classroom	2nd Floor Rm.228	Roof

Vollentine ES (2730) 1B	We have a leak in this room.	1/9/14	Library	1st floor library eastside 110	Roof
Vollentine ES (2730) 1B	We have a leak in this room	1/9/14	Gym	1st floor Rm 128	Roof
Vollentine ES (2730) 1B	ROOF LEAKING IN KITCHEN AREA-PLANT MGR FOSSETT 416- 4632 KLR	2/3/14			Roof
Vollentine ES (2730) 1B	We experience roof damage from rain parts of roof ceramic shingle fail. Need repairing, thanks.	2/5/14	Administration Area	Roof	Roof
Vollentine ES (2730) 1B	We have a leak in this room.	3/6/14	Classroom	2nd Floor Rm 239	Roof

Count of Craft	Craft										
	Location	Asbestos	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Washington Sr (2030) 1A		3	1	40	73	124	6	42	14	6	309
Grand Total		3	1	40	73	124	6	42	14	6	309

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Washington Sr (2030) 1A	The gym floor needs to be refinished.	10/9/13	Gym		Asbestos
Washington Sr (2030) 1A	Reinsulate pipes in front of room V248	11/13/13			Asbestos
Washington Sr (2030) 1A	There are some pipes in the gym that the insulation has been torn off. They are on the south wall at the double doors.	9/27/13	Gym		Asbestos
Washington Sr (2030) 1A	there is a wire down in front of school do to snow ice storm	3/7/14	Grounds	front of school	Cabling
Washington Sr (2030) 1A	panic bar broken at main entrance to school cannot lock per Sanders 416-7240	9/24/13			Carpentry
Washington Sr (2030) 1A	panic bar outside gym broken and can't secure per Mr. Sanders 416-7240	8/16/13			Carpentry
Washington Sr (2030) 1A	entrance door to gym closer is broken	5/15/14	Gym		Carpentry

Washington Sr (2030) 1A	the center mull is broken	5/16/14	Gym	entrance doors	Carpentry
Washington Sr (2030) 1A	the wind blow a window out need to be replaced birds are coming in	4/3/14	Gym	gym	Carpentry
Washington Sr (2030) 1A	We need someone to install the rubber pieces on the backboards in the gym, we have the rubber pieces.	11/24/13	Gym		Carpentry
Washington Sr (2030) 1A	when you close door it will not secure	2/14/14	Cafeteria	pantry door	Carpentry
Washington Sr (2030) 1A	work order no. 404601 yes we do have pull blinds on hand	1/8/14	1st Floor	band room	Carpentry
Washington Sr (2030) 1A	We need weather strips installed on the outside doors in the vo-tech building on the east side of the building.	10/16/13	1st Floor	Vocational building	Carpentry
Washington Sr (2030) 1A	Coach office GBOOB door handle needs to be replaced can't get out from the inside.	9/18/13			Carpentry
Washington Sr (2030) 1A	The hinge is broken on the door in the 2nd stall of the female faculty restroom across from room V233 in the vocational building.	8/22/13			Carpentry

Washington Sr (2030) 1A	Requesting ceiling 2 boxes hard 2 boxes soft replacing special cut lobby area an ramp.	8/23/13			Carpentry
Washington Sr (2030) 1A	Requesting weather stripping to go under the main office door way and under the door way of the administration door as well.	8/8/13			Carpentry
Washington Sr (2030) 1A	There are some broken windows in the gym near the boys restroom on the south side.	8/12/13	Gym		Carpentry
Washington Sr (2030) 1A	There is some damaged and missing ceiling tile in the ramp area.	8/21/13	Hallway/Corridor		Carpentry
Washington Sr (2030) 1A	there is a large hole on the wall under light switch	6/25/14	Administration Area	assit. prin. office	Carpentry
Washington Sr (2030) 1A	there is hole were a pipe was fixed last year that need to be repaired	3/18/14	Administration Area	in front by stairs	Carpentry
Washington Sr (2030) 1A	door closer broken	4/15/14	Administration Area	entrance door	Carpentry
Washington Sr (2030) 1A	from the leak in front office there are about 50 to 60 ceiling tiles need replaceing though out office and hallways	3/5/14	Administration Area	main office and hallway	Carpentry

Washington Sr (2030) 1A	ENTRANCE DOOR GYM-NOT LOCKING- WON'T BE ABLE TO SECURE-PLANT MGR HAWKINS 416-7240 KLR	9/9/13			Carpentry
Washington Sr (2030) 1A	MAIN ENTRANCE DOOR-NOT LOCKING- WON'T BE ABLE TO SECURE-SBE HAWKINS 416-7240 KLR	8/9/13			Carpentry
Washington Sr (2030) 1A	REAR ENTRANCE DOOR TO BLDG-NOT CLOSING ALL THE, WON'T BE ABLE TO SECURE-SBE HAWKINS 416-7240 KLR	8/12/13			Carpentry
Washington Sr (2030) 1A	MAIN FRONT DOOR CANT SECURE PLANT MGR- HAWKINS/416.7320	8/23/13			Carpentry
Washington Sr (2030) 1A	DOOR TO RM V252-IS JAMMED, CAN'T OPEN & DOOR TO V246-HANDLE IS DAMAGED, CAN OPEN FROM OUTSIDE, BUT CAN'T OPEN FROM INSIDE	9/18/13			Carpentry
Washington Sr (2030) 1A	requesting two boxes of ceiling tiles	12/18/13	Classroom	classrooms	Carpentry
Washington Sr (2030) 1A	build cage for cond. unit	9/30/13			Carpentry
Washington Sr (2030) 1A	Make guard for a/c	9/10/13			Carpentry

Washington Sr (2030) 1A	cut in gate on new cage	10/9/13				Carpentry
Washington Sr (2030) 1A	In room 142 requesting ceiling grid to be put in.	11/1/13				Carpentry
Washington Sr (2030) 1A	The fire door on the 2nd floor near room A-231 is broken off the hinges.	9/25/13	Hallway/Corridor	Main building		Carpentry
Washington Sr (2030) 1A	There is some missing ceiling tiles and grid in the front of this classroom.	8/8/13	2nd Floor	Room V234		Carpentry
Washington Sr (2030) 1A	There is missing ceiling grids and ceiling tile in room V234.	8/20/13	2nd Floor	Vocational Building		Carpentry
Washington Sr (2030) 1A	Repair ceiling grid,kitchen	5/22/14				Carpentry
Washington Sr (2030) 1A	Weld pump base	4/15/14				Carpentry
Washington Sr (2030) 1A	Remove & replace ceiling grid	4/15/14				Carpentry

Washington Sr (2030) 1A	When it rains water is leaking through the windows in the main office and the secretary office.	11/24/13	Administration Area	Main office	Carpentry
Washington Sr (2030) 1A	We need some wood strips installed in the gym to hang the school banners.	11/24/13	Gym		Carpentry
Washington Sr (2030) 1A	we need five trophy case built on the south wall by gym for display	5/6/14	1st Floor	southside gym entrance	Carpentry
Washington Sr (2030) 1A	The rubber padding on the backboards are torn and coming loose.	8/28/13	Basketball Court	Gymnasium	Carpentry
Washington Sr (2030) 1A	need pull blinds installed at two windows in band room	12/18/13	Classroom	band room	Carpentry
Washington Sr (2030) 1A	control wire for ah's	3/18/14			Electrical
Washington Sr (2030) 1A	Reset fire alarm panel. Scrobes have been disabled.	2/25/14			Electrical
Washington Sr (2030) 1A	vo tech boiler room --- dual water pump keeps tripping breaker	12/3/13			Electrical

Washington Sr (2030) 1A	Need 3 cases of 46807	10/16/13			Electrical
Washington Sr (2030) 1A	Check drives	11/14/13			Electrical
Washington Sr (2030) 1A	need S-1 locks on disconnects -- 2 outside by sbe ofc -- 1 on cooling tower	9/25/13			Electrical
Washington Sr (2030) 1A	two ventilation fans are not coming on in gym	5/5/14	Gym	gym	Electrical
Washington Sr (2030) 1A	the outlets in gym while in use trips breakers	2/14/14	Gym		Electrical
Washington Sr (2030) 1A	Lights are not coming on in the auditorium at all.	9/18/13	Auditorium		Electrical
Washington Sr (2030) 1A	light switch is broken there wires hanging out of switch in storage room were instruments are kept	12/18/13	Classroom	band room	Electrical
Washington Sr (2030) 1A	There are some lights on the outside of the gym and main building where the Principal and other staff park that are not coming on.	10/24/13			Electrical

Washington Sr (2030) 1A	In the auditorium there are 9 ceiling lights that are out we are asking if it is all possible can they be put up by or before the 14 of Nov .	11/5/13			Electrical
Washington Sr (2030) 1A	The wires are loose on pump #8 located in the boiler room in the gym basement, the ID# is 148-135.	1/30/14	Mechanical Room	Below the Gym	Electrical
Washington Sr (2030) 1A	The ceiling lights outside room V-144E will not come on after changing the bulbs.	1/24/14	Clinic	Vo Tech building	Electrical
Washington Sr (2030) 1A	The ceiling lights outside room v-144E blinks after changing the bulbs.	1/13/14	Clinic	Vocational building	Electrical
Washington Sr (2030) 1A	The ceiling lights in room V-144D are not coming on.	8/12/13	1st Floor	Vocational Building	Electrical
Washington Sr (2030) 1A	A/C IN LIBRARY-NOT COMING ON-PLANT MGR HAWKINS 416-7240 KLR	9/3/13			Electrical
Washington Sr (2030) 1A	The magnetic door closer is broken on the first set of doors on the first floor vocational building.	9/10/13			Electrical
Washington Sr (2030) 1A	AHU MAIN BLDG-NOT COMING ON-PLANT MGR SANDERS 416-7240 KLR	9/18/13			Electrical

Washington Sr (2030) 1A	CEILING UNIT NOT COMING ON IN RM-V238 PLANT MGR- HAWKINS/416.7240	8/23/13			Electrical
Washington Sr (2030) 1A	The receptacle in the kitchen that the hot boxes plug into has stop working.	8/26/13			Electrical
Washington Sr (2030) 1A	There are some lights in the stadium area near the restrooms and also inside the restrooms that are not coming on.	8/28/13		Stadium	Electrical
Washington Sr (2030) 1A	UNIT VENT IN RM A200 IS NOT COMING ON . SBE SANDERS 416-7240	8/2/13			Electrical
Washington Sr (2030) 1A	RECEPTACLE TO THE HOT BOX SPARKS FIRE WHEN U STICK SOMETHING IN IT. SBE HAWKINS 416-	8/2/13			Electrical
Washington Sr (2030) 1A	LIGHTS GYM REAR AREA & FRONT AREA- NOT COMING ON- THEY ARE HAVING A VOLLEYBALL TOURNAMENT TODAY-PLANT MGR HAWKINS 416 7240	10/1/13			Electrical
Washington Sr (2030) 1A	The electronic door access is not allowing the teachers badges to inter the building.	11/7/13			Electrical
Washington Sr (2030) 1A	Boiler room GB106 light fixture has a defect constantly blowing out light bulbs.	11/12/13			Electrical

Washington Sr (2030) 1A	There are some pole lights on the east side parking lot that are not coming on.	8/6/13	Parking Lot		Electrical
Washington Sr (2030) 1A	The ceiling lights in the gym lobby are not coming on.	10/15/13	Gym	Front entrance lobby	Electrical
Washington Sr (2030) 1A	There are some ceiling lights in room 108 and 202 that are not coming on after changing the bulbs.	4/29/14	Classroom	Main Building	Electrical
Washington Sr (2030) 1A	there are several outlets in the computer room	4/25/14	Classroom	room v 242	Electrical
Washington Sr (2030) 1A	There are several ceiling lights that are not coming on in this room.	7/29/13		Room V131	Electrical
Washington Sr (2030) 1A	I need 32w lamps for the entire building, about 5 cases, the inventory number is 46805.	7/31/13			Electrical
Washington Sr (2030) 1A	I need these light bulbs the ID numbers are MH175/U M57/E need 3ea. The other bulb number is C150S63/Retro Lux 150w need 3ea.	8/1/13			Electrical
Washington Sr (2030) 1A	There are several ceiling lights not coming on in room V133 and V248.	8/1/13		Vocational Building	Electrical

Washington Sr (2030) 1A	There are some ceiling lights in the ramp area that are not coming on.	8/21/13	Hallway/Corridor	Ramp Area	Electrical
Washington Sr (2030) 1A	The lights on the wall in the stairwell on the 2nd floor near the ramp are blinking after changing the bulbs. It's the south end stairwell.	1/13/14	Stairway	Vocational building	Electrical
Washington Sr (2030) 1A	Several ceiling lights in the kitchen are not coming on.	8/12/13	Kitchen		Electrical
Washington Sr (2030) 1A	there are several lights out around the gym	4/23/14	Grounds	lighting outside entire building	Electrical
Washington Sr (2030) 1A	there is a outlet that keep triping in this office	4/23/14	Administration Area	principal office	Electrical
Washington Sr (2030) 1A	light switch make static noise when turned on	2/14/14	Administration Area	mainn office	Electrical
Washington Sr (2030) 1A	main clock need setting for bells they are off by two min.	4/15/14	Administration Area	main office	Electrical
Washington Sr (2030) 1A	need electrical outlet near band room for metal detector	1/14/14	Administration Area	front foyer	Electrical

Washington Sr (2030) 1A	burning smell in main office per Mr. Sanders 416-9420	11/25/13			Electrical
Washington Sr (2030) 1A	UV NOT COMING ON IN RM-150. PLANT MGR-SANDERS/416.7240	2/26/14			Electrical
Washington Sr (2030) 1A	AHU VOC 2ND FLR RM 249 NE-NOT COMING ON-SBE SANDERS 416-7240 KLR	8/15/13			Electrical
Washington Sr (2030) 1A	PARTIAL RECEPTACLES HAVE NO POWER IN RM-136 PLANT MGR-HAWKINS/416.0086	9/13/13			Electrical
Washington Sr (2030) 1A	there several lights out around the main builging	4/23/14	Grounds	main building	Electrical
Washington Sr (2030) 1A	I need some 2 pin lamps, Biax the # is F13B/840, about 24 ea.	7/31/13	Administration Area		Electrical
Washington Sr (2030) 1A	All of the out side lights are out except about 3 or 4 all around the the school it is nearing basket ball season lights are out around the gum especially in the parking area	11/13/13			Electrical
Washington Sr (2030) 1A	About half of the ceiling lights in the Gym are not coming on.	9/25/13	Gym		Electrical

Washington Sr (2030) 1A	per ms powell 416-7420 the cooling tower and chiller are both down	4/14/14			Electrical
Washington Sr (2030) 1A	There are several ceiling lights in room V244 and V246 that are not coming on.	7/31/13	2nd Floor	Vocational Building	Electrical
Washington Sr (2030) 1A	light switch do not work have to use breaker to turn lights on	1/17/14	2nd Floor	cosmetology	Electrical
Washington Sr (2030) 1A	In student support V144 the receptale not working on the wall Ms Brown the parent cunselor works on.	10/16/13			Electrical
Washington Sr (2030) 1A	(2) CIRCULATING PUMPS BOILER RM- NOT COMING ON- PLANT MGR SANDERS 416-7240 KLR	12/9/13			Electrical
Washington Sr (2030) 1A	The lights in the stairwells near the auditorium are not coming on.	11/24/13		Stairwell	Electrical
Washington Sr (2030) 1A	FIRE ALARM SYSTEM- SHOWING TROUBLE- PLANT MGR POWELL 416-7240 KLR	1/10/14			Electrical
Washington Sr (2030) 1A	PUMP has come off the BASE in the CHILLER ROOM per Linda Powell, Plant Mgr. 416.7320	4/14/14			Electrical

Washington Sr (2030) 1A	LIGHTS ARE TRIPPING IN VOC BLDG HALL PLANT MGR- POWELL/416.7240	3/5/14			Electrical
Washington Sr (2030) 1A	(2) AHU'S AUDITORIUM AREA- BOTH NOT COMING ON-PLANT MGR POWELL 416-7420 KLR	5/27/14			Electrical
Washington Sr (2030) 1A	the number for the bulbs for work order 414844 is 46820	2/6/14	Restroom (Boys)	all restrooms	Electrical
Washington Sr (2030) 1A	repair lights on alumni wall	2/7/14	1st Floor	front hall	Electrical
Washington Sr (2030) 1A	chiller down	5/30/14			Electrical
Washington Sr (2030) 1A	check drives on AHU #5 & 6	4/23/14			Electrical
Washington Sr (2030) 1A	Room 216 has bad indoor fan motor per Steve French	5/16/14			Electrical
Washington Sr (2030) 1A	EMS panel needs #8 fuse	4/21/14			Electrical

Washington Sr (2030) 1A	FIRE ALARM - GOING OFF - SHOWING TROUBLE - PM/POWELL 416-7257	1/21/14			Electrical
Washington Sr (2030) 1A	I need some 32w lamps about 3 cases, the inventory number is 46805.	10/22/13			Electrical
Washington Sr (2030) 1A	I need 32w lamps for the entire building about 5 cases.	7/31/13			Electrical
Washington Sr (2030) 1A	need two boxes of slim lights for classrooms	1/14/14	Cafeteria	serving line	Electrical
Washington Sr (2030) 1A	need 20 bulbs for all restrooms	2/6/14	Restroom (Boys)	all restroom	Electrical
Washington Sr (2030) 1A	The cafeteria manage requesting a 110 receptacle to be put in the kitchen area.	10/30/13			Electrical
Washington Sr (2030) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	main building a/c not cooling per Ms. Hawkins 416-7240	10/14/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	boiler down	1/31/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	2nd floor vocational building entire floor blowing cold air per Ms. Powell 416-7420	12/10/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	vo tech --- rtu 1 & 2 not heating	12/11/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	boilers down	11/25/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	vo tech boiler down	11/18/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	fix busted coil	9/26/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chemical inventory at various locations	11/5/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	boilers down	11/12/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	c/o to heat	10/25/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	9/30/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Vo Tech Building not cooling per Mr. Sanders 416-9420	8/19/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	9/16/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	rm v132 fix freon leak	9/20/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	following rooms not cooling 200, 202, 204, 206, 216 per Ms. Hawkin 416-7240	8/13/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	8/14/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	8/26/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	V hall has no air per Ms. Hawkins 416-7240	8/27/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Rooms A200, A202, A204, A206 main building a/c not cooling per Ms. Hawkins 416- 7240	9/11/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	clean cond. coils on intelli pak units on vo tech roof	9/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - Air Cool Chillers-B.T. Washington High - Refer to PM schedule details.	4/7/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	A/C A HALL RMS 200, 202, 204, & 206-ALL NOT COOLING- PLANT MGR HAWKINS 416-7240 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	NEW A/C UNIT ON VOC BLDG-COILS HAVE FROZEN UP PER SBE-PLANT MGR HAWKINS 416-7240 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	AHU - V/T BLDG RMS 233-248 - ALL ARE BLOWING NOT COOLING - PM/HAWKINS 416- 7040	9/17/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	RTU NOT COOLING IN LIBRARY, & PARENT CTR. PLANT MGR- HAWKINS/416.7240	9/18/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	UV RMS 200, 204, 202, 206, & 210-ALL NOT COOLING- PLANT MGR HAWKINS 416-7240 KLR	8/22/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	UV RMS V233 &V235- BOTH NOT COOLING- PLANT MGR HAWKINS 41607240 KLR	8/23/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	UNIT VENT - MAIN BLDG V SIDE - (8)RMS - B SIDE AHU (5)RMS ALL ARE BLOWING BUT NOT COOLING - PM/HAWKINS 416- 7240	8/26/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER IS NOT COOLING THE ZBLDG. SBE HAWKINS 416-7240	8/5/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	A/C IN ENTIRE VOC BLDG-NOT COOLING- SBE SANDERS 416- 7240 KLR	8/5/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	10-CEILING UNITS NOT COOLING THRU V-HALL 1&2 FLRS PLANT MGR- HAWKINS/416.7240	8/6/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	FCU MAIN BLDG 2ND FLR RM 206-NOT COOLING-SBE SANDERS 416-7240 KLR	8/12/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	FCU MAIN BLDG 2ND FLR RM 206-NOT COOLING-SBE SANDERS 416-7240 KLR	8/12/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	UNTI VENT IN Z142 IS NOT COOLING. SBE SANDERS 416-7240	7/31/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	UV RM V132-NOT COOLING-SBE SANDERS 416-7240 KLR	8/20/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	A/C unit NOT COOLING in the CAFETERIA per Ms. Hawkins, Plant Mgr. 416.2740	10/2/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	PER SBE COILS ON A/C UNIT HAVE BURST IN RM V132 1ST FLR-FLOODING AREA PER SBE-PLANT MGR HAWKINS 416-7340	10/7/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	HEAT 2ND FLR-IS OVERHEATING-VERY HOT PER SBE-PLANT MGR HAWKINS 416-7240 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER - V/T BLDG - NOT COMING ON - PM/SANDERS 416-7240	8/20/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	UNIT NOT COOLING FOR ENTIRE 1ST FLR. PLANT MGR-SANDERS/416.7240	7/30/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Check McQuay chiller Will not start in morning.	6/18/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	6/20/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - BT WASHINGTON LVL 2 WATER TREATMENTS - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	4/25/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - BT WASHINGTON LVL 2 WATER TREATMENTS - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - BT WASHINGTON LVL 2 WATER TREATMENTS - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	2/14/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	1/17/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	5/9/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - BT WASHINGTON LVL 2 WATER TREATMENTS - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	WINDOW A/C UNIT RM GB02-NOT COMING ON-PLANT MGR HAWKINS 416- 7240 KLR	9/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	air comp. in votech.	10/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Rm V132 1st floor busted coil	10/8/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Drop old unit and Install new unit in rm 248????	11/1/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	cooling tower float	4/30/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	UNIT NOT COOLING PART OF VOC-TEC BLDG. PLANT MGR- POWELL/416.7240	5/22/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	UNIT IN RM Z130 & 131 IS NOT COOLING. SBE SANDERS 416- 7240	7/30/13	Cafetorium		Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	5-CEILING UNITS NOT COOLING IN RM- V142, B134,133,132,131 PLANT MGR- HAWKINS/416.7240	8/8/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	per ms powell 416- 7420 chiller is down	4/28/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	per ms powell 416- 7240 the gym boiler is blowing cold air	2/27/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	purchase unit for room 248	10/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER MECH RM- NOT COOLING- AFFECTS ENTIRE BLDG-PLANT MGR POWELL 416-7320 KLR	4/2/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	HEAT RM 108- OVERHEATING, TEMP IS 87 PER SBE-PLANT MGR HAWKINS 416- 7240 KLR	11/14/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	BOILER NOT COMING ON in the VOC. BUILDING, per Sanders, Plant Mgr. 416.7420	11/25/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	HEAT RM V238-OVERHEATING-TEMP IS 86-PLANT MGR POWELL 416-7240 KLR	1/14/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	V/T AREA 1ST & 2ND FLR - BLOWING NOT HEATING - PM/POWELL 416-7223	12/11/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	BOILER NOT COMING ON IN VOC TECH BLDG PLANT MGR- POWELL/416.7240	2/24/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER NOT COMING ON (113). SBE-SANDERS/416-9430	7/1/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER IS NOT COMING IN MAIN BLDG . SBE SANDERS 416-3240	7/2/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	BOILER-3 GYM MECH RM-NOT COMING ON-PLANT MGR POWELL 416-7240 KLR	3/26/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	UNIT VENTILATOR is NOT COOLING in ROOM 216 per Linda Powell, Plant Mgr. 416.7420	5/14/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	CHILLER AND COOLING TOWER IS NOT COMING ON- PM/POWELL 416-7230	4/21/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	A/C KITCHEN & CAFE DINING AREA-BOTH NOT COOLING- PLANT MGR POWELL 416-8600 KLR	4/8/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	A/C RM 213 & 216- BOTH NOT COOLING- PLANT MGR POWELL 416-7240 KLR	4/24/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER - MAIN BLDG -WON'T COME ON - PM/POWELL 416-7240	4/22/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	AHU - AUD - BLOWING NOT COOLING - PM/POWELL 416-7420	5/16/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER TO THE VO-TECH IS NOT COMING ON, SBE SANDERS 416-7240	7/22/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - Boiler#2 121 - BTW High -Boiler Room - Refer to PM schedule details.	8/5/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - Boiler 133 - BTW-Gym Basement Mech Rm - Refer to PM schedule details.	8/5/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	Monthly - Oil Lube & Belt-B.T.Washington Sr. - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Oil Lube & Belt-B.T.Washington Sr. - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Filter-B.T.Washington High - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Filter-B.T.Washington High - Refer to PM schedule details.	7/27/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Filter-B.T.Washington High - Refer to PM schedule details.	11/23/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - Cooling Towers B.T. Washington High - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Comp-Voc 2nd Flr Mech Rm-BTW Hi - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Compressor - Boiler Room - BTW Hi - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	Monthly - Air Comp- Gym Basement Mech Rm-BTW Hi - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Comp-2nd Flr Boiler Rm-BTW Hi - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Comp-Voc 2nd Flr Mech Rm-BTW Hi - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Compressor - Boiler Room - BTW Hi - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Comp- Gym Basement Mech Rm-BTW Hi - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - Air Comp-2nd Flr Boiler Rm-BTW Hi - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - Oil Samples- B.T. Washington High - Refer to PM schedule details.	9/23/13			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - Water-Cool Chiller Filter- Washington Sr - Refer to PM schedule details.	3/21/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	Yearly - Rod Chiller - Washington High - Refer to PM schedule details.	4/1/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	3/28/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	3/14/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Monthly - BT WASHINGTON LVL 2 WATER TREATMENTS - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Daily - B.T.Washinton High Level 1 Water Treatme - Refer to PM schedule details.	4/11/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	HEAT RM 231, 233, 234, & 235-ALL NOT HEATING-PLANT MGR POWELL 416-7240 KLR	3/6/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER MECH RM- NOT COMING ON- PLANT MGR POWELL 416-7420 KLR	5/27/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	COOLING TOWER- NOT COMING ON- PLANT MGR POWELL 416-7420 KLR	5/27/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	CHILLER MECH RM- NOT COMING ON- PLANT MGR POWELL 416-7420 KLR	5/29/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	A/C GYM AREA-NOT COOLING-PLANT MGR POWELL 416- 7420 KLR	5/5/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	RTU #2 not cooling	5/6/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	rm 213 making noise	5/6/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	rm 216 not cooling	5/6/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	5/7/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	vo tech not cooling	9/3/13			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	chiller down	6/10/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller --- check charge	6/13/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chemicals	5/29/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	6/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	chiller down	6/24/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	rod chiller	5/14/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	main bldg boiler	3/17/14			Heating/Ventilation /Air Conditioning

Washington Sr (2030) 1A	Yearly - Boiler 015 - BTW-Voc 2nd Flr N Mech Rm - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	Yearly - #1 Boiler 120 - BTW High - Boiler Rm - Refer to PM schedule details.	3/29/14			Heating/Ventilation /Air Conditioning
Washington Sr (2030) 1A	paint guards for A/C	10/29/13			Painting
Washington Sr (2030) 1A	Paint door to match	10/9/13			Painting
Washington Sr (2030) 1A	Paint expand metal for ac gage.	10/22/13			Painting
Washington Sr (2030) 1A	paint A/C cage	9/30/13			Painting
Washington Sr (2030) 1A	paint chips is falling from ceiling it is peeling all over	6/23/14	Gym	ceiling	Painting
Washington Sr (2030) 1A	GRAFFITI B/G RR'S VOC BLDG 1ST FLR ON STALLS, VOC 2ND FLR G RR ON STALLS, & B/G RR'S ACADEMY ON STALLS-PLANT MGR HAWKINS 446 7240	10/15/13			Painting

Washington Sr (2030) 1A	Winterize stadium	12/17/13			Plumbing
Washington Sr (2030) 1A	Assist MLGW turn gas off	2/17/14			Plumbing
Washington Sr (2030) 1A	garbage disposal stopped up per Mr. Sanders 416-7240	11/22/13			Plumbing
Washington Sr (2030) 1A	Test and report on backflow prevention devices.	4/11/14			Plumbing
Washington Sr (2030) 1A	toilet stop up over flowing	6/25/14	Auditorium	restroom on the stage	Plumbing
Washington Sr (2030) 1A	The girls restroom in the stage area is stopped up.	11/20/13	Auditorium		Plumbing
Washington Sr (2030) 1A	On the second floor in the vocational building the girls restroom one of the toilets is stopped up the restroom cross in front of the computer lab.	10/24/13			Plumbing
Washington Sr (2030) 1A	NO HOT WATER IN RM-V246. PLANT MGR-HAWKINS/416.7240	10/30/13			Plumbing

Washington Sr (2030) 1A	the three sink station is leaking from bottom	1/16/14	Cafeteria	kitchen	Plumbing
Washington Sr (2030) 1A	the mop sink in the back by door will not drain	3/31/14	Cafeteria	kitchen	Plumbing
Washington Sr (2030) 1A	There is a busted pipe in the boiler room below the kitchen.	1/30/14	Mechanical Room	Below the kitchen	Plumbing
Washington Sr (2030) 1A	The toilet seat is broken and water leaks from the pipe on the back of the commode when it's flushed, the restroom is inside of room V-132.	1/15/14	Restroom (Girls)	Vo-Tech building	Plumbing
Washington Sr (2030) 1A	sink floor detached from wall	6/30/14	Restroom (Girls)	vo-tech 2nd floor	Plumbing
Washington Sr (2030) 1A	sink leaking from the bottom	6/30/14	Restroom (Boys)	9th grade 2nd floor	Plumbing
Washington Sr (2030) 1A	toilet seat broke	6/30/14	Restroom (Boys)	mens restroom 2nd floor vo-tech	Plumbing
Washington Sr (2030) 1A	there several toilets that will not flush	6/30/14	Restroom (Boys)	allrestrooms	Plumbing

Washington Sr (2030) 1A	There is a leaking faucet in this room.	8/8/13	2nd Floor	Room V234	Plumbing
Washington Sr (2030) 1A	the shampoo sinks 4 and 6 are stopped up	1/28/14	2nd Floor	cosmetology	Plumbing
Washington Sr (2030) 1A	faucet leaking in the first sink in classroom	1/23/14	2nd Floor	v-230	Plumbing
Washington Sr (2030) 1A	shampoo sink one and five are draining very so	1/23/14	2nd Floor	v-244 cosmetology	Plumbing
Washington Sr (2030) 1A	The water pressure is low in some of the restroom sinks.	8/28/13		Stadium	Plumbing
Washington Sr (2030) 1A	CEILING UNIT OIL IS LEAKING OUT WITH A FUME SMELL IN RM-V132. PLANT MGR-HAWKINS/416.0086	9/18/13			Plumbing
Washington Sr (2030) 1A	NO HOT WATER IN THE KITCHEN SBE HAWKINS 416-	8/2/13			Plumbing
Washington Sr (2030) 1A	flush valve sticking will not flush	6/23/14	Classroom	room v-231	Plumbing

Washington Sr (2030) 1A	The drain pipes under the middle sink is leaking water in the science lab.	4/9/14	Classroom	Room V136	Plumbing
Washington Sr (2030) 1A	theres no hot water to shampoo bowls in classrom	3/18/14	Classroom	cosmetology	Plumbing
Washington Sr (2030) 1A	there is no hot water in classromm	3/27/14	Classroom	nutrition and food room 230	Plumbing
Washington Sr (2030) 1A	shampoo bowls 1 and 7 are dranng very slow	3/27/14	Classroom	cosmetology	Plumbing
Washington Sr (2030) 1A	there is a leak in one of the sinks in the far right corner of classroom	4/8/14	Classroom	room- v-136	Plumbing
Washington Sr (2030) 1A	UNIT IS LEAKING WATER IN RM-246 PLANT MGR- HAWKINS/416.0086	9/13/13			Plumbing
Washington Sr (2030) 1A	UNIT IN RM B224 IS LEAKING. SBE HAWKINS 416-	7/16/13			Plumbing
Washington Sr (2030) 1A	UNIT VENT IN RM 248 IS LEAKING. SBE SANDERS 416-7240	8/2/13			Plumbing

Washington Sr (2030) 1A	Install A/C unit	11/1/13			Plumbing
Washington Sr (2030) 1A	chemical treatment PVC coupling busted	5/28/14			Plumbing
Washington Sr (2030) 1A	TOILET PIPE IS RUNNING WATER IN B/LOCKER BASEMENT PLANT MGR- POWELL/619.1515	6/5/14			Plumbing
Washington Sr (2030) 1A	There is a water leak near the front entrance.	8/20/13		Main Entrance	Plumbing
Washington Sr (2030) 1A	The flush valve handle does not stop the water from running on the commode in the 2nd stall in the restroom near the auditorium.	1/30/14	Restroom (Girls)		Plumbing
Washington Sr (2030) 1A	The faucet on the 1st sink in the food lab does not turn the water off completely.	1/16/14	2nd Floor	Vo-Tech building room V-230	Plumbing
Washington Sr (2030) 1A	check strainer on cond. pump	5/7/14			Plumbing
Washington Sr (2030) 1A	toilet leaking from flush valve	1/17/14	1st Floor	sped classroom	Plumbing

Washington Sr (2030) 1A	Test and report on backflow prevention devices.	4/22/14				Plumbing
Washington Sr (2030) 1A	Test and report on backflow prevention devices.	7/5/13				Plumbing
Washington Sr (2030) 1A	There is a water leak above the stage in the back north corner.	8/12/13	Auditorium			Roof
Washington Sr (2030) 1A	theres a leak in the entrance to classroom	2/6/14	2nd Floor	v-237		Roof
Washington Sr (2030) 1A	water pouring from ceiling near teachers work room in corner	2/4/14	2nd Floor	near teachers work room		Roof
Washington Sr (2030) 1A	leaking from ceiling near room 214	2/4/14	2nd Floor	9th grade hall		Roof
Washington Sr (2030) 1A	We have a very bad roof leak on the second floor in front of the boys restroom, when it rain it floods the the floor.	9/30/13				Roof
Washington Sr (2030) 1A	There is water leaking from the ceiling in the GYM on the south side near the middle doors and also on the 2nd floor at room A208 and the double doors.	7/23/13	Gym			Roof

Washington Sr (2030) 1A	there aleak near window in band room and another inthe storage room were instruments are kept	12/18/13	Classroom	band room	Roof
Washington Sr (2030) 1A	there is leak coming from sealing to your right when entering door	4/28/14	Classroom	room v 235	Roof
Washington Sr (2030) 1A	there several leaks on second floor near room 202 204	4/28/14	Hallway/Corridor	2nd floor main building	Roof
Washington Sr (2030) 1A	there is major leak in the main office every time it rains it pours in and the hall next to office it is affecting the electrical outlets and switches in office	3/3/14	Administration Area	main office	Roof
Washington Sr (2030) 1A	When it rains there is a water leak from the ceiling at room A208 and the double doors, it also comes down the wall.	9/24/13	2nd Floor	Main building	Roof
Washington Sr (2030) 1A	When it rains water leaks from the ceiling in the hallway near room v233.	11/24/13	2nd Floor	vocational building	Roof
Washington Sr (2030) 1A	there a leak as soon emter in office to your left	2/4/14	Administration Area	front office	Roof
Washington Sr (2030) 1A	there are multiple leaks in the main office	2/4/14	Administration Area	front office	Roof

Washington Sr (2030) 1A	Check duct work votech building 2nd floor	11/27/13			Sheet Metal
Washington Sr (2030) 1A	install A/C unit	11/1/13			Sheet Metal
Washington Sr (2030) 1A	The main building second floor we have some lockers broken an others just cant get open	11/7/13			Sheet Metal
Washington Sr (2030) 1A	The first floor of the vocation building there are also lockers that are broken and some just want open as well.	11/7/13			Sheet Metal
Washington Sr (2030) 1A	Top of roof stack is missing on gym north east front side.	8/12/13	Gym	Roof	Sheet Metal
Washington Sr (2030) 1A	Requesting assistants to help reset locker combinations.	11/7/13			Sheet Metal

Count of Craft	Craft				
Location	Carpentry	Electrical	Painting	Plumbing	Grand Total
Washington Stadium 186-1A	2	2	8	4	16
Grand Total	2	2	8	4	16

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Washington Stadium 186-1A	need metal strip at bottom of door water flows in when rain	4/14/14	Athletic Field	boys locker room	Carpentry
Washington Stadium 186-1A	closer is broken at the top of door	4/15/14	Cafeteria	entrance door	Carpentry
Washington Stadium 186-1A	five lights around the visitor bleachers are out. Lights are too high for the stadium worker to reach on ladder, please assist in changing out lights	8/26/13	Athletic Field		Electrical
Washington Stadium 186-1A	the lights are not working in this office have check breakers	4/14/14	Administration Area	coach office	Electrical
Washington Stadium 186-1A	paint lines on football field	8/26/13			Painting
Washington Stadium 186-1A	paint lines on football field	9/4/13			Painting
Washington Stadium 186-1A	paint lines on football field	9/9/13			Painting

Washington Stadium 186-1A	paint lines on football field	9/16/13			Painting
Washington Stadium 186-1A	paint lines on football field	9/30/13			Painting
Washington Stadium 186-1A	paint lines on football field	10/7/13			Painting
Washington Stadium 186-1A	paint lines on football field	10/21/13			Painting
Washington Stadium 186-1A	paint lines on football field	8/12/13			Painting
Washington Stadium 186-1A	sprinklers are not functioning properly. water seems to be flooding the field, please assist	6/24/14	Athletic Field		Plumbing
Washington Stadium 186-1A	Need the sprinkler system cut back on for field repairs and prep for football season. Also need the plumber to check and make sure all sprinkler heads are working properly, thanks	4/10/14	Athletic Field		Plumbing
Washington Stadium 186-1A	some of the sinks in the women's restroom, homeside (pressbox) are not working, please check	8/26/13	Athletic Field		Plumbing

Washington Stadium 186-1A	Turn on water to sprinkler system, check all zones, and make needed sprinkler head repairs, thanks	5/22/14	Athletic Field		Plumbing
---------------------------	--	---------	----------------	--	----------

Count of Craft	Craft								
Location	Cabling	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Wells Academy (2353) 1A	2	17	45	36	3	43	1	4	151
Grand Total	2	17	45	36	3	43	1	4	151

Location	Request Description	Submittal Date	Area	Description	Area Number	Craft
Wells Academy (2353) 1A	this request is from Dorren Ball. We need a site survey to be done for 2nd floor area that will be in use this year. Plant manager has checked rooms and all rooms have computer drops, 6 electrical sockets around rooms, and 2 access points in rooms 205 and 202	6/2/14				Cabling
Wells Academy (2353) 1A	Please come out and repair network port 103b-station 5	3/27/14	1st Floor	103		Cabling
Wells Academy (2353) 1A	Please come out and repair doors to these classrooms.	6/10/14	2nd Floor	201,202,203,204,&205		Carpentry
Wells Academy (2353) 1A	Adjust door closers	5/30/14				Carpentry
Wells Academy (2353) 1A	Replace stall doors	5/30/14				Carpentry
Wells Academy (2353) 1A	Please come out and replace 4ft section of tile in main office	5/30/14	1st Floor	MAIN OFFICE (records room)		Carpentry
Wells Academy (2353) 1A	The entrance/exit gate around the playing field needs replacing. Gate is tearing up and hard to close and secure	6/9/14	Athletic Field	fence located on Clack St.		Carpentry

Wells Academy (2353) 1A	Please come out and place 4 ft bulletin boards in this room. 2 total bulletin boards required . Thanks	7/15/13	1st Floor	Science room	Carpentry
Wells Academy (2353) 1A	Please come out and place petition wall in this room.	7/17/13	Annex	105 Science room	Carpentry
Wells Academy (2353) 1A	Fabricate locker base	7/29/13			Carpentry
Wells Academy (2353) 1A	Please come out and install whiteboard in this room	8/1/13	1st Floor	115	Carpentry
Wells Academy (2353) 1A	Please come out and replace door handles on door. Need new handles. Old door handles are stripped out	8/28/13	1st Floor	102 Science room	Carpentry
Wells Academy (2353) 1A	Please come out and replace two peices of floor tile that came up. Also replace wall tile by wash sink next to boys restroom.	10/30/13	1st Floor	Boys restroom	Carpentry
Wells Academy (2353) 1A	ATTENTION!! Mr. Hurdle please send me 3 boxes of soft ceiling tile for Ida B. Wells .	12/10/13	1st Floor		Carpentry
Wells Academy (2353) 1A	Please place covebase around newly installed lockers on this hallway.	12/11/13	1st Floor		Carpentry

Wells Academy (2353) 1A	Please come out and encase lockers.	12/13/13	1st Floor	annex hallway	Carpentry
Wells Academy (2353) 1A	SW ENTRANCE DOOR BY CAFE- ALIGNMENT IS OFF-DOOR NOT SECURING PROPERLY-PLANT MGR MAYS 416-2858 KLR	1/10/14			Carpentry
Wells Academy (2353) 1A	Please replace door handle on this door. Old handle is stripped out	1/23/14	1st Floor	101	Carpentry
Wells Academy (2353) 1A	DOOR TO RM 101-COMING OFF HINGES- PLANT MGR MAYS 416-2858 KLR	4/1/14			Carpentry
Wells Academy (2353) 1A	Check a/c second floor west side of building	6/12/14			Electrical
Wells Academy (2353) 1A	CHILLER MECH RM-NOT COMING ON- PLANT MGR MAYS 416-9430 KLR	6/9/14			Electrical
Wells Academy (2353) 1A	6-BALLAST HAVE NO POWER IN RM-103 PLANT MGR-MAYES/643.1734	4/28/14			Electrical
Wells Academy (2353) 1A	Secure conduit to wall	4/29/14			Electrical

Wells Academy (2353) 1A	per mr mays 416-2854 room 113 there are 4 fixtures lights are out and room 106 there are 5 fixtures lights are out having TCAP testing	4/29/14			Electrical
Wells Academy (2353) 1A	Please come out and repair bad ballast in main office	7/10/13	2nd Floor	main office	Electrical
Wells Academy (2353) 1A	Please come out and replace bad ballast in main hallway also upstairs in Admin office.	7/17/13	1st Floor	main hall	Electrical
Wells Academy (2353) 1A	Please repair bad ballast in this office	4/9/14	2nd Floor	main office	Electrical
Wells Academy (2353) 1A	Check building for power outage	4/14/14			Electrical
Wells Academy (2353) 1A	Replace motor for condenser pump	4/14/14			Electrical
Wells Academy (2353) 1A	west wall in this room has no power. Please repair. Room 105	4/15/14		105	Electrical
Wells Academy (2353) 1A	Please come out and sync school clock with school's bell.	4/17/14			Electrical

Wells Academy (2353) 1A	Tom, per our conversation on Thursday. Please reset bell, power was out and bell are not on right time.	4/17/14			Electrical
Wells Academy (2353) 1A	Please send 5 cases of Flr rapid start bulbs. the stock number is 46807	8/1/13		1st & 2nd floors	Electrical
Wells Academy (2353) 1A	Please come out and set main clock to meet NEW school time	8/5/13	1st Floor	main office	Electrical
Wells Academy (2353) 1A	FCU 1ST FLR RM 101 (104)-SMOKING AND MAKING NOISES-SBE MAYS 416-2858 KLR	8/9/13			Electrical
Wells Academy (2353) 1A	Mrs Sales(DIRECTOR) of charter schools has at least 3 ballast that are out in this roomand room is very dark. Please come out ASAP!! Thanks	8/9/13	2nd Floor	212	Electrical
Wells Academy (2353) 1A	FCU 1ST FLR A/V RM SOUTH & FCU 1ST FLR A/V RM NORTH-BOTH MAKING NOISES-SBE MAYS 416-2854 KLR	8/15/13			Electrical
Wells Academy (2353) 1A	Seven lights are burning with just 1 or 2 light bulbs, and 4 have bad ballast.	8/27/13	Classroom	1st. Flr. 114	Electrical
Wells Academy (2353) 1A	Please replace bad ballast in this room.	8/28/13	1st Floor	114	Electrical

Wells Academy (2353) 1A	Please replace ballast in this light fixture. AREA directly in front of Guidance office	8/29/13	Hallway/Corridor	by main office	Electrical
Wells Academy (2353) 1A	Please come out and replace bad ballast in these rooms.	9/9/13	1st Floor	102 and 103	Electrical
Wells Academy (2353) 1A	Please come out and replace bad ballast in this room	10/7/13	1st Floor	108	Electrical
Wells Academy (2353) 1A	Please replace bad ballast in hallway in front of room 113	10/7/13	1st Floor	in front of room 113	Electrical
Wells Academy (2353) 1A	Please replace bad ballast in several fixtures located in this area. See Plant manager	10/30/13	1st Floor	by cafeteria on east side of cafe	Electrical
Wells Academy (2353) 1A	please come out and replace several bad ballast that are out in this area.	11/6/13	2nd Floor	hallway	Electrical
Wells Academy (2353) 1A	Please replace bad ballast in this room	11/6/13	1st Floor	101	Electrical
Wells Academy (2353) 1A	Please come out and replace bad bulbs. Very dark when staff gets back from games etc... Principal's request	11/6/13	Parking Lot	parking lot lights	Electrical

Wells Academy (2353) 1A	Please come out and adjust lights on poles in parking lot(3). Very dark in the evening and lights to come on around 5:30 am and pm. Principal's request	11/13/13	Parking Lot	Lightpoles	Electrical
Wells Academy (2353) 1A	Please deliver 3 boxes of lights to this location . These are the light tubes for the classroom. T-8 . 4 foot tubes.	11/13/13		1st and 2nd floors	Electrical
Wells Academy (2353) 1A	Several lights fixtures have bad ballast in them . Please come out and replace.	11/13/13	2nd Floor	entire hallway	Electrical
Wells Academy (2353) 1A	Several fixtures have bad ballast or blown lights over entire cafeteria. Small lift is required to change lights.	11/13/13	Cafeteria	and stairwell landing next to cafeteria	Electrical
Wells Academy (2353) 1A	Please come out and replace bad balast in this room	11/19/13	1st Floor	LEC (Nurse's office) in library	Electrical
Wells Academy (2353) 1A	1ST FLR HAS A BURNING SMELL COMING THRU VENTS IN MAIN OFC PER SBE, CAN'T LOCATE WHERE IT'S COMING FROM-PLANT MGR MAYS 416-2858 KLR	11/20/13			Electrical
Wells Academy (2353) 1A	Please replace bad ballast in this light fixture. Light fixture is located right outside of Professional Growth Room.	11/22/13	1st Floor	hallway by main office	Electrical
Wells Academy (2353) 1A	no power to chemical treatment controller	12/5/13			Electrical

Wells Academy (2353) 1A	Please come out and replace bad ballast in these light fixtures .	1/8/14	1st Floor	main hallway by main office and bookroom by Rm.108	Electrical
Wells Academy (2353) 1A	Several ballast are out in this room. Half or room is dark due to bad ballast. Please replace	2/3/14		108	Electrical
Wells Academy (2353) 1A	per mr mays 416-2858 room 206 upstairs the AHU is not running and has burning smell	2/18/14			Electrical
Wells Academy (2353) 1A	Please come out and replace bad ballast in these rooms. 101-- row of lights out 102--(4) ballast are out in this room 113--(1) ballast 116 --(2) ballast are out mechanical room-- (2) are out	3/17/14	Classroom	101, 113,115,102,& 116	Electrical
Wells Academy (2353) 1A	Please come out and repair bad ballast in cafeteria.	3/19/14	1st Floor	cafeteria	Electrical
Wells Academy (2353) 1A	Please come out and replace blown light in this stairwell. Also there is a spotlight that is out over stage in cafeteria that needs to be replaced.	3/19/14	1st Floor	lobby stairwell	Electrical
Wells Academy (2353) 1A	2 sockets in this room are making a whistling sound. please replace	3/19/14	1st Floor	116	Electrical
Wells Academy (2353) 1A	Please deliver 3 boxes of classroom lights.	4/2/14			Electrical

Wells Academy (2353) 1A	Please deliver 5 cases (25 light bulbs per case) of lights to Ida B Wells.	7/31/13			Electrical
Wells Academy (2353) 1A	Monthly - IDA B WELLS LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Provide and install controller for chemical treatment for cooling tower.	5/22/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	5/25/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	6/8/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Reset chiller	6/10/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	cooling tower --- gear oil	6/10/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - IDA B WELLS LVL 2 WATER TREATMENT - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning

Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	5/11/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - Filter-Ida B. Wells Academy - Refer to PM schedule details.	7/21/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - IDA B WELLS LVL 2 WATER TREATMENT - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	4/13/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - Oil Lube & Belt - Ida B Wells Academy - Refer to PM schedule details.	8/24/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	change filter in alternative office upstairs	9/12/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Yearly - Oil Samples-Ida B. Wells Academy - Refer to PM schedule details.	9/24/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	c/o to heat	10/18/13			Heating/Ventilation /Air Conditioning

Wells Academy (2353) 1A	Princ. ofc closet --- return fire damper is closed	11/20/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - Filter-Ida B. Wells Academy - Refer to PM schedule details.	11/24/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	boiler down	11/25/13			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	boiler down	1/2/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	pilot out on boiler per Mr. Mays 416-2858	1/2/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	HEAT RMS 106 & 108-BOTH NOT HEATING-PLANT MGR MAYS 416-2858 KLR	1/6/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	per Mr Mays 416-2858 rooms 106, professional growth room (same hall as main office), rooms 206 and 208 all blowing cold air	1/7/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	1/19/14			Heating/Ventilation /Air Conditioning

Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	2/2/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	2/16/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - IDA B WELLS LVL 2 WATER TREATMENT - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	3/2/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	3/16/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Monthly - Oil Lube & Belt - Ida B Wells Academy - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Yearly - Rod Chiller - Ida B. Wells Academy - Refer to PM schedule details.	3/22/14			Heating/Ventilation /Air Conditioning

Wells Academy (2353) 1A	Monthly - Filter-Ida B. Wells Academy - Refer to PM schedule details.	3/23/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Yearly - WaterCoolChiller Filter-Ida B Wells Acad - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	3/30/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Yearly - Cooling Towers - Ida B. Wells Academy - Refer to PM schedule details.	4/1/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	Daily - Ida B. Wells Level 1 Water Treatment - Refer to PM schedule details.	4/27/14			Heating/Ventilation /Air Conditioning
Wells Academy (2353) 1A	paint restrooms by cafe	6/10/14			Painting
Wells Academy (2353) 1A	Paint stall doors	6/13/14			Painting
Wells Academy (2353) 1A	Paint locker tops	12/17/13			Painting

Wells Academy (2353) 1A	TOILET PIPE IS RUNNING WATER IN B/RR 1ST FLR PLANT MGR-MAYES/643.1734	5/14/14			Plumbing
Wells Academy (2353) 1A	Please come out and repair pipe . Pipe has hole in it . 1st urinal.	5/20/14	1st Floor	boys restroom	Plumbing
Wells Academy (2353) 1A	please repair leak from this fountain.water is constantly dripping	5/20/14	1st Floor	next to library	Plumbing
Wells Academy (2353) 1A	UNIT IS FLOODING IN GUIDANCE OFFICE. PLANT MGR-MAYES/416.7854	7/29/13			Plumbing
Wells Academy (2353) 1A	Repair cooling tower line	4/3/14			Plumbing
Wells Academy (2353) 1A	STEAM TABLE in the CAFETERIA (PILOT WILL NOT STAY LIT & THERE'S LOUD GAS SMELL) per Anthony Mays, Plant Mgr. 416.2858	4/10/14			Plumbing
Wells Academy (2353) 1A	Test and report on backflow prevention devices.	4/11/14			Plumbing
Wells Academy (2353) 1A	Test and report on backflow prevention devices.	4/22/14			Plumbing

Wells Academy (2353) 1A	UNIT IS LEAKING WATER IN GUIDANCE OFFICE 1ST FLR PLANT MGR-MAYES/643.1734	4/22/14			Plumbing
Wells Academy (2353) 1A	GAS SMELL IN BOILER RM-PLANT MGR MAYS 416-2858 KLR	4/23/14			Plumbing
Wells Academy (2353) 1A	Toilet in 2nd stall is leaking large amounts of water every time toilet is flushed. Please repair	7/31/13	1st Floor	Girls restroom	Plumbing
Wells Academy (2353) 1A	Please replace toilet seat in this restroom.	7/31/13	2nd Floor	Employee restroom	Plumbing
Wells Academy (2353) 1A	Please come out and adjust water pressure in this sink. While stepping on lever to wash hand, water is shooting out and getting people wet.	8/1/13	2nd Floor	boys restroom	Plumbing
Wells Academy (2353) 1A	Air Handler unit leaking in Room 105 per Anthony Mays, Plant Mgr. 901.416.2858.	8/7/13			Plumbing
Wells Academy (2353) 1A	FCU 2ND FLR RM 201-LEAKING-SBE MAYS 416-2858 KLR	8/8/13			Plumbing
Wells Academy (2353) 1A	Please unstop drinking fountain by the main office on the 2nd floor.	8/9/13	2nd Floor	hallway by main office	Plumbing

Wells Academy (2353) 1A	AHU CAFE HALLWAY-LEAKING-PLANT MGR MAYS 416-2858 KLR	8/21/13			Plumbing
Wells Academy (2353) 1A	AHU RM 114-LEAKING-PLANT MGR MAYS 416-2858 KLR	8/22/13			Plumbing
Wells Academy (2353) 1A	Please remove towel that accidently fell into mop sink.	8/23/13	1st Floor	boiler room	Plumbing
Wells Academy (2353) 1A	AHU IS LEAKING WATER IN RM-114. PLANT MGR-MAYES/416.7854	8/28/13			Plumbing
Wells Academy (2353) 1A	2-AHU ARE LEAKING WATER IN RM-114, CAFE. PLANT MGR-MAYES/643.1734	9/3/13			Plumbing
Wells Academy (2353) 1A	Please unstop floor drain besides loop pump	9/5/13	1st Floor	mechanical room	Plumbing
Wells Academy (2353) 1A	Please come out and adjust packing on loop pump	9/5/13	1st Floor	mechanical room	Plumbing
Wells Academy (2353) 1A	A/C ALTERNATIVE OFC LEAKING & ITS GOING DOWN INTO PRIN'S OFC PER SBE & GUIDANCE OFC-LEAKING-PLANT MGR MAYS 416-7854 KLR	9/12/13			Plumbing

Wells Academy (2353) 1A	FLUSH HANDLE ON COMMODE B RR 1ST FLR 3RD STALL-CONSTANTLY LEAKING AND WHEN FLUSHED WATER SHOOTS OUT PER SBE-PLANT MGR MAYS 416-2858 KLR	9/30/13			Plumbing
Wells Academy (2353) 1A	Please come out and repair leak . Water is coming from handle everytime toilet is flushed	10/2/13	1st Floor	boys restroom	Plumbing
Wells Academy (2353) 1A	Please come out and unstop this toilet in 2nd stall.	10/2/13	2nd Floor	ladies restroom	Plumbing
Wells Academy (2353) 1A	Water is leaking from pipe under wash sink.	10/2/13	Cafeteria		Plumbing
Wells Academy (2353) 1A	Please come out and repair flush handle on toilet in 2nd stall of boys restroom.	10/22/13	1st Floor	Boys restroom	Plumbing
Wells Academy (2353) 1A	Please come out and unstop sink in this restroom. Clogged up in pipes	10/23/13	1st Floor	Teachers Lounge (ladies restroom)	Plumbing
Wells Academy (2353) 1A	Please come and replace flush valve on 2nd toilet	10/30/13	Restroom (Boys)	next to Plant manager's office on 6th grade hall	Plumbing
Wells Academy (2353) 1A	Please come out and unstop drain located in this closet	10/31/13	2nd Floor	custodial closet by mens restroom	Plumbing

Wells Academy (2353) 1A	Please come out and repair handle on water fountain.	10/31/13	1st Floor	water fountain by main office	Plumbing
Wells Academy (2353) 1A	water leaks from sink and water doesn't drain properly	10/31/13	Cafeteria	wash sink in cooking area	Plumbing
Wells Academy (2353) 1A	COMMODE B RR 1ST FLR-PIPE HAS BEEN KICKED LOOSE AND IT'S LEAKING, CAN'T CONTAIN-PLANT MGR MAYS 416-2858 KLR	11/5/13			Plumbing
Wells Academy (2353) 1A	2nd toilet is leaking from o ring.	11/6/13	1st Floor	boys restroom	Plumbing
Wells Academy (2353) 1A	please come out and replace bad handle on toilet and on urinal	11/20/13	1st Floor	boys restroom	Plumbing
Wells Academy (2353) 1A	Please unstop drain in this bathroom. (Floor Drain)	11/20/13	1st Floor	girls restroom	Plumbing
Wells Academy (2353) 1A	per Mr Mayes 416-2858 there is no hot water in the kitchen/cafeteria	1/28/14			Plumbing
Wells Academy (2353) 1A	per mr mays 416-2858 boys restroom 1st floor toilet is flooding	1/29/14			Plumbing

Wells Academy (2353) 1A	HOT WTR TANK - HAS NO HOT WTR IN THE CAFE - PM/MAYS 416-2858	2/26/14			Plumbing
Wells Academy (2353) 1A	FLR DRAIN IS STOPPED UP BY STOVE & 2-COM SINK IS STOPPED UP KITCHEN PLANT MGR-MAYS/643.1734	2/28/14			Plumbing
Wells Academy (2353) 1A	Please come out and unstop water fountain by office on 2nd floor. Plant manager tried to unstop with plunger but sink is still stopped up.	3/19/14	2nd Floor		Plumbing
Wells Academy (2353) 1A	Please come out and check roof for leaks .	12/13/13	2nd Floor	rooftop over 2nd floor	Roof
Wells Academy (2353) 1A	Please come out and repair metal on AHU in this restroom (Women) restroom. Door not closing at bottom of unit	4/30/14	1st Floor	bathrooms adjacent to cafeteria.	Sheet Metal
Wells Academy (2353) 1A	Install locker	8/14/13			Sheet Metal
Wells Academy (2353) 1A	We have lockers in this hallway that wont open at all and the principal wants all lockers to be working. Lockers numbers are 129--139--159--205--219. Please repair these lockers..	8/16/13	1st Floor	annex hall by cafeteria	Sheet Metal
Wells Academy (2353) 1A	Please come out and repair these lockers. Numbers to lockers are 115, 179, 144, 218. and # 21.	8/23/13		Locker area by cafeteria	Sheet Metal

Count of Craft	Craft						
Location	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Grand Total
Westside EI (2750) 1B	18	49	51	1	53	3	175
Grand Total	18	49	51	1	53	3	175

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Westside EI (2750) 1B	the outside roof over the cafe. has a hole in it bees are coming in THIS IS NOT ROOFING WORK	6/12/14	Cafeteria	cafe. outside	Carpentry
Westside EI (2750) 1B	ENTRANCE DOOR 2-STORY BLDG- NOT CLOSING ALL THE WAY-WON'T BE ABLE TO SECURE-PLANT MGR HUBBARD 416-3725 KLR	6/19/14			Carpentry
Westside EI (2750) 1B	floor towel is badley damage cause of water damage floor is buckeling bad	6/4/14	1st Floor	main	Carpentry
Westside EI (2750) 1B	gate is broken from outside wall	11/13/13	Grounds	south west	Carpentry
Westside EI (2750) 1B	need chork stripes mounted onwall by each classroom doors [20}	11/22/13	Hallway/Corridor	2 story	Carpentry
Westside EI (2750) 1B	need chorkboard and white board 8ft both	1/9/14	Annex	music rm.	Carpentry
Westside EI (2750) 1B	door is off hinges	3/26/14	Classroom	rm.106	Carpentry
Westside EI (2750) 1B	fence is down need to be put back up.	4/14/14	Grounds	northwest side	Carpentry
Westside EI (2750) 1B	WINDOW G RR 1ST FLR 2-STORY BLDG-IS JAMMED. WON'T COME DOWN-WILL NOT BE ABLE TO SECURE BLDG-PLANT MGR HUBBARD 416-3725 KLR	4/25/14			Carpentry
Westside EI (2750) 1B	door will not close rm 108	4/29/14	1st Floor	main hall	Carpentry

Westside EI (2750) 1B	white board [2]	8/7/13	Classroom	139	Carpentry
Westside EI (2750) 1B	white board need to be aad to class room [6]	8/14/13	Classroom	annex	Carpentry
Westside EI (2750) 1B	Need repair all 5 Stalls with doors, need Slide Latches that locks from the inside due to privacy.	9/6/13	Restroom (Girls)	3rd Floor	Carpentry
Westside EI (2750) 1B	floor tile is coming up.	9/17/13	Administration Area	main office	Carpentry
Westside EI (2750) 1B	need srcews to mount poster board in walls	1/29/14	Annex	2 story	Carpentry
Westside EI (2750) 1B	door will not lock handle is broken	2/6/14	Classroom	104 rm.	Carpentry
Westside EI (2750) 1B	floor tile is coming up in 4 places	2/13/14	Classroom	128 rm.	Carpentry
Westside EI (2750) 1B	need 4ft strip board	1/9/14	1st Floor	2 story	Carpentry
Westside EI (2750) 1B	HAS A COMPLETE POWER OUTAGE- PLANT MGR HUBBARD 416-3725 KLR	5/27/14			Electrical
Westside EI (2750) 1B	UNIT VENT - RM 136 & 138 - NOT COMING ON - PM/HUBBARD 416-3725	6/4/14			Electrical
Westside EI (2750) 1B	clocks are off	11/5/13	Administration Area	main office	Electrical

Westside EI (2750) 1B	Two lights are out behind the Annex Building.	11/27/13	Annex	Outside Building	Electrical
Westside EI (2750) 1B	ballist out in hall way	12/12/13	Hallway/Corridor	2story 1st floor	Electrical
Westside EI (2750) 1B	BALLAST 2-STORY BLDG 1ST FLR HALL-SMOKING & LEAKING PER SBE-PLANT MGR HUBBARD 416-3725 KLR	12/19/13			Electrical
Westside EI (2750) 1B	5-UV NOT COMING ON IN RM-103,138,PE RM MAIN BLDG, RM-239 STORAGE BLDG, & RM-114 ANNEX PLANT MGR-HUBBARD/650.1419	1/8/14			Electrical
Westside EI (2750) 1B	ballisit blown [2]	3/25/14	Hallway/Corridor	main hall	Electrical
Westside EI (2750) 1B	UV IS MAKING NOISE IN RM-106 PLANT MGR-HUBBARD/416.3725	3/26/14			Electrical
Westside EI (2750) 1B	Repair/Replace time clock, set outside lights.	4/2/14	Administration Area		Electrical
Westside EI (2750) 1B	bad ballist in hallway [3]	4/3/14	Hallway/Corridor	2 story	Electrical
Westside EI (2750) 1B	canpoy ligths has bad ballist blown [3]	4/3/14	Grounds	near cafe.	Electrical
Westside EI (2750) 1B	floor ligths base are not working	4/3/14	Grounds	outside	Electrical
Westside EI (2750) 1B	light switch will not come on when using key [4]	4/7/14	Hallway/Corridor	2 story	Electrical

Westside EI (2750) 1B	bad ballist in this area [3]	4/7/14	Kitchen	cafe	Electrical
Westside EI (2750) 1B	UV RM 114-NOT COMING ON-PLANT MGR HUBBARD 416-3725 KLR	4/9/14			Electrical
Westside EI (2750) 1B	ballisit need in rm 113	4/11/14	Classroom	annex hall	Electrical
Westside EI (2750) 1B	HAS A COMPLETE POWER OUTAGE- PLANT MGR HUBBARD 416-3725 KLR	4/11/14			Electrical
Westside EI (2750) 1B	A/C UNITS are NOT COMING in ROOMS 101, 106, 233, 234, and THREE (3) UNITS in the CAFETERIA per Dennis Hubbard, Plant Mgr. 416.3725	4/25/14			Electrical
Westside EI (2750) 1B	BURNING BALANCE in ROOM 109 per Dennis Hubbard, Plant Mgr. 416.3725	4/25/14			Electrical
Westside EI (2750) 1B	Check fire alarm system	7/3/13			Electrical
Westside EI (2750) 1B	FIRE ALARM PANEL IS IN ALARM. SBE PATTERSON 416-3725	7/29/13			Electrical
Westside EI (2750) 1B	UV-7 KITCHEN BY SERVING LINE W & UV-3 CAFE SW-BOTH NOT COMING ON-SBE HUBBARD 416- 0972 KLR	8/7/13			Electrical
Westside EI (2750) 1B	ballist out in hall [3]	8/14/13	Hallway/Corridor	main	Electrical
Westside EI (2750) 1B	BALLAST MAIN HALL-SMOKING- PLANT MGR HUBBARD 461-3725 KLR	8/23/13			Electrical

Westside EI (2750) 1B	UV CAFE-NOT COMING ON-PLANT MGR HUBBARD 416-3725 KLR	9/9/13				Electrical
Westside EI (2750) 1B	ballisit out	10/1/13	Custodial Closet	2 story 1st floor		Electrical
Westside EI (2750) 1B	ballisit blown in sec. office	10/1/13	Administration Area	main		Electrical
Westside EI (2750) 1B	UV IS MAKING NOISE IN RM-237. & UNIT NOT COMING ON IN CAFE PLANT MGR-HUBBARD/416.3725	10/3/13				Electrical
Westside EI (2750) 1B	Unit Ventilator is NOT COMING ON in the CAFETERIA per Dennis Hubbard, Plant Mgr. 416.3725	10/4/13				Electrical
Westside EI (2750) 1B	Unit Ventilator is NOT COMING ON in ROOM 103 per Dennis Hubbard, Plant Mgr. 416.3725	1/13/14				Electrical
Westside EI (2750) 1B	outlet making humming sound.	1/16/14	1st Floor	2 story		Electrical
Westside EI (2750) 1B	UV NOT COMING ON IN RM-114 ANNEX PLANT MGR-HUBBARD/416.3125	1/17/14				Electrical
Westside EI (2750) 1B	Monitoring company reports fire alarm system is in trouble.	1/21/14				Electrical
Westside EI (2750) 1B	per Mr. Hubbard 416-3725 UV not coming on in the cafeteria	1/23/14				Electrical
Westside EI (2750) 1B	per Hubbard 416-3725 rooms 130 UV not coming on and room 241 not coming on	1/28/14				Electrical

Westside EI (2750) 1B	hallway units are not working [7]	1/30/14	Hallway/Corridor	main	Electrical
Westside EI (2750) 1B	ballist blown out in stairwell [3]	2/4/14	2nd Floor	2 story	Electrical
Westside EI (2750) 1B	3-UNITS NOT COMING ON IN RM-140,120,121, B/RR 2ND FLR PLANT MGR-HUBBARD/416.3725	2/5/14			Electrical
Westside EI (2750) 1B	UV NOT COMING ON IN CAFE PLANT MGR-HUBBARD/416.3725	2/6/14			Electrical
Westside EI (2750) 1B	per mr hubbard 416-3725 the pre-k room 106 UV not coming on	2/7/14			Electrical
Westside EI (2750) 1B	Provide electrical power to new steam table. Support CNC, Jim C.	2/19/14	Kitchen		Electrical
Westside EI (2750) 1B	bad ballisit	2/25/14	Classroom	rm 106	Electrical
Westside EI (2750) 1B	3-UNITS NOT COMING ON IN RM-12,PE RM,RM-102 PLANT MGR-HUBBARD/416-3725	3/6/14			Electrical
Westside EI (2750) 1B	clock are off in main	3/17/14	Administration Area	office area	Electrical
Westside EI (2750) 1B	Two lights are out behind the Annex Building.	9/6/13	Annex	Outside Building	Electrical
Westside EI (2750) 1B	A/C PRIN'S OFC-WONT STAY RUNNING-PLANT MGR HUBBARD 416-3725 KLR	6/4/14			Electrical

Westside EI (2750) 1B	A/C RM 240-NOT COMING ON-PLANT MGR HUBBARD 416-3725 KLR	6/4/14			Electrical
Westside EI (2750) 1B	needs bulbs [3 boxes] hallway are dark	10/14/13	Hallway/Corridor	main	Electrical
Westside EI (2750) 1B	Monthly - Oil Lube & Belt-Westside Elementary - Refer to PM schedule details.	5/23/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Check York chiller. One circuit is not running	5/8/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Repair Freon leak and recharge unit. CHILLER REPAIR	5/20/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Replace solenoid valve gasket on chiller.	6/9/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	c/o to heat	10/21/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	5/30/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - Oil Lube & Belt-Westside Elementary - Refer to PM schedule details.	10/25/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	A/C-HEAT UNIT TEACHER'S LOUNGE SMOKING PER SBE-PLANT MGR HUBBARD 416-3725 KLR	10/31/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	11/1/13			Heating/Ventilation /Air Conditioning

Westside EI (2750) 1B	boiler down	11/18/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	UV NOT HEATING IN RM-103. PLANT MGR-HUBBARD/416.3725	11/20/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	BOILER-NOT COMING ON-AFFECTS ENTIRE BLDG-PLANT MGR HUBBARD 416-3725 KLR	11/21/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	11/29/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	uv in room 103 main floor comes on and then goes off by itself per Mr. Hubbard 416-3725	12/4/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	1/3/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - Filter-Westside Elementary - Refer to PM schedule details.	1/4/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	per dennis hubbard 416-3725 hallway unit blowing cold air	1/7/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	4/4/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Yearly - Air Cool Chillers-Westside Elementary - Refer to PM schedule details.	4/15/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	pumps in alarm --- also check chiller	4/21/14			Heating/Ventilation /Air Conditioning

Westside EI (2750) 1B	chiller down	4/29/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	5/2/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	chiller down	5/2/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - Filter-Westside Elementary - Refer to PM schedule details.	5/3/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	chiller down	5/6/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	per mr hubbard 416-3725 chiller is down	5/6/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	per mr hubbard 416-3725 2nd floor of 2 story bldg room 11 free stat problem keeps shutting itself off, also room 229 and cafeteria same problem	5/7/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	chiller down	5/7/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	CHILLER NOT COMING ON (NO ID). SBE-DENNIS/416-3725	7/19/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Room 140 a/c not working per Dennis Hubbard 416-3725	7/22/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	8/2/13			Heating/Ventilation /Air Conditioning

Westside EI (2750) 1B	chiller down	8/13/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	chiller down	8/28/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	8/30/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - Filter-Westside Elementary - Refer to PM schedule details.	8/31/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	A/C SBE'S OFC-NOT COOLING- PLANT MGR McFARLANE 416-3725 KLR	9/3/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	A/C IN RM 109-MAKING NOISES- PLANT MGR McFARLANE KLR	9/6/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	A/C RM 230 HAS AN ODOR COMING FROM IT AND KEEPS SHUTTING OFF PLANT MGR McFARLANE KLR	9/6/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	10/4/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Unit Ventilator has a BURNING SMELL AND AFTER RUNNING FOR A MOMENT THE SYSTEM GOES OUT in ROOM 132 per Dennis Hubbard, Plant Mgr. 416.3725	1/13/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	replace failed sensors in hall units	1/28/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	1/31/14			Heating/Ventilation /Air Conditioning

Westside EI (2750) 1B	secretary's office the UV is blowing cold per Mr. Hubbard 416-3725	1/31/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	UNIT VENTILATOR in the P.E. ROOM is NOT HEATING per Dennis Hubbard, Plant Mgr. 416.3725	2/4/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	3-UV NOT HEATING IN CAFE. PLANT MGR-HUBBARD/650.1419	2/4/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	UV NOT HEATING IN RM-104 PLANT MGR-HUBBARD/416.3725	2/6/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	two hall units need motors	2/10/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Monthly - 1' Filter (Monthly)-Westside Elementary - Refer to PM schedule details.	2/28/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	C/O to A/C	3/21/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	A/C RMS 106, 122, 130, 102, CAFE, 133, & 140-ALL ARE MAKING NOISES WHEN TURNED ON HIGH PER SBE- PLANT MGR HUBBARD 416-3725 KLR	10/22/13			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	Yearly - Boiler 052-Westside EI-Annex 1st FI Rm - Refer to PM schedule details.	3/24/14			Heating/Ventilation /Air Conditioning
Westside EI (2750) 1B	VERY VULGAR GRAFFITI OUTSIDE ON PLAYGROUND EQUIPMENT- PLANT MGR HUBBARD 416-0972 KLR	10/2/13			Painting
Westside EI (2750) 1B	repair toilet always running	6/23/14	Restroom (Boys)	main floor	Plumbing

Westside EI (2750) 1B	UNIT VENTILATOR is LEAKING in the CAFETERIA per Dennis Hubbard, Plant Mgr. 416.3725	6/27/14				Plumbing
Westside EI (2750) 1B	Toilet not flushing properly	5/20/14	1st Floor	finance sect. office		Plumbing
Westside EI (2750) 1B	floor drian is stopped up again.	10/18/13	Restroom (Girls)	2 story		Plumbing
Westside EI (2750) 1B	TOILET PIPE HAS BUSTED IN RM-106. PLANT MGR-HUBBARD/416.3880	5/28/14				Plumbing
Westside EI (2750) 1B	PIPE PRIN'S OFC-LEAKING IN CEILING-PLANT MGR HUBBARD 416-3725 KLR	5/28/14				Plumbing
Westside EI (2750) 1B	sink in annex will not cut off	10/24/13	Restroom (Girls)	annex		Plumbing
Westside EI (2750) 1B	toilet will not running	10/30/13	Restroom (Girls)	2 story		Plumbing
Westside EI (2750) 1B	water cooler pipe is brusted	11/14/13	Hallway/Corridor	annex		Plumbing
Westside EI (2750) 1B	PIPE IS LEAKING WATER FROM TOILET IN TEACHER LOUNGE 2-STORAGE BLDG PLANT MGR-HUUBBARD/416.3725	12/2/13				Plumbing
Westside EI (2750) 1B	pipe is leaking in toilet	12/4/13	Classroom	room106		Plumbing
Westside EI (2750) 1B	restroom leaking toilet b.b.restroom	12/4/13	1st Floor	2 story		Plumbing

Westside EI (2750) 1B	STEAM TABLE NEEDS TO BE REMOVE IN ORDER TO ADD NEW ONE	12/9/13	Kitchen	CAFE.	Plumbing
Westside EI (2750) 1B	PIPE IN CEILING OF RM 226 2ND FLR 2-STORY BLDG-LEAKING-PLANT MGR HUBBARD 416-3725 KLR	1/7/14			Plumbing
Westside EI (2750) 1B	PIPE HAS BUSTED FROM OUTSIDE BOILER RM PLANT MGR-HUBBARD/650.1419	1/8/14			Plumbing
Westside EI (2750) 1B	toilet will not flush [2]	4/7/14	Restroom (Boys)	2 story	Plumbing
Westside EI (2750) 1B	boy's r.r. toilet seat is broken in stall	4/24/14	Restroom (Boys)	annex	Plumbing
Westside EI (2750) 1B	toilet will not flush	4/29/14	Administration Area	main office	Plumbing
Westside EI (2750) 1B	teachers lounge toilet and sink is clogged	4/29/14	Annex	2 story	Plumbing
Westside EI (2750) 1B	COMMODE PRIN'S RR-NOT FLUSHING-PLANT MGR HUBBARD 416-3725 KLR	4/30/14			Plumbing
Westside EI (2750) 1B	girl's faucet will not work	4/30/14	Restroom (Girls)	main	Plumbing
Westside EI (2750) 1B	toilet will not flush in 106	4/30/14	Restroom (Boys)	main floor	Plumbing
Westside EI (2750) 1B	r.r. will not flush	4/30/14	Classroom	106 rm	Plumbing

Westside EI (2750) 1B	UNIT IN RM 238 IS LEAKING. SBE HUBBARD 416-0972	7/24/13				Plumbing
Westside EI (2750) 1B	COMMODOE LEAKING B RR ANNEX BLDG-REQUESTED BY B FROST KLR	8/29/13				Plumbing
Westside EI (2750) 1B	COMMODOE CONSTANTLY RUNNING IN TEACHER'S LOUNGE-LEAKING ON SEAT PER LEAD-LEAD MORGAN 416-3725 KLR	9/4/13				Plumbing
Westside EI (2750) 1B	garbage disposal stopped up in kitchen per Ms. Morgan 416-9494	9/5/13				Plumbing
Westside EI (2750) 1B	2nd faucet is constantly leaking.	9/6/13	Hallway/Corridor	1st. Floor by Closet		Plumbing
Westside EI (2750) 1B	floor drain is clogged in boys r.r.	9/10/13	Restroom (Boys)	1&2 floor		Plumbing
Westside EI (2750) 1B	toilet will not stop running	9/10/13	Restroom (Girls)	frist floor 2 story		Plumbing
Westside EI (2750) 1B	TOILET IS OVERFLOWING IN PRIN/RR . PLANT MGR-HUBBARD/650.1419	9/18/13				Plumbing
Westside EI (2750) 1B	Unit Ventilator is LEAKING in ROOM 241 per Dennis Hubbard, Plant Mgr. 416.3725	10/4/13				Plumbing
Westside EI (2750) 1B	UV PRIN'S OFC-LEAKING-PLANT MGR HUBBARD 416-3725 KLR	10/8/13				Plumbing
Westside EI (2750) 1B	teacher's r.r. toilet will not flush	1/10/14	1st Floor	main		Plumbing

Westside EI (2750) 1B	teacher r.r. pipe is broken can not stop water from dripping	1/13/14	Administration Area		Plumbing
Westside EI (2750) 1B	Rattling or humming noise coming from wall in room 139	1/21/14	1st Floor	rm #139	Plumbing
Westside EI (2750) 1B	Low water pressure	1/21/14	1st Floor	Hand sink in hallway	Plumbing
Westside EI (2750) 1B	Flush handle on urinal leaking	1/22/14	2nd Floor	Boys restroom (annex)	Plumbing
Westside EI (2750) 1B	URINAL IS OVERFLOWING IN B/RR 2- STORAGE BLD. PLANT MGR-HUBBARD/416.3880	1/23/14			Plumbing
Westside EI (2750) 1B	PIPE has BURST in the KITCHEN underneath the SINK per Dennis Hubbard, Plant Mgr. 416.3725.	1/27/14			Plumbing
Westside EI (2750) 1B	garbage disposal IS STOPPED UP IN KITCHEN PLANT MGR-HUBBARD/416.3880	1/29/14			Plumbing
Westside EI (2750) 1B	FLOOR DRIAN IS STOPPED UP	1/30/14	Kitchen	MAIN	Plumbing
Westside EI (2750) 1B	toilet handle is broken	2/6/14	Restroom (Boys)	2 story	Plumbing
Westside EI (2750) 1B	handle on toilet is broken	2/11/14	Restroom (Boys)	2 story	Plumbing
Westside EI (2750) 1B	water fountain needs handle [broken]	2/12/14	Hallway/Corridor	2 story	Plumbing

Westside EI (2750) 1B	toilet is leaking from under bottom	2/13/14	Restroom (Boys)	2 story 1st floor	Plumbing
Westside EI (2750) 1B	Hook-up new steam table, all supply and drain lines. To support CNC Jim C.	2/17/14	Kitchen		Plumbing
Westside EI (2750) 1B	toilet needs flush value kit	2/26/14	Restroom (Boys)	2 story	Plumbing
Westside EI (2750) 1B	toilet and wall toilet are stopped up [3] and [3]	2/28/14	Restroom (Boys)	2 story	Plumbing
Westside EI (2750) 1B	toilet need new setting it will not flush	3/21/14	Restroom (Boys)	2 story	Plumbing
Westside EI (2750) 1B	water is coming from under toilet	3/21/14	Restroom (Boys)	1st floor 2 story	Plumbing
Westside EI (2750) 1B	A/C RM 122-LEAKING FROM CEILING-PLANT MGR HUBBARD 416-3725 KLR	6/4/14			Plumbing
Westside EI (2750) 1B	UV MAIN HALL-LEAKING-PLANT MGR HUBBARD 416-3725 KLR	6/5/14			Plumbing
Westside EI (2750) 1B	roof is leaking badley rm 237	1/8/14	2nd Floor	2 story	Roof
Westside EI (2750) 1B	Roof leak in cafetorium at the center spot lights .	3/6/14	Cafetorium		Roof
Westside EI (2750) 1B	ROOF LEAKING KITCHEN AREA LIGHT FIXTURE PER SBE-PLANT MGR HUBBARD 426-3725 KLR	3/6/14			Roof

Count of Craft	Craft									
	Location	Asbestos	Carpentry	Electrical	HVAC	Painting	Plumbing	Roof	Sheet Metal	Grand Total
Woodstock Middle (0185) 1B		4	34	64	35	13	64	8	6	228
Grand Total		4	34	64	35	13	64	8	6	228

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Woodstock Middle (0185) 1B	repair broken floor tile in cafeteria	1/31/14	Cafeteria		Asbestos
Woodstock Middle (0185) 1B	Mildew in room 202 on right side window bolts to concrete per Willie Hampton 353-8590	8/7/13			Asbestos
Woodstock Middle (0185) 1B	for hardwood floor to be refinish .	9/23/13	Basketball Court		Asbestos
Woodstock Middle (0185) 1B	please refinish the gym floor, floor is starting to flake and needs refinish for the upcoming basketball season	9/20/13	Gym		Asbestos
Woodstock Middle (0185) 1B	Tile broken and coming up need to be replace side entrance doors (about 12 Pcs.).	5/19/14	Hallway/Corridor	501	Carpentry
Woodstock Middle (0185) 1B	Clock work but need to be remounted (location in plant manager office)	5/7/14	Hallway/Corridor	by room 306	Carpentry
Woodstock Middle (0185) 1B	Doors: Thresholds You can see day light over them(things are coming in to class rooms From under doors)400,402,404,405,406,407,408,409,412,&304.	4/9/14	Classroom		Carpentry
Woodstock Middle (0185) 1B	Window glass broken out.	4/16/14	Classroom	102	Carpentry

Woodstock Middle (0185) 1B	Two window glass is broken out.	4/21/14	Gym	lockers.Boys & girls'	Carpentry
Woodstock Middle (0185) 1B	Window glass broken out.	4/2/14	Cafeteria		Carpentry
Woodstock Middle (0185) 1B	Broke glass need to be replace.	2/19/14	Classroom	room 202	Carpentry
Woodstock Middle (0185) 1B	Two clocks is not working.	3/20/14	Hallway/Corridor	By room 308 &410	Carpentry
Woodstock Middle (0185) 1B	Relocate bulletin board on wall from assistant principal office to principal office	7/12/13	Administration Area		Carpentry
Woodstock Middle (0185) 1B	Need a window repaired in room 304 by the exit door	7/16/13			Carpentry
Woodstock Middle (0185) 1B	Clock is not working.	12/11/13	Hallway/Corridor	next to room 402	Carpentry
Woodstock Middle (0185) 1B	table bracket check to see if can be remounted (wood section).	12/12/13	Classroom	409 computer	Carpentry
Woodstock Middle (0185) 1B	Tile need to be replace is loose from floor (about twenty pcs, white).	1/21/14	Cafeteria		Carpentry

Woodstock Middle (0185) 1B	Need install: Security mirror and 3'x4' tack board both in library (See teacher for location).	2/4/14	Library		Carpentry
Woodstock Middle (0185) 1B	Cover coming loose on some steps going up to second floor (old & Dangerous).	2/13/14	Stairway	by room 102	Carpentry
Woodstock Middle (0185) 1B	Were window and frame going up wall(old putting dry ,cracking is letting water come in starting mold to grow).	2/13/14	Classroom	202	Carpentry
Woodstock Middle (0185) 1B	Window glass is broken .	2/18/14	2nd Floor	202	Carpentry
Woodstock Middle (0185) 1B	ENTRANCE DOORS 500 AREA REAR, 300 AREA REAR & BETWEEN 100/300 AREAS REAR-ALL NOT CLOSING PROPERLY, WON'T BE ABLE TO SECURE-SBE HAMPTON 253-2500 1/17	8/2/13			Carpentry
Woodstock Middle (0185) 1B	Need glass repair broken out.	8/8/13	Classroom	202	Carpentry
Woodstock Middle (0185) 1B	Need whiteboard install new location .	8/8/13	Classroom	101	Carpentry
Woodstock Middle (0185) 1B	Need whiteboard install wall.	8/8/13	Classroom	307	Carpentry
Woodstock Middle (0185) 1B	Need whiteboard install on wall.	8/8/13	Classroom	402	Carpentry

Woodstock Middle (0185) 1B	Need whiteboard install.	8/9/13	Classroom	305	Carpentry
Woodstock Middle (0185) 1B	REAR ENTRANCE DOOR#2 BETWEEN RMS 101 & 102-NOT CLOSING- WON'T BE ABLE TO SECURE-SBE HAMPTON 416-353-8590 KLR	8/12/13			Carpentry
Woodstock Middle (0185) 1B	Clock will not keep right time.	8/21/13	Hallway/Corridor	by room 301	Carpentry
Woodstock Middle (0185) 1B	Entrance door from back by stairway Door closure cover broken off. #2 double doors in hallway by room 100 end cap is off doors bar down.	9/6/13	1st Floor		Carpentry
Woodstock Middle (0185) 1B	need a door put on middle stall .	9/11/13	Gym	boys locker restroom	Carpentry
Woodstock Middle (0185) 1B	door service line (insulation coming out of door small round form).	9/27/13			Carpentry
Woodstock Middle (0185) 1B	Heater old on wall one parts need to be boat back to wall.	9/27/13	Gym	lobby boys rest room.	Carpentry
Woodstock Middle (0185) 1B	CLOCK NEED TO BE REPAIRED.	11/1/13	Hallway/Corridor	by 403	Carpentry
Woodstock Middle (0185) 1B	glass broken out.	5/16/14	Classroom	305	Carpentry

Woodstock Middle (0185) 1B	FRONT ENTRANCE DOOR-LATCH NOT CATCHING-PEOPLE ARE JUST WALKING IN-PLANT MGR GAMBLE 353-8590 KLR	5/8/14				Carpentry
Woodstock Middle (0185) 1B	Window broken out (can you leave a price of the cost to repair this in office Principal need it thanks).	5/19/14	Classroom	102		Carpentry
Woodstock Middle (0185) 1B	Adjust all lab tables to ADA height.	5/28/14				Carpentry
Woodstock Middle (0185) 1B	Three light out coming in from 51 road. #2 back road one light out, #3. Road coming into school , light on corner near gym.	5/13/14	Parking Lot	coming in from 51		Electrical
Woodstock Middle (0185) 1B	Need six cover for lights (Fit two lamp by 48").	2/19/14	Gym	Boys locker room		Electrical
Woodstock Middle (0185) 1B	breaker keep tripping that keep warmer on #29. Class room wall outlet cover is broken(304).	3/24/14	Kitchen			Electrical
Woodstock Middle (0185) 1B	1.10440 Incndscnt lamps 60 Watt A-130 v qty. 50 #2. 10221 Fluorescent lamp F32T8 energe efficient lamp qut. 6 cases. #3. 10283. Gloves ,powder free vinyl exam ,Med. 2 packages. #4. 10531	3/25/14	1st Floor			Electrical
Woodstock Middle (0185) 1B	Light is not working.	4/1/14	Parking Lot	on the back by band room.		Electrical
Woodstock Middle (0185) 1B	new bulbs in the fixture. need ballast	4/2/14	Administration Area	main office		Electrical

Woodstock Middle (0185) 1B	need ballast in hallway	4/2/14	Hallway/Corridor	near asst principal	Electrical
Woodstock Middle (0185) 1B	Emergence Light By room 407 & girls rest 400 hall. (not working).	4/4/14	Hallway/Corridor		Electrical
Woodstock Middle (0185) 1B	Need time clock repaired.	4/7/14		Lawn equipment room	Electrical
Woodstock Middle (0185) 1B	Please run Test. Generator Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical
Woodstock Middle (0185) 1B	kitchen back entrance door needs to be checked for ability to completely close. It's sending false security alarms CARPENTERS CHECKED THIS DOOR AND IT IS CLOSING PROPERLY	7/12/13	Administration Area		Electrical
Woodstock Middle (0185) 1B	Time clocks for the parking lot and building wall packs need to be reset.	7/16/13			Electrical
Woodstock Middle (0185) 1B	Show plant manager all electrical panels.	7/16/13			Electrical
Woodstock Middle (0185) 1B	10221 fluorescent lamp F32T8 energy efficient L.amp (4 case).	11/19/13	1st Floor		Electrical
Woodstock Middle (0185) 1B	FIRE ALARM IS SHOWING TROUBLE IN GUIDANCE OFFICE PLANT MGR- HAMPTON/873-8187	11/22/13			Electrical

Woodstock Middle (0185) 1B	LIGHT IS NOT WORKING.	12/2/13	2nd Floor	HALLWAY	Electrical
Woodstock Middle (0185) 1B	one light blank on and of.	12/3/13		413	Electrical
Woodstock Middle (0185) 1B	Supervisor trouble P R 12.	12/23/13		school	Electrical
Woodstock Middle (0185) 1B	Fire alarm pull down will not work.	1/6/14	Gym	Girls locker by back exit door	Electrical
Woodstock Middle (0185) 1B	Fire System shows a supervisory alarm.	1/10/14			Electrical
Woodstock Middle (0185) 1B	Clock is not working.	1/31/14	2nd Floor		Electrical
Woodstock Middle (0185) 1B	Exhaust fan (Ex F A1) Not working.	2/5/14		roof 400 area	Electrical
Woodstock Middle (0185) 1B	Exit light out in side (3)	2/11/14	Gym		Electrical
Woodstock Middle (0185) 1B	Exit light out.	2/11/14	Classroom	500 Band	Electrical

Woodstock Middle (0185) 1B	Emergency light not working.	2/13/14	Restroom (Girls)	400 end	Electrical
Woodstock Middle (0185) 1B	Magnet broken of door.	7/31/13	Stairway	second flour door	Electrical
Woodstock Middle (0185) 1B	Two light coming into school need repair (very high up).	8/1/13	1st Floor	entrance front	Electrical
Woodstock Middle (0185) 1B	front out side light need repair(high up).	8/1/13	Gym	front	Electrical
Woodstock Middle (0185) 1B	There light need repair(have tape on case).	8/1/13	Classroom	502	Electrical
Woodstock Middle (0185) 1B	Have three light need repair (have tape on case).	8/1/13		501	Electrical
Woodstock Middle (0185) 1B	Light need to be change out (up hight).	8/14/13		cover on back	Electrical
Woodstock Middle (0185) 1B	Phone: can,t hear other party when calling .	8/15/13		office Facilitator title one	Electrical
Woodstock Middle (0185) 1B	Door latch will not release from office so they can let people in.	8/21/13			Electrical

Woodstock Middle (0185) 1B	Latch will not release from office to let people in.	8/21/13		front.door	Electrical
Woodstock Middle (0185) 1B	#1. need fluorescent lamps(T8W. F32T8-SP41-U-6 MOD-U-line Mfg.G E) Qty ,8 (for out side front entrance). warehouse item #10221	8/26/13		school	Electrical
Woodstock Middle (0185) 1B	#1.10525 mercury lamps ,H39-22kc/c QTY,2, #1. 10525 MERCURY LAMPS ,H39 -22C/C,175W OBLONG QTY,2	8/26/13		School	Electrical
Woodstock Middle (0185) 1B	RTU - PRIN OFC- NOT COMING ON - PM/HAMILTON 353-8590	9/6/13			Electrical
Woodstock Middle (0185) 1B	Exit lights front entrance, and side door near back road,	9/12/13	Gym		Electrical
Woodstock Middle (0185) 1B	exit lights gym floor.	9/12/13	Gym		Electrical
Woodstock Middle (0185) 1B	Two exit light out.	9/12/13	Gym	girls locker	Electrical
Woodstock Middle (0185) 1B	Emergi-lite, out in hall way, and by coach office.	9/12/13	Gym		Electrical
Woodstock Middle (0185) 1B	Exit light out.	9/12/13	Hallway/Corridor	500	Electrical

Woodstock Middle (0185) 1B	Emergi- lite out.	9/12/13	Hallway/Corridor	500	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair .	9/17/13	Gym	in front near boys rest room	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair.	9/17/13	Hallway/Corridor	left side near ketchen	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair.	9/17/13	Hallway/Corridor	front on right side by office	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair.	9/17/13	Hallway/Corridor	front entrance left side	Electrical
Woodstock Middle (0185) 1B	Emergi lite need to be repair.	9/17/13	Gym	by stage	Electrical
Woodstock Middle (0185) 1B	Want to check to see can we go a higher wattage bulbs (per principal).	9/19/13	Gym	basket ball ceiling	Electrical
Woodstock Middle (0185) 1B	Two light need to repaired	9/23/13	Basketball Court	gym	Electrical
Woodstock Middle (0185) 1B	Light is not working.	9/30/13	Hallway/Corridor	by 300	Electrical

Woodstock Middle (0185) 1B	Emergi-lite not working.	10/1/13	Hallway/Corridor	500 wall side boys rest room	Electrical
Woodstock Middle (0185) 1B	Light will not work.	10/18/13	1st Floor	Parent meeting room.	Electrical
Woodstock Middle (0185) 1B	one light out.	10/21/13	2nd Floor	hallway	Electrical
Woodstock Middle (0185) 1B	Two light out(up hight).	10/21/13	Stairway	second floor	Electrical
Woodstock Middle (0185) 1B	Emergency light need repair (fire department inspection)	11/1/13	Gym	by 601	Electrical
Woodstock Middle (0185) 1B	Verify data base in burglar alarm panel.	11/1/13			Electrical
Woodstock Middle (0185) 1B	label breaker for boiler on panel door	11/7/13			Electrical
Woodstock Middle (0185) 1B	Three pole light are not working.(we need them repaired as soon as possible for security real dark in that area will help on basketball Night).	11/14/13		road on side of gym.corner by offices	Electrical
Woodstock Middle (0185) 1B	10460 lamp, metal halide, mvr 400/u mogul base sub for 1 (need 8).	11/15/13			Electrical

Woodstock Middle (0185) 1B	10182 Deodorizer ,Dsnfctnt 14Oz aerosol can QTY. 2case.	3/27/14	1st Floor		Electrical
Woodstock Middle (0185) 1B	10182 Deodorizer Dsnfctnt 14 OZ Aerosol can QTY.2 case.	3/27/14	1st Floor		Electrical
Woodstock Middle (0185) 1B	#1.10480 Mats,floor ,3x4 Qty. 6 #2.10460 Liners compactor, Gladco 31x50.	3/28/14	1st Floor		Electrical
Woodstock Middle (0185) 1B	Light out need to be repaired.	5/22/14		Book room (400 hall way)	Electrical
Woodstock Middle (0185) 1B	GAS in SMELL in the 300' s AREA per Willie Hampton, Plant Mgr. 353.8590	3/4/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Will not let bag give access to enter .	3/6/14		school	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN RM-200 PLANT MGR- HAMPTON/353.8596	11/25/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN RM-201 PLANT MGR- WILLIE/353.8590	11/26/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Unit in MAIN OFFICE is NOT COMING ON per Willie Hampton, Plant Mgr. 353.8590	12/10/13			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	Replace heat exchanger in guidance	12/19/13		Guidance	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Unit is NOT COMING ON Room 102 per Willie Hampton, Plant Mgr. 353.8590	1/6/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT RM 205-NOT HEATING-PLANT MGR HAMPTON 353-8590 KLR	2/3/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT BANDROOM #500-NOT COMING ON-PLANT MGR HAMPTON 353-8590 KLR	2/10/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Condensation drain pipe are cut off A/C units (causing mold to grow causing problem in some of the class room).	8/8/13		second floor roof	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COOLING IN RM-308 PLANT MGR-HAMPTON/353.8596	8/8/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN B/RR 2ND FLR PLANT MGR-HAMPTON/353.8590	8/13/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C RM 200-NOT COOLING-PLANT MGR HAMPTON 353-8590 KLR	8/29/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C RMS 304, 305, 307 & PRIN'S OFC-ALL NOT COOLING & RM 308-HAS (2) UNITS ONE NOT COOLING & OTHER NOT COMING ON-PLANT MGR HAMPTON KLR	9/3/13			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	A/C RM 408-NOT COOLING-PLANT MGR HAMPTON 353-8590 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Service season four units	9/19/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C is blowing foam back through vent look like insulation (ref.to W/O 383520)	9/20/13	Kitchen		Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C unit in the kitchen is blowing out installation per Mr. Willie Hampton, Plant Mgr. 353.8590	9/23/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	WE can't get A/C vents out to clean (need help inspection report).	9/26/13	Kitchen	Service line	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C is not cooling very good in rooms 300,301,302, 303'(308 first A/C)	10/16/13	Classroom		Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Need to be checked for heating ,(100 , 106).	10/24/13	Classroom		Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Check no heat on season four unit	10/28/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT RMS 300, 301, 302, & 303-ALL NOT HEATING-PLANT MGR HAMPTON 353-8590 KLR	11/7/13			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	Replace discharge temp control	11/7/13		Seasons four	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT RM 200-NOT COMING ON-PLANT MGR HAMPTON 353-8590 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT HEATING IN PRIN OFFICE PLANT MGR- HAMPTON/353.8592	11/14/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN RM-200. PLANT MGR- HAMPTON/353.8592	11/15/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COOLING IN RM-304- THRU 307 PLANT MGR- WILLIE/873.8187	5/12/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C UNITS are NOT COOLING in ROOMS 304, 305, 306, and 307 per Willie Hampton, Plant Mgr. 353.8590	5/19/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C RM 409, 410, & 411- ALL NOT COOLING- PLANT MGR CONNOR 353-8596 KLR	6/20/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	PM a/c units	6/3/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COOLING IN RM-200 PLANT MGR- CONNER/353.8596	6/6/14			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	UNIT IN RM 300-308 IS NOT COOLING. SBE HAMPTON 353-8592	7/30/13				Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT IN RM 503 IS NOT COMING ON SBE HAMPTON 416-353-8590	7/12/13				Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Service A/C on whole school	7/16/13			Whole school	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	paint peeling off wall the wood between locker.	5/20/14	1st Floor		thru out the building	Painting
Woodstock Middle (0185) 1B	Please paint classrooms on 200 hallway that has peeling/chipping paint.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please touchup paint 200 hallway.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please paint doors on 200 hallway.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please paint restrooms on 200 hallway.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please paint stairwells leading to 200 hallway	6/23/14				Painting

Woodstock Middle (0185) 1B	Please paint class rooms doors Etc.	6/26/14	1st Floor		Painting
Woodstock Middle (0185) 1B	Metal post had to be replaced (need painting).	4/9/14		Bus lane near back parking lot.	Painting
Woodstock Middle (0185) 1B	Principal office need painting .	7/24/13	Administration Area		Painting
Woodstock Middle (0185) 1B	Doors need to be painted .	8/5/13	Library		Painting
Woodstock Middle (0185) 1B	out side wall brick right side need to be seal to keep water out(to keep out fungus).in side	8/5/13	Classroom	202	Painting
Woodstock Middle (0185) 1B	Can we get Front lobby rest rooms painted , written & graffiti partitions, walls)cleaning up for celebrating 100 year of service) will be happen on Oct-6-2013	9/23/13	Gym	boys and girls .	Painting
Woodstock Middle (0185) 1B	two window need to be repainted side 4' x 6' and a part at top 1' x48" (A lot of green is showing) white is the base color look like someone have been peeling the paint off look real bad	10/22/13	Gym	out side.	Painting
Woodstock Middle (0185) 1B	We have 2 faucets on 1st floor that are not working.(One in the clinic and one in the restroom.	6/10/14	Restroom (Boys)	1st floor	Plumbing
Woodstock Middle (0185) 1B	There are 3 water coolers on the 1st floor not working.	6/10/14	1st Floor		Plumbing

Woodstock Middle (0185) 1B	Water fountain spout(floor get wet).	4/14/14	Hallway/Corridor	near 301	Plumbing
Woodstock Middle (0185) 1B	Dish wash leaking water from pipe up under .	4/16/14	Kitchen		Plumbing
Woodstock Middle (0185) 1B	Gas smell reported in the storage room in science lab 400 hallway.	3/28/14			Plumbing
Woodstock Middle (0185) 1B	Urinal leaking water from top #2.	2/26/14	1st Floor	boys rest room	Plumbing
Woodstock Middle (0185) 1B	Gym toilet stopped up..	7/12/13			Plumbing
Woodstock Middle (0185) 1B	1st floor boys toilet stopped up..	7/12/13			Plumbing
Woodstock Middle (0185) 1B	NO HOT WATER FOR DISH WASHER IN KITCHEN PLANT MGR- HAMPTON/353.8592	11/19/13			Plumbing
Woodstock Middle (0185) 1B	No hot water in kitchen	11/19/13			Plumbing
Woodstock Middle (0185) 1B	Urinal stop up.	12/5/13	1st Floor	boys rest room	Plumbing

Woodstock Middle (0185) 1B	Urinal #2 leaking watering from base.	12/18/13	1st Floor	boy rest room	Plumbing
Woodstock Middle (0185) 1B	Sink stopped up janitorial room.	12/18/13	1st Floor	up front on corner	Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 957956 2" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 957875 2" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 832020 3/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 1055208 1 1/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 832044 3/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 1058812 1 1/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	Near 103	Plumbing

Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	near 106	Plumbing
Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	near 406	Plumbing
Woodstock Middle (0185) 1B	Faucet girls rest room.	1/13/14	1st Floor	hall way 400	Plumbing
Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	By cafetria	Plumbing
Woodstock Middle (0185) 1B	Repair faucet.	1/13/14	1st Floor	Clinic Rest room	Plumbing
Woodstock Middle (0185) 1B	Unstop sink Brake room.	1/13/14	1st Floor	Main Bldg.	Plumbing
Woodstock Middle (0185) 1B	Urinal leaking from top (#2).	1/14/14		boys rest room near Library	Plumbing
Woodstock Middle (0185) 1B	Unstop sink.	1/14/14	Kitchen	Janitor	Plumbing
Woodstock Middle (0185) 1B	Water fountain leaking water (leaking from turn off).	1/16/14	1st Floor	near 106	Plumbing

Woodstock Middle (0185) 1B	Commode need replace broken .	2/6/14	Restroom (Boys)	400 area	Plumbing
Woodstock Middle (0185) 1B	repair #3 commode locker room.	7/31/13	Gym	girls rest	Plumbing
Woodstock Middle (0185) 1B	Commode seat need replace #1, #2 & #5 stall.	7/31/13	Gym	girls rest	Plumbing
Woodstock Middle (0185) 1B	REpair commode #3.	7/31/13	Restroom (Girls)	300 hall way	Plumbing
Woodstock Middle (0185) 1B	repair commode seat.	7/31/13	Restroom (Girls)	400 hall	Plumbing
Woodstock Middle (0185) 1B	Repair first commode.	8/1/13	Gym	boys locker room	Plumbing
Woodstock Middle (0185) 1B	Handicap faucet need repair.	8/7/13	Restroom (Boys)	second floor	Plumbing
Woodstock Middle (0185) 1B	Faucet need repair.	8/7/13	Restroom (Boys)	gym up front	Plumbing
Woodstock Middle (0185) 1B	Repair commode.	8/7/13	Gym	boys locker	Plumbing

Woodstock Middle (0185) 1B	Repair drain lines to A/C units on main building	9/5/13		RTU's on main building	Plumbing
Woodstock Middle (0185) 1B	commode #3 need repair .	9/11/13	Gym	boys locker restroom	Plumbing
Woodstock Middle (0185) 1B	Urinal #3 will not running water.	9/19/13	Restroom (Boys)		Plumbing
Woodstock Middle (0185) 1B	#4 leaks from base. last W/O same location.	9/19/13	Restroom (Boys)	by library	Plumbing
Woodstock Middle (0185) 1B	#3 urinal leaks from spud.	9/19/13	Restroom (Boys)	by library	Plumbing
Woodstock Middle (0185) 1B	Need handicap faucet replaced .	9/23/13	Gym	Boys up front	Plumbing
Woodstock Middle (0185) 1B	Commode broken (need a new one).	9/25/13	2nd Floor	boys	Plumbing
Woodstock Middle (0185) 1B	Three spout need to be checked for clogged.	9/25/13		front entrance of school	Plumbing
Woodstock Middle (0185) 1B	3 comp sink need to be checked for cold water (for inspection report complain).	9/25/13	Kitchen		Plumbing

Woodstock Middle (0185) 1B	Drain clog up (steamer)	9/30/13	Kitchen		Plumbing
Woodstock Middle (0185) 1B	Faucet middle when water in turn on vibrate loud disturb classes .	10/2/13	Restroom (Boys)	500 area	Plumbing
Woodstock Middle (0185) 1B	first urinal stop-up.	11/11/13	Restroom (Boys)	first floor	Plumbing
Woodstock Middle (0185) 1B	Shower need repair.	11/12/13	Gym	locker boys	Plumbing
Woodstock Middle (0185) 1B	Need to check hot water.	11/12/13	Gym		Plumbing
Woodstock Middle (0185) 1B	Check shower head.	11/12/13	Gym	locker giral	Plumbing
Woodstock Middle (0185) 1B	Drinking fountain need repair.	11/12/13	Gym	locker girls	Plumbing
Woodstock Middle (0185) 1B	NO HOT WATER TO KITCHEN-PLANT MGR HAMPTON 353-8590 KLR	11/18/13			Plumbing
Woodstock Middle (0185) 1B	Commode seat need to be repaired .	5/8/14	2nd Floor	boys rest room	Plumbing

Woodstock Middle (0185) 1B	Small urinals are clogged up.	5/12/14	1st Floor	& Second floor, Boys	Plumbing
Woodstock Middle (0185) 1B	Water fountain loose from wall and leaking water.	5/19/14	Hallway/Corridor	near 102	Plumbing
Woodstock Middle (0185) 1B	Urinal leaking water real bad.(middle).	5/21/14	Restroom (Boys)	Locker	Plumbing
Woodstock Middle (0185) 1B	Commode clogged ,(Middle one).	5/22/14	Gym	boys locker rest room	Plumbing
Woodstock Middle (0185) 1B	Water leaking from pipe under dish washer .	4/29/14	Kitchen		Plumbing
Woodstock Middle (0185) 1B	HOT WATER HEATER KITCHEN AREA-NOT WORKING-PLANT MGR HAMPTON 353-8590 KLR	3/21/14			Plumbing
Woodstock Middle (0185) 1B	W/O 431829(is for Woodstocs Middle)	4/24/14		Near 106	Plumbing
Woodstock Middle (0185) 1B	NO HOT WATER THRU BLDG PRIN-DEBRE/353.8590	11/18/13			Plumbing
Woodstock Middle (0185) 1B	Water running on wall next to street.	3/20/14		office (Mitchll)	Roof

Woodstock Middle (0185) 1B	Water leaking.	2/18/14	Hallway/Corridor	by 308 Across from center water fountain .	Roof
Woodstock Middle (0185) 1B	Coming in entrance door from hallway on boys rest room side(water leaking over # 7 shelf).	2/18/14	Library		Roof
Woodstock Middle (0185) 1B	Leaking water about center of room.	9/17/13	Classroom	413	Roof
Woodstock Middle (0185) 1B	Water leaking down wall (can see brown stain on wall)	9/17/13	Cafeteria	entrance hallway	Roof
Woodstock Middle (0185) 1B	Water leaking thru ceiling.	9/25/13		office	Roof
Woodstock Middle (0185) 1B	When coming into room second light on right .	9/25/13	Classroom	400	Roof
Woodstock Middle (0185) 1B	Leaking water right side of vent about two feet from wall.	11/7/13	Classroom	413	Roof
Woodstock Middle (0185) 1B	Wire need to be repaired (from ice storm damage).	4/21/14	Athletic Field	Base ball .	Sheet Metal
Woodstock Middle (0185) 1B	Metal post and chain need to be repair.	4/2/14		bus lane back of school	Sheet Metal

Woodstock Middle (0185) 1B	Hallways #400 there is a number of lockers need repairing . WE NEED LOCKER NUMBERS	11/25/13			Sheet Metal
Woodstock Middle (0185) 1B	Lockers numbers '883 ,881 (ref #3995630	12/2/13	Hallway/Corridor	400	Sheet Metal
Woodstock Middle (0185) 1B	3 cart need to be repaired (used to move food).	1/6/14	Kitchen		Sheet Metal
Woodstock Middle (0185) 1B	Make metal for carpenter crew (see Marshall Stutes)	9/30/13			Sheet Metal

Location	Request Description	Submittal Date	Area Description	Area Number	Craft
Woodstock Middle (0185) 1B	repair broken floor tile in cafeteria	1/31/14	Cafeteria		Asbestos
Woodstock Middle (0185) 1B	Mildew in room 202 on right side window bolts to concrete per Willie Hampton 353-8590	8/7/13			Asbestos
Woodstock Middle (0185) 1B	for hardwood floor to be refinish .	9/23/13	Basketball Court		Asbestos
Woodstock Middle (0185) 1B	please refinish the gym floor, floor is starting to flake and needs refinish for the upcoming basketball season	9/20/13	Gym		Asbestos
Woodstock Middle (0185) 1B	Tile broken and coming up need to be replace side entrance doors (about 12 Pcs.).	5/19/14	Hallway/Corridor	501	Carpentry
Woodstock Middle (0185) 1B	Clock work but need to be remounted (location in plant manager office)	5/7/14	Hallway/Corridor	by room 306	Carpentry
Woodstock Middle (0185) 1B	Doors: Thresholds You can see day light over them(things are coming in to class rooms From under doors)400,402,404,405,406,407,408,409,412,&304.	4/9/14	Classroom		Carpentry
Woodstock Middle (0185) 1B	Window glass broken out.	4/16/14	Classroom	102	Carpentry

Woodstock Middle (0185) 1B	Two window glass is broken out.	4/21/14	Gym	lockers.Boys & girls'	Carpentry
Woodstock Middle (0185) 1B	Window glass broken out.	4/2/14	Cafeteria		Carpentry
Woodstock Middle (0185) 1B	Broke glass need to be replace.	2/19/14	Classroom	room 202	Carpentry
Woodstock Middle (0185) 1B	Two clocks is not working.	3/20/14	Hallway/Corridor	By room 308 &410	Carpentry
Woodstock Middle (0185) 1B	Relocate bulletin board on wall from assistant principal office to principal office	7/12/13	Administration Area		Carpentry
Woodstock Middle (0185) 1B	Need a window repaired in room 304 by the exit door	7/16/13			Carpentry
Woodstock Middle (0185) 1B	Clock is not working.	12/11/13	Hallway/Corridor	next to room 402	Carpentry
Woodstock Middle (0185) 1B	table bracket check to see if can be remounted (wood section).	12/12/13	Classroom	409 computer	Carpentry
Woodstock Middle (0185) 1B	Tile need to be replace is loose from floor (about twenty pcs, white).	1/21/14	Cafeteria		Carpentry

Woodstock Middle (0185) 1B	Need install: Security mirror and 3'x4' tack board both in library (See teacher for location).	2/4/14	Library		Carpentry
Woodstock Middle (0185) 1B	Cover coming loose on some steps going up to second floor (old & Dangerous).	2/13/14	Stairway	by room 102	Carpentry
Woodstock Middle (0185) 1B	Were window and frame going up wall(old putting dry ,cracking is letting water come in starting mold to grow).	2/13/14	Classroom	202	Carpentry
Woodstock Middle (0185) 1B	Window glass is broken .	2/18/14	2nd Floor	202	Carpentry
Woodstock Middle (0185) 1B	ENTRANCE DOORS 500 AREA REAR, 300 AREA REAR & BETWEEN 100/300 AREAS REAR-ALL NOT CLOSING PROPERLY, WON'T BE ABLE TO SECURE-SBE HAMPTON 253-2500 1/17	8/2/13			Carpentry
Woodstock Middle (0185) 1B	Need glass repair broken out.	8/8/13	Classroom	202	Carpentry
Woodstock Middle (0185) 1B	Need whiteboard install new location .	8/8/13	Classroom	101	Carpentry
Woodstock Middle (0185) 1B	Need whiteboard install wall.	8/8/13	Classroom	307	Carpentry
Woodstock Middle (0185) 1B	Need whiteboard install on wall.	8/8/13	Classroom	402	Carpentry

Woodstock Middle (0185) 1B	Need whiteboard install.	8/9/13	Classroom	305	Carpentry
Woodstock Middle (0185) 1B	REAR ENTRANCE DOOR#2 BETWEEN RMS 101 & 102-NOT CLOSING- WON'T BE ABLE TO SECURE-SBE HAMPTON 416-353-8590 KLR	8/12/13			Carpentry
Woodstock Middle (0185) 1B	Clock will not keep right time.	8/21/13	Hallway/Corridor	by room 301	Carpentry
Woodstock Middle (0185) 1B	Entrance door from back by stairway Door closure cover broken off. #2 double doors in hallway by room 100 end cap is off doors bar down.	9/6/13	1st Floor		Carpentry
Woodstock Middle (0185) 1B	need a door put on middle stall .	9/11/13	Gym	boys locker restroom	Carpentry
Woodstock Middle (0185) 1B	door service line (insulation coming out of door small round form).	9/27/13			Carpentry
Woodstock Middle (0185) 1B	Heater old on wall one parts need to be boat back to wall.	9/27/13	Gym	lobby boys rest room.	Carpentry
Woodstock Middle (0185) 1B	CLOCK NEED TO BE REPAIRED.	11/1/13	Hallway/Corridor	by 403	Carpentry
Woodstock Middle (0185) 1B	glass broken out.	5/16/14	Classroom	305	Carpentry

Woodstock Middle (0185) 1B	FRONT ENTRANCE DOOR-LATCH NOT CATCHING-PEOPLE ARE JUST WALKING IN-PLANT MGR GAMBLE 353-8590 KLR	5/8/14				Carpentry
Woodstock Middle (0185) 1B	Window broken out (can you leave a price of the cost to repair this in office Principal need it thanks).	5/19/14	Classroom	102		Carpentry
Woodstock Middle (0185) 1B	Adjust all lab tables to ADA height.	5/28/14				Carpentry
Woodstock Middle (0185) 1B	Three light out coming in from 51 road. #2 back road one light out, #3. Road coming into school , light on corner near gym.	5/13/14	Parking Lot	coming in from 51		Electrical
Woodstock Middle (0185) 1B	Need six cover for lights (Fit two lamp by 48").	2/19/14	Gym	Boys locker room		Electrical
Woodstock Middle (0185) 1B	breaker keep tripping that keep warmer on #29. Class room wall outlet cover is broken(304).	3/24/14	Kitchen			Electrical
Woodstock Middle (0185) 1B	1.10440 Incndscnt lamps 60 Watt A-130 v qty. 50 #2. 10221 Fluorescent lamp F32T8 energe efficient lamp qut. 6 cases. #3. 10283. Gloves ,powder free vinyl exam ,Med. 2 packages. #4. 10531	3/25/14	1st Floor			Electrical
Woodstock Middle (0185) 1B	Light is not working.	4/1/14	Parking Lot	on the back by band room.		Electrical
Woodstock Middle (0185) 1B	new bulbs in the fixture. need ballast	4/2/14	Administration Area	main office		Electrical

Woodstock Middle (0185) 1B	need ballast in hallway	4/2/14	Hallway/Corridor	near asst principal	Electrical
Woodstock Middle (0185) 1B	Emergence Light By room 407 & girls rest 400 hall. (not working).	4/4/14	Hallway/Corridor		Electrical
Woodstock Middle (0185) 1B	Need time clock repaired.	4/7/14		Lawn equipment room	Electrical
Woodstock Middle (0185) 1B	Please run Test. Generator Level 2 Facilities ETSS annual load test NFPA 110	7/11/13			Electrical
Woodstock Middle (0185) 1B	kitchen back entrance door needs to be checked for ability to completely close. It's sending false security alarms CARPENTERS CHECKED THIS DOOR AND IT IS CLOSING PROPERLY	7/12/13	Administration Area		Electrical
Woodstock Middle (0185) 1B	Time clocks for the parking lot and building wall packs need to be reset.	7/16/13			Electrical
Woodstock Middle (0185) 1B	Show plant manager all electrical panels.	7/16/13			Electrical
Woodstock Middle (0185) 1B	10221 fluorescent lamp F32T8 energy efficient L.amp (4 case).	11/19/13	1st Floor		Electrical
Woodstock Middle (0185) 1B	FIRE ALARM IS SHOWING TROUBLE IN GUIDANCE OFFICE PLANT MGR- HAMPTON/873-8187	11/22/13			Electrical

Woodstock Middle (0185) 1B	LIGHT IS NOT WORKING.	12/2/13	2nd Floor	HALLWAY	Electrical
Woodstock Middle (0185) 1B	one light blank on and of.	12/3/13		413	Electrical
Woodstock Middle (0185) 1B	Supervisor trouble P R 12.	12/23/13		school	Electrical
Woodstock Middle (0185) 1B	Fire alarm pull down will not work.	1/6/14	Gym	Girls locker by back exit door	Electrical
Woodstock Middle (0185) 1B	Fire System shows a supervisory alarm.	1/10/14			Electrical
Woodstock Middle (0185) 1B	Clock is not working.	1/31/14	2nd Floor		Electrical
Woodstock Middle (0185) 1B	Exhaust fan (Ex F A1) Not working.	2/5/14		roof 400 area	Electrical
Woodstock Middle (0185) 1B	Exit light out in side (3)	2/11/14	Gym		Electrical
Woodstock Middle (0185) 1B	Exit light out.	2/11/14	Classroom	500 Band	Electrical

Woodstock Middle (0185) 1B	Emergency light not working.	2/13/14	Restroom (Girls)	400 end	Electrical
Woodstock Middle (0185) 1B	Magnet broken of door.	7/31/13	Stairway	second flour door	Electrical
Woodstock Middle (0185) 1B	Two light coming into school need repair (very high up).	8/1/13	1st Floor	entrance front	Electrical
Woodstock Middle (0185) 1B	front out side light need repair(high up).	8/1/13	Gym	front	Electrical
Woodstock Middle (0185) 1B	There light need repair(have tape on case).	8/1/13	Classroom	502	Electrical
Woodstock Middle (0185) 1B	Have three light need repair(have tape on case).	8/1/13		501	Electrical
Woodstock Middle (0185) 1B	Light need to be change out(up hight).	8/14/13		cover on back	Electrical
Woodstock Middle (0185) 1B	Phone: can,t hear other party when calling .	8/15/13		office Facilitator title one	Electrical
Woodstock Middle (0185) 1B	Door latch will not release from office so they can let people in.	8/21/13			Electrical

Woodstock Middle (0185) 1B	Latch will not release from office to let people in.	8/21/13		front.door	Electrical
Woodstock Middle (0185) 1B	#1. need fluorescent lamps(T8W. F32T8-SP41-U-6 MOD-U-line Mfg.G E) Qty ,8 (for out side front entrance). warehouse item #10221	8/26/13		school	Electrical
Woodstock Middle (0185) 1B	#1. 10525 mercury lamps ,H39-22kc/c QTY,2, #1. 10525 MERCURY LAMPS ,H39 -22C/C,175W OBLONG QTY,2	8/26/13		School	Electrical
Woodstock Middle (0185) 1B	RTU - PRIN OFC- NOT COMING ON - PM/HAMILTON 353-8590	9/6/13			Electrical
Woodstock Middle (0185) 1B	Exit lights front entrance, and side door near back road,	9/12/13	Gym		Electrical
Woodstock Middle (0185) 1B	exit lights gym floor.	9/12/13	Gym		Electrical
Woodstock Middle (0185) 1B	Two exit light out.	9/12/13	Gym	girls locker	Electrical
Woodstock Middle (0185) 1B	Emergi-lite, out in hall way, and by coach office.	9/12/13	Gym		Electrical
Woodstock Middle (0185) 1B	Exit light out.	9/12/13	Hallway/Corridor	500	Electrical

Woodstock Middle (0185) 1B	Emergi- lite out.	9/12/13	Hallway/Corridor	500	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair .	9/17/13	Gym	in front near boys rest room	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair.	9/17/13	Hallway/Corridor	left side near ketchen	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair.	9/17/13	Hallway/Corridor	front on right side by office	Electrical
Woodstock Middle (0185) 1B	Light switch need to be repair.	9/17/13	Hallway/Corridor	front entrance left side	Electrical
Woodstock Middle (0185) 1B	Emergi lite need to be repair.	9/17/13	Gym	by stage	Electrical
Woodstock Middle (0185) 1B	Want to check to see can we go a higher wattage bulbs (per principal).	9/19/13	Gym	basket ball ceiling	Electrical
Woodstock Middle (0185) 1B	Two light need to repaired	9/23/13	Basketball Court	gym	Electrical
Woodstock Middle (0185) 1B	Light is not working.	9/30/13	Hallway/Corridor	by 300	Electrical

Woodstock Middle (0185) 1B	Emergi-lite not working.	10/1/13	Hallway/Corridor	500 wall side boys rest room	Electrical
Woodstock Middle (0185) 1B	Light will not work.	10/18/13	1st Floor	Parent meeting room.	Electrical
Woodstock Middle (0185) 1B	one light out.	10/21/13	2nd Floor	hallway	Electrical
Woodstock Middle (0185) 1B	Two light out(up hight).	10/21/13	Stairway	second floor	Electrical
Woodstock Middle (0185) 1B	Emergency light need repair (fire department inspection)	11/1/13	Gym	by 601	Electrical
Woodstock Middle (0185) 1B	Verify data base in burglar alarm panel.	11/1/13			Electrical
Woodstock Middle (0185) 1B	label breaker for boiler on panel door	11/7/13			Electrical
Woodstock Middle (0185) 1B	Three pole light are not working.(we need them repaired as soon as possible for security real dark in that area will help on basketball Night).	11/14/13		road on side of gym.corner by offices	Electrical
Woodstock Middle (0185) 1B	10460 lamp, metal halide, mvr 400/u mogul base sub for 1 (need 8).	11/15/13			Electrical

Woodstock Middle (0185) 1B	10182 Deodorizer ,Dsnfctnt 14Oz aerosol can QTY. 2case.	3/27/14	1st Floor		Electrical
Woodstock Middle (0185) 1B	10182 Deodorizer Dsnfctnt 14 OZ Aerosol can QTY.2 case.	3/27/14	1st Floor		Electrical
Woodstock Middle (0185) 1B	#1.10480 Mats,floor ,3x4 Qty. 6 #2.10460 Liners compactor, Gladco 31x50.	3/28/14	1st Floor		Electrical
Woodstock Middle (0185) 1B	Light out need to be repaired.	5/22/14		Book room (400 hall way)	Electrical
Woodstock Middle (0185) 1B	GAS in SMELL in the 300' s AREA per Willie Hampton, Plant Mgr. 353.8590	3/4/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Will not let bag give access to enter .	3/6/14		school	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN RM-200 PLANT MGR- HAMPTON/353.8596	11/25/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN RM-201 PLANT MGR- WILLIE/353.8590	11/26/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Unit in MAIN OFFICE is NOT COMING ON per Willie Hampton, Plant Mgr. 353.8590	12/10/13			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	Replace heat exchanger in guidance	12/19/13		Guidance	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Unit is NOT COMING ON Room 102 per Willie Hampton, Plant Mgr. 353.8590	1/6/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT RM 205-NOT HEATING-PLANT MGR HAMPTON 353-8590 KLR	2/3/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT BANDROOM #500-NOT COMING ON-PLANT MGR HAMPTON 353-8590 KLR	2/10/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Condensation drain pipe are cut off A/C units (causing mold to grow causing problem in some of the class room).	8/8/13		second floor roof	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COOLING IN RM-308 PLANT MGR-HAMPTON/353.8596	8/8/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN B/RR 2ND FLR PLANT MGR-HAMPTON/353.8590	8/13/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C RM 200-NOT COOLING-PLANT MGR HAMPTON 353-8590 KLR	8/29/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C RMS 304, 305, 307 & PRIN'S OFC-ALL NOT COOLING & RM 308-HAS (2) UNITS ONE NOT COOLING & OTHER NOT COMING ON-PLANT MGR HAMPTON KLR	9/3/13			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	A/C RM 408-NOT COOLING-PLANT MGR HAMPTON 353-8590 KLR	9/10/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Service season four units	9/19/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C is blowing foam back through vent look like insulation (ref.to W/O 383520)	9/20/13	Kitchen		Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C unit in the kitchen is blowing out installation per Mr. Willie Hampton, Plant Mgr. 353.8590	9/23/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	WE can't get A/C vents out to clean (need help inspection report).	9/26/13	Kitchen	Service line	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C is not cooling very good in rooms 300,301,302, 303'(308 first A/C)	10/16/13	Classroom		Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Need to be checked for heating ,(100 , 106).	10/24/13	Classroom		Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Check no heat on season four unit	10/28/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT RMS 300, 301, 302, & 303-ALL NOT HEATING- PLANT MGR HAMPTON 353-8590 KLR	11/7/13			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	Replace discharge temp control	11/7/13		Seasons four	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	HEAT RM 200-NOT COMING ON-PLANT MGR HAMPTON 353-8590 KLR	11/13/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT HEATING IN PRIN OFFICE PLANT MGR- HAMPTON/353.8592	11/14/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COMING ON IN RM-200. PLANT MGR- HAMPTON/353.8592	11/15/13			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COOLING IN RM-304- THRU 307 PLANT MGR- WILLIE/873.8187	5/12/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C UNITS are NOT COOLING in ROOMS 304, 305, 306, and 307 per Willie Hampton, Plant Mgr. 353.8590	5/19/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	A/C RM 409, 410, & 411- ALL NOT COOLING- PLANT MGR CONNOR 353-8596 KLR	6/20/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	PM a/c units	6/3/14			Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT NOT COOLING IN RM-200 PLANT MGR- CONNER/353.8596	6/6/14			Heating/Ventilation /Air Conditioning

Woodstock Middle (0185) 1B	UNIT IN RM 300-308 IS NOT COOLING. SBE HAMPTON 353-8592	7/30/13				Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	UNIT IN RM 503 IS NOT COMING ON SBE HAMPTON 416-353-8590	7/12/13				Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	Service A/C on whole school	7/16/13			Whole school	Heating/Ventilation /Air Conditioning
Woodstock Middle (0185) 1B	paint peeling off wall the wood between locker.	5/20/14	1st Floor		thru out the building	Painting
Woodstock Middle (0185) 1B	Please paint classrooms on 200 hallway that has peeling/chipping paint.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please touchup paint 200 hallway.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please paint doors on 200 hallway.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please paint restrooms on 200 hallway.	6/23/14				Painting
Woodstock Middle (0185) 1B	Please paint stairwells leading to 200 hallway	6/23/14				Painting

Woodstock Middle (0185) 1B	Please paint class rooms doors Etc.	6/26/14	1st Floor		Painting
Woodstock Middle (0185) 1B	Metal post had to be replaced (need painting).	4/9/14		Bus lane near back parking lot.	Painting
Woodstock Middle (0185) 1B	Principal office need painting .	7/24/13	Administration Area		Painting
Woodstock Middle (0185) 1B	Doors need to be painted .	8/5/13	Library		Painting
Woodstock Middle (0185) 1B	out side wall brick right side need to be seal to keep water out(to keep out fungus).in side	8/5/13	Classroom	202	Painting
Woodstock Middle (0185) 1B	Can we get Front lobby rest rooms painted , written & graffiti partitions, walls)cleaning up for celebrating 100 year of service) will be happen on Oct-6-2013	9/23/13	Gym	boys and girls .	Painting
Woodstock Middle (0185) 1B	two window need to be repainted side 4' x 6' and a part at top 1' x48" (A lot of green is showing) white is the base color look like someone have been peeling the paint off look real bad	10/22/13	Gym	out side.	Painting
Woodstock Middle (0185) 1B	We have 2 faucets on 1st floor that are not working.(One in the clinic and one in the restroom.	6/10/14	Restroom (Boys)	1st floor	Plumbing
Woodstock Middle (0185) 1B	There are 3 water coolers on the 1st floor not working.	6/10/14	1st Floor		Plumbing

Woodstock Middle (0185) 1B	Water fountain spout(floor get wet).	4/14/14	Hallway/Corridor	near 301	Plumbing
Woodstock Middle (0185) 1B	Dish wash leaking water from pipe up under .	4/16/14	Kitchen		Plumbing
Woodstock Middle (0185) 1B	Gas smell reported in the storage room in science lab 400 hallway.	3/28/14			Plumbing
Woodstock Middle (0185) 1B	Urinal leaking water from top #2.	2/26/14	1st Floor	boys rest room	Plumbing
Woodstock Middle (0185) 1B	Gym toilet stopped up..	7/12/13			Plumbing
Woodstock Middle (0185) 1B	1st floor boys toilet stopped up..	7/12/13			Plumbing
Woodstock Middle (0185) 1B	NO HOT WATER FOR DISH WASHER IN KITCHEN PLANT MGR- HAMPTON/353.8592	11/19/13			Plumbing
Woodstock Middle (0185) 1B	No hot water in kitchen	11/19/13			Plumbing
Woodstock Middle (0185) 1B	Urinal stop up.	12/5/13	1st Floor	boys rest room	Plumbing

Woodstock Middle (0185) 1B	Urinal #2 leaking watering from base.	12/18/13	1st Floor	boy rest room	Plumbing
Woodstock Middle (0185) 1B	Sink stopped up janitorial room.	12/18/13	1st Floor	up front on corner	Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 957956 2" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 957875 2" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 832020 3/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 1055208 1 1/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 832044 3/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Please test the following RP 1058812 1 1/4" 975 XL	12/18/13			Plumbing
Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	Near 103	Plumbing

Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	near 106	Plumbing
Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	near 406	Plumbing
Woodstock Middle (0185) 1B	Faucet girls rest room.	1/13/14	1st Floor	hall way 400	Plumbing
Woodstock Middle (0185) 1B	Repair water fountain.	1/13/14	1st Floor	By cafetria	Plumbing
Woodstock Middle (0185) 1B	Repair faucet.	1/13/14	1st Floor	Clinic Rest room	Plumbing
Woodstock Middle (0185) 1B	Unstop sink Brake room.	1/13/14	1st Floor	Main Bldg.	Plumbing
Woodstock Middle (0185) 1B	Urinal leaking from top (#2).	1/14/14		boys rest room near Library	Plumbing
Woodstock Middle (0185) 1B	Unstop sink.	1/14/14	Kitchen	Janitor	Plumbing
Woodstock Middle (0185) 1B	Water fountain leaking water (leaking from turn off).	1/16/14	1st Floor	near 106	Plumbing

Woodstock Middle (0185) 1B	Commode need replace broken .	2/6/14	Restroom (Boys)	400 area	Plumbing
Woodstock Middle (0185) 1B	repair #3 commode locker room.	7/31/13	Gym	girls rest	Plumbing
Woodstock Middle (0185) 1B	Commode seat need replace #1, #2 & #5 stall.	7/31/13	Gym	girls rest	Plumbing
Woodstock Middle (0185) 1B	REpair commode #3.	7/31/13	Restroom (Girls)	300 hall way	Plumbing
Woodstock Middle (0185) 1B	repair commode seat.	7/31/13	Restroom (Girls)	400 hall	Plumbing
Woodstock Middle (0185) 1B	Repair first commode.	8/1/13	Gym	boys locker room	Plumbing
Woodstock Middle (0185) 1B	Handicap faucet need repair.	8/7/13	Restroom (Boys)	second floor	Plumbing
Woodstock Middle (0185) 1B	Faucet need repair.	8/7/13	Restroom (Boys)	gym up front	Plumbing
Woodstock Middle (0185) 1B	Repair commode.	8/7/13	Gym	boys locker	Plumbing

Woodstock Middle (0185) 1B	Repair drain lines to A/C units on main building	9/5/13		RTU's on main building	Plumbing
Woodstock Middle (0185) 1B	commode #3 need repair .	9/11/13	Gym	boys locker restroom	Plumbing
Woodstock Middle (0185) 1B	Urinal #3 will not running water.	9/19/13	Restroom (Boys)		Plumbing
Woodstock Middle (0185) 1B	#4 leaks from base. last W/O same location.	9/19/13	Restroom (Boys)	by library	Plumbing
Woodstock Middle (0185) 1B	#3 urinal leaks from spud.	9/19/13	Restroom (Boys)	by library	Plumbing
Woodstock Middle (0185) 1B	Need handicap faucet replaced .	9/23/13	Gym	Boys up front	Plumbing
Woodstock Middle (0185) 1B	Commode broken (need a new one).	9/25/13	2nd Floor	boys	Plumbing
Woodstock Middle (0185) 1B	Three spout need to be checked for clogged.	9/25/13		front entrance of school	Plumbing
Woodstock Middle (0185) 1B	3 comp sink need to be checked for cold water (for inspection report complain).	9/25/13	Kitchen		Plumbing

Woodstock Middle (0185) 1B	Drain clog up (steamer)	9/30/13	Kitchen		Plumbing
Woodstock Middle (0185) 1B	Faucet middle when water in turn on vibrate loud disturb classes .	10/2/13	Restroom (Boys)	500 area	Plumbing
Woodstock Middle (0185) 1B	first urinal stop-up.	11/11/13	Restroom (Boys)	first floor	Plumbing
Woodstock Middle (0185) 1B	Shower need repair.	11/12/13	Gym	locker boys	Plumbing
Woodstock Middle (0185) 1B	Need to check hot water.	11/12/13	Gym		Plumbing
Woodstock Middle (0185) 1B	Check shower head.	11/12/13	Gym	locker giral	Plumbing
Woodstock Middle (0185) 1B	Drinking fountain need repair.	11/12/13	Gym	locker girls	Plumbing
Woodstock Middle (0185) 1B	NO HOT WATER TO KITCHEN-PLANT MGR HAMPTON 353-8590 KLR	11/18/13			Plumbing
Woodstock Middle (0185) 1B	Commode seat need to be repaired .	5/8/14	2nd Floor	boys rest room	Plumbing

Woodstock Middle (0185) 1B	Small urinals are clogged up.	5/12/14	1st Floor	& Second floor, Boys	Plumbing
Woodstock Middle (0185) 1B	Water fountain loose from wall and leaking water.	5/19/14	Hallway/Corridor	near 102	Plumbing
Woodstock Middle (0185) 1B	Urinal leaking water real bad.(middle).	5/21/14	Restroom (Boys)	Locker	Plumbing
Woodstock Middle (0185) 1B	Commode clogged ,(Middle one).	5/22/14	Gym	boys locker rest room	Plumbing
Woodstock Middle (0185) 1B	Water leaking from pipe under dish washer .	4/29/14	Kitchen		Plumbing
Woodstock Middle (0185) 1B	HOT WATER HEATER KITCHEN AREA-NOT WORKING-PLANT MGR HAMPTON 353-8590 KLR	3/21/14			Plumbing
Woodstock Middle (0185) 1B	W/O 431829(is for Woodstocs Middle)	4/24/14		Near 106	Plumbing
Woodstock Middle (0185) 1B	NO HOT WATER THRU BLDG PRIN-DEBRE/353.8590	11/18/13			Plumbing
Woodstock Middle (0185) 1B	Water running on wall next to street.	3/20/14		office (Mitchll)	Roof

Woodstock Middle (0185) 1B	Water leaking.	2/18/14	Hallway/Corridor	by 308 Across from center water fountain .	Roof
Woodstock Middle (0185) 1B	Coming in entrance door from hallway on boys rest room side(water leaking over # 7 shelf).	2/18/14	Library		Roof
Woodstock Middle (0185) 1B	Leaking water about center of room.	9/17/13	Classroom	413	Roof
Woodstock Middle (0185) 1B	Water leaking down wall (can see brown stain on wall)	9/17/13	Cafeteria	entrance hallway	Roof
Woodstock Middle (0185) 1B	Water leaking thru ceiling.	9/25/13		office	Roof
Woodstock Middle (0185) 1B	When coming into room second light on right .	9/25/13	Classroom	400	Roof
Woodstock Middle (0185) 1B	Leaking water right side of vent about two feet from wall.	11/7/13	Classroom	413	Roof
Woodstock Middle (0185) 1B	Wire need to be repaired (from ice storm damage).	4/21/14	Athletic Field	Base ball .	Sheet Metal
Woodstock Middle (0185) 1B	Metal post and chain need to be repair.	4/2/14		bus lane back of school	Sheet Metal

Woodstock Middle (0185) 1B	Hallways #400 there is a number of lockers need repairing . WE NEED LOCKER NUMBERS	11/25/13			Sheet Metal
Woodstock Middle (0185) 1B	Lockers numbers '883 ,881 (ref #3995630	12/2/13	Hallway/Corridor	400	Sheet Metal
Woodstock Middle (0185) 1B	3 cart need to be repaired (used to move food).	1/6/14	Kitchen		Sheet Metal
Woodstock Middle (0185) 1B	Make metal for carpenter crew (see Marshall Stutes)	9/30/13			Sheet Metal