

Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

November 10, 2020

RE: Addendum #1: IFB#11172020 – SCS District-Wide Chemical Treatment Services

Dear Bidders:

This Addendum forms a part of the Contract Documents and modifies the Plans and Specifications dated October 20, 2020. The Contractor shall acknowledge receipt of this Addendum on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Item #1

Scope of Work– Clean cooling tower hot deck, fills and cold deck. Coordinate with SCS to satisfy completion of fall and spring schedule of SCS locations.

Item #2

Scope of Work– Provide five (5) portable meter conductivity, resistivity, PH balance, TD's and temperature 6P.

Item #3

Scope of Work– Contractor responsible for blow down operation & replacement when bad. Must replace with fast acting blow down.

Thank you,

Procurement Services.