



DEPARTMENT OF PROCUREMENT SERVICES

160 South Hollywood Street • Room 126 • Memphis, TN 38112 • (901) 416-5376

January 13, 2021

Addendum Wiring Specifications

Required wiring for this project must be - Cat6 Plenum rated cabling.

Thank you.
Procurement Services
Shelby County Schools