

Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB01032024JKG-F Raleigh Egypt HS HVAC

- 1. Didn't see fan coil units on prints or equipment schedule? Please survey the building.
- 2. Are all Reheat coils getting replaced? Yes
- 3. Unit Heaters in the gym getting replaced? Yes
- 4. Unit heaters in and RTUS on ROTC building getting replaced?
- 5. Are you looking for CO2, RH and Room temp for BAS?
- 6. Is there heat trace that needs to be replaced? Yes

General Questions

Pg. 66 Design and Construction Guidelines state the following: "Any new projects or renovations must include new and upgraded DDC controls for any new or existing HVAC equipment for the entire site, but the Bid says different things."

Please follow what was stated in the Bid.

Will SCS assist with equipment storage in the case of winning several Bids? ${\color{red}No}$

On previous MSCS design & build RFPs, we were provided with Total Square Footage of the facility. Please provide this information again.

Please see below:

<u>Location</u>	Sq Ft
Cherokee ES	61,286
Getwell ES	87,025
Gragg Tech Training Center	38,208
Idlewild ES	65,025
Overton HS	177,940
Raleigh Egypt HS	145,850
Whitehaven HS	212,776