



QUESTIONS AND ANSWERS (February 5, 2021)

RFQ - Needlepoint Bipolar Ionization Design, Procure, Install & Recommission (RFQ #021121GJ)

- 1) On the cover sheet, it mentions that this request for qualifications will ONLY be accepted electronically in ESM. Then on page 5, (6.0 Submission Deadline) it mentioned that RFQs can be delivered by hand to 160 S Hollywood, RM 126. We would like to clarify how bids are being received?
Answer: Please see Addendum 1 for this solicitation on SCS Procurement website. **Please note that a response to this solicitation must be mailed or delivered to 160 S. Hollywood Street, Room 126, Memphis, TN 38112, per Part II, 6.0 Submission Deadline.**
- 2) Based off 1.2 System Performance sections A thru O, do you have a list of NPBI manufactures that are approved to provide the NPBI devices on this project? **Answer:** No. Vendor must follow specifications detailed in this RFQ.
- 3) Based off 1.2 System Performance section L, will there be a requirement to use the alarm contact to tie into the existing BAS system? **Answer:** Vendor must follow requirements and connect to unit controller.
- 4) Is there a timeline available after award of the RFQ that the pricing negotiation will begin? **Answer:** Pricing negotiation will begin after awarded vendor conducts equipment surveys and any other necessary due diligence work to solidify requirements of the project.
- 5) Based off 3.1 pre construction services mentions final estimate and GMP, is pricing to be included in this RFQ response or only after award of RFQ? **Answer:** Cost for services is not to be included in the respondent's submission.
- 6) Based off 1.1 it mentions test and balance reports being recommended, is the contractor to present those findings to SCBE or will the contractor be expected to make recommended repairs found in test/balance reporting? **Answer:** Identify and note to SCS.
- 7) Will SCBE provide a mechanical equipment list for this project once an RFQ partner is awarded? **Answer:** This will be the vendor's responsibility to build list from field surveys.
- 8) Will there be a required percentage of MBE/MWBE required on this RFQ? **Answer:** A MBE/MWBE participation goal was not set for this project.
- 9) Is the intent of the RFQ to award to one vendor or is there a possibility multiple partners could be chosen? **Answer:** It is the intent to select one vendor from the RFQ.
- 10) What is the timeline of award from submission date of February 11th? **Answer:** TBD