

2010 FACILITIES ASSESSMENT
 NORRIS ROAD ELEMENTARY





Project Data	
Location Code:	45
Address:	1490 Norris Rd
Year Built:	1961
Grade Configuration:	K-5
Student Capacity:	500
Ideal Capacity:	403
ADA Student Enrollment:	259
Size:	0
Portables:	15.3 acres
Building & Addition	0
	52,000 s. f.

2010 FACILITIES ASSESSMENT


NORRIS ROAD ELEMENTARY


Description: Upgrade to ADA guidelines	
Timeline: 2010-11	Cost: \$612,000


Description: Exterior paint in poor condition.	
Timeline: TBD	Cost: \$145,000

Description: Window system is old, rusting and does not operate properly in certain areas.	
Timeline: TBD	Cost: \$800,000


2010 FACILITIES ASSESSMENT
NORRIS ROAD ELEMENTARY


Description: Interior paint in classrooms in poor condition.	
Timeline: TBD	Cost: \$81,000

Description: Restroom stall doors are missing.	
Timeline: TBD	Cost: \$2,000

Description: Dumpsters (2) have no enclosures.	
Timeline: TBD	Cost: \$10,000

2010 FACILITIES ASSESSMENT NORRIS ROAD ELEMENTARY

<p>Description:</p> <p>PVC Single ply roof: 11 years-fair</p>	
<p>Timeline:</p> <p>TBD</p>	<p>Cost:</p> <p>\$165,000</p>

<p>Description:</p> <p>Intercom System: Bogen MCP35A Installation Date: 2000</p>	
<p>Timeline:</p> <p>TBD</p>	<p>Costs:</p> <p>\$50,000</p>