



Environmental Hazards Services, L.L.C.
 7469 Whitepine Rd
 Richmond, VA 23237
 Telephone: 800.347.4010

Asbestos Bulk Analysis Report

Report Number: 22-08-03360

Client: National Econ Corp.
 4515 Poplar Ave., Ste. 425
 Memphis, TN 38117

Received Date: 08/17/2022
 Analyzed Date: 08/17/2022
 Reported Date: 08/17/2022

Project/Test Address: SCS - Cummings

Client Number:
 44-2606

Laboratory Results

Fax Number:
 901-767-2466

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
22-08-03360-001	S-1		Beige Paint-Like; Beige/White Granular; Inhomogeneous	NAD	100% Non-Fibrous
22-08-03360-002	S-2		Beige Paint-Like; Beige/White Granular; Inhomogeneous	NAD	100% Non-Fibrous
22-08-03360-003	S-3		Beige Paint-Like; Beige/White Brittle; Inhomogeneous	NAD	100% Non-Fibrous

Environmental Hazards Services, L.L.C

Client Number: 44-2608
 Project/Test Address: SCS - Cummings

Report Number: 22-08-03360

Lab Sample Number	Client Sample Number	Layer Type	Lab Gross Description	Asbestos	Other Materials
-------------------	----------------------	------------	-----------------------	----------	-----------------

QC Sample: 47-M22018-1
 QC Blank: SRM 1866 Fiberglass
 Reporting Limit: 1% Asbestos
 Method: EPA Method 600/R-93/116, EPA Method 600/M4-82-020
 Analyst: Keleigh King

Reviewed By Authorized Signatory:



Tasha Eaddy
 QA/QC Clerk

The condition of the samples analyzed was acceptable upon receipt per laboratory protocol unless otherwise noted on this report. Each distinct component in an inhomogeneous sample was analyzed separately and reported as a composite. Results represent the analysis of samples submitted by the client. Sample location, description, area, volume, etc., was provided by the client. This report cannot be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government. This report shall not be reproduced except in full, without the written consent of the Environmental Hazards Service, L.L.C. California Certification #2319 NY ELAP #11714 NVLAP #101882-0 VELAP 460172. All information concerning sampling location, date, and time can be found on Chain-of-Custody. Environmental Hazards Services, L.L.C. does not perform any sample collection.

Environmental Hazards Services, L.L.C. recommends reanalysis by point count (for more accurate quantification) or Transmission Electron Microscopy (TEM), (for enhanced detection capabilities) for materials regulated by EPA NESHAP (National Emission Standards for Hazardous Air Pollutants) and found to contain less than ten percent (<10%) asbestos by polarized light microscopy (PLM). Both services are available for an additional fee.

400 Point Count Analysis, where noted, performed per EPA Method 600/R-93/116 with a Reporting Limit of 0.25%.

* All California samples analyzed by Polarized Light Microscopy, EPA Method 600/M4-82-020, Dec. 1982.

LEGEND: NAD = no asbestos detected

Same Day

ENVIRONMENTAL HAZARDS SERVICES, LLC

Asbestos Chain of Custody Form

Pg. ___ of ___

Company Name	National Econ	Account #	
Company Address	4515 Poplar Ave #4125	City/State/Zip	Memphis, TN 38116
Phone	901-834-2199	Email	Cderwinne@earthlink.net
Project Name/Test Address	SES. Cummings		
PO Number		Collected By	BCS
Turn-Around Time	<input checked="" type="checkbox"/> 1 DAY	<input type="checkbox"/> 2 DAY	<input type="checkbox"/> 1 DAY

SAME DAY OR WEEKEND - Must Call Ahead

PLM New York Protocol

PLM New Jersey Protocol

PLM South Carolina Protocol

LAB NUMBER	Client Sample ID	Homogeneous Area	Positive Stop	Collection Date & Time	BULK			AIR			COMMENTS	
					PLM	Point Count 400	Point Count 1000	TEM Bulk	PCM	TEM AHERA		NIOSH 7402
1	S-1	X		8/16/22	X							Ceiling
2	S-2	X			X							
3	S-3	X			X							
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												


Released By: Nelta Cooper Date: 8/16/22 Time: 10:15
 Signature: Nelta Cooper

LAB USE ONLY - BELOW THIS LINE

Received By: TAM
 Signature: _____
 Date: 8/17/22 Time: 9:23 AM PM

Portal Contact Added
 7469 WHITEPINE RD, RICHMOND, VA 23237 (800)-347-4030
 RESULTS VIA CLIENT PORTAL AVAILABLE @ www.leadlab.com

22-08-03360



Due Date:
08/17/2022
(Wednesday)
AE

KEK

3/2/22