



THE OFFICE OF FACILITY MAINTENANCE

1364 Farmville Road • Memphis, TN 38112 • (901) 416-9670 • www.scsk12.org

Attachment 'B'

DATE: September 19, 2025

To:

From: Shonda Morrow, Environmental Health & Safety Manager

Subject: Berclair ES

In accordance with Asbestos Hazard Emergency Response Act (AHERA) the following building materials have been identified as ACM. The following materials were identified in accordance with AHERA regulations. Any activity that requires the demolition or repairs either exterior or interior, of any building components, is required to be sampled by a certified and accredited asbestos inspector.

1. 12x12 Floor Tile
2. Cement Elbows & Tee
3. Pipe Insulation
4. Floor Tile Mastic
5. 9x9 Floor Tile (Removed per 6/18/2001 3 yr Insp Report)

It is recommended that samples are taken and tested before any work is completed, to ensure that ALL areas have been identified by a certified and accredited asbestos inspector.

Please contact me via email MorrowS@scsk12.org and let me know if I can be of any further assistance.