



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

October 7, 2022

RE: Questions and Answers: **IFB#10122022LB Mitchell HS & Gardenview ES Chiller Replacements**

1. Is it required for us to hire engineers and or architects for these projects?

Not in this case, but all associated permits must be pulled

2. Is 3rd part commissioning required for these projects?

Not for these projects

3. What are the labor time restriction i.e. weekends , past 5 p.m. If there are equipment lead time delays and weather permitting delays

All work after hours must be coordinated the Master HVAC. School operation cannot be interrupted during school hours.

4. Will existing piping to new chiller need to be welded or can victaulic piping and fittings be made from chiller to the existing connections ?

Modify piping as needed and follow MSCS design guide.

Thank you,
Procurement Services