



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB 052126LR Richland ES Building & Drainage Improvements

1. Will we be putting film on the transoms?

Response: Yes

2. Please specify the type of film. Normally, it's 3M Ultra 800 with an attachment system.

Response: The film is required to meet ASTM F3561-22. The film must be attached with all mandatory attachment systems, glass framing requirements, installation conditions, and materials according to the manufacturer to meet ASTM F3561-22. Film to be 3M Scotchshield Security Window Film S2400 or equal. Substitutions are to be submitted for approval to the owner and architect.

3. All doors and sidelights (windows next to the doors) already have film on them. Are we replacing?

Response: Yes

4. Are we including the accessible windows in the breezeway? See attachment.

Response: All windows on all breezeways and ground level windows are to receive film to meet ASTM F3561-22.