



Department of Procurement Services

160 South Hollywood Street · Room 126 · Memphis, TN 38112 · (901) 416-5376

QUESTIONS AND ANSWERS

IFB# 03072023JG Alcy ES Upgrades

- 1. Please provide as built showing all the hallways and stairways.**
Hallways are to be painted from a height of 4'-0" above finished floor to ground.
Stairwells to be painted in their entirety. Colors to be determined. As-built drawings are attached. (See Addendum 1)
- 2. Please provide linear footage or indicate a start to finish point on google earth. Per walkthrough, the existing wood fence goes further than just the west and north sides.**
This scope item includes approximately 1,500 linear feet of fencing.
- 3. Are we to match the exterior door release button? Also, do we need to include a card reader as the exterior door?**
Yes, please match the exterior door release button.
- 4. Should this wall include seismic bracing ties to the existing building wall to support it? If so, please provide details.**
Yes, this new wall shall be seismically braced and tied to the existing wall. Please follow all applicable construction codes. There are no details.
- 5. Do the upgrades include a hardwood gym floor?**
No, the upgrades do not include a hardwood gym floor.
- 6. My company builds bleachers / telescopic seating. It says Aluminum Bleachers and gives the measurements, but do you know WHAT bleacher manufacturers you all approve? I just want to see if I would need to provide a substitution request also, in addition to my bid.**
Our base specification for Irwin Seating Company's telescopic bleachers with plastic seating on Model 4500 steel understructure

Thank you,

Procurement Services