



THE OFFICE OF FACILITY MAINTENANCE

1364 Farmville Road • Memphis, TN 38112 • (901) 416-9670 • www.scsk12.org

Attachment 'B'

DATE: August 11, 2026

To:

From: Shonda Morrow, Environmental Health & Safety Manager

Subject: Scenic Hills ES

In accordance with Asbestos Hazard Emergency Response Act (AHERA) the following building materials have been identified as ACM. The following materials were identified in accordance with AHERA regulations. Any activity that requires the demolition or repairs either exterior or interior, of any building components, is required to be sampled by a certified and accredited asbestos inspector.

1. 9x9 Floor Tile- Bldg. 1,2
2. Floor Tile Mastic- Bldg. 1,2
3. 12x12 Floor Tile- Bldg. 2
4. Ceiling Tile Glue- Bldg. 1

It is recommended that samples are taken and tested before any work is completed, to ensure that ALL areas have been identified by a certified and accredited asbestos inspector.

Please contact me via email Morrow@scsk12.org and let me know if I can be of any further assistance.